



Sri Manakula Vinayagar Medical College and Hospital

Complaint Status Report From 01-01-2020 To 31-12-2022

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
College Name : SMVMCH-HOS								
Work Type : Complaint								
Dept Name : Administration - Civil - Maintenance								
Comp. Dt. : 20/01/2020								
Status : Completed								
1	20010485	AO Office	TAP BROKEN - WATER LEAKAGE AT WASHING AREA	Rajendran. R.	Wrong complaint, 3rd floor 6" pipe line leakage problem in POW, floor breaking and pipe line rework		Karthik. K. - Administration	21/01/2020
Comp. Dt. : 22/02/2020								
Status : Completed								
2	20020846	AO Office	GENTS REST ROOM GUN NOT WORKING - WATER FLOW	Prakash. V.	Health faucet rework, work completed		Kadhiravan. C. - Administration	22/02/2020
Comp. Dt. : 26/03/2020								
Status : Completed								
3	20030782	Dialysis	TAP BROKEN WATER LEAKAGE - BACKSIDE OF DIALYSIS	Prakash. V.	1.1/2" pipe line broken, door elbow changed, rework the pipe line, problem solved		Gomathy. K. - Administration	26/03/2020
Comp. Dt. : 11/06/2020								
Status : Completed								
4	20060317	AO Office	IN REST ROOM-BAD SMELL PROBLEM	Prakash. V., Arunagiri. V., Ramkumar. R.	Pipe line broken, rework the pipe line, work completed		Karthik. K. - Administration	11/06/2020
Comp. Dt. : 22/06/2020								
Status : Completed								
5	20060620	AO Office	HAND SHOWER NOT WORKING AT FEMALE REST ROOM	Manikandan. S.	Health faucet full set rework, work completed		Kanimozhi. D. - Administration	22/06/2020
Comp. Dt. : 24/06/2020								
Status : Completed								
6	20060672	AO Office	WATER COOLER LEAKAGING PROBLEM	Prakash. V.	A/C dept complaint, Hot & Cold machine new drain line to be fixing work, so msg forward to A/C dept		Gomathy. K. - Administration	24/06/2020

TRUE COPY ATTESTED

DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHAKUPPAM,
MADAGADIPEI, PUDUCHERRY-605 102.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 27/06/2020 Status : Completed								
7	20060760	Dining Hall	WATER LEAKAGE AT GROUND FLOOR RECEPTION BACKSIDE DINING HALL	Prakash. V.,Ramkumar. R.,Manikandan. S.	4" pipe line 1 length changed, leakage arrested, but A/C drain line leakage problem, inform to Mr.Ra		Sathiyamoorthy. D. - Administration	04/07/2020
Comp. Dt. : 04/07/2020 Status : Completed								
8	20070090	AO Office	BACKSIDE WASHING AREA TAP REPAIR - NEED TO CHANGE	Prakash. V.,Abdul Azees. J.,Sellaveeran. M.	Backside water Pipe line refixed in properly, leakage arrested, work completed		Gomathy. K. - Administration	06/07/2020
Comp. Dt. : 17/07/2020 Status : Completed								
9	20070409	AO Office	NEED REPAIRING WORK FOR TAP - BROKEN AT BACKSIDE WASHING AREA	Prakash. V.	Pipe line rework and clamp fixed, work completed		Lester. Rodgers - Civil - Maintenance	20/07/2020
Comp. Dt. : 10/09/2020 Status : Completed								
10	20090183	AO Office	water not coming-1136	Prakash. V.,Rajendran. R.,Ramkumar. R.	POW to be ready in covid ward purpose, 8 nos of bathroom plumbing fittings fixed, so valve closed, a		Karthik. K. - Administration	12/09/2020
Comp. Dt. : 18/09/2020 Status : Completed								
11	20090354	AO Office	WASH BASIN SINK LEAKAGING PROBLEM IN DINING HALL	Abdul Azees. J.,Rajendran. R.,Prakash. V.	Wash basin waste line fully rework, work completed		Gomathy. K. - Administration	19/09/2020
Comp. Dt. : 25/09/2020 Status : Completed								
12	20090523	AO Office	wash basin sink waste line leakaging problrm	Ramkumar. R.	1.1/4" Waste line fully rework, work completed, work completed		Gomathy. K. - Administration	26/09/2020
Comp. Dt. : 03/12/2020 Status : Completed								
13	20120117	AO Office	RAINWATER PIPE LINE BROKEN - WATER FLOW - BACK SIDE OF AO OFFICE - NEED URGENT SERVICE	Prakash. V.,Sellaveeran. M.,Sankar. V.	2nd floor Dialysis backside sunshade rain water water stagnation, water removed and cleaned that pla		Kadhiravan. C. - Administration	03/12/2020

TRUE COPY ATTESTED
19/09/2020

CLEAN
SRIMANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
MADAGADIPEI, PUDUCHERRY-605 007.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 07/12/2020 Status : Completed								
14	20120292	AO Office	RAIN WATER LEAKAGE AT BACK SIDE OF WASHING AREA - NEED URGENT SERVICE	Prakash. V.,Manikandan. S.,Rajendran. R.	Due to heavy rain, 6" pipe line rework, leakage arrested, work completed		Gomathy. K. - Administration	10/12/2020
Comp. Dt. : 09/12/2020 Status : Completed								
15	20120386	AO Office	FLUSH WATER NOT COMING AT REGISTRAR RESTROOM - NEED URGENT SERVICE	Prakash. V.	Flush tank full set rework, float washer changed, work completed		Kanimozhi. D. - Administration	09/12/2020
Comp. Dt. : 09/01/2021 Status : Completed								
16	21010335	AO Office	NEED CLEANING WORK FOR RECORD ROOM [RAT DEATH]	Rajendhiran. V.	Dead rat removed, cleaned that place		Elumalai.K.A. - Administration	09/01/2021
Comp. Dt. : 11/01/2021 Status : Completed								
17	21010381	AO Office	NEED CLEANING WORK FOR FALSE CEILING AT RECORD ROOM [RAT DEATH] NEED URGENT SERVICE	Arunagiri. V.,Rajendhiran. V.,Thanuzkodi. E	Our technician check that place, we are not found the rat, msg forward to A/C dept and workshop		Elumalai.K.A. - Administration	11/01/2021
Comp. Dt. : 12/02/2021 Status : Completed								
18	21020469	AO Office	MALE REST ROOM BLOCK	Rajendhiran. V.	Toilet block removed, work completed on that day		Kadhiravan. C. - Administration	13/02/2021
Comp. Dt. : 04/03/2021 Status : Completed								
19	21030203	AO Office	SINK WATER LEAKAGE IN DINNING ROOM	Rajendran. R.,Manikandan. S.,Sellaveeran. M.	Angle valve rework and refixed in properly, problem solved		Kanimozhi. D. - Administration	04/03/2021
Comp. Dt. : 27/03/2021 Status : Completed								
20	21031048	AO Office	SINK BLOCK AT MALE RESTROOM	Rajendhiran. V.	Sink block removed, work completed		Kadhiravan. C. - Administration	27/03/2021
Comp. Dt. : 30/07/2021 Status : Completed								

13/02/2021
TRUE COPY ATTESTED
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 (MCH) KUTHALAKUPPAM,
 MADAGADI PET, PUDUCHERRY-605 107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
21	21070986	COVID CONTROL ROOM	NEED LABOURS FOR SHIFTING WORK	Pandiaraj. V., Yuvaraj. M., Thulasi. V.	Shifting work completed		Kanimozhi. D. - Administration	30/07/2021
	Comp. Dt. : 17/08/2021							
	Status : Completed							
22	21080567	AO Office	WASH BASIN BLOCK	Rajendhiran. V.	Wash basin block removed, work completed		Gomathy. K. - Administration	17/08/2021
	Comp. Dt. : 21/08/2021							
	Status : Completed							
23	21080723	AO Office	RAIN WATER BLOCK - WATER LEAKAGE AT BACK SIDE OF AO OFFICE- [AC GENERATOR SIDE]	Prakash. V., Arunagiri. V., Manikandan. S.	Rain water removed and block removed, work completed		Karthik. K. - Administration	21/08/2021
	Comp. Dt. : 28/08/2021							
	Status : Completed							
24	21080999	AO Office	RAIN WATER BLOCK - BACK SIDE OF AO OFFICE	Prakash. V., Arunagiri. V., Rajendran. R.	2nd floor flooring cement pointing work done, rain water line rework, leakage arrested, block remove		Siva. E. - Administration	28/08/2021
	Comp. Dt. : 29/09/2021							
	Status : Completed							
25	21091081	AO Office	WASHBASIN BLOCK - DINING HALL BACKSIDE	Prakash. V., Manikandan. S., Arunagiri. V.	Wash basin waste water outlet line fully rework, block removed, work completed		Gomathy. K. - Administration	29/09/2021
	Comp. Dt. : 24/12/2021							
	Status : Completed							
26	21120973	AO Office	WASHBASIN WATER LEAKAGE PROBLEM	Prakash. V., Rajendran. R., Ramkumar. R.	Wash basin outlet line fully rework, work completed		Santhosh Raja. K. - Administration	
	Comp. Dt. : 27/01/2022							
	Status : Completed							
27	22010666	AO Office	SINK BLOCK IN MALE RESTROOM	Prakash. V.	Sink block removed, waste water line rework, work completed		Kadhiravan. C. - Administration	27/01/2022
28	22010671	Chairman Office	NEED TO CHANGE RESTROOM TAP - WATER LEAKAGE IN VC SIR OFFICE RESTROOM - NEED URGENT SERVICE	Prakash. V., Manikandan. S., Rajendran. R.	New Jaquar CP health faucet - 1 No changed, work completed		Sadhasivam. K. - Administration	31/01/2022
	Comp. Dt. : 25/02/2022							

TRUE COPY ATTESTED

TRUE COPY ATTESTED

TRUE COPY ATTESTED

DEAN
24/12/2021
VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
MAUDAGADIPEET, PUDUCHERRY-605 107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
29	22020822	AO Office	DUE DEAD OF RAT - NEED CLENING WORK AT RECORD ROOM	Rajendhiran. V.,Govindan. R.,Sakthivel. E.	Rat removed and cleaned that place with housekeeping labours		Elumalai.K.A. - Administration	26/02/2022
Comp. Dt. : 01/03/2022								
Status : Completed								
30	22030010	Chairman Office	WATER LEAKAGE IN CHAIRMAN OFFICE CONFERENCE HALL RESTROOM	Prakash. V.,Ramkumar. R.,Arunagiri. V.	Health faucet leakage problem, New CP Health faucet 1No changed, work completed		Sadhasivam. K. - Administration	04/03/2022
Comp. Dt. : 08/03/2022								
Status : Completed								
31	22030249	AO Office	NEED TO CHANGE WASH BASIN TAP - WATER LEAKAGE	Ramkumar. R.	SS Sink tap spindle changed, work completed		Santhosh Raja. K. - Administration	08/03/2022
Comp. Dt. : 24/03/2022								
Status : Completed								
32	22030979	AO Office	NEED TO CHANGE REST ROOM OUTLET WATER FILLTER - BLOCK - AT S A O SIR ROOM	Thanuzkodi. E	SAO Sir room toilet block removed,work completed		Karthik. K. - Administration	24/03/2022
Comp. Dt. : 30/03/2022								
Status : Completed								
33	22031230	AO Office	STAFF REST ROOM BLOCK	Rajendhiran. V.	Toilet block removed, work completed		Santhosh Raja. K. - Administration	31/03/2022
Comp. Dt. : 20/04/2022								
Status : Completed								
34	22040699	AO Office	ICE WATER NOT COMING IN COOLER	Ramkumar. R.	Informed to AC department.		Karthik. K. - Administration	20/04/2022
Comp. Dt. : 22/04/2022								
Status : Completed								
35	22040806	AO Office	FLUSH WATER LEAKAGE & RESTROOM BLOCK AT "S A O" SIR ROOM	Prakash. V.,Thanuzkodi. E.,Rajendhiran. V.	Flush tank fullset cleaned and serviced, Toilet block removed,work completed		Santhosh Raja. K. - Administration	23/04/2022
Comp. Dt. : 30/04/2022								
Status : Completed								
36	22041115	Reception	NEED TO SPRAY " TERMITE SPREY" FOR SWAMY PHOTO BACKSIDE	Kannan. V.	AGM Inform to Project Manager Mrs. Sivapoosanam (Civil admin)		Sathiyamoorthy. D. - Administration	07/07/2022
Comp. Dt. : 04/05/2022								

20/04/2022
TRUE COPY ATTESTED

DEAN
SRIMANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
MADAGADIPET, PUDUCHERRY-605 107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
37	22050082	AO Office	NEED TO CHANGE HAND SHOWER FOR REGISTRAR ROOM [DAMAGE - WATER LEAKAGE]	Prakash. V.	New health faucet changed.		Kanimozhi. D. - Administration	04/05/2022
Comp. Dt. : 18/05/2022								
Status : Completed								
38	22050680	Main Gate	NEED LABOURS 4 NOS FOR UNLOADING PAPER BUNDALS FROM GATE TO BASEMENT STORE	Pandiaraj. V.,Yuvaraj. M.,Thulasi. V.	Paper bundle unloading work completed		Motheeswarar. R.S. - Administration	21/05/2022
Comp. Dt. : 14/06/2022								
Status : Completed								
39	22060500	AO Office	NEED TO REFIX HAND SHOWER FOR FEMALE STAFF REST ROOM	Arunagiri. V.	Health faucet fixed.		Kanimozhi. D. - Administration	23/06/2022
Comp. Dt. : 27/06/2022								
Status : Completed								
40	22060968	AO Office	MALE RESTROOM BLOCK - NEED URGENT SERVICE	Rajendhiran. V.	Block removed.		Santhosh Raja. K. - Administration	28/06/2022
Comp. Dt. : 15/07/2022								
Status : Completed								
41	22070602	General Stores[Linen]	NEED TO CHECK DUCT PIPE LINE - WATER LEAKAGE INSIDETHE STORE	Prakash. V.,Rajendran. R.,Manikandan. S.	Special clinic #100 - duct line block, so floor leakage problem, duct line fully rework, leakage arr		Motheeswarar. R.S. - Administration	16/07/2022
Comp. Dt. : 22/07/2022								
Status : Completed								
42	22070829	AO Office	DUE TO HEAVY RAIN METAL RUBBY SHEET IN BACK SIDE OF AO OFFICE FELL DOWN NEED TO REFIX	Pandiaraj. V.,Thulasi. V.,Prakash. N.	Metal rubby sheet shifted.		Gomathy. K. - Administration	26/07/2022
Comp. Dt. : 03/08/2022								
Status : Completed								
43	22080122	Chairman Office	WATER NOT COMING IN CONFERENCE HALL WASH BASIN TAP - NEED TO CHECK & CHANGE	Prakash. V.,Arunagiri. V.,Ramkumar. R.	Sink Elbow action pillar cock and hot & Cold tap filter cleaned and serviced, rework the tap, proble		Sadhasivam. K. - Administration	04/08/2022
Comp. Dt. : 17/08/2022								

TRUE COPY ATTESTE:

DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUNPAM,
MADAGADIPIET, PUDUCHERRY-605 107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
44	22080539	GENERAL STORE	NEED MANPOWER TO SHIFT EQUIPEMENT FROM MAIN ENTRANCE TO STORE	Pandiaraj. V., Yuvaraj. M., Thulasi. V.	shifting work done.		Manikandan. S. - Administration	23/08/2022
Comp. Dt. : 22/08/2022								
Status : Completed								
45	22080710	AO Office	SINK BLOCK - NEED URGENT SERVICE	Rajendhiran. V., Thanuzkodi. E., Murugan. S.	Block removed.		Kadhiravan. C. - Administration	23/08/2022
Comp. Dt. : 23/08/2022								
Status : Completed								
46	22080750	Paediatrics - OPD	NEED TO CHANGE R O DRINKING WATER TAP - WATER LEAKAGE	Prakash. V., Rajendran. R., Ramkumar. R.	Bush changed.		Arulkumaran. S. - Administration	24/08/2022
Comp. Dt. : 06/09/2022								
Status : Completed								
47	22090233	AO Office	BLOCK IN MALE RESTROOM	Rajendhiran. V., Murugan. R., Thanuzkodi. E	block removed.		Karthik. K. - Administration	07/09/2022
Comp. Dt. : 12/10/2022								
Status : Completed								
48	22100339	GENERAL STORE	2 NO'S LABOUR NEED FOR SHIFTING WORK	Pandiaraj. V.	Machine shifting work done.		Manikandan. S. - Administration	13/10/2022
Comp. Dt. : 09/11/2022								
Status : Completed								
49	22110354	GENERAL STORE	WATER LEAKAGING FROM WALL CEILING	Prakash. V., Rajendran. R., Ramkumar. R.	Water leakage arrested.		Manikandan. S. - Administration	10/11/2022
Comp. Dt. : 15/11/2022								
Status : Completed								
50	22110599	GENERAL STORE	NEED LABOURS FOR MEDICINE COVER SHIFTING PURPOSE(FROM NEAR FREE PHARMACY)	Pandiaraj. V., Yuvaraj. M., Thulasi. V.	Shifting work completed		Manikandan. S. - Administration	16/11/2022
Comp. Dt. : 01/12/2022								
Status : Completed								
51	22120006	Chairman Office	WATER NOT COMING IN WASH BASIN AT V.C SIR OFFICE ROOM	Vengatesan. V.	tap filter rework done.		Sadhasivam. K. - Administration	05/12/2022

TRUE COPY ATTESTED

DEAN
SRI MANJULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
MADAGADI PET, PUDUCHERRY-605 107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 16/12/2022		Status : Completed						
52	22120760	GENERAL STORE	NEED MANPOWER TO SHIFT MATERIALS FROM GASPLANT TO GENERAL STORE	Pandiaraj. V., Yuvaraj. M., Senthil Kumar. R.	Materials shifting work completed		Manikandan. S. - Administration	20/12/2022
Comp. Dt. : 30/12/2022		Status : Completed						
53	22121367	GENERAL STORE	NEED MANPOWER FOR MATERIALS SHIFT FROM MAIN GATE	Pandiaraj. V., Yuvaraj. M., Senthil Kumar. R.	Hospital materials shifting work completed		Manikandan. S. - Administration	31/12/2022
Dept Name : Air Condition Department - Civil - Maintenance								
Comp. Dt. : 11/02/2020		Status : Completed						
54	20020406	Mit ladies hostel	NEED TO FIX WATER COOLER FLOATING VALUE	Udhaya Kumar. R.	Float valve changed, problem solved		Saravanan. C. - Air Condition Department	18/02/2020
Comp. Dt. : 15/02/2021		Status : Completed						
55	21020517	AC DEPT	NEED TO CHANGE TAP - WATER LEAKAGE AT HOSPITAL I FLOOR	Prakash. V.	New PVC tap changed, work completed		Udhaya Shankar. P. - Air Condition Department	18/02/2021
Comp. Dt. : 05/11/2021		Status : Completed						
56	21110093	marchuary	NEED CLEANING & UNWANTED TREES CUTTING WORK FOR MARCHUARY SOUTH SIDE	Kumar. V.	Inform to Housekeeping dept Mr.Naresh		Saravanan. C. - Air Condition Department	15/11/2021
Comp. Dt. : 28/12/2021		Status : Completed						
57	21121067	NEW CHILLER IN TERROUS	PIPE LINE DAMAGE IN ROOF	Prakash. V., Arunagiri. V., Sankar. V.	1" Pipe line rework, work completed on that day		Saravanan. C. - Air Condition Department	30/12/2021
Comp. Dt. : 14/02/2022		Status : Completed						
58	22020478	HOSPITAL TERROUS	NEED A NEW PIPE LINE CONNECTION & A SMALL TANK FOR AC LEAF CLEANING PURPOSE AT HOSPITAL TERROUS "C"	Pandiaraj. V., Yuvaraj. M., Thulasi. V.	Civil work, Inform to Project Managr Mururgan sir - WFM		Babu. D. - Air Condition Department	08/03/2022
Comp. Dt. : 20/05/2022		Status : Completed						

TRUE COPY ATTESTED

DEAN
SRI MANJULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
MADAGADIPET, PUDUCHERRY-605 107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
59	22050778	CHILLER IN HOSPITAL TERROUS	NEED A NEW PIPE LINE CONNECTION	Prakash. V.	1/2" valve changed, problem solved		Babu. D. - Air Condition Department	24/05/2022
	Comp. Dt. : 23/08/2022							
	Status : Completed							
60	22080765	Casualty	NEED CLEANING & CUTTING UNWANTED TREES AT BACK SIDE OF EMERGENCY CASUALTY	Pandiaraj. V.	Unwanted trees were cut		Panneer Selvam. P. - Air Condition Department	03/09/2022
	Comp. Dt. : 29/08/2022							
	Status : Completed							
61	22080965	AHU Room-1ST FLOOR	BLOCK - BACK SIDE OF A H U ROOM I FLOOR - NEED TO CLEAR	Govindan. R., Thanuzkodi. E., Rajendran. R.	4" pipe line rework, dummy fixed, work completed		Panneer Selvam. P. - Air Condition Department	05/09/2022
	Comp. Dt. : 22/09/2022							
	Status : Completed							
62	22090899	General Medicine	DRAINAGE BLOCK - BACK SIDE OF MEDICINE OPD	Rajendhiran. V., Murugan. S., Thanuzkodi. E	block removed.		Thulasi Daran. R. - Air Condition Department	24/09/2022
	Comp. Dt. : 21/10/2022							
	Status : Completed							
63	22100714	CHILDREN'S PLAY GROUND INSIDE HOSPITAL	WATER LEAKAGING FROM 2ND FLOOR CARDIOLOGY OPD INTO GROUND FLOOR	Prakash. V., Rajendran. R., Ramkumar. R.	A/C complaint. Not a plumbing complaint.		Panneer Selvam. P. - Air Condition Department	22/10/2022
	Dept Name : ANATOMY - Civil - Maintenance							
	Comp. Dt. : 20/01/2020							
	Status : Completed							
64	20010515	ANATOMY	NEED TO CHECK WASH BASIN TAP CONNECTION - WATER LEAKAGE	Gopal. S.	Wash basin tap rework and refixed in properly, problem solved		Mathivanan.B. - ANATOMY	27/01/2021
	Comp. Dt. : 23/01/2021							
	Status : Completed							
65	21010765	ANATOMY	NEED TO CHANGE WASH BASIN TAP AT RECEPTION HALL - WATER LEAKAGE	Arunagiri. V.	Wash basin angle valve spindle changed, work completed		Mathivanan.B. - ANATOMY	27/01/2021
	Comp. Dt. : 08/03/2022							
	Status : Completed							
66	22030270	ANATOMY	WASH BASIN [2 NOS] BROKEN	Sivaraja. M.	New wash basin fixed(2 No.s)		Mathivanan.B. - ANATOMY	21/03/2022
	Comp. Dt. : 14/12/2022							
	Status : Completed							

TRUE COPY ATTESTED

DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHAL KUPPAM,
MASS/01/2021, PUDUCHERRY-605 107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
67	22120650	ANATOMY	FLUSH NOT WORKING 2 NOS	Anandharaj. M., Azhagar. N., Sellaveeran. M.	Flush tank rework done.		Mathivanan.B. - ANATOMY	17/12/2022
Dept Name : Animal House - Civil - Maintenance Comp. Dt. : 18/03/2021 Status : Completed								
68	21030754	Animal House	RESTROOM BLOCK	Rajendhiran. V.	Toilet block removed, work completed		Prema. A. - Animal House	18/03/2021
Comp. Dt. : 13/07/2021 Status : Completed								
69	21070453	Animal House	WASH BASIN WATER BLOCK	Thanuzkodi. E, Thulasi. V., Prakash. V.	New Wash basin changed, water line connection given, work completed		Prema. A. - Animal House	14/07/2021
Comp. Dt. : 02/09/2021 Status : Completed								
70	21090105	Animal House	BLOCK AT BACK SIDE OF ANIMAL HOUSE - NEED URGENT SERVICE	Rajendhiran. V.	Chamber block removed, work completed		Prema. A. - Animal House	03/09/2021
Comp. Dt. : 22/09/2021 Status : Completed								
71	21090806	Animal House	BLOCK - BACK SIDE OF ANIMAL HOUSE - NEED URGENT SERVICE	Thanuzkodi. E	Chamber block removed, work completed		Prema. A. - Animal House	22/09/2021
Dept Name : Audit Wing - Civil - Maintenance Comp. Dt. : 10/07/2020 Status : Completed								
72	20070229	Casualty	SINK WATER OUT LET LEAKAGE - NEED URGENT SERVICE	Manikandan. S., Sellaveeran. M., Ramkumar. R.	Back side pipe line Elbow, MTA, coupling changed and pipe line rework, work completed		Raji. R. - Audit Wing	11/07/2020
Comp. Dt. : 05/06/2021 Status : Completed								
73	21060139	AO Office	URINAL BLOCK AT MALE REST ROOM	Prakash. V., Rajendhiran. V., Thanuzkodi. E	Urinal line fully block removed, work completed		Raji. R. - Audit Wing	05/06/2021
Dept Name : BIOCHEMISTRY - Civil - Maintenance Comp. Dt. : 07/01/2020 Status : Completed								
74	20010151	Blood Collection Centre	wash basin sink block-1008	Rajendhiran. V.	Sink block removed and door elbow 1No changed, work completed		Srinivasamurugan. V. - BIOCHEMISTRY	07/01/2020

TRUE COPY ATTESTED

DEAN
SRIMANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALUTHEERTHALKUPPAM
MADAGADIPET, PUDUCHERRY-605 107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 24/01/2020 Status : Completed								
75	20010670	Blood Collection Centre	NEED MANPOWER TO SHIT BERO TO COLLEGE SIDE	Pandiaraj. V., Yuvaraj. M., Thulasi. V.	Bero shifting work completed		Srinivasamurugan. V. - BIOCHEMISTRY	28/01/2020
Comp. Dt. : 02/03/2020 Status : Completed								
76	20030013	COMMON MALE TOILET NEAR BIOCHEMISTRY	COMMON TPILET BLOCKED, NEED SCAVENGER	Thanuzkodi. E	Toilet block removed, work completed		Srinivasamurugan. V. - BIOCHEMISTRY	02/03/2020
77	20030041	Biochemistry Lab-Hospital	WASH BASIN SINK TAP LEAKAGING PROBLEM	Manikandan. S.	Wash basin elbow tap spindle changed, problem solved		Preethi. A. - Blood Collection Centre	03/03/2020
Comp. Dt. : 18/03/2020 Status : Completed								
78	20030604	Biochemistry Lab-Hospital	NEED TO CHANGE TAP - WATER LEAKAGE	Prakash. V.	Wash basin JK white cement pointing work completed		Srinivasamurugan. V. - BIOCHEMISTRY	18/03/2020
Comp. Dt. : 26/05/2020 Status : Completed								
79	20050205	Clinical Pathology	NEED TO CHANGE MINERAL WATER CANE	Prakash. V.	Wrong complaint		Srinivasamurugan. V. - BIOCHEMISTRY	01/06/2020
Comp. Dt. : 29/06/2020 Status : Completed								
80	20060776	Blood Collection Centre	SINK BLOCK AT ROOM NO 47	Rajendhiran. V.	Sink block removed, work completed		Srinivasamurugan. V. - BIOCHEMISTRY	29/06/2020
81	20060797	Blood Collection Centre	WASH BASIN WATER LEAKAGE AT WASHING AREA	Prakash. V., Ramkumar. R., Abdul Azees. J.	Waste coupling changed, waste outlet line rework, work completed		Srinivasamurugan. V. - BIOCHEMISTRY	30/06/2020
Comp. Dt. : 23/07/2020 Status : Completed								
82	20070560	Blood Collection Centre	NEED TO CHECK WASH BASIN - BROKEN & WATER LEAKAGE	Ramkumar. R., Prakash. V., Rajendran. R.	Tap rework, work completed		Srinivasamurugan. V. - BIOCHEMISTRY	23/07/2020
Comp. Dt. : 04/08/2020 Status : Completed								
83	20080058	COMMON MALE TOILET NEAR BIOCHEMISTRY	WASH BASIN WATER LEAKAGE	Ramkumar. R., Rajendran. R., Prakash. V.	Wash basin pillar cock rework and flush tank full set rework, work completed		Srinivasamurugan. V. - BIOCHEMISTRY	05/08/2020
Comp. Dt. : 12/08/2020								

TRUE COPY ATTESTED

DEAN
MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
MADAGADIPEI, PUDUCHERRY-605 107.