



Sri Manakula Vinayagar Medical College and Hospital

Complaint Status Report From 01-05-2022 To 30-06-2023

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
College Name : MIT								
Work Type : Complaint								
Dept Name : Work Shop - Work Shop								
Comp. Dt. : 04/05/2022								
Status : Completed								
1	22050085	JR Quarters	NEED REPAIRING WORK FOR CUPBOARD DOOR & LOCK FOR ROOM NO 102	Pachaimuthusamy. D.	Cupboard door and lock repairing work completed		KIRTHIKA - MIT	12/05/2022
2	22050108	JR Quarters	NEED TO REFIX SCREEN ROD FOR ROOM NO 92 & 102	Ekambaram. K.	Screen rod fixed, problem solved		KIRTHIKA - MIT	12/05/2022
Comp. Dt. : 05/05/2022								
Status : Completed								
3	22050152	Mit ladies hostel	NEED TO FIX CUPBOARD FOR ROOM NO 6 & 62	Ekambaram. K.	cupboard refixed, work completed		AROKIAMARY - MIT	12/05/2022
Comp. Dt. : 07/05/2022								
Status : Completed								
4	22050241	Mit ladies hostel	NEED REPAIRING WORK FOR CUPBOARD DOOR - ROOM NO 45	Ekambaram. K.	Cupboard door refixed, problem solved		AROKIAMARY - MIT	26/05/2022
Comp. Dt. : 10/05/2022								
Status : Completed								
5	22050363	MIT College	NEED TO FIX NOTICE BOARD [4 NOS] FOR GROUND FLOOR FOOD TECHNOLOGY LAB	Ekambaram. K.	4Nos of Notice board fixed, work completed		RAVI - MIT	18/05/2022
Comp. Dt. : 18/05/2022								
Status : Completed								
6	22050672	Mit ladies hostel	NEED REPAIRING WORK FOR CUPBOARD DOOR FOR ROOM NO 45 & REFIX PATLOCK FOR ROOM NO 9	Pachaimuthusamy. D.	Cupboard door repaired and serviced, padlock refixed, problem solved		AROKIAMARY - MIT	27/05/2022
Comp. Dt. : 08/06/2022								
Status : Completed								
7	22060319	Mit ladies hostel	NEED REPAIRING WORK FOR CUPBOARD FOR 20 ROOMS [GROUND FLOOR TO IV FLOOR] CONTACT PERSON GANGAMMA	Ekambaram. K.	7 nos. room cup board hanger fixed.		AROKIAMARY - MIT	13/06/2022

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 09/06/2022 Status : Completed								
8	22060337	MIT MESS	NEED TO CHANGE GRINDER PAD [THUDUPPU] BROKENED	Ekambaram. K.	New pad fixed.		DHANDAPANI - MIT	18/06/2022
Comp. Dt. : 15/06/2022 Status : Completed								
9	22060542	MIT College	NEED CARPENTER WORK FOR GROUND & I FLOOR DOOR	Pachaimuthusamy. D.	Door lock serviced and refixed in properly, problem solved		GUBERAN - MIT	01/07/2022
Comp. Dt. : 22/06/2022 Status : Completed								
10	22060794	Mit ladies hostel	TILES BROKEN - NEED TOUCH UP WORK AT ROOM NO 43 & 71	Murugavel	8M Tiles refixed, JK white ceemnt pointing work completed		AROKIAMARY - MIT	01/07/2022
Comp. Dt. : 01/07/2022 Status : Completed								
11	22070034	Mit ladies hostel	NEED TO REFIX DRESS STAND FOR IV FLOOR COMMON RESTROOM	Pachaimuthusamy. D.,Ekambaram. K.,Venkatesan. R.	8 Nos of room - Cupboard door and room door repaired and serviced		AROKIAMARY - MIT	09/07/2022
Comp. Dt. : 04/07/2022 Status : Completed								
12	22070108	MIT College	NEED REPAIRING WORK FOR DOOR - IV FLOOR ROOM NO 408	Ekambaram. K.	Door repaired and serviced, problem solved		GUBERAN - MIT	09/07/2022
Comp. Dt. : 11/07/2022 Status : Completed								
13	22070407	Mit ladies hostel	TILES BROKEN - AIR CRACK - NEED TOUCHUP WORK FOR I FLOOR GUEST ROOM	Murugavel	Tiles fixed, JK white cement pointing work completed		AROKIAMARY - MIT	20/07/2022
Comp. Dt. : 19/07/2022 Status : Completed								
14	22070711	Mit ladies hostel	TILES BROKEN - NEED TOUCHUP WORK FOR ROOM NO 23	Murugavel	Tiles refixed, JK White cement pointing work completed		AROKIAMARY - MIT	01/08/2022
15	22070729	MIT MESS	NEED A NEW CHAMBER FOR GRINDER	Murugavel	New chamber built, work completed		RAVI - MIT	01/08/2022
Comp. Dt. : 21/07/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
16	22070792	MIT College	TILES BROKEN NEED TOUCHUP WORK AT III FLOOR CANTEEN	Murugavel	8m Tiles refixed, JK White cement pointing work done, work completed		SIVASUBRAMANIYAN - MIT	01/08/2022
	Comp. Dt. : 25/07/2022							
	Status : Completed							
17	22070895	Mit ladies hostel	NEED REPAIRING WORK FOR REST ROOM DOOR LOCK FOR III FLOOR ROOM NO 104	Ekambaram. K.	Door locked, key not available		AROKIAMARY - MIT	05/08/2022
	Comp. Dt. : 26/07/2022							
	Status : Completed							
18	22070949	Mit ladies hostel	NEED REPAIRING WORK FOR DOOR LOCK - PROBLEM IN ROOM NO 104 [III FLOOR]	Ekambaram. K.	Door locked, Key not available		AROKIAMARY - MIT	05/08/2022
	Comp. Dt. : 29/07/2022							
	Status : Completed							
19	22071067	Mit ladies hostel	NEED REPAIRING WORK FOR CUPBOARD & FIX NAILS FOR ROOM NO 54	Ekambaram. K.	Door locked, Key not available		AROKIAMARY - MIT	05/08/2022
	Comp. Dt. : 30/07/2022							
	Status : Completed							
20	22071100	Mit ladies hostel	NEED TO REFIX CLOTH DRYING & CLOTH HANGER FOR III FLOOR RESTROOM [LEFTSIDE]	Sundaramoorthy. G.	Door locked, Key not available		AROKIAMARY - MIT	05/08/2022
	Comp. Dt. : 24/08/2022							
	Status : Completed							
21	22080788	MIT College	NEED DOOR REPAIRING WORK FOR IV FLOOR ROOM NO 408	Ekambaram. K.	Door repaired.		GUBERAN - MIT	09/09/2022
	Comp. Dt. : 02/09/2022							
	Status : Completed							
22	22090095	MIT College	CARPENTER DOOR WORK IN 4TH FLOOR	Ekambaram. K.	Door refix		GUBERAN - MIT	08/09/2022
	Comp. Dt. : 12/09/2022							
	Status : Completed							
23	22090431	MIT College	NEED REWORK FOR II FLOOR HOD ROOM DOOR	Ekambaram. K.	Door repaired and serviced, problem solved		BALA - MIT	28/09/2022
	Comp. Dt. : 22/09/2022							
	Status : Completed							


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
24	22090865	Mit ladies hostel	STUCK MAIN GRILL GATE	Sarathy. A.	Gate repaired and grease applied, problem solved		AROKIAMARY - MIT	08/10/2022
	Comp. Dt. : 13/10/2022							
	Status : Completed							
25	22100419	Mit ladies hostel	NEED REPAIRING WORK FOR MAIN DOOR & CUPBOARD DOOR LOCK FOR ROOM NO 104,105 & 106	Ekambaram. K.,Sundaramoorthy. G.,Viswa. V.	Door aldrop 1No fixed, door bottom seal fixed, work completed		AROKIAMARY - MIT	20/10/2022
	Comp. Dt. : 18/10/2022							
	Status : Completed							
26	22100572	MIT College	TABLE LOCK [3NOS] NOT WORKING - STUCK - AT BASEMENT OFFICE - NEED REPAIRING WORK	Ekambaram. K.	Lock refixed.		GUBERAN - MIT	29/10/2022
27	22100577	MIT College	NEED REPAIRING WORK FOR DOOR LOCK - LOCK NOT WORKING - ROOM NO 311	Ekambaram. K.	Work completed.		GUBERAN - MIT	29/10/2022
	Comp. Dt. : 28/11/2022							
	Status : Completed							
28	22111195	Mit ladies hostel	TILES BROKEN - NEED TOUCHUP WORK FOR ROOM NO 50	Murugavel	Tiles refixed, JK White cement pointing work completed		AROKIAMARY - MIT	19/12/2022
	Comp. Dt. : 02/12/2022							
	Status : Completed							
29	22120065	Mit ladies hostel	NEED CEMENT WORK FOR II FLOOR CARITOR SIDE WALL	Murugavel	Work completed.		AROKIAMARY - MIT	10/12/2022
	Comp. Dt. : 19/12/2022							
	Status : Completed							
30	22120854	MIT College	NEED LABOURS FOR DUAL DESK SHIFTING WORK FROM FIRST FLOOR TO FOURTH FLOOR - 4 NOS	Ganesan. A.	Wrong complaint, msg inform to maintenance dept		BALA - MIT	30/12/2022
	Comp. Dt. : 20/12/2022							
	Status : Completed							
31	22120897	Mit ladies hostel	CUPBOARD REFIXING WORK FOR ROOM NO 45,108,109,110	Ekambaram. K.,Sundaramoorthy. G.,Pachaimuthusamy . D.	all room Cupboard and door refixed, work completed		AROKIAMARY - MIT	27/12/2022
32	22120898	Mit ladies hostel	IN 3RD FLOOR BATHROOM TILES BROKEN	Murugavel	Tiles refixed, JK white cement pointing work completed		AROKIAMARY - MIT	27/12/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 26/12/2022								
Status : Completed								
33	22121156	Mit ladies hostel	3RD FLOOR CUPBOARD PROBLEM IN ROOM NO 87,88,89,98	Ekambaram. K.	5Nos of room Cup board door and lock repaired and serviced, problem solved		AROKIAMARY - MIT	02/01/2023
34	22121157	Mit ladies hostel	4TH FLOOR CUPBOARD PROBLEM IN ROOM NO 106,108,121,128	Ekambaram. K.	All room cup board door and lock repaired and serviced, problem solved		AROKIAMARY - MIT	02/01/2023
Comp. Dt. : 28/12/2022								
Status : Completed								
35	22121280	MIT College	NEED LABOURS FOR CHAIR SHIFTING WORK FROM MIT TO JR QUARTERS - 4 NOS	Ganesan. A.	Wrong complaint, Inform to Maintenance dept		BALA - MIT	05/01/2023
Comp. Dt. : 04/01/2023								
Status : Completed								
36	23010138	MIT College	DOOR PROBLEM	Ekambaram. K.	Door repaired and serviced, problem solved		GUBERAN - MIT	23/01/2023
37	23010162	MIT College	IN GROUND FLOOR CANTEEN AREA-MASON WORK OVER WATER TAP	Murugavel	Canteen pipe line plastering work completed		RAVI - MIT	12/01/2023
Comp. Dt. : 18/01/2023								
Status : Completed								
38	23010617	MIT College	NEED REPAIRING WORK FOR DOORS 2 NO - [MBA & FOOD TECHNOLOGY CLASS ROOM DOOR]	Ekambaram. K.	2Nos of door repaired and serviced, problem solved		RAVI - MIT	30/01/2023
Comp. Dt. : 02/02/2023								
Status : Completed								
39	23020044	Mit ladies hostel	NEED TO REFIX DRESS HANGER FOR IV FLOOR RESTROOM & NEED REPAIRING WORK FOR RESTROOM DOOR & LOCK ROOM	Ekambaram. K.	All carpenter work completed		AROKIAMARY - MIT	11/02/2023
Comp. Dt. : 13/02/2023								
Status : Completed								
40	23020503	MIT College	NEED CEMENT WORK FOR "G 12" CLASS ROOM	Murugavel	Mason work completed		RAVI - MIT	17/02/2023
Comp. Dt. : 14/02/2023								
Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
41	23020549	MIT MESS	TILES AIR CRACK - AT ENTRANCE	Murugavel	Tiles refixed, JK white cement pointing work completed		RAVI - MIT	17/02/2023
	Comp. Dt. : 16/02/2023							
	Status : Completed							
42	23020635	MIT College	CSE HOD SIR ROOM- -NEED TO FIX DOOR CLOSER	Ekambaram. K.	New Door closer fixed, problem solved		RAVI - MIT	23/02/2023
	Comp. Dt. : 02/03/2023							
	Status : Completed							
43	23030089	MIT College	NEED REPAIRING WORK FOR B WING LADIES RESTROOM DOOR	Ekambaram. K.	Rest room door repaired and serviced, problem solved		RAVI - MIT	09/03/2023
	Comp. Dt. : 04/03/2023							
	Status : Completed							
44	23030171	JR Quarters	NEED TILES PACKING WORK AT III & IV FLOOR	Parivallal. P.	Tiles refixed, JK White cement pointing work completed		GUBERAN - MIT	09/03/2023
	Comp. Dt. : 09/03/2023							
	Status : Completed							
45	23030353	JR Quarters	NEED POINTING & MATION WORK AT JR QUARTERS IV FLOOR	Murugavel	WORK COMPLETED		RAVI - MIT	23/03/2023
46	23030354	Mit ladies hostel	NEED REPAIRING WORK FOR CUPBOARD - ROOM NO 60 & 90	Ekambaram. K.	CUPBOARD FIXED.		AROKIAMARY - MIT	23/03/2023
	Comp. Dt. : 17/03/2023							
	Status : Completed							
47	23030717	MIT College	TILES AIR CRACK - NEED TOUCH UP WORK AT II FLOOR ROOM NO 202	Parivallal. P.	Tiles refixed, JK white cement pointing work completed		RAVI - MIT	31/03/2023
	Comp. Dt. : 18/03/2023							
	Status : Completed							
48	23030752	MIT College	NEED REPAIRING WORK FOR A.O CABIN DOOR LOCK [DAMAGE]	Ekambaram. K.	Lock repaired and serviced, problem solved		GUBERAN - MIT	31/03/2023
	Comp. Dt. : 20/03/2023							
	Status : Completed							
49	23030814	JR Quarters	NEED REPAIRING WORK FOR CUPBOARD - DAMAGE ROOM NO 121 & TILES BROKEN NEED TOUCHUP WORK ROOM NO 124 [	Ekambaram. K., Sundaramoorthy. G., Parivallal. P.	No complaints in this area's		AROKIAMARY - MIT	31/03/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
50	23030815	JR Quarters	NEED REPAIRING WORK FOR IV FLOOR RESTROOM DOOR [LEFT SIDE] DAMAGE	Ekambaram. K.	No complaints in this area's		AROKIAMARY - MIT	31/03/2023
51	23030816	JR Quarters	NEED TO REFIX HANGER FOR ALL RESTROOMS	Ekambaram. K.	No complaints		AROKIAMARY - MIT	31/03/2023
Comp. Dt. : 22/03/2023 Status : Completed								
52	23030912	MIT College	NEED REPAIRING WORK FOR DOOR - DAMAGE & BROKEN - CLASS ROOM 201	Ekambaram. K.	DOOR REPAIRED.		GUBERAN - MIT	01/04/2023
Comp. Dt. : 30/03/2023 Status : Completed								
53	23031303	MIT College	NEED REPAIRING WORK FOR CLASS ROOM DOORS - ROOM NO 101 ,104 & 107	Ekambaram. K.	Class room doors refixed, work completed		BALA - MIT	06/04/2023
Comp. Dt. : 08/04/2023 Status : Completed								
54	23040248	MIT College	NEED TO REFIX ALUMINIUM GLASS DOOR - DOOR GLASS DAMAGE AT GROUND FLOOR MECHANICAL LAB [OPP TO	Ekambaram. K.,Pachaimuthusamy . D.,Manivannan. A.	Aluminium glass door changed, work completed		BALA - MIT	19/04/2023
Comp. Dt. : 11/04/2023 Status : Completed								
55	23040295	MIT Auditorium	NEED TO REPLACE DOOR CLOSER 6 NOS FOR MIT AUDITORIUM & LAB	Ekambaram. K.	Door closer changed, work completed		RAVI - MIT	19/04/2023
Comp. Dt. : 13/04/2023 Status : Completed								
56	23040406	MIT College	NEED CEMENT TOUCHUP WORK AT IV FLOOR MALE RESTROOM	Parivallal. P.	Cement pointing work completed		RAVI - MIT	20/04/2023
Comp. Dt. : 20/04/2023 Status : Completed								
57	23040651	MIT College	NEED III FLOOR CLASS ROOM ALUMINIUM DOOR REWORK & TABLE LOCK REPAIRING WORK FOR PLACEMENT OFFICER R	Ekambaram. K.,Sundaramoorthy. G.,Pachaimuthusamy . D.	WORK COMPLETEDQ		BALA - MIT	02/05/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 03/05/2023 Status : Completed								
58	23050107	Mit ladies hostel	NEED TO CHECK ENTRANCE GRILL GATE - STUCK	Ekambaram. K.	DOOR REPAIRED.		AROKIAMARY - MIT	13/05/2023
Comp. Dt. : 04/05/2023 Status : Completed								
59	23050152	MIT College	NEED TO REFIX DOOR STOPPER FOR MBA HOD ROOM	Ekambaram. K.	DOOR STOPPER FIXED.		RAVI - MIT	13/05/2023
Comp. Dt. : 08/05/2023 Status : Completed								
60	23050298	MIT College	NEED CEMENT WORK FOR GROUND FLOOR ELECTRICAL ROOM [HOLE FILLING WORK]	Parivallal. P.	holes packed		SIVASUBRAMANIYAN - MIT	18/05/2023
Comp. Dt. : 07/06/2023 Status : Completed								
61	23060230	Mit ladies hostel	NEED TO CHECK IV FLOOR BACKSIDE TILES - BROKEN WATER LEAKAGE NEED URGENT SERVICE	Parivallal. P.	Work completed		AROKIAMARY - MIT	20/06/2023

College Name : Others

Work Type : Complaint

Dept Name : Work Shop - Work Shop

Comp. Dt. : 12/05/2022

Status : Completed

62	22050431	Mit ladies hostel	IN 2ND FLOOR BATHROOM NO.2 DOOR BROKEN,REPLACE BY NEW DOOR	Ekambaram. K.	Door changed, problem solved		AROKIYAMARY - Others	27/05/2022

Comp. Dt. : 19/08/2022

Status : Completed

63	22080615	J.R Quateres	DUMMY COOLER SHIFTING WORK - NEED LABOURS - 2 NOS	Venkatesan. R.	Wrong complaint		VIRGIN MARY - Others	25/08/2022

Comp. Dt. : 26/10/2022

Status : Completed

64	22100838	Mit ladies hostel	IN 3RD FLOOR-SIDE WALL GOT DAMAGED-MASON WORK NEED TO DO	Murugavel	Work completed.		AROKIYAMARY - Others	03/11/2022

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 27/10/2022								
Status : Completed								
65	22100869	J.R Quateres	IN 4TH FLOOR-POINTING WORK NEED TO DO(MASON WORK)	Murugavel	Work completed.		RAVI - Others	03/11/2022
Comp. Dt. : 29/10/2022								
Status : Completed								
66	22100968	Mit ladies hostel	CUB BOARD PROBLEM IN ROOM NO.108	Ekambaram. K.	Cub board door repaired and serviced, problem solved		AROKIAMARY - Others	15/11/2022
67	22100969	Mit ladies hostel	NEED TO CHECK ALL ROOM CUBBOARD - CUBBOARD PROBLEM	Ekambaram. K.,Sundaramoorthy. G.,Manivannan. A.	All room Cub board checked, some door repaired and serviced, problem solved		AROKIAMARY - Others	15/11/2022
68	22100970	Mit ladies hostel	COT NOISE PROBLEM IN ROOM NO. 113	Ekambaram. K.	Cot side rails refixed, bush fixed, problem solved		AROKIAMARY - Others	15/11/2022
Comp. Dt. : 07/11/2022								
Status : Completed								
69	22110207	B.ED COLLEGE	NEED PLUMBER	Ganesan. A.	Informed to plumbing complaint		SRIMAN - Others	17/11/2022
Comp. Dt. : 08/11/2022								
Status : Completed								
70	22110320	Mit ladies hostel	4TH FLOOR CUPBOARD PROBLEM IN ROOM NO. 127 (KEY MISSING)	Ekambaram. K.	Cup board repaired and serviced, problem solved		AROKIAMARY - Others	18/11/2022
Comp. Dt. : 06/12/2022								
Status : Completed								
71	22120260	B.ED COLLEGE	NEED 1 PERSON TO FIRE ON CYLINDER FOR INSPECTION PURPOSE	Ekambaram. K.	Electrical dept complaint, inform to electrical dept		SRIMAN - Others	19/12/2022
72	22120269	Mit ladies hostel	IN ROOM NO.5 AND WARDEN ROOM-FLOOR TILES BROKEN,TOUCH UP WORK NEEDED	Murugavel	Tiles refixed, JK White cement pointing work completed		AROKIAMARY - Others	19/12/2022
Comp. Dt. : 10/12/2022								
Status : Completed								
73	22120480	Ladies hostel Phase-II	IN GROUND FLOOR ALL ROOMS-REQUEST TO CHECK VELCRO IS ALRAEDY FIXED IN ALL WINDOWS AND IF NOT NED TO	Ekambaram. K.	Mosquito net refixed, problem solved		arokiyamary - Others	19/12/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
74	22120484	Ladies hostel Phase-II	IN ROOM NO.19 -RAINWATER GETTING INSIDE THROUGH WINDOW-CEMENT WORK NEED TO DO	Murugavel	Mason work completed		AROKIYAMARY - Others	19/12/2022
Comp. Dt. : 17/12/2022 Status : Completed								
75	22120828	Mit ladies hostel	IN GROUND FLOOR-BATHROOM DOOR BROKEN AND ANOTHER DOOR NOT CLOSING PROPERLY	Ekambaram. K.,Sundaramoorthy. G.,Pachaimuthusamy . D.	Door repaired and serviced, problem solved		arokiyamary - Others	23/12/2022
Comp. Dt. : 29/12/2022 Status : Completed								
76	22121320	Mit ladies hostel	IN 1ST FLOOR COMMON BATHROOM-MASON WORK IN WATER HEATER PIPELINE	Murugavel	Mason work completed		AROKIYAMARRY - Others	05/01/2023

College Name : SMVMCH

Work Type : Complaint

Dept Name : Air Condition Department - Work Shop

Comp. Dt. : 07/11/2022

Status : Completed

77	22110206	PHARMACOLOGY	AC BASE LIGHT WELDING WORK	Sarathy. A.	bold welded		Babu. D. - Air Condition Department	17/11/2022

Dept Name : ANATOMY - Work Shop

Comp. Dt. : 21/12/2022

Status : Completed

78	22120987	ANATOMY	WASH BASIN CABIN DOOR PROBLEM - HISTOLOGY LAB	Ekambaram. K.,Sundaramoorthy. G.,Pachaimuthusamy . D.	Door refixed, problem solved		Mathivanan.B. - ANATOMY	27/12/2022

Dept Name : Canteen - Boys Hostel - Work Shop

Comp. Dt. : 04/08/2022

Status : Completed

79	22080153	Boys hostel PH-I	IN ROOM NO.48,50,31,47 GRATING WORK NEED TO DO(MASON WORK)	Murugavel	All room grating fixed, jk white cement pointing work done, problem solved		Sambasivam. K. - Canteen - Boys Hostel	17/08/2022

Comp. Dt. : 17/08/2022

Status : Completed

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
80	22080517	Boys hostel P.H-III	IN ROOM NO.32 HANGER REFIXNG WORK NEED TO DO	Ekambaram. K.	Hanger refixed properly, problem solved		Sambasivam. K. - Canteen - Boys Hostel	25/08/2022
81	22080537	Boys hostel Phase-II	IN ROOM NO.25 WINDOW DOOR NOT CLOSING	Ekambaram. K.	Window door repaired and serviced, problem solved		Sambasivam. K. - Canteen - Boys Hostel	25/08/2022
Comp. Dt. : 27/10/2022 Status : Completed								
82	22100844	Boys hostel PH-I	NEED TO FIX SS MESH VENTILATOR IN ROOM NO. 54	Ekambaram. K.,Manivannan. A.,Sundaramoorthy. G.	2nos. mesh fixed.		Sambasivam. K. - Canteen - Boys Hostel	03/11/2022
83	22100854	Boys hostel PH-I	IN ROOM NO.29 WALL CEILING MASON WORK NEED TO DO	Murugavel	Ceiling plastering work.		Sambasivam. K. - Canteen - Boys Hostel	03/11/2022
Comp. Dt. : 28/10/2022 Status : Completed								
84	22100931	Kitchen - Boys Hostel	IN WASHING AREA-STEEL GOT DAMAGED AND WATER LEAKAGING PROBLEM	Ganesan. A.	Wrong complaint.		Kesavaraj. P. - Canteen - Boys Hostel	03/11/2022
Comp. Dt. : 29/10/2022 Status : Completed								
85	22100955	Boys hostel Phase-II	SCREEN PIPE CLAMP REPAIR WORK IN ROOM NO. 41	Ekambaram. K.	Screen pipe clamp changed, problem solved		Sambasivam. K. - Canteen - Boys Hostel	08/11/2022
86	22100956	Boys hostel PH-I	BEROW LOCK REPAIR WORK IN ROOM NO. 37, 38, 40 - 6 NOS	Ekambaram. K.	6Nos of Lock repaired and serviced, problem solved		Sambasivam. K. - Canteen - Boys Hostel	08/11/2022
Comp. Dt. : 07/11/2022 Status : Completed								
87	22110209	Boys hostel PH-I	ROOM NO 32 BATHROOM DOOR REPAIR WORK	Ekambaram. K.	Work completed.		Sambasivam. K. - Canteen - Boys Hostel	17/11/2022
88	22110210	Boys hostel PH-I	ROOM NO 41 BATHROOM DOOR REPAIR WORK AND WINDOW DOOR NOT CLOSING	Ekambaram. K.	Work completed.		Sambasivam. K. - Canteen - Boys Hostel	17/11/2022
89	22110211	Boys hostel PH-I	ROOM NO 30 BATHROOM DOOR REPAIR WORK	Ekambaram. K.	Work completed.		Sambasivam. K. - Canteen - Boys Hostel	17/11/2022
90	22110212	Boys hostel PH-I	WINDOW MOSQUITOE FRAME WORK (NEW) LETTER GIVEN	Ekambaram. K.	Work completed.		Sambasivam. K. - Canteen - Boys Hostel	17/11/2022
Comp. Dt. : 08/11/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
91	22110311	Boys hostel Phase-II	CUPBOARD REPAIR WORK IN ROOM NO.26	Ekambaram. K.	Cupboard repaired and serviced, problem solved		Sambasivam. K. - Canteen - Boys Hostel	18/11/2022
Comp. Dt. : 10/11/2022 Status : Completed								
92	22110401	Boys hostel PH-I	IN ROOM NO.39 AND 33 FLOOR TILES WHITE CEMENT PACKAGING WORK NEED TO DO	Murugavel	Tiles refixed, JK White cement pointing work completed		Sambasivam. K. - Canteen - Boys Hostel	18/11/2022
93	22110402	Boys hostel PH-I	IN ROOM NO.30-HANGER REPAIR WORK	Ekambaram. K.	Hangr refixed, problem solved		Sambasivam. K. - Canteen - Boys Hostel	18/11/2022
94	22110403	Boys hostel PH-I	IN ROOM NO.35 AND 34-VENTILATOR MOSQUITO NET REFIXING WORK NEED TO DO	Ekambaram. K.	SS Mesh fixed, problem solved		Sambasivam. K. - Canteen - Boys Hostel	18/11/2022
95	22110404	Boys hostel PH-I	IN ROOM NO.39-SCREEN CLAMP REPAIR WORK NEED TO DO	Ekambaram. K.	Clamp fixed, problem solved		Sambasivam. K. - Canteen - Boys Hostel	18/11/2022
96	22110405	Boys hostel PH-I	IN ROOM NO.41-WINDOW MOSQUITO NET REFIXING WORK NEED TO DO	Ekambaram. K.	SS Mesh fixed, problem solved		Sambasivam. K. - Canteen - Boys Hostel	18/11/2022
Comp. Dt. : 15/11/2022 Status : Completed								
97	22110610	Boys hostel PH-I	IN ROOM NO.34-BATHROOM DOOR LATCH(INSIDE AND OUTSIDE)NEED TO BE REPAIR	Ekambaram. K.	Door lock repaired and serviced, problem solved		Sambasivam. K. - Canteen - Boys Hostel	21/11/2022
98	22110611	Boys hostel PH-I	IN ROOM NO.34 MIRROR REFIXING WORK NEED TO DO	Ekambaram. K.	Mirror fixed, work completed		Sambasivam. K. - Canteen - Boys Hostel	21/11/2022
99	22110612	Boys hostel PH-I	IN ROOM NO.36 AND 37-HANGER WORK NEED TO DO	Ekambaram. K.	Hanger fixed, problem solved		Sambasivam. K. - Canteen - Boys Hostel	21/11/2022
Comp. Dt. : 16/11/2022 Status : Completed								
100	22110666	Boys hostel PH-I	IN ROOM NO.38 -MAIN DOOR INSIDE HANDLE NEED TO BE REPAIR	Ekambaram. K.	Door Handle refixed, problem solved		Sambasivam. K. - Canteen - Boys Hostel	21/11/2022
101	22110667	Boys hostel PH-I	IN ROOM NO.30-MOSQUITO NET FRAME NEED TO BE FIX	Ekambaram. K.	Mosquito net refixed, work completed		Sambasivam. K. - Canteen - Boys Hostel	21/11/2022
Comp. Dt. : 21/11/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
102	22110857	Boys hostel PH-I	IN ROOM NO.27-SS MOSQUITO NET FIXING WORK BATHROOM VENTILATOR	Ekambaram. K.	Mosquito net fixed, problem solved		Sambasivam. K. - Canteen - Boys Hostel	01/12/2022
103	22110858	Boys hostel Phase-II	IN ROOM NO.32-MAIN DOOR HANDLE GOT DAMAGED	Ekambaram. K.	Door handle changed, problem solved		Sambasivam. K. - Canteen - Boys Hostel	01/12/2022
104	22110859	Boys hostel Phase-II	IN ROOM NO.56-HANGER NEED TO BE REPAIR	Ekambaram. K.	Hanger refixed, problem solved		Sambasivam. K. - Canteen - Boys Hostel	01/12/2022
Comp. Dt. : 24/11/2022 Status : Completed								
105	22111039	Boys hostel Phase-II	IN ROOM NO.36 MAIN DOOR REPAIR WORK	Ekambaram. K.	Door repaired and serviced, problem solved		Sambasivam. K. - Canteen - Boys Hostel	01/12/2022
Comp. Dt. : 26/11/2022 Status : Completed								
106	22111139	Kitchen - Boys Hostel	GRINDER BELT NEED TO BE CHNAGE	Ekambaram. K.	Wrong complaint, electrical dept complaint, Inform to Electrical dept		Elumalai. M. - Canteen - Boys Hostel	06/12/2022
Comp. Dt. : 03/12/2022 Status : Completed								
107	22120121	Boys hostel PH-I	HANGER FIXING WORK IN ROOM NO. 37	Ekambaram. K.	Work completed.		Sambasivam. K. - Canteen - Boys Hostel	10/12/2022
108	22120122	Boys hostel P.H-III	RESTROOM DOOR HANDLE FIXING WORK IN ROOM NO. 22	Ekambaram. K.	Work completed.		Sambasivam. K. - Canteen - Boys Hostel	10/12/2022
Comp. Dt. : 05/12/2022 Status : Completed								
109	22120174	Kitchen - Boys Hostel	GRINDER BOLT GOT DAMAGED,NEED TO BE CHNAGE	Ekambaram. K.	SS table leg welded. SS tray weled. Grinder stone bolt fixed.		Elumalai. M. - Canteen - Boys Hostel	10/12/2022
Comp. Dt. : 06/12/2022 Status : Completed								
110	22120244	Boys hostel PH-I	IN ROOM NO.19-MOSQUITO NET STABBLER ATTACHMENT WORK NEED TO DO	Ekambaram. K.	Hinges 5Nos, door stopper 4Nos, Padlock 10Nos changed, work completed		Sambasivam. K. - Canteen - Boys Hostel	19/12/2022
111	22120245	Boys hostel PH-I	IN ROOM NO.21-HANGER REFIXING WORK NEED TO DO	Ekambaram. K.	Hinges 5Nos, door stopper 4Nos, Padlock 10Nos changed, work completed		Sambasivam. K. - Canteen - Boys Hostel	19/12/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
112	22120246	Boys hostel Phase-II	TOTALLY 8 ROOMS-MOSQUITO NET STABLER ATTACHMENT WORK NEED TO DO	Ekambaram. K.	Hinges 5Nos, door stopper 4Nos, Padlock 10Nos changed, work completed		Sambasivam. K. - Canteen - Boys Hostel	19/12/2022
113	22120247	Boys hostel Phase-II	REQUEST TO CHECK ALL BATHROOMS ARE IN PROPER WORKING MANNER OR ANY CAUSED ANY DAMAGES IN 2ND AND 3RD	Ekambaram. K.	Hinges 5Nos, door stopper 4Nos, Padlock 10Nos changed, work completed		Sambasivam. K. - Canteen - Boys Hostel	19/12/2022
Comp. Dt. : 07/12/2022 Status : Completed								
114	22120312	Mit boys hostel	MASON WORK AT WATER PIPELINE	Murugavel	Tiles refixed, JK White cement pointing work completed		Elumalai. M. - Canteen - Boys Hostel	19/12/2022
Comp. Dt. : 08/12/2022 Status : Completed								
115	22120365	Boys hostel P.H-III	IN ROOM NO.10 MAIN DOOR CYLINDER LOCK PROBLEM	Ekambaram. K.	Lock repaired and serviced, problem solved		Sambasivam. K. - Canteen - Boys Hostel	19/12/2022
Comp. Dt. : 12/12/2022 Status : Completed								
116	22120541	Mit boys hostel	TWOWHEELER ELEVATING CIRCUS BROKEN-MASON WORK(CEMENT WORK)NEED TO DO	Murugavel	Mason work completed		Sambasivam. K. - Canteen - Boys Hostel	19/12/2022
Comp. Dt. : 20/12/2022 Status : Completed								
117	22120883	Canteen - Boys Hostel	Need to refix vegetable cutter blade.	Sarathy. A.,Ekambaram. K.,Sundaramoorthy. G.	Vegetable cutter blade refixed, problem solved		Elumalai. M. - Canteen - Boys Hostel	27/12/2022
118	22120910	Boys hostel Phase-II	IN ROOM NO 28 CUPBOARD DOOR REPAIR WORK	Ekambaram. K.	Door repaired and serviced, problem solved		Sambasivam. K. - Canteen - Boys Hostel	27/12/2022
119	22120911	Boys hostel Phase-II	IN ROOM NO 26 COT NEED TO BE REFIX	Ekambaram. K.	Cot siderails and bush refixed, problem solved		Sambasivam. K. - Canteen - Boys Hostel	27/12/2022
120	22120912	Boys hostel Phase-II	IN ROOM NO 46 & 47 SCREEN PIPE REPAIR WORK	Ekambaram. K.	Screen pipe refixed, problem solved		Sambasivam. K. - Canteen - Boys Hostel	27/12/2022
121	22120913	Boys hostel Phase-II	IN ROOM NO 32 MOSQUITO NET STAPLER PIN WORK	Ekambaram. K.	Mosquito net refixed, problem solved		Sambasivam. K. - Canteen - Boys Hostel	27/12/2022
Comp. Dt. : 27/12/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
122	22121239	Boys hostel Phase-II	IN ROOM NO.26,37,10-HANGER REPAIR AND REFIXING WORK NEED TO DO	Ekambaram. K.,Sundaramoorthy. G.,Manivannan. A.	All room hanger refixed, problem solved		Sambasivam. K. - Canteen - Boys Hostel	05/01/2023
123	22121240	Boys hostel PH-I	IN ROOM NO.10 AND 49-BERO LOCK REPAIR WORK NEED TO DO	Ekambaram. K.	Bero lock repaired and serviced, problem solved		Sambasivam. K. - Canteen - Boys Hostel	05/01/2023
124	22121241	Boys hostel PH-I	IN ROOM NO.8,10 AND 44-MASON WORK	Murugavel	Mason work completed		Sambasivam. K. - Canteen - Boys Hostel	05/01/2023
125	22121242	Boys hostel PH-I	IN ROOM NO.26 BATHROOM ROOF GOT DAMAGED-MASON WORK NEED TO DO	Murugavel	mason work completed		Sambasivam. K. - Canteen - Boys Hostel	05/01/2023
126	22121243	Boys hostel PH-I	IN ROOM NO.10-GRATING WORK NEED TO DO	Murugavel	Grating fixed, Mason work completed		Sambasivam. K. - Canteen - Boys Hostel	05/01/2023
Comp. Dt. : 03/01/2023 Status : Completed								
127	23010093	Boys hostel PH-I	IN ROOM NO.31-MASON WORK	Murugavel	Mason work completed		Mathubalan. M. - Canteen - Boys Hostel	12/01/2023
Comp. Dt. : 05/01/2023 Status : Completed								
128	23010241	Boys hostel Phase-II	IN ROOM NO.52/54/55/57/62-MAIN DOOR ENTRANCE-MASON WORK	Murugavel	Work completed.		Sambasivam. K. - Canteen - Boys Hostel	11/01/2023
129	23010242	Boys hostel P.H-III	IN ROOM NO.20-MAIN DOOR LOCK NEED TO BE REPAIR	Ekambaram. K.	work completed.		Sambasivam. K. - Canteen - Boys Hostel	11/01/2023
130	23010243	Boys hostel Phase-II	IN 2ND FLOOR LIFT OPPOSITE-WINDOW GLASS DOOR SIDE REAPER REWORK	Ekambaram. K.	work completed.		Sambasivam. K. - Canteen - Boys Hostel	11/01/2023
Comp. Dt. : 10/01/2023 Status : Completed								
131	23010397	Boys hostel PH-I	IN ROOM NO.41-BATHROOM VENTILATOR MOSQUITO NET FIXING WORK NEED TO DO	Ekambaram. K.	Mosquito net fixed, problem solved		Sambasivam. K. - Canteen - Boys Hostel	23/01/2023
132	23010398	Boys hostel PH-I	IN ROOM NO.44-WINDOW MOSQUITO NET REFIXING WORK NEED TO DO	Ekambaram. K.	Mosquito net fixed, problem solved		Sambasivam. K. - Canteen - Boys Hostel	23/01/2023
Comp. Dt. : 11/01/2023 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
133	23010441	Boys hostel PH-I	IN ROOM NO.39-TILES GRATING WORK	Murugavel	18Nos of Tiles refixed, JK White cement pointing work completed		Sambasivam. K. - Canteen - Boys Hostel	23/01/2023
Comp. Dt. : 16/06/2023 Status : Completed								
134	23060594	Boys hostel Phase-II	ROOM NO-45,WINDOW GRILL WELDING WORK AND TERES TOP HANDLE PIPE RUST CLEANING WORK	Sarathy. A.	Work completed		Sambasivam. K. - Canteen - Boys Hostel	27/06/2023
Dept Name : Canteen-Girls Hostel - Work Shop Comp. Dt. : 12/05/2022 Status : Completed								
135	22050409	JR Quarters	ROOM NO-18.CUPBOARD HANDLE FIXING WORK	Ekambaram. K.	Cupboard handle fixed, problem solved		Virgin Mary - Canteen-Girls Hostel	27/05/2022
Comp. Dt. : 13/05/2022 Status : Completed								
136	22050465	Ladies hostel Phase-II	IN ROOM NO.36 CUPBOARD DOOR DAMAGED	Ekambaram. K.	Cupboard door refixed in properly, problem solved		Malliga. K. - Canteen-Girls Hostel	27/05/2022
137	22050467	Ladies hostel Phase-II	IN 2ND FLOOR-ROOM NO.61 MAIN DOOR AND CUPBOARD DOOR LOCK PROBLEM	Ekambaram. K.	Main door repaired and refixed, cupboard lock changed, problem solved		Malliga. K. - Canteen-Girls Hostel	27/05/2022
Comp. Dt. : 10/06/2022 Status : Completed								
138	22060369	JR Quarters	(3042) FAN CLAMP FIXING WORK	Ekambaram. K.	Fan clamp fixed.		Virgin Mary - Canteen-Girls Hostel	18/06/2022
Comp. Dt. : 04/08/2022 Status : Completed								
139	22080159	Ladies hostel Phase-I	IN ROOM NO.52 MAIN DOOR UNDER BOTTOM -BRICKS WORK-NEED TO DO	Murugavel	masion work completed		Revathy. N. - Canteen-Girls Hostel	17/08/2022
Comp. Dt. : 10/09/2022 Status : Completed								
140	22090394	JR Quarters	NEED MATION WORK FOR GROUND FLOOR	Murugavel	Masion work completed		Virgin Mary - Canteen-Girls Hostel	28/09/2022
Comp. Dt. : 12/10/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
141	22100342	Ladies hostel Phase-II	IN 2ND FLOOR TV HALL TABLE SCREW FIXED	Ekambaram. K.,Sundaramoorthy. G.,Manivannan. A.	Screw fixed, problem solved		Malliga. K. - Canteen-Girls Hostel	20/10/2022
Comp. Dt. : 28/10/2022 Status : Completed								
142	22100895	J.R Quateres	IN ROOM NO.47,85 CUPBOARD DOOR PROBLEM	Ganesan. A.	Wrong complaint.		Virgin Mary - Canteen-Girls Hostel	03/11/2022
Comp. Dt. : 03/11/2022 Status : Completed								
143	22110079	J.R Quateres	IN ROOM NO.108-DOOR LOCK PROBLEM	Ekambaram. K.	Pad lock and hinges changed, work completed		Virgin Mary - Canteen-Girls Hostel	06/12/2022
144	22110080	J.R Quateres	IN GROUND FLOOR REST ROOM NO.3 DOOR LOCK BROKEN,CHANGE IT	Ekambaram. K.	New Pad lock and hinges changed, problem solved		Virgin Mary - Canteen-Girls Hostel	06/12/2022
Comp. Dt. : 04/11/2022 Status : Completed								
145	22110133	J.R Quateres	IN ROM NO.124 DOOR LOCK PROBLEM,CHANGE IT	Ekambaram. K.	New Pad lock and hinges changed, problem solved		Virgin Mary - Canteen-Girls Hostel	06/12/2022
Comp. Dt. : 10/11/2022 Status : Completed								
146	22110387	J.R Quateres	IN WARDEN ROOM-CUPBOARD PATTERN LOCK NEED TO BE FIX	Ekambaram. K.	New Pad lock fixed, problem solved		Virgin Mary - Canteen-Girls Hostel	18/11/2022
147	22110431	Ladies hostel Phase-I	IN ROOM NO.79 CUPBOARD DOOR LOCK NOT CLOSING PROPERLY	Ekambaram. K.	Cupboard door lock repaired and serviced, problem solved		Malliga. K. - Canteen-Girls Hostel	18/11/2022
148	22110432	Ladies hostel Phase-I	IN ROOM NO.79 IN DOOR ENTRANCE-MASON WORK(BRICKS WORK)	Murugavel	Masion work completed		Malliga. K. - Canteen-Girls Hostel	18/11/2022
Comp. Dt. : 11/11/2022 Status : Completed								
149	22110475	Ladies hostel Phase-II	SOME MASON WORK ARE THERE TO DO	Murugavel	Masion work completed		Revathy. N. - Canteen-Girls Hostel	18/11/2022
Comp. Dt. : 14/11/2022 Status : Completed								
150	22110513	Ladies hostel Phase-II	IN ROOM NO.87 AND 81-MASON WORK(CEMENT WALL TO AVOID RAT)	Murugavel	Wall pastering work completed		Revathy. N. - Canteen-Girls Hostel	21/11/2022
151	22110520	J.R Quateres	NEED TO REFIX REST ROOM DOOR LOCK AT GROUND FLOOR	Ekambaram. K.	Door lock repaired and refixed in properly, problem solved		Virgin Mary - Canteen-Girls Hostel	21/11/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
152	22110521	J.R Quateres	IN 3RD FLOOR-ROOM NO.100 FLOOR TILES BROKEN,TOUCHUP WORK NEED TO DO	Murugavel	Tiles refixed, K white cement pointing work completed		Virgin Mary - Canteen-Girls Hostel	21/11/2022
Comp. Dt. : 15/11/2022 Status : Completed								
153	22110586	J.R Quateres	IN ROOM NO.92,84,101,91 CUPBOARD DOOR LOCK REPAIR	Ekambaram. K.	Four Nos of room door lock repaired and serviced, problem solved		Virgin Mary - Canteen-Girls Hostel	21/11/2022
154	22110587	J.R Quateres	IN ROOM NO.100 AND 98-FLOOR TILES BROKEN,TOUCHUP WORK NEEDED	Murugavel	Tiles refixed, JK white cement pointing work completed		Virgin Mary - Canteen-Girls Hostel	21/11/2022
155	22110589	J.R Quateres	IN GROUND FLOOR-BATHROOM DOOR LOCK PROBLEM,NEED TO BE REPAIR	Ekambaram. K.	Bathroom door lock repaired and serviced, problem solved		Virgin Mary - Canteen-Girls Hostel	21/11/2022
Comp. Dt. : 23/11/2022 Status : Completed								
156	22110985	Ladies hostel Phase-I	IN ROOM NO.1-MESH NEED TO BE FIX ON VENTILATOR	Ekambaram. K.	Ventilator mesh fixed, problem solved		Revathy. N. - Canteen-Girls Hostel	01/12/2022
157	22110986	Ladies hostel Phase-I	IN MESS-DINING TABLE LEG BROKEN	Sarathy. A.	Table damaged, not able to repair		Revathy. N. - Canteen-Girls Hostel	06/12/2022
Comp. Dt. : 29/11/2022 Status : Completed								
158	22111240	Ladies hostel Phase-I	MAIN DOOR PLYWOOD GOT DAMAGED	Ekambaram. K.	Plywood fixed in door, work completed		Revathy. N. - Canteen-Girls Hostel	06/12/2022
159	22111241	Ladies hostel Phase-I	IN MESS -MIRROR NEED TO FIX ABOVE WASH BASIN SINK	Ekambaram. K.	Mirror fixed, problem solved		Revathy. N. - Canteen-Girls Hostel	06/12/2022
Comp. Dt. : 06/12/2022 Status : Completed								
160	22120236	Ladies hostel Phase-I	IN ROOM NO.63 AND 67-MIRROR NEED TO BE FIX	Ekambaram. K.	Mirror fixed, problem solved		Revathy. N. - Canteen-Girls Hostel	13/12/2022
Comp. Dt. : 12/12/2022 Status : Completed								
161	22120545	Ladies hostel Phase-I	IN ENTRANCE-WINDOW MIRROR BROKEN	Ekambaram. K.	Novapam sheet fixed, problem solved		Revathy. N. - Canteen-Girls Hostel	19/12/2022
Comp. Dt. : 20/12/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
162	22120884	J.R Quateres	IN 4TH FLOOR ROOM NO 111,113,118,120,121,123 CUPBOARD LOCK REFIXING	Ekambaram. K.,Sundaramoorthy. G.,Pachaimuthusamy . D.	All room cupboard lock refixed, problem solved		Virgin Mary - Canteen-Girls Hostel	27/12/2022
163	22120885	J.R Quateres	DOOR NOT CLOSING IN ROOM NO 113 & 118	Ekambaram. K.	Door repaired and serviced, problem solved		Virgin Mary - Canteen-Girls Hostel	27/12/2022
164	22120928	Ladies hostel Phase-II	ROOM NO 20 DOOR LOCK NOT WORKING	Ekambaram. K.	Door lock repaired and serviced, problem solved		Malliga. K. - Canteen-Girls Hostel	27/12/2022
Comp. Dt. :		21/12/2022						
Status :		Completed						
165	22120970	Ladies hostel Phase-II	NEED TO SCREW FIXING WORK IN CART - ROOM NO. 6	Ekambaram. K.	Cot screw refixed, problem solved		Malliga. K. - Canteen-Girls Hostel	27/12/2022
Comp. Dt. :		22/12/2022						
Status :		Completed						
166	22121006	Ladies hostel Phase-II	CUPBOARD DOOR PROBLEM IN ROOM NO. 17	Ekambaram. K.	Cupboard door repaired and serviced, problem solved		Malliga. K. - Canteen-Girls Hostel	27/12/2022
167	22121007	Ladies hostel Phase-II	NEED TO FIX WINDOW WELGROW IN ROOM NO. 97	Ekambaram. K.,Sundaramoorthy. G.,Pachaimuthusamy . D.	Mosquito net refixed, problem solved		Malliga. K. - Canteen-Girls Hostel	27/12/2022
Comp. Dt. :		26/12/2022						
Status :		Completed						
168	22121173	Ladies hostel Phase-I	NEED MASON WORK NEAR MESS	Murugavel	Mason work completed		Revathy. N. - Canteen-Girls Hostel	02/01/2023
Comp. Dt. :		27/12/2022						
Status :		Completed						
169	22121207	J.R Quateres	IN ROOM NO.11 AND 15-CUPBOARD BROKEN,NEED TO BE REPAIR	Ekambaram. K.,Pachaimuthusamy . D.,Sundaramoorthy. G.	Cipboard door repaired and serviced, problem solved		Virgin Mary - Canteen-Girls Hostel	05/01/2023
Comp. Dt. :		29/12/2022						
Status :		Completed						
170	22121323	Ladies hostel Phase-II	IN ROOM NO.21 PATIENT COT RETIGHTENING WORK	Ekambaram. K.	Cot repaired and serviced, problem solved		Malliga. K. - Canteen-Girls Hostel	05/01/2023
Comp. Dt. :		02/01/2023						
Status :		Completed						
171	23010054	Ladies hostel Phase-I	IN ROOM NO.78-DOOR LOCK NEED TO BE REPAIR	Ekambaram. K.	Door lock repaired and serviced, problem solved		Revathy. N. - Canteen-Girls Hostel	12/01/2023
Comp. Dt. :		05/01/2023						
Status :		Completed						


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
172	23010220	J.R Quateres	NEED TO DO PAINTING WORK IN ENTRANCE	Manimaran. A.	Already painted		Virgin Mary - Canteen-Girls Hostel	23/01/2023
Comp. Dt. : 12/01/2023 Status : Completed								
173	23010522	Ladies hostel Phase-I	IN MESS-MASON WORK	Murugavel	Flooring cement work completed		Revathy. N. - Canteen-Girls Hostel	30/01/2023
Comp. Dt. : 27/01/2023 Status : Completed								
174	23010966	Ladies hostel Phase-II	IN ROOM NO.42-WINDOW AREA-MASON WORK NEED TO DO	Murugavel	Mason work completed		Malliga. K. - Canteen-Girls Hostel	30/01/2023
175	23010993	Ladies hostel Phase-I	IN MESS-MASON WORK	Murugavel	Mason work completed		Revathy. N. - Canteen-Girls Hostel	30/01/2023
Comp. Dt. : 15/02/2023 Status : Completed								
176	23020583	Ladies hostel Phase-II	2ND FLOOR ENTRANCE DOOR PROBLEM	Ekambaram. K.	Door repaired and serviced, problem solved		Malliga. K. - Canteen-Girls Hostel	17/02/2023
Comp. Dt. : 16/02/2023 Status : Completed								
177	23020627	Ladies hostel Phase-II	ROOM NO-110 DOOR STOPER LOOSE POSITION.	Ekambaram. K.	Door stopper adjusted, problem solved		Malliga. K. - Canteen-Girls Hostel	23/02/2023
Comp. Dt. : 05/05/2023 Status : Completed								
178	23050201	JR Quarters	NEED TO CHECK COOLER FLOOR - WATER LEAKAGE AT 1ST FLOOR.	Ekambaram. K.	COOLER BED PLASTERING WORK.		Virgin Mary - Canteen-Girls Hostel	13/05/2023
Comp. Dt. : 15/06/2023 Status : Completed								
179	23060555	Ladies hostel Phase-II	ROOM NO-101 AND 117- -NEED TO FIX DOOR STOPERS.	Ekambaram. K.	Door stopper fixed.		Malliga. K. - Canteen-Girls Hostel	27/06/2023
Dept Name : Civil - Execution - Work Shop Comp. Dt. : 10/06/2022 Status : Completed								
180	22060384	DIRECTOR QUATERS	NEED TO BE REPAIR RAMP GRILL	Sarathy. A.	Work completed.		Sasikala. P. - Civil - Execution	24/09/2022
Comp. Dt. : 18/10/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
181	22100606	professor quarters	PROFESSOR QUATERS ROOM NO:6,9,10 NEED TO CHANGE DOOR	Parthiban.K.,Ekamba ram. K.,Sundaramoorthy. G.	New 3Nos of door fixed, work completed		Sivamurugan. M - Civil - Execution	15/11/2022
Comp. Dt. : 20/01/2023 Status : Completed								
182	23010721	professor quarters	Room no.6,9,10 all rooms door tower bolt to be checked.	Ekambaram. K.	All room door checked, no complaints		Sasikala. P. - Civil - Execution	30/01/2023
Comp. Dt. : 14/03/2023 Status : Completed								
183	23030561	professor quarters	ROOM NO.6 - NEED TO CHANGE MAIN DOOR BOTTOM TILE PIECES.....URGENT	Parivallal. P.	WORK COMPLETED		Sasikala. P. - Civil - Execution	23/03/2023
Comp. Dt. : 22/03/2023 Status : Completed								
184	23030906	professor quarters	NEED TO FIX VENTILATOR GAS AT TOILET IN ROOM NO.6	Ekambaram. K.	GLASS FIXED.		Praveen Kumar. K. - Civil - Execution	01/04/2023
Comp. Dt. : 04/04/2023 Status : Completed								
185	23040123	professor quarters-DEAN SIR HOUSE	NEED TO CHANGE TILES IN BALCONY.	Parivallal. P.	Tiles refixed, JK White cement pointing work completed		Murugan.N. - Civil - Execution	13/04/2023
186	23040124	professor quarters-DEAN SIR HOUSE	NEED TO REPAIR THE DAMAGED BALCONY DOOR	Ekambaram. K.	Door repaired and serviced, refixed in properly, problem solved		Murugan.N. - Civil - Execution	17/04/2023
187	23040125	professor quarters-DEAN SIR HOUSE	NEED TO CHANGE THE GRANITE IN LIFT AREA	Parivallal. P.	Granite changed, work completed		Murugan.N. - Civil - Execution	17/04/2023
Comp. Dt. : 08/04/2023 Status : Completed								
188	23040256	professor quarters-DEAN SIR HOUSE	NEED TO FIX MOSQUITO NET IN ALL WINDOWS	Ekambaram. K.	MUSQUITO NET FIXED.		Murugan.N. - Civil - Execution	05/05/2023
Comp. Dt. : 17/05/2023 Status : Completed								
189	23050684	professor quarters	NEED TO FIX GRANITE IN ALL FLOOR STAIRCASE; IN ROOM NO.9, WALL TILE GROUT SHOULD BE APPLIED	Parivallal. P.	WORK COMPLETED		Praveen Kumar. K. - Civil - Execution	01/06/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 18/05/2023 Status : Completed								
190	23050754	MIT College	NEED TO FIX THE GLASS IN SHUTTER AT GROUND FLOOR FOOD TECHNOLOGY LAB	Ekambaram. K.	New glass fixed.		Murugan.N. - Civil - Execution	05/08/2023
Comp. Dt. : 30/06/2023 Status : Completed								
191	23061125	COURTYARD	Need to fix banner (2nos.) at courtyard opposite to paediatrics opd for doctor's day celebration.	Pachaimuthusamy. D.	Banner fixing work completed		Murugan.N. - Civil - Execution	08/07/2023
Dept Name : Civil - Maintenance - Work Shop Comp. Dt. : 18/04/2023 Status : Completed								
192	23040558	HOSPITAL TERROUS	RAIN WATER PIPE PATCH WORK	Parivallal. P.	PACKING WORK COMPLETED		Gopal. S. - Civil - Maintenance	02/05/2023
Dept Name : Computer Department - Work Shop Comp. Dt. : 09/11/2022 Status : Completed								
193	22110327	EDP IN UNDERGROUND	Need 2 System stand	Ekambaram. K.	New stand fixed, problem solved		Selvam. D. - Computer Department	18/11/2022
Comp. Dt. : 20/01/2023 Status : Completed								
194	23010716	Pathology Lab	HOLE CLOSE AND PAINTING	Murugavel	Hole closed, cement patching work completed		Raja.B - Computer Department	30/01/2023
Comp. Dt. : 31/05/2023 Status : Completed								
195	23051265	MEDICAL COLLEGE	Lect. Hall 2 and 3 projector screen to fix	Ekambaram. K., Sundaramoorthy. G., Manivannan. A.	Screen fixed		Selvam. D. - Computer Department	20/06/2023
Comp. Dt. : 06/06/2023 Status : Completed								
196	23060193	EDP IN UNDERGROUND	office Table partiion need fixed	Ekambaram. K.	Partition fixing work completed		Selvam. D. - Computer Department	05/08/2023
Dept Name : CSSD - Work Shop Comp. Dt. : 02/07/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
197	22070064	CSSD	NEED TO FIX REXINE SHEET FOR TABLE	Pachaimuthusamy. D.	Rexine sheet fixed, problem solved		Pazhanivel.S. - CSSD	09/07/2022
Dept Name : Derm,Pulmo,Psych Ward - Work Shop Comp. Dt. : 20/12/2022 Status : Completed								
198	22120938	PSYCHIATRY WARD	IN REST ROOM FIXING TOWEL STAND	Ekambaram. K.	Towel stand fixed, work completed		Sarathkumar. R. - Derm,Pulmo,Psych Ward	23/01/2023
199	22120939	PSYCHIATRY WARD	NURSES CABIN MICA SHEET REFIXING WORK	Ekambaram. K.,Pachaimuthusamy . D.,Sundaramoorthy. G.	New Nurses cabin fixed, problem solved		Sarathkumar. R. - Derm,Pulmo,Psych Ward	27/12/2022
Dept Name : Director Office - Work Shop Comp. Dt. : 19/08/2022 Status : Completed								
200	22080639	A.P Quateres	IN ROOM NO.12 WALL TILES FIXING WORK NEED TO DO	Murugavel	Tiles fixed, JK white cement pointing work completed		Mani. A. - Director Office	25/08/2022
Comp. Dt. : 28/10/2022 Status : Completed								
201	22100904	A.P Quateres	IN ROOM NO.28 BATHROOM DOOR PROBLEM	Ekambaram. K.	Restroom door refixed.		Mani. A. - Director Office	03/11/2022
202	22100906	A.P Quateres	IN ROOM NO.55 BEDROOM FLOOR TILES PACKING WORK NEED TO DO	Murugavel	Tiles refixed.		Mani. A. - Director Office	03/11/2022
203	22100936	A.P Quateres	IN ROOM NO.31 BATHROOM DOOR AND MAIN DOOR PROBLEM	Ekambaram. K.	Restroom door refixed.		Mani. A. - Director Office	03/11/2022
Comp. Dt. : 31/10/2022 Status : Completed								
204	22101031	A.P Quateres	BATHROOM DOOR PROBLEM IN AP 28	Ekambaram. K.	Door repaired and refixed in properly, problem solved		Mani. A. - Director Office	08/11/2022
Comp. Dt. : 21/11/2022 Status : Completed								
205	22110881	A.P Quateres	IN ROOM NO.12-TILES PACKAGING AND PLATERING WORK NEED TO DO	Murugavel	Tiles fixed, JK white cement pointing work done		Mani. A. - Director Office	01/12/2022
206	22110882	A.P Quateres	IN ROOM NO.19-WINDOW DOOR PROBLEM	Ekambaram. K.	Window door repaired and serviced, problem solved		Mani. A. - Director Office	01/12/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
207	22110883	A.P Quateres	IN ROOM NO.31-BEDROOM-DOOR LOCK PROBLEM	Ekambaram. K.	Door lock repaired and serviced, problem solved		Mani. A. - Director Office	01/12/2022
	Comp. Dt. : 20/12/2022							
	Status : Completed							
208	22120921	A.P Quateres	TILES PACKING WORK IN ROOM NO 10 & 43	Murugavel	Tiles refixed, JK White cement pointing work completed		Mani. A. - Director Office	29/12/2022
	Comp. Dt. : 21/12/2022							
	Status : Completed							
209	22120983	LECTURE HALL 1 AND 2 IN MEDICAL COLLEGE	NEED CARPENTER WORK IN LECTURE HALL 1 AND 2	Ekambaram. K.,Pachaimuthusamy .D.,Sundaramoorthy. G.	Carpenter work completed		Bala Murugan.K. - Director Office	29/12/2022
	Comp. Dt. : 23/12/2022							
	Status : Completed							
210	22121079	A.P Quateres	BALCONY & KITCHEN DOOR DAMAGED IN ROOM NO 16	Ekambaram. K.	Balcony and kitchen door repaired and serviced, problem solved		Mani. A. - Director Office	02/01/2023
	Comp. Dt. : 05/01/2023							
	Status : Completed							
211	23010227	QUARTERS OFFICE	S-TYPE CHAIR WIRE GOT DAMAGED,NEED TO BE REPAIR	Venkatesan. R.	Chair repaired.		Mani. A. - Director Office	11/01/2023
	Comp. Dt. : 10/01/2023							
	Status : Completed							
212	23010409	A.P Quateres	IN ROOM NO.13-BATHROOM TILES PACKING WORK NEED TO DO	Murugavel	Tiles refixed, JK white cement pointing work completed		Mani. A. - Director Office	23/01/2023
	Comp. Dt. : 11/01/2023							
	Status : Completed							
213	23010495	A.P Quateres	IN ROOM NO.28-BATHROOM DOOR FRAME GOT DAMAGED,REPAIR IT	Ekambaram. K.	Door repaired and serviced, problem solved		Mani. A. - Director Office	23/01/2023
214	23010496	ASSOCIATIVE PROFESSOR QUARTERS	IN ROOM NO.12-BATHROOM WALL PLASTERING WORK	Murugavel	Wall plastering work completed		Mani. A. - Director Office	23/01/2023
	Comp. Dt. : 16/06/2023							
	Status : Completed							


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
215	23060613	A.P Quateres	ROOM NO-44 AND 53- -FLOOR TILES PACKING WORK	Parivallal. P.	Tiles fixed		Mani. A. - Director Office	05/08/2023
Dept Name : EMERGENCY MEDICINE - Work Shop Comp. Dt. : 05/08/2022 Status : Completed								
216	22080193	Casualty	MOVABLE SCREEN RODE IS BROKEN NEED TO REFIX IT	Sarathy. A.	screen rod and Spring refixed, problem solved		Devi. S - EMERGENCY MEDICINE	17/08/2022
Comp. Dt. : 05/10/2022 Status : Completed								
217	22100045	Casualty	NEED REPAIRING WORK FOR COT - BROKEN	Sarathy. A.	Cot repaired and servied, problem solved		Kanimozhi. E. - EMERGENCY MEDICINE	12/10/2022
Comp. Dt. : 20/10/2022 Status : Completed								
218	22100673	Casualty	ROOM NO 38, DOOR NOT WORKING, SCREEN WHEEL NOT WORKING, BED RISER NOT WORKING	Ekambaram. K.	Work completed.		Balamurugan. M. - EMERGENCY MEDICINE	29/10/2022
Dept Name : ENT & Ophthal Ward - Work Shop Comp. Dt. : 02/09/2022 Status : Completed								
219	22090083	ENT WARD	NEED TO 408 TREATMENT ROOM TILES BROKEN NEED TO REFIX IT	Murugavel	26 m of tiles refixed and JK white applied.		Samundeeswari. E. - ENT & Ophthal Ward	08/09/2022
Comp. Dt. : 20/12/2022 Status : Completed								
220	22120940	ENT WARD-408	IN 408 WARD PATIENT DUCT ROOM DOOR NOT WORKING	Ekambaram. K.	Duct door fixed, problem solved		Jayalakshmi. J. - ENT & Ophthal Ward	29/12/2022
Dept Name : Female Medical Ward - Work Shop Comp. Dt. : 05/07/2022 Status : Completed								
221	22070165	Female Medical Ward	NEED TO FIX MOSQUITO NET FOR ALL ROOM - WARD NO 305 & 306	Ekambaram. K.,Pachaimuthusamy . D.,Venkatesan. R.	Frame and mesh fixed.		Vaitheeswari. A. - Female Medical Ward	24/09/2022
Dept Name : FORENSIC MEDICINE - Work Shop Comp. Dt. : 16/12/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
222	22120785	FORENSIC MEDICINE (3RD FLOOR) IN COLLEGE	TILES BROKEN 15 NOS - NEED TOUCH UP WORK	Murugavel	20Nos of Tiles refixed, JK white cement pointing work completed		Mathavi. B. - FORENSIC MEDICINE	23/12/2022
Dept Name : Guest House - Indian Bank - Work Shop Comp. Dt. : 19/08/2022 Status : Completed								
223	22080633	Guest House - Indian Bank	MAIN DOOR LOCK PROBLEM IN ROOM NO 205	Ekambaram. K.	Lock repaired. work completed.		John. H. - Guest House - Indian Bank	24/09/2022
Comp. Dt. : 16/02/2023 Status : Completed								
224	23020632	Guest House - Indian Bank	NEED TO CHANGE ALL WASHBASIN MIRROR	Pachaimuthusamy. D.	Mirror fixed, work completed		John. H. - Guest House - Indian Bank	23/02/2023
Comp. Dt. : 22/02/2023 Status : Completed								
225	23020867	Guest House - Indian Bank	ROOM NO-205,MAIN DOOR DAMAGE AND REST ROOM DOOR ALSO DAMAGE	Ekambaram. K.	Door repaired and refixed in properly, problem solved		John. H. - Guest House - Indian Bank	01/03/2023
Comp. Dt. : 03/04/2023 Status : Completed								
226	23040068	Guest House - Indian Bank	ROOM NO 204 & 205 REST ROOM TILES PATCH WORK...URGENT INSPECTION PURPOSE	Parivallal. P.	New tiles refixed, JK White cement pointing work completed		John. H. - Guest House - Indian Bank	17/04/2023
Dept Name : Housekeeping - Work Shop Comp. Dt. : 07/06/2022 Status : Completed								
227	22060271	Paediatrics - Ward 309	NEED TO FIX SCREEN PIPE ROD FOR DRESS CHANGING ROOM	Sundaramoorthy. G.	New screen pipe fixed.		Naresh. R - Housekeeping	13/06/2022
Comp. Dt. : 05/01/2023 Status : Completed								
228	23010239	Boys hostel	S-TYPE CHAIR GOT DAMAGED AND NEED TO BE REPAIR	Venkatesan. R.	Chairs (2nos.) completed.		Sankar.R. - Housekeeping	11/01/2023
Comp. Dt. : 18/04/2023 Status : Completed								
229	23040557	LIFT 3 AND 4	GROUND FLOOR TILES BROKEN	Parivallal. P.	TILES REFIXED		Palasubramaniyam. G. - Housekeeping	02/05/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Dept Name : ICCU - Work Shop Comp. Dt. : 14/11/2022 Status : Completed								
230	22110549	Mit ladies hostel	FLOOR TILES BROKEN, TOUCHUP WORK NEEDED	Murugavel	15Nos of Tilesrefixed, JK White cement pointing work completed		Ammu. R. - ICCU	21/11/2022
Comp. Dt. : 15/11/2022 Status : Completed								
231	22110578	Mit ladies hostel	IN ROOM NO.70-DOOR LOCK PROBLEM AND ROOM NO.104-CUPBOARD DOOR NEED TO BE REFIX	Ekambaram. K.	Cup door and door lock refixed in properly, problem solved		Ammu. R. - ICCU	21/11/2022
Comp. Dt. : 19/11/2022 Status : Completed								
232	22110829	Mit ladies hostel	IN GROUND FLOOR -STAFF SIDE BATHROOM-BATHROOM DOOR LOCK PROBLEM	Ekambaram. K.	Door repaired and serviced, refixed in properly, problem solved		Ammu. R. - ICCU	01/12/2022
233	22110830	Mit ladies hostel	IN GROUND FLOOR -STAFF SIDE BATHROOM-TOWEL STAND NEED TO BE FIX	Ekambaram. K.	Towel stand refixed in properly, problem solved		Ammu. R. - ICCU	01/12/2022
Dept Name : ICU - Work Shop Comp. Dt. : 30/05/2023 Status : Completed								
234	23051190	ICU	NEED REPAIRING WORK FOR STRETCHER [NORMAL & O2] - STUCK	Sarathy. A.	Wheel replaced		Regina Mary. S. - ICU	20/06/2023
Dept Name : Labour Ward - Work Shop Comp. Dt. : 10/05/2023 Status : Completed								
235	23050397	labour room -pow	NAME BOARD REMOVING	Ekambaram. K.	BOARD REOVED		Brema. V. - Labour Ward	18/05/2023
Dept Name : Library - Work Shop Comp. Dt. : 21/12/2022 Status : Completed								
236	22120986	MEDICAL COLLEGE LIBRARY	NEED TO CHECK DOOR PROBLEM	Ekambaram. K.,Sundaramoorthy. G.,Pachaimuthusamy . D.	New door fixed, work completed		Elangovan.N. - Library	29/12/2022
Comp. Dt. : 08/02/2023 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
237	23020297	MEDICAL COLLEGE LIBRARY	DOOR CLOSURE NOT WORKING IN GROUND FLOOR LIBRARY	Parthiban.K.	Door closer adjusted, problem solved		Elangovan.N. - Library	16/02/2023
Dept Name : Male Ortho Ward - Work Shop Comp. Dt. : 11/01/2023 Status : Completed								
238	23010454	Male Ortho - Ward 404	CROSSCORD TROLLY REPAIR WORK	Sarathy. A.	Trolley repaired and serviced, problem solved		Rajasree. R. - Male Ortho Ward	23/01/2023
Dept Name : MS Office - Work Shop Comp. Dt. : 22/11/2022 Status : Completed								
239	22110917	HOSPITAL I FLOOR D WING	MARBLES TILES DAMAGED NEAR LIFT NO 3	Murugavel	Marbles fixed and plastering work completed		Sundarrajan. R. - MS Office	01/12/2022
Comp. Dt. : 09/12/2022 Status : Completed								
240	22120412	POW & SICU	PILLAR SLAB MARBLES DAMAGED & BROKEN NEED TOUCHUP WORK AT POST OPP WARD OPPOSITE	Murugavel	Slab fixed and mason work completed		Sundarrajan. R. - MS Office	19/12/2022
Dept Name : Nursing Office - Work Shop Comp. Dt. : 02/03/2023 Status : Completed								
241	23030073	New OT	NEED REPAIRING WORK FOR NORCOATING DOUBLE LOCK - NOTWORKING	Ekambaram. K.	NEW LOCK FIXED.		Devika.R - Nursing Office	04/05/2023
Dept Name : OPD - Work Shop Comp. Dt. : 12/10/2022 Status : Completed								
242	22100329	PSYCHIATRY OPD	DOTCOR ROOM TOWEL STAND SCREW REMOVED NEED TO BE FIXED	Sundaramoorthy. G.	Towel stand refixed, problem solved		Bhuvaneswari. G. - P.H.C. - Tiruvonnainallur	20/10/2022
Comp. Dt. : 20/10/2022 Status : Completed								
243	22100671	Ophthalmology - OPD	BIN WELDING WORK	Sarathy. A.	BNin repaired		Seetha. R. - OPD	29/10/2022
244	22100674	General Medicine - OPD	ROLLING CHAIR NOT WORKING	Ekambaram. K.	Chair repaired.		Sharathi.D. - OPD	29/10/2022
Comp. Dt. : 02/01/2023								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
245	23010017	Ophthalmology - OPD	BOX REPAIR WORK NEED TO DO	Ekambaram. K.	Box repaired and serviced, problem solved		Seetha. R. - OPD	12/01/2023
Dept Name : Paediatrics Ward - Work Shop								
Comp. Dt. : 23/12/2022								
Status : Completed								
246	22121094	Paediatrics - Ward 308	NEED TO CHECK DOOR PROBLEM IN DEMO ROOM	Ekambaram. K.	Demo room door repaired and serviced, problem solved		Chitra. P. - Paediatrics Ward	02/01/2023
Dept Name : Pharmacy - Work Shop								
Comp. Dt. : 20/10/2022								
Status : Completed								
247	22100703	Free Pharmacy	free pharmacy near ladies toilet door lock not working - 2 door	Ekambaram. K.	pad lock fixed.		Thilagavathi. T. - Pharmacy	29/10/2022
Dept Name : RICU - Work Shop								
Comp. Dt. : 27/12/2022								
Status : Completed								
248	22121232	RICU	MONITOR CABLE HANGING CLAMP 24 NO'S NEED TO BE FIX	Sarathy. A.	24Nos Hanging clamp fixed, work completed		Tamililakkiya. K. - RICU	05/01/2023
Dept Name : SMV Allied Health Sciences - Work Shop								
Comp. Dt. : 22/12/2022								
Status : Completed								
249	22121020	MICROBIOLOGY IN COLLEGE	BEROW HANDLE BROKEN IN TUTOR ROOM	Ekambaram. K.	Bero handle fixed, problem solved		Raffik Moideen. M. - SMV Allied Health Sciences	29/12/2022
Dept Name : Special Ward - Work Shop								
Comp. Dt. : 12/10/2022								
Status : Completed								
250	22100334	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	BLACK CHAIR NEED TO BE FIXED PROPERLY	Ekambaram. K., Parthiban. K., Sundaramoorthy. G.	Chiar repaired and serviced, problem solved		Elakkiya. S. - Special Ward	15/11/2022
Comp. Dt. : 28/12/2022								
Status : Completed								
251	22121273	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	DOOR PROBLEM IN MAIN DOOR AND ECG ROOM DOOR	Ekambaram. K.	Door screw refixed, problem solved		Dhatchayani. N. - Special Ward	05/01/2023
Dept Name : Transport - Work Shop								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 15/09/2022 Status : Completed								
252	22090586	WATER SERVICE	CHANNEL FIXING WORK FOR COMPRESSOR(WELDING WORK)	Sarathy. A.,Moorthy. L.,Manivannan. A.	New frame maked and fixed in compessor, work completed		Sasikumar. P. - Transport	28/09/2022
Work Type : Work Dept Name : Canteen - Boys Hostel - Work Shop Comp. Dt. : 06/12/2022 Status : Completed								
253	22120248	Boys hostel P.H-III	REQUEST TO MAKE WHITE CEMENT PACKAGING WORK IN ALL ROOMS DOOR ENTRANCE (MASON WORK AT TOTALLY 17 ROO	Murugavel	10 Nos of room JK white cement pointing work completed		Sambasivam. K. - Canteen - Boys Hostel	19/12/2022
Dept Name : Canteen-Girls Hostel - Work Shop Comp. Dt. : 23/11/2022 Status : Completed								
254	22110992	Ladies hostel Phase-II	IN ROOM NO.37-INFRONT OF DOOR(MASON WORK-CEMENT WORK)NEED TO DO	Murugavel	Masion work completed		Malliga. K. - Canteen-Girls Hostel	01/12/2022
Comp. Dt. : 28/11/2022 Status : Completed								
255	22111165	Ladies hostel Phase-I	NEED TO PAINT 32 NO'S DINING CHAIRS	Manimaran. A.,Viswa. V.,Sundaramoorthy. K.	Chairs painting work completed		Revathy. N. - Canteen-Girls Hostel	06/12/2022
Dept Name : Civil - Execution - Work Shop Comp. Dt. : 30/06/2023 Status : Completed								
256	23061110	Polytechnic college	I floor west side ladies toilet - door shutter and frame, Duct door repair work to be done	Ekambaram. K.,Sundaramoorthy. G.,Ganesh. S.	Work completed		Sasikala. P. - Civil - Execution	08/07/2023
Dept Name : Transport - Work Shop Comp. Dt. : 07/03/2023 Status : Completed								
257	23030282	Transport	In commercial complex - Transport office door lock to be change	Ekambaram. K.	ALUMINIUM DOOR LOCK FIXED.		Ashok Kumar. K. - Transport	14/03/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
College Name :		SMVMCH-COL						
Work Type :		Complaint						
Dept Name :		Air Condition Department - Work Shop						
Comp. Dt. :		18/08/2022						
Status :		Completed						
258	22080586	DIGITAL LAB	A/C PLYWOOD NEED TO BE CLOSE	Ekambaram. K.	Plywood closed, work completed		Panneer Selvam. P. - Air Condition Department	25/08/2022
Comp. Dt. :		20/03/2023						
Status :		Completed						
259	23030800	MEDICAL COLLEGE	NEED PAINTING WORK FOR CHILLER BASE	Manimaran. A.	CHILLER BASE PAINTING WORK COMPLETED		Panneer Selvam. P. - Air Condition Department	04/05/2023
Dept Name :		ANATOMY - Work Shop						
Comp. Dt. :		18/05/2022						
Status :		Completed						
260	22050681	ANATOMY	NEED REPAIRING WORK FOR PROF. ROOM DOOR LOCK	Ekambaram. K.	Door closer refixed and lock serviced, problem solved		Mathivanan.B. - ANATOMY	27/05/2022
Comp. Dt. :		22/06/2022						
Status :		Completed						
261	22060784	ANATOMY	NEED WELDING WORK FOR STOOLS [10 NOS]	Sarathy. A.	22 nos. stool welded and painted.		Mathivanan.B. - ANATOMY	24/09/2022
Comp. Dt. :		26/09/2022						
Status :		Completed						
262	22091032	ANATOMY	NEED WELDING WORK FOR SPOT LIGHT	Manivannan. A.	Spotlight repaired, problem solved		Mathivanan.B. - ANATOMY	08/10/2022
Comp. Dt. :		10/10/2022						
Status :		Completed						
263	22100255	ANATOMY	NEED REPAIRING WORK FOR DISSECTION HALL BACK DOOR - DAMAGE & BROKEN	Ekambaram. K., Sundaramoorthy. G., Venkatesan. R.	New door and 1.1/2" Hinges 3 Nos fixed, work completed		Mathivanan.B. - ANATOMY	15/11/2022
Comp. Dt. :		27/10/2022						
Status :		Completed						
264	22100859	DISSERTION HALL IN MEDICAL COLLEGE	CADAVER DOOR PROBLEM-NOT CLOSING PROPERLY	Ekambaram. K.	5" SS Hinges 3Nos changed, problem solved		Mathivanan.B. - ANATOMY	15/11/2022
Comp. Dt. :		02/01/2023						
Status :		Completed						


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
265	23010033	ANATOMY	IN TUTOR ROOM-RAINWATER LEAKAGING FROM SUNSIDE-NEED TO BE CLOSE WITH PLYWOOD	Ekambaram. K.	Wrong complaint, civil dept complaint, inform to civil dept		Mathivanan.B. - ANATOMY	12/01/2023
Comp. Dt. : 13/04/2023 Status : Completed								
266	23040408	ANATOMY	NEED TO FIX PHOTO FRAME	Ekambaram. K.	Photo frame fixed		Mathivanan.B. - ANATOMY	20/04/2023
Dept Name : BIOCHEMISTRY - Work Shop Comp. Dt. : 10/06/2022 Status : Completed								
267	22060366	BIOCHEMISTRY--COLLEGE	CHAIR LIFTING PROBLEM	Sarathy. A.	Chair repaired.		Suganthi. P. - BIOCHEMISTRY	21/06/2022
Comp. Dt. : 23/06/2022 Status : Completed								
268	22060860	BIOCHEMISTRY--COLLEGE	NEED REPAIRING WORK FOR TABLE - BROKENED - [HOD SIR ROOM]	Pachaimuthusamy. D.	Screen fixed, work completed		Suganthi. P. - BIOCHEMISTRY	01/07/2022
Comp. Dt. : 19/09/2022 Status : Completed								
269	22090740	Central Research Lab	DUE MOVING FALSE CEILING THERMOCOL AC COOLING GOING OUT SIDE - NEED TO REFIX -	Ekambaram. K.	False ceiling fixed, problem solved		Anusuya. J. - BIOCHEMISTRY	29/09/2022
Comp. Dt. : 21/09/2022 Status : Completed								
270	22090835	Central Research Lab	NEED REPAIRING WORK FOR WINDOW - ON OFF PROBLEM	Ekambaram. K.,Sundaramoorthy. G.,Venkatesan. R.	Window repairing work completed		Anusuya. J. - BIOCHEMISTRY	29/09/2022
Comp. Dt. : 17/03/2023 Status : Completed								
271	23030719	BIOCHEMISTRY	NEED REPAIRING WORK FOR CUSHION CHAIRS & REFIX WINDOW GLASS DOOR PIPING WORK	Parthiban.K.	All carpenter work completed		Suganthi. P. - BIOCHEMISTRY	31/03/2023
272	23030720	BIOCHEMISTRY	NEED TO FIX SCREEN ROD & HOOK	Ekambaram. K.	Screen rod fixed		Suganthi. P. - BIOCHEMISTRY	31/03/2023
Comp. Dt. : 23/03/2023 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
273	23030965	BIOCHEMISTRY-- -COLLEGE	NEED TO CHECK [REPAIRING WORK] CUSHION CHAIR 13 NOS -	Pachaimuthusamy. D.	CHAIR HAS NO DAMAGED.		Suganthi. P. - BIOCHEMISTRY	01/04/2023
274	23030966	BIOCHEMISTRY-- -COLLEGE	NEED REPAIRING WORK FOR WINDOW GLASS DOOR - BROKEN	Ekambaram. K.	NEW GLASS FIXED.		Suganthi. P. - BIOCHEMISTRY	01/04/2023
Comp. Dt. : 19/04/2023 Status : Completed								
275	23040593	BIOCHEMISTRY	NEED REPAIRING WORK FOR DOOR STOPPER & RESTROOM DOOR LOCK FOR HOD ROOM	Ekambaram. K.	DOOR STOPPER FIXED		Suganthi. P. - BIOCHEMISTRY	17/05/2023
Comp. Dt. : 20/04/2023 Status : Completed								
276	23040638	BIOCHEMISTRY-- -COLLEGE	NEED REPAIRING WORK FOR DOOR PATLOCK - STUCK - NOT ABLE TO OPEN	Ekambaram. K.	WORK COMPLETEDQ		Suganthi. P. - BIOCHEMISTRY	02/05/2023
277	23040669	BIOCHEMISTRY-- -COLLEGE	NEED TO FIT A NEW WOODEN RACK FOR ACID TO KEEP	Ekambaram. K., Sundaramoorthy. G., Pachaimuthusamy . D.	WORK COMPLETED		Suganthi. P. - BIOCHEMISTRY	02/05/2023
Comp. Dt. : 26/04/2023 Status : Completed								
278	23040857	BIOCHEMISTRY-- -COLLEGE	NEED TO FIT SCREEN ROD BETWEEN STAFF ROOM TO RESTROOM	Ekambaram. K.	Screen rod fixed, problem solved		Suganthi. P. - BIOCHEMISTRY	08/05/2023
Comp. Dt. : 11/05/2023 Status : Completed								
279	23050430	BIOCHEMISTRY-- -COLLEGE	NEED REPAIRING WORK FOR ROLLING CHAIR - WHEEL STUCK	Ekambaram. K.	WRONG COMPLAINT		Suganthi. P. - BIOCHEMISTRY	18/05/2023
Comp. Dt. : 19/05/2023 Status : Completed								
280	23050794	BIOCHEMISTRY-- -COLLEGE	NEED TO REFIX NAME BOARD AT C R LAB	Ekambaram. K.	BOARD FIXED.		Anusuya. J. - BIOCHEMISTRY	01/06/2023
Comp. Dt. : 26/05/2023 Status : Completed								
281	23051024	BIOCHEMISTRY-- -COLLEGE	NEED PAINTING WORK FOR LAB	Manimaran. A.	PAINTING WORK COMPLETED		Suganthi. P. - BIOCHEMISTRY	03/06/2023
Dept Name : Civil - Execution - Work Shop Comp. Dt. : 25/03/2023								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
282	23031055*	COMMUNITY MEDICINE DEPT IN MEDICAL COLLEGE	NEED DOOR FRAME TILES PACKING WORK	Parivallal. P.	NEW TILES FIXED.		Sivamurugan. M - Civil - Execution	01/04/2023
Comp. Dt. : 28/03/2023								
Status : Completed								
283	23031194	FORENSIC MEDICINE	NEED TO FIX DOORS IN PROPOSED DEMO ROOM	Ekambaram. K.	DOOR FIXED.		Sasikala. P. - Civil - Execution	05/05/2023
Comp. Dt. : 05/04/2023								
Status : Completed								
284	23040160	DIGITAL LAB	NEED TO FIX SLIDING DOOR AT GROUND FLOOR DIGITAL LIBRARY	Ekambaram. K.	WORK COMPLETED		Murugan.N. - Civil - Execution	05/05/2023
Dept Name : Civil - Maintenance - Work Shop								
Comp. Dt. : 14/03/2023								
Status : Completed								
285	23030533	DISSERTION HALL IN MEDICAL COLLEGE	DUE TO REMOVE UNWANTED WASH BASIN TAPS [15 NOS] NEED TO CLOSE THE HOLES WITH CEMENT	Murugavel	PLASTERING WORK COMPLETED. (1 BAG CEMENT USED)		Sankar. R - Civil - Maintenance	23/03/2023
Dept Name : COMMUNITY MEDICINE - Work Shop								
Comp. Dt. : 02/05/2022								
Status : Completed								
286	22050022	COMMUNITY MEDICINE DEPT IN MEDICAL COLLEGE	NEED TO REFIX DOOR STOPER	Ekambaram. K.	New door stopper 2Nos fixed, problem solved		Muthuvel. A. - COMMUNITY MEDICINE	26/05/2022
Comp. Dt. : 18/05/2022								
Status : Completed								
287	22050640	COMMUNITY MEDICINE DEPT IN MEDICAL COLLEGE	NEED TO REFIX DOOR STOPPER FOR LAB & SEMINAR ROOM	Pachaimuthusamy. D.	Door stopper refixed, problem solved		Muthuvel. A. - COMMUNITY MEDICINE	27/05/2022
288	22050642	COMMUNITY MEDICINE DEPT IN MEDICAL COLLEGE	NEED TO FIX BOARD 2 NOS FOR INSPECTION	Ekambaram. K.	Bord 2Nos fixed, work completed		Muthuvel. A. - COMMUNITY MEDICINE	27/05/2022
Comp. Dt. : 24/05/2022								
Status : Completed								
289	22050862	COMMUNITY MEDICINE DEPT IN MEDICAL COLLEGE	NEED TO REFIX DOOR STOPPER FOR SEMINOR ROOM DOOR	Ekambaram. K.	New door stopper fixed, problem solved		Muthuvel. A. - COMMUNITY MEDICINE	27/05/2022
Comp. Dt. : 14/12/2022								
Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
290	22120670	COMMUNITY MEDICINE DEPT IN MEDICAL COLLEGE	NEED TO REFIX DAMAGED BROKEN TILES FOR FEMALE RESTROOM	Murugavel	Tiles refixed, JK white cement pointing work completed		Sunitha. P. - COMMUNITY MEDICINE	23/12/2022
Comp. Dt. : 15/12/2022 Status : Completed								
291	22120727	PHYSIOLOGY-- -COLLEGE	NEED REPAIRING WORK FOR BERO LOCK	Ekambaram. K.	New lock changed, problem solved		Raghavendran. V. - COMMUNITY MEDICINE	23/12/2022
Comp. Dt. : 25/01/2023 Status : Completed								
292	23010915	Medical Education Unit	NEED TO CHECK STEEL TABLE DRAW - STUCK	Ekambaram. K.	Table draw repaired and serviced, problem solved		Raghavendran. V. - COMMUNITY MEDICINE	16/02/2023
Comp. Dt. : 11/02/2023 Status : Completed								
293	23020443	COMMUNITY MEDICINE DEPT IN MEDICAL COLLEGE	NEED REPAIRING WORK FOR "S" TYPE CHAIR 6NOS	Manivannan. A.	knitted wire in S Type chair with contract labour, work completed		Muthuvel. A. - COMMUNITY MEDICINE	16/02/2023
Comp. Dt. : 11/05/2023 Status : Completed								
294	23050444	COMMUNITY MEDICINE DEPT IN MEDICAL COLLEGE	NEED TO REFIX MICCO FOR HOD TABLE	Ekambaram. K.	MICA FIXED		Muthuvel. A. - COMMUNITY MEDICINE	18/05/2023
Dept Name : Computer Department - Work Shop Comp. Dt. : 26/08/2022 Status : Completed								
295	22080878	MEDICAL COLLEGE	NEED TO FIX WHITE BOARD FOR CLASS ROOM	Ekambaram. K.	Board fixed.		Prakash. P. - Computer Department	09/09/2022
296	22080911	DIGITAL LAB	NEED TO REFIX PLYWOOD SHEET FOR SERVER ROOM TOP & REPAIRING WORK FOR TABLE LEG - DAMAGE	Pachaimuthusamy. D.	Board fixed.		Madhubalan. S. - Computer Department	09/09/2022
Comp. Dt. : 16/09/2022 Status : Completed								
297	22090619	DIGITAL LAB	NEED REPAIRING WORK FOR SERVER ROOM DOOR - CLOSING PROBLEM	Parthiban.K.	New door closer 1No fixed and false ceiling fixed, problem solved		Jayaraj. J. - Computer Department	20/10/2022
Comp. Dt. : 27/09/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
298	22091040	MEDICAL COLLEGE	NEED TO PUT HOLE FOR PODIUM FOR SKILL LAB AT MEDICAL COLLEGE	Ekambaram. K.	Holes drilled, problem solved		Prakash. P. - Computer Department	20/10/2022
Comp. Dt. : 03/12/2022 Status : Completed								
299	22120110	PHARMACOLOGY	BOARD REFIXING WORK IN DEMO ROOM 2	Ekambaram. K.	Board fixed.		Raja.B - Computer Department	10/12/2022
Comp. Dt. : 21/02/2023 Status : Completed								
300	23020809	DIGITAL LAB	NEED REPAIRING WORK FOR DOOR - NOT CLOSING PROPER	Ekambaram. K.	Door repaired and serviced, problem solved		Harikrishnan. R. - Computer Department	01/03/2023
Comp. Dt. : 03/03/2023 Status : Completed								
301	23030132	DIGITAL LAB	NEED REPAIRING WORK FOR FRONT DOOR LOCK - NOT WORKING	Ekambaram. K.	Door and door lock repaired and serviced, problem solved		Venkatesh. S. - Computer Department	09/03/2023
Comp. Dt. : 21/03/2023 Status : Completed								
302	23030868	DIGITAL LAB	NEED WHITE CEMENT WORK	Parivallal. P.	JK white cement pointing work completed		Jayaraj. J. - Computer Department	31/03/2023
Comp. Dt. : 22/05/2023 Status : Completed								
303	23050873	DIGITAL LAB	NEED REPAIRING WORK FOR BACKSIDE DOOR - STUCK	Ekambaram. K.	DOOR REPAIRED.		Harikrishnan. R. - Computer Department	01/06/2023
Dept Name : COVID Ward - Work Shop Comp. Dt. : 04/06/2022 Status : Completed								
304	22060161	ENT WARD-407	NEED REPAIRING WORK FOR DEMO ROOM DOOR	Pachaimuthusamy. D.	Door and door frame serviced.		Jayalakshmi. J. - ENT & Ophthal Ward	10/06/2022
Dept Name : Director Office - Work Shop Comp. Dt. : 26/05/2022 Status : Completed								
305	22050981	MEDICAL COLLEGE I FLOOR	NEED REPAIRING WORK FOR RESTROOM DOOR LOCK - LOCK DAMAGE	Ekambaram. K.	Door repaired.		Maithily. M. - Director Office	10/06/2022
Comp. Dt. : 30/05/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
306	22051069	LECTURE HALL V	NEED CARPENTER WORK	Ekambaram. K.	work completed		Prasanna.B. - Director Office	18/06/2022
	Comp. Dt. : 18/07/2022							
	Status : Completed							
307	22070637	Electrical Maintanance College	NEED MATION WORK	Murugavel	Holes packing work completed		Prasanna.B. - Director Office	01/08/2022
	Comp. Dt. : 25/07/2022							
	Status : Completed							
308	22070931	A.P Quateres	NEED TO REFIX WINDOW GLASS & VENTILATION GLASS & WALL PLASTERING WORK FOR QUARTERS NO 53	Ekambaram. K.	Window glass and ventilation glass refixed, problem solved		Mani. A. - Director Office	05/08/2022
	Comp. Dt. : 30/07/2022							
	Status : Completed							
309	22071104	LECTURE HALL V	NEED CARPENTER WORK	Pachaimuthusamy. D.	Workl completed.		Prasanna.B. - Director Office	24/09/2022
	Comp. Dt. : 07/09/2022							
	Status : Completed							
310	22090256	Electrical Maintanance College	NEED MATION WORK FOR FILLING HOLE	Murugavel	Holes packing work completed.		Prasanna.B. - Director Office	24/09/2022
	Comp. Dt. : 05/10/2022							
	Status : Completed							
311	22100071	MEDICAL COLLEGE I FLOOR	NEED TO FIX NEW SMALL WHITE BOARD FOR LECTURE HALL 1 & 2	Ekambaram. K.	Wrong complaint		Prasanna.B. - Director Office	20/10/2022
	Comp. Dt. : 18/10/2022							
	Status : Completed							
312	22100614	A.P Quateres	IN ROOM NO. 50 BEDROOM AND RESTROOM DOOR PROBLEM	Ekambaram. K.	Window mesh fixed.		Mani. A. - Director Office	29/10/2022
	Comp. Dt. : 26/10/2022							
	Status : Completed							
313	22100824	professor quarters	HALL FLOOR TILES PACKING WORK--NEAR ROOM NO-9	Murugavel	Civil execution complaint.		Mani. A. - Director Office	03/11/2022
	Comp. Dt. : 28/11/2022							
	Status : Completed							
314	22111181	Electrical Maintanance College	SOME MASON WORK NEED TO DO	Murugavel	Mason work completed		Prasanna.B. - Director Office	19/12/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 01/02/2023								
Status : Completed								
315	23020022	Electrical Maintanance College	NEED REPAIRING WORK FOR DOOR HANDLE FOR ELECTRICAL ROOM	Ekambaram. K.	New handle changed, problem solved		Prasanna.B. - Director Office	11/02/2023
316	23020027	A.P Quateres	NEED REPAIRING WORK FOR WINDOW LOCK - QUARTERS NO 41	Ekambaram. K.	Window lock repaired and serviced, problem solved		Mani. A. - Director Office	11/02/2023
Comp. Dt. : 28/02/2023								
Status : Completed								
317	23021042	Lecture Hall 3	SOME CARPENTER WORK	Ekambaram. K.	Carpenter work completed		Prasanna.B. - Director Office	04/03/2023
Comp. Dt. : 24/03/2023								
Status : Completed								
318	23031021	ASSOCIATIVE PROFESSOR QUARTERS	NEED TO FIX RESTROOM VENTILATOR MOSQUITO NET FIXING WORK - QUARTERS NO 9	Ekambaram. K.,Veerappan. D.,Sundaramoorthy. G.	WORK COMPLETED		Mani. A. - Director Office	01/04/2023
319	23031022	A.P Quateres	NEED TILES PACKING WORK FOR RESTROOM FLOOR - QUARTERS NO 10	Parivallal. P.	TILES FIXED.		Mani. A. - Director Office	01/04/2023
Comp. Dt. : 06/04/2023								
Status : Completed								
320	23040198	A.P Quateres	NEED NET FIXING WORK FOR QUARTERS NO 10 & 28	Ekambaram. K.	Net fixed, work completed		Mani. A. - Director Office	19/04/2023
321	23040199	professor quarters	NEED REPAIRING WORK FOR KITCHEN DOOR - DAMAGE QUARTERS NO 4	Ekambaram. K.	Kitchen door repaired and serviced, problem solved		Mani. A. - Director Office	19/04/2023
Comp. Dt. : 22/05/2023								
Status : Completed								
322	23050864	MEDICAL COLLEGE I FLOOR	NEED WORKSHOP TECHNICIAN HELP FOR I FLOOR COOLER BASE REMOVING WORK	Ekambaram. K.	COOLER BOTTOM REMOVED AND REFIXED		Prasanna.B. - Director Office	01/06/2023
Comp. Dt. : 30/05/2023								
Status : Completed								
323	23051186	Lecture Hall 3	NEED CARPENTER - WORK	Ekambaram. K.	False ceiling cutting		Prasanna.B. - Director Office	20/06/2023
Comp. Dt. : 08/06/2023								
Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
324	23060304	Director Office	NEED REPAIRING WORK FOR MAIN ENTRANCE DOOR - SOUND PROBLEM	Ekambaram. K.	door repaired.		Vijayalakshmi. G. D. - Director Office	20/06/2023
Dept Name : FORENSIC MEDICINE - Work Shop Comp. Dt. : 09/05/2022 Status : Completed								
325	22050285	FORENSIC MEDICINE (3RD FLOOR) IN COLLEGE	TILES BROKEN NEED TOUCHUP WORK	Murugavel	Tiles refixed, JK white cement pointing work completed		Mathavi. B. - FORENSIC MEDICINE	18/05/2022
Comp. Dt. : 23/06/2022 Status : Completed								
326	22060830	FORENSIC MEDICINE (3RD FLOOR) IN COLLEGE	NEED REPAIRING WORK FOR CLASS ROOM WINDOW DOORS - STUCK	Pachaimuthusamy. D.	Window door serviced, problem solved		Mathavi. B. - FORENSIC MEDICINE	01/07/2022
Comp. Dt. : 27/06/2022 Status : Completed								
327	22060943	FORENSIC MEDICINE (3RD FLOOR) IN COLLEGE	NEED TO REFIX NAME BOARDS	Pachaimuthusamy. D.	Board fixed		Mathavi. B. - FORENSIC MEDICINE	05/07/2022
Comp. Dt. : 19/08/2022 Status : Completed								
328	22080626	FORENSIC MEDICINE (3RD FLOOR) IN COLLEGE	MASON WORK - FLOOR TILES WORK	Murugavel	Tiles refixed, JK white cement pointing work completed		Mathavi. B. - FORENSIC MEDICINE	25/08/2022
Comp. Dt. : 11/11/2022 Status : Completed								
329	22110453	FORENSIC MEDICINE (3RD FLOOR) IN COLLEGE	IN LADIES TOILET-FLOOR TILES 1 NO.BROKEN	Murugavel	Tiles refixed, JK white cement pointing work completed		Mathavi. B. - FORENSIC MEDICINE	18/11/2022
Comp. Dt. : 22/11/2022 Status : Completed								
330	22110913	FORENSIC MEDICINE (3RD FLOOR) IN COLLEGE	NEED REPAIRING WORK FOR WINDOW DOOR - STUCK AT CLASS ROOM	Ekambaram. K.	Window door repaired and serviced, problem solved		Mathavi. B. - FORENSIC MEDICINE	01/12/2022
Comp. Dt. : 14/12/2022 Status : Completed								
331	22120647	FORENSIC MEDICINE (3RD FLOOR) IN COLLEGE	NEED REPAIRING WORK FOR STEEL BERO LOCK - NOT WORKING -	Ekambaram. K.	Lock repaired and serviced, problem solved		Mathavi. B. - FORENSIC MEDICINE	23/12/2022
Comp. Dt. : 30/03/2023 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
332	23031296	FORENSIC MEDICINE	TILES PACKING WORK	Parivallal. P.	Tiles refixed, work completed		Mathavi. B. - FORENSIC MEDICINE	06/04/2023
333	23031302	FORENSIC MEDICINE (3RD FLOOR) IN COLLEGE	NEED TO REPLACE & REFIT " CLASS ROOM BOARD - OLD CLASS ROOM TO NEW CLASS ROOM	Ekambaram. K.	Class room board fixed, work completed		Mathavi. B. - FORENSIC MEDICINE	06/04/2023
Comp. Dt. : 05/04/2023 Status : Completed								
334	23040171	FORENSIC MEDICINE (3RD FLOOR) IN COLLEGE	TILES BROKEN - NEED TOUCHUP WORK AT RESTROOM	Parivallal. P.	TILES REFIXED		Mathavi. B. - FORENSIC MEDICINE	05/05/2023
Comp. Dt. : 20/04/2023 Status : Completed								
335	23040647	FORENSIC MEDICINE (3RD FLOOR) IN COLLEGE	NEED ADJUSTMENT WORK FOR "FIXED CLASS ROOM BOARDS" AT NEW DEMO ROOM [3 NOS]	Ekambaram. K.	WORK COMPLETED		Mathavi. B. - FORENSIC MEDICINE	02/05/2023
336	23040660	FORENSIC MEDICINE (3RD FLOOR) IN COLLEGE	NEED TO REFIX ROD FOR STUDENT SITTING SINGLE CHAIR 2NOS	Sarathy. A.	WORK COMPLETED		Mathavi. B. - FORENSIC MEDICINE	02/05/2023
Dept Name : Housekeeping - Work Shop Comp. Dt. : 18/08/2022 Status : Completed								
337	22080604	MEDICAL COLLEGE	DHANVANDRI STATUE GATE BROKEN	Ekambaram. K.	Gate refixed, problem solved		Elangchezhiyan. R. - Housekeeping	25/08/2022
Dept Name : Library - Work Shop Comp. Dt. : 26/05/2022 Status : Completed								
338	22050988	medical college library 2nd floor	NEED REPAIRING WORK FOR MAIN DOOR - NOT CLOSING PROPER	Pachaimuthusamy. D.	Door repaired.		Elangovan.N. - Library	10/06/2022
Comp. Dt. : 28/06/2022 Status : Completed								
339	22061007	medical college library 2nd floor	NEED REPAIRING WORK FOR MAIN DOOR - NOT CLOSING	Pachaimuthusamy. D.	Door floor spring fixed		Lakshmi Gandhan.S. - Library	05/07/2022
Comp. Dt. : 12/10/2022 Status : Completed								
340	22100312	MEDICAL COLLEGE LIBRARY	TILES PACKING WORK IN 1ST FLOOR LIBRARY	Murugavel	Tiles refixed, JK White cement pointing work completed		Elangovan.N. - library	15/11/2022
Comp. Dt. : 02/12/2022								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
341	22120080	medical college library 2nd floor	NEED REPAIRING WORK FOR RESTROOM DOOR	Ekambaram. K.	New door fixed.		Elangovan.N. - Library	10/12/2022
Comp. Dt. : 03/01/2023								
Status : Completed								
342	23010117	MEDICAL COLLEGE LIBRARY	IN GROUND FLOOR-DOOR CLOSER CHANGED RECENTLY BUT NOT WORKING PROPERLY	Ekambaram. K.	Door closer repaired and serviced, refixed in properly		Elangovan.N. - Library	12/01/2023
Comp. Dt. : 10/01/2023								
Status : Completed								
343	23010431	MEDICAL COLLEGE LIBRARY	IN GROUND FLOOR-DOOR HANDLE NEED TO BE RETIGHT AND KUSHON CHAIR REPAIR WORK	Ekambaram. K.	Door handle repaired and refixed, work completed		Elangovan.N. - Library	23/01/2023
Comp. Dt. : 25/01/2023								
Status : Completed								
344	23010937	MEDICAL COLLEGE LIBRARY	NEED REPAIRING WORK FOR GROUND FLOOR LIBRARY MAIN DOOR -DOOR STOPER PROBLEM	Ekambaram. K.	Door closer adjusted, problem solved		Elangovan.N. - Library	30/01/2023
Comp. Dt. : 06/02/2023								
Status : Completed								
345	23020206	MEDICAL COLLEGE LIBRARY	NEED REPASTE FOR WINDOW SCREEN CLOTH	Ekambaram. K.	Window screen fixed		Elangovan.N. - Library	16/02/2023
Comp. Dt. : 12/05/2023								
Status : Completed								
346	23050497	MEDICAL COLLEGE LIBRARY	NEED TO REFIX AC DOOR PATLOCK FOR GROUND , I & II FLOOR	Ekambaram. K.	Padlock fixed.		Elangovan.N. - Library	05/08/2023
Dept Name : Medical Records - Work Shop								
Comp. Dt. : 13/12/2022								
Status : Completed								
347	22120595	Medical Records	NEED TO REFIX DOOR HANDLE + PATLOCK 10 NOS & OPEN RACK DOOR FIXING - NEED URGENT SERVICE	Ekambaram. K.	New Lock 4Nos changed, problem solved		Martin Prabu.V. - Medical Records	23/12/2022
Dept Name : MICROBIOLOGY - Work Shop								
Comp. Dt. : 23/05/2022								
Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
348	22050840	MICROBIOLOGY IN COLLEGE	NEED TO CLOSE AC & WINDOW GAPS WITH WOODEN SHEETS	Ekambaram. K.	Window glass and plywood sheet fixed, problem solved		Gopal. R. - MICROBIOLOGY	27/05/2022
Comp. Dt. :		24/05/2022						
Status :		Completed						
349	22050918	MICROBIOLOGY IN COLLEGE	NEED WELDING WORK	Sarathy. A.	Welding completed.		Praveenkumar. S. - MICROBIOLOGY	10/06/2022
Comp. Dt. :		28/05/2022						
Status :		Completed						
350	22051059	MICROBIOLOGY IN COLLEGE	NEED REPAIRING WORK FOR MAIN DOOR	Pachaimuthusamy. D.	Door repaired.		Mathu. M. - MICROBIOLOGY	10/06/2022
351	22051063	MICROBIOLOGY IN COLLEGE	NEED PAINTING WORK	Manimaran. A.	Door Painted.		Anandh. P. - MICROBIOLOGY	10/06/2022
Comp. Dt. :		30/05/2022						
Status :		Completed						
352	22051101	MICROBIOLOGY IN COLLEGE	NEED CARPENTER WORK FOR CLOSING DOOR HOLE	Ekambaram. K.	Hole closed.		Gopal. R. - MICROBIOLOGY	10/06/2022
Comp. Dt. :		31/05/2022						
Status :		Completed						
353	22051113	MICROBIOLOGY IN COLLEGE	NEED REPAIRING WORK FOR MAIN GLASS DOOR - SOUND, CLOSING & BUSH PROBLEM	Pachaimuthusamy. D.	Door serviced.		Anandh. P. - MICROBIOLOGY	10/06/2022
Comp. Dt. :		18/06/2022						
Status :		Completed						
354	22060684	MICROBIOLOGY IN COLLEGE	NEED TO CLOSE HOLES IN THE WALL - RAT PROBELM	Murugavel	Holes packed		Gopal. R. - MICROBIOLOGY	23/06/2022
Comp. Dt. :		21/06/2022						
Status :		Completed						
355	22060760	MICROBIOLOGY IN COLLEGE	NEED PAINTING WORK	Manimaran. A.	Door painting work completed		Mageswari. R. - MICROBIOLOGY	01/07/2022
Comp. Dt. :		15/07/2022						
Status :		Completed						
356	22070607	MICROBIOLOGY IN COLLEGE	NEED TO FIX NAILS FOR FIXING NOTICE BOARD	Ekambaram. K.	Notice board fixed, problem solved		Buvana. C. - MICROBIOLOGY	01/08/2022
Comp. Dt. :		27/07/2022						
Status :		Completed						
357	22071022	MICROBIOLOGY IN COLLEGE	NEED TO REFIX DOOR	Ekambaram. K.	Door refixed in properly, work completed		Buvana. C. - MICROBIOLOGY	05/08/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 22/08/2022								
Status : Completed								
358	22080694	MICROBIOLOGY IN COLLEGE	NEED CARPENDER HELP	Ekambaram. K.	Carpenter work completed		Gopal. R. - MICROBIOLOGY	01/09/2022
Comp. Dt. : 26/08/2022								
Status : Completed								
359	22080905	MICROBIOLOGY IN COLLEGE	NEED CARPENTER HELP	Ekambaram. K.	Work completed.		Gopal. R. - MICROBIOLOGY	09/09/2022
Comp. Dt. : 26/09/2022								
Status : Completed								
360	22091004	MICROBIOLOGY IN COLLEGE	NEED TOUCH UP WORK FOR MARBLE - BROKEN	Murugavel	Civil work, Msg iforward to Civil department		Raffik Moideen. M. - SMV Allied Health Sciences	12/10/2022
Comp. Dt. : 18/10/2022								
Status : Completed								
361	22100593	MICROBIOLOGY IN COLLEGE	NEED TO REFIX BERO HANDLE - HANDLE BROKEN	Ekambaram. K.	3 nos. new handle fixed.		Gopal. R. - MICROBIOLOGY	29/10/2022
Comp. Dt. : 23/12/2022								
Status : Completed								
362	22121067	MICROBIOLOGY IN COLLEGE	LOCK PROBLEM	Ekambaram. K.	Lock repaired and serviced, problem solved		Mageswari. R. - MICROBIOLOGY	02/01/2023
Comp. Dt. : 04/01/2023								
Status : Completed								
363	23010178	MICROBIOLOGY IN COLLEGE	IN PCR ROOM-DOOR PROBLEM	Ekambaram. K.	Door repaired and serviced, problem solved		Mageswari. R. - MICROBIOLOGY	12/01/2023
Comp. Dt. : 09/01/2023								
Status : Completed								
364	23010339	MICROBIOLOGY IN COLLEGE	IN TUTOR ROOM-BERO HANDLE NEED TO BE REPAIR	Ekambaram. K.	Bero handle refixed in properly, problem solved		Mageswari. R. - MICROBIOLOGY	23/01/2023
Comp. Dt. : 13/02/2023								
Status : Completed								
365	23020489	MICROBIOLOGY IN COLLEGE	NEED TO REFIX SOAP STAND SCREW FOR RESTROOM	Veerappan. D.	Complaint forward to Plumbing dept		Mageswari. R. - MICROBIOLOGY	17/02/2023
Comp. Dt. : 13/03/2023								
Status : Completed								
366	23030489	MICROBIOLOGY IN COLLEGE	NEED REPAIRING WORK FOR DOOR - BROKEN	Ekambaram. K.	DOOR REPAIRED.		Praveenkumar. S. - MICROBIOLOGY	23/03/2023

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHAL KUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 15/03/2023 Status : Completed								
367	23030583	MICROBIOLOGY IN COLLEGE	NEED REPAIRING WORK FOR DOOR - SPRING & CLOSING PROBLEM	Ekambaram. K.	Door spring fixed		Mageswari. R. - MICROBIOLOGY	23/03/2023
Comp. Dt. : 20/03/2023 Status : Completed								
368	23030769	MICROBIOLOGY IN COLLEGE	NEED REPAIRING WORK FOR DOOR LOCK - DAMAGE -NOT WORKING AT PCR LAB	Ekambaram. K.	Door lock refixed, problem solved		Mageswari. R. - MICROBIOLOGY	31/03/2023
Comp. Dt. : 19/04/2023 Status : Completed								
369	23040572	MICROBIOLOGY IN COLLEGE	NEED TO REFIX DOOR STOPER FOR CULTURE LAB - [5 DOORS]	Ekambaram. K.	DOOR STOPPER FIXED		Mageswari. R. - MICROBIOLOGY	17/05/2023
Comp. Dt. : 22/05/2023 Status : Completed								
370	23050893	MICROBIOLOGY	NEED CARPENDER HELP AT BOTH HOSPITAL & COLLEGE SIDE	Ekambaram. K.	WORK COMPLETED		Gopal. R. - MICROBIOLOGY	01/06/2023
Dept Name : MS Office - Work Shop Comp. Dt. : 27/09/2022 Status : Completed								
371	22091079	NEW SKILL LAB - MEDICAL COLLEGE	NEED TO REFIX WALL CLOCK & NOTICE BOARD	Ekambaram. K.	Wall clock and notice board fixed, problem solved		Elumalai. M. - MS Office	08/10/2022
Comp. Dt. : 07/11/2022 Status : Completed								
372	22110231	SKILL LAB - MEDICAL COLLEGE	ENTRANCE DOOR HANDLE BROKEN IN 3RD FLOOR SKILL LAB	Ekambaram. K.	Door handle changed, problem solved		Prabhakaran. S. - Medical Records	18/11/2022
Comp. Dt. : 28/04/2023 Status : Completed								
373	23040952	SKILL LAB - MEDICAL COLLEGE	NEED TO REFIX DOOR STOPPER	Ekambaram. K.	11Nos of Door stopper fixed, work completed		Elumalai. M. - MS Office	08/05/2023
Comp. Dt. : 24/05/2023 Status : Completed								
374	23050970	SKILL LAB - MEDICAL COLLEGE	NEED REPAIRING WORK FOR DOOR - BROKE	Ekambaram. K.	door fixed		Elumalai. M. - MS Office	03/06/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Dept Name : PATHOLOGY - Work Shop Comp. Dt. : 11/07/2022 Status : Completed								
375	22070434	PATHOLOGY IN COLLEGE	NEED REPAIRING WORK FOR DOOR	Ekambaram. K.,Pachaimuthusamy . D.,Sundaramoorthy. G.	Door repaired and serviced, New Door stopper fixed, work completed		Sathia Rajesh. C. - PATHOLOGY	20/07/2022
Comp. Dt. : 14/09/2022 Status : Completed								
376	22090555	PATHOLOGY IN COLLEGE	NEED PAINTING WORK FOR LAB	Manimaran. A.	Lab cleaned and painting work completed		Thavamani. K. - PATHOLOGY	28/09/2022
Comp. Dt. : 21/09/2022 Status : Completed								
377	22090827	PATHOLOGY IN COLLEGE	NEED TO FIX NOTICE BOARD	Ekambaram. K.	5Nos of bord fixed		Sathia Rajesh. C. - PATHOLOGY	29/09/2022
Comp. Dt. : 02/11/2022 Status : Completed								
378	22110007	PATHOLOGY IN COLLEGE	FLOOR TILES BROKEN	Murugavel	20Nos of Tiles refixed, JK White cement pointing work completed		Sathia Rajesh. C. - PATHOLOGY	16/11/2022
Comp. Dt. : 03/11/2022 Status : Completed								
379	22110101	PATHOLOGY IN COLLEGE	FLOOR TILES PACKAGING WORK NEED TO DO	Murugavel	20Nos of Tiles refixed, JK White cement pointing work completed		Sathia Rajesh. C. - PATHOLOGY	16/11/2022
Comp. Dt. : 16/11/2022 Status : Completed								
380	22110668	PATHOLOGY IN COLLEGE	FLOOR TILES BROKEN	Murugavel	36 nos tiles refixed and JK white applied.		Sathia Rajesh. C. - PATHOLOGY	21/11/2022
Comp. Dt. : 18/01/2023 Status : Completed								
381	23010604	PATHOLOGY IN COLLEGE	TILES BROKEN & AIR CRACK - NEED TOUCH UP WORK AT HOD ROOM	Murugavel	18Nos of Tiles refixed, JK White cement pointing work completed		Thavamani. K. - PATHOLOGY	30/01/2023
Comp. Dt. : 25/01/2023 Status : Completed								
382	23010912	PATHOLOGY IN COLLEGE	NEED TO REFIX NOTICE BOARD	Ekambaram. K.	Notice board fixed, problem solved		Sathia Rajesh. C. - PATHOLOGY	30/01/2023
Comp. Dt. : 17/02/2023								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
383	23020672	PATHOLOGY IN COLLEGE	TILES BROKEN - NEED TOUCHUP WORK	Murugavel	8Nos of Tiles refixed, JK White cement pointing work completed		Thavamani. K. - PATHOLOGY	23/02/2023
Comp. Dt. : 29/03/2023								
Status : Completed								
384	23031262	PATHOLOGY IN COLLEGE	TILES BROKEN - NEED TOUCHUP WORK	Parivallal. P.	10Nos of tiles refixed, JK white cement pointing work completed		Sathia Rajesh. C. - PATHOLOGY	06/04/2023
Comp. Dt. : 27/04/2023								
Status : Completed								
385	23040935	PATHOLOGY IN COLLEGE	NEED TO PUT A HOLE FOR WOODEN TABLE	Ekambaram. K.	Hole drilled, work completed		Sathia Rajesh. C. - PATHOLOGY	08/05/2023
Comp. Dt. : 09/05/2023								
Status : Completed								
386	23050367	PATHOLOGY IN COLLEGE	TILES BROKEN - NEED TOUCH UP WORK	Parivallal. P.	TILES REFIXED AND JK WHITE APPLIED		Sathia Rajesh. C. - PATHOLOGY	18/05/2023
Dept Name : PHARMACOLOGY - Work Shop								
Comp. Dt. : 13/05/2022								
Status : Completed								
387	22050485	PHARMACOLOGY	CHEMICAL RACK NEED TO DO PAINTING WORK-3 NO'S	Manimaran. A.	3Nos of chemical rack cleaned and painting work completed		Devanathan. S. - PHARMACOLOGY	27/05/2022
Comp. Dt. : 07/09/2022								
Status : Completed								
388	22090294	PHARMACOLOGY	NEED REPAIRING WORK FOR FACULTY ROOM DOOR LOCK	Ekambaram. K.	1no. Door flock fixed.		Panchali. P. - PHARMACOLOGY	24/09/2022
Comp. Dt. : 09/09/2022								
Status : Completed								
389	22090370	PHARMACOLOGY	NEED TO REFIX DOOR STOPPER	Ekambaram. K.	New Door stopper fixed, problem solved		Panchali. P. - PHARMACOLOGY	28/09/2022
Comp. Dt. : 20/09/2022								
Status : Completed								
390	22090758	Animal House	NEED TO FIX PHOTO'S 10 NOS AT ANIMAL HOUSE	Ekambaram. K.,Venkatesan. R.,Sundaramoorthy. G.	10Nos of board fixed, work completed		Panchali. P. - PHARMACOLOGY	29/09/2022
Comp. Dt. : 10/10/2022								
Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
391	22100228	PHARMACOLOGY	KEY MISSING - NEED TO BROKE BERO LOCK	Ekambaram. K.	Lock brokened, new lock changed, problem solved		Devanathan. S. - PHARMACOLOGY	12/10/2022
Comp. Dt. : 13/10/2022 Status : Completed								
392	22100385	PHARMACOLOGY	NEED TO REFIX BERO LOCK	Ekambaram. K.	New pad lock fixed, problem solved		Panchali. P. - PHARMACOLOGY	20/10/2022
Comp. Dt. : 07/11/2022 Status : Completed								
393	22110240	PHARMACOLOGY	IN LAB-SCREEN FIXING WORK NEED TO DO	Venkatesan. R.	Screen fixed, problem solved		Devanathan. S. - PHARMACOLOGY	18/11/2022
Comp. Dt. : 05/12/2022 Status : Completed								
394	22120202	PHARMACOLOGY	LCD PROJECTOR FIXING WALL-PAINTING WORK NEED TO DO	Manimaran. A.	Work completed.		Panchali. P. - PHARMACOLOGY	10/12/2022
Comp. Dt. : 07/12/2022 Status : Completed								
395	22120308	PHARMACOLOGY	IN DEMO ROOM-SCREEN CLAMP NEED TO BE FIX	Ekambaram. K.	Screen clamp fixed, problem solved		Devanathan. S. - PHARMACOLOGY	19/12/2022
Comp. Dt. : 26/04/2023 Status : Completed								
396	23040853	PHARMACOLOGY	DRAW LOCK STUCK - NEED REPAIRING WORK	Ekambaram. K.	Draw lock fixed, work completed		Kalidoss. T. - PHARMACOLOGY	08/05/2023
Dept Name : PHYSIOLOGY - Work Shop Comp. Dt. : 02/05/2022 Status : Completed								
397	22050031	PHYSIOLOGY-- -COLLEGE	NEED REPAIRING WORK FOR TROLLEY WHEEL [4NOS] NOT WORKING	Sarathy. A.	6m wheel 4Nos replaced, problem solved		Balasankar. P. - PHYSIOLOGY	12/05/2022
Comp. Dt. : 06/05/2022 Status : Completed								
398	22050206	PHYSIOLOGY-- -COLLEGE	NEED REPAIRING WORK FOR TROLLEY WHEEL	Sarathy. A.	Trolley wheel changed, problem solved		Balasankar. P. - PHYSIOLOGY	12/05/2022
Comp. Dt. : 19/05/2022 Status : Completed								
399	22050693	PHYSIOLOGY-- -COLLEGE	NEED TO FIX NAIL 2 NO FOR FIXING HEIGHT MACHINE	Ekambaram. K.	Nail fixed, problem solved		Shanthini. M. - BIOCHEMISTRY	27/05/2022
Comp. Dt. : 06/06/2022								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
400	22060186	PHYSIOLOGY-- -COLLEGE	NEED REPAIRING WORK FOR TROLLEY WHEEL - WHEEL NOT WORKING	Sarathy. A.	New 4" wheel fixed		Balasankar. P. - PHYSIOLOGY	10/06/2022
401	22060187	Director Office	NEED REPAIRING WORK FOR TROLLEY WHEEL - WHEEL NOT WORKING	Sarathy. A.	Wheel replaced and leg welded.		Balasankar. P. - PHYSIOLOGY	10/06/2022
Comp. Dt. : 13/06/2022								
Status : Completed								
402	22060483	PHYSIOLOGY-- -COLLEGE	NEED TO FIX NAILS [2NOS] FOR PHYSIOLOGY MAMONIAL LAB	Ekambaram. K.	Nail fixed.		Shanthini. M. - BIOCHEMISTRY	21/06/2022
Comp. Dt. : 14/06/2022								
Status : Completed								
403	22060508	PHYSIOLOGY-- -COLLEGE	NEED CEMENT WORK FOR CLOSING HOLE UNDER STEPS	Murugavel	Holes cement packing work done		Jayanthi.A. - PHYSIOLOGY	01/07/2022
Comp. Dt. : 22/06/2022								
Status : Completed								
404	22060796	PHYSIOLOGY-- -COLLEGE	NEED TO FIX NAILS FOR FIXING BOARDS 3NO	Ekambaram. K.	Board fixed with nails, work completed		Shanthini. M. - BIOCHEMISTRY	01/07/2022
Comp. Dt. : 24/06/2022								
Status : Completed								
405	22060898	PHYSIOLOGY-- -COLLEGE	NEED TO FIX BOARDS	Ekambaram. K.	Board fixed, work completed		Balasankar. P. - PHYSIOLOGY	01/07/2022
Comp. Dt. : 07/07/2022								
Status : Completed								
406	22070263	PHYSIOLOGY-- -COLLEGE	NEED TO REFIX NAIL FOR COMPUTER TABLE	Ekambaram. K.	Computer table nail fixed		Shanthini. M. - BIOCHEMISTRY	16/07/2022
Comp. Dt. : 03/08/2022								
Status : Completed								
407	22080144	PHYSIOLOGY-- -COLLEGE	NEED REPAIRING WORK FOR KEYBOARD DRAW - STUCK	Sundaramoorthy. G.	Keyboard draw repaired and serviced, problem solved		Jayanthi.A. - PHYSIOLOGY	08/08/2022
Comp. Dt. : 18/08/2022								
Status : Completed								
408	22080579	PHYSIOLOGY-- -COLLEGE	IN CLASS ROOM-BOARD NEED TO BE REFIX	Ekambaram. K.	Board fixed, work completed		Balasankar. P. - PHYSIOLOGY	25/08/2022
Comp. Dt. : 23/08/2022								
Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
409	22080776	PHYSIOLOGY-- -COLLEGE	DUE TO DAMAGE AND BROKED NET, NEED TO REMOVE NET AT UNDER THE STUDENT SITING CHAIRS [90 NOS] TO	Parthiban.K.	Work completed.		Balasankar. P. - PHYSIOLOGY	24/09/2022
Comp. Dt. : 27/09/2022 Status : Completed								
410	22091080	PHYSIOLOGY-- -COLLEGE	NEED TO CHANGE ROLLING CHAIR COVERS [4 NOS] - DUST & DAMAGE	Sarathy. A.	Wrong complaint		Gowri.V. - PHYSIOLOGY	08/10/2022
Comp. Dt. : 08/11/2022 Status : Completed								
411	22110270	PHYSIOLOGY-- -COLLEGE	WASH BASIN BROKEN	Ganesan. A.	Plumbing dept complaint, inform to plumbing dept		Gowri.V. - PHYSIOLOGY	18/11/2022
Comp. Dt. : 05/01/2023 Status : Completed								
412	23010222	PHYSIOLOGY-- -COLLEGE	MEDICINE TROLLY WHEEL NEED TO BE CHANGE	Sarathy. A.	Wheel repaired.		Balasankar. P. - PHYSIOLOGY	11/01/2023
Comp. Dt. : 19/01/2023 Status : Completed								
413	23010673	PHYSIOLOGY-- -COLLEGE	NEED TO REFIX SCREW FOR STUDENT SITTING STEEL CHAIR [10 NOS]	Ekambaram. K.	Chair screw refixed		Balasankar. P. - PHYSIOLOGY	16/02/2023
Comp. Dt. : 09/02/2023 Status : Completed								
414	23020343	PHYSIOLOGY-- -COLLEGE	NEED TO FIX BERO LOCK	Ekambaram. K.	New lock fixed		Balasankar. P. - PHYSIOLOGY	16/02/2023
Comp. Dt. : 14/03/2023 Status : Completed								
415	23030528	PHYSIOLOGY-- -COLLEGE	NEED WHITE WASH WORK FOR WASH BASIN NEAR WALL - DAMAGE	Manimaran. A.	WORK COMPLETED		Deepika. V. - PHYSIOLOGY	23/03/2023
Comp. Dt. : 29/03/2023 Status : Completed								
416	23031237	PHYSIOLOGY-- -COLLEGE	NEED REPAIRING WORK FOR "S" TYPE CHAIR [NET]	Ekambaram. K.,Sundaramoorthy. G.,Sarathy. A.	Wrong complaint		Shanthini. M. - BIOCHEMISTRY	06/04/2023
Comp. Dt. : 03/04/2023 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
417	23040084	PHYSIOLOGY-- -COLLEGE	NEED PAINTING WORK FOR WASH BASIN [PINK COLOUR]	Manimaran. A.	Painting work completed		Balasankar. P. - PHYSIOLOGY	17/04/2023
Comp. Dt. : 20/04/2023 Status : Completed								
418	23040621	PHYSIOLOGY-- -COLLEGE	NEED TO REPASTE PLYWOOD SHEET FOR DAMAGED TABLE [2 NOS]	Ekambaram. K.	MICA FIXED.		Gowri.V. - PHYSIOLOGY	02/05/2023
Comp. Dt. : 02/05/2023 Status : Completed								
419	23050045	PHYSIOLOGY-- -COLLEGE	NEED TO FIX ROD FOR FIXING SCREEN FOR MADAM ROOM	Ekambaram. K.	SCREEN ROD FIXED.		Shanthini. M. - BIOCHEMISTRY	13/05/2023
Comp. Dt. : 04/05/2023 Status : Completed								
420	23050129	PHYSIOLOGY-- -COLLEGE	NEED WELDING WORK FOR TROLLEY	Sarathy. A.	TROLLY REPAIRED.		Balasankar. P. - PHYSIOLOGY	13/05/2023
Comp. Dt. : 12/05/2023 Status : Completed								
421	23050504	PHYSIOLOGY-- -COLLEGE	NEED REPAIRING WORK FOR DOOR LOCK - STUCK	Ekambaram. K.	LOCK FIXED		Balasankar. P. - PHYSIOLOGY	18/05/2023
Comp. Dt. : 07/06/2023 Status : Completed								
422	23060248	PHYSIOLOGY-- -COLLEGE	NEED TO FIX SCREEN ROD - NEED URGENT	Ekambaram. K.	screen rod fixed		Deepika. V. - PHYSIOLOGY	20/06/2023
Comp. Dt. : 16/06/2023 Status : Completed								
423	23060591	PHYSIOLOGY-- -COLLEGE	5 STUDENTS TABLE BOLD NUT TIGHTING WORK	Ekambaram. K.	Table bold fixed.		Balasankar. P. - PHYSIOLOGY	27/06/2023
Dept Name : Security - SIS - Work Shop Comp. Dt. : 09/06/2022 Status : Completed								
424	22060350	MEDICAL COLLEGE GROUND FLOOR	NEED TO FIX PATLOCK FOR DUCT DOOR	Pachaimuthusamy. D.	Duct door padlock fixed, problem solved		Prabakaran. P. - Security - SIS	13/06/2022
Comp. Dt. : 30/08/2022 Status : Completed								
425	22081017	MEDICAL COLLEGE	NEED TO REFIX SHEET AT ENTRANCE [DAMAGE & BROKEN] RAIN WATER FLOW AT ENTRANCE	Ekambaram. K.	Civil execution complaints.		Javazhagan. A. - Security - SIS	09/09/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 01/12/2022 Status : Completed								
426	22120001	MEDICAL COLLEGE I FLOOR	NEED TO REPAIRING & REFIX DOOR LOCK FOR FEMALE DINNING HALL ROOM DOOR	Ekambaram. K.	Door refixed.		Prabakaran. P. - Security - SIS	10/12/2022
Comp. Dt. : 09/01/2023 Status : Completed								
427	23010332	MEDICAL COLLEGE III FLOOR	LADIES REST ROOM-DOOR NOT CLOSING PROPERLY	Ekambaram. K.	Door repaired and serviced, problem solved		Prabakaran. P. - Security - SIS	23/01/2023
Comp. Dt. : 03/03/2023 Status : Completed								
428	23030123	MEDICAL COLLEGE I FLOOR	TILES AIR CRACK [2NOS] NEED TOUCH UP WORK FOR I FLOOR FEMALE RESTROOM	Parivallal. P.	Tiles refixed, JK White cement pointing work completed		Elavazhagan. A. - Security - SIS	09/03/2023
Comp. Dt. : 16/06/2023 Status : Completed								
429	23060576	College	(2002)NEED TO FIX ONE NEW LOCK IN SECURITY TABLE	Ekambaram. K.	Lock fixed.		Prabakaran. P. - Security - SIS	05/08/2023
Dept Name : Skill Lab - Work Shop Comp. Dt. : 22/04/2023 Status : Completed								
430	23040702	SIMULATION LAB - MEDICAL COLLEGE III FLOOR	NEED TO REFIX DOOR CLOSER	Ekambaram. K.	DOOR CLOSER FIXED.		Jayasri. S. - Skill Lab	02/05/2023
Dept Name : SMV Allied Health Sciences - Work Shop Comp. Dt. : 06/01/2023 Status : Completed								
431	23010263	MICROBIOLOGY IN COLLEGE	(2085) TUTOR ROOM BERO LOCK PROBLEM	Ekambaram. K.	Lock repaired		Raffik Moideen. M. - SMV Allied Health Sciences	11/01/2023
Dept Name : Ward - Work Shop Comp. Dt. : 23/06/2022 Status : Completed								
432	22060846	PHYSIOLOGY--COLLEGE	KEY MISSING - NEED TO REFIX BERO LOCK	Ekambaram. K.	Bero lock opened, problem solved		Gowri.V. - PHYSIOLOGY	01/07/2022
Comp. Dt. : 08/07/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
433	22070345	PHYSIOLOGY-- -COLLEGE	NEED TO RE PASTE MICA SHEET FOR TABLE [HOD SIR ROOM]	Pachaimuthusamy. D.	Mica sheet fixed, work completed		Gowri.V. - PHYSIOLOGY	16/07/2022
Work Type : Work Dept Name : FORENSIC MEDICINE - Work Shop Comp. Dt. : 09/08/2022 Status : Completed								
434	22080298	FORENSIC MEDICINE (3RD FLOOR) IN COLLEGE	WINDOW DOOR STUCK AT CLASS ROOM	Ekambaram. K.	Door repaired and serviced, problem solved		Mathavi. B. - FORENSIC MEDICINE	23/08/2022
Dept Name : MICROBIOLOGY - Work Shop Comp. Dt. : 27/02/2023 Status : Completed								
435	23021037	MICROBIOLOGY IN COLLEGE	NEED CARPENTER HELP FOR FIXING BOARD & SCREWS	Parthiban.K.,Ekamba ram. K.,Sundaramoorthy. G.	Board fixed		Gopal. R. - MICROBIOLOGY	04/03/2023
Dept Name : PHYSIOLOGY - Work Shop Comp. Dt. : 05/10/2022 Status : Completed								
436	22100067	PHYSIOLOGY-- -COLLEGE	NEED TO REMOVE IRON NET FOR STUDENTS SETTING IRON CHAIRS [90 NOS]	Sarathy. A.,Ekambaram. K.,Venkatesan. R.	waiting for Director sir approval, still we are not receive the letter		Balasankar. P. - PHYSIOLOGY	15/11/2022
College Name : SMVMCH-HOS Work Type : Complaint Dept Name : Administration - Work Shop Comp. Dt. : 06/05/2022 Status : Completed								
437	22050188	General Stores[Linen]	NEED REPAIRING WORK FOR " S" TYPE CHAIR - DAMAGED BACK REST	Sarathy. A.	Chair repairing work completed		Motheeswarar. R.S. - Administration	12/05/2022
Comp. Dt. : 17/06/2022 Status : Completed								
438	22060648	AO Office	NEED TO CHECK ROLLING CHAIR & CUPBOARD DRAW - STUCK & SOUND PROBLEM	Sarathy. A.	work completed		Elumalai.K.A. - Administration	23/06/2022
Comp. Dt. : 18/06/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
439	22060677	HOSPITAL I FLOOR OPP TO LIFT 1	NEED TOUCHUP WORK FOR PILLER SLAB TILES - BROKEN	Murugavel	work completed		Sathiyamoorthy. D. - Administration	23/06/2022
	Comp. Dt. : 30/08/2022							
	Status : Completed							
440	22081021	AO Office	NEED CEMENT WORK FOR CLOSING FLOOR GAP COMING RAT IN WASHING AREA	Murugavel	Gap arrested		Gomathy. K. - Administration	09/09/2022
	Comp. Dt. : 02/09/2022							
	Status : Completed							
441	22090070	GENERAL STORE	NEED LABOUR FOR INSTRUMENT SHIFTING WORK - (4 NOS)	Ganesan. A.	Work completed.		Motheeswarar. R.S. - Administration	08/09/2022
	Comp. Dt. : 13/09/2022							
	Status : Completed							
442	22090498	AO Office	NEED REPAIRING WORK FOR ENTRANCE DOOR - LOCK PROBLEM	Parthiban.K.	New Door closer fixed, problem solved		Elumalai.K.A. - Administration	12/10/2022
	Comp. Dt. : 14/10/2022							
	Status : Completed							
443	22100439	Pay Pharmacy	NEED TO REFIX ENTRANCE GLASS DOOR LOCK - LOCK PROBLEM	Parthiban.K.	Door & Door lock repaired and serviced, problem solved		Sathiyamoorthy. D. - Administration	21/10/2022
	Comp. Dt. : 26/10/2022							
	Status : Completed							
444	22100834	AO Office	WALL PAINTING WORK NEED TO DO	Manimaran. A.	Wall cleaned and painting work completed		Anbarasan. R. - Administration	15/11/2022
	Comp. Dt. : 20/01/2023							
	Status : Completed							
445	23010712	AO Office	NEED REPAIRING WORK FOR MALE RESTROOM DOOR - DAMAGE & BROKEN	Ekambaram. K.	New door closer changed, problem solved		Santhosh Raja. K. - Administration	30/01/2023
446	23010737	SKILL LAB - MEDICAL COLLEGE	NEED CARPENDER FOR FIXING OXIGEN PIPE LINE	Ekambaram. K.	O2 pipe line fixed, work completed		Prabakaran. B. - Administration	16/02/2023
	Comp. Dt. : 21/01/2023							
	Status : Completed							
447	23010766	AO Office	NEED REPAIRING WORK FOR RESTROOM DOOR - SOUND PROBLEM	Ekambaram. K.	Door repaired and serviced, problem solved		Karthik. K. - Administration	30/01/2023

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 30/01/2023 Status : Completed								
448	23011069	AO Office	NEED REPAIRING WORK FOR DOOR & ALSO SOUND PROBLEM	Ekambaram. K.	Door repaired and serviced, lock changed, problem solved		Elumalai.K.A. - Administration	11/02/2023
Comp. Dt. : 14/02/2023 Status : Completed								
449	23020543	General Stores[Linen]	NEED TO REFIX DOOR SCREEN SPRING	Ekambaram. K.	Spring hook fixed		Arulkumaran. S. - Administration	17/02/2023
Comp. Dt. : 16/03/2023 Status : Completed								
450	23030651	AO Office	NEED REPAIRING WORK FOR DRAW LOCK - STUCK [HR CABIN]	Ekambaram. K.	New Lock fixed.		Karthik. K. - Administration	23/03/2023
Comp. Dt. : 15/06/2023 Status : Completed								
451	23060545	Administration	MAIN DOOR CLOSER PROBLEM	Ekambaram. K.	New door closer fixed.		Karthik. K. - Administration	27/06/2023
Comp. Dt. : 20/06/2023 Status : Completed								
452	23060705	AO Office	NEED REPAIRING WORK FOR MAIN DOOR - SOUND AND DOOR STOPPER NOT WORKING	Ekambaram. K.	New door closer fixed.		Kadhiravan. C. - Administration	27/06/2023
Comp. Dt. : 22/06/2023 Status : Completed								
453	23060829	AO Office	NEED REPAIRING WORK FOR MALE RESTROOM DOOR - SOUND & UN FIX -	Ekambaram. K.	Work completed		Siva. E. - Administration	07/07/2023
Dept Name : Air Condition Department - Work Shop Comp. Dt. : 09/05/2022 Status : Completed								
454	22050279	AC DEPT	NEED TABLE REWORK	Parthiban.K.	Table leg welding and painting work completed		Panneer Selvam. P. - Air Condition Department	18/05/2022
Comp. Dt. : 19/05/2022 Status : Completed								
455	22050690	HOSPITAL II FLOOR	NEED TO FIX CHAMBER BED FOR FIXING NEW AC UNIT AT II FLOOR "G" WING	Murugavel	Civil work, msg inform to civil dept	 Dr. KAGNE. R.N DEAN SRI MANAKULA VINAYAGAR MEDICAL COLLEGE & HOSPITAL KALITHEERTHALKUPPAM, PUDUCHERRY-605107.	Rabu. D. - Air Condition Department	27/05/2022

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 25/05/2022 Status : Completed								
456	22050925	SURGERY OT	NEED DRILLING WORK FOR A H MOTOR BED	Sarathy. A.	Holes drilled.		Babu. D. - Air Condition Department	10/06/2022
Comp. Dt. : 10/09/2022 Status : Completed								
457	22090406	AHU Room-1ST FLOOR	NEED CEMENT WORK FOR PIPELINE CLOSING WORK AT BACK SIDE OF I FLOOR AHU ROOM	Murugavel	Hole packing work completed		Panneer Selvam. P. - Air Condition Department	28/09/2022
Comp. Dt. : 05/10/2022 Status : Completed								
458	22100078	DIALYSIS IN 2ND FLOOR	NEED TO FIX GRILL STEPS	Sarathy. A.	Steps fixed, problem solved		Panneer Selvam. P. - Air Condition Department	15/11/2022
Comp. Dt. : 03/11/2022 Status : Completed								
459	22110059	Air Condition	A/C COMPRESSOR LEG FIXING WORK	Sarathy. A.	Bolt welded		Babu. D. - Air Condition Department	16/11/2022
Comp. Dt. : 08/11/2022 Status : Completed								
460	22110297	CT Scan	BASEMENT CT SCAN UPS ROOM NEED TO CLOSE WINDOW SHUTTER	Ekambaram. K.	Window shutter repaired and serviced, problem solved		Panneer Selvam. P. - Air Condition Department	18/11/2022
Comp. Dt. : 21/11/2022 Status : Completed								
461	22110877	AHU Room-1ST FLOOR	MASON WORK /PACKAGING WORK NEED TO DO	Murugavel	Mason work completed		Elumalai. J. - Air Condition Department	01/12/2022
Comp. Dt. : 16/12/2022 Status : Completed								
462	22120767	Hospital	NEED PAINTING WORK FOR AC GRILL AT OLD PICU & NICU	Manimaran. A.	Bed side locker and IV stand fixed.		Panneer Selvam. P. - Air Condition Department	23/12/2022
Comp. Dt. : 18/01/2023 Status : Completed								
463	23010618	CHILLER IN HOSPITAL TERROUS	NEED PAINTING WORK FOR PUMP MOTOR	Manimaran. A.	Pump painted, work completed		Panneer Selvam. P. - Air Condition Department	30/01/2023
Comp. Dt. : 27/02/2023 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
464	23021022	Work Shop	NEED WELDING WORK FOR OUTDOOR AC LEG	Sarathy. A.	Outdoor unit A/C leg welding work completed		Ramesh. P. - Air Condition Department	04/03/2023
Comp. Dt. : 20/03/2023 Status : Completed								
465	23030799	MEDICAL COLLEGE	NEED PAINTING WORK FOR MEDICAL COLLEGE CHILLER PUMP	Manimaran. A.	Painting work completed		Panneer Selvam. P. - Air Condition Department	31/03/2023
Comp. Dt. : 27/05/2023 Status : Completed								
466	23051103	AHU Room	NEED PAINTING WORK FOR ALL AHU ROOMS	Manimaran. A.	Work completed		Panneer Selvam. P. - Air Condition Department	05/08/2023
Comp. Dt. : 08/06/2023 Status : Completed								
467	23060260	Work Shop	NEED WELDING WORK FOR AC OUTDOOR BASE	Sarathy. A.	wrong complaint		Ramesh. P. - Air Condition Department	20/06/2023
Dept Name : Anaesthesiology - Work Shop Comp. Dt. : 13/12/2022 Status : Completed								
468	22120596	CLINICAL DEPARTMENT IN 2ND FLOOR	DUE TO FUNGUS FORM - BAD SMELL AT WALL SIDE - NEED PAINTING WORK - LEFT SIDE LAST ROOM	Manimaran. A.	Wrong complaint.		Suneeth P. Lazarus - Anaesthesiology	23/12/2022
Dept Name : Animal House - Work Shop Comp. Dt. : 26/07/2022 Status : Completed								
469	22070979	Animal House	NEED TO FIX SCREEN ROD & CLAMP FOR NEW ANIMAL HOUSE NEAR NURSING COLLEGE	Ekambaram. K.	Screen rod refixed and new clamp fixed, problem solved		Prema. A. - Animal House	05/08/2022
Comp. Dt. : 24/08/2022 Status : Completed								
470	22080811	Animal House	NEED TO FIX BOARDS [10 NOS]	Ekambaram. K.,Venkatesan. R.,Sundaramoorthy. G.	Board fixed.		Prema. A. - Animal House	09/09/2022
Dept Name : BIOCHEMISTRY - Work Shop Comp. Dt. : 02/05/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
471	22050055	Blood Collection Centre	NEED TO REFIX PHLEBOTOMY CHAIR HANDLE SCREWS - FOR ALL CHAIRS	Sarathy. A.	All chairs screw refixed, problem solved		Srinivasamurugan. V. - BIOCHEMISTRY	12/05/2022
Comp. Dt. : 17/05/2022 Status : Completed								
472	22050625	Blood Collection Centre	NEED TO REFIX BLOOD COLLECTION CHAIR SCREWS	Sarathy. A.	6m chair screw refixed, problem solved		Srinivasamurugan. V. - BIOCHEMISTRY	27/05/2022
473	22050626	BIOCHEMISTRY	NEED REPAIRING WORK FOR "S" TYPE CHAIR	Sarathy. A.	S Type chair repairing work completed, screw refixed, problem solved		Srinivasamurugan. V. - BIOCHEMISTRY	27/05/2022
Comp. Dt. : 19/05/2022 Status : Completed								
474	22050708	BIOCHEMISTRY	NEED TO CHECK LAB ENTRANCE GLASS DOOR - GLASS BROKEND - NEED URGENT SERVICE	Pachaimuthusamy. D.	Glass door fixed, problem solved		Srinivasamurugan. V. - BIOCHEMISTRY	27/05/2022
Comp. Dt. : 15/06/2022 Status : Completed								
475	22060588	Blood Collection Centre	NEED TO FIX SCREEN ROD	Pachaimuthusamy. D.	Screen rod fixed, problem solved		Srinivasamurugan. V. - BIOCHEMISTRY	01/07/2022
Comp. Dt. : 24/08/2022 Status : Completed								
476	22080805	Blood Collection Centre	NEED WHITE CEMENT WORK FOR SINK	Murugavel	JK white applied.		Srinivasamurugan. V. - BIOCHEMISTRY	09/09/2022
Comp. Dt. : 01/09/2022 Status : Completed								
477	22090015	COMMON FEMALE TOILET NEAR BIOCHEMISTRY	NEED TO BROKE RESTROOM DOOR LOCK	Ekambaram. K.	Lock opened.		Sangeetha. S. - BIOCHEMISTRY	08/09/2022
Comp. Dt. : 06/09/2022 Status : Completed								
478	22090243	BIOCHEMISTRY	NEED REPAIRING WORK FOR CUPBOARD DOOR & LOCK - LOCK NOT WORKING	Ekambaram. K.	New magnet lock fixed.		Srinivasamurugan. V. - BIOCHEMISTRY	24/09/2022
Comp. Dt. : 16/09/2022 Status : Completed								
479	22090659	Blood Collection Centre	NEED TO REFIX PHLEBOTOMY CHAIRS	Sarathy. A.	Chair screw fixed, problem solved		Srinivasamurugan. V. - BIOCHEMISTRY	29/09/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 18/10/2022								
Status : Completed								
480	22100574	Biochemistry Lab-Hospital	NEED REPAIRING WORK FOR DOOR - SOUND & NOT CLOSING PROPER	Ekambaram. K.,Sundaramoorthy. G.,Venkatesan. R.	Door refixed.		Srinivasamurugan. V. - BIOCHEMISTRY	29/10/2022
Comp. Dt. : 20/10/2022								
Status : Completed								
481	22100661	Biochemistry Lab-Hospital	DOOR NOT CLOSING PROPERLY	Ekambaram. K.	New magnet lock fixed.		Srinivasamurugan. V. - BIOCHEMISTRY	29/10/2022
Comp. Dt. : 14/11/2022								
Status : Completed								
482	22110493	Blood Collection Centre	PLYWOOD BROKEN	Ekambaram. K.	Plywood fixed.		Srinivasamurugan. V. - BIOCHEMISTRY	21/11/2022
Comp. Dt. : 16/11/2022								
Status : Completed								
483	22110640	Blood Collection Centre	PHLEBOTOMY CHAIR SCREW NEED TO BE REFIX	Ekambaram. K.	Chair screw fixed.		Srinivasamurugan. V. - BIOCHEMISTRY	21/11/2022
Comp. Dt. : 07/12/2022								
Status : Completed								
484	22120283	Pathology Lab	IN ROOM NO.45-DOOR NOT CLOSING PROPERLY	Ekambaram. K.	Door closer adjusted, problem solved		Srinivasamurugan. V. - BIOCHEMISTRY	19/12/2022
Comp. Dt. : 12/01/2023								
Status : Completed								
485	23010508	BIOCHEMISTRY--COLLEGE	NEED TO FIX RACK	Ekambaram. K.	RACK FIXED.		Suganthi. P. - BIOCHEMISTRY	04/05/2023
Comp. Dt. : 20/01/2023								
Status : Completed								
486	23010728	Blood Collection Centre	NEED REPAIRING WORK FOR DOOR CLOSER - NOT WORKING PROPER	Ekambaram. K.	Door closer adjusted, problem solved		Srinivasamurugan. V. - BIOCHEMISTRY	30/01/2023
Comp. Dt. : 30/01/2023								
Status : Completed								
487	23011081	BIOCHEMISTRY	NEED TO FIX NAIL FOR FIXING [PHOTO & FRAME]	Ekambaram. K.	Steel nail fixed		Srinivasamurugan. V. - BIOCHEMISTRY	11/02/2023
Comp. Dt. : 06/02/2023								
Status : Completed								
488	23020157	BIOCHEMISTRY	NEED TO FIX NAILS	Ekambaram. K.	Iron nail fixed		Srinivasamurugan. V. - BIOCHEMISTRY	16/02/2023
Comp. Dt. : 27/03/2023								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
489	23031139	BIOCHEMISTRY	NEED TO REPASTE / REFIX " NAME BOARD"	Ekambaram. K.	BOARD FIXED.		Srinivasamurugan. V. - BIOCHEMISTRY	01/04/2023
Comp. Dt. : 26/05/2023								
Status : Completed								
490	23051031	Blood Collection Centre	NEED TO REFIX SCREW FOR PHLEBOTOMY CHAIR	Ekambaram. K.	5 NOS CHAIR REPAIRED		Srinivasamurugan. V. - BIOCHEMISTRY	03/06/2023
Dept Name : Biomedical - Work Shop								
Comp. Dt. : 05/05/2022								
Status : Completed								
491	22050136	ICU	NEED WELDING WORK FOR ECHO MACHINE STAND	Sarathy. A.	Stand new clamp fixed, problem solved		Premkumar. G. - Biomedical	12/05/2022
Comp. Dt. : 18/10/2022								
Status : Completed								
492	22100587	Biomedical	NEED CUTTING WORK FOR CT TABLE BOLT	Ekambaram. K., Sundaramoorthy. G., Manivannan. A.	Bolt removed.		Gurumoorthy. G. - Biomedical	29/10/2022
Comp. Dt. : 22/02/2023								
Status : Completed								
493	23020873	Biomedical	WINDOW CLOSING WORK	Ekambaram. K.	Window door repaired, problem solved		Sridhar. K. - Biomedical	01/03/2023
Dept Name : BLOOD BANK - Work Shop								
Comp. Dt. : 25/05/2022								
Status : Completed								
494	22050939	Mit ladies hostel	NEED TO REFIX NEW PATLOCK [2NOS] FOR CUPBOARD - ROOM NO 9	Ekambaram. K.	Pad lock fixed.		Suhasini. K. - BLOOD BANK	10/06/2022
Comp. Dt. : 05/09/2022								
Status : Completed								
495	22090176	Blood Bank	NEED TO REFIX SCREW [NAIL] FOR TEAPOY	Venkatesan. R.	Screen fixing work completed.		Ganesh. V. - BLOOD BANK	24/09/2022
Comp. Dt. : 09/11/2022								
Status : Completed								
496	22110369	Blood Bank	DOOR CLOSER NEED TO BE CHANGE	Ekambaram. K.	New Door closer changed, problem solved		Thirumangai. S. - BLOOD BANK	18/11/2022
Comp. Dt. : 26/11/2022								
Status : Completed								
497	22111135	Blood Bank	DONER COUCH MOVING AROUND	Ekambaram. K.	Couch wheel 2Nos changed, problem solved		Thirumangai. S. - BLOOD BANK	06/12/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 29/11/2022 Status : Completed								
498	22111216	Blood Bank	NEED REPAIRING FOR DOOR LOCK (INSIDE)	Sundaramoorthy. G.	New pad lock fixed, problem solved		Thirumangai. S. - BLOOD BANK	06/12/2022
Comp. Dt. : 20/01/2023 Status : Completed								
499	23010743	Blood Bank	NEED DRILLING WORK FOR DOOR [INSTRUMENT]	Sarathy. A.	Drilling work completed		Ganesh. V. - BLOOD BANK	30/01/2023
Comp. Dt. : 06/02/2023 Status : Completed								
500	23020155	Blood Bank	NEED REPAIRING WORK FOR TABLE LEG - BROKEN	Sarathy. A.	Table leg fixed		Thirumangai. S. - BLOOD BANK	16/02/2023
Comp. Dt. : 24/03/2023 Status : Completed								
501	23031008	Blood Bank	NEED REPAIRING WORK FOR MAINDOOR - SOUND PROBLEM	Sundaramoorthy. G., Ekambaram. K., Pachaimuthusamy . D.	DOOR SERVICED.		Sivasankari.I. - BLOOD BANK	01/04/2023
Comp. Dt. : 30/03/2023 Status : Completed								
502	23031311	Blood Bank	NEED REPAIRING & ADJUSTMENT WORK FOR DOOR	Ekambaram. K.	Door repairing work completed		Ganesh. V. - BLOOD BANK	06/04/2023
Comp. Dt. : 11/05/2023 Status : Completed								
503	23050428	Blood Bank	NEED REPAIRING WORK FOR DOOR - BROKEN	Ekambaram. K.	DOOR REPAIRED		Thirumangai. S. - BLOOD BANK	18/05/2023
Dept Name : Canteen - Boys Hostel - Work Shop Comp. Dt. : 02/05/2022 Status : Completed								
504	22050054	Boys hostel PH-I	NEED TO REFIX MOSQUITO NET FOR ROOM NO 40	Ekambaram. K.	Mosquito net refixed, problem solved		Sambasivam. K. - Canteen - Boys Hostel	12/05/2022
Comp. Dt. : 05/05/2022 Status : Completed								
505	22050138	BOYS HOSTEL MESS	NEED REPAIRING WORK FOR COCONUT GRATER - BROKEND	Sarathy. A.	Coconut grater welded, problem solved		nand. G. - Transport	12/05/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
506	22050156	Boys hostel P.H-III	MAIN DOOR CYLINDER LOCK PROBLEM IN ROOM NO 43	Pachaimuthusamy. D.	Lock repairing work completed		Sambasivam. K. - Canteen - Boys Hostel	12/05/2022
507	22050157	Boys hostel PH-I	NEED REPAIRING WORK FOR BERO LOCK FOR ROOM NO 53	Pachaimuthusamy. D.	Bero lock refixed, problem solved		Sambasivam. K. - Canteen - Boys Hostel	12/05/2022
Comp. Dt. : 09/05/2022 Status : Completed								
508	22050255	Boys hostel	NEED TO REFIX RESTROOM DOOR INSIDE LOCK FOR PHASE III - ROOM NO 33 & RESTROOM VENTILATOR MESH FOR PH	Pachaimuthusamy. D.	Rest room door and lock refixed, ventilator mesh fixed, problem solved		Sambasivam. K. - Canteen - Boys Hostel	18/05/2022
Comp. Dt. : 17/05/2022 Status : Completed								
509	22050614	Boys hostel PH-I	NEED MATION WORK FOR WINDOW SIDE - ROOM NO 51 & REPAIRING WORK FOR COT ROOM NO 22	Murugavel,Sankar. T. M.,Ekambaram. K.	All workshop complaint rectified, problem solved		Sambasivam. K. - Canteen - Boys Hostel	27/05/2022
510	22050615	Boys hostel PH-I	NEED TO REFIX HANGER FOR ROOM NO 26 & MOSQUITO NET FOR ROOM NO 20	Ekambaram. K.	Hanger and mosquito net refixed, problem solved		Sambasivam. K. - Canteen - Boys Hostel	27/05/2022
Comp. Dt. : 20/05/2022 Status : Completed								
511	22050776	Boys hostel PH-I	REFFIX VENTILATION MOSQUITO NET FOR RESTROOM - ROOM NO 20,22,& 41	Ekambaram. K.	Mosquito net refixed, work completed		Sambasivam. K. - Canteen - Boys Hostel	28/05/2022
512	22050777	Ladies hostel Phase-II	NEED REPAIRING WORK HANGER ROOM NO 35 & REFFIX VENTILATION MOSQUITO NET FOR RESTROOM - ROOM NO 54	Ekambaram. K.	Mosquito net and hanger refixed, problem solved		Sambasivam. K. - Canteen - Boys Hostel	28/05/2022
Comp. Dt. : 21/05/2022 Status : Completed								
513	22050793	Boys hostel Phase-II	NEED TO REFIX COMMON REST ROOM DOOR INSIDE PATLOCK - 3 ROOMS	Ekambaram. K.,Venkatesan. R.,Pachaimuthusamy . D.	New padlock changed in 3Nos of rest room, problem solved		Sambasivam. K. - Canteen - Boys Hostel	28/05/2022
514	22050794	Boys hostel PH-I	NEED PAINTING WORK FOR BERO TOP SIDE ROOM NO 29	Manimaran. A.	Painting work completed		Sambasivam. K. - Canteen - Boys Hostel	28/05/2022
Comp. Dt. : 23/05/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
515	22050824	Boys hostel Phase-II	NEED TO REFIX MOSQUITO NET FOR ROOM NO 42	Ekambaram. K.	Mosquito net refixed, problem solved		Sambasivam. K. - Canteen - Boys Hostel	28/05/2022
Comp. Dt. : 24/05/2022 Status : Completed								
516	22050910	Boys hostel PH-I	NEED REPAIRING & REFIX RESTROOM DOOR , MOSQUITO NET & VENTILATION SHEET FOR ROOM NO 15,21 &49	Ekambaram. K.	Welding work completed		Sambasivam. K. - Canteen - Boys Hostel	10/06/2022
517	22050911	Boys hostel Phase-II	NEED TO FIX RESTROOM WINDOW SIDE GAP CLOSING WORK WITH WOODEN SHEETS FOR II FLOOR COMMON RESTROOM	Ekambaram. K., Pachaimuthusamy . D., Venkatesan. R.	Welding completed		Sambasivam. K. - Canteen - Boys Hostel	10/06/2022
518	22050912	Boys hostel P.H-III	NEED TO REFIX SOAP STAND FOR ROOM NO 33	Ekambaram. K.	Welding work completed		Sambasivam. K. - Canteen - Boys Hostel	10/06/2022
Comp. Dt. : 02/06/2022 Status : Completed								
519	22060074	Boys hostel Phase-II	NEED TO REFIX MOSQUITO NET - ROOM NO 30	Ekambaram. K.	Net fixed.		Sambasivam. K. - Canteen - Boys Hostel	10/06/2022
Comp. Dt. : 07/06/2022 Status : Completed								
520	22060248	Boys hostel Phase-II	NEED REPAIRING WORK FOR CUPBOARD DOOR - ROOM NO 41 & 56	Ekambaram. K.	Net fixed.		Sambasivam. K. - Canteen - Boys Hostel	13/06/2022
Comp. Dt. : 09/06/2022 Status : Completed								
521	22060348	Boys hostel PH-I	NEED TO REFIX MOSQUITO NET FOR WINDOWS - ROOM NO 50	Ekambaram. K.	Net fixed.		Sambasivam. K. - Canteen - Boys Hostel	13/06/2022
Comp. Dt. : 16/06/2022 Status : Completed								
522	22060619	Boys hostel Phase-II	NEED REPAIRING WORK FOR MAIN DOOR HANDLE - ROOM NO 32	Pachaimuthusamy. D.	Handle fixed		Sambasivam. K. - Canteen - Boys Hostel	23/06/2022
Comp. Dt. : 23/06/2022 Status : Completed								
523	22060848	BOYS HOSTEL MESS	NEED TO CHECK STOVE BURNER	Sarathy. A.	Wrong complaint		malai. M. - Canteen - Boys Hostel	01/07/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
	Comp. Dt. : 25/06/2022							
	Status : Completed							
524	22060918	Boys hostel PH-I	NEED MATION WORK FOR ROOM NO 15 , 22 & 50	Murugavel	Plastering JK white applied		Sambasivam. K. - Canteen - Boys Hostel	05/07/2022
	Comp. Dt. : 28/06/2022							
	Status : Completed							
525	22061004	Boys hostel P.H-III	NEED WHITE CEMENT WORK FOR RESTROOM TILES FOR ROOM NO 3	Murugavel	Tiles refixed and JK white applied		Sambasivam. K. - Canteen - Boys Hostel	05/07/2022
	Comp. Dt. : 30/06/2022							
	Status : Completed							
526	22061103	Boys hostel PH-I	NEED TILES GREETING & BINDING WORK FOR ROOM NO 53	Murugavel	JK white paint work done		Sambasivam. K. - Canteen - Boys Hostel	05/07/2022
	Comp. Dt. : 04/07/2022							
	Status : Completed							
527	22070121	Boys hostel P.H-III	NEED REPAIRING WORK FOR REST ROOM VENTILATOR MESH - ROOM NO 39	Ekambaram. K.,Sundaramoorthy. G.,Venkatesan. R.	New Mesh fixed in ventilator, work completed		Sambasivam. K. - Canteen - Boys Hostel	20/07/2022
	Comp. Dt. : 08/07/2022							
	Status : Completed							
528	22070350	BOYS HOSTEL MESS	need welding work for gas stove vessle stand	Sarathy. A.	gas stove and vessels stand welding work completed		Sambasivam. K. - Canteen - Boys Hostel	16/07/2022
	Comp. Dt. : 11/07/2022							
	Status : Completed							
529	22070441	Boys hostel Phase-II	NEED REPAIRING WORK FOR WINDOW - ROOM NO 29	Ekambaram. K.,Venkatesan. R.,Sundaramoorthy. G.	Window door repaired and refixed in properly, problem solved		Sambasivam. K. - Canteen - Boys Hostel	20/07/2022
	Comp. Dt. : 12/07/2022							
	Status : Completed							
530	22070470	Boys hostel PH-I	NEED TO REFIX DOOR STOPER FOR ROOM NO 42 & 44	Ekambaram. K.	Door stoper refixed, problem solved		Sambasivam. K. - Canteen - Boys Hostel	20/07/2022
	Comp. Dt. : 13/07/2022							
	Status : Completed							
531	22070514	Boys hostel Phase-II	NEED CARPENTER WORK FOR ROOM NO 29 [WINDOW SIDE]	Sundaramoorthy. G.	Window door repaired and serviced, problem solved		Sambasivam. K. - Canteen - Boys Hostel	01/08/2022

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 18/07/2022 Status : Completed								
532	22070647	Boys hostel P.H-III	NEED REPAIRING WORK FOR MAIN DOOR LOCK - ROOM NO 3	Ekambaram. K.	Door and door lock repaired and serviced, refixed in properly, problem solved		Sambasivam. K. - Canteen - Boys Hostel	01/08/2022
Comp. Dt. : 21/07/2022 Status : Completed								
533	22070777	Boys hostel P.H-III	NEED TILES GROUTING WORK & MATION WORK FOR ROOM NO 3	Murugavel	Tiles refixed, JK white cement pointing work done, work completed		Sambasivam. K. - Canteen - Boys Hostel	01/08/2022
Comp. Dt. : 23/07/2022 Status : Completed								
534	22070860	Ladies hostel Phase-II	DUE FUNGUS FORMED - NEED PAINTING WORK FOR ROOM NO 50	Manimaran. A.	Painting work completed.		Sambasivam. K. - Canteen - Boys Hostel	24/09/2022
Comp. Dt. : 01/08/2022 Status : Completed								
535	22080038	Boys hostel Phase-II	NEED REPAIRING WORK FOR MAIN DOOR LATCH FOR ROOM NO 41 & MASQUITO NET FOR ROOM NO 42	Ekambaram. K.	#41- door lock refixed, #42- Mosquito net refixed, work completed		Sambasivam. K. - Canteen - Boys Hostel	08/08/2022
Comp. Dt. : 02/08/2022 Status : Completed								
536	22080068	Boys hostel PH-I	NEED TO REFIX VENTILATION MASQUITO NET & WINDOW GLASS DOOR ROOM NO 6 & 16	Ekambaram. K.	Window glass door and mosquito net refixed, work completed		Sambasivam. K. - Canteen - Boys Hostel	08/08/2022
Comp. Dt. : 04/08/2022 Status : Completed								
537	22080152	Boys hostel P.H-III	ROOM NO.49 BATHROOM JOINT TAILS BROKEN	Murugavel	Tiles refixed, JK white cement pointing work done, problem solved		Sambasivam. K. - Canteen - Boys Hostel	17/08/2022
Comp. Dt. : 08/08/2022 Status : Completed								
538	22080261	Boys hostel PH-I	NEED WHITE CEMENT WORK FOR RESTROOM TILES BAKING WORK - ROOM NO 27 & 28	Murugavel	Tiles fixed, JK white cement pointing work done, problem solved		Sambasivam. K. - Canteen - Boys Hostel	23/08/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
539	22080262	Boys hostel P.H-III	NEED REPAIRING WORK FOR MAIN DOOR CYLINDRICAL LOCK - ROOM NO 20	Ekambaram. K.	Door and door lock repaired and serviced, problem solved		Sambasivam. K. - Canteen - Boys Hostel	23/08/2022
Comp. Dt. : 09/08/2022 Status : Completed								
540	22080311	Boys hostel P.H-III	NEED TO REFIX DOOR STOPPER FOR ROOM NO 54 & HANGER FOR ROOM NO 33	Ekambaram. K.	New Door stopper changed, problem solved		Sambasivam. K. - Canteen - Boys Hostel	23/08/2022
Comp. Dt. : 10/08/2022 Status : Completed								
541	22080377	Boys hostel	NEED PAINTING WORK FOR FLAG POST	Manimaran. A.	Flag post painting work completed		Sambasivam. K. - Canteen - Boys Hostel	23/08/2022
542	22080378	Boys hostel PH-I	NEED GRADING & MATION WORK FOR 6 ROOMS [6NOS]	Murugavel	Grating fixed and masion work completed		Sambasivam. K. - Canteen - Boys Hostel	23/08/2022
543	22080388	Boys hostel	NEED WELDING WORK FOR BASKET BALL WING	Sarathy. A.,Viswa. V.,Sundaramoorthy. G.	Welding work completed		Sambasivam. K. - Canteen - Boys Hostel	23/08/2022
Comp. Dt. : 27/08/2022 Status : Completed								
544	22080939	Boys hostel	NEED WELDING WORK FOR GAS PIPE LINE - GAS LEAKAGE	Sarathy. A.	Work completed.		Elumalai. M. - Canteen - Boys Hostel	09/09/2022
545	22080950	Boys hostel Phase-II	NEED MATION WORK FOR ROOM NO 29	Murugavel	Work completed.		Sambasivam. K. - Canteen - Boys Hostel	09/09/2022
Comp. Dt. : 01/09/2022 Status : Completed								
546	22090041	Boys hostel PH-I	NEED TO REFIX RESTROOM MOSQUITO NET ROOM NO 44	Ekambaram. K.	Net fixed.		Sambasivam. K. - Canteen - Boys Hostel	08/09/2022
Comp. Dt. : 05/09/2022 Status : Completed								
547	22090173	BOYS HOSTEL MESS	NEED CEMENT WORK FOR KITCHEN FLOOR - DAMAGE AND BROKEN - NEED URGENT SERVICE	Murugavel	Work completed.		Kesavaraj. P. - Canteen - Boys Hostel	24/09/2022
Comp. Dt. : 07/09/2022 Status : Completed								
548	22090267	Boys hostel PH-I	NEED TO REARRANGE WINDOW - FULLY DAMAGE - ROOM NO 44	Ekambaram. K.,Sundaramoorthy. G.,Parthiban.K.	Window repaired.		Mathubalan. M. - Canteen - Boys Hostel	24/09/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 13/09/2022 Status : Completed								
549	22090472	BOYS HOSTEL MESS	NEED TO FIX BLADE FOR VEGITABLE CUTTER	Manivannan. A.	Blade fixed, welding work completed		Elumalai. M. - Canteen - Boys Hostel	28/09/2022
Comp. Dt. : 17/09/2022 Status : Completed								
550	22090686	Boys hostel	NEED WELDING WORK FOR OUTSIDE GATE PARTITION STEEL SHEET - REFIX & FALL DOWN [BACK SIDE OF PG HOS	Sarathy. A.,Manivannan. A.,Venkatesan. R.	Sheet refixed, problem solved		Sambasivam. K. - Canteen - Boys Hostel	29/09/2022
551	22090687	Boys hostel	DUE TO SPORTS DAY PURPOSE NEED PAINTING WORK FOR FLAG POST & PODIUM - NEED URGENT SERVICE	Manimaran. A.	30Nos Post painting work completed		Sambasivam. K. - Canteen - Boys Hostel	29/09/2022
Comp. Dt. : 21/09/2022 Status : Completed								
552	22090839	Boys hostel	NEED TO FIX HANDLE FOR TABLE DRAW FOR COMPUTER ROOM	Ekambaram. K.	Table draw handle fixed, probelm solved		Kesavaraj. P. - Canteen - Boys Hostel	29/09/2022
Comp. Dt. : 24/09/2022 Status : Completed								
553	22090969	Boys hostel P.H-III	NEED WHITE CEMENT WORK FOR RESTROOM FOR ROOM NO 3 & 40	Murugavel	Restroom floor - JK white cement pointing work completed		Sambasivam. K. - Canteen - Boys Hostel	08/10/2022
Comp. Dt. : 05/10/2022 Status : Completed								
554	22100031	Boys hostel	NEED TO FIX STAINLESS STEEL NET FOR WINDOW FOR COMPUTER ROOM	Sundaramoorthy. G.	6' X 4' SS mesh fixed, problem solved		Anand. G. - Transport	20/10/2022
Comp. Dt. : 10/10/2022 Status : Completed								
555	22100204	BOYS HOSTEL MESS	NEED WELDING WORK FOR BOILER SIDE CONNECTION PIPELINE [SS PIPELINE] - NEED URGENT SERVICE	Sarathy. A.	Boiler SS pipe line welding work completed		Kesavaraj. P. - Canteen - Boys Hostel	12/10/2022
Comp. Dt. : 14/10/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
556	22100473	Boys hostel PH-I	TILES DAMAGE - NEED WHITE CEMENT PACKING WORK FOR ROOM NO 17,31 &45	Murugavel	Tiles refixed, JK white cement pointing work done		Sambasivam. K. - Canteen - Boys Hostel	21/10/2022
Comp. Dt. : 19/10/2022 Status : Completed								
557	22100634	Boys hostel	MIXER MACHINE PROBLEM	Sarathy. A.	No complaint in mixer machine.		Anand. G. - Transport	29/10/2022
Comp. Dt. : 24/11/2022 Status : Completed								
558	22111036	Boys hostel PH-I	IN ROOM NO.62-CUPBOARD DOOR REPAIR WORK NEED TO DO	Ekambaram. K.	Cupboard lock fixed, problem solved		Sambasivam. K. - Canteen - Boys Hostel	01/12/2022
559	22111037	Boys hostel PH-I	IN ROOM NO.53-CUPBOARD DOOR REPAIR WORK NEED TO DO	Ekambaram. K.	Cupboard door repaired and serviced, problem solved		Sambasivam. K. - Canteen - Boys Hostel	01/12/2022
560	22111038	Boys hostel Phase-II	IN ROOM NO.60-CUPBOARD DOOR LOCK REPAIR WORK NEED TO DO	Ekambaram. K.	Cupboard door and lock repaired and serviced, problem solved		Sambasivam. K. - Canteen - Boys Hostel	01/12/2022
Comp. Dt. : 29/11/2022 Status : Completed								
561	22111221	Boys hostel PH-I	NEED TO REFIX VENTILATOR MOSQUITO NET FOR REST ROOM - ROOM NO 22 & 27	Ekambaram. K.	Ventilator mosquito net fixed, problem solved		Sambasivam. K. - Canteen - Boys Hostel	06/12/2022
Comp. Dt. : 08/12/2022 Status : Completed								
562	22120364	Boys hostel P.H-III	IN ROOM NO.3 BATHROOM DOOR NOT CLOSING PROPERLY	Ekambaram. K.	Door repaired and adjusted, problem solved		Sambasivam. K. - Canteen - Boys Hostel	19/12/2022
Comp. Dt. : 12/12/2022 Status : Completed								
563	22120521	Mit boys hostel	I ST FLOOR - MAIN DOOR GLASS BROKEN	Ekambaram. K.	Door glass fixed, problem solved		Sambasivam. K. - Canteen - Boys Hostel	19/12/2022
Comp. Dt. : 13/12/2022 Status : Completed								
564	22120617	Boys hostel P.H-III	NEED REPAIRING WORK FOR CUPBOARD MULTIPURPOSE LOCK FOR ROOM NO 1	Ekambaram. K.	Lock fixed.		Sambasivam. K. - Canteen - Boys Hostel	23/12/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 30/12/2022 Status : Completed								
565	22121360	Kitchen - Boys Hostel	CHAPPATHI FLOUR MIXER MACHINE BOLE NEED TO BE RETIGHTEN	Sarathy. A.	Belt fixed, work completed		Kesavaraj. P. - Canteen - Boys Hostel	05/01/2023
Comp. Dt. : 02/01/2023 Status : Completed								
566	23010031	Mit boys hostel	IN 3RD FLOOR-MASON WORK NEED TO DO	Murugavel	Tiles pointing work completed		Sambasivam. K. - Canteen - Boys Hostel	12/01/2023
Comp. Dt. : 21/01/2023 Status : Completed								
567	23010780	Boys hostel	NEED TO CHECK GRINDER - NOT WORKING	Ekambaram. K.	Grinder repaired and serviced, problem solved		Kesavaraj. P. - Canteen - Boys Hostel	30/01/2023
Comp. Dt. : 30/01/2023 Status : Completed								
568	23011050	Mit boys hostel	NEED TO CHANGE RESTROOM WINDOW GLASS DOOR GLASS BROKEN AT WARDEN ROOM	Ekambaram. K.	Glass door changed, work completed		Sambasivam. K. - Canteen - Boys Hostel	11/02/2023
Comp. Dt. : 31/01/2023 Status : Completed								
569	23011098	BOYS HOSTEL MESS	NEED WELDING WORK FOR KITCHEN INSTRUMENT	Sarathy. A.	Welding work completed		Elumalai. M. - Canteen - Boys Hostel	11/02/2023
Comp. Dt. : 11/02/2023 Status : Completed								
570	23020430	Boys hostel PH-I	NEED TO REFIX MOSQUITO NET FOR WINDOW & RESTROOM VENTILATOR - ROOM NO 44 - NEED URGENT SERVICE	Pachaimuthusamy. D.	New framed and SS MESH fixed, work completed		Sambasivam. K. - Canteen - Boys Hostel	16/02/2023
Comp. Dt. : 13/02/2023 Status : Completed								
571	23020462	Boys hostel Phase-II	NEED TO REFIX MOSQUITO NET FOR ROOM NO 26,32 & 41	Pachaimuthusamy. D.	Mosquito net refixed in all room		Sambasivam. K. - Canteen - Boys Hostel	17/02/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
572	23020463	Boys hostel PH-I	NEED TO REFIX HANGER FOR ROOM NO 25 & DOOR BACKSIDE HANDLE FOR ROOM NO 16	Pachaimuthusamy. D.	Hanger and door handle refixed, problem solved		Sambasivam. K. - Canteen - Boys Hostel	17/02/2023
573	23020464	Boys hostel P.H-III	NEED REPAIRING WORK FOR MAIN DOOR LOCK	Pachaimuthusamy. D.	Door lock repaired and serviced, problem solved		Sambasivam. K. - Canteen - Boys Hostel	17/02/2023
Comp. Dt. : 14/02/2023 Status : Completed								
574	23020519	Boys hostel PH-I	NEED WHITE CEMENT WORK FOR RESTROOM - ROOM NO 20	Murugavel	JK white cement pointing work completed		Sambasivam. K. - Canteen - Boys Hostel	17/02/2023
Comp. Dt. : 16/02/2023 Status : Completed								
575	23020620	Boys hostel PH-I	ROOM NO-48,WINDOW MOSQUITO NET DAMAGE.	Ekambaram. K.	Mosquito net fixed, work completed		Mathubalan. M. - Canteen - Boys Hostel	23/02/2023
Comp. Dt. : 17/02/2023 Status : Completed								
576	23020687	Boys hostel Phase-II	NEED REPAIRING WORK FOR WINDOW DOOR - ROOM NO 30 & 36	Ekambaram. K.	Window door repaired and serviced, work completed		Sambasivam. K. - Canteen - Boys Hostel	08/03/2023
577	23020688	Boys hostel PH-I	PILLAR CRACK AT I FLOOR WATER HEATER NEAR	Murugavel	3Nos of pillar plastering work completed		Sambasivam. K. - Canteen - Boys Hostel	23/02/2023
Comp. Dt. : 20/02/2023 Status : Completed								
578	23020771	Boys hostel Phase-II	NEED TO REFIX MOSQUITO NET FOR ROOM NO 31 & 44	Ekambaram. K.	Mosquito net fixed, work completed		Mathubalan. M. - Canteen - Boys Hostel	01/03/2023
Comp. Dt. : 21/02/2023 Status : Completed								
579	23020796	Boys hostel P.H-III	NEED TO REFIX RESTROOM VENTILATOR NET FOR ROOM NO 26	Ekambaram. K.	Mosquito net fixed, work completed		Sambasivam. K. - Canteen - Boys Hostel	01/03/2023
580	23020797	Boys hostel PH-I	NEED WHITE CEMENT AND CEMENT WORK FOR ROOM NO 30 & 43 [RESTROOM]	Murugavel	Mason work completed		Sambasivam. K. - Canteen - Boys Hostel	01/03/2023
Comp. Dt. : 24/02/2023 Status : Completed								
581	23020932	Boys hostel PH-I	NEED REPAIRING WORK FOR MAIN DOOR BACKSIDE HANDLE - DAMAGE - ROOM NO 34	Ekambaram. K.	Door handle fixed, work completed		Sambasivam. K. - Canteen - Boys Hostel	04/03/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 09/03/2023 Status : Completed								
582	23030375	Boys hostel	NEED REPAIRING & PAINTING WORK FOR DINING HALL CHAIR 20 NOS	Manimaran. A.	WORK COMPLETED.		Sambasivam. K. - Canteen - Boys Hostel	23/03/2023
Comp. Dt. : 14/03/2023 Status : Completed								
583	23030572	BOYS HOSTEL MESS	NEED TO RE FIX BOLT FOR CHAPATI MACHINE - NEED URGENT SERVICE	Sarathy. A.	NEW BOLT FIXED.		Elumalai. M. - Canteen - Boys Hostel	23/03/2023
Comp. Dt. : 17/03/2023 Status : Completed								
584	23030714	Boys hostel P.H-III	NEED TO REFIX RESTROOM DOOR INSIDE LOCK AT III FLOOR	Ekambaram. K.	Lock refixed		Sambasivam. K. - Canteen - Boys Hostel	31/03/2023
Comp. Dt. : 20/03/2023 Status : Completed								
585	23030782	Boys hostel PH-I	NEED TO REFIX WINDOW MOSQUITO NET - ROOM NO 19	Ekambaram. K.	Mosquito net refixed, work completed		Mathubalan. M. - Canteen - Boys Hostel	31/03/2023
Comp. Dt. : 21/03/2023 Status : Completed								
586	23030855	Boys hostel Phase-II	NEED TO REFIX WINDOW MOSQUITO NET FOR ROOM NO 31 - DAMAGE	Ekambaram. K.	Mosquito net refixed, work completed		Mathubalan. M. - Canteen - Boys Hostel	31/03/2023
Comp. Dt. : 24/03/2023 Status : Completed								
587	23031003	Boys hostel Phase-II	NEED WINDOW FRAME REWORK - ROOM NO 62	Ekambaram. K., Sundaramoorthy. G., Manivannan. A.	FRAME REWORK DONE.		Mathubalan. M. - Canteen - Boys Hostel	01/04/2023
588	23031029	Boys hostel Phase-II	NEED TO REFIX MOSQUITO NET FOR COMMON RESTROOM AT II & III FLOOR	Ekambaram. K., Sundaramoorthy. G., Veerappan. D.	NET FIXED.		Sambasivam. K. - Canteen - Boys Hostel	01/04/2023
Comp. Dt. : 28/03/2023 Status : Completed								
589	23031178	Boys hostel Phase-II	TOWARDS WINDOW FRAME DAMAGED- NEED MATION WORK ROOM NO 62	Sankar. T. M.	Window frame refixed, work completed		Sambasivam. K. - Canteen - Boys Hostel	06/04/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
590	23031179	Boys hostel P.H-III	NEED GRATING WORK FOR RESTROOM TILES ROOM NO 7	Parivallal. P.	Grating fixed, work completed		Sambasivam. K. - Canteen - Boys Hostel	06/04/2023
		Comp. Dt. : 11/04/2023 Status : Completed						
591	23040344	BOYS HOSTEL-DINING HALL	NEED REPAIRING WORK FOR DOOR LOCK - BROKEN	Ekambaram. K.	New door lock fixed, problem solved		Elumalai. M. - Canteen - Boys Hostel	20/04/2023
		Comp. Dt. : 17/04/2023 Status : Completed						
592	23040530	Boys hostel P.H-III	NEED TO REFIX MOSQUITO NET - ROOM NO 44	Ekambaram. K.	NET FIXED. WORK COMPLETED		Sambasivam. K. - Canteen - Boys Hostel	02/05/2023
593	23040531	Boys hostel P.H-III	NEED RESTROOM DRAINAGE GRATING WORK FOR ROOM NO 12	Parivallal. P.	Work completed		Sambasivam. K. - Canteen - Boys Hostel	05/08/2023
		Comp. Dt. : 15/05/2023 Status : Completed						
594	23050608	STAFF'S CANTEEN IN COMMERCIAL BLOCK	SHUTTER DOOR STUCK	Ekambaram. K.	Shutter door serviced, work completed		Kesavaraj. P. - Canteen - Boys Hostel	23/05/2023
595	23050609	BOYS HOSTEL MESS	NEED ADJUSTMENT / CHANGE GRINDER PAD - DAMAGE	Ekambaram. K.	Grinder pad changed, problem solved		Kesavaraj. P. - Canteen - Boys Hostel	23/05/2023
		Comp. Dt. : 18/05/2023 Status : Completed						
596	23050764	Boys hostel Phase-II	NEED REPAIRING WORK FOR CUPBOARD DOOR - ROOM NO 31 & 43	Ekambaram. K.	CUPBOARD HINGES FIXED.		Sambasivam. K. - Canteen - Boys Hostel	01/06/2023
597	23050766	BOYS HOSTEL MESS	GRINDER STONE BROKEN - NEED REPAIRING WORK	Ekambaram. K.	WORK COMPLETED		Elumalai. M. - Canteen - Boys Hostel	01/06/2023
		Comp. Dt. : 19/05/2023 Status : Completed						
598	23050798	Boys hostel	NEED REPAIRING WORK FOR WOODEN TABLE LEG - BROKEN	Ekambaram. K.	LEG FIXED.		Kesavaraj. P. - Canteen - Boys Hostel	01/06/2023
		Comp. Dt. : 22/05/2023 Status : Completed						
599	23050872	BOYS HOSTEL MESS	NEED TO REMOVE GRINDER PARTS	Ekambaram. K.	PARTS REMOVED.		Elumalai. M. - Canteen - Boys Hostel	01/06/2023
		Comp. Dt. : 29/05/2023						


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
600	23051148	Boys hostel P,H-III	NEED TO REFIX MOSQUITO NET FOR RESTROOM VENTILATION - ROOM NO 26	Ekambaram. K.	MOSQUITO NET FIXED		Sambasivam. K. - Canteen - Boys Hostel	03/06/2023
601	23051149	Boys hostel PH-I	TILES BROKEN - NEED TOUCHUP WORK FOR RESTROOM - ROOM NO 35	Parivallal. P.	TILES REFIXED		Sambasivam. K. - Canteen - Boys Hostel	03/06/2023
602	23051150	Boys hostel Phase-II	TILES AIR CRACK - NEED TOUCHUP WORK FOR II FLOOR CARITOR	Parivallal. P.	TILES REFIXED		Sambasivam. K. - Canteen - Boys Hostel	03/06/2023
Comp. Dt. : 05/06/2023								
Status : Completed								
603	23060138	Boys hostel	NEED TO REMOVE OLD GAS STOVE SPARE PART	Ekambaram. K.	Parts removed		Elumalai. M. - Canteen - Boys Hostel	20/06/2023
Comp. Dt. : 08/06/2023								
Status : Completed								
604	23060284	Boys hostel Phase-II	NEED REPAIRING WORK FOR MAIN DOOR - ROOM NO 36	Ekambaram. K.	Door repaired		Sambasivam. K. - Canteen - Boys Hostel	20/06/2023
Comp. Dt. : 16/06/2023								
Status : Completed								
605	23060612	Boys hostel Phase-II	3 AND 4 FLOOR--COMMON BATHROOM MIRROR RE FIXING WORK	Ekambaram. K.	Mirror fixed.		Sambasivam. K. - Canteen - Boys Hostel	05/08/2023
Comp. Dt. : 21/06/2023								
Status : Completed								
606	23060774	Mit boys hostel	NEED REPAIRING WORK FOR MAIN DOOR - UNFIX & SOUND - ROOM NO 15	Pachaimuthusamy. D.	Main door repaired.		Sambasivam. K. - Canteen - Boys Hostel	27/06/2023
Dept Name : Canteen - Hospital - Work Shop								
Comp. Dt. : 18/06/2022								
Status : Completed								
607	22060671	HOSPITAL IV FLOOR	TILES BROKEN - AIR BREAK - NEED TOUCHUP WORK AT ENTRANCE WARD NO 409 & 410	Murugavel	30 nos. tiles refixed and JK white paint work		Sankar. M. - Canteen - Hospital	23/06/2022
Comp. Dt. : 26/10/2022								
Status : Completed								
608	22100808	DIET DEPARMENT	(1441)TROLLY DOOR BROKEN	Ekambaram. K.	Door welded.		Sankar. M. - Canteen - Hospital	03/11/2022

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 17/06/2023 Status : Completed								
609	23060631	DIET DEPARMENT	NEED REPAIRING WORK FOR DOOR - SOUND & STUCK	Ekambaram. K.	Door repaired.		Suriyaprakash. R. J. - Canteen - Hospital	27/06/2023
Dept Name : Canteen-Girls Hostel - Work Shop Comp. Dt. : 02/05/2022 Status : Completed								
610	22050020	Ladies hostel Phase-II	NEED REPAIRING WORK FOR DOOR FOR ROOM NO 93 & DOOR LOCK FOR I & II FLOOR DOOR	Pachaimuthusamy. D.	Door and door lock repairing work completed		Malliga. K. - Canteen-Girls Hostel	12/05/2022
611	22050035	JR Quarters	NEED REPAIRING WORK FOR CUPBOARD DOOR LOCK FOR ROOM NO 2	Ekambaram. K.	Cupboard door and lock repairing work completed		Virgin Mary - Canteen-Girls Hostel	12/05/2022
Comp. Dt. : 05/05/2022 Status : Completed								
612	22050125	Ladies hostel Phase-II	NEED REPAIRING WORK FOR RESTROOM DOOR & LOCK FOR II & III FLOOR	Pachaimuthusamy. D.	Rest room door repairing work completed		Malliga. K. - Canteen-Girls Hostel	12/05/2022
613	22050127	JR Quarters	NEED REPAIRING WORK FOR CUPBOARD DOOR & LOCKER FOR ROOM NO 2 ,19	Pachaimuthusamy. D.	Cupboard door and lock repairing work completed		Virgin Mary - Canteen-Girls Hostel	12/05/2022
Comp. Dt. : 06/05/2022 Status : Completed								
614	22050178	JR Quarters	NEED REPAIRING WORK FOR CUPBOARD LOCK FOR ROOM NO 5	Ekambaram. K.	New lock fixed, problem solved		Virgin Mary - Canteen-Girls Hostel	12/05/2022
615	22050190	Ladies hostel Phase-I	NEED CEMENT WORK FOR REST ROOM ROOM NO 7	Murugavel	JK white cement pointing work done, problem solved		Revathy. N. - Canteen-Girls Hostel	12/05/2022
Comp. Dt. : 07/05/2022 Status : Completed								
616	22050230	Ladies hostel Phase-II	NEED TO REFIX WINDOW VOLCANO FOR ROOM NO 95	Pachaimuthusamy. D.	Window velcro net refixed, problem solved		Malliga. K. - Canteen-Girls Hostel	12/05/2022
617	22050236	JR Quarters	NEED REPAIRING WORK FOR CUPBOARD DOOR & LOCK ROOM NO 2 & 5	Pachaimuthusamy. D.	Cupboard door and lock repairing work completed		Virgin Mary - Canteen-Girls Hostel	12/05/2022
Comp. Dt. : 09/05/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
618	22050249	Ladies hostel Phase-I	NEED REPAIRING & REFIX AC DOOR FOR ROOM NO 10 & IV FLOOR DUCT DOOR BROKENED	Pachaimuthusamy. D.,Ekambaram. K.,Venkatesan. R.	AC Door refixed, new duct door changed, problem solved		Revathy. N. - Canteen-Girls Hostel	18/05/2022
619	22050250	Ladies hostel Phase-I	NEED REPAIRING WORK FOR IV FLOOR DUCT DOOR - BROKEND - NEED URGENT SERVICE	Pachaimuthusamy. D.	New duct door changed, problem solved		Revathy. N. - Canteen-Girls Hostel	18/05/2022
620	22050260	JR Quarters	TILES BORKEN NEED TOUCHUP WORK FOR IV FLOOR & CUPBOARD REAPIRING WORK FOR ROOM NO 5,2 & 18	Murugavel,Sankar. T. M.,Pachaimuthusamy . D.	Tiles refixed, JK White cement pointing work done, cupboard fixed, work completed in all rooms		Virgin Mary - Canteen-Girls Hostel	18/05/2022
Comp. Dt. : 10/05/2022		Status : Completed						
621	22050324	JR Quarters	NEED REPAIRING WORK FOR CUPBOARD DOOR & LOCK - ROOM NO 19	Pachaimuthusamy. D.	Cup board fixed, problem solved		Virgin Mary - Canteen-Girls Hostel	18/05/2022
622	22050335	Ladies hostel Phase-II	NEED REPAIRING WORK FOR CUPBOARD DOOR FOR ROOM NO 36	Pachaimuthusamy. D.	Cupboard fixed, work completed		Malliga. K. - Canteen-Girls Hostel	18/05/2022
Comp. Dt. : 16/05/2022		Status : Completed						
623	22050564	Ladies hostel Phase-I	NEED TO REFIX DOOR INSIDE LOCK FOR GUEST ROOM	Ekambaram. K.	Door lock refixed, problem solved		Revathy. N. - Canteen-Girls Hostel	27/05/2022
Comp. Dt. : 18/05/2022		Status : Completed						
624	22050652	Ladies hostel Phase-II	NEED TO REFIX HANGER FOR ROOM NO 86 & VOLCONA FOR ROOM NO 99	Ekambaram. K.	Hanger refixed, work completed		Malliga. K. - Canteen-Girls Hostel	27/05/2022
625	22050653	JR Quarters	NEED REPAIRING WORK FOR MAIN GLASS DOOR LOCK - NOT WORKING	Pachaimuthusamy. D.	Door repaired and refixed, lock serviced, problem solved		Virgin Mary - Canteen-Girls Hostel	27/05/2022
626	22050675	LADIES HOSTEL MESS	NEED MATION WORK FOR CLOSING FLOOR HOLE UNDER DOOR	Murugavel	Holes packing work, work completed		Revathy. N. - Canteen-Girls Hostel	28/05/2022
Comp. Dt. : 21/05/2022		Status : Completed						
627	22050784	Ladies hostel Phase-II	NEED REPAIRING WORK & REFIX RESTROOM DOOR , TOWEL STAND & SOAP STAND FOR III FLOOR	Pachaimuthusamy. D.	Rest room door repaired and refixed, Towel stand and soap fixed, problem solved		Malliga. K. - Canteen-Girls Hostel	28/05/2022
628	22050789	JR Quarters	NEED REPAIRING WORK FOR CUPBOARD DOOR & LOCK [DAMAGE]	Ekambaram. K.	Cupboard door and lock repaired and serviced, problem solved		Virgin Mary - Canteen-Girls Hostel	28/05/2022

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 23/05/2022								
Status : Completed								
629	22050818	Ladies hostel Phase-I	NEED REPAIRING & WHITE CEMENT WORK FOR RESTROOM DOOR FOR ROOM NO 9 & REFIX VENTILATION NET FOR	Murugavel,Sankar. T. M.,Ekambaram. K.	Rest room door hinges fixed with JK white cement, Ventilation net refixed, problem solved		Revathy. N. - Canteen-Girls Hostel	28/05/2022
630	22050831	Ladies hostel Phase-II	NEED REPAIRING WORK FOR DOOR LOCK - ROOM NO 89	Ekambaram. K.	Door lock repaired and serviced, problem solved		Malliga. K. - Canteen-Girls Hostel	28/05/2022
Comp. Dt. : 28/05/2022								
Status : Completed								
631	22051050	Ladies hostel Phase-I	NEED REPAIRING WORK FOR REST ROOM DOOR & REFIX VENTILATOR NET FOR ROOM NO 53	Ekambaram. K.,Venkatesan. R.,Pachaimuthusamy . D.	Door repainted. Net fixed.		Revathy. N. - Canteen-Girls Hostel	10/06/2022
632	22051052	Ladies hostel Phase-I	NEED DOOR REPAIRING WORK FOR ENTRANCE [MAIN DOOR] & ROOM NO 6	Ekambaram. K.	Door repaired.		Revathy. N. - Canteen-Girls Hostel	10/06/2022
Comp. Dt. : 30/05/2022								
Status : Completed								
633	22051078	JR Quarters	NEED TO REFIX FLOOR PARA BLOCK FOR ENTRANCE	Murugavel	Paver block fixed		Virgin Mary - Canteen-Girls Hostel	10/06/2022
634	22051082	Ladies hostel Phase-I	NEED TO CLOSE HOLE FOR MAIN DOOR WITH PLYWOOD SHEET - RAT COMING INSIDE THE ROOM FOR ROOM NO 6	Ekambaram. K.	Plywood fixed.		Revathy. N. - Canteen-Girls Hostel	10/06/2022
Comp. Dt. : 06/06/2022								
Status : Completed								
635	22060189	Ladies hostel Phase-I	NEED TO CLOSE VENTILATION NET - DAMAGE & RATS COMING INSIDE THE ROOM	Ekambaram. K.	Net fixed.		Revathy. N. - Canteen-Girls Hostel	10/06/2022
Comp. Dt. : 09/06/2022								
Status : Completed								
636	22060330	JR Quarters	NEED REPAIRING WORK FOR MAIN DOOR	Ekambaram. K.	Door and cupboard repaired.		Virgin Mary - Canteen-Girls Hostel	13/06/2022
637	22060354	Ladies hostel Phase-II	NEED REPAIRING WORK FOR II FLOOR RESTROOM DOOR LOCK 2 NOS	Ekambaram. K.	Restroom lock fixed.		Malliga. K. - Canteen-Girls Hostel	13/06/2022
Comp. Dt. : 11/06/2022								
Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
638	22060432	Ladies hostel Phase-II	NEED CEMENT WORK FOR II FLOOR RESTROOM DOOR FRAME & ENTRANCE	Ekambaram. K., Pachaimuthusamy . D., Venkatesan. R.	Work completed		Malliga. K. - Canteen-Girls Hostel	21/06/2022
Comp. Dt. : 13/06/2022 Status : Completed								
639	22060461	Ladies hostel Phase-I	NEED TO CHANGE VENTILATION NET FOR ROOM NO 74	Ekambaram. K., Venkatesan. R., Pachaimuthusamy . D.	Net fixed.		Revathy. N. - Canteen-Girls Hostel	21/06/2022
640	22060480	Ladies hostel Phase-II	NEED TO REFIX PAVER TILES AT ENTRANCE	Murugavel	Tiles refixed with JK white.		Malliga. K. - Canteen-Girls Hostel	21/06/2022
Comp. Dt. : 20/06/2022 Status : Completed								
641	22060701	Ladies hostel Phase-I	NEED REPAIRING WORK FOR DOOR FOR ROOM NO 14 & NEED TO REFIX VENTILATOR [INSIDE RATS PROBLEM]	Pachaimuthusamy. D., Ekambaram. K., Parthiban. K.	Door repaired and mesh fixed		Revathy. N. - Canteen-Girls Hostel	23/06/2022
Comp. Dt. : 23/06/2022 Status : Completed								
642	22060823	JR Quarters	NEED TO REFIX [REPAIRING WORK] FOR WRITING TABLE TOP - DAMAGE - NEED URGENT SERVICE	Parthiban. K.	New 12M Table top fixed and table painted, work completed		Virgin Mary - Canteen-Girls Hostel	20/07/2022
643	22060834	Ladies hostel Phase-II	NEED REPAIRING WORK FOR II FLOOR REST ROOM DOOR LOCK & III FLOOR RESTROOM TOWEL STAND - DAMAGE &	Ekambaram. K.	Door lock repaired, towel rod refixed, work completed		Virgin Mary - Canteen-Girls Hostel	01/07/2022
644	22060857	Ladies hostel Phase-II	NEED REPAIRING WORK FOR DOOR RESTER NABB FOR ROOM NO 72	Ekambaram. K.	Door closure repaired and refixed, problem solved		Virgin Mary - Canteen-Girls Hostel	01/07/2022
Comp. Dt. : 25/06/2022 Status : Completed								
645	22060910	Ladies hostel Phase-II	NEED CEMENT WORK FOR FIXING MAINDOOR STEPS FOR ROOM NO 53	Murugavel	Steps packing work		Malliga. K. - Canteen-Girls Hostel	05/07/2022
Comp. Dt. : 28/06/2022 Status : Completed								
646	22060991	Ladies hostel Phase-II	NEED TO REFIX TOWEL STAND FOR IV FLOOR RESTROOM	Pachaimuthusamy. D.	Towel stand fixed		Malliga. K. - Canteen-Girls Hostel	05/07/2022
Comp. Dt. : 01/07/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
647	22070040	Ladies hostel Phase-I	NEED TO CHANGE WINDOW GLASS - BROKEN - ROOM NO 36	Parthiban.K.	New window glass fixed, problem solved		Revathy. N. - Canteen-Girls Hostel	20/07/2022
	Comp. Dt. : 04/07/2022 Status : Completed							
648	22070087	Ladies hostel Phase-I	NEED REPAIRING WORK FOR WINDOW GLASS DOOR - ROOM NO 36	Ekambaram. K.,Venkatesan. R.,Sundaramoorthy. G.	New glass fixed in window, problem solved		Revathy. N. - Canteen-Girls Hostel	09/07/2022
	Comp. Dt. : 05/07/2022 Status : Completed							
649	22070138	Ladies hostel Phase-I	NOT ABLE TO OPEN BERO - NEED TO OPEN ROOM NO 2	Ekambaram. K.	Wrong complaint		Revathy. N. - Canteen-Girls Hostel	16/07/2022
	Comp. Dt. : 07/07/2022 Status : Completed							
650	22070266	Ladies hostel Phase-I	NEED REPAIRING WORK FOR WINDOW DOOR - OPEN CLOSE PROBLEM - ROOM NO 53	Pachaimuthusamy. D.	Door repaired and serviced, problem solved		Revathy. N. - Canteen-Girls Hostel	16/07/2022
	Comp. Dt. : 09/07/2022 Status : Completed							
651	22070366	Ladies hostel Phase-I	NEED WHITE CEMENT WORK FOR ROOM NO 4	Murugavel	JK White cement pointing work completed		Revathy. N. - Canteen-Girls Hostel	20/07/2022
	Comp. Dt. : 12/07/2022 Status : Completed							
652	22070469	LADIES HOSTEL MESS	NEED A NEW WOODEN STAND FOR NEW GRINDER	Manivannan. A.	New wooden stand fixed, work completed		Revathy. N. - Canteen-Girls Hostel	20/07/2022
	Comp. Dt. : 14/07/2022 Status : Completed							
653	22070544	Ladies hostel Phase-I	NEED TO CHANGE WINDOW DOOR GLASS FOR ROOM NO 36 & WHITE CEMENT WORK FOR ROOM NO 4	Murugavel,Sankar. T. M.,Ekambaram. K.	#36 - Window glass door changed, #4 -JK white cement pointing work done, work completed		Revathy. N. - Canteen-Girls Hostel	01/08/2022
	Comp. Dt. : 15/07/2022 Status : Completed							
654	22070613	Ladies hostel Phase-II	REST TO REFIX HANGER FOR ROOM NO 53	Ekambaram. K.	Hanger fixed, work completed		Malliga. K. - Canteen-Girls Hostel	01/08/2022
	Comp. Dt. : 16/07/2022 Status : Completed							


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
655	22070630	Ladies hostel Phase-II	NEED TO REFIX HANGER FOR ROOM NO 53	Ekambaram. K.	hanger refixed, problem solved		Malliga. K. - Canteen-Girls Hostel	01/08/2022
Comp. Dt. : 19/07/2022 Status : Completed								
656	22070705	JR Quarters	NEED TO REFIX NAILS FOR ROOM NO47 & 50 + NEED REPAIRING WORK FOR COT ROOM NO 39 & WINDOW DOOR FOR 32	Sarathy. A.,Moorthy. L.,Ekambaram. K.	Cot, window door repaired and serviced, nails fixed, work completed		Virgin Mary - Canteen-Girls Hostel	01/08/2022
657	22070706	JR Quarters	NEED REPAIRING WORK FOR DUCT DOOR ROOM NO 35 & 40	Ekambaram. K.	Duct door repairing work completed		Virgin Mary - Canteen-Girls Hostel	01/08/2022
Comp. Dt. : 20/07/2022 Status : Completed								
658	22070744	JR Quarters	NEED CUPBOARD REPAIRING WORK & FIX SCREEN ROD FOR ROOM NO 32,35,40, 42, 49	Sundaramoorthy. G.	Wrong complaint		Virgin Mary - Canteen-Girls Hostel	01/08/2022
Comp. Dt. : 25/07/2022 Status : Completed								
659	22070887	LADIES HOSTEL MESS	NEED REPAIRING WORK FOR FOOD TROLLEY WHEEL & GRINDER SPARE	Sarathy. A.	Work completed.		Revathy. N. - Canteen-Girls Hostel	24/09/2022
Comp. Dt. : 29/07/2022 Status : Completed								
660	22071058	JR Quarters	NEED REPAIRING WORK FOR CUPBOARD FOR ROOM NO 35 & 40 + ADJUSTMENT FOR SCREEN ROD, CLOTH DRYING ROPE	Pachaimuthusamy. D.,Ekambaram. K.,Sundaramoorthy. G.	Door locked, Key not available		Virgin Mary - Canteen-Girls Hostel	05/08/2022
Comp. Dt. : 03/08/2022 Status : Completed								
661	22080123	Ladies hostel Phase-I	NEED CEMENT WORK FOR REFIXING SOAP STAND FOR ROOM NO 75	Murugavel	Soap stand refixed, cement packing work completed		Revathy. N. - Canteen-Girls Hostel	08/08/2022
Comp. Dt. : 04/08/2022 Status : Completed								
662	22080161	Ladies hostel Phase-I	IN ROOMNO.25 BATHROOM DOOR NEED TO BE REPAIR	Ekambaram. K.	Door refixed, problem solved		Revathy. N. - Canteen-Girls Hostel	17/08/2022
663	22080168	Ladies hostel Phase-II	in room no.81,82 screen rod need to be fix and mosquito net need to be fix	Ekambaram. K.	Mosquito net refixed, problem solved		Malliga. K. - Canteen-Girls Hostel	17/08/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 08/08/2022 Status : Completed								
664	22080250	Ladies hostel Phase-I	NEED TO REFIX MIRROR & RESTROOM NET FOR ROOM NO 40	Ekambaram. K.	Mirror fixed.		Revathy. N. - Canteen-Girls Hostel	24/09/2022
Comp. Dt. : 09/08/2022 Status : Completed								
665	22080322	Ladies hostel Phase-I	NEED TO REFIX MIRROR & NAILS 2 NOS FOR ROOM NO 13	Ekambaram. K.	Mirror fixed and work completed.		Revathy. N. - Canteen-Girls Hostel	24/09/2022
666	22080347	Ladies hostel Phase-I	NEED REPAIRING WORK FOR COT [20 NOS]	Ekambaram. K.	Painting work completed.		Revathy. N. - Canteen-Girls Hostel	24/09/2022
Comp. Dt. : 22/08/2022 Status : Completed								
667	22080689	LADIES HOSTEL MESS	NEED TO REFIX PLYWOOD SHEETS FOR GRINDER BOTTOM - DAMAGE & BROKEN	Parthiban.K.	Plywood sheet fixed, work completed		Revathy. N. - Canteen-Girls Hostel	01/09/2022
Comp. Dt. : 23/08/2022 Status : Completed								
668	22080753	Ladies hostel Phase-I	NEED TO REFIX MIRROR FOR ROOM NO 31	Ekambaram. K.	Mirror fixed, work completed		Revathy. N. - Canteen-Girls Hostel	01/09/2022
Comp. Dt. : 27/08/2022 Status : Completed								
669	22080936	Ladies hostel Phase-II	WATER LEAKAGE AT FLOOR TILES AT II FLOOR ROOM NO 66 & 67	Murugavel	Tiles refixed.		Malliga. K. - Canteen-Girls Hostel	09/09/2022
Comp. Dt. : 30/08/2022 Status : Completed								
670	22081008	Ladies hostel Phase-I	NEED WHITE CEMENT WORK FOR RESTROOM - ROOM NO 4	Murugavel	JK white applied.		Revathy. N. - Canteen-Girls Hostel	09/09/2022
Comp. Dt. : 08/09/2022 Status : Completed								
671	22090307	JR Quarters	NEED REPAIRING WORK FOR RESTROOM DOOR LOCK - DAMAGE & NOT WORKING	Venkatesan. R.	Rest room door repaired and serviced, problem solved		Virgin Mary - Canteen-Girls Hostel	28/09/2022
672	22090320	Ladies hostel Phase-II	NEED CEMENT WORK FOR CUPBOARD & DOOR NEAR FLOOR FOR ROOM NO 46 & REPAIRING WORK FOR III FLOOR RES	Murugavel	Mason work completed		Malliga. K. - Canteen-Girls Hostel	28/09/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 16/09/2022 Status : Completed								
673	22090623	Ladies hostel Phase-I	DUE TO WATER COMING INSIDE THE ROOM NEED A NEW CHAMBER FOR NEAR MAIN DOOR - ROOM NO 52	Murugavel	Masion work completed		Revathy. N. - Canteen-Girls Hostel	29/09/2022
Comp. Dt. : 19/09/2022 Status : Completed								
674	22090731	LADIES HOSTEL MESS	NEED CEMENT WORK - KITCHEN NEAR FLOOR AND OTHER SOME PLACES	Murugavel	Cement patch work completed		Revathy. N. - Canteen-Girls Hostel	29/09/2022
Comp. Dt. : 21/09/2022 Status : Completed								
675	22090838	Ladies hostel Phase-I	NEED TO CLOSE DOOR HOLE WITH CEMENT OR PLY WOOD SHEET FOR GROUND FLOOR ROOM NO 6	Murugavel	Hole closed - Cement patch work completed		Revathy. N. - Canteen-Girls Hostel	12/10/2022
Comp. Dt. : 24/09/2022 Status : Completed								
676	22090980	Ladies hostel Phase-II	NEED TO FILL WINDOW GAP WITH WOODEN OR GLASS OR CEMENT FOR III FLOOR ROOM NO 95	Murugavel	Gap filled with cement, problem solved		Malliga. K. - Canteen-Girls Hostel	08/10/2022
Comp. Dt. : 26/09/2022 Status : Completed								
677	22090997	JR Quarters	NEED REPAIRING WORK FOR CUPBOARD DOOR FOR ROOM NO 25	Ekambaram. K.	Wrong complaint		Virgin Mary - Canteen-Girls Hostel	08/10/2022
Comp. Dt. : 27/09/2022 Status : Completed								
678	22091055	Ladies hostel Phase-II	NEED REPAIRING WORK FOR TABLE AT II FLOOR T V ROOM & WINDOW DOOR FOR ROOM NO 41 + NEED TO CLOSE WIT	Ekambaram. K., Sundaramoorthy. G., Murugavel	Table and window door repaired and serviced, window gap filled, Masion work completed		Malliga. K. - Canteen-Girls Hostel	08/10/2022
Comp. Dt. : 28/09/2022 Status : Completed								
679	22091137	Ladies hostel Phase-II	NEED REPAIRING WORK FOR WINDOW DOOR - STUCK - ROOM NO 41	Ekambaram. K.	Window door repaired and serviced, problem solved		Malliga. K. - Canteen-Girls Hostel	08/10/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 29/09/2022 Status : Completed								
680	22091154	Ladies hostel Phase-II	NEED CEMENT WORK FOR FILLING WINDOW GAP - ROOM NO 101	Murugavel	Cement filled in gap, work completed		Malliga. K. - Canteen-Girls Hostel	08/10/2022
Comp. Dt. : 07/10/2022 Status : Completed								
681	22100144	JR Quarters	NEED TO REFIX PATLOCK FOR BERO	Ekambaram. K.	New padlock fixed, problem solved		Virgin Mary - Canteen-Girls Hostel	20/10/2022
Comp. Dt. : 11/10/2022 Status : Completed								
682	22100269	Ladies hostel Phase-I	DUE TO RAT PROBLEM , NEED TO CLOSE STOREROOM DOOR HOLE WITH PLYWOOD SHEET	Parthiban.K.	Hole closed, problem solved		Revathy. N. - Canteen-Girls Hostel	12/10/2022
Comp. Dt. : 18/10/2022 Status : Completed								
683	22100570	Ladies hostel Phase-I	NEED TO FIX MIRROR FOR ROOM NO 1	Ekambaram. K.	Mirror fixed.		Revathy. N. - Canteen-Girls Hostel	29/10/2022
Comp. Dt. : 28/10/2022 Status : Completed								
684	22100932	J.R Quateres	IN 4TH FLOOR-REQUEST TO FIX CUPBOARD LOCK FOR ALL ROOMS	Ekambaram. K.	Lock fixed, problem solved		Virgin Mary - Canteen-Girls Hostel	15/11/2022
Comp. Dt. : 16/11/2022 Status : Completed								
685	22110655	J.R Quateres	IN 4TH FLOOR BATHROOM DOOR -FRAME WORK NEED TO DO	Ekambaram. K.	Door repaired.		Virgin Mary - Canteen-Girls Hostel	21/11/2022
Comp. Dt. : 17/11/2022 Status : Completed								
686	22110714	Ladies hostel Phase-II	IN ROOM NO.87-DOOR INSIDE LATCH PROBLEM	Ekambaram. K.	Padlock fixed, problem solved		Malliga. K. - Canteen-Girls Hostel	01/12/2022
Comp. Dt. : 24/11/2022 Status : Completed								
687	22111031	Ladies hostel Phase-I	IN ROOM NO.26-MESH NEED TO BE FIX ON VENTILATOR	Ekambaram. K.	Ventilator mesh fixed, problem solved		Revathy. N. - Canteen-Girls Hostel	01/12/2022
Comp. Dt. : 29/11/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
688	22111239	Ladies hostel Phase-I	IN ROOM NO.30-SCREEN HANGER REFIXING WORK NEED TO DO	Ekambaram. K.	Screen rod refixed, problem solved		Revathy. N. - Canteen-Girls Hostel	06/12/2022
Comp. Dt. : 05/12/2022 Status : Completed								
689	22120152	Ladies hostel Phase-I	NEED TO FIX MIRROR FOR IV FLOOR ALL ROOMS	Ekambaram. K.	mirror fixed.		Revathy. N. - Canteen-Girls Hostel	10/12/2022
690	22120153	Ladies hostel Phase-I	NEED TO CHANGE PLY WOOD SHEET FOR MAIN DOOR	Ekambaram. K.	Plywood sheet changed.		Revathy. N. - Canteen-Girls Hostel	10/12/2022
Comp. Dt. : 12/12/2022 Status : Completed								
691	22120551	Ladies hostel Phase-II	IN ROOM NO.14 AND 19 MAIN DOOR LOCK BROKEN,NEED TO REFIX IT NEWLY	Ekambaram. K.	Lock changed, problem solved		Malliga. K. - Canteen-Girls Hostel	19/12/2022
Comp. Dt. : 13/12/2022 Status : Completed								
692	22120585	Ladies hostel Phase-II	NEED TP REFIX WINDOW VELCRO FOR ROOM NO 42	Ekambaram. K.	window velcro refixed.		Malliga. K. - Canteen-Girls Hostel	23/12/2022
Comp. Dt. : 14/12/2022 Status : Completed								
693	22120663	Ladies hostel Phase-II	NEED REPAIRING WORK FOR DOOR LOCK FOR II FLOOR RESTROOM	Ekambaram. K.	Door lock repaired.		Malliga. K. - Canteen-Girls Hostel	23/12/2022
Comp. Dt. : 15/12/2022 Status : Completed								
694	22120709	JR Quarters	TILES BROKEN NEED TOUCHUP WORK AT IV FLOOR	Murugavel	18 nos. tiles refixed, JK white applied.		Virgin Mary - Canteen-Girls Hostel	23/12/2022
Comp. Dt. : 21/12/2022 Status : Completed								
695	22120960	Ladies hostel Phase-I	NEED TO REFIX WINDOW IN GROUND FLOOR	Ekambaram. K.	Window door refixed, problem solved		Revathy. N. - Canteen-Girls Hostel	29/12/2022
Comp. Dt. : 23/12/2022 Status : Completed								
696	22121083	J.R Quateres	NEED TO FIX HEATER HOSE FOR GROUND FLOOR REST ROOM	Ganesan. A.	Wrong complaint, plumbing dept complaint, msg inform to plumbing dept		Virgin Mary - Canteen-Girls Hostel	02/01/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 19/01/2023 Status : Completed								
697	23010666	Ladies hostel Phase-II	NEED WHITE CEMENT WORK FOR ROOM NO 42 [I FLOOR]	Murugavel	JK white cement pointing work completed		Malliga. K. - Canteen-Girls Hostel	30/01/2023
Comp. Dt. : 24/01/2023 Status : Completed								
698	23010855	Ladies hostel Phase-II	NEED MATION WORK FOR GROUND FLOOR ROOM NO 5	Murugavel	Mason work completed		Malliga. K. - Canteen-Girls Hostel	30/01/2023
Comp. Dt. : 27/01/2023 Status : Completed								
699	23010968	JR Quarters	NEED REPAIRING WORK FOR III FLOOR COMMON RESTROOM	Sarathy. A.	Work completed		Virgin Mary - Canteen-Girls Hostel	30/01/2023
700	23010969	JR Quarters	NEED TO REFIX HANGER FOR IV FLOOR COMMON RESTROOM	Ekambaram. K.	hanger refixed		Virgin Mary - Canteen-Girls Hostel	30/01/2023
701	23010972	JR Quarters	NEED TO FIX WINDOW DOOR FOR ROOM NO 123	Ekambaram. K.	Window door repaired and refixed, problem solved		Virgin Mary - Canteen-Girls Hostel	30/01/2023
Comp. Dt. : 30/01/2023 Status : Completed								
702	23011043	Ladies hostel Phase-II	NEED TO FIX NAILS FOR CLOTH DRYING AT GROUND FLOOR	Ekambaram. K.	Nail fixed		Malliga. K. - Canteen-Girls Hostel	11/02/2023
Comp. Dt. : 31/01/2023 Status : Completed								
703	23011091	Ladies hostel Phase-I	NEED NEW CHAMBERS FOR COOLER FOR ALL FLOORS	Murugavel	New chambers built, work completed		Revathy. N. - Canteen-Girls Hostel	11/02/2023
Comp. Dt. : 13/02/2023 Status : Completed								
704	23020497	Ladies hostel Phase-II	NEED REPAIRING WORK FOR II FLOOR CARITOR WINDOW DOOR - NOT CLOSING PROPER	Ekambaram. K.	Window door repaired and serviced, problem solved		Malliga. K. - Canteen-Girls Hostel	17/02/2023
Comp. Dt. : 27/02/2023 Status : Completed								
705	23021010	Ladies hostel Phase-II	NEED NEW CHAMBER FIXING WORK	Murugavel	new chamber built, work completed		Malliga. K. - Canteen-Girls Hostel	04/03/2023
Comp. Dt. : 07/03/2023								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
706	23030265	JR Quarters	NEED TILES REPAIRING WORK FOR IV FLOOR RESTROOM	Parivallal. P.	TILES REFIXED.		Virgin Mary - Canteen-Girls Hostel	04/05/2023
Comp. Dt. : 08/03/2023								
Status : Completed								
707	23030311	Ladies hostel Phase-I	NEED TO CHECK ALL FLOOR COOLER CHAMBER - WATER BLOCK	Murugavel	CHAMBER CONSTRUCTED.		Revathy. N. - Canteen-Girls Hostel	14/03/2023
Comp. Dt. : 09/03/2023								
Status : Completed								
708	23030358	JR Quarters	NEED TO REFIX MOSQUITO NET FOR ROOM NO 41	Ekambaram. K.	WORK COMPLETED		Virgin Mary - Canteen-Girls Hostel	23/03/2023
709	23030361	JR Quarters	NEED REPAIRING WORK FOR IV FLOOR RESTROOM [ALL DOOR PROBLEM]	Ekambaram. K.	WORK COMPLETED		Virgin Mary - Canteen-Girls Hostel	23/03/2023
Comp. Dt. : 14/03/2023								
Status : Completed								
710	23030552	Ladies hostel Phase-I	NEED REPAIRING WORK FOR DINING HALL MAIN DOOR	Ekambaram. K.	DOOR REPAIRED.		Revathy. N. - Canteen-Girls Hostel	23/03/2023
Comp. Dt. : 16/03/2023								
Status : Completed								
711	23030669	Ladies hostel Phase-II	NEED REPAIRING WORK FOR I FLOOR RESTROOM DOOR LOCK	Ekambaram. K.	Lock fixed.		Malliga. K. - Canteen-Girls Hostel	23/03/2023
Comp. Dt. : 25/03/2023								
Status : Completed								
712	23031052	JR Quarters	NEED REPAIRING WORK FOR CUPBOARD DOOR - DAMAGE	Ekambaram. K.	DOOR FIXED.		Virgin Mary - Canteen-Girls Hostel	01/04/2023
Comp. Dt. : 27/03/2023								
Status : Completed								
713	23031112	Ladies hostel Phase-II	NEED TO REPAIRING FOR DOOR STOPER - ROOM NO 22	Ekambaram. K.	DOOR STOPPER FIXED.		Malliga. K. - Canteen-Girls Hostel	01/04/2023
714	23031135	Ladies hostel Phase-I	DUCT DOOR FOR GROUND FLOOR BROKEN & DAMAGE - NEED REPAIRING WORK - NEED URGENT SERVICE	Ekambaram. K.	DUCT DOOR REFIXED.		Revathy. N. - Canteen-Girls Hostel	01/04/2023
Comp. Dt. : 28/03/2023								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
715	23031159	Ladies hostel Phase-I	NEED TO REFIT TILES FOR RESTROOM - ROOM NO 45	Parivallal. P.	Tiles refixed, JK white cement pointing work completed		Revathy. N. - Canteen-Girls Hostel	06/04/2023
716	23031160	Ladies hostel Phase-I	NEED REPAIRING WORK FOR GROUND FLOOR WINDOW GLASS DOOR - STUCK	Ekambaram. K.	DOOR FIXED.		Revathy. N. - Canteen-Girls Hostel	05/05/2023
717	23031189	Ladies hostel Phase-II	NEED TO REFIT DOOR STOPPER ROOM NO 118	Ekambaram. K.	3Nos of door stopper fixed, problem solved		Malliga. K. - Canteen-Girls Hostel	06/04/2023
Comp. Dt. : 29/03/2023								
Status : Completed								
718	23031253	Ladies hostel Phase-II	NEED TO REFIT DOOR STOPPER FOR ROOM NO 20	Ekambaram. K.	3Nos of door stopper fixed, problem solved		Malliga. K. - Canteen-Girls Hostel	06/04/2023
Comp. Dt. : 30/03/2023								
Status : Completed								
719	23031283	JR Quarters	NEED REPAIRING WORK FOR WINDOW - STUCK ROOM NO 87	Ekambaram. K.	Wrong complaint		Virgin Mary - Canteen-Girls Hostel	06/04/2023
Comp. Dt. : 03/04/2023								
Status : Completed								
720	23040051	Ladies hostel Phase-II	NEED REPAIRING WORK FOR CUPBOARD - ROOM NO 21	Ekambaram. K.	Cupboard door fixed, work completed		Malliga. K. - Canteen-Girls Hostel	17/04/2023
721	23040058	Ladies hostel Phase-I	NEED REPAIRING WORK FOR RESTROOM DOOR - ROOM NO 18 & TV ROOM MAIN DOOR - BROKEN	Ekambaram. K.	Rest room door refixed in properly, problem solved		Revathy. N. - Canteen-Girls Hostel	17/04/2023
Comp. Dt. : 04/04/2023								
Status : Completed								
722	23040100	Ladies hostel Phase-II	NEED REPAIRING WORK FOR MAIN DOOR - SOUND & STOPPER PROBLEM ROOM NO 118	Ekambaram. K.	Door stopper changed		Malliga. K. - Canteen-Girls Hostel	17/04/2023
Comp. Dt. : 05/04/2023								
Status : Completed								
723	23040151	Ladies hostel Phase-II	NEED TO REFIX DOOR STOPPER FOR ROOM NO 117	Ekambaram. K.	New door stopper changed		Malliga. K. - Canteen-Girls Hostel	17/04/2023
Comp. Dt. : 11/04/2023								
Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
724	23040335	JR Quarters	NEED REPAIRING WORK FOR CUPBOARD - DOOR BROKEN AT ROOM NO 64	Ekambaram. K.	Door repaired and refixed, problem solved		Virgin Mary - Canteen-Girls Hostel	20/04/2023
725	23040336	JR Quarters	NEED TO REFIX SCREEN ROD & CLAMP FOR ROOM NO 64 ,66 & 72	Ekambaram. K.	Screen rod and clamp fixed, work completed		Virgin Mary - Canteen-Girls Hostel	20/04/2023
Comp. Dt. : 17/04/2023 Status : Completed								
726	23040497	JR Quarters	TILES BROKEN NEED TOUCH UP WORK - GROUND FLOOR ROOM NO 4	Parivallal. P.	TILES REFIXED		Virgin Mary - Canteen-Girls Hostel	02/05/2023
Comp. Dt. : 19/04/2023 Status : Completed								
727	23040584	Ladies hostel Phase-II	NEED CEMENT WORK & GRATING WORK FOR III FLOOR RESTROOM	Parivallal. P., Sarathy. A., Sankar. T. M.	Work completed		Malliga. K. - Canteen-Girls Hostel	05/08/2023
Comp. Dt. : 20/04/2023 Status : Completed								
728	23040639	LADIES HOSTEL- KITCHEN	NEED WELDING WORK FOR GAS STOVE BURNER 2NOS	Sarathy. A.	STOVE FRAME WELDED.		Revathy. N. - Canteen-Girls Hostel	02/05/2023
Comp. Dt. : 29/04/2023 Status : Completed								
729	23040992	JR Quarters	NEED TO FIT CLAMP FOR FAN FIXING WORK	Sarathy. A., Ekambaram. K., Sundaramoorthy. G.	Clamp fixed, problem solved		Virgin Mary - Canteen-Girls Hostel	08/05/2023
730	23041003	Ladies hostel Phase-II	NEED WHITE CEMENT WORK ROOM NO 3	Parivallal. P.	JK White cement pointing work completed		Malliga. K. - Canteen-Girls Hostel	08/05/2023
Comp. Dt. : 02/05/2023 Status : Completed								
731	23050035	JR Quarters	TILES BROKEN - NEED TOUCH UP WORK - ROOM NO 4	Parivallal. P.	2 NOS OF TILES REFIXED. JK WHITE APPLIED.		Virgin Mary - Canteen-Girls Hostel	13/05/2023
Comp. Dt. : 04/05/2023 Status : Completed								
732	23050149	JR Quarters	LOCK DAMAGE- NOT ABLE TO OPENED THE LOCK NEED TO BROKE - ROOM NO 47	Ekambaram. K.	WORK COMPLETED.		Virgin Mary - Canteen-Girls Hostel	13/05/2023
733	23050164	JR Quarters	NEED REPAIRING WORK FOR CUPBOARD DOOR - BROKEN - ROOM NO 108	Ekambaram. K.	WORK COMPLETED		Virgin Mary - Canteen-Girls Hostel	13/05/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 08/05/2023 Status : Completed								
734	23050316	Ladies hostel Phase-I	NEED REPAIRING WORK FOR MAIN DOOR HANDLE - BROKEN - ROOM NO 49	Ekambaram. K.	HANDLE FIXED		Revathy. N. - Canteen-Girls Hostel	18/05/2023
Comp. Dt. : 16/05/2023 Status : Completed								
735	23050642	Ladies hostel Phase-II	NEED TO FIX WINDOW VALCORRA FOR III FLOOR GYM	Ekambaram. K.	Window mosquito net fixed		Malliga. K. - Canteen-Girls Hostel	23/05/2023
736	23050643	Ladies hostel Phase-II	NEED REPAIRING WORK FOR DOOR LOCK ROOM NO 12	Ekambaram. K.	Door lock repaired and serviced, problem solved		Malliga. K. - Canteen-Girls Hostel	23/05/2023
Comp. Dt. : 19/05/2023 Status : Completed								
737	23050788	Ladies hostel Phase-II	NEED REPAIRING WORK FOR DOOR STOPPER - ROOM NO 118 & NEED TO REFIX SCREEN ROD FOR III FLOOR STUDY HAL	Ekambaram. K.	DOOR STOPPER FIXED.		Malliga. K. - Canteen-Girls Hostel	01/06/2023
738	23050808	JR Quarters	NEED REPAIRING WORK FOR CUPBOARD DOOR ROOM NO 108	Ekambaram. K.	CUPBOARD DOOR FIXED.		Virgin Mary - Canteen-Girls Hostel	01/06/2023
Comp. Dt. : 22/05/2023 Status : Completed								
739	23050862	JR Quarters	NEED TO REFIX NAILS & MOSQUITO MESH FOR WARDEN ROOM	Ekambaram. K.	NET FIXED.		Virgin Mary - Canteen-Girls Hostel	01/06/2023
Comp. Dt. : 24/05/2023 Status : Completed								
740	23050953	Ladies hostel Phase-I	NEED CONNECTION WORK FOR GAS STOVE AT KITCHEN	Ekambaram. K.	STOVE CONNECTION WORK COMPLETED		Revathy. N. - Canteen-Girls Hostel	03/06/2023
Comp. Dt. : 25/05/2023 Status : Completed								
741	23050991	Ladies hostel Phase-I	NEED WELDING WORK FOR KITCHEN RACK	Sarathy. A.	RACK WELDED		Revathy. N. - Canteen-Girls Hostel	03/06/2023
Comp. Dt. : 26/05/2023 Status : Completed								
742	23051052	JR Quarters	NEED REPAIRING WORK FOR RESTROOM WINDOW - DAMAGE	Ekambaram. K.	RESTROOM WINDOW REPAIRED		Virgin Mary - Canteen-Girls Hostel	03/06/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 27/05/2023 Status : Completed								
743	23051083	Main OT	STRETCHER WHEEL STUCK	Sarathy. A.	STRETCHER WHEEL REPLACED		Jayakodi. V. - Canteen-Girls Hostel	03/06/2023
Comp. Dt. : 29/05/2023 Status : Completed								
744	23051136	Ladies hostel Phase-II	NEED REPAIRING WORK FOR MAIN DOOR AT GROUND FLOOR	Ekambaram. K.	DOOR REPAIRED		Malliga. K. - Canteen-Girls Hostel	03/06/2023
Comp. Dt. : 12/06/2023 Status : Completed								
745	23060396	JR Quarters	NEED REPAIRING WORK FOR MAIN DOOR - ROOM NO 115	Ekambaram. K.	Door repaired		Virgin Mary - Canteen-Girls Hostel	20/06/2023
746	23060428	Ladies hostel Phase-II	NEED REPAIRING WORK FOR MAIN DOOR LOCK FOR ROOM NO 99	Ekambaram. K.	Door fixed		Malliga. K. - Canteen-Girls Hostel	20/06/2023
Comp. Dt. : 14/06/2023 Status : Completed								
747	23060483	Ladies hostel Phase-II	NEED REPAIRING WORK FOR MAIN DOOR - ROOM NO 110	Ekambaram. K.	Door repaired.		Malliga. K. - Canteen-Girls Hostel	27/06/2023
Comp. Dt. : 20/06/2023 Status : Completed								
748	23060703	Ladies hostel Phase-II	NEED TO REFIX DOOR STOPPER FOR ROOM NO 118 & REPAIRING WORK FOR DOOR LOCK FOR ROOM NO 99	Ekambaram. K.	Door stopper fixed.		Malliga. K. - Canteen-Girls Hostel	27/06/2023
Comp. Dt. : 24/06/2023 Status : Completed								
749	23060915	Ladies hostel Phase-II	NEED TO FILLING GAP AT III FLOOR REST ROOM DOOR & FRAME WALL - NEED CEMENT WORK	Parivallal. P.	Civil Maintenance work		Malliga. K. - Canteen-Girls Hostel	07/07/2023
Comp. Dt. : 27/06/2023 Status : Completed								
750	23061020	JR Quarters	DUE TO PIPELINE REPAIRING WORK DONE , NEED TO REFIT BROKED TILES FOR GROUND FLOOR REST ROOM	Parivallal. P.	Work completed		Virgin Mary - Canteen-Girls Hostel	08/07/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
751	23061021	JR Quarters	NEED TO FIX L CLAMP FOR CLOTH DRYING ROPE FOR BASEMENT WASHING AREA	Ekambaram. K.,Sundaramoorthy. G.,Ganesh. S.	Wrong complaint		Virgin Mary - Canteen-Girls Hostel	08/07/2023
Dept Name : CARDIOLOGY - Work Shop Comp. Dt. : 11/06/2022 Status : Completed								
752	22060427	ECHO CARDIO GRAM	NEED REPAIRING WORK FOR DOOR - SOUND PROBLEM	Ekambaram. K.,Venkatesan. R.,Pachaimuthusamy . D.	Door repaired.		Aarthi. A. - CARDIOLOGY	21/06/2022
Comp. Dt. : 21/06/2022 Status : Completed								
753	22060771	Cath Lab	NEED REPAIRING WORK FOR PATIENT STRUCTURE WHEEL - BROKENED	Sarathy. A.	Structure wheel 4Nos changed, work completed		Deva Arul Selva Sagayaraj. A. - CARDIOLOGY	01/07/2022
Comp. Dt. : 01/09/2022 Status : Completed								
754	22090013	Cath Lab	NEED TO FIX DRESS HANGER	Ekambaram. K.	Hanger fixed.		Deva Arul Selva Sagayaraj. A. - CARDIOLOGY	08/09/2022
Comp. Dt. : 12/12/2022 Status : Completed								
755	22120540	ECHO CARDIO GRAM	REVOLVING CHAIR HANDLE NEED TO BE RETIGHT	Ekambaram. K.	Chair repaired and serviced, problem solved		Ramani Palanivel.P. - CARDIOLOGY	19/12/2022
Comp. Dt. : 16/02/2023 Status : Completed								
756	23020631	ECHO CARDIO GRAM	DOOR CLOSER PROBLEM AND ONE CHAIR HANDLE SCREW PROBLEM	Ekambaram. K.	Door closer screw and chair handle screw refixed, problem solved		Ramani Palanivel.P. - CARDIOLOGY	23/02/2023
Comp. Dt. : 20/02/2023 Status : Completed								
757	23020757	ECHO CARDIO GRAM	NEED REPAIRING WORK FOR REVOLVING CHAIR HANDLE & DOOR STOPPER - DAMAGE	Ekambaram. K.	Door stopper adjusted and chair handle refixed, problem solved		Ramani Palanivel.P. - CARDIOLOGY	01/03/2023
Comp. Dt. : 02/03/2023 Status : Completed								
758	23030066	ECHO CARDIO GRAM	NEED REPAIRING WORK FOR DOOR STOPER - NOT WORKING	Ekambaram. K.	New door stopper changed, problem solved		Ramani Palanivel.P. - CARDIOLOGY	09/03/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 10/04/2023 Status : Completed								
759	23040259	General Medicine - OPD	NEED REPAIRING WORK FOR 3 FOLDER SCREEN - WHEEL STUCK - AT ECG ROOM	Ekambaram. K.	New screen wheel fixed, problem solved		Priyanka. M. - CARDIOLOGY	20/04/2023
Comp. Dt. : 03/06/2023 Status : Completed								
760	23060089	Cath Lab	NEED TO REFIX DRESS HANGER STAND	Ekambaram. K.	Wrong complaint		Deva Arul Selva Sagayaraj. A. - CARDIOLOGY	20/06/2023
Dept Name : Cardiothoracic ICU - Work Shop Comp. Dt. : 05/05/2022 Status : Completed								
761	22050149	ICU	NEED TO FIX NORCOTIC CUPBOARD	Ekambaram. K.	New Cupboard fixed, problem solved		Aswani. J. - Cardiothoracic ICU	12/05/2022
Comp. Dt. : 19/05/2022 Status : Completed								
762	22050705	CT-ICU ROOM-NEAR ORTHO OT RECOVERY ROOM	NEED TO REFIX BED SIDE RAILS - NEED URGENT SERVICE	Sarathy. A.	Bed siderails fixed, problem solved		Aswani. J. - Cardiothoracic ICU	28/05/2022
Comp. Dt. : 28/05/2022 Status : Completed								
763	22051054	CT POW -SPECIAL WARD B	NEED TO REFIX LOBBY FRAME	Ekambaram. K.	Frame fixed.		Nilavu. K. - Cardiothoracic POW	10/06/2022
764	22051056	CT POW -SPECIAL WARD B	NEED TO CHECK COT ADJUSTMENT WHEEL - WHEEL STUCK	Sarathy. A.	COT adjustment wheel welded.		Nilavu. K. - Cardiothoracic POW	10/06/2022
Comp. Dt. : 06/07/2022 Status : Completed								
765	22070221	CT-ICU ROOM-NEAR ORTHO OT RECOVERY ROOM	NEED REPAIRING WORK FOR CUPBOARD DOOR - NOT OPENED -	Parthiban.K.	Cupboard door fixed, problem solved		Sadham Husain. S. - Cardiothoracic ICU	16/07/2022
Comp. Dt. : 21/07/2022 Status : Completed								
766	22070770	CT-ICU ROOM-NEAR ORTHO OT RECOVERY ROOM	NEED REPAIRING WORK FOR CARDIAC TABLE - BROKEN	Pachaimuthusamy. D.,Ekambaram. K.,Sarathy. A.	Cot and table repairing work completed		Sadham Husain. S. - Cardiothoracic ICU	01/08/2022
Comp. Dt. : 05/10/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
767	22100051	CT-ICU ROOM-NEAR ORTHO OT RECOVERY ROOM	NEED TO REFIX CARDIAC TABLE WHEEL	Sarathy. A.	New Wheel changed, problem solved		Sadham Husain. S. - Cardiothoracic ICU	12/10/2022
Comp. Dt. :		11/11/2022						
Status :		Completed						
768	22110469	CT-ICU ROOM-NEAR ORTHO OT RECOVERY ROOM	DOOR SOUND PROBLEM	Ekambaram. K.	Door repaired and serviced, problem solved		Thamizhselvi. A. - Cardiothoracic ICU	06/12/2022
Comp. Dt. :		22/11/2022						
Status :		Completed						
769	22110947	CTVS INSIDE ORTHO OT	NEED TO REFIX COT ROD - COT BEND & DAMAGE	Sarathy. A.	Cot bend repared and serviced, problem solved		Thamizhselvi. A. - Cardiothoracic ICU	01/12/2022
Comp. Dt. :		05/12/2022						
Status :		Completed						
770	22120201	CT-ICU ROOM-NEAR ORTHO OT RECOVERY ROOM	PLYWOOD WORK NEED TO DO	Ekambaram. K.	Plywood work completed.		Sadham Husain. S. - Cardiothoracic ICU	10/12/2022
Comp. Dt. :		04/01/2023						
Status :		Completed						
771	23010135	CT-ICU ROOM-NEAR ORTHO OT RECOVERY ROOM	CARDIAC TABLE BROKEN	Ekambaram. K.	Table wheel repaired and refixed in properly, problem solved		Aswani. J. - Cardiothoracic ICU	12/01/2023
Comp. Dt. :		06/01/2023						
Status :		Completed						
772	23010265	CTVS INSIDE ORTHO OT	CARDIAC TABLE WHEEL BROKEN.REPAIR IT	Sarathy. A.	Wheel repaired.		Rajeswari. K. - Cardiothoracic ICU	11/01/2023
Comp. Dt. :		24/02/2023						
Status :		Completed						
773	23020926	CT-POST OPERATIVE WARD IN 4TH FLOOR	NEED REPAIRING WORK FOR DOOR - SOUND & BROKEN	Ekambaram. K.	Door repaired and serviced, problem solved		Rosaria Baska Rani - Cardiothoracic ICU	04/03/2023
Comp. Dt. :		25/04/2023						
Status :		Completed						
774	23040790	CT-ICU ROOM-NEAR ORTHO OT RECOVERY ROOM	NEED REPAIRING WORK FOR DOOR - SOUND PROBLEM - NEED URGENT SERVICE	Sarathy. A.	NEW DOOR CLOSED FIXED.		Aswani. J. - Cardiothoracic ICU	02/05/2023
Comp. Dt. :		18/05/2023						
Status :		Completed						


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
775	23050731	CT POW -SPECIAL WARD B	NEED REPAIRING WORK FOR COT - BEND & RAISE PROBLEM	Ekambaram. K.	COT REPAIRED. WHEEL 4 NOS. REPLACED.		Saroja. P. - Cardiothoracic ICU	01/06/2023
Dept Name : Cardiothoracic POW - Work Shop Comp. Dt. : 20/05/2022 Status : Completed								
776	22050737	CT-POST OPERATIVE WARD IN 4TH FLOOR	NEED TO REFIX COT ADJUSTMENT SCREW - SCREW BROKEN -	Ekambaram. K.	Cot screw refixed, problem solved		Jenifer Mary. P. - Cardiothoracic POW	28/05/2022
Comp. Dt. : 01/06/2022 Status : Completed								
777	22060025	CT-POST OPERATIVE WARD IN 4TH FLOOR	NEED TO REFIX X RAY LOBBY FRAME - DAMAGE	Ekambaram. K.	Xray lobby fixed.		Praveena. M. - Cardiothoracic POW	10/06/2022
Comp. Dt. : 02/06/2022 Status : Completed								
778	22060064	CT POW -SPECIAL WARD B	NEED PAINTING WORK	Manimaran. A.	Wall cleaned and painted.		Praveena. M. - Cardiothoracic POW	18/06/2022
Comp. Dt. : 11/06/2022 Status : Completed								
779	22060408	CT-POST OPERATIVE WARD IN 4TH FLOOR	DUE TO AC WATER LEAKAGE - FUNGUS FORM IN THE WALL - NEED PAINTING WORK	Manimaran. A.	fungus cleared and painted.		Praveena. M. - Cardiothoracic POW	21/06/2022
Comp. Dt. : 02/07/2022 Status : Completed								
780	22070056	CT POW -SPECIAL WARD B	NEED TO FIX MOSQUITO NET FOR WINDOWS	Ekambaram. K.	New Mosquito net fixed, problem solved		Praveena. M. - Cardiothoracic POW	20/07/2022
Comp. Dt. : 14/07/2022 Status : Completed								
781	22070535	CT POW -SPECIAL WARD B	NEED WELDING WORK FOR HYDRAULIC COT - BROKE	Sarathy. A.	Hydraulic cot welding work completed		Praveena. M. - Cardiothoracic POW	01/08/2022
782	22070547	SPECIAL WARD---B	NEED TO CHANGE NEW DOOR CLOSER	Ekambaram. K.	New door closer fixed.		Praveena. M. - Cardiothoracic POW	24/09/2022
Comp. Dt. : 20/07/2022 Status : Completed								
783	22070755	CT-POST OPERATIVE WARD IN 4TH FLOOR	NEED TO REFIX " BIO MEDICAL WASTE" NAME BOARD	Ekambaram. K.	Name board fixed, problem solved		Srimathi. V. - Cardiothoracic POW	01/08/2022
Comp. Dt. : 03/08/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
784	22080128	CT POW -SPECIAL WARD B	NEED PAINTING WORK FOR WALLS & RED LINE MARKER AT PRE POST OPP	Manimaran. A.	Work completed.		Jenifer Mary. P. - Cardiothoracic POW	24/09/2022
	Comp. Dt. : 13/10/2022							
	Status : Completed							
785	22100376	CT POW -SPECIAL WARD B	NEED TO REFIX DOOR LOCK [PATLOCK] FOR "B" WARD PRIVATE WASH ROOM	Sundaramoorthy. G.	New padlock fixed, problem solved		Jenifer Mary. P. - Cardiothoracic POW	20/10/2022
	Comp. Dt. : 15/12/2022							
	Status : Completed							
786	22120706	SPECIAL WARD---B	NEED MATION WORK FOR CARITOR WALL OPPOSITE TO NURSE'S STATION	Murugavel	Work completed.		Jenifer Mary. P. - Cardiothoracic POW	23/12/2022
	Comp. Dt. : 29/12/2022							
	Status : Completed							
787	22121324	CT-ICU ROOM-NEAR ORTHO OT RECOVERY ROOM	PATINET COT SIDE BOLT NEED TO BE RETIGHTEN	Sarathy. A.	Cot side rail fixed, problem solved		Nilavu. K. - Cardiothoracic POW	05/01/2023
	Comp. Dt. : 05/01/2023							
	Status : Completed							
788	23010195	CT POW -SPECIAL WARD B	NEED REPAIRING WORK FOR RESTROOM DOOR LOCK-BROKEN	Ekambaram. K.	Door repaired.		Srimathi. V. - Cardiothoracic POW	11/01/2023
	Comp. Dt. : 09/01/2023							
	Status : Completed							
789	23010359	CT POW -SPECIAL WARD B	FLOOR TILES BROKEN,TOUCHUP WORK NEEDED	Murugavel	Tiles refixed, JK White cement pointing work completed		Praveena. M. - Cardiothoracic POW	23/01/2023
	Comp. Dt. : 23/01/2023							
	Status : Completed							
790	23010796	CT-POST OPERATIVE WARD IN 4TH FLOOR	NEED REPAIRING WORK FOR DOOR - SOUND PROBLEM - NEED URGENT SERVICE	Ekambaram. K.	Door repaired and serviced, problem solved		Srimathi. V. - Cardiothoracic POW	16/02/2023
	Comp. Dt. : 24/01/2023							
	Status : Completed							
791	23010886	CT POW -SPECIAL WARD B	NEED REPAIRING WORK FOR DOOR & DOOR LOCK	Ekambaram. K.	Door and lock repaired and serviced		Praveena. M. - Cardiothoracic POW	16/02/2023
	Comp. Dt. : 30/01/2023							
	Status : Completed							


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
792	23011052	CTVS	NEED TO REFIX WHEEL CHAIR BELT - IV FLOOR INSIDE SPE WARD B	Sarathy. A.	Wheel chair Belt fixed, work completed		Sathiavani. A. - Cardiothoracic POW	11/02/2023
Comp. Dt. : 03/02/2023 Status : Completed								
793	23020109	CT POW -SPECIAL WARD B	NEED TO REFIX BELT FOR DRESSING TROLLEY	Sarathy. A.	Wheel chair belt refixed, problem solved		Sathiavani. A. - Cardiothoracic POW	11/02/2023
Comp. Dt. : 07/02/2023 Status : Completed								
794	23020221	CT POW -SPECIAL WARD B	NEED REPAIRING WORK FOR DOOR - SOUND PROBLEM	Ekambaram. K.	Door repaired and refixed in properly		Sathiavani. A. - Cardiothoracic POW	16/02/2023
Comp. Dt. : 14/02/2023 Status : Completed								
795	23020512	CT POW -SPECIAL WARD B	NEED TO REFIX & REPAIRING WORK FOR DOOR AND MIRROR STAND	Ekambaram. K.	Door repaired and refixed in properly		Sathiavani. A. - Cardiothoracic POW	17/02/2023
Comp. Dt. : 03/03/2023 Status : Completed								
796	23030149	CT-POST OPERATIVE WARD IN 4TH FLOOR	TILES AIR CRACK - NEED TOUCHUP WORK	Parivallal. P.	Tiles refixed, JK White cement pointing work completed		Praveena. M. - Cardiothoracic POW	09/03/2023
Comp. Dt. : 23/03/2023 Status : Completed								
797	23030944	CT-POST OPERATIVE WARD IN 4TH FLOOR	NEED TO REFIX RESTROOM MIRROR	Ekambaram. K., Sundaramoorthy. G., Pachaimuthusamy. D.	MIRROR REFIXED		Sathiavani. A. - Cardiothoracic POW	04/05/2023
Comp. Dt. : 24/04/2023 Status : Completed								
798	23040727	CTVS INSIDE ORTHO OT	NEED REPAIRING WORK FOR COT ADJUSTMENT ROD - BROKEN	Ekambaram. K.	COT REPAIRED.		Nilavu. K. - Cardiothoracic POW	02/05/2023
Comp. Dt. : 05/06/2023 Status : Completed								
799	23060135	CTVS-FEMALE PRE-OP ROOM INSIDE SPECIAL WARD B	NEED REPAIRING WORK FOR COT - BEND - INTERCOM NO 1459	Sarathy. A.	Door fixed		Sathiavani. A. - Cardiothoracic POW	20/06/2023
Dept Name : Cardiothoracic Surgery - Work Shop Comp. Dt. : 17/11/2022								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
800	22110740	CTVS-ROOM NO.225 -2ND FLOOR	DOOR NOISE PROBLEM	Ekambaram. K.	Door repaired and serviced, problem solved		Rajasekar. M. - Cardiothoracic Surgery	01/12/2022
Dept Name : Cath Lab - Work Shop								
Comp. Dt. : 06/08/2022								
Status : Completed								
801	22080237	Cath Lab	NEED TO REFIX STRUCTURE WHEEL - BROKEN	Sarathy. A.	Structure wheel changed, problem solved		Muthukumaran. S. - Cath Lab	17/08/2022
Dept Name : Civil - Execution - Work Shop								
Comp. Dt. : 20/05/2022								
Status : Completed								
802	22050739	Casualty	NEED CEILING REPAIRING WORK FOR DUTY DOCTOR'S ROOM & DRAINAGE ROOM	Murugavel	Ceiling touch up work completed		Sasikala. P. - Civil - Execution	20/07/2022
Comp. Dt. : 11/07/2022								
Status : Completed								
803	22070405	Civil - Execution	NEED REPAIRING WORK FOR ROOLER SHUTTER - STUCK	Ekambaram. K., Manivannan. A., Moorthy. L.	Shutter rework and refixed in properly, problem solved		Surendhiran. R. - Civil - Execution	20/07/2022
Comp. Dt. : 02/09/2022								
Status : Completed								
804	22090064	PICU & NICU	Need to check all the windows	Ekambaram. K.	Window checking work completed.		Praveen Kumar. K. - Civil - Execution	08/09/2022
Comp. Dt. : 08/09/2022								
Status : Completed								
805	22090316	BASEMENT	NEED A NEW CHAMBER FOR ARREST RAIN WATER AT OPPOSITE TO ELECTRICAL MAINTENANCE OFFICE ENTRANCE	Murugavel	Chamber built, work completed		Murugan. N. - Civil - Execution	28/09/2022
806	22090328	MIT College	2nd floor Robotics lab - North side damaged window frame and shutter to be rectified.	Ekambaram. K.	Window frame and shutter repaired and serviced, problem solved		Murugan. N. - Civil - Execution	28/09/2022
Comp. Dt. : 12/09/2022								
Status : Completed								
807	22090455	Civil - Maintenance	NEED REPAIRING WORK FOR "S" TYPE CHAIR	Sarathy. A.	Chair repaired, problem solved		Surendhiran. R. - Civil - Execution	28/09/2022

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHAL KUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 19/09/2022								
Status : Completed								
808	22090707	TRANSPORT DEPARTMENT IN COMMERCIAL COMPLEX	NEED REPAIRING WORK FOR PARTITION DOOR - SOUND AND CLOSING PROBLEM	Sarathy. A.	New Padlock fixed, problem solved		Surendhiran. R. - Civil - Execution	12/10/2022
Comp. Dt. : 28/10/2022								
Status : Completed								
809	22100929	COMMERCIAL BLOCK	Tiles broken at Doctors canteen area.	Murugavel	20 nos. tiles refixed. JK white applied.		Murugan.N. - Civil - Execution	03/11/2022
Comp. Dt. : 24/11/2022								
Status : Completed								
810	22111044	professor quarters	2nd floor room no.6, need to tight the window grill.	Ekambaram. K.	Grill refixed, problem solved		Rajendiran. K. - Civil - Execution	01/12/2022
Comp. Dt. : 09/01/2023								
Status : Completed								
811	23010364	CIVIL EXECUTION OFFICE	Need to repair S type chair.	Moorthy. L.	Chair repaired, problem solved		Surendhiran. R. - Civil - Execution	23/01/2023
Comp. Dt. : 11/01/2023								
Status : Completed								
812	23010485	professor quarters	Room no.6,9,10 all rooms door tower bolt to be checked.	Sarathy. A.	All room door checked, bolt refixed, problem solved		Sasikala. P. - Civil - Execution	23/01/2023
Comp. Dt. : 20/01/2023								
Status : Completed								
813	23010704	Work Shop	NEED STEEL CUTTING WORK FOR CUPBOARD	Sarathy. A.	Rod cutting work completed		Sivamurugan. M - Civil - Execution	30/01/2023
Comp. Dt. : 08/03/2023								
Status : Completed								
814	23030342	FORENSIC MEDICINE (3RD FLOOR) IN COLLEGE	NEED TO LAY TILES IN DOOR PIECE	Parivallal. P.	DOOR PIECE SKIRTING WORK DONE		Sasikala. P. - Civil - Execution	14/03/2023
815	23030343	FORENSIC MEDICINE (3RD FLOOR) IN COLLEGE	NEED TO FIX DOOR	Ekambaram. K.	DOOR PIECE SKIRTING WORK DONE.		Sasikala. P. - Civil - Execution	14/03/2023
Comp. Dt. : 28/03/2023								
Status : Completed								
816	23031193	COMMUNITY MEDICINE	NEED TO FIX DOORS IN PROPOSED DEMO ROOM	Ekambaram. K.	DOOR FIXED.		Sasikala. P. - Civil - Execution	05/05/2023
Comp. Dt. : 18/05/2023								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
817	23050755	HOSPITAL TERROUS	MID ATRIUM - DAMAGED WINDOW GLASS TO BE REPLACED	Ekambaram. K.	Work completed		Praveen Kumar. K. - Civil - Execution	05/08/2023
Comp. Dt. : 05/06/2023								
Status : Completed								
818	23060141	Casualty	NEED TO CHANGE THE DAMAGED GRANITE IN NORTH SIDE OF CASUALTY RAMP	Parivallal. P.	Cot repaired		Murugan.N. - Civil - Execution	20/06/2023
Dept Name : Civil - Maintenance - Work Shop								
Comp. Dt. : 04/05/2022								
Status : Completed								
819	22050105	Work Shop	NEED WELDING WORK FOR GARDEN INSTRUMENT & SHARPENING WORK FOR SCISSORS 4 NOS	Sarathy. A.	Garden tools sharpening work completed		Kumar. V. - Civil - Maintenance	12/05/2022
Comp. Dt. : 11/05/2022								
Status : Completed								
820	22050397	ICU	PAINTING WORK FOR TOWEEL RODS	Manimaran. A.	Towel rod painted, work completed		Prakash. V. - Civil - Maintenance	18/05/2022
Comp. Dt. : 13/05/2022								
Status : Completed								
821	22050451	Clinical Department	2NOS WASH BASIN CLAMP NEED TO BE FIX(1 CLINICAL DEPT AND ANOTHER ONE IN NEW MORTUARY)	Sarathy. A.	Clamp fixed.		Prakash. V. - Civil - Maintenance	18/06/2022
Comp. Dt. : 23/05/2022								
Status : Completed								
822	22050830	NEW STP	NEED TO FIX NAME BOARD	Pachaimuthusamy. D.	Name board fixed.		Ranganathan. K. - Civil - Maintenance	18/06/2022
Comp. Dt. : 27/05/2022								
Status : Completed								
823	22051030	MS Office	NEED POINTING WORK FOR RESTROOM [NURSE USED]	Murugavel	Restroom pointing work done.		Prakash. V. - Civil - Maintenance	10/06/2022
Comp. Dt. : 06/06/2022								
Status : Completed								
824	22060181	DIALYSIS NEW UNIT IN 1ST FLOOR	NEED POINTING WORK FOR RESTROOM	Murugavel	JK white paint work.		Prakash. V. - Civil - Maintenance	10/06/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 14/06/2022		Status : Completed						
825	22060512	OG OT	NEED POINTING WORK FOR DUTY DOCTOR'S REST ROOM [2NOS]	Murugavel	Rest room pointing work done, work completed		Prakash. V. - Civil - Maintenance	01/07/2022
Comp. Dt. : 22/06/2022		Status : Completed						
826	22060799	Boys hostel	NEED WELDING WORK FOR AURO PLANT DOOR	Sarathy. A.	Door welding work completed		Sankar. V. - Civil - Maintenance	20/07/2022
Comp. Dt. : 24/06/2022		Status : Completed						
827	22060899	Female Surgery - Ward 206	NEED MATION WORK AT OPPOSITE TO 206	Murugavel	Tiles refixed in properly, JK white cement pointing work completed		Prakash. V. - Civil - Maintenance	02/07/2022
Comp. Dt. : 28/06/2022		Status : Completed						
828	22061016	MIT College	NEED TO CONSTRUCT CHAMBERS FOR GARDEN AT MIT COLLEGE BACKSIDE	Murugavel	4 nos. chamber built		Kumar. V. - Civil - Maintenance	05/07/2022
829	22061017	Work Shop	NEED SHARPENING WORK FOR SCISSORS 4 NOS	Sarathy. A.	Scissor sharpened		Kumar. V. - Civil - Maintenance	05/07/2022
Comp. Dt. : 19/07/2022		Status : Completed						
830	22070698	OLD STP PLANT	NEED CUTTING WORK FOR PUMP BASE BOLT	Venkatesan. R.	pump base bolt removed, problem solved		Ranganathan. K. - Civil - Maintenance	01/08/2022
Comp. Dt. : 22/07/2022		Status : Completed						
831	22070830	Work Shop	NEED WELDING WORK FOR HAND SHOVEL	Ekambaram. K.	Shovel welded, work completed		Sakthivel. E. - Civil - Maintenance	05/08/2022
Comp. Dt. : 29/07/2022		Status : Completed						
832	22071079	ROAD- OUTSIDE GARDEN	NEED NEW CHAMBERS [6NOS] FOR ROAD SIDE GARDEN	Murugavel	New chamber's built, work completed		Kumar. V. - Civil - Maintenance	12/10/2022
Comp. Dt. : 01/08/2022		Status : Completed						
833	22080042	Gynac Ward	NEED TO REFIX ALUMINIUM PARTICIAN DOOR SHEETS - WARD 209 & 210	Ekambaram. K.	Wrong complaint		Jurunathan. V. - Civil Maintenance	08/08/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 17/08/2022 Status : Completed								
834	22080532	NEW STP	SLUDGE TANK AIR LINE LEAKAGING -WELDING WORK NEED TO DO	Sarathy. A.	Tank line welding work completed		Ranganathan. K. - Civil - Maintenance	25/08/2022
Comp. Dt. : 23/08/2022 Status : Completed								
835	22080781	Hospital	NEED CHAMBERS AT MIT GARDEN , MEDICAL COLLEGE & DIRECTOR QUARTERS	Murugavel	New chamber built, work completed		Kumar. V. - Civil - Maintenance	01/09/2022
Comp. Dt. : 26/08/2022 Status : Completed								
836	22080867	Work Shop	NEED WELDING WORK FOR GARDEN INSTRUMENT AXE	Sarathy. A.	AXe welded.		Kumar. V. - Civil - Maintenance	09/09/2022
837	22080908	NEW STP	NEED MATION WORK FOR PUMP BASE	Murugavel	Work completed.		Ranganathan. K. - Civil - Maintenance	09/09/2022
Comp. Dt. : 29/08/2022 Status : Completed								
838	22080986	SURGERY OT	NEED FLOOR POINTING WORK FOR DUTY DOCTOR'S ROOM	Murugavel	JK white applied.		Prakash. V. - Civil - Maintenance	09/09/2022
Comp. Dt. : 30/08/2022 Status : Completed								
839	22081027	NEW STP	NEED WELDING WORK FOR AERATION TANK AIR LINE	Sarathy. A.	Pipe welded.		Ranganathan. K. - Civil - Maintenance	09/09/2022
Comp. Dt. : 03/09/2022 Status : Completed								
840	22090132	NEW STP	NEED WELDING WORK FOR SEWAGE PUMP BASE BOLT	Sarathy. A.	Pipe welded.		Ranganathan. K. - Civil - Maintenance	08/09/2022
Comp. Dt. : 09/09/2022 Status : Completed								
841	22090349	NEW STP	FILTER FEED PUMP DELIVERY LINE LEAKAGE [M.S LINE]	Moorthy. L.	MS line welding work completed		Ranganathan. K. - Civil - Maintenance	28/09/2022
Comp. Dt. : 19/09/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
842	22090751	GARDEN STORE ROOM	NEED TO PROVIDE STEEL TOP FOR GARDEN STORE ROOM	Ekambaram. K.	New steel shed fabricated		Kumar. V. - Civil - Maintenance	15/11/2022
Comp. Dt. : 22/09/2022 Status : Completed								
843	22090868	NEW STP	NEED TO PROVIDE NEW "WASTE DRAINAGE REMOVING INSTRUMENT" [2NOS]	Moorthy. L.	Instrument 1No repaired and issued		Ranganathan. K. - Civil - Maintenance	08/10/2022
844	22090887	Boys hostel Phase-II	NEED POINTING WORK FOR III FLOOR RESTROOM	Murugavel	Rest room floor JK white cement pointing work completed		Prakash. V. - Civil - Maintenance	08/10/2022
Comp. Dt. : 27/09/2022 Status : Completed								
845	22091066	NEW STP	NEED WELDING WORK FOR CLARIFIER MACHINE MESH	Sarathy. A.	GI pipe and machine mash welding work completed		Ranganathan. K. - Civil - Maintenance	08/10/2022
Comp. Dt. : 28/09/2022 Status : Completed								
846	22091135	NEW STP	NEED WELDING WORK FOR AERATION AIR LINE	Sarathy. A.	Aeration pipe line welding work completed		Ranganathan. K. - Civil - Maintenance	08/10/2022
Comp. Dt. : 30/09/2022 Status : Completed								
847	22091213	Boys hostel P.H-III	NEED CEMENT WORK AT III FLOOR FOR PIPELINE	Murugavel	Mason work completed		Prakash. V. - Civil - Maintenance	08/10/2022
848	22091214	Boys hostel PH-I	NEED CEMENT WORK FOR ROOM NO 16	Murugavel	Mason work completed		Prakash. V. - Civil - Maintenance	08/10/2022
Comp. Dt. : 11/10/2022 Status : Completed								
849	22100286	RO Plant	NEED TO COMPLETE REMAINING REPAIRING WORK FOR WINDOW & DOOR ALSO PAINTING WORK FOR NEW R O PLANT	Manimaran. A.,Viswa. V.,Sarathy. A.	Window and door repaired and painting work completed		Gurunathan. V. - Civil - Maintenance	06/12/2022
Comp. Dt. : 18/10/2022 Status : Completed								
850	22100605	GARDEN	STOOL WELDING WORK	Sarathy. A.	Stool leg welded.		Kumar. V. - Civil - Maintenance	29/10/2022
Comp. Dt. : 27/10/2022 Status : Completed								
851	22100872	OLD STP PLANT	TROLLY WELDING WORK NEED TO DO	Sarathy. A.	Handle welded.		Kaliyamoorthy. A. - Civil - Maintenance	03/11/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 24/11/2022 Status : Completed								
852	22111034	NEW STP	AERATION AIRLINE WELDING WORK NEED TO DO	Sarathy. A.	Aeration airline welding work completed		Ranganathan. K. - Civil - Maintenance	01/12/2022
Comp. Dt. : 26/11/2022 Status : Completed								
853	22111142	ENT WARD-408	DUCT DOOR NEED TO BE OPEN	Ekambaram. K.	Door opened, work completed		Prakash. V. - Civil - Maintenance	06/12/2022
854	22111143	Paediatrics - Ward 308	DUCT DOOR NEED TO BE OPEN	Ekambaram. K.	Door opened, work completed		Prakash. V. - Civil - Maintenance	06/12/2022
855	22111144	Obstetrics - Ward 208	DUCT DOOR NEED TO BE OPEN	Ekambaram. K.	Door opened, work completed		Prakash. V. - Civil - Maintenance	06/12/2022
Comp. Dt. : 30/11/2022 Status : Completed								
856	22111282	DIRECTOR QUATERS	NEED A NEW CHAMPER FOR PIPE VALUE	Murugavel	New chamber raised, problem solved		Kumar. V. - Civil - Maintenance	19/12/2022
Comp. Dt. : 02/12/2022 Status : Completed								
857	22120096	Work Shop	NEED WELDING WORK FOR CHAMPER KEY	Sarathy. A.	Key welding work completed.		Sakthivel. E. - Civil - Maintenance	10/12/2022
Comp. Dt. : 07/12/2022 Status : Completed								
858	22120333	A.P Quateres	NEED MATION WORK FOR QUARTERS NO 12	Murugavel	Tiles refixed, JK White cement pointing work completed		Gopal. S. - Civil - Maintenance	19/12/2022
Comp. Dt. : 08/12/2022 Status : Completed								
859	22120360	NEW STP	TREATED WATER PUMP SUCTION LINE WELDING WORK NEED TO DO	Sarathy. A.	Flange welding work completed		Ranganathan. K. - Civil - Maintenance	19/12/2022
860	22120366	Paediatrics - OPD	BACKSIDE OF OPD-NEW CHAMBER BRICKS WORK NEEDED	Murugavel	Chamber raised and plastering work completed		Prakash. V. - Civil - Maintenance	19/12/2022
Comp. Dt. : 14/12/2022 Status : Completed								
861	22120642	NEW STP	NEED WELDING WORK FOR AERATION TANK AIR LINE	Sarathy. A.	Welding work completed.		Ranganathan. K. - Civil - Maintenance	23/12/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
862	22120652	GARDEN	NEED WELDING WORK FOR WASTE MATERIAL TROLLEY HANDLE	Sarathy. A.	Handle welded.		Kumar. V. - Civil - Maintenance	23/12/2022
	Comp. Dt. : 15/12/2022							
	Status : Completed							
863	22120731	Male Medical - Ward 301	NEED MASON WORK FOR RESTROOM WALL	Murugavel	Plastering work completed.		Prakash. V. - Civil - Maintenance	23/12/2022
	Comp. Dt. : 22/12/2022							
	Status : Completed							
864	22121016	NEW STP	AERATION TANK MS CHANNEL WELDING WORK	Sarathy. A.	MS Channel welded, problem solved		Ranganathan. K. - Civil - Maintenance	23/01/2023
	Comp. Dt. : 23/12/2022							
	Status : Completed							
865	22121084	OLD STP PLANT	SLUDGE REMOVAL EQUIPMENT WELDING WORK	Sarathy. A.	Welding work completed		Ranganathan. K. - Civil - Maintenance	02/01/2023
	Comp. Dt. : 27/12/2022							
	Status : Completed							
866	22121247	Male Surgery - Ward 203	IN PATIENT BATHROOM-MASON WORK NEED TO DO	Murugavel	Tiles fixed, JK white cement pointing work completed		Prakash. V. - Civil - Maintenance	05/01/2023
	Comp. Dt. : 02/01/2023							
	Status : Completed							
867	23010009	CIVIL MAINTENANCE OFFICE	WASH BASIN SINK CLAMP NEED TO BE FIX	Ekambaram. K.	Wash basin sink clamp fixed, problem solved		Gurunathan. V. - Civil - Maintenance	12/01/2023
	Comp. Dt. : 04/01/2023							
	Status : Completed							
868	23010137	GARDEN STORE ROOM	CEMENT WORK AND 2 NO'S SHEET WELDING WORK NEED TO DO	Murugavel	Mason work completed, and sheet welding work completed		Kumar. V. - Civil - Maintenance	12/01/2023
	Comp. Dt. : 09/01/2023							
	Status : Completed							
869	23010351	NEW STP	PUMP BASE CHANNEL WELDING WORK NEED TO DO	Sarathy. A.	Pump base channel welded, work completed		Ranganathan. K. - Civil - Maintenance	23/01/2023
	Comp. Dt. : 07/02/2023							
	Status : Completed							
870	23020240	Work Shop	NEED CEMENT WORK FOR FIXING WATER TANK	Murugavel	Mason work completed		Kumar. V. - Civil - Maintenance	16/02/2023

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 28/02/2023								
Status : Completed								
871	23021043	MEDICAL COLLEGE	CHAMBER MASON WORK	Murugavel	new chamber built, work completed		Prakash. V. - Civil - Maintenance	04/03/2023
872	23021089	Civil - Maintenance	SAND CUTTER WELDING WORK	Sarathy. A.	Machine welding work completed		Sakthivel. E. - Civil - Maintenance	04/03/2023
Comp. Dt. : 01/03/2023								
Status : Completed								
873	23030026	Boys hostel	NEED A NEW CHAMBER NEAR BOYS HOSTEL	Murugavel	New chamber built work completed		Kumar. V. - Civil - Maintenance	09/03/2023
Comp. Dt. : 08/03/2023								
Status : Completed								
874	23030323	Nursing College	NEED TO REFIX URINAL CLAMP 20 NOS FOR ALL FLOORS	Ekambaram. K.	WORK COMPLETED		Manikandan. S. - Civil - Maintenance	04/05/2023
Comp. Dt. : 24/03/2023								
Status : Completed								
875	23031000	NEW STP	NEED WELDING WORK FOR AIR PIPE LINE	Sarathy. A.	PIPE LINE WELDED		Ranganathan. K. - Civil - Maintenance	01/04/2023
Comp. Dt. : 10/04/2023								
Status : Completed								
876	23040266	Civil - Execution	KEY MISSING - NEED TO BROKE LOCK [2 NOS] & CHANGE NEW LOCK FOR MURUGAN SIR ROOM	Ekambaram. K.	LOCK FIXED		Lester. Rodgers - Civil - Maintenance	17/05/2023
Comp. Dt. : 06/05/2023								
Status : Completed								
877	23050233	SPECIAL WARD - A1	NEED FLOOR TILES POINTING WORK IN TOILET.	Parivallal. P.	WORK COMPLETED		Vengatesan. V. - Civil - Maintenance	13/05/2023
878	23050234	Special Ward - A	NEED TILES POINTING WORK IN TOILET.	Parivallal. P.	4 NOS OF GRILL GATE REPAIRED AND PAINTED		Vengatesan. V. - Civil - Maintenance	13/05/2023
879	23050236	DIALYSIS NEW UNIT IN 1ST FLOOR	NEED TO LAY TILES AT DIALYSIS MOTOR ROOM	Parivallal. P.	Tiles laying work completed		Vengatesan. V. - Civil - Maintenance	15/05/2023
Comp. Dt. : 09/05/2023								
Status : Completed								
880	23050344	Civil - Execution	SHUTTER DOOR STUCK	Ekambaram. K.	SHUTTER REPAIRED		Lester. Rodgers - Civil - Maintenance	18/05/2023
Comp. Dt. : 20/05/2023								
Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
881	23050831	NEW STP	NEED WELDING WORK FOR CLARIFIER MOTOR AREA M.S CHANNEL	Sarathy. A.	CHANNEL WELDED		Ranganathan. K. - Civil - Maintenance	01/06/2023
Comp. Dt. : 25/05/2023 Status : Completed								
882	23050980	Female Ortho - Ward 401	WALL AND FLOOR TILES TO BE LAID FOR FIXING NEW WASH BASIN IN PATIENT'S COMMON TOILET.	Parivallal. P.	WORK COMPLETED		Vengatesan. V. - Civil - Maintenance	03/06/2023
Comp. Dt. : 27/05/2023 Status : Completed								
883	23051086	DIALYSIS IN 2ND FLOOR	NEED TO CUT PLYWOOD IN DIALYSIS 2ND UNIT.	Ekambaram. K.	WORK COMPLETED		Vengatesan. V. - Civil - Maintenance	03/06/2023
Comp. Dt. : 03/06/2023 Status : Completed								
884	23060090	OLD STP PLANT	NEED WELDING WORK FOR WASTE METERIAL TROLLEY	Sarathy. A.	Trolly handle welded.		Ranganathan. K. - Civil - Maintenance	20/06/2023
Comp. Dt. : 13/06/2023 Status : Completed								
885	23060466	CSSD	NEED TO CUT PLUMBING LINE	Sarathy. A.	Work completed		Sivaraja. M. - Civil - Maintenance	20/06/2023
Comp. Dt. : 14/06/2023 Status : Completed								
886	23060489	G-WING SINGLE LIFT	Need to repair the door in the room near Dietry Lift	Ekambaram. K.	Door repaired.		Vengatesan. V. - Civil - Maintenance	27/06/2023
Comp. Dt. : 23/06/2023 Status : Completed								
887	23060884	Work Shop	NEED TO PROVIDE SINK CLAMP 4 NOS	Sarathy. A.,Ekambaram. K.,Sundaramoorthy. G.	4 nos of clamp issued 2' length		Manikandan. S. - Civil - Maintenance	07/07/2023
Comp. Dt. : 30/06/2023 Status : Completed								
888	23061136	HOSPITAL TERROUS	NEED TO LAY TILES AT OLD RO PLANT STEPS.	Parivallal. P.	Tiles fixed.		Gurunathan. V. - Civil - Maintenance	05/08/2023
Dept Name : Clinical Department - Work Shop Comp. Dt. : 09/05/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
889	22050302	CLINICAL DEPARTMENT IN 2ND FLOOR	DOOR PROBELM IN ROOM NO 3 [RIGHT SIDE] - NEED REPAIRING WORK	Pachaimuthusamy. D.	Door repaired and serviced, problem solved		Kheerthikaa. V. - Clinical Department	18/05/2022
Comp. Dt. :		14/05/2022						
Status :		Completed						
890	22050496	CLINICAL DEPARTMENT IN 2ND FLOOR	3RD ROOM DOOR OPEN CLOSER PROBLEM	Ekambaram. K.	Door closer serviced, door repaired and refixed, problem solved		Kheerthikaa. V. - Clinical Department	27/05/2022
Comp. Dt. :		21/05/2022						
Status :		Completed						
891	22050787	CLINICAL DEPARTMENT IN 2ND FLOOR	NEED REPAIRING WORK FOR BERO LOCKER - NOT WORKING	Ekambaram. K.	Lock repaired and serviced, problem solved		Vidhyavathi. S. - Clinical Department	28/05/2022
Comp. Dt. :		26/05/2022						
Status :		Completed						
892	22050990	CLINICAL DEPARTMENT IN 4th FLOOR	NEED TO REFIX KEY BOARD	Ekambaram. K.	Keyboard fixed.		Bhuvana.M. - Clinical Department	10/06/2022
Comp. Dt. :		31/05/2022						
Status :		Completed						
893	22051126	CLINICAL DEPARTMENT IN 3RD FLOOR	NEED REPAIRING WORK FOR DOOR - SOUND & STOPER NOT WORKING [RIGHT SIDE ROOM NO 4]	Ekambaram. K.	Door stoper fixed		Selvi. A. - Clinical Department	10/06/2022
Comp. Dt. :		06/06/2022						
Status :		Completed						
894	22060212	CLINICAL DEPARTMENT IN 4th FLOOR	TILES BROKEN IN STEPS - NEED TOUCHUP WORK	Murugavel	Tiles refixed.		Patchammal. K. - Clinical Department	10/06/2022
895	22060220	CLINICAL DEPARTMENT IN 2ND FLOOR	NEED TO REFIX DOOR STOPER FOR ROOM NO 6	Ekambaram. K.	New Door stoper refixed.		Kheerthikaa. V. - Clinical Department	10/06/2022
896	22060226	CLINICAL DEPARTMENT IN 3RD FLOOR	DUE TO DONE OF GRILL FIXING WORK NEED CEMENT WORK	Sarathy. A.,Sundaramoorthy. G.,Murugavel	Plastering work done		Selvi. A. - Clinical Department	10/06/2022
Comp. Dt. :		28/06/2022						
Status :		Completed						
897	22061027	CLINICAL DEPARTMENT IN 2ND FLOOR	NEED REPAIRING WORK FOR DOOR [LAST END DOOR]	Parthiban.K.	Door repaired		Vidhyavathi. S. - Clinical Department	05/07/2022
Comp. Dt. :		07/07/2022						
Status :		Completed						
898	22070288	CLINICAL DEPARTMENT IN 4th FLOOR	NEED TO OPEN BERO - LOCK REPAIR - NOT ABLE TO OPEN	Pachaimuthusamy. D.	Lock repaired and serviced, problem solved		Bhuvana.M. - Clinical Department	16/07/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 09/08/2022 Status : Completed								
899	22080330	CLINICAL DEPARTMENT IN 4th FLOOR	NEED TO REFIX DOOR STOPPER FOR ROOM NO 2	Ekambaram. K.	New door stopper changed, problem solved		Vimal. P. - Clinical Department	23/08/2022
Comp. Dt. : 10/08/2022 Status : Completed								
900	22080351	CLINICAL DEPARTMENT IN 2ND FLOOR	NEED TO REFIX DOOR STOPPER FOR ROOM NO 7	Parthiban.K.	New Door stopper changed, problem solved		Bhuvana.M. - Clinical Department	23/08/2022
901	22080354	CLINICAL DEPARTMENT IN 4th FLOOR	NEED REPAIRING WORK FOR REST ROOM DOOR & CHANGE DOOR FRAME - ROOM NO 5	Ekambaram. K.	Dorr refixed. work completed.		Patchammal. K. - Clinical Department	24/09/2022
902	22080356	CLINICAL DEPARTMENT IN 4th FLOOR	NEED REPAIRING WORK FOR DOOR LOCK - ROOM NO 4	Ekambaram. K.	Door lock repaired and serviced, problem solved		Bhuvana.M. - Clinical Department	23/08/2022
Comp. Dt. : 12/09/2022 Status : Completed								
903	22090429	CLINICAL DEPARTMENT IN 2ND FLOOR	TILES BROKEN - NEED TOUCHUP WORK AT LEFT SIDE SEMINOR ROOM	Murugavel	Tiles refixed, JK White cement pointing work completed		Vidhyavathi. S. - Clinical Department	28/09/2022
Comp. Dt. : 16/11/2022 Status : Completed								
904	22110675	CLINICAL DEPARTMENT IN 3RD FLOOR	IN ROOM NO.7-DOOR STOPPER NEED TO CHANGE	Ekambaram. K.	Door closed 3 nos. fixed.		Sangeetha. C. - Clinical Department	21/11/2022
Comp. Dt. : 03/01/2023 Status : Completed								
905	23010092	CLINICAL DEPARTMENT IN 2ND FLOOR	IN ROOM NO.4-DOOR STOPPER NEED TO BE REFIX TIGHTLY	Ekambaram. K.	2Nos of Door stopper fixed, problem solved		Kheerthikaa. V. - Clinical Department	12/01/2023
Comp. Dt. : 23/01/2023 Status : Completed								
906	23010800	CLINICAL DEPARTMENT IN 4th FLOOR	NEED TO CHANGE BUSH FOR ROLLING CHAIR	Sarathy. A.	Rolling chair bush fixed		Vimal. P. - Clinical Department	30/01/2023
Comp. Dt. : 11/02/2023 Status : Completed								
907	23020424	CLINICAL DEPARTMENT IN 2ND FLOOR	NEED PAINTING WORK FOR MUESIUM	Manimaran. A.,Sundaramoorthy. K.,Veerappan. D.	Wall cleaned, putty and painting work completed		Kheerthikaa. V. - Clinical Department	16/02/2023
908	23020425	CLINICAL DEPARTMENT IN 4th FLOOR	DOOR STOPPER NOT WORKING - ROOM NO 4	Ekambaram. K.	New door stopper fixed, problem solved		Vimal. P. - Clinical Department	16/02/2023
Comp. Dt. : 20/02/2023								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
909	23020768	CLINICAL DEPARTMENT IN 4th FLOOR	DOOR STOPPER NOT WORKING - ROOM NO 3 & 4	Ekambaram. K.	Door stopper changed, problem solved		Patchammal. K. - Clinical Department	01/03/2023
Comp. Dt. : 03/03/2023								
Status : Completed								
910	23030120	CLINICAL DEPARTMENT IN 3RD FLOOR	NEED REPAIRING WORK FOR DOOR DYNAMO STOPPER FOR ROOM NO3 & 4	Ekambaram. K.	Door stopper changed, work completed		Vimal. P. - Clinical Department	09/03/2023
Comp. Dt. : 09/03/2023								
Status : Completed								
911	23030363	CLINICAL DEPARTMENT IN 3RD FLOOR	NEED TO REFIX " NOTICE BOARD" ROOM NO 5 [LEFT SIDE]	Ekambaram. K.	WORK COMPLETED		Manimegalai. M. - Clinical Department	23/03/2023
Comp. Dt. : 25/05/2023								
Status : Completed								
912	23050977	CLINICAL DEPARTMENT IN 3RD FLOOR	NEED REPAIRING WORK FOR REST ROOM DOOR LOCK FOR ROOM NO 7	Ekambaram. K.	DOOR REPAIRED		Bhuvana.M. - Clinical Department	03/06/2023
Comp. Dt. : 05/06/2023								
Status : Completed								
913	23060158	CLINICAL DEPARTMENT IN 3RD FLOOR	NEED REPAIRING WORK FOR DOOR LOCK - STUCK NOT WORKING	Ekambaram. K.	Lock fixed		Selvi. A. - Clinical Department	20/06/2023
Comp. Dt. : 27/06/2023								
Status : Completed								
914	23061028	MS Office	NEED PAINTING WORK FOR M. S SIR ROOM	Manimaran. A.	Painting work completed		Hemavathi. P. - MS Office	08/07/2023
Dept Name : CLINICAL PATHOLOGY - Work Shop								
Comp. Dt. : 25/08/2022								
Status : Completed								
915	22080840	Clinical Pathology	NEED REPAIRING WORK FOR CUPBOARD DOOR	Ekambaram. K.	Cupboard door fixed.		Vinod Gnana Kumar. D. - CLINICAL PATHOLOGY	09/09/2022
Comp. Dt. : 10/12/2022								
Status : Completed								
916	22120466	Clinical Pathology	NEED REPAIRING WORK FOR TABLE DRAW - BROKEN - NED TO REFIX	Ekambaram. K.	Table draw refixed, problem solved		Vinothini. R. - CLINICAL PATHOLOGY	19/12/2022
Comp. Dt. : 01/02/2023								

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
917	23020017	Clinical Pathology	NEED TO FIX NAIL	Ekambaram. K.	Nail fixed		Vinod Gnana Kumar. D. - CLINICAL PATHOLOGY	11/02/2023
Comp. Dt. : 10/02/2023								
Status : Completed								
918	23020409	Clinical Pathology	CUPBOARD LOCK PROBLEM	Ekambaram. K.	New lock fixed		Vinod Gnana Kumar. D. - CLINICAL PATHOLOGY	16/02/2023
Comp. Dt. : 02/03/2023								
Status : Completed								
919	23030075	Clinical Pathology	NEED REPAIRING WORK FOR CUPBOARD DOOR - REPEAT COMPLAINT	Ekambaram. K.	Cupboard fixed, work completed		Vinod Gnana Kumar. D. - CLINICAL PATHOLOGY	09/03/2023
Dept Name : COMMUNITY MEDICINE - Work Shop								
Comp. Dt. : 11/04/2023								
Status : Completed								
920	23040301	COMMUNITY MEDICINE DEPT IN MEDICAL COLLEGE	NEED REPAIRING WORK FOR GLASS DOOR WINDOW - STUCK AT NAC OFFICE	Ekambaram. K.	Glass door window repaired and serviced, problem solved		Rajesh. D. - COMMUNITY MEDICINE	20/04/2023
Dept Name : Computer Department - Work Shop								
Comp. Dt. : 04/05/2022								
Status : Completed								
921	22050116	MICROBIOLOGY IN COLLEGE	NEED TO FIX SCREW FOR LCD SCREEN AT MICROBIOLOGY DEMO ROOM	Ekambaram. K.	LCD screen screw refixed, problem solved		Jayaraj. J. - Computer Department	12/05/2022
Comp. Dt. : 08/06/2022								
Status : Completed								
922	22060304	DIGITAL LAB	NEED CEMENT WORK FOR CLOSING 2 HOLES AT DIGITAL LAB	Murugavel	7nos. holes cement packed.		Raja.B - Computer Department	13/06/2022
Comp. Dt. : 09/08/2022								
Status : Completed								
923	22080307	EDP IN UNDERGROUND	NEED CUTTING WORK FOR CAMERA PLATE	Ekambaram. K.	Camera plate cutting work completed		Prakash. P. - Computer Department	23/08/2022
Comp. Dt. : 13/09/2022								
Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
924	22090487	DIGITAL LAB	NEED REPAIRING WORK FOR TABLE	Ekambaram. K.	Table leg welding work completed		Jayaraj. J. - Computer Department	28/09/2022
925	22090493*	COMMUNITY MEDICINE DEPT IN MEDICAL COLLEGE	NEED TO FIX PLYWOOD SHEET FOR FIXING STAND	Parthiban.K.	Plywood sheet fixed, problem solved		Shafiullah. R. - Computer Department	23/01/2023
Comp. Dt. : 11/10/2022 Status : Completed								
926	22100264	EDP IN UNDERGROUND	NEED TO PUT HOLE FOR COMPUTER TABLE	Sundaramoorthy. G.,Manivannan. A.,Parthiban.K.	Table - hole drilled, work completed		Raja.B - Computer Department	12/10/2022
Comp. Dt. : 08/11/2022 Status : Completed								
927	22110262	PHARMACOLOGY	NEED TO FIX CLAMP FOR LCD SCREEN AT PHARMACOLOGY CLASS ROOM 2ND FLOOR	Ekambaram. K.	Clamp fixed, problem solved		Raja.B - Computer Department	18/11/2022
Comp. Dt. : 10/11/2022 Status : Completed								
928	22110389	B.ED COLLEGE	NEED TO FIX MICAPLATE AROUND BOX	Parthiban.K.	New Mica plate fixed, work completed		Murugavel.R - Computer Department	18/11/2022
Comp. Dt. : 06/01/2023 Status : Completed								
929	23010280	DIGITAL LAB	NEED TO FIX NEW SCREEN (2003)	Manivannan. A.	Screen rod fixed.		Jayaraj. J. - Computer Department	11/01/2023
Comp. Dt. : 11/01/2023 Status : Completed								
930	23010475	EDP IN UNDERGROUND	REQUEST TO MAKE NEW CAMERA STAND	Sundaramoorthy. G.	Frame maked and given to dept		Raja.B - Computer Department	23/01/2023
931	23010479	EDP IN UNDERGROUND	REQUEST TO FIX PLYWOOD SHEET ON RACK SHELFs	Ekambaram. K.	Plywood sheet fixed, work completed		Raja.B - Computer Department	23/01/2023
Comp. Dt. : 28/02/2023 Status : Completed								
932	23021045	EDP IN UNDERGROUND	ONE CHAIR BROKEN.NEED TO REPAIR	Sarathy. A.	Chair screw refixed, problem solved		Valamburi. R. - Computer Department	04/03/2023
Comp. Dt. : 02/03/2023 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
933	23030057	EDP IN UNDERGROUND	NEED REPAIRING WORK FOR SERVER ROOM DOOR - SOUND AND DAMAGE	Ekambaram. K.	No complaints in server room door		Valamburi. R. - Computer Department	09/03/2023
Comp. Dt. : 04/03/2023 Status : Completed								
934	23030189	Boys hostel	NEED TO FIX CCTV CAMERA POST	Moorthy. L.,Murugavel,Sankar. T. M.	4Nos of New Post 10' fixed, work completed		Prakash. P. - Computer Department	09/03/2023
935	23030190	LADIES HOSTEL STREET	NEED TO FIX CCTV CAMERA POST	Moorthy. L.,Murugavel,Sankar. T. M.	4Nos of New Post 10' fixed, work completed		Prakash. P. - Computer Department	09/03/2023
Comp. Dt. : 08/03/2023 Status : Completed								
936	23030317	Boys hostel	NEED TO FIX CAMERA POST [2NOS]	Moorthy. L.	POST CONCRETE LAID		Prakash. P. - Computer Department	14/03/2023
937	23030318	LADIES HOSTEL STREET	NEED TO FIX CAMERA POST [2NOS]	Moorthy. L.	CAMER POST FIXED.		Prakash. P. - Computer Department	14/03/2023
Comp. Dt. : 15/03/2023 Status : Completed								
938	23030576	Boys hostel	NEED TO FIX CAMERA POST	Moorthy. L.	Port concrete work done.		Prakash. P. - Computer Department	23/03/2023
Comp. Dt. : 04/04/2023 Status : Completed								
939	23040087	MICROBIOLOGY IN COLLEGE	NEED TO FIX L C D PROJECTOR - SCREEN DAMAGED BY SQUIRREL AT DEMO "B"	Ekambaram. K.	Projector screen changed		Shafiullah. R. - Computer Department	17/04/2023
Comp. Dt. : 24/04/2023 Status : Completed								
940	23040730	DEAN HOUSE	NEED TO PUT A HOLE [IN WOOD] FOR NET WORK CONNECTION	Ekambaram. K.	HOLES DRILLED.		Murugavel.R - Computer Department	02/05/2023
Comp. Dt. : 15/05/2023 Status : Completed								
941	23050612	DIGITAL LAB	NEED REPAIRING WORK FOR MAIN DOOR - PROBLEM	Ekambaram. K.	Door repairing work completed		Jayaraj. J. - Computer Department	23/05/2023
Comp. Dt. : 16/05/2023 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
942	23050651	DIGITAL LAB	NEED TO REFIX & REPAIRING WORK FOR DOOR STOPPER AT DIGITAL LAB	Ekambaram. K.	Door stopper fixed, problem solved		Shafiullah. R. - Computer Department	23/05/2023
Comp. Dt. : 18/05/2023 Status : Completed								
943	23050752	EDP IN UNDERGROUND	NEED CAMERA STAND 4 NOS	Sarathy. A.	4NOS FRAME PROVIDED		Valamburi. R. - Computer Department	01/06/2023
Comp. Dt. : 19/05/2023 Status : Completed								
944	23050776	EDP IN UNDERGROUND	NEED REPAIRING WORK FOR EDP MAIN DOOR LOCK - [PARTITION DOOR]	Ekambaram. K.	WORK COMPLETED		Raja.B - Computer Department	01/06/2023
Comp. Dt. : 23/05/2023 Status : Completed								
945	23050898	Nursing Quarters	NEED DIGGING HOLES FOR FIXING CAMERA AT NURSING QUARTERS	Ekambaram. K.	WRONG COMPLAINT		Prakash. P. - Computer Department	03/06/2023
Comp. Dt. : 02/06/2023 Status : Completed								
946	23060051	boys hostel-gym	NEED REPAIRING WORK FOR GYM DOOR	Ekambaram. K.	Door closer adjusted		Selvam. D. - Computer Department	20/06/2023
Comp. Dt. : 08/06/2023 Status : Completed								
947	23060270	Work Shop	NEED PAINTING WORK FOR TOWER LEG	Manimaran. A.	Work completed		Prakash. P. - Computer Department	05/08/2023
Comp. Dt. : 10/06/2023 Status : Completed								
948	23060349	MICROBIOLOGY IN COLLEGE	NEED TO CLOSE THE WAY TO ENTER SQUIRREL ,THEY DAMAGE THE L C D PROJECTOR LINE CONNECTION AT DEMO	Ekambaram. K.	Work completed..		Shafiullah. R. - Computer Department	20/06/2023
Dept Name : COVID Control Room - Work Shop Comp. Dt. : 06/05/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
949	22050207	Casualty	WHEEL CHAIR WHEEL NOT WORKING	Sarathy. A.	Wheel chair wheel changed, problem solved		Kanimozhi. E. - EMERGENCY MEDICINE	12/05/2022
Comp. Dt. : 11/05/2022 Status : Completed								
950	22050382	Casualty	FIX ONE BOARD ON THE WALL	Ekambaram. K.,Venkatesan. R.,Pachaimuthusamy . D.	Board fixed, problem solved		Kanimozhi. E. - EMERGENCY MEDICINE	18/05/2022
Comp. Dt. : 24/05/2022 Status : Completed								
951	22050890	Casualty	NEED REPAIRING WORK FOR PATIENT STRUCTURE SIDE RAILS & WHEEL CHAIR BELT	Sarathy. A.,Moorthy. L.,Sundaramoorthy. G.	Side rail fixed.		Kanimozhi. E. - EMERGENCY MEDICINE	10/06/2022
Comp. Dt. : 27/05/2022 Status : Completed								
952	22051021	Casualty	NEED TO FIX NEW STAND [2 NOS] FOR KEEP TISSUE PAPER	Ekambaram. K.	fake complaint.		Kanimozhi. E. - EMERGENCY MEDICINE	10/06/2022
Dept Name : COVID Ward - Work Shop Comp. Dt. : 02/05/2022 Status : Completed								
953	22050026	ENT WARD-407	NEED TO REFIX NURSE'S CABIN DRAW HANDLE	Pachaimuthusamy. D.	Draw handle refixed, problem solved		Jayalakshmi. J. - ENT & Ophthal Ward	26/05/2022
Comp. Dt. : 16/05/2022 Status : Completed								
954	22050516	Female Ortho - Ward 402	NEED REPAIRING WORK FOR MONITOR TROLLEY WHEEL - BROKEN	Sarathy. A.	Trolley wheel repaired and serviced, problem solved		Girija. G. - Female Ortho Ward	27/05/2022
955	22050551	Female Ortho - Ward 401	NEED REPAIRING WORK FOR WHEEL CHAIR WHEEL - WHEEL NOT MOVING	Sarathy. A.	Wheel chair wheel changed, problem solved		Girija. G. - Female Ortho Ward	27/05/2022
956	22050560	Ophthalmology - OPD	NEED REPAIRING WORK FOR DEMO ROOM DOOR	Ekambaram. K.	Door repaired and serviced, problem solved		Jayalakshmi. J. - ENT & Ophthal Ward	27/05/2022
Comp. Dt. : 03/06/2022 Status : Completed								
957	22060097	Female Ortho - Ward 401	NEED TO REFIX SCREEN ROD	Pachaimuthusamy. D.	3m 3fold screen fixed.		Girija. G. - Female Ortho Ward	10/06/2022
958	22060126	Female Ortho - Ward 401	NEED TO REFIX BUSH FOR PATIENT STOOLS [8 NOS]	Sarathy. A.	New spring fixed.		Girija. G. - Female Ortho Ward	10/06/2022
959	22060146	Female Ortho - Ward 401	NEED TO CHANGE X RAY FRAME - DAMAGE	Pachaimuthusamy. D.	New bush fixed.		Girija. G. - Female Ortho Ward	10/06/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 09/06/2022 Status : Completed								
960	22060357	Female Ortho - Ward 402	NEED TO FIX PATLOCK FOR BERO	Ekambaram. K.	pad lock fixed.		Girija. G. - Female Ortho Ward	13/06/2022
Comp. Dt. : 10/06/2022 Status : Completed								
961	22060392	Female Ortho - Ward 401	STRECTURE WHHEL REPAIR,NEED TO BE CHNAGE	Sarathy. A.	Wheel replaced.		Girija. G. - Female Ortho Ward	21/06/2022
Comp. Dt. : 13/06/2022 Status : Completed								
962	22060463	Female Ortho - Ward 401	DUE TO WATER COMING INSIDE THE ROOM, NEED CEMENT WORK FOR RESTROOM DOOR STOP FLOOR -	Murugavel	Work completed		Girija. G. - Female Ortho Ward	21/06/2022
Comp. Dt. : 16/06/2022 Status : Completed								
963	22060605	ENT WARD-408	TILES BROKEN - NEED TOUCHUP WORK	Murugavel	20m tiles refixed and JK white paint work done		Jayalakshmi. J. - ENT & Ophthal Ward	23/06/2022
Comp. Dt. : 21/06/2022 Status : Completed								
964	22060741	Female Ortho Ward	NEED REPAIRING WORK FOR PATIENT STRUCTURE WHEEL , MEDICINE & DRESSING TROLLEY WHEEL & WHEEL CHAIR W	Sarathy. A.,Moorthy. L.,Venkatesan. R.	Structure wheel, trolley wheel and wheel chair repaired and welding work completed		Girija. G. - Female Ortho Ward	02/07/2022
965	22060742	Female Ortho Ward	NEED TO CHANGE X RAY LABBY FRAME - WARD NO 401 & 402	Pachaimuthusamy. D.	New Transparant sheet 2M fixed, work completed		Girija. G. - Female Ortho Ward	02/07/2022
Comp. Dt. : 01/07/2022 Status : Completed								
966	22070012	Female Ortho - Ward 401	NEED TO CHANGE WHEELS FOR DRESSING , MEDICINE, PATIENT STRUCTURE [10 NOS]	Sarathy. A.	5" new wheel 4Nos fixed, problem solved		Girija. G. - Female Ortho Ward	09/07/2022
Comp. Dt. : 02/07/2022 Status : Completed								
967	22070058	Female Ortho - Ward 401	TILES BROKEN - NEED TOUCHUP WORK AT ENTRANCE	Murugavel	30M Tiles refixed, JK White cement pointing work completed		Girija. G. - Female Ortho Ward	09/07/2022
Comp. Dt. : 05/07/2022								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
968	22070146	Female Ortho	NEED TO CHANGE SCREEN SPRING	Sarathy. A.	Wheel spring changed, problem solved		Girija. G. - Female Ortho Ward	16/07/2022
Comp. Dt. : 07/07/2022								
Status : Completed								
969	22070271	Female Ortho - Ward 401	PLYWOOD SHEET AND DOOR AT CARITOR - DAMAGE AND BROKENED - NEED TO CHANGE	Ekambaram. K.	Door repaired and serviced, problem solved		Girija. G. - Female Ortho Ward	16/07/2022
Dept Name : CSSD - Work Shop								
Comp. Dt. : 07/06/2022								
Status : Completed								
970	22060278	TB & Chest OPD	NEED REPAIRING WORK FOR DOOR LOCK - NOT WORKING IN HOD ROOM DOOR	Ekambaram. K.	pad lock fixed.		Jothi.R. - OPD	13/06/2022
Comp. Dt. : 09/06/2022								
Status : Completed								
971	22060345	TB & Chest OPD	NEED REPAIRING WORK FOR MAIN DOOR LOCK	Ekambaram. K.	Pad lock fixed.		Jothi.R. - OPD	13/06/2022
Comp. Dt. : 02/07/2022								
Status : Completed								
972	22070063	CSSD	NEED PAINTING WORK FOR DAMAGED CEILING WALL	Viswa. V.	Ceiling painting work completed		Pazhanivel.S. - CSSD	20/07/2022
Comp. Dt. : 06/10/2022								
Status : Completed								
973	22100108	CSSD	NEED SHARPENING WORK FOR SCISSOR [5NOS]	Sarathy. A.	Scissor sharpened, work completed		Mangalakshmi. J - CSSD	12/10/2022
Comp. Dt. : 07/10/2022								
Status : Completed								
974	22100133	CSSD	NEED TO REMOVE BOLT IN AUTOCLAVE MACHINE	Sarathy. A.	Machine bolt refixed, problem solved		Pazhanivel.S. - CSSD	12/10/2022
Comp. Dt. : 23/11/2022								
Status : Completed								
975	22110994	CSSD	REQUEST TO PUT HOLES ON 6 NO'S SILICON SHEET	Ekambaram. K.	Holes drilled, work completed		Pazhanivel.S. - CSSD	01/12/2022
Comp. Dt. : 04/03/2023								
Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
976	23030164	CSSD	NEED REPAIRING WORK FOR DRESSING ROOM DOOR LOCK - NOT WORKING	Ekambaram. K.	Door lock refixed in properly, problem solved		Vinnarasi. R - CSSD	09/03/2023
Comp. Dt. : 10/03/2023 Status : Completed								
977	23030409	CSSD	NEED CEMENT WORK FOR CEILING - DAMAGE	Murugavel	CEILING PAINTING WORK DONE		Pazhanivel.S. - CSSD	23/03/2023
978	23030410	CSSD	NEED REPAIRING WORK FOR SS BIN	Ekambaram. K.	BIN REPAIRED.		Pazhanivel.S. - CSSD	23/03/2023
Comp. Dt. : 20/03/2023 Status : Completed								
979	23030783	CSSD	TILES BROKEN - NEED TOUCHUP WORK	Parivallal. P.	Tiles refixed, JK White cement pointing work completed		Pazhanivel.S. - CSSD	31/03/2023
Comp. Dt. : 27/03/2023 Status : Completed								
980	23031110	CSSD	NEED REPAIRING WORK FOR PARTITION SHEET - DAMAGE	Ekambaram. K.,Sundaramoorthy. G.,Parthiban.K.	SHEET FIXED.		Pazhanivel.S. - CSSD	01/04/2023
Comp. Dt. : 25/05/2023 Status : Completed								
981	23050987	CSSD	NEED PAINTING WORK FOR CEILING EXPAND JOINT	Manimaran. A.	CEILING PAINTED		Pazhanivel.S. - CSSD	03/06/2023
Dept Name : Derm,Pulmo,Psych Ward - Work Shop Comp. Dt. : 13/06/2022 Status : Completed								
982	22060484	TB AND CHEST WARD-405	NEED REPAIRING WORK FOR FOWLER'S COT WHEEL - BROKENED	Sarathy. A.	4m 5" wheel fixed.		Sarathkumar. R. - Derm,Pulmo,Psych Ward	21/06/2022
Comp. Dt. : 21/06/2022 Status : Completed								
983	22060740	TB AND CHEST WARD-405	NEED REPAIRING WORK FOR MAIN DOOR FLOOR SPRING - DAMAGE AND SOUND PROBLEM	Pachaimuthusamy. D.,Ekambaram. K.,Murugavel	Door repaired and serviced, Plastering work completed		Sarathkumar. R. - Derm,Pulmo,Psych Ward	02/07/2022
984	22060761	TB AND CHEST WARD-405	NEED TO REPLACE COT WHEEL & REFIX PLAIN TABLE BUSH	Sarathy. A.	Cot wheel, plain table bush fixed, problem solved		Sarathkumar. R. - Derm,Pulmo,Psych Ward	02/07/2022
Comp. Dt. : 22/06/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
985	22060777	TB AND CHEST WARD-405	NEED CEMENT WORK FOR REMOVED DOOR WALL GAP	Murugavel	Door side wall gap cement plastering work completed		Sarathkumar. R. - Derm,Pulmo,Psych Ward	02/07/2022
	Comp. Dt. : 24/06/2022							
	Status : Completed							
986	22060902	TB AND CHEST WARD-405	NEED TO REFIX COT BUSH FOR DOCTOR'S COT	Sarathy. A.,Venkatesan. R.,Sundaramoorthy. G.	Cot bush fixed, problem solved		Sarathkumar. R. - Derm,Pulmo,Psych Ward	02/07/2022
	Comp. Dt. : 28/06/2022							
	Status : Completed							
987	22060988	TB & Chest / Psychiatry	NEED TO REFIX PATLOCK FOR DOOR WARD NO 406	Pachaimuthusamy. D.	Pad lock fixed		Ashok Kumar. S. - Derm,Pulmo,Psych Ward	05/07/2022
	Comp. Dt. : 09/07/2022							
	Status : Completed							
988	22070387	Female Surgery - Ward 205	BLOCK IN PATIENT RESTROOM	Ganesan. A.	Wrong complaint		Sarathkumar. R. - Derm,Pulmo,Psych Ward	20/07/2022
989	22070394	TB AND CHEST WARD-405	NEED TO FIX NAILS FOR FIXING WALL CLOCK	Ekambaram. K.	Wall clock nail fixed.		Sarathkumar. R. - Derm,Pulmo,Psych Ward	20/07/2022
	Comp. Dt. : 15/07/2022							
	Status : Completed							
990	22070606	PSYCHIATRY WARD	NEED TO FIX POSTERS & BANNERS AT WARD NO 405 ECG ROOM	Pachaimuthusamy. D.,Ekambaram. K.,Venkatesan. R.	Baner and posters fixed, problem solved		Sarathkumar. R. - Derm,Pulmo,Psych Ward	01/08/2022
	Comp. Dt. : 19/07/2022							
	Status : Completed							
991	22070717	PSYCHIATRY WARD	NEED TO REFIX HANDLE FOR NURSE'S CABIN DRAW	Ekambaram. K.	Draw handle refixed, problem solved		Sarathkumar. R. - Derm,Pulmo,Psych Ward	01/08/2022
	Comp. Dt. : 27/07/2022							
	Status : Completed							
992	22071031	PSYCHIATRY WARD	NEED TO REFIX SAFETY BELT FOR PATIENT STRUCTURE & WHEEL CHAIR	Sarathy. A.	Structure and wheel chair belt refixed, problem solved		Kavitha. S. - Derm,Pulmo,Psych Ward	05/08/2022
	Comp. Dt. : 01/08/2022							
	Status : Completed							
993	22080029	PSYCHIATRY WARD	NEED REPAIRING WORK FOR SLIDING DOOR AT ECG ROOM	Ekambaram. K.	Sliding door repaired and serviced, problem solved		Sarathkumar. R. - Derm,Pulmo,Psych Ward	08/08/2022

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHAL KUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 03/08/2022 Status : Completed								
994	22080110	PSYCHIATRY WARD	NEED REPAIRING WORK FOR DOOR LOCK - LOCK NOT WORKING AT ECG ROOM	Ekambaram. K.	Door lock repaired and serviced, problem solved		Ashok Kumar. S. - Derm,Pulmo,Psych Ward	08/08/2022
Comp. Dt. : 05/08/2022 Status : Completed								
995	22080214	PSYCHIATRY WARD	NEED REPAIRING WORK FOR CUPBOARD DOOR AT ECG ROOM	Parthiban.K.	Cupboard door repaired and refixed in properly, problem solved		Sarathkumar. R. - Derm,Pulmo,Psych Ward	17/08/2022
Comp. Dt. : 08/08/2022 Status : Completed								
996	22080279	PSYCHIATRY WARD	NEED REPAIRING WORK FOR ENTRANCE DOOR	Ekambaram. K.	Entrance door and cupboard door repaired and serviced, problem solved		Sarathkumar. R. - Derm,Pulmo,Psych Ward	23/08/2022
Comp. Dt. : 20/08/2022 Status : Completed								
997	22080679	PSYCHIATRY WARD	NEED TO REPLACE MIRROR	Ekambaram. K.	Mirror fixed, problem solved		Sarathkumar. R. - Derm,Pulmo,Psych Ward	25/08/2022
Comp. Dt. : 01/09/2022 Status : Completed								
998	22090023	PSYCHIATRY WARD	NEED TO REFIX WHEEL CHAIR BELT	Sarathy. A.	Wheel chair belt fixed, problem solved		Sarathkumar. R. - Derm,Pulmo,Psych Ward	15/11/2022
Comp. Dt. : 05/09/2022 Status : Completed								
999	22090166	PSYCHIATRY WARD	NEED TO REFIX TOWEL STAND HANGER & WOODEN FIRE EXTN BOARD	Ekambaram. K.	Hanger, cupboard fixed.		Sarathkumar. R. - Derm,Pulmo,Psych Ward	24/09/2022
Comp. Dt. : 08/09/2022 Status : Completed								
1000	22090315	PSYCHIATRY WARD	NEED REPAIRING WORK FOR NURSE'S CABIN DRAW - NOT CLOSING PROPER	Ekambaram. K.	Table draw repaired and refixed in properly, problem solved		Sarathkumar. R. - Derm,Pulmo,Psych Ward	28/09/2022
Comp. Dt. : 13/09/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1001	22090502	PSYCHIATRY WARD	NEED REPAIRING WORK FOR PANTRY ROOM DOOR LOCK	Ekambaram. K.	Door refixed, problem solved		Sarathkumar. R. - Derm,Pulmo,Psych Ward	28/09/2022
	Comp. Dt. : 14/09/2022							
	Status : Completed							
1002	22090539	PSYCHIATRY WARD	NEED TO REFIX COT SIDE RAILS	Sarathy. A.	Side rails fixed.		Sarathkumar. R. - Derm,Pulmo,Psych Ward	27/09/2022
	Comp. Dt. : 20/09/2022							
	Status : Completed							
1003	22090765	PSYCHIATRY WARD	NEED TO RE FIX DRAW HANDLE FOR NURSE'S CABIN & BED SIDE SAILS	Ekambaram. K.	Draw handle fixed, problem solved		Sarathkumar. R. - Derm,Pulmo,Psych Ward	29/09/2022
	Comp. Dt. : 11/10/2022							
	Status : Completed							
1004	22100263	PSYCHIATRY WARD	NEED TO REFIX HANDLE FOR NURSE'S CABIN DRAW	Ekambaram. K.	2Nos of draw handle fixed, problem solved		Sarathkumar. R. - Derm,Pulmo,Psych Ward	12/10/2022
	Comp. Dt. : 12/10/2022							
	Status : Completed							
1005	22100335	PSYCHIATRY WARD	ROOM NO 405 BUSH NEED TO BE FIXED IN STOOL	Sarathy. A.	Bush fixed, problem solved		Sarathkumar. R. - Derm,Pulmo,Psych Ward	20/10/2022
1006	22100336	PSYCHIATRY WARD	COT NOB NEED TO BE FIXED 5 NO'S	Sarathy. A.	Cot knob fixed, problem solved		Sarathkumar. R. - Derm,Pulmo,Psych Ward	20/10/2022
	Comp. Dt. : 18/10/2022							
	Status : Completed							
1007	22100563	PSYCHIATRY WARD	NEED TO REFIX POSTERS & BANNERS	Moorthy. L.	Sticker pasted.		Sarathkumar. R. - Derm,Pulmo,Psych Ward	29/10/2022
	Comp. Dt. : 22/11/2022							
	Status : Completed							
1008	22110936	PSYCHIATRY WARD	NEED REPAIRING WORK FOR SLIDING DOOR & NEED TO REFIX BUSH FOR COTS	Ekambaram. K.,Sundaramoorthy. G.,Sarathy. A.	Door repaired and serviced, problem solved		Sarathkumar. R. - Derm,Pulmo,Psych Ward	01/12/2022
1009	22110960	PSYCHIATRY WARD	NEED REPAIRING WORK FOR MAIN DOOR -SOUND PROBLEM- TILES MASHING WORK	Ekambaram. K.,Sundaramoorthy. G.,Murugavel	Steel plate fixed, mason work completed		Sarathkumar. R. - Derm,Pulmo,Psych Ward	01/12/2022
	Comp. Dt. : 01/12/2022							
	Status : Completed							


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1010	22120037	Male Psychiatry - Ward 405	NEED REPAIRING WORK FOR COT BROKEN	Sarathy. A.	cot repaired.		Sarathkumar. R. - Derm,Pulmo,Psych Ward	10/12/2022
	Comp. Dt. : 24/12/2022							
	Status : Completed							
1011	22121131	PSYCHIATRY WARD	ECT ROOM -TOWEL STAND NEED TO BE FIX	Ekambaram. K.	New Towel stand fixed, problem solved		Kavitha. S. - Derm,Pulmo,Psych Ward	02/01/2023
	Comp. Dt. : 09/01/2023							
	Status : Completed							
1012	23010344	TB AND CHEST WARD-405	EMERGENCY BOARD NEED TO BE REFIX	Ekambaram. K.	Board fixed, problem solved		Sarathkumar. R. - Derm,Pulmo,Psych Ward	23/01/2023
	Comp. Dt. : 20/01/2023							
	Status : Completed							
1013	23010691	Male Psychiatry - Ward 405	NEED TO REFIX PATLOCK [IN & OUTSIDE] FOR MAIN ENTRANCE DOOR	Ekambaram. K.	New pad lock fixed, problem solved		Sarathkumar. R. - Derm,Pulmo,Psych Ward	30/01/2023
	Comp. Dt. : 23/02/2023							
	Status : Completed							
1014	23020887	TB AND CHEST WARD-405	NEED REPAIRING WORK FOR MAIN DOOR - BROKEN	Ekambaram. K.	Main door novopan fixed		Bharathi. A - Derm,Pulmo,Psych Ward	01/03/2023
	Comp. Dt. : 28/02/2023							
	Status : Completed							
1015	23021048	TB AND CHEST WARD-405	SOME POSTER PASTING WORK	Ekambaram. K.,Sundaramoorthy. G.,Ganesh. S.	Poster fixed, work completed		Sarathkumar. R. - Derm,Pulmo,Psych Ward	04/03/2023
	Comp. Dt. : 01/03/2023							
	Status : Completed							
1016	23030006	Male Medical - Ward 303	NEED REPAIRING WORK FOR CABIN & CRASH CART - DAMAGE & BROKEN - NOT WORKING	Ekambaram. K.,Viswa. V.,Sundaramoorthy. G.	Crash cart and nurses cabin door repaired and serviced, work completed		Vijay. V. - Derm,Pulmo,Psych Ward	09/03/2023
	Comp. Dt. : 02/03/2023							
	Status : Completed							
1017	23030110	TB AND CHEST WARD-405	NEED TO REFIX PATLOCK FOR PANTRY ROOM	Ekambaram. K.	New Pad lock refixed, problem solved		Preethi. R. - Derm,Pulmo,Psych Ward	09/03/2023
	Comp. Dt. : 20/03/2023							
	Status : Completed							


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1018	23030825	Male Psychiatry - Ward 405	NEED REPAIRING WORK FOR FEMALE RESTROOM DOOR - BROKEN & DAMAGE	Ekambaram. K.	Door repaired and serviced, problem solved		Sarathkumar. R. - Derm,Pulmo,Psych Ward	31/03/2023
	Comp. Dt. : 31/03/2023 Status : Completed							
1019	23031347	Male Psychiatry - Ward 405	NEED REPAIRING WORK FOR BERO & X RAY ROOM DOOR	Ekambaram. K.	Door repaired and refixed, work completed		Sarathkumar. R. - Derm,Pulmo,Psych Ward	06/04/2023
	Comp. Dt. : 13/04/2023 Status : Completed							
1020	23040393	Male Psychiatry - Ward 405	NEED REPAIRING WORK FOR BERO & MAIN DOOR LOCK	Ekambaram. K.	Bero leg welding work completed		Sarathkumar. R. - Derm,Pulmo,Psych Ward	20/04/2023
	Comp. Dt. : 04/05/2023 Status : Completed							
1021	23050123	TB AND CHEST WARD-405	NEED REPAIRING WORK FOR MAIN GRILL GATE - ROD BROKEN	Sarathy. A.,Moorthy. L.,Parivallal. P.	Grill gate repaired and painting work completed		Preethi. R. - Derm,Pulmo,Psych Ward	15/05/2023
	Comp. Dt. : 09/05/2023 Status : Completed							
1022	23050377	Male Psychiatry - Ward 405	NEED REPAIRING WORK FOR NURSE'S CABIN DOOR - BROKEN	Ekambaram. K.,Sundaramoorthy. G.,Manivannan. A.	NURSE'S CABIN DOOR FIXED		Sarathkumar. R. - Derm,Pulmo,Psych Ward	18/05/2023
	Comp. Dt. : 29/05/2023 Status : Completed							
1023	23051143	Male Psychiatry - Ward 405	NEED TO REFIX LOCK FOR ECG SLIDING DOOR	Ekambaram. K.	SLIDING WHEEL CHANGED.		Sarathkumar. R. - Derm,Pulmo,Psych Ward	03/06/2023
	Comp. Dt. : 02/06/2023 Status : Completed							
1024	23060056	Female Psychiatry - Ward 406	TILES AIR CRACK AT DR'S ROOM & CARITOR	Parivallal. P.	38 nos of tiles refixed and JK white applied		Sarathkumar. R. - Derm,Pulmo,Psych Ward	20/06/2023
	Comp. Dt. : 06/06/2023 Status : Completed							
1025	23060188	Male Psychiatry - Ward 405	NEED TO BROKE INSIDE DOOR LOCK FOR FRONT MAIN DOOR - KEY MISSING	Ekambaram. K.	Lock opened		Prammadevan. P. - Derm,Pulmo,Psych Ward	20/06/2023
	Comp. Dt. : 20/06/2023							


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
1026	23060728	Male Psychiatry - Ward 405	NEED REPAIRING WORK FOR COT BACK REST - BROKEN	Ekambaram. K.	Back rest repaired.		Sarathkumar. R. - Derm,Pulmo,Psych Ward	27/06/2023
Dept Name : Dermatology & Vener. - Work Shop								
Comp. Dt. : 08/10/2022								
Status : Completed								
1027	22100171	DERMATOLOGY OPD	NEED PAINTING WORK (WALL WHITE WASH AND DOOR PAINTING WORK)	Manimaran. A.	Painting work completed		Jayachandran. M. - Dermatology & Vener.	15/11/2022
Comp. Dt. : 28/10/2022								
Status : Completed								
1028	22100877	Orthopaedics - OPD	NEED MAN POWER FOR CHAIR SHIFTING WORK FROM BASEMENT AUDITORIUM TO ORTHO DEMO ROOM	Ganesan. A.	Wrong complaint.		Jayachandran. M. - Dermatology & Vener.	03/11/2022
Comp. Dt. : 11/01/2023								
Status : Completed								
1029	23010432	DERMATOLOGY OPD	NAME BOARD FIXING WORK	Ekambaram. K.	Name board fixed		Jayachandran. M. - Dermatology & Vener.	23/01/2023
Comp. Dt. : 13/02/2023								
Status : Completed								
1030	23020483	DERMATOLOGY OPD	NEED TO REFIX SCREW FOR "S" TYPE CHAIR	Ganesh. S.	Chairs screw's refixed		Jayachandran. M. - Dermatology & Vener.	17/02/2023
Comp. Dt. : 06/03/2023								
Status : Completed								
1031	23030228	DERMATOLOGY OPD	NEED REPAIRING WORK FOR KEYBOARD TRAY - STUCK	Ekambaram. K.	Keyboard tray repaired and refixed in properly, problem solved		Jayachandran. M. - Dermatology & Vener.	09/03/2023
Dept Name : Dialysis - Work Shop								
Comp. Dt. : 05/05/2022								
Status : Completed								
1032	22050140	DIALYSIS IN 2ND FLOOR	NEED REPAIRING WORK FOR DOOR - SOUND PROBLEM	Pachaimuthusamy. D.	Door repairing work completed		Kayalvizhi. V. - Dialysis	12/05/2022
Comp. Dt. : 18/05/2022								
Status : Completed								
1033	22050643	DIALYSIS IN 2ND FLOOR	NEED TO CHECK CRASH CART - PROBLEM IN OPEN & CLOSE	Pachaimuthusamy. D.	Crash cart repaired and serviced, problem solved		Pravin Kumar. A. - Dialysis	28/05/2022

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHAL KUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 26/05/2022 Status : Completed								
1034	22051001	DIALYSIS IN 2ND FLOOR	NEED REPAIRING WORK FOR DOOR - SOUND PROBLEM	Ekambaram. K.	Door repaired.		Pragathi. D. - Dialysis	10/06/2022
Comp. Dt. : 30/05/2022 Status : Completed								
1035	22051085	DIALYSIS IN 2ND FLOOR	NEED TO REFIX DOOR STOPPER - NEED URGENT SERVICE	Ekambaram. K.	Door stopper fixed.		Kalaimani. P. - Dialysis	10/06/2022
Comp. Dt. : 06/06/2022 Status : Completed								
1036	22060203	DIALYSIS IN 2ND FLOOR	NEED TO REFIX SIDE RAILS SCREWS - COT RAILS NOT WORKING	Sarathy. A.	Side rails fixed.		Arthy. T. - Dialysis	10/06/2022
Comp. Dt. : 20/06/2022 Status : Completed								
1037	22060706	DIALYSIS IN 2ND FLOOR	NEED TO FIX PLYWOOD SHEET FOR COT FOOT END [2 NOS] & NEED REPAIRING WORK FOR COT WHEEL	Pachaimuthusamy. D.	2m plywood for cot foot end		Vennila. K. - Dialysis	23/06/2022
Comp. Dt. : 03/09/2022 Status : Completed								
1038	22090115	DIALYSIS NEW UNIT IN 1ST FLOOR	NEED REPAIRING WORK FOR NURSE'S CABIN TABLE DRAW	Ekambaram. K.	Drawer repaired.		Malathy. M. - Dialysis	08/09/2022
Comp. Dt. : 24/09/2022 Status : Completed								
1039	22090984	ICU	NEED REPAIR WORK FOR COT	Sarathy. A.	Cot repaired and serviced, problem solved		Piravinkumar. A. - Dialysis	08/10/2022
Comp. Dt. : 14/12/2022 Status : Completed								
1040	22120646	DIALYSIS NEW UNIT IN 1ST FLOOR	NEED TO REFIX SCREEN FOR DRESS CHANGING ROOM	Ekambaram. K.	Wrong complaint.		Sarathambal. R. - Dialysis	23/12/2022
Comp. Dt. : 15/12/2022 Status : Completed								
1041	22120712	ICU	NEED TO PROVIDE WOODEN BOXES [6 NO] TOWARDS MEIDCINES KEEP	Ekambaram. K.	New boxes 10 nos. issued.		Piravinkumar. A. - Dialysis	23/12/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 05/01/2023 Status : Completed								
1042	23010226	DIALYSIS NEW UNIT IN 1ST FLOOR	MAIN DOOR SOUND PROBLEM	Ekambaram. K.	Door serviced.		Sarathambal. R. - Dialysis	11/01/2023
Comp. Dt. : 23/01/2023 Status : Completed								
1043	23010825	ICU	NEED TO REFIX HEIGHT LEVEL FOR FOOD RACK	Ekambaram. K.	Height scale fixed		Piravinkumar. A. - Dialysis	30/01/2023
1044	23010826	ICU	NEED TO REFIX BEDSIDE STERILLIUM STAND	Ekambaram. K.	St. Stand fixed		Piravinkumar. A. - Dialysis	30/01/2023
Comp. Dt. : 12/05/2023 Status : Completed								
1045	23050492	DIALYSIS IN 2ND FLOOR	NEED REPAIRING WORK FOR DOOR - STOPPER NOT WORKING & SOUND PROBLEM	Ekambaram. K.	NEW DOOR CLOSER CHANGED		Bharathi. M. - Dialysis	18/05/2023
Comp. Dt. : 26/05/2023 Status : Completed								
1046	23051048	DIALYSIS IN 2ND FLOOR	NEED TO REMOVE NAIL FROM DOOR - DOOR DAMAGE	Ekambaram. K.	NAIL REMOVED.		Ranjitha. A - Dialysis	03/06/2023
Dept Name : Director Office - Work Shop Comp. Dt. : 10/05/2022 Status : Completed								
1047	22050336	professor quarters	NEED WELDING WORK FOR LIFT MACHINE ROOM LADDER	Sarathy. A.	Ladder welded and painted.		Mani. A. - Director Office	18/06/2022
Comp. Dt. : 01/06/2022 Status : Completed								
1048	22060028	A.P Quateres	NEED TILES PACKING WORK FOR QUARTER NO 53 & REFIX NET FOR RESTROOM VENTILATION -QUARTERS NO 55	Murugavel	10m tiles refixed.		Mani. A. - Director Office	10/06/2022
1049	22060029	professor quarters	NEED TILES PACKING WORK FOR QUARTERS NO 5	Murugavel	Plastering & tiles touch up work done		Mani. A. - Director Office	10/06/2022
Comp. Dt. : 11/06/2022 Status : Completed								
1050	22060424	professor quarters	NEED TILES PACKING WORK FOR QUARTERS NO 10	Murugavel	18m tiles refix JK white		Mani. A. - Director Office	21/06/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 25/06/2022 Status : Completed								
1051	22060934	A.P Quateres	NEED TO REFIX VENTILATION NET FOR ROOM NO 54 & 55	Ekambaram. K.	2romm ventilator mesh fixed		Mani. A. - Director Office	05/07/2022
Comp. Dt. : 15/07/2022 Status : Completed								
1052	22070595	A.P Quateres	NEED TO REFIX MOSQUITO NET FOR QUARTER NO 28 & RESTROOM FLOOR PACKING WORK FOR QUARTERS NO 41	Murugavel,Sankar. T. M.,Ekambaram. K.	Mosquito net fixed, bathroom tiles jk white cement pointing work completed		Mani. A. - Director Office	01/08/2022
Comp. Dt. : 21/07/2022 Status : Completed								
1053	22070804	A.P Quateres	NEED VENTILATION GLASS DOOR FIXING & REST ROOM FLOOR TILES PACKING WORK FOR QUARTERS NO 41	Ekambaram. K.	Door fixed, tiles packing work completed		Mani. A. - Director Office	01/08/2022
Comp. Dt. : 01/08/2022 Status : Completed								
1054	22080034	A.P Quateres	NEED REPAIRING & REFIX VENTILATION GLASS FOR QUARTERS NO 53 & KITCHEN WINDOW FOR QUARTERS NO 20 & FL	Parthiban.K.,Sundara moorthy. G.,Sarathy. A.	Ventilation glass and kitchen window glass refixed, Tiles are refixed, JK White cement pointing work		Mani. A. - Director Office	08/08/2022
Comp. Dt. : 03/09/2022 Status : Completed								
1055	22090134	A.P Quateres	NEED TO FIX RESTROOM VENTILATION NET FOR QUARTERS NO 52 & RESTROOM DOOR REPAIRING WORK FOR QUARTERS	Ekambaram. K.	Net fixed and restroom door repaired.		Mani. A. - Director Office	08/09/2022
Comp. Dt. : 06/09/2022 Status : Completed								
1056	22090251	A.P Quateres	NEED REPAIRING WORK FOR REST ROOM DOOR - DAMAGE AT QUARTERS NO 47	Ekambaram. K.	Door repaired and serviced, refixed the door in properly, problem solved		Mani. A. - Director Office	12/10/2022
Comp. Dt. : 12/09/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1057	22090437	professor quarters	NEED TERROUS AREA PLASTERING WORK & FLOOR TILES PACKING FOR QUARTERS NO 7 & 9	Murugavel	In terrace plastering work completed and Tiles refixed, JK white cement pointing work completed		Mani. A. - Director Office	12/10/2022
Comp. Dt. : 07/10/2022 Status : Completed								
1058	22100153	A.P Quateres	NEED REPAIRING WORK FOR BED ROOM WINDOW DOOR QUARTERS NO 41,53 & NEED TO REFIX NET FOR QUARTERS NO	Ekambaram. K.,Sundaramoorthy. G.,Manivannan. A.	Window door and net refixed, work completed		Mani. A. - Director Office	20/10/2022
Comp. Dt. : 12/10/2022 Status : Completed								
1059	22100358	A.P Quateres	NEED TILES PACKING FOR BED ROOM FLOOR AT QUARTERS NO 58	Murugavel	Tiles refixed, JK White cement pointing work completed		Mani. A. - Director Office	15/11/2022
Comp. Dt. : 16/11/2022 Status : Completed								
1060	22110661	A.P Quateres	IN ROOM NO.12 FLOOR TILES PACKAGING AND PLATERING WORK	Murugavel	Tiles fixed		Mani. A. - Director Office	21/11/2022
Comp. Dt. : 09/12/2022 Status : Completed								
1061	22120418	A.P Quateres	NEED PLASTERING WORK FOR RESTROOM DOOR WALL QUARTERS NO 31 & REPAIRING WORK FOR RESTROOM DOOR QUARTE	Ekambaram. K.,Sundaramoorthy. G.,Murugavel	Mason work completed		Mani. A. - Director Office	19/12/2022
Comp. Dt. : 15/12/2022 Status : Completed								
1062	22120695	A.P Quateres	NEED REPAIRING WORK FOR REST ROOM DOOR QUARTERS NO 36 & 45	Ekambaram. K.	Work completed.		Mani. A. - Director Office	23/12/2022
1063	22120696	A.P Quateres	NEED WALL PLASTERING WORK FOR RESTROOM WALL - QUARTERS NO 12	Murugavel	wall plastering work completed.		Mani. A. - Director Office	23/12/2022
Comp. Dt. : 23/12/2022 Status : Completed								
1064	22121080	A.P Quateres	TILES PACKING WORK IN ROOM NO 43	Murugavel	Tiles fixed, JK White cement pointing work completed		Mani. A. - Director Office	02/01/2023
Comp. Dt. : 30/12/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1065	22121378	DIRECTOR OFFICE-1ST FLOOR IN COLLEGE	RATS PROBLEM-REQUEST TO CLOSE UNWANTED WAYS WITH PLYWOOD SHEETS TO AVOID RATS ENTRY	Parthiban.K.,Manivanan. A.,Viswa. V.	Duct door ACP sheet fixed, work completed		Vijayalakshmi. G. D. - Director Office	05/01/2023
Comp. Dt. : 13/01/2023 Status : Completed								
1066	23010568	ASSOCIATIVE PROFESSOR QUARTERS	NEED PLASTERING & FLOOR PACKING WORK FOR REST ROOM WALL QUARTERS NO 4 & 7	Murugavel	Mason work completed		Mani. A. - Director Office	30/01/2023
Comp. Dt. : 04/03/2023 Status : Completed								
1067	23030175	A.P Quateres	NEED TO FIX VENTILATOR NET FOR QUARTERS NO 49	Ekambaram. K.	VENTILATOR NET FIXED.		Mani. A. - Director Office	04/05/2023
1068	23030176	A.P Quateres	NEED TO BE REMOVED ALL DUCT DOOR GRILLS	Ekambaram. K.	GRILL REMOVED.		Mani. A. - Director Office	04/05/2023
1069	23030177	ASSOCIATIVE PROFESSOR QUARTERS	NEED TO FIX LOCK & SCREEN FOR QUARTERS NO 1	Ekambaram. K.	Lock and screen refixed, problem solved		Mani. A. - Director Office	09/03/2023
Comp. Dt. : 10/03/2023 Status : Completed								
1070	23030427	ASSOCIATIVE PROFESSOR QUARTERS	NEED TILES PACKING WORK AT RESTROOM - QUARTERS NO 7	Parivallal. P.	SCREEN FIXED.		Mani. A. - Director Office	23/03/2023
Comp. Dt. : 14/03/2023 Status : Completed								
1071	23030525	A.P Quateres	NEED TO FIX VENTILATION GLASS & NET QUARTERS NO 23	Ekambaram. K.	VENTILATION GLASS AND NET FIXED.		Mani. A. - Director Office	04/05/2023
1072	23030526	ASSOCIATIVE PROFESSOR QUARTERS	TILES BROKEN NEED TOUCHUP WORK - QUARTERS NO 17	Parivallal. P.	WORK COMPLETED.		Mani. A. - Director Office	23/03/2023
Comp. Dt. : 16/03/2023 Status : Completed								
1073	23030646	ASSOCIATIVE PROFESSOR QUARTERS	NEED MAIN WATER LINE PLASTERING WORK	Parivallal. P.	2 bags cement used. Work competed		Mani. A. - Director Office	23/03/2023
1074	23030647	A.P Quateres	NEED REPAIRING WORK FOR DOOR FRAME - DAMAGE AT QUARTERS NO 3	Ekambaram. K.	Door frame fixed.		Mani. A. - Director Office	23/03/2023
Comp. Dt. : 22/03/2023								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
1075	23030910	ASSOCIATIVE PROFESSOR QUARTERS	NEED PACKING WORK FOR KITCHEN GRANITE QUARTERS NO 7	Parivallal. P.	sINK FIXED GRANITE NOSING WORK DONE		Mani. A. - Director Office	01/04/2023
1076	23030911	ASSOCIATIVE PROFESSOR QUARTERS	NEED TILES CHANGING WORK [6NOS] FOR BEDROOM - QUARTERS NO 6	Parivallal. P.	WORK COMPLETED		Mani. A. - Director Office	01/04/2023
Comp. Dt. : 29/03/2023								
Status : Completed								
1077	23031254	MEDICAL COLLEGE III FLOOR	TILES BROKEN NEED TOUCHUP WORK AT FEMALE COMMON LUNCH ROOM	Parivallal. P.	10Nos of tiles refixed, JK white cement pointing work completed		Bala Murugan.K. - Director Office	06/04/2023
Comp. Dt. : 17/04/2023								
Status : Completed								
1078	23040520	A.P Quateres	NEED REPAIRING WORK FOR WINDOW DOOR - QUARTERS NO 41 & 56	Ekambaram. K.	RESTROOM DOOR FIXED		Mani. A. - Director Office	02/05/2023
1079	23040521	A.P Quateres	NEED RESTROOM FLOOR TILES PACKING WORK QUARTERS NO 22	Parivallal. P.	RESTROOM DOOR FIXED		Mani. A. - Director Office	02/05/2023
Comp. Dt. : 04/05/2023								
Status : Completed								
1080	23050137	professor quarters	NEED TO FIX TILES FOR KITCHEN WALL QUARTERS NO 10	Parivallal. P.	Room fully - Tiles refixed, JK White cement pointing work completed		Mani. A. - Director Office	15/05/2023
1081	23050138	A.P Quateres	NEED REPAIRING WORK FOR WINDOW DOOR QUARTERS NO 28	Ekambaram. K.	Window door net fixed		Mani. A. - Director Office	15/05/2023
1082	23050139	A.P Quateres	NEED TO FIX NET FOR QUARTERS NO 33	Ekambaram. K.	Net fixed, work completed		Mani. A. - Director Office	15/05/2023
Comp. Dt. : 17/05/2023								
Status : Completed								
1083	23050716	A.P Quateres	NEED REPAIRING WORK FOR DOOR - QUARTERS NO 29	Ekambaram. K.	DOOR REPAIRED.		Mani. A. - Director Office	01/06/2023
Comp. Dt. : 30/05/2023								
Status : Completed								
1084	23051207	professor quarters	NEED REPAIRING WORK FOR MAIN DOOR - QUARTERS NO 4	Ekambaram. K.	Door repaired		Mani. A. - Director Office	20/06/2023
Comp. Dt. : 05/06/2023								
Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1085	23060167	A.P Quateres	NEED HALL FLOOR TILES PACKING WORK FOR QUARTERS NO 3	Parivallal. P.	Tiles refixed		Mani. A. - Director Office	20/06/2023
Comp. Dt. : 10/06/2023 Status : Completed								
1086	23060361	A.P Quateres	NEED TO CHANGE WINDOW GLASS - BROKEN AT QUARTERS NO 7 & 30	Ekambaram. K.	Glass fixedq		Mani. A. - Director Office	20/06/2023
Comp. Dt. : 27/06/2023 Status : Completed								
1087	23061006	A.P Quateres	NEED REPAIRING * NET FIXING WORK FOR MAIN DOOR - QUARTERS NO 37	Ekambaram. K.,Sundaramoorthy. G.,Ganesh. S.	Net fixed.		Mani. A. - Director Office	08/07/2023
Dept Name : Dressing - Work Shop Comp. Dt. : 24/09/2022 Status : Completed								
1088	22090975	Male Surgery	NEED TO REFIX DRESSING TROLLEY WHEEL & BERO LOCK AT MALE SURGERY WARD 201 & 202	Sarathy. A.	New wheel changed, problem solved		Dhachinamoorthy.R. - Dressing	08/10/2022
Comp. Dt. : 14/10/2022 Status : Completed								
1089	22100470	CSSD	NEED TO REFIX BUSH [120 NOS] FOR TABLE , STOOL & OTHER'S	Sarathy. A.	120 Nos of bush fixed, work completed		Shankar. A. - Dressing	21/10/2022
Comp. Dt. : 03/03/2023 Status : Completed								
1090	23030129	Male Surgery - Ward 201	NEED REPAIRING WORK FOR TROLLEY WHEEL	Ekambaram. K.	Trolley wheel changed, problem solved		Dhachinamoorthy.R. - Dressing	09/03/2023
Dept Name : Electrical Maintenance - Work Shop Comp. Dt. : 21/05/2022 Status : Completed								
1091	22050782	BASEMENT AUDITORIUM	NEED TO REFIT BANNER FRAME - FRAME BROKEND	Pachaimuthusamy. D.	New banner frame maked.		Azhagappan. J. - Electrical Maintenance	18/06/2022
Comp. Dt. : 24/05/2022 Status : Completed								
1092	22050849	TRANSFORMER YARD	NEED WELDING WORK FOR STREET LIGHT BASE	Moorthy. L.	Base welded		Yathianathan.M - Electrical Maintenance	18/06/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 20/06/2022 Status : Completed								
1093	22060730	POWER ROOM NEAR RADIOLOGY	NEED CUTTING WORK FOR ELECTRICAL WORKING TABLE	Ekambaram. K.	work completed		Vaithianathan.M - Electrical Maintenance	23/06/2022
Comp. Dt. : 04/08/2022 Status : Completed								
1094	22080180	Lift Head Room-A wing	NEED MAINDOOR MAINTANANCE WORK & PAINTING FOR FIFT NI 3 & 4 - NEED URGENT SERVICE	Manimaran. A.	Painting work completed		Vaithianathan.M - Electrical Maintenance	15/11/2022
Comp. Dt. : 19/09/2022 Status : Completed								
1095	22090700	Hospital D-Wing Ground floor	NEED CEMENT WORK FOR FILLING LIGHT FITTING BOX [CONCEAL & SURFACECONDUITS FOR 11 NOS]	Parthiban.K.,Viswa. V.,Manivannan. A.	Box fixed, problem solved		Vaithianathan.M - Electrical Maintenance	29/09/2022
Comp. Dt. : 27/10/2022 Status : Completed								
1096	22100857	CT Scan	CT MACHINE STAND -ALTERATION WORK NEED TO DO	Moorthy. L.	CT machine stand leg welded, problem solved		Azhagappan. J. - Electrical Maintenance	08/11/2022
1097	22100871	Electrical Maintenance	ELECTRICAL VEHICLE WELDING WORK NEED TO DO	Sarathy. A.	Stand leg welded.		Sathishkumar. R. - Electrical Maintenance	03/11/2022
Comp. Dt. : 08/11/2022 Status : Completed								
1098	22110263	CT Scan	REMOVE THE DOOR FROM CT SCAN ROOM BASEMENT AREA	Ekambaram. K.	Door removed, work completed		Vaithianathan.M - Electrical Maintenance	18/11/2022
Comp. Dt. : 09/11/2022 Status : Completed								
1099	22110347	CT Scan	IN UPS ROOM-CABLE TRAY VALVE HOLES NEED TO BE CLOSE	Ekambaram. K.	Holes closed, problem solved		Vaithianathan.M - Electrical Maintenance	18/11/2022
Comp. Dt. : 22/11/2022 Status : Completed								
1100	22110903	Paediatrics Ward	FOR FIRE WORK PURPOSE -NEED TO OPEN GRILL GLASS & WINDOW GLASS AT WARD NO 309 & 310	Ekambaram. K.	Grill removed, work completed		Vaithianathan.M - Electrical Maintenance	01/12/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 07/12/2022								
Status : Completed								
1101	22120304	SPECIAL WARD A1-FOURTH FLOOR	FALSE CEILING LIGHTS ARE DISCONNECTED,NOW HOLES TO BE RECLOSE	Pachaimuthusamy. D.	Holes closed, work completed		Vaithianathan.M - Electrical Maintenance	19/12/2022
1102	22120305	SPECIAL WARD A THIRD FLOOR	FALSE CEILING LIGHTS ARE DISCONNECTED,NOW HOLES TO BE RECLOSE	Pachaimuthusamy. D.	Holes closed, work completed		Vaithianathan.M - Electrical Maintenance	19/12/2022
1103	22120306	CT-ICU ROOM-NEAR ORTHO OT RECOVERY ROOM	FALSE CEILING LIGHTS ARE DISCONNECTED,NOW HOLES TO BE RECLOSE	Pachaimuthusamy. D.	Holes closed, work completed		Vaithianathan.M - Electrical Maintenance	19/12/2022
1104	22120307	General Medicine - OPD	FALSE CEILING LIGHTS ARE DISCONNECTED,NOW HOLES TO BE RECLOSE	Pachaimuthusamy. D.	Holes closed, work completed		Vaithianathan.M - Electrical Maintenance	19/12/2022
Comp. Dt. : 27/12/2022								
Status : Completed								
1105	22121245	HOSPITAL TERROUS	NEED TO DO PAINTING WORK ON FIRE PIPELINE	Manimaran. A.	Fire pipe line painting work completed		Vaithianathan.M - Electrical Maintenance	16/02/2023
Comp. Dt. : 19/01/2023								
Status : Completed								
1106	23010661	Electrical Maintenance	NEED REPAIRING & WELDING WORK FOR " GOD PERUMAL PICTURE FRAME"	Sarathy. A.	New frame fixed, problem solved		Vaithianathan.M - Electrical Maintenance	30/01/2023
Comp. Dt. : 28/01/2023								
Status : Completed								
1107	23011009	PHYSIOTHERAPY ROOM IN 4TH FLOOR	NEED HOLE SAW CUTER MACHINE WORK	Sarathy. A.	Wrong complaint		Vaithianathan.M - Electrical Maintenance	30/01/2023
Comp. Dt. : 30/01/2023								
Status : Completed								
1108	23011075	General Stores[Linen]	NEED TO PUT PARTITION HOLES AT GENERAL STORE	Ekambaram. K.	Holes drilled, work completed		Azhagappan. J. - Electrical Maintenance	11/02/2023
Comp. Dt. : 07/02/2023								
Status : Completed								
1109	23020223	TRANSFORMER YARD	NEED WELDING & REFIX SHEETS	Sarathy. A.,Moorthy. L.,Venkatesan. R.	Sheet's fixed, work completed		Vaithianathan.M - Electrical Maintenance	16/02/2023
Comp. Dt. : 28/02/2023								
Status : Completed								
1110	23021053	TRANSFORMER YARD	HT PANEL SHED SIDE CLOSING WORK	Ekambaram. K.	Shed closing work completed		Vaithianathan.M - Electrical Maintenance	04/03/2023
1111	23021054	TRANSFORMER YARD	DIESEL BARREL SHED- -NEED TO CLOSED	Ekambaram. K.	Shed closing work completed		Vaithianathan.M - Electrical Maintenance	04/03/2023

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 22/04/2023 Status : Completed								
1112	23040713	BASEMENT AUDITORIUM	NEED PLYWOOD CUTTING WORK - NEED URGENT SERVICE	Ekambaram. K.	PLYWOOD CUTTING WORK COMPLETED	Q	Manimaran. M. - Electrical Maintenance	02/05/2023
Comp. Dt. : 24/04/2023 Status : Completed								
1113	23040744	HOSPITAL TERROUS	GRANITE BROKEN AT LIFT NO 5 AT TERROUS	Parivallal. P.	WORK COMPLETED.		Vaithianathan.M - Electrical Maintenance	02/05/2023
Comp. Dt. : 03/05/2023 Status : Completed								
1114	23050088	LIFT 3 AND 4 HEAD ROOM	NEED REPAIRING WORK FOR LIFT 3 AND 4 HEAD POWER ROOM DOOR - DAMAGE & BROKEN AT HOSPITAL TERROUS	Sarathy. A.	Door welding work completed		Vaithianathan.M - Electrical Maintenance	15/05/2023
Comp. Dt. : 23/05/2023 Status : Completed								
1115	23050936	HOSPITAL TERROUS	NEED TO CHECK CHANGE GRANITE AT HOSPITAL TERROUS - NEAR LIFT NEED URGENT SERVICE & EMERGENCY	Parivallal. P.	WORK COMPLETED		Angappan. A. - Electrical Maintenance	03/06/2023
Comp. Dt. : 05/06/2023 Status : Completed								
1116	23060168	Electrical Maintenance	NEED PAINTING WORK FOR EXHAUST FAN MOTOR - NEED URGENT SERVICE	Manimaran. A.	Fan motor painted..		Manimaran. M. - Electrical Maintenance	20/06/2023
Comp. Dt. : 17/06/2023 Status : Completed								
1117	23060620	Male Medical - Ward 301	TILES AIR CRACK - NEED TOUCH UP WORK AT OPP WARD NO 301 CARITOR	Parivallal. P.	10 nos. tiles touch up work done.		Angappan. A. - Electrical Maintenance	27/06/2023
1118	23060628	Electrical Maintenance	NEED WELDING WORK FOR GENERATOR SILENCER PIPE HOLES - MOST URGENT	Sarathy. A.	3'x3' sheet fixed and welded		Vaithianathan.M - Electrical Maintenance	27/06/2023
Comp. Dt. : 19/06/2023 Status : Completed								
1119	23060676	BASEMENT AUDITORIUM	NEED REPAIRING WORK FOR MAIN DOOR - SCREW AND REFIXING WORK NEED	Ekambaram. K.	Door repaired.		Vaithianathan.M - Electrical Maintenance	27/06/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1120	23060687	Work Shop	NEED WELDING WORK FOR FAN ROD	Sarathy. A.	Rod welded.		Senthil Murugan. A. - Electrical Maintenance	27/06/2023
Dept Name : EMERGENCY MEDICINE - Work Shop Comp. Dt. : 26/05/2022 Status : Completed								
1121	22050970	Casualty	NEED TO REFIX WHEEL FOR CARDIAC TABLE - BROKENED	Sarathy. A.	Wheel fixed.		Rajipriya. K. - EMERGENCY MEDICINE	10/06/2022
Comp. Dt. : 02/06/2022 Status : Completed								
1122	22060060	Casualty	NEED PAINTING WORK FOR CUPBOARD	Manimaran. A.	Cup board painted.		Bhuvaneswari. M. - ENT & Ophthal Ward	10/06/2022
Comp. Dt. : 15/06/2022 Status : Completed								
1123	22060549	Casualty	NEED TO REFIX WHEEL CHAIR BELT	Sarathy. A.	Wheel belt fixed, problem solved		Bhuvaneswari. M. - ENT & Ophthal Ward	20/07/2022
Comp. Dt. : 18/06/2022 Status : Completed								
1124	22060678	Casualty	NEED TO REFIX PATIENT STRUCTURE SIDE RAILS	Sarathy. A.	Side rail fixed		Kanimozhi. E. - EMERGENCY MEDICINE	23/06/2022
Comp. Dt. : 24/06/2022 Status : Completed								
1125	22060896	Female Casulaty	NEED TO REFIX SUCTION - SCREW UNFIXED	Ekambaram. K.,Venkatesan. R.,Manivannan. A.	Suction screw refixed, problem solved		Vinasri. R. - EMERGENCY MEDICINE	02/07/2022
Comp. Dt. : 29/06/2022 Status : Completed								
1126	22061055	Casualty	NEED REPAIRING WORK FOR COT - BROKENED	Sarathy. A.	cot repaired and wheel replaced		Kanimozhi. E. - EMERGENCY MEDICINE	05/07/2022
Comp. Dt. : 30/06/2022 Status : Completed								
1127	22061117	Casualty	NEED TO REFIX SCREEN ROD	Ekambaram. K.	Screen Rod fixed		Kanimozhi. E. - EMERGENCY MEDICINE	05/07/2022
Comp. Dt. : 05/07/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1128	22070150	Casualty	NEED PAINTING WORK FOR LOCKERS	Moorthy. L.	Locker painting work completed		Kanimozhi. E. - EMERGENCY MEDICINE	16/07/2022
Comp. Dt. : 06/07/2022 Status : Completed								
1129	22070196	ENT WARD-407	NEED WELDING WORK FOR CT JAR FORCEPS	Sarathy. A.	Jar welding work completed		Bhuvaneswari. M. - ENT & Ophthal Ward	16/07/2022
1130	22070207	Casualty	NEED REPAIRING WORK FOR COT [2NOS]	Sarathy. A.	Cot 2Nos repaired and serviced, problem solved		Kanimozhi. E. - EMERGENCY MEDICINE	16/07/2022
Comp. Dt. : 08/07/2022 Status : Completed								
1131	22070318	Female Casulaty	NEED TO FIX NET , REPAIRING WORK FOR WINDOW & DOOR FOR DUTY DOCTOR'S ROOM	Pachaimuthusamy. D.	Window and door repaired and serviced, net fixed, problem solved		Kanimozhi. E. - EMERGENCY MEDICINE	16/07/2022
1132	22070320	Female Casulaty	AFTER REMOVING THE EXHAUST FAN NEED TO CLOSE THE GAP WITH PLYWOOD SHEET	Parthiban.K.	Gap closed with plywood, work completed		Kanimozhi. E. - EMERGENCY MEDICINE	16/07/2022
1133	22070324	Casualty	NEED REPAIRING WORK FOR COT [SIDE RAILS & TIGHTING WORK]	Sarathy. A.	Cot side rail fixed, problem solved		Kanimozhi. E. - EMERGENCY MEDICINE	16/07/2022
Comp. Dt. : 11/07/2022 Status : Completed								
1134	22070429	Female Casulaty	NEED TO REFIX COT SIDE RAILS	Sarathy. A.	Cot side rail refixed, problem solved		Rajipriya. K. - EMERGENCY MEDICINE	20/07/2022
Comp. Dt. : 12/07/2022 Status : Completed								
1135	22070475	Casualty	NEED TO REFIX SIDE RAILS FOR COT [3NOS]	Sarathy. A.	Cot side rail refixed, problem solved		Kanimozhi. E. - EMERGENCY MEDICINE	20/07/2022
Comp. Dt. : 14/07/2022 Status : Completed								
1136	22070528	Casualty	NEED TO REFIX WALL MOUNTING SUCTION HOOK	Ekambaram. K.	Wall mount suction hook refixed, work completed		Kazhagamani. V. - EMERGENCY MEDICINE	01/08/2022
Comp. Dt. : 26/07/2022 Status : Completed								
1137	22070954	Casualty	NEED TO REFIX WHEEL [30 NOS] FOR WHEEL CHAIR , PATIENT STRUCTURE , MEDICINE TROLLEY	Sarathy. A.,Moorthy. L.,Parthiban.K.	Wheel chair and medicine trolley wheels are refixed in properly, problem solved		Kanimozhi. E. - EMERGENCY MEDICINE	05/08/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 11/08/2022 Status : Completed								
1138	22080420	Casualty	NEED REPAIRING WORK FOR COT	Sarathy. A.	Cot repaired and serviced, problem solved		Kanimozhi. E. - EMERGENCY MEDICINE	23/08/2022
Comp. Dt. : 12/08/2022 Status : Completed								
1139	22080448	Casualty	NEED TO REFIX COT SIDE RAILS AT GREEN AREA	Sarathy. A.	Cot side rails refixed, problem solved		Rajipriya. K. - EMERGENCY MEDICINE	23/08/2022
1140	22080452	MAIN CASUALTY	NEED WELDING WORK FOR COT	Sarathy. A.	Cot leg welding work completed		Rajipriya. K. - EMERGENCY MEDICINE	23/08/2022
Comp. Dt. : 17/08/2022 Status : Completed								
1141	22080498	Casualty	O2 STRUCTURE STAND BROKEN-NEED TO BE REPAIR	Sarathy. A.	Structure wheel repaired and refixed in properly, problem solved		Rajipriya. K. - EMERGENCY MEDICINE	25/08/2022
1142	22080499	Female Casulaty	MAIN DOOR LOCK PROBLEM	Ekambaram. K.	Door lock repaired and serviced, problem solved		Rajipriya. K. - EMERGENCY MEDICINE	25/08/2022
1143	22080500	PRIORITY-III ROOM IN CASUALTY	DOOR GLASS BROKEN	Ekambaram. K.	Door glass changed, novapam fixed, work completed		Rajipriya. K. - EMERGENCY MEDICINE	25/08/2022
Comp. Dt. : 25/08/2022 Status : Completed								
1144	22080844	Casualty	NEED TO REFIX WHEEL CHAIR BELT & COT SIDE RAILS [2NOS]	Sarathy. A.	Side rail fixed. (NEW)		Kanimozhi. E. - EMERGENCY MEDICINE	09/09/2022
Comp. Dt. : 29/08/2022 Status : Completed								
1145	22080970	marchuary	NEED REPAIRING WORK FOR MARCHUARY DOOR - NOT WORKING	Ekambaram. K.	Door repaired.		Sasirekha. K. - EMERGENCY MEDICINE	09/09/2022
Comp. Dt. : 30/08/2022 Status : Completed								
1146	22081010	Casualty	NEED REPAIRING WORK FOR COT - BEND	Sarathy. A.	cot mechanism repaired.		Sasirekha. K. - EMERGENCY MEDICINE	09/09/2022
Comp. Dt. : 02/09/2022 Status : Completed								
1147	22090074	Casualty	FOUR WHEELER COT BROKEN	Sarathy. A.	cot repaired.		Devi. S - EMERGENCY MEDICINE	08/09/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 10/09/2022 Status : Completed								
1148	22090396	Casualty	NEED REPAIRING WORK FOR CUPBOARD	Ekambaram. K.	2 nos. butterfly hinges fixed.		Rajipriya. K. - EMERGENCY MEDICINE	27/09/2022
Comp. Dt. : 14/09/2022 Status : Completed								
1149	22090550	Casualty	NEED OIL SERVICE FOR X RAY MACHINE & TROLLEY WHEELS - SOUND PROBLEM	Ekambaram. K.,Venkatesan. R.,Sundaramoorthy. G.	Cot repaired.		Kanimozhi. E. - EMERGENCY MEDICINE	27/09/2022
Comp. Dt. : 20/09/2022 Status : Completed								
1150	22090792	FEVER CLINIC	NEED TO PROVIDE A NEW STAND NEAR MEDICINE TABLE	Ekambaram. K.,Sundaramoorthy. G.,Venkatesan. R.	New stand make and fixed, problem solved		Dhanalakshmi. M. - EMERGENCY MEDICINE	29/09/2022
Comp. Dt. : 30/09/2022 Status : Completed								
1151	22091200	Casualty	NEED TO CHECK ENTRANCE GRILL GATE - STUCK	Ekambaram. K.	Entrance grill gate repaired and serviced, wheel welding work completed		Rajipriya. K. - EMERGENCY MEDICINE	08/10/2022
Comp. Dt. : 07/10/2022 Status : Completed								
1152	22100149	Casualty	NEED REPAIRING WORK FOR NURSE'S CABIN DRAW STUCK	Ekambaram. K.	Draw wheel changed, problem solved		Rajipriya. K. - EMERGENCY MEDICINE	13/10/2022
Comp. Dt. : 08/10/2022 Status : Completed								
1153	22100168	Casualty	CABIN BROKEN	Ekambaram. K.	Cabin Draw wheel changed, problem solved		Veeramani. D. - EMERGENCY MEDICINE	13/10/2022
Comp. Dt. : 17/10/2022 Status : Completed								
1154	22100509	Casualty	NEED REPAIRING WORK FOR WHEEL CHAIR FRONT SMALL WHEEL - BROKEN	Sarathy. A.	New wheel changed.		Jayalakshmi. J. - EMERGENCY MEDICINE	29/10/2022
Comp. Dt. : 18/10/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1155	22100609	Casualty	IN ROOM NO-38,PROCEDURE ROOM DOOR PROBLEM	Ekambaram. K.	Door repaired.		Devi. S - EMERGENCY MEDICINE	29/10/2022
		Comp. Dt. : 18/11/2022 Status : Completed						
1156	22110759	FEVER CLINIC	NEED REPAIRING WORK FOR DOOR - STUCK	Ekambaram. K.	Door repaired and serviced, problem solved		Kanimozhi. E. - EMERGENCY MEDICINE	01/12/2022
		Comp. Dt. : 21/11/2022 Status : Completed						
1157	22110865	Casualty	CHEATLE FORCEPS JAR WELDING WORK NEED TO DO	Sarathy. A.	Jar welded, problem solved		Sasirekha. K. - EMERGENCY MEDICINE	01/12/2022
		Comp. Dt. : 06/12/2022 Status : Completed						
1158	22120272	Casualty	IN PROCEDURE ROOM-DOOR BROKEN	Ekambaram. K.	Door changed, problem solved		Sasirekha. K. - EMERGENCY MEDICINE	19/12/2022
		Comp. Dt. : 10/12/2022 Status : Completed						
1159	22120461	Casualty	MAIN DOOR GLASS BROKEN - NEED TO CHANGE	Ekambaram. K.	New acrylic sheet fixed		Kanimozhi. E. - EMERGENCY MEDICINE	19/12/2022
1160	22120462	Casualty	NEED REPAIRING WORK FOR WHEEL CHAIR WHEEL 4 NOS & PATIENT STRETCHER WHEEL 2 NOS	Sarathy. A.	Wheel chair wheel and stretcher wheel changed, problem solved		Kanimozhi. E. - EMERGENCY MEDICINE	19/12/2022
		Comp. Dt. : 16/12/2022 Status : Completed						
1161	22120783	Casualty	NEED TO CHANGE WHEEL 3NOS FOR WRITING TABLE	Sarathy. A.	Writing table wheel replaced.		Balamurugan. M. - EMERGENCY MEDICINE	23/12/2022
		Comp. Dt. : 21/12/2022 Status : Completed						
1162	22120973	Casualty	MONITOR STAND BROKEN	Ekambaram. K.,Sundaramoorthy. G.,Pachaimuthusamy . D.	Monitor stand fixed, work completed		Kanimozhi. E. - EMERGENCY MEDICINE	29/12/2022
		Comp. Dt. : 28/12/2022 Status : Completed						
1163	22121286	Casualty	WRITING TABLE BROKEN,NEED TO BE REPAIR	Sarathy. A.	Table repaired and serviced, problem solved		Kanimozhi. E. - EMERGENCY MEDICINE	05/01/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 04/01/2023 Status : Completed								
1164	23010142	Casualty	STOOLS AND BASIC STAND PAINTING WORK NEED TO DO	Manimaran. A.	All items painting work completed		Jayalakshmi. J. - EMERGENCY MEDICINE	12/01/2023
Comp. Dt. : 24/01/2023 Status : Completed								
1165	23010860	Casualty	NEED TO REFIX MONITOR STAND	Ekambaram. K.	Monitor stand refixed, problem solved		Kanimozhi. E. - EMERGENCY MEDICINE	30/01/2023
1166	23010861	Casualty	NEED TO REFIX CRASH CART	Ekambaram. K.	Crash cart refixed		Kanimozhi. E. - EMERGENCY MEDICINE	30/01/2023
Comp. Dt. : 28/01/2023 Status : Completed								
1167	23011024	Casualty	NEED REPAIRING WORK FOR TABLE DRAW - DAMAGE - IN NURSE'S CABIN	Ekambaram. K.	Table draw repaired and refixed		Kanimozhi. E. - EMERGENCY MEDICINE	30/01/2023
Comp. Dt. : 02/02/2023 Status : Completed								
1168	23020058	Casualty	NEED REPAIRING WORK FOR CRASHCART & COT WHEEL - STUCK	Sarathy. A.	Crashcart and cot wheel repaired and serviced, problem solved		Kanimozhi. E. - EMERGENCY MEDICINE	11/02/2023
Comp. Dt. : 24/02/2023 Status : Completed								
1169	23020919	Casualty	NEED REPAIRING WORK FOR STRETCHER WHEEL STUCK	Sarathy. A.	Stretcher wheel repaired, problem solved		Kanimozhi. E. - EMERGENCY MEDICINE	04/03/2023
1170	23020920	Casualty	NEED TO REFIX BED SIDE SCREEN ROD	Ekambaram. K.	Screen rod refixed, problem solved		Kanimozhi. E. - EMERGENCY MEDICINE	04/03/2023
Comp. Dt. : 03/03/2023 Status : Completed								
1171	23030117	Casualty	NEED REPAIRING WORK FOR MAIN ENTRANCE ROLLING GATE	Sarathy. A.	Main gate rail welding work completed		Sasirekha. K. - EMERGENCY MEDICINE	09/03/2023
Comp. Dt. : 06/03/2023 Status : Completed								
1172	23030216	Casualty	NEED TO REFIX " NOTICE BOARD"	Ekambaram. K.	Notice board fixed		Kanimozhi. E. - EMERGENCY MEDICINE	09/03/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 08/03/2023 Status : Completed								
1173	23030312	Casualty	NEED TO REFIX FOOT STORPER FOR DOOR [2NOS]	Ekambaram. K.	DOOR STOPPER FIXED.		Kanimozhi. E. - EMERGENCY MEDICINE	14/03/2023
Comp. Dt. : 11/03/2023 Status : Completed								
1174	23030448	Casualty	NEED REPAIRING WORK FOR BED SIDE SCREEN - BROKEN	Sarathy. A.	STAND PAINTED.		Kanimozhi. E. - EMERGENCY MEDICINE	23/03/2023
Comp. Dt. : 14/03/2023 Status : Completed								
1175	23030534	Casualty	NEED RING CUTTING WORK	Sarathy. A.	RING REMOVED.		Balamurugan. M. - EMERGENCY MEDICINE	23/03/2023
Comp. Dt. : 16/03/2023 Status : Completed								
1176	23030671	Casualty	NEED TO FIX NEW LOCK FOR WOODEN BOX	Ekambaram. K.	Wood box lock fixed.		Racida. R. - EMERGENCY MEDICINE	23/03/2023
Comp. Dt. : 17/03/2023 Status : Completed								
1177	23030726	Casualty	NEED REPAIRING WORK FOR NURSE'S CABIN DRAW - BROKEN	Ekambaram. K.	Cabin draw repaired and refixed, problem solved		Kanimozhi. E. - EMERGENCY MEDICINE	31/03/2023
Comp. Dt. : 18/03/2023 Status : Completed								
1178	23030748	Casualty	NEED TO REFIX MONITOR STAND	Ekambaram. K.	Monitor stand refixed		Raja. A. - EMERGENCY MEDICINE	31/03/2023
Comp. Dt. : 28/03/2023 Status : Completed								
1179	23031226	Female Casulaty	NEED REPAIRING WORK FOR DOOR - SOUND AND STUCK	Ekambaram. K.	Door repaired and new padlock fixed, problem solved		Sasirekha. K. - EMERGENCY MEDICINE	13/04/2023
Comp. Dt. : 08/04/2023 Status : Completed								
1180	23040230	Casualty	NEED TO REFIX DOOR STOPPER - DAMAGE	Ekambaram. K.	New door stopper fixed, problem solved		Sasirekha. K. - EMERGENCY MEDICINE	20/04/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
1181	23040425	Female Casulaty	NEED REPAIRING WORK FOR MAIN DOOR - NOT CLOSING PROPERLY	Ekambaram. K.	Door repaired and serviced		Kalaivani. N. - EMERGENCY MEDICINE	20/04/2023
Comp. Dt. : 19/04/2023								
Status : Completed								
1182	23040613	Casualty	NEED ALL WHEEL CHAIR SERVICE	Ekambaram. K., Sarathy. A., Veerappan. D.	WHEEL CHAIR REPAIRED		Kanimozhi. E. - EMERGENCY MEDICINE	02/05/2023
Comp. Dt. : 18/05/2023								
Status : Completed								
1183	23050756	Casualty	NEED REPAIRING WORK FOR DOOR & DOOR LOCK	Ekambaram. K.	DOOR REPAIRED		Kanimozhi. E. - EMERGENCY MEDICINE	01/06/2023
Comp. Dt. : 24/05/2023								
Status : Completed								
1184	23050944	Casualty	NEED REPAIRING WORK FOR WHEEL CHAIR WHEEL - STUCK [2NOS]	Sarathy. A.	4 NOS TROLLY WHEEL REPLACED		Balamurugan. M. - EMERGENCY MEDICINE	03/06/2023
Comp. Dt. : 05/06/2023								
Status : Completed								
1185	23060139	CASUALTY RECEPTION	TILES AIR CRACK - NEED TOUCHUP WORK - URGENT SERVICE NEED	Parivallal. P.	Tiles refixed		Balamurugan. M. - EMERGENCY MEDICINE	20/06/2023
Comp. Dt. : 15/06/2023								
Status : Completed								
1186	23060522	Casualty	IN ROOM NO-41, DOOR CLOSER PROBLEM	Ekambaram. K.	Work completed		Racida. R. - EMERGENCY MEDICINE	27/06/2023
1187	23060557	Casualty	SCREEN ROD CUTTING WORK(1014)	Sarathy. A.	Board fixed.		Sasirekha. K. - EMERGENCY MEDICINE	27/06/2023
Dept Name : Endoscopy - Work Shop								
Comp. Dt. : 02/07/2022								
Status : Completed								
1188	22070059	Endoscopy	NEED TO FIX CUPBOARD MIRROR & HANDLE HOOK	Manivannan. A.	Cupboard fixed, problem solved		Vijayalakshmi. G. - Endoscopy	20/07/2022
Comp. Dt. : 28/03/2023								
Status : Completed								
1189	23031162	Endoscopy	NEED PAINTING WORK FOR LINEN TROLLEY	Manivannan. A., Manimaran. A., Viswa. V.	Wheel replaced and painting work completed		Amilselvi. E. - Endoscopy	13/04/2023

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHAL KUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 04/04/2023 Status : Completed								
1190	23040136	Endoscopy	NEED REPAIRING WORK FOR CSSD BIN	Ekambaram. K.,Sundaramoorthy. G.,Sarathy. A.	CSSD Bin repaired, problem solved		Vijayalakshmi. G. - Endoscopy	17/04/2023
Comp. Dt. : 06/04/2023 Status : Completed								
1191	23040184	Endoscopy	NEED CANE CUTTING WORK	Sarathy. A.	Cane cutting work completed		Tamilselvi. E. - Endoscopy	20/04/2023
Comp. Dt. : 24/04/2023 Status : Completed								
1192	23040752	Endoscopy	NEED TO FIX AIR STERILIZER	Ekambaram. K.	STERILIZER FIXED.		Tamilselvi. E. - Endoscopy	02/05/2023
Comp. Dt. : 17/06/2023 Status : Completed								
1193	23060621	Endoscopy	NEED TO FIT BOARD	Ekambaram. K.	Tiles fixed and Jk white applied.		Vijayalakshmi. G. - Endoscopy	27/06/2023
Dept Name : ENT & Ophthal Ward - Work Shop Comp. Dt. : 05/09/2022 Status : Completed								
1194	22090177	Female Medical Ward	NEED TO REFIX BUSH FOR COT, STOOL & TROLLEY FOR WARD NO 305 & 306	Sarathy. A.	Work completed		Bhuvaneswari. M. - ENT & Ophthal Ward	24/09/2022
Comp. Dt. : 07/09/2022 Status : Completed								
1195	22090275	ENT WARD-408	NEED TO REFIX NAME BOARD FOR " RESTROOM "	Venkatesan. R.	Board fixed.		Jayalakshmi. J. - ENT & Ophthal Ward	24/09/2022
Comp. Dt. : 08/09/2022 Status : Completed								
1196	22090337	Female Medical - Ward 305	NEED TO REFIX BUSH FOR PATIENT STRUCTURE COUCH	Sarathy. A.	Bush fixed.		Bhuvaneswari. M. - ENT & Ophthal Ward	27/09/2022
Comp. Dt. : 09/09/2022 Status : Completed								
1197	22090360	ENT WARD-408	NEED TO CHECK TILES - DAMAGE & SOUND PROBLEM	Murugavel	18 nos tiles refixed and JK white applied.		Jayalakshmi. J. - ENT & Ophthal Ward	27/09/2022
Comp. Dt. : 12/09/2022								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
1198	22090454	Female Medical - Ward 305	NEED REPAIRING WORK FOR BERO LOCK - LOCK PROBLEM	Ekambaram. K.	Bero lock repaired.		Bhuvaneswari. M. - ENT & Ophthal Ward	27/09/2022
1199	22090461	ENT WARD-408	NEED REPAIRING WORK FOR NEW CABIN DRAW - NOT CLOSING PROPERLY	Ekambaram. K.	Draw repaired and serviced, problem solved		Jayalakshmi. J. - ENT & Ophthal Ward	29/09/2022
Comp. Dt. : 13/09/2022								
Status : Completed								
1200	22090497	ENT WARD-407	TILES BROKEN AT ENTRANCE - NEED TOUCHUP WORK	Murugavel	Tiles refixed, JK White cement pointing work completed		Jayalakshmi. J. - ENT & Ophthal Ward	29/09/2022
Comp. Dt. : 15/09/2022								
Status : Completed								
1201	22090588	Female Medical - Ward 305	NEED TO FIX DOCTORS ROOM DOOR LOCK BROKEN	Ekambaram. K.	Door repaired and serviced, door lock changed, problem solved		Bhuvaneswari. M. - ENT & Ophthal Ward	29/09/2022
Comp. Dt. : 20/09/2022								
Status : Completed								
1202	22090785	ENT WARD-407	NEED TO FIX A NEW DOOR FOR PANTRY ROOM	Ekambaram. K.,Venkatesan. R.,Sundaramoorthy. G.	New door fixed, problem solved		Jayalakshmi. J. - ENT & Ophthal Ward	29/09/2022
Comp. Dt. : 26/09/2022								
Status : Completed								
1203	22091024	Female Medical - Ward 305	NEED REPAIRING WORK FOR DEMO ROOM TABLE & NURSE'S CABIN	Ekambaram. K.,Venkatesan. R.,Sundaramoorthy. G.	Demo room table and Nurses cabin door repaired and serviced, problem solved		Bhuvaneswari. M. - ENT & Ophthal Ward	08/10/2022
Comp. Dt. : 27/09/2022								
Status : Completed								
1204	22091036	Female Medical - Ward 305	NEED TO REFIX COT SIDE RAILS	Sarathy. A.	Side rail refixed in cot, work completed		Bhuvaneswari. M. - ENT & Ophthal Ward	08/10/2022
Comp. Dt. : 30/09/2022								
Status : Completed								
1205	22091202	ENT WARD-408	TILES AIR CRACK - NEED TOUCH UP WORK	Murugavel	Tiles refixed, JK white cement pointing work completed		Jayalakshmi. J. - ENT & Ophthal Ward	08/10/2022
Comp. Dt. : 12/10/2022								
Status : Completed								
1206	22100325	ENT WARD-407	COT STAND NEED TO BE ADJUSTED	Sarathy. A.	Stand adjusted, problem solved		Jayalakshmi. J. - ENT & Ophthal Ward	20/10/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 14/10/2022 Status : Completed								
1207	22100443	ENT WARD-407	NEED TO CHANGE SUCTION APPARATUS WHEEL - WHEEL BROKEN	Sarathy. A.	4Nos of new wheel changed, problem solved		Jayalakshmi. J. - ENT & Ophthal Ward	21/10/2022
Comp. Dt. : 15/10/2022 Status : Completed								
1208	22100489	ENT WARD-407	NEED PAINTING WORK FOR ALL COT & LOCKERS	Manimaran. A.	Painting work completed		Jayalakshmi. J. - ENT & Ophthal Ward	21/10/2022
1209	22100494	ENT WARD-407	DRESSING TROLLEY PAINTING WORK NEED TO DO	Manimaran. A.	Painting work completed		Jayalakshmi. J. - ENT & Ophthal Ward	21/10/2022
1210	22100495	ENT WARD-407	NEED TO RETIGHT TROLLEY WHEEL	Sarathy. A.	4Nos of new wheel changed, problem solved		Jayalakshmi. J. - ENT & Ophthal Ward	21/10/2022
Comp. Dt. : 17/10/2022 Status : Completed								
1211	22100524	ENT WARD-407	PROBLEM IN MAIN ENTRANCE - [DOOR UNDER ALUMINIUM PART] SOUND AND STUCK	Ekambaram. K.	Main door repaired.		Jayalakshmi. J. - ENT & Ophthal Ward	29/10/2022
Comp. Dt. : 21/10/2022 Status : Completed								
1212	22100712	ENT WARD-407	IN ENTRANCE DOOR- DOOR BOTTOM STEEL PLATE UNDER DOOR CLOSER NEED TO BE REFIX	Ekambaram. K., Sundaramoorthy. G., Manivannan. A.	Steel plate fixed at bottom		Jayalakshmi. J. - ENT & Ophthal Ward	29/10/2022
Comp. Dt. : 27/10/2022 Status : Completed								
1213	22100852	ENT WARD-407	PATIENT'S BED SIDE SCREEN ROD BROKEN	Sarathy. A.	Work completed.		Jayalakshmi. J. - ENT & Ophthal Ward	03/11/2022
1214	22100863	Female Medical - Ward 305	NURSES CABIN DRAWER NOT CLOSING PROPERLY	Ekambaram. K.	Side rail fixed.		Bhuvaneswari. M. - ENT & Ophthal Ward	03/11/2022
Comp. Dt. : 29/10/2022 Status : Completed								
1215	22100974	Female Medical - Ward 305	NEED TO FIX NET STAND	Parthiban. K.	Stand fixed, work completed		Bhuvaneswari. M. - ENT & Ophthal Ward	08/11/2022
1216	22100975	Female Medical - Ward 306	DOCTOR'S ROOM DOOR LOCK PROBLEM	Ekambaram. K.	Door and door lock repaired and serviced, problem solved		Bhuvaneswari. M. - ENT & Ophthal Ward	08/11/2022
1217	22100976	Female Medical - Ward 305	DOCTOR'S ROOM DOOR LOCK PROBLEM	Sundaramoorthy. G.	Door and door lock refixed, problem solved		Bhuvaneswari. M. - ENT & Ophthal Ward	15/11/2022
1218	22100977	Female Medical - Ward 305	NURSES CABIN DOOR BROKEN	Ekambaram. K.	Door fixed, problem solved		Bhuvaneswari. M. - ENT & Ophthal Ward	15/11/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1219	22100978	Female Medical - Ward 305	NEED TO FIX PATIENT STOOL BUSH	Moorthy. L.	Bush fixed		Bhuvaneswari. M. - ENT & Ophthal Ward	08/11/2022
Comp. Dt. : 03/11/2022								
Status : Completed								
1220	22110074	ENT WARD-407	PATIENTS BED SIDE-SCREEN ROD NEED TO DO TIGHTENING	Sarathy. A.	Screen rod fixed, work completed		Jayalakshmi. J. - ENT & Ophthal Ward	16/11/2022
1221	22110104	ENT WARD-407	FIRE EXIT BOARD NEED TO BE REFIX ON WALL	Sarathy. A.	Screen rod fixed, work completed		Jayalakshmi. J. - ENT & Ophthal Ward	16/11/2022
Comp. Dt. : 04/11/2022								
Status : Completed								
1222	22110125	Female Medical - Ward 306	FLOOR TILES PACKING WORK NEED TO DO IN PATIENT BATHROOM	Murugavel	Tiles refixed, JK White cement pointing work completed		Bhuvaneswari. M. - ENT & Ophthal Ward	16/11/2022
1223	22110131	ENT WARD-407	MAIN DOOR BOTTOM STEEL PLATE NEED TO BE REFIX	Murugavel	Steel plate fixed, problem solved		Jayalakshmi. J. - ENT & Ophthal Ward	16/11/2022
Comp. Dt. : 10/11/2022								
Status : Completed								
1224	22110435	Female Medical - Ward 305	WHEEL CHAIR BELT NEED TO BE REFIX	Sarathy. A.	Belt fixed, problem solved		Bhuvaneswari. M. - ENT & Ophthal Ward	18/11/2022
Comp. Dt. : 14/11/2022								
Status : Completed								
1225	22110538	ENT WARD-407	NURSES CABIN DRAWER NEED TO BE REFIX	Ekambaram. K.	Drawer repaired.		Jayalakshmi. J. - ENT & Ophthal Ward	21/11/2022
Comp. Dt. : 18/11/2022								
Status : Completed								
1226	22110753	Female Medical - Ward 305	NEED TO CHANGE NURSES CABIN	Ekambaram. K.	New Nurses cabin make and fixed, work completed		Bhuvaneswari. M. - ENT & Ophthal Ward	01/12/2022
Comp. Dt. : 25/11/2022								
Status : Completed								
1227	22111102	Female Medical - Ward 305	ECG MACHINE TROLLEY PAINTING WORK NEED TO DO	Manimaran. A.	ECG Machine trolley painting work completed		Bhuvaneswari. M. - ENT & Ophthal Ward	06/12/2022
Comp. Dt. : 02/12/2022								
Status : Completed								
1228	22120056	ENT WARD-407	NEED REPAIRING WORK FOR COT WHEEL - DAMAGED & NOT WORKING	Sarathy. A.	Work completed.		Jayalakshmi. J. - ENT & Ophthal Ward	10/12/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1229	22120079	ENT WARD-407	NEED REPAIRING WORK FOR BERO HANDLE	Ekambaram. K.	Handle fixed.		Jayalakshmi. J. - ENT & Ophthal Ward	10/12/2022
	Comp. Dt. : 06/12/2022							
	Status : Completed							
1230	22120261	Female Medical - Ward 305	NAILS NEED TO BE ATTACH ON WALL TO FIX X-RAY LOBE	Ekambaram. K.	X-ray lobby and nail fixed, problem solved		Bhuvaneswari. M. - ENT & Ophthal Ward	19/12/2022
	Comp. Dt. : 16/12/2022							
	Status : Completed							
1231	22120762	ENT WARD-407	BEDSIDE LOCKER PAINTING WORK NEED TO DO	Manimaran. A.	10 nos. bedside locker painted.		Jayalakshmi. J. - ENT & Ophthal Ward	23/12/2022
	Comp. Dt. : 22/12/2022							
	Status : Completed							
1232	22121027	ENT WARD-407	NEED LABOURS FOR CART ARRANGEMENT - 4 NOS	Ganesan. A.	Wrong complaint, inform to Maintenance dept		Jayalakshmi. J. - ENT & Ophthal Ward	29/12/2022
	Comp. Dt. : 27/12/2022							
	Status : Completed							
1233	22121203	ENT WARD-407	BIN SIDE HOOK GOT LOOSE	Viswa. V.	Hook refixed, problem solved		Jayalakshmi. J. - ENT & Ophthal Ward	05/01/2023
	Comp. Dt. : 02/01/2023							
	Status : Completed							
1234	23010028	ENT WARD-407	FOLDING SCREEN ROD NEED TO BE FIX	Ekambaram. K.	Screen rod welding work completed		Jayalakshmi. J. - ENT & Ophthal Ward	12/01/2023
	Comp. Dt. : 06/01/2023							
	Status : Completed							
1235	23010256	ENT WARD-407	CRUSH CARD TROLLY OPEN PROBLEM	Sarathy. A.	Wheel repaired.		Jayalakshmi. J. - ENT & Ophthal Ward	11/01/2023
	Comp. Dt. : 10/01/2023							
	Status : Completed							
1236	23010376	Female Medical - Ward 305	IN DEMO ROOM-X-RAY LOBY NEED TO BE FIX	Ekambaram. K.	X-ray lobby fixed, problem solved		Bhuvaneswari. M. - ENT & Ophthal Ward	23/01/2023
	Comp. Dt. : 12/01/2023							
	Status : Completed							
1237	23010535	ENT WARD-408	TILES BROKEN	Murugavel	Tiles refixed, JK white cement pointing work completed		Madhiveni. M. - ENT & Ophthal Ward	30/01/2023
	Comp. Dt. : 13/01/2023							
	Status : Completed							


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1238	23010547	ENT WARD-408	NEED TOUCHUP WORK FOR TILES -AIR CRACK	Murugavel	Tiles refixed, JK White cement pointing work completed		Jayalakshmi. J. - ENT & Ophthal Ward	30/01/2023
	Comp. Dt. : 14/02/2023							
	Status : Completed							
1239	23020535	ENT WARD-407	TILES AIR CRACK	Murugavel	Tiles fixed, JK white cement pointing work completed		Jayalakshmi. J. - ENT & Ophthal Ward	17/02/2023
	Comp. Dt. : 27/02/2023							
	Status : Completed							
1240	23020994	ENT WARD-407	NEEED TO REFIX COT SIDE RAILS	Ekambaram. K.	SIDE RAIL FIXED		Jayalakshmi. J. - ENT & Ophthal Ward	07/03/2023
	Comp. Dt. : 01/03/2023							
	Status : Completed							
1241	23030046	ENT WARD-407	NEED REPAIRING WORK FOR GAUZE BIN	Sarathy. A.	Gauze bin repaired, problem solved		Agila. V. - ENT & Ophthal Ward	09/03/2023
	Comp. Dt. : 15/03/2023							
	Status : Completed							
1242	23030587	ENT WARD-407	NEED TO REFIX ENTRANCE " NOTICE BOARD"	Ekambaram. K.	Board fixed		Jayalakshmi. J. - ENT & Ophthal Ward	23/03/2023
	Comp. Dt. : 03/04/2023							
	Status : Completed							
1243	23040031	ENT WARD-408	NEED REPAIRING WORK FOR FOLDER COT - STUCK	Sarathy. A.	Cot repaired and serviced, problem solved		Madhiveni. M. - ENT & Ophthal Ward	17/04/2023
1244	23040067	ENT WARD	NEED TO REFIX COT LOCK WARD NO 407 & 407	Sarathy. A.	Cot repaired and serviced, problem solved		Agila. V. - ENT & Ophthal Ward	17/04/2023
	Comp. Dt. : 20/04/2023							
	Status : Completed							
1245	23040618	Female Medical - Ward 14	NEED REPAIRING WORK AND PAINTING WORK FOR BERO NEW LOCK & LOCKER LOCK 5NOS , IV STAND 3NOS , WR	Manimaran. A.	PAINTING WORK COMPLETED		Bhuvaneswari. M. - ENT & Ophthal Ward	02/05/2023
	Comp. Dt. : 05/05/2023							
	Status : Completed							
1246	23050194	Female Medical - Ward 305	NEED PAINTING WORK FOR MEDICINE TROLLEY , IV STAND , LOCKER	Manimaran. A.	All materials painting work completed		Bhuvaneswari. M. - ENT & Ophthal Ward	15/05/2023
	Comp. Dt. : 29/05/2023							
	Status : Completed							


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1247	23051128	ENT WARD-407	NEED REPAIRING WORK FOR PARTITION DOOR & PATLOCK	Ekambaram. K.	DOOR REFIXED		Agila. V. - ENT & Ophthal Ward	03/06/2023
Comp. Dt. : 03/06/2023 Status : Completed								
1248	23060105	Female Medical - Ward 305	NEED PAINTING WORK FOR 3 FOLDER SCREEN 4NOS	Manimaran. A.	Wheel 16 nos changed and painted		Bhuvaneswari. M. - ENT & Ophthal Ward	20/06/2023
Comp. Dt. : 23/06/2023 Status : Completed								
1249	23060890	ENT WARD-407	TILES BROKEN - NEED TOUCHUP WORK	Parivallal. P.	8 nos. tiles refixed.		Agila. V. - ENT & Ophthal Ward	07/07/2023
Dept Name : Female Medical Ward - Work Shop Comp. Dt. : 25/05/2022 Status : Completed								
1250	22050930	Female Medical - Ward 305	NEED REPAIRING WORK FOR CUPBOARD DRAW - NOT WORKING	Ekambaram. K.	Cup board draw fixed.		Vaitheeswari. A. - Female Medical Ward	10/06/2022
Comp. Dt. : 02/06/2022 Status : Completed								
1251	22060084	Female Medical - Ward 305	NEED REPAIRING WORK FOR WHEEL CHAIR WHEEL - DAMAGE AND NOT WORKING	Sarathy. A.	Wheel replaced in wheel chair.		Vaitheeswari. A. - Female Medical Ward	10/06/2022
Comp. Dt. : 04/01/2023 Status : Completed								
1252	23010163	Female Medical - Ward 306	STEEL TABLE TOPSIDE-PLYWOOD GOT DAMGED	Ekambaram. K.	New Table top fixed, problem solved		Gnanasoundari. G - Female Medical Ward	12/01/2023
Comp. Dt. : 18/01/2023 Status : Completed								
1253	23010632	Female Medical - Ward 305	NEED REPAIRING WORK FOR DOCTOR'S ROOM RESTROOM DOOR LOCK - LOCK DAMAGE & BROKEN	Ekambaram. K.	Door and lock screw refixed, problem solved		Gnanasoundari. G - Female Medical Ward	30/01/2023
Comp. Dt. : 22/02/2023 Status : Completed								
1254	23020854	Female Surgery - Ward 206	NURSES STAION TABLE DOOR BROKEN.REPAIR IT	Ekambaram. K.	Table door hinges changed, problem solved		Santhiya. T. - Female Medical Ward	01/03/2023
Comp. Dt. : 24/04/2023 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1255	23040747	Male Medical - Ward 302	NEED REPAIRING WORK FOR WHEEL CHAIR WHEEL STUCK	Sarathy. A.	WHEEL CHAIR REPAIRED.		Vaitheeswari. A. - Female Medical Ward	02/05/2023
Dept Name : Female Ortho Ward - Work Shop Comp. Dt. : 07/06/2022 Status : Completed								
1256	22060259	Male Ortho - Ward 404	NEED REPAIRING WORK FOR RESTROOM DOOR LOCK - DAMAGE	Ekambaram. K.	door repaired.		Gayathri. S. - Male Ortho Ward	13/06/2022
Comp. Dt. : 28/06/2022 Status : Completed								
1257	22061014	Injection Room - OPD	NEED TO REFIX HEIGHT SCALE - OPD NO 54	Pachaimuthusamy. D.	Height scale fixed		Badmasri. P. - OPD	05/07/2022
Comp. Dt. : 23/07/2022 Status : Completed								
1258	22070855	Female Ortho - Ward 401	WHEEL CHAIR BROKEN	Sarathy. A.	Wheel chair repaired and serviced, problem solved		Anbuselvi. P. - Female Ortho Ward	05/08/2022
Comp. Dt. : 29/07/2022 Status : Completed								
1259	22071056	Female Ortho - Ward 401	TILES DAMAGE - NEED TOUCHUP WORK AT PANTARY ROOM	Murugavel	Tiles refixed, JK white cement pointing work completed		Girija. G. - Female Ortho Ward	05/08/2022
Comp. Dt. : 04/08/2022 Status : Completed								
1260	22080158	Female Ortho - Ward 401	COT SIDE RAILS BROKEN	Sarathy. A.	Cot side rail refixed, problem solved		Anbuselvi. P. - Female Ortho Ward	17/08/2022
1261	22080185	Female Ortho - Ward 401	NEED CLOSED WOODEN CUPBOARD FOR KEEP FOR IV FLUID	Parthiban.K.	cupboard closed, work completed		Girija. G. - Female Ortho Ward	06/12/2022
Comp. Dt. : 29/08/2022 Status : Completed								
1262	22080996	Female Ortho - Ward 401	NEED REPAIRING & REFIX WHEEL CHAIR WHEEL & SAFETY BELT	Sarathy. A.	Wheel chair repaired.		Girija. G. - Female Ortho Ward	09/09/2022
Comp. Dt. : 13/09/2022 Status : Completed								
1263	22090512	Female Ortho - Ward 402	NEED TO REFIX WHEEL CHAIR BELT & PATIENT STRUCTURE SIDE RAILS	Sarathy. A.	Wheel chair - wheel, belt refixed, Stretcher side rail refixed, problem solved		Girija. G. - Female Ortho Ward	29/09/2022
Comp. Dt. : 22/09/2022								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
1264	22090890	Female Ortho - Ward 402	NEED TO REFIX PATLOCK FOR PATIENT RESTROOM	Ekambaram. K.	New pat lock fixed, problem solved		Girija. G. - Female Ortho Ward	08/10/2022
Comp. Dt. : 29/09/2022								
Status : Completed								
1265	22091161	Female Ortho Ward	AQUAGUARD NOT WORKING	Ganesan. A.	Wrong complaint, inform to Plumbing dept		Girija. G. - Female Ortho Ward	08/10/2022
Comp. Dt. : 05/10/2022								
Status : Completed								
1266	22100021	Female Ortho - Ward 401	NEED TO CHANGE WHEEL CHAIR TYRE - DAMAGE	Sarathy. A.	Wheel chair belt refixed, problem solved		Girija. G. - Female Ortho Ward	16/11/2022
Comp. Dt. : 22/10/2022								
Status : Completed								
1267	22100753	Female Ortho - Ward 401	NURSE TABLE CABIN DOOR PROBLEM(1414)	Ekambaram. K.	Door refixed.		Punithavathi. E. - Female Ortho Ward	29/10/2022
Comp. Dt. : 16/11/2022								
Status : Completed								
1268	22110676	Female Ortho - Ward 401	STRETCHER WHEEL BROEKN,REPAIR IT	Sarathy. A.	Wheel replaced.		Girija. G. - Female Ortho Ward	21/11/2022
Comp. Dt. : 23/11/2022								
Status : Completed								
1269	22111002	Female Ortho - Ward 402	NEAR PANTRY ROOM-FLOOR TILES BROKEN,TOUCHUP WORK NEEDED	Murugavel	Floor tiles refixed, JK white cement pointing work completed		Girija. G. - Female Ortho Ward	01/12/2022
Comp. Dt. : 05/12/2022								
Status : Completed								
1270	22120185	Female Ortho - Ward 401	PATIENT COT SIDE RAILS BROKEN	Ekambaram. K.	side rail fixed.		Anbuselvi. P. - Female Ortho Ward	10/12/2022
Comp. Dt. : 28/12/2022								
Status : Completed								
1271	22121255	Female Ortho - Ward 401	NEED LABOURS FOR CART ARRANGEMENT	Ganesan. A.	Wrong complaint, inform to Maintenance dept		Punithavathi. E. - Female Ortho Ward	05/01/2023
Comp. Dt. : 02/01/2023								
Status : Completed								
1272	23010007	Female Ortho - Ward 402	MEDICINE TROLLY WHEEL BROKEN	Sarathy. A.	Medicine Trolley wheel replaced, problem solved		Girija. G. - Female Ortho Ward	12/01/2023
Comp. Dt. : 09/02/2023								
Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1273	23020348	Female Ortho - Ward 401	NEED TO FIX WHEELCHAIR BELT	Moorthy. L.	Wheel chair belt fixed, problem solved		Girija. G. - Female Ortho Ward	16/02/2023
Comp. Dt. :		15/02/2023						
Status :		Completed						
1274	23020579	Female Ortho - Ward 402	NEED TO REFIX WHEEL CHAIR BELT	Sarathy. A.	Wheel chair belt refixed		Girija. G. - Female Ortho Ward	17/02/2023
Comp. Dt. :		07/03/2023						
Status :		Completed						
1275	23030254	Female Ortho - Ward 402	NEED REPAIRING WORK FOR FOWLER COT - BROKEN	Sarathy. A.	WORK COMPLETED.		Girija. G. - Female Ortho Ward	14/03/2023
1276	23030266	Female Ortho - Ward 402	NEED REPAIRING WORK FOR PATIENT COT - BEND	Sarathy. A.	4 NOS. NEW WHEELS FIXED.		Girija. G. - Female Ortho Ward	14/03/2023
1277	23030288	Female Ortho - Ward 401	NEED REPAIRING AND REFIX STRETCHER WHEEL & WHEEL CHAIR BELT	Sarathy. A.	4 NOS. WHEELS FIXED.		Meena. E. - Female Ortho Ward	14/03/2023
Comp. Dt. :		16/03/2023						
Status :		Completed						
1278	23030641	Female Ortho - Ward 401	NEED REPAIRING WORK FOR WHEEL CHAIR WHEEL - STUCK	Sarathy. A.	WHEEL REPAIRED.		Girija. G. - Female Ortho Ward	23/03/2023
Comp. Dt. :		24/04/2023						
Status :		Completed						
1279	23040750	Female Ortho - Ward 402	NEED REPAIRING WORK FOR COT WHEEL - STUCK	Ekambaram. K.,Sundaramoorthy. G.,Sarathy. A.	COT WHEEL REPLACED.		Shabina Begum. S. - Female Ortho Ward	02/05/2023
Comp. Dt. :		27/04/2023						
Status :		Completed						
1280	23040890	Female Ortho - Ward 402	NEED TO REFIX COT SIDE RAILS	Sarathy. A.	Cot side rails fixed, work completed		Anbuselvi. P. - Female Ortho Ward	08/05/2023
Comp. Dt. :		29/04/2023						
Status :		Completed						
1281	23041009	Female Ortho - Ward 402	NEED TO REFIX SIDE RAILS -	Ekambaram. K.	Cot side rails refixed, work completed		Dhansulakshmi. K. - Female Ortho Ward	08/05/2023
Comp. Dt. :		30/06/2023						
Status :		Completed						
1282	23061130	Female Ortho - Ward 402	KEY NOT IN USE - NEED TO REFIX PATLOCK FOR BERO	Ekambaram. K.,Sundaramoorthy. G.,Ganesh. S.	Key not given. Letter should be provided.		Punithavathi. E. - Female Ortho Ward	08/07/2023
Comp. Dt. :		30/06/2023						
Status :		Completed						
Dept Name : Female Surgery - Work Shop								

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 18/06/2022								
Status : Completed								
1283	22060676	Male Surgery - Ward 203	NEED REPAIRING WORK FOR NURSE'S CABIN CUPBOARD - BROKEN	Pachaimuthusamy. D.	Cup board fixed		Mounica. B. - Male Surgery	23/06/2022
Comp. Dt. : 29/06/2022								
Status : Completed								
1284	22061087	Male Surgery - Ward 203	NEED STERILLIUM BOTTLE CUTTING WORK	Sarathy. A.	Boottle cut work done		Mounica. B. - Male Surgery	05/07/2022
Comp. Dt. : 30/06/2022								
Status : Completed								
1285	22061106	Male Surgery - Ward 203	NEED REPAIRING WORK FOR NURSE'S CABIN - PLY WOOD SHEETS DAMAGE & BROKENED	Pachaimuthusamy. D.,Ekambaram. K.,Venkatesan. R.	Plywood repairing work completed		Sasikala. A. - Male Surgery	05/07/2022
Comp. Dt. : 05/07/2022								
Status : Completed								
1286	22070132	Male Surgery - Ward 203	NEED WELDING WORK FOR STERILIZER - WATER LEAKAGE	Sarathy. A.	Wrong complaint		Ezhilarasi. E. - Male Surgery	16/07/2022
Comp. Dt. : 08/09/2022								
Status : Completed								
1287	22090324	Male Surgery - Ward 204	NEED TO REFIX PATIENT COT - UNFIX PROBLEM	Sarathy. A.	Cot repaired and serviced, problem solved		Vaidegi. S. - Female Surgery	29/09/2022
Comp. Dt. : 16/09/2022								
Status : Completed								
1288	22090624	Male Surgery	NEED REPAIRING WORK FOR COT - COT BENDING AND SLANDING WARD NO 203 &204	Sarathy. A.	Cot leg welding work completed		Vaidegi. S. - Female Surgery	12/10/2022
Comp. Dt. : 20/09/2022								
Status : Completed								
1289	22090784	Female Surgery	NEED REPAIRNG WORK FOR DEMO ROOM PATLOCK	Ekambaram. K.	New pad lock fixed, problem solved		Vaidegi. S. - Female Surgery	29/09/2022
Comp. Dt. : 28/09/2022								
Status : Completed								
1290	22091122	Male Surgery - Ward 204	NEED REPAIRING WORK FOR COT - UNFIX	Sarathy. A.	All cot repaired and serviced, probem solved		Subashini. D. - Gynac Ward	08/10/2022
Comp. Dt. : 30/12/2022								
Status : Completed								

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1291	22121353	Gynaecology - Ward 209	CHEATLE FORCEPS JAR WELDING WORK	Sarathy. A.	Forcebs Jar welded, work completed		Priyanka. V. - Female Surgery	05/01/2023
		Comp. Dt. : 03/01/2023 Status : Completed						
1292	23010070	Female Surgery - Ward 205	BERO CUPBOARD BROKEN	Ekambaram. K.	Cupboard refixed, problem solved		Subashini. D. - Gynac Ward	12/01/2023
		Comp. Dt. : 04/01/2023 Status : Completed						
1293	23010143	Female Surgery - Ward 206	NEED LABOURS 2 NO'S FOR CABIN ARRANGEMENTS WORK	Ganesan. A.	wrong complaint, msg infrom to maintenance dept		Vaidegi. S. - Female Surgery	12/01/2023
		Comp. Dt. : 13/03/2023 Status : Completed						
1294	23030515	Female Surgery - Ward 205	NEED REPAIRING WORK FOR BED SIDE SCREEN WHEEL, O2 CYLINDER WHEEL , MEDICINE TROLLEY WHEEL - STUCK	Sarathy. A.	WORK COMPLETED		Vaidegi. S. - Female Surgery	23/03/2023
		Comp. Dt. : 22/03/2023 Status : Completed						
1295	23030903	Male Surgery - Ward 204	NEED REPAIRING WORK FOR NURSE'S CABIN LOCKER - DAMAGE	Ekambaram. K.	NURSE'S CABIN LOCKER REFIXED.		Subashini. D. - Gynac Ward	01/04/2023
		Comp. Dt. : 25/03/2023 Status : Completed						
1296	23031074	Male Surgery - Ward 203	NEED REPAIRING WORK FOR COT [BEND]	Ekambaram. K.,Sundaramoorthy. G.,Sarathy. A.	COT REPAIRED.		Subashini. D. - Gynac Ward	01/04/2023
		Dept Name : FORENSIC MEDICINE - Work Shop Comp. Dt. : 15/07/2022 Status : Completed						
1297	22070571	FORENSIC MEDICINE (3RD FLOOR) IN COLLEGE	NEED TO REFIX CLASS ROOM WINDOW GLASS DOOR BROKE - DUE TO CLASS GOING ON NEED URGENT SERVICE	Ekambaram. K.	Window glass door repaired and refixed, work completed		Mathavi. B. - FORENSIC MEDICINE	01/08/2022
		Dept Name : Gas Power Plant - Work Shop Comp. Dt. : 06/05/2022 Status : Completed						
1298	22050202	NEW GAS PLANT	NEED ALUMINIUM PARTICIAN DOOR WORK	Pachaimuthusamy. D.	Partition door refixed, problem solved		Mahi Mohan Ram.S. - Gas Power Plant	18/07/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 27/06/2022 Status : Completed								
1299	22060960	Gas Power Plant	NEED TO FIX A NEW PARTITION DOOR	Pachaimuthusamy. D.	Repeated complaint		Mahi Mohan Ram.S. - Gas Power Plant	20/07/2022
Comp. Dt. : 20/09/2022 Status : Completed								
1300	22090797	Gas Power Plant	NEED PAINTING WORK FOR CENTRALIZED PIPELINE AT "D" WING SIDE [PENDING]	Manimaran. A.	Painting work completed		Mahi Mohan Ram.S. - Gas Power Plant	12/10/2022
Comp. Dt. : 16/11/2022 Status : Completed								
1301	22110643	Gas Power Plant	MOSQUITO NET NEED TO BE REFIX	Ekambaram. K.	New fixed.		Mahi Mohan Ram.S. - Gas Power Plant	21/11/2022
Comp. Dt. : 02/01/2023 Status : Completed								
1302	23010003	Printing Press	GATE PAINTING WORK NEED TO DO	Manimaran. A.	Painting work completed		Mahi Mohan Ram.S. - Gas Power Plant	23/01/2023
Comp. Dt. : 04/01/2023 Status : Completed								
1303	23010158	Printing Press	REQUEST TO REDUCE OR RESIZE THE TABLE SIZE	Ekambaram. K.	New plywood fixed, work completed		Mahi Mohan Ram.S. - Gas Power Plant	23/01/2023
Comp. Dt. : 06/02/2023 Status : Completed								
1304	23020169	Printing Press	NEED TO FIX FOUNDATION BOLT FOR NEW PRINTING MACHINE	Ekambaram. K.	New printing machine bolt fixed and tightened, problem solved		Mahi Mohan Ram.S. - Gas Power Plant	16/02/2023
Comp. Dt. : 20/02/2023 Status : Completed								
1305	23020737	Gas Power Plant	NEED PAINTING WORK	Manimaran. A.	Pipe's Painting work completed		Mahi Mohan Ram.S. - Gas Power Plant	01/03/2023
Comp. Dt. : 04/05/2023 Status : Completed								
1306	23050127	Printing Press	NEED WORKSHOP TECHNICIAN FOR PINNING MACHINE FIXING WORK	Ekambaram. K., Sundaramoorthy. G., Pachaimuthusamy . D.	Wrong complaint		Mahi Mohan Ram.S. - Gas Power Plant	15/05/2023
Comp. Dt. : 25/05/2023 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1307	23050985	Gas Power Plant	NEED PAINTING WORK AND ON TOP THE NAME SHOULD BE WRITTEN FOR CYLINDERS	Manimaran. A.	NAME WRITTEN WITH PAINT		Mahi Mohan Ram.S. - Gas Power Plant	03/06/2023
Dept Name : General Surgery - Work Shop Comp. Dt. : 19/12/2022 Status : Completed								
1308	22120876	AUDITORIUM IN BASEMENT	NEED TO REMOVE BANNER AND HANDOVER THE BANNER IN SURGERY DEPARTMENT 2ND FLOOR	Manivannan. A.	Baner removed, work completed		Govardhanan. R. - General Surgery	30/12/2022
Dept Name : Guest House - Indian Bank - Work Shop Comp. Dt. : 19/05/2022 Status : Completed								
1309	22050716	Guest House - Indian Bank	NEED REPAIRING WORK FOR DOOR BUSH LOCK FOR ROOM NO 103 & 105	Ekambaram. K.	Door Bush fixed, problem solved		John. H. - Guest House - Indian Bank	28/05/2022
Comp. Dt. : 07/06/2022 Status : Completed								
1310	22060277	Guest House - Indian Bank	NEED TO REFIX & REPAIRING WORK FOR DOOR LOCK - PRESSURE NOT FIXED THE DOOR LOCK FOR 6 ROOMS	Ekambaram. K.	Door and door locker repaired and serviced and All work completed		John. H. - Guest House - Indian Bank	20/07/2022
Comp. Dt. : 23/06/2022 Status : Completed								
1311	22060851	Guest House - Indian Bank	NEED TO REFIX REST ROOM DOOR LOCK - LOCK BROKEN - ROOM NO 205	Pachaimuthusamy. D.	7M door stopper fixed, work completed		John. H. - Guest House - Indian Bank	02/07/2022
Comp. Dt. : 30/06/2022 Status : Completed								
1312	22061133	Guest House - Indian Bank	DUE TO FOREIGNERS VISIT - NEED TO CHECK ALL WORKSHOP RELATED ITEMS FOR ALL ROOMS	Pachaimuthusamy. D., Ekambaram. K., Sundaramoorthy. G.	All rooms JK white painting work completed		John. H. - Guest House - Indian Bank	05/07/2022
Comp. Dt. : 26/07/2022 Status : Completed								
1313	22070958	Guest House - Indian Bank	NEED TO CHANGE RECEPTION TABLE GLASS - BROKED	Pachaimuthusamy. D.	New glass fixed.		John. H. - Guest House - Indian Bank	24/09/2022
Comp. Dt. : 26/08/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1314	22080910	Guest House - Indian Bank	NEED REPAIRING WORK FOR DOOR HANDLE - BROKEN AT ROOM NO 205 & STORE ROOM	Ekambaram. K.	Lock repaired. New table glass fixed.		John. H. - Guest House - Indian Bank	09/09/2022
Comp. Dt. : 10/10/2022 Status : Completed								
1315	22100235	Guest House - Indian Bank	NEED REPAIRING WORK & FIX PATLOCK FOR RESTROOM DOOR FOR STORE ROOM	Ekambaram. K.	New Padlock fixed, problem solved		John. H. - Guest House - Indian Bank	16/11/2022
1316	22100243	Guest House - Indian Bank	NEED TO REPASTE MIRROR FRAME FOR ALL 12 ROOMS	Ekambaram. K.,Venkatesan. R.,Manivannan. A.	Mirror refixed, problem solved		John. H. - Guest House - Indian Bank	16/11/2022
Comp. Dt. : 16/12/2022 Status : Completed								
1317	22120761	Guest House - Indian Bank	SIGN BOARD NEED TO BE REFIX	Ekambaram. K.	Sign board fixed, work completed		John. H. - Guest House - Indian Bank	16/02/2023
Comp. Dt. : 16/03/2023 Status : Completed								
1318	23030649	Guest House - Indian Bank	TILES BROKEN NEED TOUCH UP WORK FOR ROOM NO 204 & 205 [RESTROOM ALSO]	Parivallal. P.	WORK COMPLETED		John. H. - Guest House - Indian Bank	23/03/2023
1319	23030650	Guest House - Indian Bank	NEED TO REFIX MOSQUITO NET FOR ALL RESTROOM [TOTAL 12 ROOMS]	Ekambaram. K.	MUSQUITO NET FIXED		John. H. - Guest House - Indian Bank	05/05/2023
Comp. Dt. : 02/05/2023 Status : Completed								
1320	23050056	Guest House - Indian Bank	NEED ENTRANCE ROOF TOP SETTING WORK	Pachaimuthusamy. D.,Ekambaram. K.,Sundaramoorthy. G.	Wrong complaint		John. H. - Guest House - Indian Bank	05/08/2023
Comp. Dt. : 06/06/2023 Status : Completed								
1321	23060203	Guest House - Indian Bank	NEED REPAIRING WORK FOR FALSE CEILING AND DOOR FOR ROOM NO 103 ,205 & 206	Ekambaram. K.	Work completed		John. H. - Guest House - Indian Bank	05/08/2023
Dept Name : Gynac Ward - Work Shop Comp. Dt. : 28/05/2022 Status : Completed								
1322	22051035	Obstetrics - Ward 207	NEED TO REFIX RESTROOM DOOR -	Ekambaram. K.	New pvc door fixed.		Sangeetha. J. - Gynac Ward	18/06/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 09/06/2022 Status : Completed								
1323	22060327	DENTAL OPD -2ND FLOOR	NEED TO FIX A NEW PHONE STAND	Ekambaram. K.	New phone stand fixed.		Amsavalli. S. - Gynac Ward	13/06/2022
Comp. Dt. : 30/06/2022 Status : Completed								
1324	22061113	Obstetrics - Ward 207	NEED TO REFIX SIDE RAILS	Sarathy. A.	Side rails refixed		Ashwini. V. - Gynac Ward	05/07/2022
Comp. Dt. : 01/07/2022 Status : Completed								
1325	22070025	Obstetrics - Ward 208	NEED TO REFIX PATLOCK FOR NURSE'S CABIN DOOR	Ekambaram. K.	Pad lock refixed, problem solved		Sangeetha. J. - Gynac Ward	09/07/2022
Comp. Dt. : 08/07/2022 Status : Completed								
1326	22070296	Female Surgery	NEED TO FIX PATLOCK - WARD NO 205 & 206	Parthiban.K.	Pad lock fixed, problem solved		Ashwini. V. - Gynac Ward	16/07/2022
Comp. Dt. : 09/07/2022 Status : Completed								
1327	22070357	Female Surgery - Ward 205	NEED TO REFIX BUSH FOR PATIENT STOOL & LOCKER - 23 NOS	Sarathy. A.	bush fixed in stool and locker.		Ashwini. V. - Gynac Ward	20/07/2022
Comp. Dt. : 14/07/2022 Status : Completed								
1328	22070539	Labour Room	PROBLEM IN PATIENT STRUCTURE WHEEL	Sarathy. A.	Structure wheel changed, problem solved		Kanimozhi. S. - Labour Ward	01/08/2022
Comp. Dt. : 23/08/2022 Status : Completed								
1329	22080782	Obstetrics - Ward 208	NEED REPAIRING WORK FOR PHOTOTHERAPY WHEEL - WHEEL STUCK - NEED URGENT SERVICE	Sarathy. A.	Wheel repaired, problem solved		Divya. K. - Gynac Ward	01/09/2022
Comp. Dt. : 24/08/2022 Status : Completed								
1330	22080790	Obstetrics - Ward 207	NEED TO REFIX HEIGHT SCALE STAND	Manivannan. A.	Height scale fixed.		Ashwini. V. - Gynac Ward	09/09/2022
Comp. Dt. : 25/08/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1331	22080828	Obstetrics	NEED REFIX & REPAIRING WORK FOR NURSE'S CABIN , MEDICINE & WHEEL CHAIR TROLLEY & SCREEN SPRING FOR	Ekambaram. K.,Venkatesan. R.,Sundaramoorthy. G.	Wheel chair repaired. 3 fold screen / bush fixed.		Ashwini. V. - Gynac Ward	09/09/2022
Comp. Dt. :		28/09/2022						
Status :		Completed						
1332	22091129	Obstetrics - Ward 208	NEED REPAIRING & PAINTING WORK FOR CHEATLE FORCEPS , FOOT STOOL & TROLLEY	Manimaran. A.	Painting work completed		Ashwini. V. - Gynac Ward	08/10/2022
Comp. Dt. :		18/11/2022						
Status :		Completed						
1333	22110775	Female Surgery - Ward 206	TILES BROKEN - NEED TOUCH UP WORK	Murugavel	12Nos of Tiles refixed, JK White cement pointing work completed		Ashwini. V. - Gynac Ward	01/12/2022
Comp. Dt. :		09/12/2022						
Status :		Completed						
1334	22120434	Obstetrics - Ward 208	NEED REPAIRING WORK FOR DOOR LOCK - LOCK BROKEN	Ekambaram. K.	Door and door lock repaired and serviced, problem solved		Ashwini. V. - Gynac Ward	19/12/2022
Comp. Dt. :		31/12/2022						
Status :		Completed						
1335	22121392	Gynaecology - Ward 209	IV GRANULATION TROLLY PAINTING WORK NEED TO DO	Manimaran. A.	Trolley painting work completed		Sangeetha. J. - Gynac Ward	05/01/2023
Comp. Dt. :		06/01/2023						
Status :		Completed						
1336	23010289	Obstetrics - Ward 207	(1223) STERILLIUM BOX CUTTING WORK	Sarathy. A.	10 nos box cutting work completed.		Sangeetha. J. - Gynac Ward	11/01/2023
Comp. Dt. :		10/01/2023						
Status :		Completed						
1337	23010381	SPECIAL WARD -C IN FOURTH FLOOR	SCREEN ROD REPAIR WORK	Ekambaram. K.	New screen rod fixed, problem solved		Ashwini. V. - Gynac Ward	23/01/2023
Dept Name :		Hospital Infection Control - Work Shop						
Comp. Dt. :		10/10/2022						
Status :		Completed						
1338	22100234	PHYSIOTHERAPY ROOM IN 4TH FLOOR	NEED TO REMOVE BLACK SHEET AT PASTED IN DOOR . ALSO NEED PAINTING WORK	Manimaran. A.	Sticker removed, painting work completed		Mohana. M. - Hospital Infection Control	20/10/2022

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 28/10/2022 Status : Completed								
1339	22100917	HICC ROOM IN 4TH FLOOR-403	FLOOR TILES WHITE CEMENT PACKAGING WORK NEED TO DO	Murugavel	JK white applied and painting work completed.		Anitha. N. - Hospital Infection Control	03/11/2022
Comp. Dt. : 09/11/2022 Status : Completed								
1340	22110334	Infection Control	NEED TO CHECK DOOR LOCK PROBLEM IN 4TH FLOOR HOSPITAL INFECTION CONTROL DEPARTMENT	Parthiban.K.	Door lock changed, problem solved		Mohana. M. - Hospital Infection Control	18/11/2022
Comp. Dt. : 10/11/2022 Status : Completed								
1341	22110437	HICC ROOM IN 4TH FLOOR-403	BOARD FIXING WORK NEED TO DO	Ekambaram. K.	Board fixed, problem solved		Mohana. M. - Hospital Infection Control	18/11/2022
Comp. Dt. : 24/11/2022 Status : Completed								
1342	22111030	HICC ROOM IN 4TH FLOOR-403	TISSUE HANGING BOX NEED TO BE FIX AND MIRROR NEED TO BE FIX	Ekambaram. K.	Box and mirror refixed, problem solved		Mohana. M. - Hospital Infection Control	01/12/2022
Comp. Dt. : 07/12/2022 Status : Completed								
1343	22120326	HICC ROOM IN 4TH FLOOR-403	NEED TO REFIX WINDOW SCREEN SPRING	Ekambaram. K.	Spring fixed, problem solved		Mohana. M. - Hospital Infection Control	19/12/2022
1344	22120327	HICC ROOM IN 4TH FLOOR-403	NEED REPAIRING WORK FOR MAIN DOOR & DOOR LOCK - NOT WORKING	Ekambaram. K.	Door repaired and serviced, problem solved		Mohana. M. - Hospital Infection Control	19/12/2022
Comp. Dt. : 01/03/2023 Status : Completed								
1345	23030010	Infection Control	4TH FLOOR --NEED TO FIX ONE BOARD ON THE WALL	Ekambaram. K.	Board fixed		Mohana. M. - Hospital Infection Control	09/03/2023
Comp. Dt. : 03/03/2023 Status : Completed								
1346	23030151	Male Ortho - Ward 403	NEED TO REFIX WHITE BOARD	Ekambaram. K.	White board fixed, problem solved		Saranya. S. - Hospital Infection Control	09/03/2023
Comp. Dt. : 06/05/2023 Status : Completed								
1347	23050232	H I C - IV FLOOR INSIDE 403	NEED TO REFIX DRESS HANGER	Ekambaram. K.	hanger fixed, work completed		Anitha. N. - Hospital Infection Control	15/05/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Dept Name : Housekeeping - Work Shop Comp. Dt. : 09/05/2022 Status : Completed								
1348	22050292	OPD	NEED TO REFIX HANGER FOR ALL OPD RESTROOMS	Ekambaram. K.	Inform to Plumbing dept		Elangchezhiyan. R. - Housekeeping	26/05/2022
1349	22050295	Special Ward - C	NEED TO REFIX COMMON REST ROOM DOOR - BROKEN	Ekambaram. K.	Rest room door refixed, now problem solved		Ayyappan. K. - Housekeeping	18/05/2022
Comp. Dt. : 14/05/2022 Status : Completed								
1350	22050502	1st floor	AERO MARK BOARD PASTING WORK	Pachaimuthusamy. D.	Board fixed.		Balasubramaniyam. G. - Housekeeping	18/06/2022
Comp. Dt. : 16/05/2022 Status : Completed								
1351	22050553	Reception	NEED TO CHECK MAIN DOOR [GLASS DOOR] AT RECEPTION	Pachaimuthusamy. D.	Inform to AGM, civil admin office work with support service		Elangchezhiyan. R. - Housekeeping	27/05/2022
Comp. Dt. : 17/05/2022 Status : Completed								
1352	22050623	Obstetrics - Ward 208	NEED TO REFIX REST ROOM DOOR - BROKEN	Ekambaram. K.	Door hinges refixed, problem solved		Balasubramaniyam. G. - Housekeeping	27/05/2022
1353	22050624	HOSPITAL I FLOOR OPP TO LIFT 1	NEED TO REFIX ARROW MARK BOARD AT I FLOOR STEPS NEAR CENTER LEFT	Ekambaram. K.	board fixed.		Balasubramaniyam. G. - Housekeeping	18/06/2022
Comp. Dt. : 24/05/2022 Status : Completed								
1354	22050883	Female Medical - Ward 306	TAILS BROKEN - NEED TOUCHUP WORK AT ENTRANCE	Murugavel	Tiles refixed, JK White cement pointing work completed		Elangchezhiyan. R. - Housekeeping	28/05/2022
Comp. Dt. : 03/06/2022 Status : Completed								
1355	22060109	Main OT	COMMON RESTROOM DUCT DOOR BROKENED - NEED URGENT SERVICE [INSIDE ORTHO OT]	Ekambaram. K.	Door closed.		Naresh. R - Housekeeping	10/06/2022
Comp. Dt. : 22/06/2022 Status : Completed								
1356	22060806	COMMON FEMALE TOILET NEAR BIOCHEMISTRY	NEED REPAIRING WORK FOR RESTROOM DOOR - BROKEN	Ekambaram. K.	New Pad lock fixed, work completed		Elangchezhiyan. R. - Housekeeping	02/07/2022
Comp. Dt. : 25/06/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1357	22060929	Main Lobby	MARBLE BROKEN & CRACK - NEED TOUCH UP WORK AT MAIN PORTICO	Murugavel	Marble fixed		Vengadesan. K. - Housekeeping	05/07/2022
		Comp. Dt. : 08/07/2022 Status : Completed						
1358	22070298	ORTHO OT	NEED TO REFIX WASH BASIN MIRROR AT COMMON MALE REST ROOM	Parthiban.K.	Wrong complaint		Elangchezhiyan. R. - Housekeeping	18/07/2022
		Comp. Dt. : 14/07/2022 Status : Completed						
1359	22070562	Male Surgery - Ward 202	NEED REPAIRING WORK FOR RESTROOM DOOR	Ekambaram. K.	Restroom door repaired and serviced, problem solved		Balasubramaniyam. G. - Housekeeping	01/08/2022
1360	22070563	PSYCHIATRY WARD	MARBLES & TILES DAMAGE & BROKE AT 405 CARITOR & RESTROOM - NEED TOUCH UP WORK	Murugavel	Damage tiles refixed, JK white cement pointing work done, work completed		Ayyappan. K. - Housekeeping	01/08/2022
		Comp. Dt. : 21/07/2022 Status : Completed						
1361	22070796	Obstetrics - Ward 208	NEED REPAIRING WORK FOR RESTROOM DOOR	Parthiban.K.	Rest room door repaired and refixed, work completed		Balasubramaniyam. G. - Housekeeping	01/08/2022
		Comp. Dt. : 27/07/2022 Status : Completed						
1362	22071017	Male Surgery - Ward 202	NEED REPAIRING WORK FOR RESTROOM DOOR - BROKEN	Ekambaram. K.	Door repaired and refixed in properly, problem solved		Balasubramaniyam. G. - Housekeeping	05/08/2022
		Comp. Dt. : 01/08/2022 Status : Completed						
1363	22080026	Surgery OPD	NEED TO REFIX WHEEL CHAIR WHEEL BELT	Sarathy. A.	New Belt fixed, problem solved		Indirani. S. - Housekeeping	08/08/2022
		Comp. Dt. : 02/08/2022 Status : Completed						
1364	22080084	New OT	NEED TO CHECK PATIENT STRUCTURE - NEED TO REFIX SIDE RAILS & SCREW'S	Parthiban.K.	Patient structure - Side rails, belt and screw refixed, work completed		Balasubramaniyam. G. - Housekeeping	08/08/2022
		Comp. Dt. : 06/08/2022 Status : Completed						
1365	22080239	Male Ortho - Ward 403	PILLAR MARBLES DAMAGE & BROKEN - NEED TOUCHUP WORK	Murugavel	Masion work completed		Ayyappan. K. - Housekeeping	17/08/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 11/08/2022 Status : Completed								
1366	22080424	BASEMENT AUDITORIUM	NEED TO REFIX DOOR STOPER	Ekambaram. K.	New Door stopper changed, problem solved		Elangchezhiyan. R. - Housekeeping	23/08/2022
Comp. Dt. : 19/08/2022 Status : Completed								
1367	22080647	COMMON TOILET NEAR FREE PHARMACY	MALE SIDE-BATHROOM DOOR BROKEN	Ekambaram. K.	Door hinges fixed, problem solved		Elangchezhiyan. R. - Housekeeping	26/08/2022
Comp. Dt. : 20/08/2022 Status : Completed								
1368	22080673	COMMON TOILET NEAR MEDICINE OPD	NEED REPAIRING WORK FOR RESTROOM DOOR - BROKEN	Ekambaram. K.	Door hinges fixed, problem solved		Vengadesan. K. - Housekeeping	26/08/2022
Comp. Dt. : 22/08/2022 Status : Completed								
1369	22080716	Obstetrics - Ward 208	NEED CEMENT WORK	Murugavel	Masion work completed		Balasubramaniyam. G. - Housekeeping	01/09/2022
Comp. Dt. : 24/08/2022 Status : Completed								
1370	22080804	Obstetrics - Ward 208	NEED TO CHECK WESTERN RESTROOM FLOOR - WATER BLOCK	Murugavel	work complaint.		Balasubramaniyam. G. - Housekeeping	09/09/2022
Comp. Dt. : 25/08/2022 Status : Completed								
1371	22080847	SUPER SPECILAITY OPD IN 2ND FLOOR	NEED REPAIRING WORK FOR MAIN ENTRANCE DOOR LOCK - NOT WORKING [SUPER SPECILAITY OT]	Ekambaram. K.	Door repaired.		Elangchezhiyan. R. - Housekeeping	09/09/2022
Comp. Dt. : 27/08/2022 Status : Completed								
1372	22080953	Reception	FLOOR MARBILES BROKEN - NEED TOUCHUP WORK AT MAIN RECEPTION	Murugavel	Marbles fixed.		Elangchezhiyan. R. - Housekeeping	09/09/2022
Comp. Dt. : 10/09/2022 Status : Completed								
1373	22090405	Paediatrics Ward	NEED TO CHANGE PATLOCK FOR HOUSE KEEPING STORE ROOM DOOR AT WARD NO 309 & 310	Ekambaram. K.	New Pad lock fixed, problem solved		Naresh. R - Housekeeping	29/09/2022

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 14/09/2022								
Status : Completed								
1374	22090544	Male Medical - Ward 301	NEED TO REFIX RESTROOM DOOR AT COMMON RESTROOM - DOOR BROKEN	Pachaimuthusamy. D.	New door changed and refixed, problem solved		Naresh. R - Housekeeping	29/09/2022
1375	22090545	Female Ophthalmology - Ward 408	NEED TO REFIX RESTROOM DOOR AT COMMON RESTROOM - DOOR BROKEN	Pachaimuthusamy. D.	Door repaired and refixed, problem solved		Naresh. R - Housekeeping	29/09/2022
1376	22090567	SPECIAL WARD---B	NEED REPAIRING WORK FOR RESTROOM DOOR LOCK - ROOM NO B21-22-23	Ekambaram. K.	Rest room door lock repaired and serviced, problem solved		Ayyappan. K. - Housekeeping	29/09/2022
Comp. Dt. : 16/09/2022								
Status : Completed								
1377	22090657	RICU	PILLAR MARBLE DAMAGE NEED TOUCH UP WORK AT RICU ENTRANCE	Murugavel	Marble fixed, cement and JK white cement pointing work completed		Balasubramaniyam. G. - Housekeeping	29/09/2022
Comp. Dt. : 21/09/2022								
Status : Completed								
1378	22090852	BIOMEDICAL WASTAGE ROOM BACKSIDE OF COMMERCIAL COMPLEX	NEED CEMENT WORK FOR FLOOR - BROKEN	Murugavel	Flooring work completed		Ayyappan. K. - Housekeeping	29/09/2022
Comp. Dt. : 26/09/2022								
Status : Completed								
1379	22091013	Male Medical - Ward 301	NEED REPAIRING WORK FOR COMMON RESTROOM DOOR - BROKEN	Ekambaram. K., Sundaramoorthy. G., Venkatesan. R.	New Door changed, problem solved		Ayyappan. K. - Housekeeping	16/11/2022
Comp. Dt. : 15/10/2022								
Status : Completed								
1380	22100497	Boys hostel	NEED MATION WORK FOR EAST SIDE SHED	Murugavel	Masion work completed		Naresh. R - Housekeeping	21/10/2022
1381	22100502	Female surgery ward - 208	NEED REPAIRING WORK FOR RESTROOM DOOR LOCK	Ekambaram. K.	Door and door lock repaired, problem solved		Ayyappan. K. - Housekeeping	21/10/2022
Comp. Dt. : 19/10/2022								
Status : Completed								
1382	22100636	SPECIAL WARD---B	PILLAR MARBLES BROKEN IN SPECIAL WARD B OPPOSITE	Murugavel	Marbles fixed.		Ayyappan. K. - Housekeeping	29/10/2022
Comp. Dt. : 02/11/2022								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
1383	22110026	HOSPITAL CAMPUS	5 NO'S MOB HOLDER FIXING WORK	Sarathy. A.	Holder fixed, problem solved		Naresh. R - Housekeeping	16/11/2022
Comp. Dt. : 04/11/2022								
Status : Completed								
1384	22110156	TB AND CHEST WARD-405	FLOOR TILES PACKING WORK NEEDTO DO	Murugavel	Tiles fixed, JK White cement pointing work completed		Vengadesan. K. - Housekeeping	16/11/2022
Comp. Dt. : 14/11/2022								
Status : Completed								
1385	22110495	COMMON TOILET NEAR MEDICINE OPD	NEED TOUCHUP WORK FOR TILES & REPAIRING WORK FOR DOOR INSIDE LOCK AT FEMALE RESTROOM	Murugavel	Work completed.		Elangchezhiyan. R. - Housekeeping	21/11/2022
Comp. Dt. : 15/11/2022								
Status : Completed								
1386	22110607	Reception	IN ENTRANCE -MAIN GLASS DOOR NEED TO BE REPAIR	Ekambaram. K.	Door repaired.		Elangchezhiyan. R. - Housekeeping	21/11/2022
1387	22110615	COMMON TOILET NEAR FREE PHARMACY	IN LADIES TOILET-FLOOR TILES BROKEN,TOUCH UP WORK NEEDED	Murugavel	Lock repaired.		Elangchezhiyan. R. - Housekeeping	21/11/2022
Comp. Dt. : 16/11/2022								
Status : Completed								
1388	22110677	COMMON FEMALE RESTROOM NEAR ORTHO OPD	BATHROOM DOOR LOCK NEED TO BE REPAIR	Ekambaram. K.	Pad lock fixed.		Elangchezhiyan. R. - Housekeeping	21/11/2022
1389	22110678	COMMON TOILET NEAR OPHTAL OPD	MALE BATHROOM DOOR LOCK NEED TO BE REPAIR(2 ROOMS)	Ekambaram. K.	Pad lock fixed.		Elangchezhiyan. R. - Housekeeping	21/11/2022
1390	22110687	Casualty	OUTERSIDE-4 NO'S MESH DAMAGED	Ekambaram. K.	work completed.		Elangchezhiyan. R. - Housekeeping	21/11/2022
Comp. Dt. : 23/11/2022								
Status : Completed								
1391	22110990	COMMON TOILET NEAR OPHTAL OPD	LADIES TOILET-BATHROOM DOOR LOCK NEED TO BE REPAIR	Ekambaram. K.	Pad lock fixed, problem solved		Elangchezhiyan. R. - Housekeeping	01/12/2022
Comp. Dt. : 29/11/2022								
Status : Completed								
1392	22111256	COMMON TOILET NEAR MEDICINE OPD	FEMALE COMMON BATHROOM MAIN DOOR LOCK NEED TO BE FIX	Ekambaram. K.	New door lock fixed, problem solved		Elangchezhiyan. R. - Housekeeping	06/12/2022

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHAKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 01/12/2022 Status : Completed								
1393	22120045	SPECIAL WARD - A1	MONITOR STAND DAMAGED & BROKEN NEED TO REFIX FOR ROOM NO.1	Ekambaram. K.	Stand refixed, problem solved		Elangchezhiyan. R. - Housekeeping	13/12/2022
Comp. Dt. : 02/12/2022 Status : Completed								
1394	22120054	IVF ART CLINIC-INSIDE OF OG OPD(NO.68)	NEED TO FIX NEW MOP HOLDER	Ekambaram. K.	Mop holder fixed.		Naresh. R - Housekeeping	10/12/2022
Comp. Dt. : 15/12/2022 Status : Completed								
1395	22120732	Male Surgery - Ward 202	NEED REPAIRING WORK FOR RESTROOM DOOR - BROKEN	Ekambaram. K.	Frame dremoved and new door fixed.		Balasubramaniyam. G. - Housekeeping	23/12/2022
Comp. Dt. : 20/01/2023 Status : Completed								
1396	23010718	TEMPLE [HOSPITAL]	TILES BROKEN - NEED TOUCHUP WORK FOR TEMPLE STEPS	Murugavel	8Nos of Tiles refixed, JK White cement pointing work completed		Ayyappan. K. - Housekeeping	30/01/2023
Comp. Dt. : 25/01/2023 Status : Completed								
1397	23010919	Female Ortho - Ward 401	NEED REPAIRING WORK FOR COMMON RESTROOM DOOR - BROKEN	Ekambaram. K.	Door repaired and serviced, problem solved		Elangchezhiyan. R. - Housekeeping	30/01/2023
Comp. Dt. : 08/02/2023 Status : Completed								
1398	23020285	Male Ortho - Ward 403	REST ROOM HANDLE BROKEN	Ekambaram. K.	Door handle changed, problem solved		Elangchezhiyan. R. - Housekeeping	16/02/2023
Comp. Dt. : 14/02/2023 Status : Completed								
1399	23020533	BIOMEDICAL WASTAGE ROOM - BACKSIDE OF ORTHO OPD	WALL DAMAGE & BROKEN - NEED CEMENT WORK	Murugavel	Wall brick work completed		Ayyappan. K. - Housekeeping	17/02/2023
1400	23020534	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	STEPS DAMAGE NEED TOUCHUP WORK - OPP TO 100	Murugavel	Wall plastering work completed		Ayyappan. K. - Housekeeping	17/02/2023
Comp. Dt. : 01/03/2023 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1401	23030017	Paediatrics - Ward 309	WALL TILES BROKEN - NEED TOUCH UP WORK AT DOCTOR'S ROOM	Murugavel	Tiles refixed, JK White cement pointing work completed		Balasubramaniam. G. - Housekeeping	09/03/2023
Comp. Dt. : 04/03/2023 Status : Completed								
1402	23030186	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	NEED CEILING WORK FOR STEPS	Murugavel	Mason work completed		Ayyappan. K. - Housekeeping	09/03/2023
1403	23030187	BIOMEDICAL WASTAGE ROOM - BACKSIDE OF ORTHO OPD	NEED CENEMT WORK FOR WALL	Murugavel	Mason work completed		Ayyappan. K. - Housekeeping	09/03/2023
Comp. Dt. : 09/03/2023 Status : Completed								
1404	23030379	Hospital	NEED REPAIRING & PAINTING WORK FOR SANITARY STAND 2NOS	Manimaran. A.	PAINTING WORK COMPLETED		Balasubramaniam. G. - Housekeeping	04/05/2023
Comp. Dt. : 16/03/2023 Status : Completed								
1405	23030652	SPECIAL WARD---B	NEED REPAIRING WORK FOR RESTROOM DOOR LOCK - DAMAGE - COMMON RESTROOM	Ekambaram. K.	RESTROOM LOCK FIXED.		Elangchezhiyan. R. - Housekeeping	23/03/2023
Comp. Dt. : 20/03/2023 Status : Completed								
1406	23030793	Male Psychiatry - Ward 405	NEED REPAIRING WORK FOR RESTROOM DOOR - BROKEN AT 405 & 406	Ekambaram. K.	Rest room door refixed		Elangchezhiyan. R. - Housekeeping	31/03/2023
Comp. Dt. : 21/03/2023 Status : Completed								
1407	23030842	SPECIAL WARD - A1	NEED TO REFIX STEEL PIPE CLAMP - OPP TO SPECIAL WARD A1	Ekambaram. K.	Wrong complaint		Vengadesan. K. - Housekeeping	31/03/2023
Comp. Dt. : 24/03/2023 Status : Completed								
1408	23031026	Surgery OPD	DUE TO ENTER OF RAT AND INSECTS NEED CEMENT WORK FOR CLOSING HOLE AT DEMOROOM	Sankar. T. M.	WORK COMPLETED		Elangchezhiyan. R. - Housekeeping	01/04/2023
Comp. Dt. : 27/03/2023 Status : Completed								
1409	23031122	New OT	NEED TO REFIX " EXIT " BOARD	Ekambaram. K.	BOARD FIXED.		Elangchezhiyan. R. - Housekeeping	01/04/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 31/03/2023 Status : Completed								
1410	23031338	Ophthalmology - OPD	NEED REPAIRING WORK FOR GLASS DOOR - OPD LEFT SIDE	Ekambaram. K.	Glass door fixed, work completed		Balasubramaniyam. G. - Housekeeping	13/04/2023
Comp. Dt. : 12/04/2023 Status : Completed								
1411	23040370	SPECIAL WARD---B	PILLAR SIDE MARBLE BROKEN - NEED TOUCH UP WORK AT OPP TO SPECIAL WARD " B "	Parivallal. P.	marble fixed, cement pointing work completed		Ayyappan. K. - Housekeeping	20/04/2023
1412	23040379	CSSD	NEED TO REFIX TILES [3NOS] FOR CEMENT TANK	Parivallal. P.	Tiles refixed, JK white cement pointing work completed		Balasubramaniyam. G. - Housekeeping	20/04/2023
Comp. Dt. : 17/04/2023 Status : Completed								
1413	23040507	HOSPITAL III FLOOR	NEED TO CHANGE [REPLACE] HANGER FOR ATTENDER DRESS CHANGING ROOM FROM WARD NO 309 & 310 TO WARD NO	Ekambaram. K.	HANGER REFIXED		Elangchezhiyan. R. - Housekeeping	02/05/2023
Comp. Dt. : 19/04/2023 Status : Completed								
1414	23040575	HOSPITAL III FLOOR	PILLAR MARBLES BROKEN NEED TOUCHUP WORK - [OPPOSITE TO LIFT NO 5]	Parivallal. P.	MARBLE REFIXED		Vengadesan. K. - Housekeeping	02/05/2023
Comp. Dt. : 24/04/2023 Status : Completed								
1415	23040740	SPECIALITY OT	NEED TO FIT MAP HOLDER STAND [FROM OLD PLACE TO ANOTHER PLACE]	Ekambaram. K.	BOARD FIXED.		Ayyappan. K. - Housekeeping	02/05/2023
Comp. Dt. : 25/04/2023 Status : Completed								
1416	23040811	Pay Pharmacy	NEED REPAIRING WORK FOR GLASS DOOR - BETWEEN PAY PHARMACY AND OPPOSITE OPTICAL SHOP	Ekambaram. K.	DOOR REPAIRED.		Balasubramaniyam. G. - Housekeeping	02/05/2023
Comp. Dt. : 05/05/2023 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1417	23050188	TEMPLE [HOSPITAL]	NEED REPAIRING WORK FOR TEMPLE DOOR HANDLE - BROKEN	Ekambaram. K.	Door repaired and handle fixed, problem solved		Elangchezhiyan. R. - Housekeeping	15/05/2023
Comp. Dt. : 09/05/2023 Status : Completed								
1418	23050385	COMMON TOILET NEAR OPHTAL OPD	TILES AIRLOCK - WATER BLOCK NEED TO CLEAR AT COMMON MALE RESTROOM	Parivallal. P.	WRONG COMPLAINT		Balasubramaniyam. G. - Housekeeping	18/05/2023
Comp. Dt. : 20/05/2023 Status : Completed								
1419	23050845	ENT WARD	TILES BROKEN - NEED TOUCHUP WORK AT CARITOR	Manimaran. A.	8 NOS TILES FIXED.		Vengadesan. K. - Housekeeping	01/06/2023
Comp. Dt. : 16/06/2023 Status : Completed								
1420	23060598	Reception	TILES BROKEN.TOUCH UP WORK	Parivallal. P.	Tiles fixed and JK white applied.		Balasubramaniyam. G. - Housekeeping	27/06/2023
1421	23060599	COMMON TOILET NEAR FREE PHARMACY	TILES BROKEN.TOUCH UP WORK	Parivallal. P.	Tiles fixed and JK white applied.		Balasubramaniyam. G. - Housekeeping	27/06/2023
Comp. Dt. : 21/06/2023 Status : Completed								
1422	23060782	Reception	NEED TO CHECK FLOOR TILES - AIR CRACK - BROKEN -NEED TOUCH UP WORK	Parivallal. P.	Work completed		Balasubramaniyam. G. - Housekeeping	27/06/2023
Comp. Dt. : 23/06/2023 Status : Completed								
1423	23060862	Male Ortho - Ward 404	NEED ADJUSTMENT FOR COT SCREW - DAMAGE & UNFIX	Sarathy. A.	Work completed		Elangchezhiyan. R. - Housekeeping	07/07/2023
1424	23060880	COMMON MALE TOILET NEAR ORTHO OPD	TILES BROKEN - NEED TOUCH UP WORK	Parivallal. P.	Tiles refixed.		Balasubramaniyam. G. - Housekeeping	07/07/2023
Dept Name : ICCU - Work Shop Comp. Dt. : 09/05/2022 Status : Completed								
1425	22050307	ICCU	NEED TO REFIX MAIN DOOR - BROKEN - NEED URGENT SERVICE	Ekambaram. K.	Main door refixed, problem solved		Saradha. G. - ICCU	18/05/2022
Comp. Dt. : 21/05/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1426	22050785	ICCU	SIDE RAILS NOT WORKING IN PLAN STRUCTURE	Sarathy. A.	Bed side rails nob refixed, problem solved		Ammu. R. - ICCU	28/05/2022
	Comp. Dt. : 26/05/2022							
	Status : Completed							
1427	22050982	ICCU	NEED TO REFIX WHEELCHAIR TYRE - DAMAGE & NOT WORKING	Sarathy. A.	4nos new wheel fixed.		Ammu. R. - ICCU	18/06/2022
	Comp. Dt. : 07/07/2022							
	Status : Completed							
1428	22070291	Mit ladies hostel	NEED WELDING WORK FOR FIXING HAND TOWEL STAND AT GROUND FLOOR REST ROOM [STAF SIDE]	Sarathy. A.	Towel stand welding work completed		Ammu. R. - ICCU	18/07/2022
	Comp. Dt. : 17/08/2022							
	Status : Completed							
1429	22080494	ICCU	DOOR GLASS BROKEN	Parthiban.K.	New Glass fixed, work completed		Ammu. R. - ICCU	26/08/2022
	Comp. Dt. : 25/08/2022							
	Status : Completed							
1430	22080835	Mit ladies hostel	NEED WELDING WORK FOR SOAP TOWEL STAND AT GROUND FLOOR RESTROOM [STAFF SIDE]	Venkatesan. R.	Work completed.		Ammu. R. - ICCU	09/09/2022
	Comp. Dt. : 02/09/2022							
	Status : Completed							
1431	22090112	ICCU	WHEEL CHAIR BROKEN	Sarathy. A.	Wheel chair wheel repaired and refixed, problem solved		Ammu. R. - ICCU	12/10/2022
	Comp. Dt. : 08/09/2022							
	Status : Completed							
1432	22090330	ICCU	NEED REPAIRING WORK FOR PATIENT LOCKER	Ekambaram. K.,Venkatesan. R.,Manivannan. A.	Locker key welded, work completed		Ammu. R. - ICCU	29/09/2022
	Comp. Dt. : 19/09/2022							
	Status : Completed							
1433	22090696*	Main Gate	NEED REPAIRING WORK FOR ENTRANCE GATE	Sarathy. A.	Gate grilled and repaired, problem solved		Saradha. G. - ICCU	20/10/2022
	Comp. Dt. : 22/09/2022							
	Status : Completed							


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1434	22090884*	ICCU	CLOSING PROBLEM IN MAIN DOOR - NEED REPAIRING WORK	Ekambaram. K.,Venkatesan. R.,Sundaramoorthy. G.	Door repaired and serviced, problem solved		Saradha. G. - ICCU	20/10/2022
	Comp. Dt. :	31/10/2022						
	Status :	Completed						
1435	22101002	RICU	DOOR HANDLE BROKEN	Ekambaram. K.	New door handle changed, problem solved		Ravivarma. P. - ICCU	08/11/2022
	Comp. Dt. :	05/11/2022						
	Status :	Completed						
1436	22110162	ICCU	FRIDGE STAND BROKEN	Sarathy. A.	Stand repaired and welded, problem solved		Saradha. G. - ICCU	16/11/2022
	Comp. Dt. :	19/11/2022						
	Status :	Completed						
1437	22110807	ICCU	NEED REPAIRING WORK FOR FRIDGE STAND UNBALANCE	Ekambaram. K.	Fridge stand repaired, problem solved		Ammu. R. - ICCU	01/12/2022
	Comp. Dt. :	05/12/2022						
	Status :	Completed						
1438	22120211	ICCU	COT SIDE RAILS LOCK NEED TO BE REFIX TIGHTLY	Ekambaram. K.	Side rail fixed.		Ammu. R. - ICCU	10/12/2022
	Comp. Dt. :	14/12/2022						
	Status :	Completed						
1439	22120641	ICCU	COT SIDE RAILS NOT WORKING STUCK	Sarathy. A.	side rail refixed.		Saradha. G. - ICCU	23/12/2022
	Comp. Dt. :	20/12/2022						
	Status :	Completed						
1440	22120907	Mit ladies hostel	BATHROOM DOOR NOT CLOSING	Ekambaram. K.,Sundaramoorthy. G.,Pachaimuthusamy . D.	Bathroom door repaired and refixed in properly, problem solved		Ammu. R. - ICCU	23/01/2023
	Comp. Dt. :	22/12/2022						
	Status :	Completed						
1441	22121024	ICCU	NEED LABOURS FOR CART SHIFTING WORK - 2 NOS	Ganesan. A.	Wrong complaint, inform to maintenance dept		Ammu. R. - ICCU	29/12/2022
	Comp. Dt. :	02/01/2023						
	Status :	Completed						
1442	23010019	ICCU	DOOR CLOSER NOISE PROBLEM	Ekambaram. K.	New Door closer fixed, problem solved		Saradha. G. - ICCU	12/01/2023

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 27/01/2023 Status : Completed								
1443	23010978	Mit ladies hostel	NEED REPAIRING WORK FOR REST ROOM DOOR - BROKEN AT GROUND FLOOR [STAFF SIDE]	Ekambaram. K.	Door refixed in properly, problem solved		Ammu. R. - ICCU	30/01/2023
Comp. Dt. : 06/02/2023 Status : Completed								
1444	23020182	ICCU	NEED PAINTING WORK FOR WOODEN BOX , IV STAND & FOOT STOOL	Sundaramoorthy. K.,Veerappan. D.,Moorthy. L.	All wooden box, IV Stand and Foot stool - painting work completed		Ammu. R. - ICCU	16/02/2023
1445	23020183	ICCU	NEED REPAIRING & REFIX WORK FOR RESTROOM DOOR LOCK & RESTROOM HAND WASH STAND AT GROUND FLOOR [STAF	Ekambaram. K.	Door lock refixed in properly		Ammu. R. - ICCU	16/02/2023
Comp. Dt. : 08/02/2023 Status : Completed								
1446	23020275	ICCU	DOOR LOCK PROBLEM	Ekambaram. K.	New door lock fixed		Ammu. R. - ICCU	16/02/2023
Comp. Dt. : 17/02/2023 Status : Completed								
1447	23020666	ICCU	NEED PAINTING WORK FOR IV STAND , FOOT STOOL & WOODEN BOX	Manimaran. A.	All things painting work completed		Ammu. R. - ICCU	23/02/2023
Comp. Dt. : 18/02/2023 Status : Completed								
1448	23020719	ICCU	NEED TO REFIX SIDE RAILS FOR COT	Sarathy. A.	Cot side rail refixed in properly, problem solved		Ammu. R. - ICCU	23/02/2023
Comp. Dt. : 21/02/2023 Status : Completed								
1449	23020808	ICCU	NEED PAINTING WORK FOR WOODEN BOX 12NOS	Manimaran. A.	12Nos of boxes painted, work completed		Ammu. R. - ICCU	01/03/2023
Comp. Dt. : 27/02/2023 Status : Completed								
1450	23021002	ICU	NEED REPAIRING WORK FOR DOOR 0 NEED URGENT SERVICE AT - ICU EXTN	Ekambaram. K.	DOOR REPAIRED		Ravivarma. P. - ICCU	07/03/2023
Comp. Dt. : 01/03/2023 Status : Completed								
1451	23030002	ICCU	NEED TO REFIX CLOTH DRYING STAND CLAMP	Ekambaram. K.	Stand refixed, work completed		Ammu. R. - ICCU	09/03/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 10/03/2023		Status : Completed						
1452	23030398	Mit ladies hostel	NEED PAINTING WORK FOR ROOM NO 1	Manimaran. A.	WORK COMPLETED		Ammu. R. - ICCU	23/03/2023
1453	23030399	Mit ladies hostel	NEED REPAIRING WORK FOR RESTROOM LOCK [STAFF SIDE]	Ekambaram. K.	WORK COMPLETED		Ammu. R. - ICCU	23/03/2023
1454	23030400	Mit ladies hostel	NEED TO FIX HAND WASH STAND	Ekambaram. K.	WORK COMPLETED		Ammu. R. - ICCU	23/03/2023
1455	23030401	Mit ladies hostel	NEED TO REFIX CUPBOARD LOCK 5 NOS	Ekambaram. K.	WORK COMPLETED		Ammu. R. - ICCU	23/03/2023
Comp. Dt. : 16/03/2023		Status : Completed						
1456	23030633	ICCU	NEED TO REFIX COT SIDE RAILS SCREW	Sarathy. A.	SIDE RAIL FIXED.		Ammu. R. - ICCU	23/03/2023
Comp. Dt. : 08/04/2023		Status : Completed						
1457	23040250	ICCU	NEED REPAIRING WORK FOR DOOR - REFIX DOOR STOPER - SOUND PROBLEM	Ekambaram. K.	Door and door stopper repaired and serviced, problem solved		Ammu. R. - ICCU	20/04/2023
Comp. Dt. : 10/04/2023		Status : Completed						
1458	23040264	ICCU	NEED REPAIRING WORK FOR DOOR - SOUND PROBLEM	Ekambaram. K.	Door repaired and serviced, problem solved		Ammu. R. - ICCU	20/04/2023
Comp. Dt. : 17/04/2023		Status : Completed						
1459	23040490	ICCU	NEED REPAIRING WORK FOR ICU & ICCU MAIN DOOR - SOUND PROBLEM	Ekambaram. K.	DOOR SERVICED		Ammu. R. - ICCU	02/05/2023
Comp. Dt. : 20/04/2023		Status : Completed						
1460	23040676	ICCU	NEED REPAIRING WORK FOR DOOR - SOUND PROBLEM	Ekambaram. K.	REPEATED COMPLAINT		Suriyakala. A. - ICCU	02/05/2023
Comp. Dt. : 02/05/2023		Status : Completed						
1461	23050029	ICCU	NEED REPAIRING WORK FOR DOOR - SOUND PROBLEM	Ekambaram. K.	door repaired		Ammu. R. - ICCU	17/05/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 04/05/2023 Status : Completed								
1462	23050175	ICCU	NEED REPAIRING WORK FOR DOOR LOCK - PROBLEM	Ekambaram. K.	door repaired		Ravivarma. P. - ICCU	17/05/2023
Comp. Dt. : 29/05/2023 Status : Completed								
1463	23051124	ICCU	NEED REPAIRING WORK FOR DOOR	Ekambaram. K.	DOOR SERVICED.		Ammu. R. - ICCU	03/06/2023
Comp. Dt. : 30/05/2023 Status : Completed								
1464	23051182	ICCU	NEED PAINTING WORK FOR URINARY STAND	Manimaran. A.	5 nos stand painted		Ammu. R. - ICCU	20/06/2023
Comp. Dt. : 16/06/2023 Status : Completed								
1465	23060603	ICCU	COT RISER TIGHTENING POSITION	Sarathy. A.	Cot bold fixed.		Kamali. S. - ICCU	27/06/2023
Comp. Dt. : 27/06/2023 Status : Completed								
1466	23061031	ICCU	NEED REPAIRING WORK FOR COT - BROKEN	Sarathy. A.,Moorthy. L.,Veerappan. D.	Cot repaired.		Ammu. R. - ICCU	08/07/2023
Comp. Dt. : 28/06/2023 Status : Completed								
1467	23061057	ICCU	NEED TO CHANGE TROLLEY WHEEL - BROKEN	Sarathy. A.,Moorthy. L.,Veerappan. D.	Cot repaired.		Ammu. R. - ICCU	08/07/2023
Dept Name : ICU - Work Shop Comp. Dt. : 02/05/2022 Status : Completed								
1468	22050014	ICU	NEED REPAIRING WORK FOR ECHO MACHINE TROLLEY STAND & WHEEL - DAMAGE	Sarathy. A.	Trolley stnad and wheel welding work completed		Maheswaran. D. - ENT & Ophthal Ward	12/05/2022
Comp. Dt. : 04/05/2022 Status : Completed								
1469	22050078	ICU	NEED PAINTING WORK	Manimaran. A.	Stretcher, focus lamp and stool painting work completed		Latha. K. - ICU	12/05/2022
Comp. Dt. : 07/05/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1470	22050231	ICU	NEED REPAIRING WORK FORDRESSING TROLLEY WHEEL -	Sarathy. A.	Trolley wheel refixed, problem solved		Latha. K. - ICU	12/05/2022
	Comp. Dt. : 08/06/2022							
	Status : Completed							
1471	22060286	ICU	NEED TO REFIX PATIENT STRUCTURE SIDE RAILS	Venkatesan. R.	side rail fixed.		Latha. K. - ICU	13/06/2022
	Comp. Dt. : 27/06/2022							
	Status : Completed							
1472	22060946	ICU	NEED REPAIRING WORK FOR COT - BROKENED	Sarathy. A.	cot mechanism refixed		Latha. K. - ICU	05/07/2022
	Comp. Dt. : 23/07/2022							
	Status : Completed							
1473	22070871	ICU	PATIENT STRUCTURE WHEEL DAMAGE - NOT WORKING - NEED TO CHANGE	Sarathy. A.,Moorthy. L.,Sundaramoorthy. G.	Structure wheel refixed in properly, problem solved		Regina Mary. S. - ICU	05/08/2022
	Comp. Dt. : 30/07/2022							
	Status : Completed							
1474	22071105	ICU	NEED TO REFIX SAFETY BELT FOR PATIENT STRUCTURE & WHEEL CHAIR & SIDE RAILS	Sarathy. A.	Wheel chair and structure belt refixed and side rails are refixed in properly, problem solved		Jayabharathi. R. - ICU	05/08/2022
	Comp. Dt. : 12/09/2022							
	Status : Completed							
1475	22090462	ICU	NEED REPAIRING WORK FOR X RAY LOBBY MACHINE WHEEL - STUCK	Sarathy. A.,Sundaramoorthy. G.,Moorthy. L.	X-Ray machine wheel changed, problem solved		Regina Mary. S. - ICU	29/09/2022
	Comp. Dt. : 13/09/2022							
	Status : Completed							
1476	22090496	ICU	NEED REPAIRING WORK FOR PATIENT STRUCTURE WHEEL - STUCK	Sarathy. A.	Patient stretcher wheel changed, problem solved		Regina Mary. S. - ICU	29/09/2022
	Comp. Dt. : 19/09/2022							
	Status : Completed							
1477	22090753	ICU	NEED REPAIRING WORK FOR COT - BROKEN	Sarathy. A.	Cot wheel repaired, problem solved		Regina Mary. S. - ICU	29/09/2022
	Comp. Dt. : 22/09/2022							
	Status : Completed							


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1478	22090900	ICU	NEED TO CHANGE WHEEL FOR PATIENT STRUCTURE & TROLLEY	Sundaramoorthy. G.,Sarathy. A.,Moorthy. L.	Wheel changed, problem solved		Regina Mary. S. - ICU	08/10/2022
Comp. Dt. : 18/10/2022 Status : Completed								
1479	22100589	ICU	NEED TO FIX SCREW AND RESET ECHO MACHINE ALIGNMENT	Parthiban.K.,Ekambaram. K.,Manivannan. A.	Screw fixed.		Regina Mary. S. - ICU	29/10/2022
Comp. Dt. : 25/11/2022 Status : Completed								
1480	22111085	ICU	MONITOR STAND BROKEN	Sarathy. A.	Monitor stand fixed, problem solved		Regina Mary. S. - ICU	06/12/2022
Comp. Dt. : 10/12/2022 Status : Completed								
1481	22120486	ICU	O2 STRETCHER COT WHEEL NOT MOVING	Sarathy. A.	Stretcher wheel changed, problem solved		Rajeshwari. P. - ICU	19/12/2022
Comp. Dt. : 07/01/2023 Status : Completed								
1482	23010315	ICU	WARD FUMICATION WORK-REQUEST TO CHECK WHETHER ALL DOOR AND WINDOWS AND TABLE AND BERO CUOBOARDS ARE	Ekambaram. K.,Sundaramoorthy. G.,Pachaimuthusamy . D.	Work completed.		Regina Mary. S. - ICU	11/01/2023
Comp. Dt. : 10/01/2023 Status : Completed								
1483	23010389	ICU	MAIN DOOR NOISE PROBLEM	Ekambaram. K.	Door dismantled and refixed in properly		Regina Mary. S. - ICU	23/01/2023
Comp. Dt. : 03/02/2023 Status : Completed								
1484	23020088	ICU	NEED TO REFIX COT SIDE RAILS	Sarathy. A.	Cot side rails fixed, problem solved		Regina Mary. S. - ICU	11/02/2023
Comp. Dt. : 20/02/2023 Status : Completed								
1485	23020744	ICU	NEED TO REFIX HEAD END BOARD SCREW - DAMAGE & UNFIX	Ekambaram. K.	Board screw refixed, problem solved		Regina Mary. S. - ICU	01/03/2023
Comp. Dt. : 23/02/2023 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1486	23020903	ICU	NEED REPAIRING WORK FOR COT WHEEL - STUCK IN [EXTN ICU]	Sarathy. A.	Cot wheel repaired and serviced, problem solved		Latha. K. - ICU	01/03/2023
	Comp. Dt. : 25/02/2023							
	Status : Completed							
1487	23020967	ICU	NEED REPAIRING WORK FOR MEDICINE TROLLEY WHEEL , COT WHEEL, IV WHEEL [REFIX 25 NOS]	Sarathy. A.	WHEEL REPLACED		Regina Mary. S. - ICU	07/03/2023
	Comp. Dt. : 01/03/2023							
	Status : Completed							
1488	23030024	ICU	NED TO FIX NAIL	Ekambaram. K.	Nail fixed		Latha. K. - ICU	09/03/2023
	Comp. Dt. : 02/03/2023							
	Status : Completed							
1489	23030094	ICU	NEED REPAIRING WORK FOR STRETCHER WHEEL STUCK	Sarathy. A.	Stretcher wheel repaired and serviced, problem solved		Regina Mary. S. - ICU	09/03/2023
	Comp. Dt. : 06/03/2023							
	Status : Completed							
1490	23030214	ICU	NEED PAINTING WORK FOR COT [6NOS]	Manimaran. A.	COT PAINTED		Latha. K. - ICU	04/05/2023
	Comp. Dt. : 09/03/2023							
	Status : Completed							
1491	23030356	SPECIAL WARD---B	NEED TO REFIX DOOR STOPER	Ekambaram. K.	DOOR STOPPER FIXED.		Gogul. M. - ICU	23/03/2023
1492	23030368	ICU	NEED TO REFIX WALL MOUNTING SUCTION STAND	Ekambaram. K.	STAND FIXED.		Jayabharathi. R. - ICU	23/03/2023
	Comp. Dt. : 10/03/2023							
	Status : Completed							
1493	23030390	ICU	NEED REPAIRING WORK FOR COT - SIDE RAILS PROBLEM - NOT LOCKED	Ekambaram. K.	SIDE RAILS REPAIRED		Latha. K. - ICU	23/03/2023
	Comp. Dt. : 11/03/2023							
	Status : Completed							
1494	23030451	Female Surgery - Ward 206	NEED TO REFIX WHEEL CHAIR WHEEL - DAMAGE - STUCK	Sarathy. A.	WHEEL REPLACED		Suseela. R. - ICU	23/03/2023
	Comp. Dt. : 13/03/2023							
	Status : Completed							


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1495	23030480	Female Surgery - Ward 206	NEED REPAIRING WORK FOR IV LINE TROLLEY , MEDICINE TROLLEY & WHEEL CHAIR - WHEEL - STUCK	Sarathy. A.	WORK COMPLETED		Suseela. R. - ICU	23/03/2023
	Comp. Dt. : 15/03/2023							
	Status : Completed							
1496	23030600	ICU	NEED REPAIRING WORK FOR 3 FOLDER SCREEN WHEEL - STUCK	Sarathy. A.	WHEEL SERVICED.		Latha. K. - ICU	23/03/2023
	Comp. Dt. : 25/03/2023							
	Status : Completed							
1497	23031054	ICU	NEED REPAIRING WORK FOR MAIN ENTRANCE GATE - SOUND PROBLEM	Ekambaram. K.	MAIN DOOR REPAIRED.		Latha. K. - ICU	01/04/2023
	Comp. Dt. : 30/03/2023							
	Status : Completed							
1498	23031288	ICU	NEED MOSQUITO NET CUTTING WORK	Ekambaram. K.	Wrong complaint		Regina Mary. S. - ICU	13/04/2023
	Comp. Dt. : 04/04/2023							
	Status : Completed							
1499	23040088	Female Surgery - Ward 206	NEED REPAIRING WORK FOR CUPBOARD DOOR - BROKEN	Ekambaram. K.	Cupboard door repaired and refixed, problem solved		Suseela. R. - ICU	17/04/2023
	Comp. Dt. : 06/04/2023							
	Status : Completed							
1500	23040207	ICU	NEED TO REFIX COT SIDE RAILS - ICU II	Sarathy. A.	Cot side rails refixed, problem solved		Latha. K. - ICU	20/04/2023
	Comp. Dt. : 08/04/2023							
	Status : Completed							
1501	23040217	ICU	NEED REPAIRING WORK FOR MAIN DOOR	Ekambaram. K.	Main door repaired and refixed, problem solved		Jayabharathi. R. - ICU	20/04/2023
	Comp. Dt. : 15/04/2023							
	Status : Completed							
1502	23040452	ICU	NEED TO REFIX BED SIDE RAILS [5 COTS] - ICU -II	Ekambaram. K.,Sarathy. A.,Sundaramoorthy. G.	Snos of cot side rails fixed		Latha. K. - ICU	20/04/2023
	Comp. Dt. : 22/04/2023							
	Status : Completed							


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1503	23040694	ICU	NEED REPAIRING WORK FOR ICU DOOR - DAMAGE & DOCTOR'S ROOM INSIDE LOCK - LOCK NOT WORKING	Ekambaram. K.	REPEATED COMPLAINT		Latha. K. - ICU	02/05/2023
	Comp. Dt. : 29/04/2023							
	Status : Completed							
1504	23040997	ICU	U S G MACHINE PROBLEM - NEED CARPENDER	Ekambaram. K.	Machine screw fixed		Regina Mary. S. - ICU	08/05/2023
	Comp. Dt. : 03/05/2023							
	Status : Completed							
1505	23050081	Female Surgery - Ward 205	NEED REPAIRING WORK FOR CUPBOARD LOCK - BROKEN	Ekambaram. K.	lock fixed		Suseela. R. - ICU	17/05/2023
	Comp. Dt. : 11/05/2023							
	Status : Completed							
1506	23050431	ICU	NEED REPAIRING WORK FOR DOCTOR'S ROOM DOOR INSIDE	Ekambaram. K.	DOOR PADLOCK FIXED		Hemamalini. A. - ICU	18/05/2023
	Comp. Dt. : 12/05/2023							
	Status : Completed							
1507	23050474	ICU	COT FOOT BOARD BROKEN - NEED REPAIRING WORK FOR COT NO 4	Ekambaram. K.	BOARD FIXED		Latha. K. - ICU	18/05/2023
	Comp. Dt. : 16/05/2023							
	Status : Completed							
1508	23050631	ICU	NEED TO REFIX SCREW FOR WHEEL CHAIR WHEEL	Ekambaram. K.	Wheel chair screw fixed		Regina Mary. S. - ICU	23/05/2023
	Comp. Dt. : 17/05/2023							
	Status : Completed							
1509	23050672	ICU	NEED REPAIRING WORK FOR NURSE'S CABIN DOOR DAMAGE & BROKEN	Ekambaram. K.	NURSE'S CABIN DOOR FIXED.		Latha. K. - ICU	01/06/2023
	Comp. Dt. : 19/05/2023							
	Status : Completed							
1510	23050818	ICU	NEED REPAIRING WORK FOR COT SIDE RAILS - BROKEN	Ekambaram. K.	SIDE RAIL FIXED.		Jayabharathi. R. - ICU	01/06/2023
	Comp. Dt. : 29/05/2023							
	Status : Completed							


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1511	23051139	ICU	NEED REPAIRING WORK FOR CABIN LOCKER - LOCK NOT WORKING	Ekambaram. K.	LOCK REPAIRED		Regina Mary. S. - ICU	03/06/2023
Comp. Dt. : 30/05/2023 Status : Completed								
1512	23051189	ICU	NEED REPAIRING WORK FOR COT - COT FOOT END BOARD NOT ELEVATED	Sarathy. A.	Work completed		Regina Mary. S. - ICU	20/06/2023
Comp. Dt. : 10/06/2023 Status : Completed								
1513	23060371	ICU	NEED REPAIRING & REFIX WORK FOR O2 & NORMAL STRETCHER WHEEL & BELT	Sarathy. A.	New wheel replaced		Regina Mary. S. - ICU	20/06/2023
Comp. Dt. : 14/06/2023 Status : Completed								
1514	23060495	ICU	NEED REPAIRING WORK FOR MAIN ENTRANCE DOOR - STUCK	Ekambaram. K.	Door repaired.		Regina Mary. S. - ICU	27/06/2023
Comp. Dt. : 22/06/2023 Status : Completed								
1515	23060835	ICU	NEED URGENT SERVICE - U S G MACHINE WHEEL BROKEN & STUCK	Sarathy. A.	4 nos. new wheel 4" fixed.		Regina Mary. S. - ICU	07/07/2023
Comp. Dt. : 28/06/2023 Status : Completed								
1516	23061073	ICU	COT WHEEL STUCK	Sarathy. A.,Moorthy. L.,Veerappan. D.	3nos. screen pipe fixed.		Jayabharathi. R. - ICU	08/07/2023
Dept Name : Labour Ward - Work Shop Comp. Dt. : 07/05/2022 Status : Completed								
1517	22050244	ORTHO OT	NEED REPAIRING WORK FOR DOOR - SOUND - OPEN & CLOSE - NOT WORKING PROPERLY	Ekambaram. K.	Door repaired and refixed, problem solved		Mukeshkannan. M. - Operation Theatre	26/05/2022
Comp. Dt. : 30/05/2022 Status : Completed								
1518	22051109	labour room -pow	NEED TO REFIX COT SIDE RAILS	Sarathy. A.	Side rails fixed.		Thenmozhi. J. - labour Ward	10/06/2022
Comp. Dt. : 20/06/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1519	22060711	labour room -pow	NEED REPAIRING WORK FOR BERO HANDLE - BROKEN	Pachaimuthusamy. D.	Handle fixed		Thenmozhi. J. - Labour Ward	23/06/2022
	Comp. Dt. : 07/07/2022							
	Status : Completed							
1520	22070237	Labour Room	NEED TO REFIX BUSH & PAINTING WORK FOR IV STAND , SQUIRE STOOL & FOOT STOOL 8 NOS	Manimaran. A.	IV Stand, stool - Bush fixed and painting work completed		Sathiyavathi. S. - Labour Ward	18/07/2022
	Comp. Dt. : 18/07/2022							
	Status : Completed							
1521	22070668	SPECIALITY OT	NEED REPAIRING WORK FOR MAIN DOOR STOPPER - NOT WORKING	Ekambaram. K.	Door stopper refixed, problem solved		Dinesh. A. - Operation Theatre	01/08/2022
	Comp. Dt. : 27/07/2022							
	Status : Completed							
1522	22070991	Labour Room	NEED REPAIRING WORK FOR "S" TYPE CHAIR & REFIX SAFETY BELT FOR WHEEL CHAIR & PATIENT STRUCTURE		Structure and wheel chair belt refixed, side rails are refixed in properly		Usharani. A. - Labour Ward	05/08/2022
	Comp. Dt. : 17/08/2022							
	Status : Completed							
1523	22080553	labour room -pow	CHEATLE FORCEPS JAR BROKEN-WELDING WORK NEED TO DO	Sarathy. A.	Forceps jar welding work completed		Thenmozhi. J. - Labour Ward	26/08/2022
	Comp. Dt. : 18/08/2022							
	Status : Completed							
1524	22080583	Labour Room	DEIVERY COT NET RETIGHTING WORK NEED TO DO	Sarathy. A.	4Nos of cot side rail fixed, work completed		Krishnadevi. D. - Labour Ward	26/08/2022
	Comp. Dt. : 05/10/2022							
	Status : Completed							
1525	22100027	Labour Room	NEED TO CHANGE WARMER WHEEL - BROKEN	Sarathy. A.	4Nos of new wheel fixed, problem solved		Sathiyavathi. S. - Labour Ward	12/10/2022
	Comp. Dt. : 12/10/2022							
	Status : Completed							
1526	22100328	Labour Room	TABLE SCREW NEED TO BE FIXED (SCREW REMOVED)	Ekambaram. K.	Table screw, Wheel and bush fixed, work completed		Krishnadevi. D. - Labour Ward	20/10/2022
	Comp. Dt. : 17/10/2022							


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
1527	22100513	Labour Room	NEED TO CHECK & REFIX DELIVERY COT BOARD - DAMAGE & REFIX SCREW	Ekambaram. K.,Venkatesan. R.,Parthiban.K.	Wheel and bush fixed.		Krishnadevi. D. - Labour Ward	29/10/2022
Comp. Dt. : 21/10/2022								
Status : Completed								
1528	22100735	labour room -pow	DOUBLE LOCKER KEY GOT STRUCKED	Ekambaram. K.	Key refixed.		Priyanka. R. - Labour Ward	29/10/2022
Comp. Dt. : 26/10/2022								
Status : Completed								
1529	22100814	labour room -pow	DOUBLE KEY LOCKER PROBLEM	Ekambaram. K.	Locker repaired.		Iyshwariya. M. - Labour Ward	03/11/2022
Comp. Dt. : 09/11/2022								
Status : Completed								
1530	22110323	labour room -pow	NEED TO CHECK CUPBOARD LOCKER - KEY MISSING	Sarathy. A.	Cupboard locker changed, problem solved		Brema. V. - Labour Ward	18/11/2022
1531	22110330	Labour Room	NEED TO CHECK PATIENT COT	Sarathy. A.	Patient cot siderail repaired and serviced, problem solved		Krishnadevi. D. - Labour Ward	18/11/2022
Comp. Dt. : 14/11/2022								
Status : Completed								
1532	22110535	Labour Room	IN DOCTOR'S ROOM-DOOR LOCK PROBLEM	Ekambaram. K.	Lock repaired.		Sathiyavathi. S. - Labour Ward	21/11/2022
Comp. Dt. : 15/11/2022								
Status : Completed								
1533	22110601	labour room -pow	NORCOTIC BOX-KEY GOT STRUCKED	Ekambaram. K.	Key removed.		Brema. V. - Labour Ward	21/11/2022
Comp. Dt. : 19/11/2022								
Status : Completed								
1534	22110811	Labour Room	NEED REPAIRING WORK FOR COT - BEND AND UNBALANCED	Ekambaram. K.	Cot bend removed and repaired, problem solved		Kirupavathy. S. - Labour Ward	01/12/2022
Comp. Dt. : 21/11/2022								
Status : Completed								
1535	22110851	labour room -pow	3 NO'S COT SIDE RAILS NOT WORKING	Sarathy. A.	Cot side rails repaired and serviced, refixed in properly, problem solved		Brema. V. - Labour Ward	01/12/2022
Comp. Dt. : 05/12/2022								
Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1536	22120213	Labour Room	MAIN DOOR HAS GOT HOLE-REQUEST TO CLOSE IT	Ekambaram. K.	Nova pan board fixed.		Kirupavathy. S. - Labour Ward	10/12/2022
Comp. Dt. : 07/12/2022 Status : Completed								
1537	22120290	labour room -pow	NURSES CABIN PLYWOOD GOT DAMAGED	Ekambaram. K.	Plywood changed, problem solved		Brema. V. - Labour Ward	19/12/2022
1538	22120317	Labour Room	NEED TO REFIX PARCHURATION RACK	Ekambaram. K.	Rack refixed, work completed		Sathiyavathi. S. - Labour Ward	19/12/2022
1539	22120318	Labour Room	NEED PAINTING WORK FOR SURGEN DOCTOR'S ROOM [2NOS]	Manimaran. A.	Painting work completed		Sathiyavathi. S. - Labour Ward	19/12/2022
1540	22120319	Labour Room	NEED TO REFIX IV STAND BUSH & WARMER SIDE RAILS	Ekambaram. K.	Bush and siderails refixed, problem solved		Sathiyavathi. S. - Labour Ward	19/12/2022
Comp. Dt. : 08/12/2022 Status : Completed								
1541	22120384	Labour Room	WHEEL CHAIR NEED TO BE REPAIR	Sarathy. A.	Wheel chair repaired and serviced, problem solved		Krishnadevi. D. - Labour Ward	19/12/2022
Comp. Dt. : 09/12/2022 Status : Completed								
1542	22120446	Labour Room	NEED REPAIRING WORK FOR DOOR LOCK [2NOS] - NOT WORKING	Ekambaram. K.	Door lock repaired and serviced, problem solved		Sathiyavathi. S. - Labour Ward	19/12/2022
Comp. Dt. : 19/12/2022 Status : Completed								
1543	22120851	Labour Room	NEED TO FIX RACK BUSH	Sarathy. A.	Bush fixed, problem solved		Kirupavathy. S. - Labour Ward	30/12/2022
Comp. Dt. : 22/12/2022 Status : Completed								
1544	22121021	Labour Room	NEED TO FIX DOOR STOPPER	Ekambaram. K.	New door stopper changed, problem solved		Kirupavathy. S. - Labour Ward	29/12/2022
Comp. Dt. : 04/01/2023 Status : Completed								
1545	23010185	Labour Room	WINDOW DOOR NOT CLOSING PROPERLY	Ekambaram. K.	Door repaired and serviced, problem solved		Kirupavathy. S. - Labour Ward	12/01/2023
Comp. Dt. : 25/01/2023 Status : Completed								
1546	23010918	Labour Room	NEED WELDING WORK FOR STERILIZER - WATER LEAKAGE	Sarathy. A.	Welding work completed, leakage arrested		Sathiyavathi. S. - Labour Ward	30/01/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 27/01/2023 Status : Completed								
1547	23010952	IVF ART CLINIC-INSIDE OF OG OPD(NO.68)	DUE TO RAT PROBLEM - NEED TO RE FIX MESH NET FOR RESTROOM WOODEN DOOR - UNDER PART	Ekambaram. K.	Mesh net fixed		Sathiyavathi. S. - Labour Ward	30/01/2023
Comp. Dt. : 01/02/2023 Status : Completed								
1548	23020005	Labour Room	NEED WELDING WORK FOR STERILIZER	Sarathy. A.	sterlizer damaged, return to ward		Aruldevi. M. - Labour Ward	11/02/2023
Comp. Dt. : 27/02/2023 Status : Completed								
1549	23020997	Labour Room	NEED REPAIRING WORK FOR WHEEL CHAIR, DELIVERY COT & STRETCHER - WHEEL STUCK	Sarathy. A.	WHEEL CHANGED.		Sathiyavathi. S. - Labour Ward	07/03/2023
1550	23020998	Labour Room	NEED PAINTING WORK FOR IV STAND	Manimaran. A.	IV STAND PAINTED		Sathiyavathi. S. - Labour Ward	07/03/2023
Comp. Dt. : 01/03/2023 Status : Completed								
1551	23030028	Labour Room	NEED REPAIRING WORK FOR DOOR LOCK - DAMAGE	Ekambaram. K.	Door lock fixed, problem solved		Usharani. A. - Labour Ward	09/03/2023
Comp. Dt. : 04/03/2023 Status : Completed								
1552	23030188	Labour Room	TILES BROKEN - NEED TOUCHUP WORK	Parivallal. P.	Tiles refixed, JK white cement pointing work completed		Usharani. A. - Labour Ward	09/03/2023
Comp. Dt. : 09/03/2023 Status : Completed								
1553	23030382	Labour Room	TILES BROKEN - NEED TOUCHUP WORK	Parivallal. P.	TILES REFIXED. JK WHITE APPLIED		Krishnadevi. D. - Labour Ward	23/03/2023
Comp. Dt. : 22/03/2023 Status : Completed								
1554	23030924	Labour Room	NEED PAINTING WORK	Manimaran. A.	ROOM PAINTED		Kanimozhi. S. - Labour Ward	01/04/2023
Comp. Dt. : 11/04/2023 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1555	23040297	Labour Room	STRETCHER WHEEL STUCK - & PARTURITION BOARD NEED TO FIX	Sarathy. A.	Wheel repalced and board fixed, work completed		Sathiyavathi. S. - Labour Ward	20/04/2023
	Comp. Dt. : 25/04/2023							
	Status : Completed							
1556	23040791	Labour Room	NEED REPAIRING WORK FOR WHEEL CHAIR WHEEL - STUCK	Sarathy. A.	WHEEL REPLACED		Usharani. A. - Labour Ward	02/05/2023
	Comp. Dt. : 08/05/2023							
	Status : Completed							
1557	23050302	Labour Room	NEED TO REFIX "PARTUTION BOARD"	Ekambaram. K.	BOARD FIXED		Sathiyavathi. S. - Labour Ward	18/05/2023
	Comp. Dt. : 12/05/2023							
	Status : Completed							
1558	23050517	labour room -pow	NEED REPAIRING WORK FOR NURSE'S CABIN DRAW - SCREW & DOOR DAMAGE - BROKEN	Ekambaram. K.	DOOR FIXED		Iyshwariya. M. - Labour Ward	18/05/2023
	Comp. Dt. : 26/05/2023							
	Status : Completed							
1559	23051065	Labour Room	STRETCHER WHEEL STUCK	Sarathy. A.	WHEEL REPAIRED		Usharani. A. - Labour Ward	03/06/2023
	Comp. Dt. : 02/06/2023							
	Status : Completed							
1560	23060061	Labour Room	NEED REPAIRING WORK FOR IV STAND NAB & WHEEL CHAIR , MEDICINE TROLLEY WHEEL STUCK + REMOVE LOCK FO	Ekambaram. K.,Sundaramoorthy. G.,Manivannan. A.	Work completed		Sathiyavathi. S. - Labour Ward	20/06/2023
1561	23060075	labour room -pow	NEED REPAIRING AND PAINTING WORK FOR COT, MEDICINE TROLLEY WHEEL STUCK	Manimaran. A.	Work completed		Brema. V. - Labour Ward	20/06/2023
	Comp. Dt. : 20/06/2023							
	Status : Completed							
1562	23060707	Labour Room	DOUBLE LOCK - LOCKER KEY DAMAGE -NEED TO REFIT NEW LOCK	Ekambaram. K.	Lock fixed.		Santhiya. A. - Labour Ward	27/06/2023
1563	23060708	Labour Room	NEED PAINTING WORK FOR RESTROOM [BOTH SIDES]	Manimaran. A.	New wheel fixed. (4nos)		Santhiya. A. - Labour Ward	27/06/2023
	Comp. Dt. : 21/06/2023							
	Status : Completed							


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1564	23060783	Labour Room - Ward 1	ECG MACHINE DRAWLY WELL BROKEN PAITENT COT NEED TO FIX ONE BUSH	Sarathy. A.	Door repaired.		Kirupavathy. S. - Labour Ward	27/06/2023
		Comp. Dt. : 22/06/2023 Status : Completed						
1565	23060815	Labour Room	NEED WELDING WORK FOR I V STAND [3NOS] - BROKEN	Sarathy. A.	Leg welded.		Santhiya. A. - Labour Ward	07/07/2023
		Comp. Dt. : 26/06/2023 Status : Completed						
1566	23060931	Labour Room	NEED REPAIRING WORK FOR BERO & DOUBLE LOCKER	Sarathy. A.,Ekambaram. K.,Sundaramoorthy. G.	Bero repaired.		Krishnadevi. D. - Labour Ward	07/07/2023
		Dept Name : Library - Work Shop Comp. Dt. : 07/06/2022 Status : Completed						
1567	22060258	medical college library 2nd floor	NEED TO FIX PLYWOOD SHEET FOR CEILING NEAR SIDE WALL - SAND FALLING DOWN	Ganesan. A.	Civil dept work, Inform to Project Manager, Civil execution dept.		Elangovan.N. - Library	13/06/2022
		Comp. Dt. : 26/10/2022 Status : Completed						
1568	22100801	medical college library 2nd floor	TROLLY WHEEL BROKEN	Sarathy. A.	New wheel 2 nos. fixed and painted.		Elangovan.N. - Library	03/11/2022
		Dept Name : Male Medical Ward - Work Shop Comp. Dt. : 06/05/2022 Status : Completed						
1569	22050196	Male Medical - Ward 302	NEED REPAIRING WORK FOR NURSE'S STATION DRAW - BROKEND & DAMAGE	Ekambaram. K.	Not able to repair the draw, condemned, removed the draw for scrab		Soniya Gandhi. A. - Male Medical Ward	12/05/2022
1570	22050208	Male Medical - Ward 303	NEED TO FIX NAIL FOR WALL CLOCK & ROD FOR MOVABLE SCREEN	Ekambaram. K.	Nail fixed, Movable screen rod fixed, work completed		Vijayalakshmi. S. - Male Medical Ward	12/05/2022
		Comp. Dt. : 07/05/2022 Status : Completed						
1571	22050232	Male Medical - Ward 302	TILES BROKEN NEED TOUCHUP WORK	Murugavel	New tiles refixed, JK White cement pointing work done		Soniya Gandhi. A. - Male Medical Ward	12/05/2022
		Comp. Dt. : 09/05/2022						


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
1572	22050304	Male Medical - Ward 303	NEED REPAIRING WORK FOR CUPBOARD	Ekambaram. K.	Cupboard door refixed, problem solved		Vijayalakshmi. S. - Male Medical Ward	26/05/2022
Comp. Dt. : 16/05/2022								
Status : Completed								
1573	22050524	Male Medical - Ward 303	NEED REPAIRING QORK FOR DOOR - BROKENED	Ekambaram. K.	Door repaired and serviced, problem solved		Vijayalakshmi. S. - Male Medical Ward	27/05/2022
Comp. Dt. : 17/05/2022								
Status : Completed								
1574	22050619	Male Medical - Ward 303	NEED PAINTING WORK FOR PATIENT LOCKER 5 NOS	Manimaran. A.	Lockers were painted		Vijayalakshmi. S. - Male Medical Ward	18/06/2022
Comp. Dt. : 18/05/2022								
Status : Completed								
1575	22050678	Male Medical - Ward 303	DUE TO BE FIX OF WASH BASIN - NEED TO REPLACE & REFIX MIRROR	Ekambaram. K.	Wash basin mirror refixed, work completed		Vijayalakshmi. S. - Male Medical Ward	28/05/2022
Comp. Dt. : 20/05/2022								
Status : Completed								
1576	22050747	Male Medical - Ward 301	NEED TO REFIX WHEEL CHAIR BELT - DAMAGE	Sarathy. A.	belt fixed.		Soniya Gandhi. A. - Male Medical Ward	18/06/2022
Comp. Dt. : 25/05/2022								
Status : Completed								
1577	22050963	Male Medical - Ward 303	NEED TO FIX PLYWOOD SHEET FOR DOOR	Pachaimuthusamy. D.	Plywood sheet fixed.		Vijayalakshmi. S. - Male Medical Ward	10/06/2022
Comp. Dt. : 27/05/2022								
Status : Completed								
1578	22051026	Male Medical - Ward 304	NEED REPAIRING WORK FOR CARDIAC TABLE BOARD - BROKENED	Ekambaram. K.	2nos new table maked and Issued.		Vijayalakshmi. S. - Male Medical Ward	10/06/2022
Comp. Dt. : 30/05/2022								
Status : Completed								
1579	22051080	Male Medical - Ward 302	NEED REPAIRING WORK FOR CABIN DRAW	Ekambaram. K.	Cabin draw repaired.		Bharathi. K. - Male Medical Ward	10/06/2022
Comp. Dt. : 01/06/2022								
Status : Completed								
1580	22060005	Male Medical - Ward 303	NEED REPAIRING WORK FOR NURSE'S CABIN DOOR - BROKENED	Ekambaram. K.	Nurse's cabin door fixed.		Vijayalakshmi. S. - Male Medical Ward	10/06/2022
1581	22060020	Male Medical - Ward 303	NEED PAINTING WORK FOR LOCKER [10 NOS]	Ekambaram. K.	Locker painted		Vijayalakshmi. S. - Male Medical Ward	10/06/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 05/07/2022 Status : Completed								
1582	22070179	Male Medical - Ward 301	NEED REPAIRING WORK FOR COT SIDE RAILS	Sarathy. A.	Side rail refixed in properly, problem solved		Soniya Gandhi. A. - Male Medical Ward	18/07/2022
Comp. Dt. : 06/07/2022 Status : Completed								
1583	22070205	Male Medical - Ward 302	NEED TO REPLACE & REFIX NAIL	Ekambaram. K.	nail refixed		Soniya Gandhi. A. - Male Medical Ward	18/07/2022
Comp. Dt. : 07/07/2022 Status : Completed								
1584	22070242	Male Medical - Ward 301	NEED REPAIRING WORK FOR WHEEL CHAIR WHEEL [2NOS] - NOT WORKING	Sarathy. A.	2Nos of wheel refixed, problem solved		Nirmalraj. R. - Male Medical Ward	18/07/2022
Comp. Dt. : 09/07/2022 Status : Completed								
1585	22070375	Male Medical - Ward 303	NEED REPAIRING WORK FOR COT - RAISING PROBLEM	Sarathy. A.	Cot repaired and serviced, problem solved		Vijayalakshmi. S. - Male Medical Ward	20/07/2022
Comp. Dt. : 13/07/2022 Status : Completed								
1586	22070494	Male Medical - Ward 303	NEED REPAIRING WORK FOR COT - BROKEN	Sarathy. A.	Cot repaired and serviced, bush fixed, problem solved		Sujitha. G. - Male Medical Ward	01/08/2022
Comp. Dt. : 18/07/2022 Status : Completed								
1587	22070660	Male Medical - Ward 303	NEED TO REFIX PATLOCK FOR BERO	Ekambaram. K.	Padlock fixed, problem solved		Vijayalakshmi. S. - Male Medical Ward	01/08/2022
Comp. Dt. : 23/07/2022 Status : Completed								
1588	22070862	Male Medical - Ward 301	NEED TO REFIX NAILS [SCREWS] FOR PARTITION DOOR FRAME	Ekambaram. K.	Partition fixing work completed		Soniya Gandhi. A. - Male Medical Ward	24/09/2022
Comp. Dt. : 27/07/2022 Status : Completed								
1589	22070986	Male Medical - Ward 301	NEED TO CHANGE WHEEL FOR WHEEL CHAIR & PATIENT STRUCTURE	Sarathy. A.	Structure and wheel chair - wheel cahnged, work completed		Vijayalakshmi. S. - Male Medical Ward	05/08/2022
Comp. Dt. : 13/08/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1590	22080477	Male Medical - Ward 302	NEED REPAIRING WORK FOR REST ROOM DOOR LOCK - BROKEN	Ekambaram. K.	New door fixed.		Soniya Gandhi. A. - Male Medical Ward	24/09/2022
		Comp. Dt. : 18/08/2022 Status : Completed						
1591	22080587	Male Medical - Ward 302	NURSES STATION CUPBOARD RACK'S BROKEN,NEED TO BE REFIX	Ekambaram. K.	New cupboard fixed, work completed		Soniya Gandhi. A. - Male Medical Ward	26/08/2022
		Comp. Dt. : 23/08/2022 Status : Completed						
1592	22080780	Male Medical - Ward 301	NEED TO FIX NEW DRAW FOR NEW NURSE'S CABIN	Ekambaram. K.	Draw refixed, problem solved		Soniya Gandhi. A. - Male Medical Ward	01/09/2022
		Comp. Dt. : 01/09/2022 Status : Completed						
1593	22090055	Male Medical - Ward 301	NEED TO CHANGE WHEELS FOR STRUCTURE 2NOS & MEDICINE TROLLEY 3 NOS	Sarathy. A.	Work completed.		Soniya Gandhi. A. - Male Medical Ward	08/09/2022
		Comp. Dt. : 05/09/2022 Status : Completed						
1594	22090151	Male Medical - Ward 301	KEY PROBLEM IN DOUBLE DOOR LOCKER LOCK	Ekambaram. K.	Lock fixed.		Soniya Gandhi. A. - Male Medical Ward	24/09/2022
		Comp. Dt. : 06/09/2022 Status : Completed						
1595	22090227	Male Medical - Ward 301	NEED ALTER WORK FOR NURSE'S CABIN	Parthiban.K.	Shelf fixed.		Vijayalakshmi. S. - Male Medical Ward	24/09/2022
		Comp. Dt. : 12/09/2022 Status : Completed						
1596	22090427	Male Medical - Ward 301	NEED TO REARRANGE CABIN DRAW - UNFIX	Ekambaram. K.	Cabin draw repaired and serviced, problem solved		Soniya Gandhi. A. - Male Medical Ward	29/09/2022
		Comp. Dt. : 20/09/2022 Status : Completed						
1597	22090780	Male Medical - Ward 301	NEED REPAIRING WORK FOR RESTROOM DOOR - BROKEN	Ekambaram. K.	Door repaired and serviced, problem solved		Soniya Gandhi. A. - Male Medical Ward	29/09/2022
		Comp. Dt. : 22/09/2022 Status : Completed						
1598	22090901	Male Medical - Ward 301	NEED TO REFIX 3 FOLDER SCREEN WHEEL - NOT WORKING	Sarathy. A.,Sundaramoorthy. G.,Viswa. V.	2" PVC screen Wheel 10Nos changed, problem solved		Karthika. S. - Female Surgery	08/10/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 06/10/2022								
Status : Completed								
1599	22100095	Male Medical - Ward 301	NEED TO REFIX WHEEL CHAIR WHEEL - DAMAGE	Sarathy. A.	Wheel chair wheel changed, problem solved		Soniya Gandhi. A. - Male Medical Ward	12/10/2022
1600	22100106	Male Medical - Ward 301	NEED REPAIRING WORK FOR NURSE'S CABIN - BROKEN	Ekambaram. K.	Nurses cabin door refixed in properly, problem solved		Soniya Gandhi. A. - Male Medical Ward	12/10/2022
Comp. Dt. : 08/10/2022								
Status : Completed								
1601	22100179	Male Medical - Ward 301	WHEEL CHAIR BELT PROBLEM	Sarathy. A.	Belt refixed, problem solved		Soniya Gandhi. A. - Male Medical Ward	16/11/2022
Comp. Dt. : 11/10/2022								
Status : Completed								
1602	22100261	Male Medical - Ward 302	NEED REPAIRING WORK FOR WINDOW DOOR - NOT CLOSING PROPER - RAIN WATER COMING INSIDE THE WARD	Ekambaram. K., Sundaramoorthy. G., Venkatesan. R.	Window door repaired and serviced, problem solved		Karthikeyan. I. - Male Medical Ward	12/10/2022
Comp. Dt. : 29/10/2022								
Status : Completed								
1603	22100971	Male Medical - Ward 302	NEED TO FIX COT BUSH AND PATIENT STOOL BUSH	Moorthy. L.	cot Bush and stool bush fixed, problem solved		Soniya Gandhi. A. - Male Medical Ward	08/11/2022
1604	22100972	Male Medical - Ward 301	NEED TO FIX COT BUSH AND PATIENT STOOL BUSH	Moorthy. L.	Cot bush and stool bush fixed, problem solved		Soniya Gandhi. A. - Male Medical Ward	08/11/2022
1605	22100973	Male Medical - Ward 302	MEDICINE TROLLEY REPAIRING WORK	Sarathy. A.	Trolley wheel changed, problem solved		Soniya Gandhi. A. - Male Medical Ward	08/11/2022
Comp. Dt. : 31/10/2022								
Status : Completed								
1606	22100990	Male Medical - Ward 301	X-RAY LOBBY STAND BROKEN.NEED TO FIX	Sarathy. A.	X-Ray lobby stand fixed, problem solved		Vijayalakshmi. S. - Male Medical Ward	08/11/2022
Comp. Dt. : 07/11/2022								
Status : Completed								
1607	22110235	RICU	BATHROOM GLASS BROKEN	Ekambaram. K.	Novopan sheet fixed, problem solved		Nirmalraj. R. - Male Medical Ward	18/11/2022
Comp. Dt. : 21/11/2022								
Status : Completed								
1608	22110867	PSYCHIATRY WARD	MAIN DOOR/ECG ROOM DOOR NOT CLOSING PROPERLY	Ekambaram. K.	Door repaired and serviced, floor - mason work completed		Deva. S. - Male Medical Ward	01/12/2022
Comp. Dt. : 23/11/2022								
Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1609	22110966	Male Medical - Ward 302	NEED TO FIX HEIGHT SCALE	Ekambaram. K.	Height scale fixed, work completed		Soniya Gandhi. A. - Male Medical Ward	06/12/2022
1610	22110967	Male Medical - Ward 302	KEY MISSING - NEED TO BREAK & FIX LOCK FOR DEMO ROOM DOOR	Ekambaram. K.	Lock broken, new lock changed, problem solved		Soniya Gandhi. A. - Male Medical Ward	01/12/2022
Comp. Dt. : 30/11/2022 Status : Completed								
1611	22111262	Male Medical - Ward 302	TILES BROKEN	Murugavel	Tiles refixed, JK White cement pointing work completed		Vijayalakshmi. S. - Male Medical Ward	19/12/2022
Comp. Dt. : 19/12/2022 Status : Completed								
1612	22120867	Male Medical - Ward 303	WINDOW DOOR FIXING WORK	Ekambaram. K.	Window door repaired and serviced, refixed in properly, problem solved		Vijay. N. - Male Medical Ward	30/12/2022
Comp. Dt. : 03/01/2023 Status : Completed								
1613	23010072	Female Medical - Ward 306	FLOOR TILES BROKEN, TOUCHUP WORK NEEDED	Murugavel	18Nos Tiles refixed, JK white cement pointing work completed		Geedhanjali. I - Male Medical Ward	12/01/2023
Comp. Dt. : 19/01/2023 Status : Completed								
1614	23010663	Male Medical Ward	NEED WALL PAINTING WORK FOR WARD NO 301 & 302	Manimaran. A.	WALL PAINTING WORK COMPLETED		Soniya Gandhi. A. - Male Medical Ward	04/05/2023
Comp. Dt. : 20/01/2023 Status : Completed								
1615	23010740	Male Medical - Ward 302	NEED TO REFIX HEIGHT SCALE	Ekambaram. K.	Height scale refixed		Geedhanjali. I - Male Medical Ward	30/01/2023
Comp. Dt. : 21/01/2023 Status : Completed								
1616	23010778	Male Medical - Ward 302	NEED TO FIX HEIGHT SCALE	Ekambaram. K.	Height scale fixed, Repeated complaint		Soniya Gandhi. A. - Male Medical Ward	30/01/2023
Comp. Dt. : 08/02/2023 Status : Completed								
1617	23020280	Male Medical - Ward 301	WHEEL REFIXING WORK IN WHEEL CHAIR AND DRESS TROLLEY	Sarathy. A.	Wheel chair and dress trolley - wheel fixed, problem solved		Karthikeyan. I. - Male Medical Ward	16/02/2023
Comp. Dt. : 09/02/2023 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1618	23020363	Male Medical - Ward 301	WHEEL CHAIR WHEEL PROBLEM & DRESSING TROLLY WHEEL CHANGE	Moorthy. L.	Wheel chair wheel and dressing trolley wheel changed, problem solved		Soniya Gandhi. A. - Male Medical Ward	16/02/2023
Comp. Dt. : 17/02/2023 Status : Completed								
1619	23020671	Male Medical - Ward 302	NEED REPAIRING WORK FOR NURSE'S STATION - BROKEN	Ekambaram. K.	Nurses cabin door repaired and refixed, work completed		Vijayalakshmi. S. - Male Medical Ward	23/02/2023
Comp. Dt. : 28/02/2023 Status : Completed								
1620	23021057	Paediatrics - Ward 309	ONE BOARD REMOVE WORK AND SOME COTS BOLD NUT PROBLEM(1312)	Sarathy. A.	BOLT AND NUT FIXED		Nanthini. R. - Male Medical Ward	07/03/2023
Comp. Dt. : 17/03/2023 Status : Completed								
1621	23030723	Male Psychiatry - Ward 405	NEED TO REFIX COT SIDE RAILS	Sarathy. A.	Cot siderail refixed		Deva. S. - Male Medical Ward	31/03/2023
Comp. Dt. : 01/04/2023 Status : Completed								
1622	23040026	Male Medical - Ward 303	NEED TO REFIX SCREEN ROD - DAMAGE & BROKEN	Ekambaram. K.	Screen rod refixed, problem solved		Vijayalakshmi. S. - Male Medical Ward	18/04/2023
Comp. Dt. : 04/04/2023 Status : Completed								
1623	23040129	Male Medical - Ward 301	NEED REPAIRING WORK FOR NURSE'S CABIN DOOR - BROKEN	Ekambaram. K.	Nurses cabin door refixed, work completed		Soniya Gandhi. A. - Male Medical Ward	18/04/2023
Comp. Dt. : 12/04/2023 Status : Completed								
1624	23040353	Male Medical - Ward 302	NEED REPAIRING WORK FOR WHEEL CHAIR - BEND	Sarathy. A.	Wheel chair repaired and serviced		Soniya Gandhi. A. - Male Medical Ward	20/04/2023
Comp. Dt. : 13/04/2023 Status : Completed								
1625	23040395	Male Medical - Ward 301	NEED TO REFIX NAIL FOR SCREEN	Ekambaram. K.	Screen and nail fixed		Soniya Gandhi. A. - Male Medical Ward	20/04/2023
Comp. Dt. : 08/06/2023 Status : Completed								
1626	23060296	Male Medical - Ward 301	NED REPAIRING WORK FOR WHEEL CHAIR WHEEL - STUCK	Sarathy. A.	New wheel replaced		Soniya Gandhi. A. - Male Medical Ward	20/06/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Dept Name : Male Ortho Ward - Work Shop Comp. Dt. : 17/05/2022 Status : Completed								
1627	22050603	Male Ortho - Ward 404	NEED REPAIRING WORK FOR GLASS DOOR [WARD INSIDE DOOR]	Ekambaram. K.	Glass door removed to workshop		Rajasree. R. - Male Ortho Ward	27/05/2022
Comp. Dt. : 24/05/2022 Status : Completed								
1628	22050881	Male Ortho - Ward 403	NEED ADJUSTMENT FOR ORTHO FOWLER COT SIDE RAILS	Sarathy. A.	Cot side rails repaired and serviced, problem solved		Rajasree. R. - Male Ortho Ward	28/05/2022
Comp. Dt. : 11/06/2022 Status : Completed								
1629	22060430	Male Ortho - Ward 404	NEED REPAIRING WORK FOR RESTROOM DOOR LOCK	Ekambaram. K.	Pad lock fixed.		Rajasree. R. - Male Ortho Ward	21/06/2022
Comp. Dt. : 18/07/2022 Status : Completed								
1630	22070661	Female Ortho - Ward 402	NEED TO REFIX " BIO MEDICAL " BOARD	Ekambaram. K.	name Board fixed, problem solved		Rajasree. R. - Male Ortho Ward	01/08/2022
1631	22070662	Male Ortho - Ward 404	NEED REPAIRING WORK FOR BERO LOCK	Ekambaram. K.	Bero lock repaired and refixed, problem solved		Rajasree. R. - Male Ortho Ward	01/08/2022
Comp. Dt. : 27/07/2022 Status : Completed								
1632	22071034	Male Ortho Ward	NEED TO REFIX WHEEL CHAIR BELT - WARD NO 403 & 404	Sarathy. A.	Wheel chair belt refixed in properly, problem solved		Rajasree. R. - Male Ortho Ward	05/08/2022
Comp. Dt. : 03/08/2022 Status : Completed								
1633	22080115	Male Ortho Ward	NEED TO REFIX SCREW FOR 3 FOLDER SCREEN	Sarathy. A.	Screen rod screw and hook fixed, problem solved		Rajasree. R. - Male Ortho Ward	08/08/2022
Comp. Dt. : 04/08/2022 Status : Completed								
1634	22080167	Male Ortho - Ward 403	IV FLUID RACK NEED TO BE FIX	Ekambaram. K.	Rack refixed, problem solved		Rajasree. R. - Male Ortho Ward	16/11/2022
Comp. Dt. : 29/08/2022 Status : Completed								
1635	22080974	Male Ortho - Ward 403	NEED TO REFIX STRUCTURE SIDE RAILS & WHEEL - NOT MOVING	Sarathy. A.	Side rail fixed.		vanitha. P. - Male Ortho Ward	09/09/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 30/08/2022 Status : Completed								
1636	22081013	Male Ortho - Ward 403	TILES AIR BREAK - NEED TOUCHUP WORK	Murugavel	Work completed.		Maheswari. J. - Male Ortho Ward	09/09/2022
Comp. Dt. : 26/09/2022 Status : Completed								
1637	22090999	Male Ortho - Ward 403	NEED TO REFIX NAME BOARD	Ekambaram. K.	Name board fixed, problem solved		Sandhiya. L. - Male Ortho Ward	08/10/2022
Comp. Dt. : 27/09/2022 Status : Completed								
1638	22091084	Male Ortho - Ward 403	NEED TO REFIX NAIL FOR FIXING BOARDS	Ekambaram. K.	Board fixed, problem solved		Maheswari. J. - Male Ortho Ward	08/10/2022
Comp. Dt. : 28/09/2022 Status : Completed								
1639	22091109	Male Ortho - Ward 403	NEED TO REFIX WHITE BOARD	Ekambaram. K.	White board fixed, problem solved		Rajasree. R. - Male Ortho Ward	08/10/2022
Comp. Dt. : 29/09/2022 Status : Completed								
1640	22091170	Male Ortho - Ward 404	NEED REPAIRING WORK FOR DOCTOR'S ROOM REST ROOM DOOR - DAMAGE , UNFIX & BROKEN	Ekambaram. K.	Rest room door repaired and refixed, problem solved		Gayathri. S. - Male Ortho Ward	08/10/2022
Comp. Dt. : 10/10/2022 Status : Completed								
1641	22100218	Male Surgery - Ward 203	NEED TO FIX NAIL FOR X RAY LOBBY FIXING	Ekambaram. K.	Table drawer wheel changed and Nail fixed, work completed		Vanitha. P. - Male Ortho Ward	13/10/2022
1642	22100230	Male Ortho - Ward 404	NEED TO REFIX PATLOCK FOR RESTROOM FRONT DOOR INSIDE	Sarathy. A.	New Padlock fixed, problem solved		Rajasree. R. - Male Ortho Ward	12/10/2022
Comp. Dt. : 15/10/2022 Status : Completed								
1643	22100484	Male Ortho - Ward 404	NEED TO REFIX COT SIDE RAILS SCREW - DAMAGE & NOT FIX	Sarathy. A.	Cot Side rail screw refixed, problem solved		Rajasree. R. - Male Ortho Ward	21/10/2022
Comp. Dt. : 17/10/2022 Status : Completed								
1644	22100526	Male Ortho - Ward 404	NEED TO FIX NAILS FOR FIXING WALL CLOCK	Viswa. V.	Clock fixed.		Rajasree. R. - Male Ortho Ward	29/10/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 21/10/2022								
Status : Completed								
1645	22100719	Male Ortho - Ward 403	DURING CORONA PERIOD-WOODEN PEICES ATTACHED IN WINDOW NEED TO BE REFIX	Ekambaram. K.	COT repaired.		Rajasree. R. - Male Ortho Ward	29/10/2022
1646	22100720	Male Ortho - Ward 403	COT SIDE RAILS BROKEN	Sarathy. A.	side rail fixed.		Rajasree. R. - Male Ortho Ward	29/10/2022
Comp. Dt. : 26/10/2022								
Status : Completed								
1647	22100786	Male Ortho - Ward 404	COT BROKEN IN DUTY DOCTOR ROOM	Sarathy. A.	Cot repaired.		Manjula. P. - Male Ortho Ward	03/11/2022
Comp. Dt. : 28/10/2022								
Status : Completed								
1648	22100919	Male Ortho - Ward 403	PATIENT COT SIDE RAILS SCREW NEED TO BE REFIX	Sarathy. A.	Side rail refixed.		Manikandan. V. - Male Ortho Ward	03/11/2022
Comp. Dt. : 03/11/2022								
Status : Completed								
1649	22110072	Male Ortho - Ward 404	IN ENTRANCE -DOOR GLASS BROKEN	Ekambaram. K.	Door repaired and serviced, problem solved		Gayathri. S. - Male Ortho Ward	06/12/2022
1650	22110103	Male Ortho - Ward 403	IN EXAMINATION ROOM-SCREW NEED TO BE REFIX IN WINDOW DOOR	Ekambaram. K.	New screw fixed in window door, problem solved		Maheswari. J. - Male Ortho Ward	16/11/2022
Comp. Dt. : 07/11/2022								
Status : Completed								
1651	22110201	Male Surgery - Ward 203	PAINT WORK IN IV STAND AND BUSH (10 NOS) STOOL PAINTING WORK AND BUSH	Sarathy. A.	IV Stand painting work completed, bush fixed, problem solved		Vanitha. P. - Male Ortho Ward	18/11/2022
Comp. Dt. : 08/11/2022								
Status : Completed								
1652	22110280	Male Ortho - Ward 403	NEED TO FIX WINDOW (NEW)	Ekambaram. K.	Mosquito net fixed in window, work completed		Maheswari. J. - Male Ortho Ward	06/12/2022
Comp. Dt. : 09/11/2022								
Status : Completed								
1653	22110350	Male Ortho - Ward 404	IN TREATMENT ROOM-SCREEN ROD NEED TO BE FIX	Ekambaram. K.	New screen rod fixed, problem solved		Rajasree. R. - Male Ortho Ward	18/11/2022
Comp. Dt. : 24/11/2022								
Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1654	22111069	Female Surgery - Ward 206	SCREEN STAND BROKEN	Ekambaram. K.,Sundaramoorthy. G.,Sarathy. A.	Screen wheel replaced, problem solved		Vanitha. P. - Male Ortho Ward	01/12/2022
1655	22111070	Male Surgery - Ward 203	IV STAND WHEEL PUSH NEED TO BE FIX	Ekambaram. K.,Sundaramoorthy. G.,Sarathy. A.	Bush fixed, problem solved		Vanitha. P. - Male Ortho Ward	01/12/2022
1656	22111071	Male Surgery - Ward 204	IN WARD-FOR EXAMINATION PURPOSE-ALL WINDOWS DOOR NEED TO BE CLOSE	Ekambaram. K.	Window door repaired and serviced, problem solved		Vanitha. P. - Male Ortho Ward	01/12/2022
Comp. Dt. : 02/12/2022 Status : Completed								
1657	22120057	Male Surgery - Ward 203	TILES AIR CRACK NEED TO CHECK & CHANGE	Murugavel	Civil execution complaint		Vanitha. P. - Male Ortho Ward	10/12/2022
Comp. Dt. : 07/12/2022 Status : Completed								
1658	22120295	Male Surgery - Ward 203	FLOOR TILES BROKEN,TOUCHUP WORK NEEDED	Murugavel	Tiles refixed, JK white cement pointing work completed		Vanitha. P. - Male Ortho Ward	19/12/2022
1659	22120323	Male Ortho	NEED TO REFIX SIDE RAILS AND BUSH & PAINTING WORK FOR COT	Sarathy. A.	Siderails and bush refixed, cot painting work completed		Sandhiya. L. - Male Ortho Ward	19/12/2022
Comp. Dt. : 10/12/2022 Status : Completed								
1660	22120481	Male Ortho - Ward 403	PLYWOOD OR MIRROR NEED TO BE CLOSE WITH WINDOW-RAINWATER GETTING INSIDE	Ekambaram. K.	New shutter 3Nos fixed, work completed		Rajasree. R. - Male Ortho Ward	19/12/2022
Comp. Dt. : 15/12/2022 Status : Completed								
1661	22120715	Male Ortho Ward	NEED PAINTING & REFIX BUSH FOR COT , IV STAND & LOCKERS	Sarathy. A.	Bush fixed.		Rajasree. R. - Male Ortho Ward	23/12/2022
Comp. Dt. : 17/12/2022 Status : Completed								
1662	22120802	Male Ortho Ward	NEED REPAIRING & PAINTING WORK FOR WHEEL CHAIR WHEEL	Manimaran. A.	Wheel replaced and painted.		Rajasree. R. - Male Ortho Ward	23/12/2022
Comp. Dt. : 19/12/2022 Status : Completed								
1663	22120847	Male Ortho - Ward 403	LOCKER, CART, ECG MACHINE AND TROLLY PAINTING WORK	Manimaran. A.	All materials are painting work completed		Rajasree. R. - Male Ortho Ward	30/12/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 26/12/2022 Status : Completed								
1664	22121148	Male Ortho - Ward 403	NURSES CABIN NEED TO REMOVED NEED LABOURS	Ganesan. A.	Wrong complaint, labours complaint, msg inform to maintenance dept		Manjula. P. - Male Ortho Ward	02/01/2023
Comp. Dt. : 11/01/2023 Status : Completed								
1665	23010460	Male Surgery - Ward 203	PATIENT STOOL AND IV STAND -BUSH NEED TO BE FIX	Sarathy. A.	Stool and IV Stand - bush fixed		Vanitha. P. - Male Ortho Ward	23/01/2023
Comp. Dt. : 01/02/2023 Status : Completed								
1666	23020033	Male Surgery - Ward 203	NEED REPAIRING WORK FOR DEMO ROOM LOCK - BROKEN	Ekambaram. K.	Lock changed, problem solved		Vanitha. P. - Male Ortho Ward	11/02/2023
1667	23020034	Male Surgery - Ward 203	NEED TO REFIX COT SIDE RAILS	Ekambaram. K.	Cot side rail refixed, problem solved		Vanitha. P. - Male Ortho Ward	11/02/2023
1668	23020035	Male Surgery - Ward 203	NEED TO REFIX BUSH FOR PATIENT STOOL, COT & LOCKER	Sarathy. A.	All stool, locker and cot - new bush changed, work completed		Vanitha. P. - Male Ortho Ward	11/02/2023
Comp. Dt. : 09/02/2023 Status : Completed								
1669	23020329	Male Ortho - Ward 404	PLYWOOD REMOVING WORK	Ekambaram. K.	Plywood partition removed		Rajasree. R. - Male Ortho Ward	16/02/2023
Comp. Dt. : 11/02/2023 Status : Completed								
1670	23020423	Male Ortho Ward	NEED TO REFIX SCREW FOR COT SIDE RAILS [20 NOS] FOR MALE ORTHO 403 & 404	Sarathy. A.	Cot side rails screw refixed in properly		Manjula. P. - Male Ortho Ward	16/02/2023
Comp. Dt. : 13/02/2023 Status : Completed								
1671	23020480	Male Surgery - Ward 204	NEED TO REFIX STRETCHER SIDE RAILS	Ekambaram. K.	Stretcher side rails refixed, problem solved		Vanitha. P. - Male Ortho Ward	17/02/2023
Comp. Dt. : 08/03/2023 Status : Completed								
1672	23030328	Male Ortho - Ward 404	NEED PAINTING WORK FOR WOODEN TABLE	Manimaran. A.	TABLES REPAIRED		Sandhiya. L. - Male Ortho Ward	14/03/2023
Comp. Dt. : 15/03/2023 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1673	23030579	Male Ortho - Ward 404	NEED TO REMOVE KEY MISSING BERO LOCK , AND FIX NEW KEY	Ekambaram. K.	WORK COMPLETED.		Manjula. P. - Male Ortho Ward	23/03/2023
1674	23030580	Male Ortho Ward	NEED TO REPAIRING & REFIX WHEEL FOR WHEEL CHAIR , DRESSING TROLLEY & STRETCHER WHEEL	Sarathy. A.	WORK COMPLETED		Manjula. P. - Male Ortho Ward	23/03/2023
Comp. Dt. : 28/03/2023 Status : Completed								
1675	23031215	Male Surgery - Ward 204	NEED TO REFIX DOOR PATLOCK	Ekambaram. K.	New padlock fixed		Vanitha. P. - Male Ortho Ward	13/04/2023
Comp. Dt. : 30/06/2023 Status : Completed								
1676	23061089	Male Ortho - Ward 404	NEED REPAIRING WORK FOR CRASH CART LOCK - STUCK	Ekambaram. K.,Sundaramoorthy. G.,Ganesh. S.	Cart repaired.		Sandhiya. L. - Male Ortho Ward	08/07/2023
Dept Name : Male Surgery - Work Shop Comp. Dt. : 07/05/2022 Status : Completed								
1677	22050227	Male Surgery - Ward 201	NEED TO REFIX PATIENT SCREEN SPRING	Ekambaram. K.	Screen spring refixed, problem solved		Sugumari. M. - Male Surgery	12/05/2022
Comp. Dt. : 09/05/2022 Status : Completed								
1678	22050308	Male Surgery - Ward 202	NEED WHEEL REPAIRING WORK FOR WHEEL CHAIR [2NOS] & DRESSING TROLLEY [2NOS]	Sarathy. A.	Wheel chair wheel refixed, problem solved		Santhiya. N. - Male Surgery	18/05/2022
Comp. Dt. : 19/05/2022 Status : Completed								
1679	22050694	Female Surgery - Ward 206	NEED TO REFIX PATLOCK FOR NURSE'S CABIN DOOR	Ekambaram. K.	Cabin door new padlock fixed, problem solved		Vinodhini. K. - Female Surgery	28/05/2022
Comp. Dt. : 20/05/2022 Status : Completed								
1680	22050735	Female Surgery	NEED REPAIRING WORK FOR NURSE'S CABIN DOOR WARD NO 206 & DRAW FOR WARD NO 205	Ekambaram. K.,Venkatesan. R.,Pachaimuthusamy . D.	cabin door and draw repaired and serviced, refixed, problem solved		Vaidegi. S. - Female Surgery	28/05/2022
Comp. Dt. : 02/06/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1681	22060068	Male Surgery - Ward 201	NEED TO REFIX WHEEL CHAIR BELT & WHEEL - NOT WORKING PROPERLY	Sarathy. A.	Wheel repaired.		Sugumari. M. - Male Surgery	10/06/2022
Comp. Dt. :		06/06/2022						
Status :		Completed						
1682	22060199	Female Surgery - Ward 205	NEED WELDING WORK FOR STERILIZER - WATER LEAKAGE	Sarathy. A.	Welding work completed		Vaidegi. S. - Female Surgery	10/06/2022
1683	22060218	Female Surgery - Ward 205	PROBLEM IN NURSE'S CABIN DRAW - DRAW NOT WORKING	Pachaimuthusamy. D.	Draw himp fixed		Vaidegi. S. - Female Surgery	10/06/2022
Comp. Dt. :		29/06/2022						
Status :		Completed						
1684	22061076	Female Surgery - Ward 206	NEED REPAIRING WORK FOR WHEEL CHAIR WHEEL NOT WORKING & NEED WELDING WORK FOR STERILIZER - WATER L	Sarathy. A.	Wheel chair wheel refixed		Vaidegi. S. - Female Surgery	05/07/2022
Comp. Dt. :		05/07/2022						
Status :		Completed						
1685	22070139	Female Surgery - Ward 205	NEED TO REFIX " FIRE EXIT" BOARD	Pachaimuthusamy. D.	Fire exite board refixed, work completed		Vaidegi. S. - Female Surgery	18/07/2022
Comp. Dt. :		26/08/2022						
Status :		Completed						
1686	22080894	Male Surgery - Ward 202	NEED TO REFIX BERO PATLOCK SCREW - SCREW DAMAGE	Venkatesan. R.	pad lock fixed.		Sangeedha. M. - Male Surgery	09/09/2022
Comp. Dt. :		21/09/2022						
Status :		Completed						
1687	22090813	Male Surgery - Ward 201	NEED REPAIRING WORK FOR NURSE'S CABIN - BROKEN	Ekambaram. K.,Venkatesan. R.,Sundaramoorthy. G.	Cupboard refixed, problem solved		Sugumari. M. - Male Surgery	29/09/2022
Comp. Dt. :		23/09/2022						
Status :		Completed						
1688	22090913	Male Surgery	NEED REPAIRING WORK FOR WINDOW DOORS - DAMAGE & BROKEN -WARD NO 201 & 202	Ekambaram. K.	Window door repaired and serviced, problem solved		Sugumari. M. - Male Surgery	08/10/2022
Comp. Dt. :		14/10/2022						
Status :		Completed						
1689	22100471	Male Surgery - Ward 201	NEED TO REFIX CRASH CART KEY	Ekambaram. K.	Key fixed, problem solved		Sugumari. M. - Male Surgery	21/10/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 27/10/2022 Status : Completed								
1690	22100861	Male Surgery - Ward 201	BERO LOCK NEED TO BE REFIX	Ekambaram. K.	Lock refixed.		Girija. S. - Male Surgery	03/11/2022
Comp. Dt. : 28/10/2022 Status : Completed								
1691	22100910	Male Surgery - Ward 201	ECG MACHIONE TROLLY WHEEL BROKEN-NEED TO CHANGE IT	Sarathy. A.	Trolly wheel refixed.		Girija. S. - Male Surgery	03/11/2022
Comp. Dt. : 18/11/2022 Status : Completed								
1692	22110748	Male Surgery - Ward 202	NEED TO REFIX TOWEL STAND HANGER FOR DOCTOR'S ROOM - BROKEN	Ekambaram. K.	Towel stand fixed, problem solved		Sugumari. M. - Male Surgery	01/12/2022
1693	22110781	Male Surgery - Ward 201	NEED REPAIRING FOR BERO LOCK - STUCK	Ekambaram. K.	Bero lock repaired and serviced, problem solved		Kanimozhi. N - Male Surgery	01/12/2022
Comp. Dt. : 21/11/2022 Status : Completed								
1694	22110873	Male Surgery - Ward 202	SINK PAINTING WORK NEED TO DO	Manimaran. A.	Paining work completed		Ananthi. S. - Male Surgery	01/12/2022
Comp. Dt. : 24/11/2022 Status : Completed								
1695	22111055	Male Surgery - Ward 202	MASON WORK IN REST ROOM	Murugavel	Door frame plastering work completed		Sangeedha. M. - Male Surgery	01/12/2022
Comp. Dt. : 06/12/2022 Status : Completed								
1696	22120274	Male Surgery - Ward 202	PATIENT COT GOT DAMAGED	Sarathy. A.	Cot repaired and serviced, problem solved		Kanimozhi. N - Male Surgery	19/12/2022
Comp. Dt. : 12/12/2022 Status : Completed								
1697	22120502	Female Surgery - Ward 205	MEDICINE TROLLY WHEEL PROBLEM	Sarathy. A.	Trolley wheel refixed, work completed		Ezhilarasi. E. - Male Surgery	19/12/2022
Comp. Dt. : 10/01/2023 Status : Completed								
1698	23010416	Male Surgery - Ward 201	FLOOR TILES BROKEN, TOUCHUP WORK NEEDED	Murugavel	20Nos of Tiles refixed, JK white cement pointing work completed		Kanimozhi. N - Male Surgery	23/01/2023
Comp. Dt. : 20/01/2023								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
1699	23010722	Female Surgery - Ward 206	NEED PAINTING WORK FOR BERO 3 NOS & COUCH 4 NOS	Manimaran. A.	Bero and couch painted, work completed		Sivasankari. T. - Male Surgery	30/01/2023
Comp. Dt. : 17/02/2023								
Status : Completed								
1700	23020692	Male Surgery - Ward 201	NEED TO RIFIX DOOR FOR CENTRAL PIPELINE DUCT - OPENED - NEED URGENT SERVICE	Ekambaram. K.	Duct door refixed, work completed		Kanimozhi. N - Male Surgery	23/02/2023
Comp. Dt. : 25/02/2023								
Status : Completed								
1701	23020982	Male Surgery - Ward 201	NEED REPAIRING WORK FOR WHEEL CHAIR WHEEL - STUCK	Sarathy. A.	WHEEL REPAIRED		Malathy. S - Male Surgery	07/03/2023
Comp. Dt. : 28/02/2023								
Status : Completed								
1702	23021069	Male Surgery - Ward 201	ECG MACHINE ONE WHEEL BROKEN	Ekambaram. K.	NEW WHEEL CHANGED.		Malathy. S - Male Surgery	07/03/2023
Comp. Dt. : 03/03/2023								
Status : Completed								
1703	23030156	Male Surgery - Ward 201	NEED PAINTING WORK FOR FOOT STOOL & IV STAND	Manimaran. A.	Painting work completed		Kanimozhi. N - Male Surgery	09/03/2023
Comp. Dt. : 07/03/2023								
Status : Completed								
1704	23030253	Male Surgery - Ward 201	NEED REPAIRING WORK FOR COT - BROKEN & BEND	Sarathy. A.	COT REPAIRED.Q		Kanimozhi. N - Male Surgery	14/03/2023
Comp. Dt. : 28/03/2023								
Status : Completed								
1705	23031200	Male Surgery - Ward 201	NEED TO REFIT " C P R CHART "	Ekambaram. K., Sundaramoorthy. G., Sarathy. A.	Board fixed, problem solved		Malathy. S - Male Surgery	13/04/2023
Comp. Dt. : 05/04/2023								
Status : Completed								
1706	23040145	Female Surgery - Ward 206	NEED TO REFIX COT BUSH [5NOS]	Sarathy. A.	Bush fixed		Raveena. K. - Male Surgery	18/04/2023
Comp. Dt. : 16/04/2023								
Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1707	23040480	Male Surgery - Ward 202	NEED TO FIX NEW PATLOCK FOR DOCTOR'S ROOM	Ekambaram. K.	PADLOCK FIXED		Kanimozhi. N - Male Surgery	02/05/2023
Comp. Dt. : 26/05/2023 Status : Completed								
1708	23051041	Female Surgery - Ward 205	NEED REPAIRING WORK FOR DRESSING TROLLEY - WHEEL STUCK	Sarathy. A.	WHEEL REPAIRED		Raveena. K. - Male Surgery	03/06/2023
Dept Name : Marketing Team - Work Shop Comp. Dt. : 17/05/2022 Status : Completed								
1709	22050584	FEVER CLINIC	NEED TO REFIX PATLOCK FOR COMPUTER BOX	Pachaimuthusamy. D.	Pad lock fixed, problem solved		Amirtharaj. A. - Marketing Team	27/05/2022
Comp. Dt. : 11/07/2022 Status : Completed								
1710	22070415	SPECIAL WARD---B	NEED REPAIRING WORK FOR PATIENT RESTROOM INSIDE DOOR LOCK FOR ROOM NO B7 - NEED URGENT SERVICE	Pachaimuthusamy. D.	4" T Belt fixed, problem solved		Prithivi. G. - Marketing Team	20/07/2022
Comp. Dt. : 22/07/2022 Status : Completed								
1711	22070817	CANTEEN - OPP TO SPECIAL CLINIC 100	NEED TO REFIX STEPS HANDLE - BROKEN - NEED URGENT SERVICE	Parthiban.K.	Hndle refixed in properly, problem solved		Prithivi. G. - Marketing Team	05/08/2022
1712	22070822	SPECIAL WARD---B	NEED REPAIRING WORK FOR RESTROOM DOOR LOCK - ROOM NO B19-20-21	Ekambaram. K.	Restroom door fixed. work completed.		Prithivi. G. - Marketing Team	24/09/2022
Comp. Dt. : 29/09/2022 Status : Completed								
1713	22091169	SPECIAL WARD---B	RESTROOM TILES BROKEN - NEED TOUCHUP WORK FOR ROOM NO 4 & 6	Murugavel	16Nos of Tiles refixed, JK white cement pointing work completed		Gokulraj. K. - Marketing Team	08/10/2022
Comp. Dt. : 08/11/2022 Status : Completed								
1714	22110287	CUSTOMER CARE EXECUTIVE-RECEPTION	ROLLING CHAIR PROBLEM	Sarathy. A.	Rolling chair screw fixed		Shameena Begum. A. - Marketing Team	18/11/2022
Comp. Dt. : 15/11/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1715	22110629	SPECIAL WARD A1-FOURTH FLOOR	IN ROOM NO.8-DOOR CLOSER PROBLEM	Ekambaram. K.	Door closer adjusted.		Prithivi. G. - Marketing Team	21/11/2022
Comp. Dt. : 09/12/2022 Status : Completed								
1716	22120433	Chairman Office	NEED REPAIRING WORK FOR MAIN DOOR - SOUND PROBLEM NEED URGENT SERVICE	Ekambaram. K.	Door repaired and serviced, problem solved		Priya. A. - Marketing Team	19/12/2022
Comp. Dt. : 22/12/2022 Status : Completed								
1717	22121030	CUSTOMER CARE EXECUTIVE-RECEPTIO N	WHEEL CHAIR HANDLE BROKEN	Sarathy. A.	Wheel chair handle fixed, problem solved		Sathiya Priya. J. - Marketing Team	29/12/2022
Comp. Dt. : 22/03/2023 Status : Completed								
1718	23030899	Reception	NEED REPAIRING WORK FOR ROLLING CHAIR WHEEL - STUCK	Sarathy. A.	CHAIR WHEEL REPAIRED.		Sathiya Priya. J. - Marketing Team	01/04/2023
Comp. Dt. : 05/05/2023 Status : Completed								
1719	23050211	Reception	NEED REPAIRING WORK FOR CHAIR HANDLE FOR C C COUNTER	Ekambaram. K.	HANDLE REFIXED		Sathiya Priya. J. - Marketing Team	17/05/2023
Comp. Dt. : 27/06/2023 Status : Completed								
1720	23060997	IVF ART CLINIC-INSIDE OF OG OPD(NO.68)	KEY MISSING - NEED TO BROKE LOCK FOR INSIDE RESTROOM	Ekambaram. K.	Letter to be provided.		Sathiya. M. - Marketing Team	08/07/2023
Dept Name : Medical Records - Work Shop Comp. Dt. : 12/05/2022 Status : Completed								
1721	22050422	CASHCOUNTER IN RECEPTION	CASH DRAWER OPEN CLOSER PROBLEM	Pachaimuthusamy. D.	Cash draw lock repaired and serviced, problem solved		Iyyanar. D. - Medical Records	27/05/2022
Comp. Dt. : 27/05/2022 Status : Completed								
1722	22051011	Medical Records	NEED TABLE CUTTING WORK & REFIX PATLOCK FOR BERO [2 NOS]	Pachaimuthusamy. D.	Pad lock fixed.		Martin Prabu.V. - Medical Records	10/06/2022
Comp. Dt. : 20/06/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1723	22060707	Male Surgery	NEED REPAIRING WORK FOR NURSE'S CABIN DRAW FOR MALE SURGERY 203 & 204	Pachaimuthusamy. D.	Nurses cabin draw wheel fixed.		Praveena. V. - Medical Records	23/06/2022
Comp. Dt. : 05/07/2022 Status : Completed								
1724	22070175	Male Surgery - Ward 204	NEED REPAIRING WORK FOR DOCTOR'S ROOM DOOR	Pachaimuthusamy. D.	Novapam door fixed, work completed		Praveena. V. - Medical Records	18/07/2022
Comp. Dt. : 06/07/2022 Status : Completed								
1725	22070183	Medical Records	NEED TO FIXED LAYER FOR TABLE CUPBOARD	Pachaimuthusamy. D.	2' X 1' plywood fixed, problem solved		Basheer Ahamed Khan. C - Medical Records	18/07/2022
Comp. Dt. : 07/07/2022 Status : Completed								
1726	22070250	Medical Records	NEED REPAIRING WORK FOR FOOT STOOL - REFIX NAIL	Venkatesan. R.	Stool nail refixed, problem solved		Avanthia. R. - Medical Records	18/07/2022
Comp. Dt. : 25/07/2022 Status : Completed								
1727	22070924	Medical Records	NEED TO FIX NEW PATLOCK FOR TABLE DRAWER	Parthiban.K.	New padlock fixed, problem solved		Basheer Ahamed Khan. C - Medical Records	05/08/2022
Comp. Dt. : 29/07/2022 Status : Completed								
1728	22071046	Medical Records	NEED REPAIRING WORK FOR ENTRANCE DOOR	Parthiban.K.	Door stopper repaired and serviced, problem solved		Martin Prabu.V. - Medical Records	05/08/2022
Comp. Dt. : 01/08/2022 Status : Completed								
1729	22080001	COMMON TOILET NEAR OPHTAL OPD	NEED REPAIRING WORK FOR FEMALE RESTROOM DOOR NO 3 - PROBLEM IN DOOR CLOSING	Ekambaram. K.	Rest room door repaired and serviced, refixed the door, problem solved		Sukanya. S. - Medical Records	08/08/2022
Comp. Dt. : 05/08/2022 Status : Completed								
1730	22080186	COMMON TOILET NEAR OPHTAL OPD	NEED REPAIRING WORK FOR RESTROOM DOOR - NOT CLOSING PROPER - ROOM NO 3 AT FEMALE COMMON RESTROOM NE	Parthiban.K.	Door repaired and refixed in properly, problem solved		Sukanya. S. - Medical Records	17/08/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 05/09/2022								
Status : Completed								
1731	22090150	Medical Records	NEED TO REFIX DOOR HANDLE - BROKEN AT M R D ENTRANCE DOOR	Ekambaram. K.	Handle fixed. Pad lock fixed.		Martin Prabu.V. - Medical Records	24/09/2022
1732	22090165	Medical Records	NEED TO FIX PATLOCK FOR TABLE DRAW	Ekambaram. K.	Pad lock fixed.		Moorthy.R. - Medical Records	24/09/2022
Comp. Dt. : 14/09/2022								
Status : Completed								
1733	22090525	Medical Records	NEED REPAIRING WORK & RESET FOR ROLLING CHAIR	Sarathy. A.	Chair repaired and serviced, problem solved		Martin Prabu.V. - Medical Records	29/09/2022
Comp. Dt. : 21/09/2022								
Status : Completed								
1734	22090842	Medical Records	NEED REPAIRING WORK FOR ROLLING CHAIR	Sarathy. A.	Chair welding work completed		Martin Prabu.V. - Medical Records	29/09/2022
Comp. Dt. : 23/09/2022								
Status : Completed								
1735	22090909	Medical Records	NEED REPAIRING WORK FOR ROLLING CHAIR & LADDER	Sarathy. A.	Chair and ladder repaired, problem solved		Martin Prabu.V. - Medical Records	08/10/2022
Comp. Dt. : 12/10/2022								
Status : Completed								
1736	22100363	Medical Records	COMPUTER TABLE KEY BOARD TRAY & DRAW NOT WORKING - STUCK	Ekambaram. K.	Computer keybopard tray and draw repaired and serviced, problem solved		Iswin Joseph.M. - Medical Records	16/11/2022
Comp. Dt. : 20/10/2022								
Status : Completed								
1737	22100690	Female Ortho - Ward 402	CUPBOARD NOT WORKING	Ekambaram. K.	Cupboard fixed.		Yogeswari. P. - Super Speciality OPD	29/10/2022
Comp. Dt. : 21/10/2022								
Status : Completed								
1738	22100722	SUPER SPECILAITY OPD IN 2ND FLOOR	IN RECEPTION -HOLES NEED TO BE FIX ON TABLE	Ekambaram. K.	Holes grilled.		Martin Prabu.V. - Medical Records	29/10/2022
Comp. Dt. : 18/11/2022								
Status : Completed								
1739	22110786	Medical Records	NEED TO REFIX PATLOCK FOR BERO	Ekambaram. K.	Padlock fixed, problem solved		Martin Prabu.V. - Medical Records	01/12/2022
1740	22110790	SPECIALITY OPD	NEED REPAIRINGWORK FOR KEY BOARD DRAW-SPECIALITY OPD II FLOOR	Ekambaram. K.	New keyboard draw wheel changed, work completed		Punitha. P. - Medical Records	01/12/2022

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 31/01/2023 Status : Completed								
1741	23011127	Medical Records	NEED TO REFIX PATLOCK 4 NOS - BROKEN - NEED URGENT SERVICE	Ekambaram. K.	4Nos of padlock fixed		Martin Prabu.V. - Medical Records	11/02/2023
Comp. Dt. : 28/02/2023 Status : Completed								
1742	23021068	Medical Records	NEED TO FIX WIRE CHAIR BOLTS AND NUTS	Ganesh. S.	CHAIR SCREW FIXED.		Sivaprakasam. V. - Medical Records	07/03/2023
Comp. Dt. : 06/03/2023 Status : Completed								
1743	23030215	Male Surgery - Ward 204	NEED REPAIRING WORK FOR NURSE'S CABIN LOCKER	Ekambaram. K.	Nurses cabin door repaired and serviced, problem solved		Praveena. V. - Medical Records	09/03/2023
Comp. Dt. : 19/04/2023 Status : Completed								
1744	23040570	Medical Records	NEED REPAIRING WORK FOR DOOR LOCK - STUCK	Ekambaram. K.	BAMNNER FIXED		Martin Prabu.V. - Medical Records	02/05/2023
1745	23040577	Work Shop	NEED TO PASTE BANNER FOR ADVERTISEMENT VEHICLE	Ekambaram. K.	HANDLE WELDED		Manivannan. S. - Medical Records	02/05/2023
Comp. Dt. : 17/05/2023 Status : Completed								
1746	23050703	Medical Records	NEED REPAIRING WORK FOR ROLLING CHAIR 3 NOS	Ekambaram. K.	WORK COMPLETED		Martin Prabu.V. - Medical Records	01/06/2023
Comp. Dt. : 12/06/2023 Status : Completed								
1747	23060383	Medical Records	NEED REPAIRING WORK FOR ROLLING CHAIR	Ekambaram. K.	New wheel replaced		Martin Prabu.V. - Medical Records	20/06/2023
Dept Name : MICROBIOLOGY - Work Shop Comp. Dt. : 02/05/2022 Status : Completed								
1748	22050051	MICROBIOLOGY	NEED TO CLOSE SINK HOLE WITH PLYWOOD SHEET OR CEMENT	Pachaimuthusamy. D.	Cement sheet fixed, problem solved		Karthik. S. - MICROBIOLOGY	26/05/2022
Comp. Dt. : 20/05/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1749	22050759	MICROBIOLOGY	NEED REPAIRING WORK FOR CUPBOARD PATLOCK - NOT WORKING	Ekambaram. K.	New padlock fixed, problem solved		Karthik. S. - MICROBIOLOGY	28/05/2022
	Comp. Dt. : 10/06/2022							
	Status : Completed							
1750	22060386	microbiology opd lab	IN ROOM NO.43-DOOR CLOSER BROKEN,CHANGE IT	Ekambaram. K.,Venkatesan. R.,Pachaimuthusamy . D.	Door closer adjusted.		Karthik. S. - MICROBIOLOGY	21/06/2022
	Comp. Dt. : 07/09/2022							
	Status : Completed							
1751	22090273	MICROBIOLOGY	NEED TO REFIX DRESS HANGER	Ekambaram. K.	Hanger fixed.		Vinothini. V. - MICROBIOLOGY	24/09/2022
	Comp. Dt. : 05/10/2022							
	Status : Completed							
1752	22100030	MICROBIOLOGY	NEED REPAIRING WORK FOR DOOR - DAMAGE	Ekambaram. K.	Door repaired and serviced, problem solved		Gomathi. A. - MICROBIOLOGY	12/10/2022
	Comp. Dt. : 08/10/2022							
	Status : Completed							
1753	22100180	microbiology lab	DOOR BROKEN	Ekambaram. K.,Venkatesan. R.,Sundaramoorthy. G.	Door repaired and serviced, problem solved		Arunachalam. G. - MICROBIOLOGY	12/10/2022
	Comp. Dt. : 10/10/2022							
	Status : Completed							
1754	22100227	MICROBIOLOGY	NEED REPAIRING WORK FOR CUPBOARD - BROKEN -	Ekambaram. K.	Cup board repaired, work completed		Karthik. S. - MICROBIOLOGY	12/10/2022
	Comp. Dt. : 22/11/2022							
	Status : Completed							
1755	22110924	MICROBIOLOGY	NEED REPAIRING WORK FOR STEEL BERO LOCK 2NOS - BROKEN	Ekambaram. K.	New lock changed, problem solved		Karthik. S. - MICROBIOLOGY	01/12/2022
	Comp. Dt. : 03/05/2023							
	Status : Completed							
1756	23050094	MICROBIOLOGY	NEED REPAIRING WORK FOR DOOR - BROKEN	Ekambaram. K.	DOOR REPAIRED		Vinothini. V. - MICROBIOLOGY	17/05/2023
	Comp. Dt. : 09/05/2023							
	Status : Completed							


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1757	23050359	MICROBIOLOGY	NEED REPAIRING WORK FOR DOOR - BROKEN - NEED URGENT SERVICE	Ekambaram. K.	DOOR STOPER CHANGED		Vinothini. V. - MICROBIOLOGY	18/05/2023
Comp. Dt. : 17/05/2023 Status : Completed								
1758	23050698	MICROBIOLOGY	NEED REPAIRING WORK FOR MAIN DOOR , HANDLE & GLASS DOOR WINDOW - GLASS BROKEN	Ekambaram. K.	Glass fixed.		Karthik. S. - MICROBIOLOGY	05/08/2023
Dept Name : MS Office - Work Shop Comp. Dt. : 02/05/2022 Status : Completed								
1759	22050032	Female Ortho - Ward 401	TILES BROKEN AT WORD ENTRANCE - NEED TOUCHUP WORK	Murugavel	broken tiles changed, Tiles jk white cement pointing work completed		Sundarrajan. R. - MS Office	12/05/2022
Comp. Dt. : 06/05/2022 Status : Completed								
1760	22050171	Female Ortho - Ward 402	8 NOS OF TILES AIR CRACK - NEED TOUCHUP WORK	Murugavel	8Nos of tiles replaced, Touchup work completed		Sundarrajan. R. - MS Office	12/05/2022
Comp. Dt. : 17/05/2022 Status : Completed								
1761	22050633	HOSPITAL IV FLOOR	TILES AIR BREAK - BROKEN - NEED TOUCHUP WORK - OPP TO 401 CARITOR NEED URGENT SERVICE	Murugavel	30Nos of tiles refixed, JK White cement pointing work done, work completed		Sundarrajan. R. - MS Office	27/05/2022
Comp. Dt. : 24/05/2022 Status : Completed								
1762	22050888	Male Medical - Ward 303	NEED TO CLOSE DUCT DOOR	Ekambaram. K.	Duct door closed, problem solved		Sundarrajan. R. - MS Office	28/05/2022
1763	22050889	Female Medical Ward	CEILING DAMAGE & BROKEN AT ENTRANCE OF WARD 305 & 306 - NEED TOUCHUP WORK	Murugavel	Ceiling damage area plastering work completed		Sundarrajan. R. - MS Office	28/05/2022
Comp. Dt. : 25/05/2022 Status : Completed								
1764	22050931	Female Medical - Ward 306	TILES BROKEN - NEED TOUCHUP WORK	Murugavel	12 nos tiles refixed		Sundarrajan. R. - MS Office	10/06/2022
Comp. Dt. : 30/05/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1765	22051087	MEDICAL STORE IN BASEMENT	TILES BROKEN - NEED TOUCHUP WORK - OPP TO BASEMENT MEDICAL STORES	Murugavel	Tiles refixed. JK white painting work.		Sundarrajan. R. - MS Office	10/06/2022
		Comp. Dt. : 31/05/2022 Status : Completed						
1766	22051128	CANTEEN - OPP TO SPECIAL CLINIC 100	RED TILES BROKEN - NEED TOUCHUP WORK	Murugavel	Tiles fixed and JK white applied		Sundarrajan. R. - MS Office	10/06/2022
		Comp. Dt. : 02/06/2022 Status : Completed						
1767	22060076	OPD -225 IN 2ND FLOOR	TILES AIR LOCK AT ENTRANCE - NEED TOUCHUP	Murugavel	12m tiles refixed.		Sundarrajan. R. - MS Office	10/06/2022
		Comp. Dt. : 06/06/2022 Status : Completed						
1768	22060231	HOSPITAL III FLOOR	NEED CEILING TOUCHUP WORK FOR III FLOOR WARD NO 303 EXIT WAY STAIRCASE -	Murugavel	Ceiling plastering work done		Sundarrajan. R. - MS Office	10/06/2022
		Comp. Dt. : 13/06/2022 Status : Completed						
1769	22060470	MS Office	NEED TO FIX A NAIL FOR MS SIR CABIN - NEED URGENT	Ekambaram. K.	Nail fixed.		Nageswari. N. - MS Office	21/06/2022
		Comp. Dt. : 28/06/2022 Status : Completed						
1770	22060987	COMMERCIAL BLOCK	MARBLES BROKENED NEED TOUCHUP WORK NEAR CANTEEN WAY STEPS	Murugavel	Mrables refixed		Sundarrajan. R. - MS Office	05/07/2022
		Comp. Dt. : 09/07/2022 Status : Completed						
1771	22070391	Reception	PILLAR BEADING NEED TO REFIX AT RECEPTION COUNTER	Pachaimuthusamy. D.	Beading refixed in properly, problem solved		Sundarrajan. R. - MS Office	20/07/2022
		Comp. Dt. : 11/07/2022 Status : Completed						
1772	22070411	ORTHO OT	NEED TO REFIX MIRROR FOR MALE RESTROOM	Ekambaram. K.	Its already there. wrong complaint		Sundarrajan. R. - MS Office	20/07/2022
		Comp. Dt. : 12/07/2022 Status : Completed						


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1773	22070452	SCAN - GROUND FLOOR - BLOOD BANK OPP	NEED WELDING WORK FOR 3 SEATER STEEL CHAIR	Sarathy. A.	Welded and painted.		Sundarrajan. R. - MS Office	24/09/2022
Comp. Dt. :		13/07/2022						
Status :		Completed						
1774	22070518	SPECIAL WARD---B	NEED REPAIRING & CEMENT WORK FOR COMMON RESTROOM DOOR & NEAR FLOOR [DAMAGE & BROKED	Murugavel,Sankar. T. M.,Ekambaram. K.	Rest room Door repaired and serviced, Holes packing work completed		Sundarrajan. R. - MS Office	01/08/2022
Comp. Dt. :		25/07/2022						
Status :		Completed						
1775	22070921	Male Medical Ward	NEED TO CHECK DUCT DOOR - NOT CLOSING PROPERLY - NEED URGENT SERVICE AT WARD NO 301 & 302	Parthiban.K.	New door fixed, work completed		Sundarrajan. R. - MS Office	05/08/2022
Comp. Dt. :		26/08/2022						
Status :		Completed						
1776	22080900	ENT WARD-407	TILES BROKEN - NEED TOUCHUP WORK AT ENTRANCE	Murugavel	Tiles refixed,		Sundarrajan. R. - MS Office	09/09/2022
1777	22080901	Male Ortho - Ward 404	TILES BROKEN - NEED TOUCHUP WORK AT ENTRANCE	Murugavel	Tiles fixed.		Sundarrajan. R. - MS Office	09/09/2022
1778	22080902	Female Ortho - Ward 401	TILES BROKEN - NEED TOUCHUP WORK AT ENTRANCE	Murugavel	Tiles fixed.		Sundarrajan. R. - MS Office	09/09/2022
1779	22080914	SPECIAL WARD---B	TILES AIR LOCK	Murugavel	14m + 2m new tiles fixed and jk white applied.		Sundarrajan. R. - MS Office	09/09/2022
Comp. Dt. :		01/09/2022						
Status :		Completed						
1780	22090024	Male Medical - Ward 301	TILES & PILLAR SLAB BROKEN & DAMAGE - NEED TOUCHUP WORK AT WARD NO 301 ENTRANCE & OPP -	Murugavel	Tiles refixed and marble fixed.		Sundarrajan. R. - MS Office	08/09/2022
Comp. Dt. :		09/09/2022						
Status :		Completed						
1781	22090357	Female Ortho - Ward 401	TILES AIRCRACK AT ENTRANCE 6 NOS & OPPOSITE CARITOR 4 NOS - NEED TOUCHUP WORK	Murugavel	18Nos of Tiles refixed, JK White cement pointing work completed		Sundarrajan. R. - MS Office	29/09/2022
Comp. Dt. :		13/09/2022						
Status :		Completed						


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1782	22090509	Male Ortho - Ward 404	TILES [6NOS] AIR CRACK - NEED TOUCHUP WORK	Murugavel	Tiles refixed and JK White cement pointing work completed		Sundarrajan. R. - MS Office	29/09/2022
1783	22090510	ENT WARD-407	TILES [4 NOS] AIR CRACK - NEED TOUCHUP WORK AT ENT ENTRANCE	Murugavel	Tiles refixed and JK White cement pointing work completed		Sundarrajan. R. - MS Office	29/09/2022
Comp. Dt. : 19/09/2022 Status : Completed								
1784	22090749	Reception	NEED REPAIRING WORK FOR CASH DRAW - BROKEN FOR COUNTER NO 13	Parthiban.K.	Cash draw repaired and lock fixed, problem solved		Sundarrajan. R. - MS Office	16/11/2022
Comp. Dt. : 20/09/2022 Status : Completed								
1785	22090787	OPTICAL SHOP NEAR OPHTHAL OPD	NEED TO REFIX OPHTHAL DISPLAY BOARD AT OPHTHAL OPD	Ekambaram. K.	Board fixed, problem solved		Sundarrajan. R. - MS Office	29/09/2022
1786	22090788	Pay Pharmacy	NEED TO REFIX " FIRE EXTN " BOARD AT PAY PHARMACY CARITOR	Ekambaram. K.	Board fixed, work completed		Sundarrajan. R. - MS Office	29/09/2022
Comp. Dt. : 27/09/2022 Status : Completed								
1787	22091034	Surgery OPD	NEED TO REFIX WHEEL CHAIR WHEEL - BROKEN	Sarathy. A.	2Nos of wheel changed in wheel chair, problem solved		Sundarrajan. R. - MS Office	08/10/2022
Comp. Dt. : 10/10/2022 Status : Completed								
1788	22100247	MEDICAL COLLEGE	NEED TO REFIX DOOR STOPPER & NEW LOCK FOR DOOR AT MEDICAL COLLEGE SKILL LAB	Parthiban.K.	New door stopper and lock changed, problem solved		Prabhakaran. S. - Medical Records	20/10/2022
Comp. Dt. : 11/10/2022 Status : Completed								
1789	22100303	RADIOLOGY	NEED TO REFIX ENTRANCE " DISPLAY NAME BOARD"	Sundaramoorthy. G.	Display name board fixed, problem solved		Sundarrajan. R. - MS Office	20/10/2022
Comp. Dt. : 28/10/2022 Status : Completed								
1790	22100934	COMMON MALE TOILET NEAR BIOCHEMISTRY	WESTERN TOILET ROOM DOOR INNER LOCK NEED TO BE FIX	Ekambaram. K.	Pad lock fixed.		Sundarrajan. R. - MS Office	03/11/2022
Comp. Dt. : 10/11/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1791	22110399	CLINICAL DEPARTMENT IN 3RD FLOOR	IN OUTSIDE PORTICO-TILES AIRCRACK PROBLEM	Murugavel	2Nos of New tiles fixed, JK white cement pointing work completed		Sundarrajan. R. - MS Office	18/11/2022
	Comp. Dt. : 22/11/2022							
	Status : Completed							
1792	22110905	HOSPITAL I FLOOR D WING	TILES 10 NOS CRACK AT I FLOOR LIFT NO 5 OPP	Murugavel	Tiles refixed, JK white cement pointing work completed		Sundarrajan. R. - MS Office	01/12/2022
	Comp. Dt. : 15/12/2022							
	Status : Completed							
1793	22120707	Hospital	PILLAR SLAB MARBLE BROKEN - NEED TOUCHUP WORK - GROUND FLOOR LIFT NO 3 OPPOSITE	Murugavel	Marble refixed, JK white cement pointing work completed		Sundarrajan. R. - MS Office	23/12/2022
	Comp. Dt. : 20/12/2022							
	Status : Completed							
1794	22120903	LIFT 5	IN 3RD FLOOR LIFT NO 5 OPPOSITE PILLAR MARBLE TILES BROKEN	Murugavel	marbles fixed, JK white cement pointing work completed		Sundarrajan. R. - MS Office	29/12/2022
	Comp. Dt. : 25/01/2023							
	Status : Completed							
1795	23010923	SPECIAL OPD IN 2ND FLOOR	NEED TO REFIX DISPLAY BOARD AT ENTRANCE	Ekambaram. K.	Board refixed, work completed		Sundarrajan. R. - MS Office	16/02/2023
	Comp. Dt. : 03/02/2023							
	Status : Completed							
1796	23020082	Main Lobby	MARBLE TILES BROKEN - NEED TOUCHUP WORK BOTH SIDE [OPHTHAL & FREE PHARMACY]	Murugavel	Tiles Jk white cement pointing work completed		Sundarrajan. R. - MS Office	11/02/2023
	Comp. Dt. : 10/02/2023							
	Status : Completed							
1797	23020385	LIFT 1	WALL SLAB TILES BROKEN - LIFT NO.1 OPOSITE	Murugavel	Marble's fixed, JK white cement pointing work completed		Sundarrajan. R. - MS Office	16/02/2023
	Comp. Dt. : 22/02/2023							
	Status : Completed							
1798	23020832	Reception	PILLAR BEADING FIXING WORK	Murugavel	Beading fixed, work completed		Sundarrajan. R. - MS Office	01/03/2023
	Comp. Dt. : 27/02/2023							
	Status : Completed							


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1799	23021003	Male Medical Ward	PILLAR SLAB DAMAGE NEED TOUCHUP WORK AT OPP TO WARD NO 301 & 302	Manimaran. A.	PILLAR SLAB TOUCH UP WORK DONE		Sundarrajan. R. - MS Office	07/03/2023
	Comp. Dt. : 11/03/2023 Status : Completed							
1800	23030449	Special Ward - A	TILES AIR LOCK - NEED TOUCH UP WORK AT III FLOOR SPE WARD "A" CARITOR	Parivallal. P.	TILES REFIXED. JK WHITE APPLIED		Sundarrajan. R. - MS Office	23/03/2023
	Comp. Dt. : 15/03/2023 Status : Completed							
1801	23030588	Hospital	TILES BROKEN - NED TOUCHUP WORK AT II & IV FLOOR CARITOR	Parivallal. P.	WORK COMPLETED		Sundarrajan. R. - MS Office	23/03/2023
	Comp. Dt. : 24/03/2023 Status : Completed							
1802	23030993	MEDICAL COLLEGE OPP FOUNTAIN	NEED TO REARRANGE IRON RODS AT MEDICAL COLLEGE OPP STEP PATH	Veerappan. D.,Venkatesan. R.,Ganesh. S.	WORK COMPLETED		Sundarrajan. R. - MS Office	04/05/2023
	Comp. Dt. : 13/04/2023 Status : Completed							
1803	23040401	HOSPITAL IV FLOOR	TILES BROKEN AT CARITOR	Parivallal. P.	Wrong complaint		Sundarrajan. R. - MS Office	20/04/2023
	Comp. Dt. : 17/04/2023 Status : Completed							
1804	23040495	Free Pharmacy	NEED WELDING WORK FOR STEEL RAMP	Sarathy. A.	HANDLE WELDED		Sundarrajan. R. - MS Office	02/05/2023
	Comp. Dt. : 19/04/2023 Status : Completed							
1805	23040609	Female Medical - Ward 307	TILES BROKEN NEED TOUCH UP WORK AT WARD NO 307 ENTRANCE & CARITOR	Parivallal. P.	10 NOS TILE REFIXED AND JK WHITE APPLIED		Sundarrajan. R. - MS Office	02/05/2023
	Comp. Dt. : 27/04/2023 Status : Completed							
1806	23040902	HOSPITAL IV FLOOR	TILES BROKEN - NEED TOUCHUP WORK - AT OPPOSITE CARITOR AT WARD NO 402 & 408	Parivallal. P.	Tiles refixed, JK White cement pointing work completed		Sundarrajan. R. - MS Office	08/05/2023
	Comp. Dt. : 04/05/2023							


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
1807	23050167	BASEMENT	TILES BROKEN - NEED TOUCHUP WORK ATBASEMENT MEDICAL STORE EDP OPP CARITOR	Parivallal. P.	TILES REFIXED		Sundarrajan. R. - MS Office	17/05/2023
Comp. Dt. : 27/05/2023								
Status : Completed								
1808	23051104	HOSPITAL IV FLOOR OPP TO 403	PILLAR SLAB TILES BROKEN - NEED TOUCHUP WORK	Parivallal. P.	SLAB FIXED		Sundarrajan. R. - MS Office	03/06/2023
Comp. Dt. : 29/05/2023								
Status : Completed								
1809	23051160	Male Medical - Ward 303	PILLER SLAB TILES BROKEN - NEED TOUCHUP WORK AT III FLOOR OPP TO MALE MEDICAL WARD - 303	Parivallal. P.	WORK COMPLETED		Sundarrajan. R. - MS Office	03/06/2023
Comp. Dt. : 01/06/2023								
Status : Completed								
1810	23060012	Free Pharmacy	TILES BROKEN - NEED TOUCHUP WORK AT OPP TO FREE PHARMACY I & II FLOOR STAIRCASE	Parivallal. P.	Work completed		Sundarrajan. R. - MS Office	20/06/2023
Comp. Dt. : 09/06/2023								
Status : Completed								
1811	23060343	MS Office	TILES AIR CRACK - NEED TOUCH UP WORK AT M.S OFFICE ENTRANCE	Parivallal. P.	Tiles refixed and JK white applied		Sundarrajan. R. - MS Office	20/06/2023
Comp. Dt. : 10/06/2023								
Status : Completed								
1812	23060366	HOSPITAL II FLOOR	PILLAR SLAB TILES BROKEN NEED TOUCHUP WORK AT OPPOSITE TO II FLOOR SPECIAL CLINIC CARITOR	Parivallal. P.	Tiles refixed and JK white applied		Sundarrajan. R. - MS Office	20/06/2023
1813	23060367	Chairman Office	TILES BROKEN NEED TOUCH UP WORK AT I FLOOR CHAIRMAN OFFICE WAY	Parivallal. P.	Tiles refixed and JK white applied		Sundarrajan. R. - MS Office	20/06/2023
Comp. Dt. : 12/06/2023								
Status : Completed								
1814	23060417	Female Ortho - Ward 402	TILES BROKEN - NEED TOUCHUP WORK AT WARD INSIDE	Parivallal. P.	Tiles refixed and JK white applied		Sundarrajan. R. - MS Office	20/06/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1815	23060418	Female Ortho - Ward 402	NEED TO CHANGE WINDOW GLASS DOOR - BROKEN AT BACK SIDE	Ekambaram. K.	Wrong complaint		Sundarrajan. R. - MS Office	20/06/2023
Comp. Dt. : 14/06/2023 Status : Completed								
1816	23060494	Reception	NEED TO FIX PILLAR BEADING	Ekambaram. K.	Beading fixed.		Sundarrajan. R. - MS Office	27/06/2023
Comp. Dt. : 23/06/2023 Status : Completed								
1817	23060846	Casualty	PILLAR SLAB TILES BROKEN - NEED TOUCHUP WORK - OPPOSITE TO CASUALTY	Parivallal. P.	Work completed		Sundarrajan. R. - MS Office	07/07/2023
1818	23060847	HOSPITAL III FLOOR	PILLAR SLAB TILES BROKEN - NEED TOUCHUP WORK - OPPOSITE TO LIFT NO 5	Parivallal. P.	Work completed		Sundarrajan. R. - MS Office	07/07/2023
Comp. Dt. : 26/06/2023 Status : Completed								
1819	23060934	Reception	NEED TO REFIX PILLOR BEADING - 2 PLACES	Parivallal. P.	Beeding fixed.		Sundarrajan. R. - MS Office	07/07/2023
Dept Name : Nephrology - Work Shop Comp. Dt. : 02/05/2022 Status : Completed								
1820	22050047	DIALYSIS IN 2ND FLOOR	NEED REPAIRING WORK FOR MAIN DOOR - SOUND PROBLEM	Ekambaram. K.	Door repaired and refixed, problem solved		Sangeetha. K. - Nephrology	26/05/2022
Comp. Dt. : 01/07/2022 Status : Completed								
1821	22070020	DIALYSIS IN 2ND FLOOR	NEED REPAINTING WORK FOR AURO WATER PLANT	Manimaran. A.	Wall painting work completed		Aathimoolam. R. - Nephrology	20/07/2022
Comp. Dt. : 30/07/2022 Status : Completed								
1822	22071109	DIALYSIS IN 2ND FLOOR	NEED TO CHECK WALL TILES WOODEN PARTS AT DOOR SIDE - DAMAGE & BROKEN & FUNGUS FORMATION	Murugavel	Tiles changed, door parts cleaned and cement binding work completed		Suganya. B. - Nephrology	05/08/2022
Comp. Dt. : 26/08/2022 Status : Completed								
1823	22080881	DIALYSIS NEW UNIT IN 1ST FLOOR	NEED TO REFIX DOOR STOPER FOR 2 DOORS	Ekambaram. K.	Door repaired.		Aathimoolam. R. - Nephrology	09/09/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 21/09/2022 Status : Completed								
1824	22090855	DIALYSIS NEW UNIT IN 1ST FLOOR	NEED REPAIRING WORK FOR WINDOW - PROBLEM IN CLOSING	Ekambaram. K.	No complaint in Dialysis room		Kamal. B. - Nephrology	29/09/2022
Comp. Dt. : 14/12/2022 Status : Completed								
1825	22120633	DIALYSIS IN 2ND FLOOR	NEED DRILLING WORK FOR " BIO MEDICAL WASTE" BOARD FIXING WORK	Ekambaram. K.	Wrong complaint.		Suganya. D. - Nephrology	23/12/2022
Comp. Dt. : 22/12/2022 Status : Completed								
1826	22121018	DIALYSIS IN 2ND FLOOR	WATER LEAKAGE - CEMENT WORK	Murugavel	Mason work completed		Suganya. B. - Nephrology	29/12/2022
Comp. Dt. : 09/01/2023 Status : Completed								
1827	23010350	DIALYSIS IN 2ND FLOOR	STAND REFIXING WORK	Sarathy. A.	Monitor stand fixed		Suganya. B. - Nephrology	23/01/2023
Comp. Dt. : 25/02/2023 Status : Completed								
1828	23020963	DIALYSIS NEW UNIT IN 1ST FLOOR	NEED WELDING WORK FOR FAN	Sarathy. A.	WORK COMPLETED		Kamal. B. - Nephrology	07/03/2023
Comp. Dt. : 06/03/2023 Status : Completed								
1829	23030245	DIALYSIS IN 2ND FLOOR	NEED PAINTING WORK FOR COT 4 NOS	Manimaran. A.	COT PAINTING WORK COMPLETED		Suganya. B. - Nephrology	04/05/2023
Comp. Dt. : 17/04/2023 Status : Completed								
1830	23040513	DIALYSIS NEW UNIT IN 1ST FLOOR	NEED PAINTING WORK FOR COT [20 NOS]	Manimaran. A.	Painting work completed		Kamal. B. - Nephrology	05/08/2023
Comp. Dt. : 05/05/2023 Status : Completed								
1831	23050196	DIALYSIS IN 2ND FLOOR	TILES BROKEN - NEED TOUCHUP WORK & NEED PAINTING WORK ALSO	Manimaran. A.	TILES REFIXED		Suganya. B. - Nephrology	17/05/2023
Comp. Dt. : 23/05/2023 Status : Completed								
1832	23050940	DIALYSIS NEW UNIT IN 1ST FLOOR	NEED WELDING WORK FOR FAN BOTTOM	Sarathy. A.	WELDING WORK COMPLETED		Kamal. B. - Nephrology	03/06/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 03/06/2023 Status : Completed								
1833	23060108	DIALYSIS NEW UNIT IN 1ST FLOOR	NEED TO REFIX DOOR STOPPER 3NOS	Ekambaram. K.	Door stopper fixed		Kamal. B. - Nephrology	20/06/2023
Dept Name : Nursing Office - Work Shop Comp. Dt. : 14/05/2022 Status : Completed								
1834	22050506	Pulmonary Medicine	REVOLVING CHAIR PROBLEM	Sarathy. A.	Chair repaired and serviced, problem solved		Ilambharat.K. - Nursing Office	27/05/2022
Comp. Dt. : 17/05/2022 Status : Completed								
1835	22050599	OG-OPD	NEED REPAIRING WORK FOR MAIN DOOR - SOUND PROBLEM	Pachaimuthusamy. D.	Mian door repaired and serviced, problem solved		Velangannie.N. - Nursing Office	27/05/2022
Comp. Dt. : 24/05/2022 Status : Completed								
1836	22050876	SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	NEED TO REFIX MAIN GLASS DOOR LOCK & KEY BOARD DRAW - NEED URGENT SERVICE	Ekambaram. K.	Main door refixed, padlock changed, problem solved		Tamilarasi.C. - Nursing Office	28/05/2022
1837	22050901	Casualty	NEED PAINTING WORK FOR PATIENT STOOL , IV STAND & COT	Manivannan. A.	Welding work completed		Ilambharat.K. - Nursing Office	10/06/2022
Comp. Dt. : 26/05/2022 Status : Completed								
1838	22050977	Casualty	NEED TO FIX A NEW DOOR FOR CUPBOARD	Ekambaram. K.	New door fixed.		Prabavathi. K. - Nursing Office	10/06/2022
Comp. Dt. : 03/06/2022 Status : Completed								
1839	22060100	Female Ortho - Ward 401	NEED TO REFIX SIDE RAILS	Sarathy. A.	All cot side rails refixed.		Vani. M. - Female Ortho Ward	10/06/2022
Comp. Dt. : 04/06/2022 Status : Completed								
1840	22060166	SPECIALITY OT	NEED PAINTING WORK FOR FOOT STEP	Manimaran. A.	Foot step painted.		Velangannie.N. - Nursing Office	10/06/2022
Comp. Dt. : 07/06/2022 Status : Completed								
1841	22060266	Casualty	NEED TO FIX PATLOCK FOR HAZMAT CUPBOARD DOOR [5NOS] -	Ekambaram. K.	5 nos. pad lock fixed.		Tha.L. - Nursing Office	13/06/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 08/06/2022								
Status : Completed								
1842	22060307	ORTHO OT	NEED TO CHECK AND REFIX FALSE CEILING - DAMAGE, BROKENED & FALLING DOWN AT INSIDE OF STORE ROOM	Ekambaram. K.	welding work completed		Greeta Guna Seelan - Nursing Office	13/06/2022
1843	22060314	SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	NEED REPAIRING WORK FOR ROLLING CHAIR WHEEL	Ekambaram. K.	Chair damaged.		Tamilarasi.C. - Nursing Office	13/06/2022
Comp. Dt. : 11/06/2022								
Status : Completed								
1844	22060419	SPECIALITY OT	NEED TO FIX HANGERS	Ekambaram. K.	Hanger fixed.		Rajalakshmi. N. - Nursing Office	21/06/2022
Comp. Dt. : 23/06/2022								
Status : Completed								
1845	22060839	Obstetrics - Ward 207	NEED TO REFIX SCREEN SPRING	Pachaimuthusamy. D.,Ekambaram. K.,Sarathy. A.	4M 3 fold stand spring fixed, problem solved		Devika.R - Nursing Office	02/07/2022
Comp. Dt. : 25/06/2022								
Status : Completed								
1846	22060935	SICU	CRUSH CART NOT WORKING	Pachaimuthusamy. D.	Crush cart repaired		Chandralekha. S. - Nursing Office	05/07/2022
Comp. Dt. : 27/06/2022								
Status : Completed								
1847	22060975	Nursing Office	NEED REPAIRING WORK FOR DOOR - SOUND PROBLEM	Pachaimuthusamy. D.	Door repaired		Prabavathi. K. - Nursing Office	05/07/2022
1848	22060980	Female Casulaty	NEED TO REFIX PATLOCK FOR MAIN DOOR - NEED URGENT SERVICE	Ekambaram. K.	Pad lock fixed		Sudha.L. - Nursing Office	05/07/2022
Comp. Dt. : 01/07/2022								
Status : Completed								
1849	22070035	Paediatrics Ward	NEED TO REFIX SIDE RAILS FOR WARD NO 307.308,309 & 310	Sarathy. A.	Cot side rails and bush fixed, problem solved		Ilambharat.K. - Nursing Office	09/07/2022
Comp. Dt. : 07/07/2022								
Status : Completed								
1850	22070268	Female Medical Ward	NEED TO FIX X LOBBY FRAME AT WARD NO 307 & 308	Pachaimuthusamy. D.	X-Ray lobby frame refixed, problem solved		Devika.R - Nursing Office	18/07/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
1851	22070306	Ward	NEED TO REFIX HAND TOWEL STAND RING FOR PEADIATRICS OPD DEMOHALL , SURGERY OPD DEMOHALL & MEDICINE	Ekambaram. K.,Venkatesan. R.,Pachaimuthusamy . D.	Towel stand and ring fixed, work completed		Ilambharat.K. - Nursing Office	18/07/2022
Comp. Dt. : 09/07/2022								
Status : Completed								
1852	22070368	Surgery OPD	WHEEL CHAIR WHEEL BROKENED - NEED TO CHANGE	Sarathy. A.	New 4" wheel changed, problem solved		Ilambharat.K. - Nursing Office	20/07/2022
Comp. Dt. : 14/07/2022								
Status : Completed								
1853	22070541	Special Ward - C	NEED TO REFIX BUSH & WHEELS FOR COT , IV STAND & OTHERS	Sarathy. A.	Cot and IV Stand bush, wheel changed, work completed		Tamilarasi.C. - Nursing Office	01/08/2022
Comp. Dt. : 15/07/2022								
Status : Completed								
1854	22070593	Nursing Office	NEED REPAIRING WORK FOR "S" TYPE CHAIR	Sarathy. A.	Chair leg welding work completed		Prabavathi. K. - Nursing Office	01/08/2022
Comp. Dt. : 21/07/2022								
Status : Completed								
1855	22070797	Nursing Office	NEED REPAIRING WORK FOR " S " TYPE CHAIR - NEED URGENT SERVICE	Sarathy. A.	S Type chair bolt refixed, problem solved		Prabavathi. K. - Nursing Office	01/08/2022
Comp. Dt. : 25/07/2022								
Status : Completed								
1856	22070913	Nursing Office	NEED PAINTING WORK FOR "S" TYPE CHAIR	Sarathy. A.	S Type chair screw refixed and painting work completed, problem solved		Prabavathi. K. - Nursing Office	05/08/2022
Comp. Dt. : 26/07/2022								
Status : Completed								
1857	22070938	RICU	NEED TO REFIX CHAMBER BETWEEN WARD AND RESTROOM - DRAINAGE WATER INSIDE THE WARD COMING	Murugavel	Bend built, work completed		Powlin.P. - Nursing Office	05/08/2022
Comp. Dt. : 27/07/2022								
Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1858	22070998	Casualty	NEED TO CHANGE HYDROLIC WHEEL CHAIR WHEEL & SAFTY BELT FOR PATIENT CHAIR & STRUCTURE & 30 NOS OF WHE	Sarathy. A.	Wheel chair and structure - wheel and belt fixed, problem solved		Sudha.L. - Nursing Office	05/08/2022
		Comp. Dt. : 30/07/2022 Status : Completed						
1859	22071110	Male Surgery - Ward 203	NEED REPAIRING WORK FOR NURSE'S CABIN DOOR - BROKE	Pachaimuthusamy. D.	Door repaired and refixed in properly, problem solved		Kalaiaarasi. D. - Nursing Office	05/08/2022
		Comp. Dt. : 08/08/2022 Status : Completed						
1860	22080273	Labour Room	NEED TO REFIX SCREEN STAND SPRING 3NOS	Ekambaram. K.	Screen stand spring full box fixed		Ilambharat.K. - Nursing Office	23/08/2022
		Comp. Dt. : 10/08/2022 Status : Completed						
1861	22080365	Male Surgery - Ward 201	NEED REPAIRING WORK FOR NURSE'S CABIN DOOR - DAMAGE & BROKEN	Ekambaram. K.	Nurses cabin door repaired and refixed, problem solved		Kalaiaarasi. D. - Nursing Office	23/08/2022
		Comp. Dt. : 17/08/2022 Status : Completed						
1862	22080505	Labour Room	NEED TO DO WHITEWASH ON WHOLE LABOUR ROOM COMPLEX	Manimaran. A.	Work completed.		Rajalakshmi. N. - Nursing Office	24/09/2022
1863	22080520	Nursing Office	S-TYPE CHAIR PAINTING WORK NEED TO DO	Manimaran. A.	Chair welded and painted.		Prabavathi. K. - Nursing Office	24/09/2022
1864	22080538	ENT WARD-407	BED SIDE LOCKER DAMAGED	Sarathy. A.,Moorthy. L.,Manimaran. A.	Side locker welded and painting work completed		Ilambharat.K. - Nursing Office	26/08/2022
		Comp. Dt. : 18/08/2022 Status : Completed						
1865	22080585	Paediatrics - OPD	ENTRANCE MAIN DOOR BROKEN	Ekambaram. K.	Door repaired and serviced, problem solved		Kalaiaarasi. D. - Nursing Office	26/08/2022
		Comp. Dt. : 20/08/2022 Status : Completed						
1866	22080671	ICCU	NEED REPAIRING WORK FOR DOOR - SOUND & DAMAGE	Ekambaram. K.,Sundaramoorthy. G.,Murugavel	Door repaired and serviced, Tiles refixed, JK White cement pointing work completed		Powlin.P. - Nursing Office	26/08/2022
		Comp. Dt. : 23/08/2022 Status : Completed						


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1867	22080746	ICCU	NEED TO CHANGE DOOR GLASS FOR DRESS CHANGING ROOM DOOR	Parthiban.K.	New door glass fixed, work completed		Powlin.P. - Nursing Office	01/09/2022
1868	22080747	Nursing Office	NEED REPAIRING WORK FOR ROLLING CHAIR - BROKE [NS MADAM'S CHAIR]	Sarathy. A.	Wheel repaired and refixed in properly, problem solved		Rajalakshmi. N. - Nursing Office	01/09/2022
Comp. Dt. : 27/08/2022 Status : Completed								
1869	22080929	Casualty	NEED TO REFIX SAFETY BELT FOR WHEEL CHAIR [2NOS]	Sarathy. A.	Waiting for belt.		Sudha.L. - Nursing Office	09/09/2022
Comp. Dt. : 30/08/2022 Status : Completed								
1870	22081020	Obstetrics - Ward 208	NEED TO REFIX X RAY FRAME - DAMAGE	Ekambaram. K.	Frame fixed. Work completed.		Padma. A. - Nursing Office	24/09/2022
Comp. Dt. : 05/09/2022 Status : Completed								
1871	22090152	ENT & Ophthal Ward	TILES AIR BREAK NEED TOUCH UP WORK AT OPHthal WARD 408	Murugavel	26 nos. tiles refixed and JK white applied.		Chandralekha. S. - Nursing Office	24/09/2022
Comp. Dt. : 22/09/2022 Status : Completed								
1872	22090888	ANS DRESS CHANGING ROOM	NEED TO REFIX DRESS HANGER STAND	Ekambaram. K.	Hanger refixed, problem solved		Ilambharat.K. - Nursing Office	08/10/2022
Comp. Dt. : 24/09/2022 Status : Completed								
1873	22090965	ORTHO OT	NEED TO REFIX WHEEL FOR PATINET STRUCTURE	Sarathy. A.	New wheel 2Nos changed in patient stretcher		Rajalakshmi. N. - Nursing Office	08/10/2022
Comp. Dt. : 28/09/2022 Status : Completed								
1874	22091106	RICU	NEED TO REFIX COT [2NOS] SIDE RAILS	Sarathy. A.	Cot side rail fixed, problem solved		Powlin.P. - Nursing Office	08/10/2022
1875	22091144	Special Ward	NEED TO REFIX DOOR STOPER & CLOSER FOR SPECILA WARD A A1 , B & C	Parthiban.K.	New door colser 4Nos fixed, problem solved		Tamilarasi.C. - Nursing Office	16/11/2022
Comp. Dt. : 30/09/2022 Status : Completed								
1876	22091204	SICU	NEED ADJUSTMENT FOR MONITOR STAND	Ekambaram. K.	All monitor stand refixed, problem solved		Sury Hillary Scurvilles - Nursing Office	08/10/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 10/10/2022 Status : Completed								
1877	22100225	Casualty	NEED REPAIRING WORK FOR DRAW - BROKEN	Ekambaram. K.,Sundaramoorthy. G.,Venkatesan. R.	Draw new wheel changed, problem solved		Sudha.L. - Nursing Office	13/10/2022
Comp. Dt. : 12/10/2022 Status : Completed								
1878	22100314	SPECIAL WARD---B	TILES BROKEN OPPOSITE TO SPECIAL WARD B PILLAR	Murugavel	Tiles refixed, JK white cement pointing work completed		Tamilarasi.C. - Nursing Office	16/11/2022
Comp. Dt. : 13/10/2022 Status : Completed								
1879	22100391	Paediatrics Ward	NEED TO FIX MOSQUITO NET FOR ALL VENTILATION AT WARD NO 309 & 310	Ekambaram. K.,Parthiban.K.,Venkatesan. R.	Mosquito net fixed, problem solved		Greeta Guna Seelan - Nursing Office	06/12/2022
Comp. Dt. : 20/10/2022 Status : Completed								
1880	22100662	PICU & NICU	NAME BOARD FIXING WORK ON THE DOORS AT SECOND FLOOR NEW AREA	Ekambaram. K.	New board, stand fixed, work completed		Powlin.P. - Nursing Office	16/11/2022
Comp. Dt. : 18/11/2022 Status : Completed								
1881	22110763	FEVER CLINIC	NEED TO FIX LOCK FOR CUPBOARD - FOR SYSTEM & PRINTER KEPT LOCKER	Ekambaram. K.	Cup board locker repaired and refixed in properly, problem solved		Sudha.L. - Nursing Office	01/12/2022
1882	22110782	Female Surgery	TILES BROKEN NEED TOUCHUP WORK AT WARD NO 205 NURSES CABIN OPPOSITE AND REST ROOM FOR WARD NO 206	Murugavel	20Nos of Tiles refixed, JK white cement pointing work completed		Padma. A. - Nursing Office	01/12/2022
Comp. Dt. : 21/11/2022 Status : Completed								
1883	22110876	Female Surgery - Ward 205	FLOOR TILES BROKEN, TOUCH UP WORK NEEDED	Murugavel	Tiles refixed, Jk white cement pointing work completed		Padma. A. - Nursing Office	01/12/2022
Comp. Dt. : 24/11/2022 Status : Completed								
1884	22111035	PSYCHIATRY WARD	FLOOR TILES BROKEN, TOUCHUP WORK NEEDED	Murugavel	tiles refixed, JK white cement pointing work completed		Chandralekha. S. - Nursing Office	01/12/2022
Comp. Dt. : 02/12/2022								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
1885	22120059	SPECIAL WARD - A1	NEED TO CHECK & CHANGE FALSE CEILING DAMAGE & BROKEN - ROOM NO 4 & 5	Ekambaram. K.	10 nos. new board fixed.		Tamilarasi.C. - Nursing Office	10/12/2022
Comp. Dt. : 12/12/2022								
Status : Completed								
1886	22120525	Male Medical - Ward 303	NURSES CABIN PROBLEM	Ekambaram. K.	Nurses cabin repaired, work completed		Leena Grace. B. - Nursing Office	19/12/2022
1887	22120529	NEW NICU & PICU-2ND FLOOR	MAIN DOOR LOCK PROBLEM	Ekambaram. K.	Door lock repaired and serviced, problem solved		Devika.R - Nursing Office	19/12/2022
Comp. Dt. : 16/12/2022								
Status : Completed								
1888	22120750	ICU	NEED TO REFIX CLAMP FOR SUCTION 9NO'S AND CUPBOARD 2 NO'S	Ekambaram. K.	clamp refixed.		Powlin.P. - Nursing Office	23/12/2022
1889	22120763	SPECIAL WARD A THIRD FLOOR	WHITE CEMENT PACKAGING WORK NEED TO DO-(BOTH A AND A1 WARD)	Murugavel	white cement packing work completed.		Tamilarasi.C. - Nursing Office	23/12/2022
Comp. Dt. : 27/12/2022								
Status : Completed								
1890	22121205	ICU	REQUEST TO FIX 9 NO'S SUCTION FIXING CLAMP AND 9 NO'S MONITOR FIXING CLAMP	Sarathy. A.,Sundaramoorthy. G.,Ekambaram. K.	9Nos of clamp fixed, problem solved		Powlin.P. - Nursing Office	05/01/2023
Comp. Dt. : 28/12/2022								
Status : Completed								
1891	22121292	Paediatrics - Ward 309	WARD DOOR LOCK CANNOT OPEN	Ekambaram. K.	Lock repaired and serviced, problem solved		Leena Grace. B. - Nursing Office	05/01/2023
Comp. Dt. : 02/01/2023								
Status : Completed								
1892	23010044	ICU	FLOOR TILES BROKEN, TOUCHUP WORK NEEDED	Ekambaram. K.	Tiles refixed, JK white cement pointing work completed		Powlin.P. - Nursing Office	12/01/2023
Comp. Dt. : 03/01/2023								
Status : Completed								
1893	23010077	ICU	MOSQUITO NET FRAME REPAIRING WORK	Ekambaram. K.	Net frame refixed in properly, problem solved		Powlin.P. - Nursing Office	23/01/2023
Comp. Dt. : 04/01/2023								
Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1894	23010139	OLD NICU	COT BUSH NEED TO BE FIX FOR ALL PATIENT'S COT	Sarathy. A.	All patient cot bush fixed, work completed		Powlin.P. - Nursing Office	12/01/2023
1895	23010157	Female Medical - Ward 306	X-RAY LOBY FIXING CLAMP NEED TO BE FIX	Ekambaram. K.	X-Ray lobby clamp fixed, problem solved		Chandralekha. S. - Nursing Office	12/01/2023
Comp. Dt. : 06/01/2023 Status : Completed								
1896	23010260	ICU	NEW BOX CUTTING WORK-10 NOS	Ekambaram. K.	Work completed.		Powlin.P. - Nursing Office	11/01/2023
1897	23010267	NICU	(1141) NEED TO FIX DOOR STOPPER(INDOOR TO OUT DOOR)	Ekambaram. K.	Door stopper fixed.		Powlin.P. - Nursing Office	11/01/2023
Comp. Dt. : 09/01/2023 Status : Completed								
1898	23010360	Orthopaedics - OPD	DOUBLE SIDE DRAWER REPAIR WORK	Ekambaram. K.	Draw locker repaired and serviced, problem solved		Padma. A. - Nursing Office	23/01/2023
Comp. Dt. : 18/01/2023 Status : Completed								
1899	23010637	New OT	NEED TO REFIX PATLOCK FOR REST ROOM DOOR	Ekambaram. K.	New Padlock fixed, problem solved		Devika.R - Nursing Office	30/01/2023
Comp. Dt. : 23/01/2023 Status : Completed								
1900	23010816	SPECIAL WARD---B	NEED TO CHECK & REFIX ALL RESTROOM DOOR LOCKS [IN & OUT SIDE] & STOPERS	Ekambaram. K.	All rest room door lock checked, some doors lock repaired and refixed, work completed		Tamilarasi.C. - Nursing Office	16/02/2023
Comp. Dt. : 10/02/2023 Status : Completed								
1901	23020391	Gynaecology - OPD	NEED TO FIX PATLOCK IN POP BERO	Ekambaram. K.	New padlock fixed		Padma. A. - Nursing Office	16/02/2023
Comp. Dt. : 11/02/2023 Status : Completed								
1902	23020416	OG OT	ALL MAIN DOOR INSIDE OT-WHEN CLOSE/OPEN DONE SCRATCHES ON FLOORS	Ekambaram. K.	Wrong complaint		Devika.R - Nursing Office	08/03/2023
1903	23020417	New OT	NORCOTIC CUPBARD DOOR KEY NOT CLOSING PROPERLY	Ekambaram. K.	New key changed, problem solved		Devika.R - Nursing Office	08/03/2023
Comp. Dt. : 01/03/2023 Status : Completed								
1904	23030021	POW & SICU	NEED TO REFIX HANGER	Ekambaram. K.	Hanger refixed		Velangannie.N. - Nursing Office	09/03/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1905	23030036	Special Ward - A	NEED TO CLOSE CEILING WALL HOLE - ROOM NO 4	Murugavel	HOLE CLOSED		Tamilarasi.C. - Nursing Office	04/05/2023
Comp. Dt. : 02/03/2023								
Status : Completed								
1906	23030086	Main OT	NEED CEMENT WORK FOR WASH BASIN DAMAGE SIDE	Murugavel	Holes packing work completed		Devika.R - Nursing Office	09/03/2023
Comp. Dt. : 03/03/2023								
Status : Completed								
1907	23030136	TB & Chest OPD	PIGEON CUPBOARD LOCKER KEY MISSING - NEED TO REFIX KEY	Ekambaram. K.	Key replaced		Padma. A. - Nursing Office	09/03/2023
1908	23030137	ALL OPD'S AND WARD'S	NEED TO CHECK & REFIX ROD FOR THREE FOLDER SCREEN	Sarathy. A.	Screen spring fixed, work completed		Padma. A. - Nursing Office	09/03/2023
1909	23030150	Male Medical Ward	NEED TO REMOVE PARTITION & WASTE WOODS - WARD NO 301 & 302 [BACKSIDE OF STEPS]	Ganesh. S.	Labours complaint		Sudha.L. - Nursing Office	09/03/2023
Comp. Dt. : 04/03/2023								
Status : Completed								
1910	23030169	SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	NEED TO FIX SCREEN ROD & HOOK	Sarathy. A.	Screen Rod fixed, work completed		Tamilarasi.C. - Nursing Office	09/03/2023
1911	23030172	HOSPITAL IV FLOOR	NEED TO REFIX ALL WINDOW DOOR GLASS	Ekambaram. K.	WINDOW DOOR GLASS REFIXED		Ilambharat.K. - Nursing Office	04/05/2023
1912	23030191	Female Ortho - Ward 401	NEED LABOURS 3 NOS. FOR SHIFTING WASTE PLYWOOD MATERIALS FROM WARD NO.401 TO WORKSHOP	Ganesh. S.	Labours complaint		Chandralekha. S. - Nursing Office	09/03/2023
Comp. Dt. : 07/03/2023								
Status : Completed								
1913	23030269	New OT	NEED REPAIRING WORK FOR DOOR & DOUBLE LOCKER - DAMAGE & BROKEN	Ekambaram. K.	LOCK REPAIRED.		Ilambharat.K. - Nursing Office	14/03/2023
1914	23030276	Paediatrics Ward	TILES BROKEN NEED TOUCHUP WORK AT 309 & 310	Parivallal. P.	TILES REFIXED AND JK WHITE APPLIED.		Tamilarasi.C. - Nursing Office	14/03/2023
Comp. Dt. : 10/03/2023								
Status : Completed								
1915	23030391	Labour Room	NEED PAINTING WORK FOR RESTROOM WALL	Manimaran. A.	WORK COMPLETED		Devika.R - Nursing Office	23/03/2023

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHAL KUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1916	23030392	New OT	NEED PAINTING WORK FOR RESTROOM WALL	Manimaran. A.	PAINTING WORK COMPLETED		Devika.R - Nursing Office	23/03/2023
Comp. Dt. : 01/04/2023 Status : Completed								
1917	23040027	ENT WARD-407	NEED REPAIRING WORK FOR 3 FOLDER COT WHEEL - STUCK & BROKEN	Sarathy. A.	Cot wheel repaired and serviced		Ilambharat.K. - Nursing Office	18/04/2023
Comp. Dt. : 03/04/2023 Status : Completed								
1918	23040048	Paediatrics - Ward 308	NEED REPAIRING WORK FOR FEEDING ROOM - DAMAGE	Ekambaram. K.	Door repaired and refixed, work completed		Powlin.P. - Nursing Office	18/04/2023
1919	23040049	Paediatrics - Ward 308	NEED MOSQUITO NET CUTTING WORK	Ekambaram. K.	Mosquito net frame cutting and clamp fixed, work completed		Powlin.P. - Nursing Office	18/04/2023
1920	23040055	NICU	NEED REPAIRING WORK FOR MAIN DOOR - DOOR STOPPER & SOUND PROBLEM [NEW NICU - 209]	Ekambaram. K.	DOOR FIXED		Powlin.P. - Nursing Office	05/05/2023
Comp. Dt. : 06/04/2023 Status : Completed								
1921	23040189	ICU	NEED REPAIRING WORK FOR MAIN DOOR - STUCK	Ekambaram. K.	Main door repaired and serviced, problem solved		Kalaiaarasi. D. - Nursing Office	20/04/2023
Comp. Dt. : 19/04/2023 Status : Completed								
1922	23040581	Main OT	NEED REPAIRING WORK FOR COT - BROKEN	Ekambaram. K.	COT REPAIRED		Devika.R - Nursing Office	02/05/2023
Comp. Dt. : 29/04/2023 Status : Completed								
1923	23040990	New OT	NEED REPAIRING WORK FOR MAIN ENTRANCE DOOR - SOUND AND NOT CLOSING PROPER	Ekambaram. K.	Door repaired and serviced, problem solved		Devika.R - Nursing Office	08/05/2023
1924	23041005	Female Ortho - Ward 401	NEED TO BE CHANGE WOODEN DOOR INSTEAD OF GLASS DOOR AT WARD NO 401 END CARITOR	Ekambaram. K.	Wrong complaint		Tamilarasi.C. - Nursing Office	08/05/2023
1925	23041007	Paediatrics Ward	NEED TO REFIX WINDOW GLASS DOORS FOR WARD NO 307 & 308	Ekambaram. K.	Window glass door refixed		Powlin.P. - Nursing Office	08/05/2023
Comp. Dt. : 06/05/2023 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1926	23050223	SPECIALITY OT	NEED PAINTING WORK FOR RESTROOM - FUNGUS FORM	Manimaran. A.	WALL CLEANED AND PAINTED		Devika.R - Nursing Office	17/05/2023
1927	23050225	SPECIALITY OT	DOOR STOPPER NOT WORKING	Ekambaram. K.	WORK COMPLETED		Devika.R - Nursing Office	17/05/2023
Comp. Dt. : 08/05/2023 Status : Completed								
1928	23050326	Paediatrics - Ward 309	NEED CARPENTER FOR REMOVEING BOARD FROM WARD NO 309 & TO REFIT WARD NO 308	Ekambaram. K.	WORK COMPLETED		Powlin.P. - Nursing Office	18/05/2023
Comp. Dt. : 09/05/2023 Status : Completed								
1929	23050373	Female Medical - Ward 307	NEED REPAIRING WORK FOR PATIENT EXAM COUCH	Ekambaram. K.	COUCH REPAIRED		Powlin.P. - Nursing Office	18/05/2023
Comp. Dt. : 17/05/2023 Status : Completed								
1930	23050697	NICU	NEED TO CHANGE MAIN DOOR HANDLE	Ekambaram. K.	HANDLE FIXED.		Powlin.P. - Nursing Office	01/06/2023
Comp. Dt. : 18/05/2023 Status : Completed								
1931	23050739	NICU	NEED REPAIRING & PAINTING WORK FOR CUPBOARD	Manimaran. A.	cupboard door fixed.		Powlin.P. - Nursing Office	01/06/2023
Comp. Dt. : 08/06/2023 Status : Completed								
1932	23060274	Male Psychiatry - Ward 405	NEED PAINTING WORK FOR IV STAND 2 NOS	Manimaran. A.	Work completed		Ilambharat.K. - Nursing Office	20/06/2023
1933	23060275	ENT WARD-407	NEED PAINTING WORK FOR IV STAND 2 NOS	Manimaran. A.	Work completed		Ilambharat.K. - Nursing Office	20/06/2023
Comp. Dt. : 12/06/2023 Status : Completed								
1934	23060420	ICU	NEED REPAIRING WORK FOR COT - - COT & SIDE RAILS BROKEN	Sarathy. A.	Cot wheel and side rail fixed		Kalaarasi. D. - Nursing Office	20/06/2023
Comp. Dt. : 13/06/2023 Status : Completed								
1935	23060440	Special Ward - C	CRUSH CART - STUCK	Ekambaram. K.	Cart repaired		amilarasi.C. - Nursing Office	20/06/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1936	23060441	ORTHO OT	NEED REPAIRING WORK FOR COT - DAMAGE - BEND	Ekambaram. K.,Sundaramoorthy. G.,Sarathy. A.	Cot wheel repaired		Devika.R - Nursing Office	20/06/2023
Comp. Dt. : 15/06/2023 Status : Completed								
1937	23060530	SPECIALITY OT	(1124) HANGER STAND FIXING WORK	Ekambaram. K.	Wrong complaint		Devika.R - Nursing Office	27/06/2023
Comp. Dt. : 21/06/2023 Status : Completed								
1938	23060748	ORTHO OT	NEED REPAIRING WORK FOR MAIN DOOR - [UNFIX & SOUND PROBLEM]	Ekambaram. K.	Door repaired.		Devika.R - Nursing Office	27/06/2023
Comp. Dt. : 24/06/2023 Status : Completed								
1939	23060897	ORTHO OT	NEED REPAIRING WORK FOR MAIN DOOR - SOUND & STUCK	Ekambaram. K.	Door repaired.		Devika.R - Nursing Office	07/07/2023
Dept Name : Nutrition & Dietetics - Work Shop Comp. Dt. : 10/05/2022 Status : Completed								
1940	22050314	DIET DEPARMENT	NEED WELDING WORK FOR GRINDER	Sarathy. A.,Sundaramoorthy. G.,Manivannan. A.	New grinder bed make and fixed, work completed		Shanmugapriya. J. - Nutrition & Dietetics	18/05/2022
Comp. Dt. : 03/06/2022 Status : Completed								
1941	22060106	DIET DEPARMENT	NEED TO REFIX PATLOCK FOR KITCHEN	Pachaimuthusamy. D.	Pad lock fixed.		Shanmugapriya. J. - Nutrition & Dietetics	10/06/2022
Comp. Dt. : 15/06/2022 Status : Completed								
1942	22060545	DIET DEPARMENT	NEED WHITE WASH WORK FOR KITCHEN	Manimaran. A.	Painting work completed		Shanmugapriya. J. - Nutrition & Dietetics	20/07/2022
1943	22060546	DIET DEPARMENT	NEED WELDING WORK FOR FOOD TROLLEY WHEEL & REFIX PLYWOOD SHEET FOR TABLE [2NOS]	Sarathy. A.	Trolley wheel changed, Table top plywood sheet 2Nos changed, work completed		Shanmugapriya. J. - Nutrition & Dietetics	01/07/2022
Comp. Dt. : 13/07/2022 Status : Completed								
1944	22070505	DIET DEPARMENT	NEED TO CHANGE TROLLEY WHEEL [2NOS] & PADLOCK FOR 2 NOS	Sarathy. A.	4M new wheel changed, work completed		Shanmugapriya. J. - Nutrition & Dietetics	01/08/2022
1945	22070506	DIET DEPARMENT	NEED MATION WORK FOR WASHING AREA	Murugavel	Washing area floor batching work completed		Shanmugapriya. J. - Nutrition & Dietetics	01/08/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 06/08/2022 Status : Completed								
1946	22080236	DIET DEPARMENT	NEED TO FIX A STAND FOR WHEAT FLOUR MACHINE	Parthiban.K.	New stand made and issued.		Shanmugapriya. J. - Nutrition & Dietetics	24/09/2022
Comp. Dt. : 22/08/2022 Status : Completed								
1947	22080719	DIET DEPARMENT	NEED TO CHANGE BUSH FOR CHAIRS 4NOS & STOOL 2 NOS	Sarathy. A.	New bush fixed, problem solved		Shanmugapriya. J. - Nutrition & Dietetics	01/09/2022
Comp. Dt. : 19/09/2022 Status : Completed								
1948	22090701*	DIET DEPARMENT	NEED REPAIRING & SERVICE FOR TROLLEY & TROLLEY NO 1 [DAMAGE WHEEL BALLS]	Sarathy. A.	Trolley repaired and serviced, problem solved		Shanmugapriya. J. - Nutrition & Dietetics	29/09/2022
Comp. Dt. : 28/09/2022 Status : Completed								
1949	22091098	DIET DEPARMENT	NEED TO REFIX FOOD TROLLEY CLOSER STAND - DAMAGE	Sarathy. A.	All trolley serviced, 4Nos of new wheel fixed, problem solved		Shanmugapriya. J. - Nutrition & Dietetics	08/10/2022
Comp. Dt. : 12/10/2022 Status : Completed								
1950	22100316	DIET DEPARMENT	TABLE DRAW NEED TO BE FIXED	Sarathy. A.	New Table side wheel and bush changed, work completed		Shanmugapriya. J. - Nutrition & Dietetics	20/10/2022
Comp. Dt. : 24/11/2022 Status : Completed								
1951	22111056	DIET DEPARMENT	IN 5TH FLOOR TERROUS DOOR-WELDING WORK NEED TO DO	Sarathy. A.	Door welded, padlock fixed, problem solved		Shanmugapriya. J. - Nutrition & Dietetics	01/12/2022
Comp. Dt. : 08/12/2022 Status : Completed								
1952	22120359	DIET DEPARMENT	GRINDER BLADE NEED TO BE REFIX	Ekambaram. K.,Sundaramoorthy. G.,Sarathy. A.	Grinder blade refixed, problem solved		Shanmugapriya. J. - Nutrition & Dietetics	19/12/2022
Comp. Dt. : 09/12/2022 Status : Completed								
1953	22120406	DIET DEPARMENT	NEED REPAIRING WORK FOR KITCHEN DOOR LOCK - LOCK PROBLEM	Ekambaram. K.	Door lock repaired and serviced, problem solved		Shanmugapriya. J. - Nutrition & Dietetics	19/12/2022

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 13/12/2022 Status : Completed								
1954	22120601	DIET DEPARMENT	NEED PAINTING WORK FOR STORE ROOM VEGITABLE RACK	Manimaran. A.	Vegetable rack painting work completed.		Shanmugapriya. J. - Nutrition & Dietetics	23/12/2022
1955	22120602	DIET DEPARMENT	TO AVOID RAT ENTER NEED TO REFIX WIRE MESH FOR KITCHEN INGREDIENTS RACK	Ekambaram. K.	work completed.		Shanmugapriya. J. - Nutrition & Dietetics	23/12/2022
Comp. Dt. : 31/12/2022 Status : Completed								
1956	22121389	DIET DEPARMENT	COCONUT SCRABER MACHINE BOLT NEED TO BE RETIGHT	Ekambaram. K.	Coconut machine bolt fixed, problem solved		Shanmugapriya. J. - Nutrition & Dietetics	05/01/2023
Comp. Dt. : 06/01/2023 Status : Completed								
1957	23010288	DIET DEPARMENT	GRINDER MOTOR STAND WELDING WORK	Sarathy. A.	Stand welded.		Shanmugapriya. J. - Nutrition & Dietetics	11/01/2023
Comp. Dt. : 09/01/2023 Status : Completed								
1958	23010373	DIET DEPARMENT	IN TERROUS-KITCHEN OUTDOOR-MASON WORK	Murugavel	Plastering work completed		Shanmugapriya. J. - Nutrition & Dietetics	23/01/2023
Comp. Dt. : 12/01/2023 Status : Completed								
1959	23010513	DIET DEPARMENT	GAS STOVE WELDING WORK NEED TO DO	Moorthy. L.	Stove welded, problem solved		Shanmugapriya. J. - Nutrition & Dietetics	30/01/2023
Comp. Dt. : 19/01/2023 Status : Completed								
1960	23010649	DIET DEPARMENT	NEED WELDING WORK FOR FOOD TROLLEY WHEELS [BOTH BIG & SMALL 2NOS]	Sarathy. A.	Trolley wheel welding work completed		Shanmugapriya. J. - Nutrition & Dietetics	30/01/2023
Comp. Dt. : 15/02/2023 Status : Completed								
1961	23020591	DIET DEPARMENT	NEED WHITE WASH WORK	Manimaran. A.	WORK COMPLETED		Shanmugapriya. J. - Nutrition & Dietetics	04/05/2023
Comp. Dt. : 16/02/2023 Status : Completed								
1962	23020616	DIET DEPARMENT	(1441) TROLLY WHEEL BROKEN.WELDING WORK	Sarathy. A.	Trolley wheel welding work completed		Shanmugapriya. J. - Nutrition & Dietetics	23/02/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1963	23020650	DIET DEPARMENT	(1441) RAMP RUST PROBLEM.NEED TO PAINTED	Manimaran. A.	RAMP PAINTED		Shanmugapriya. J. - Nutrition & Dietetics	04/05/2023
	Comp. Dt. : 02/03/2023							
	Status : Completed							
1964	23030070	DIET DEPARMENT	NEED TO CLOSE RESTROOM EXHAUST HOLE AT V FLOOR - BAD SMELL AND HOLE OPEN - NEED URGENT SERVICE.	Ekambaram. K.,Sundaramoorthy. G.,Murugavel	Hole packing work completed		Shanmugapriya. J. - Nutrition & Dietetics	09/03/2023
	Comp. Dt. : 15/03/2023							
	Status : Completed							
1965	23030582	DIET DEPARMENT	NEED WELDING WORK FOR STEP STEEL HANDLE	Sarathy. A.	WORK COMPLETED		Shanmugapriya. J. - Nutrition & Dietetics	23/03/2023
	Comp. Dt. : 16/03/2023							
	Status : Completed							
1966	23030628	DIET DEPARMENT	GRINDER PULLEY BROKEN	Ekambaram. K.	PUTTY FIXED		Shanmugapriya. J. - Nutrition & Dietetics	23/03/2023
	Comp. Dt. : 25/03/2023							
	Status : Completed							
1967	23031077	DIET DEPARMENT	NEED WELDING WORK FOR FOOR TROLLEY	Sarathy. A.	TROLLY REPAIRED.		Shanmugapriya. J. - Nutrition & Dietetics	01/04/2023
	Comp. Dt. : 11/04/2023							
	Status : Completed							
1968	23040314	DIET DEPARMENT	NEED REPAIRING WORK FOR FOOD TROLLEY - STUCK	Sarathy. A.	4Nos of trolley repaired, problem solved		Shanmugapriya. J. - Nutrition & Dietetics	20/04/2023
	Comp. Dt. : 24/04/2023							
	Status : Completed							
1969	23040745	DIET DEPARMENT	NEED TO CHANGE GRINDER PAD - BROKEN	Ekambaram. K.	PAD CHANGED.		Shanmugapriya. J. - Nutrition & Dietetics	02/05/2023
	Comp. Dt. : 27/04/2023							
	Status : Completed							
1970	23040925	DIET DEPARMENT	NEED WELDING WORK FOR TROLLEY NO 1 - WHEEL BROKEN	Sarathy. A.	Trolley wheel welding work completed		Shanmugapriya. J. - Nutrition & Dietetics	08/05/2023
	Comp. Dt. : 28/04/2023							
	Status : Completed							
1971	23040983	Hospital	GRANITE DAMAGE & BROKEN NEAR LIFT NO 5 AT V FLOOR	Parivallal. P.	Granite fixed.		Shanmugapriya. J. - Nutrition & Dietetics	05/08/2023

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHAL KUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 03/05/2023 Status : Completed								
1972	23050104	DIET DEPARMENT	NEED TO FIX A NEW STAND FOR FIXING CAP & MASK	Ekambaram. K.,Sundaramoorthy. G.,Pachaimuthusamy . D.	STAND FIXED		Shanmugapriya. J. - Nutrition & Dietetics	17/05/2023
Comp. Dt. : 04/05/2023 Status : Completed								
1973	23050156	DIET DEPARMENT	NEED TO FIT A STAND FOR KITCHEN	Ekambaram. K.,Sundaramoorthy. G.,Pachaimuthusamy . D.	STAND FIXED		Shanmugapriya. J. - Nutrition & Dietetics	17/05/2023
Comp. Dt. : 19/05/2023 Status : Completed								
1974	23050792	DIET DEPARMENT	NEED REPAIRING WORK FOR "S" TYPE CHAIR 3 NOS	Manivannan. A.	WRONG COMPLAINT		Shanmugapriya. J. - Nutrition & Dietetics	01/06/2023
Comp. Dt. : 01/06/2023 Status : Completed								
1975	23060010	DIET DEPARMENT	GRINTER PAD BROKEN - NEED TO CHANGE AT V FLOOR KITCHEN	Ekambaram. K.,Sundaramoorthy. G.,Manivannan. A.	Pad changed.		Shanmugapriya. J. - Nutrition & Dietetics	20/06/2023
Comp. Dt. : 08/06/2023 Status : Completed								
1976	23060255	HOSPITAL III FLOOR	WHILE MOVING TROLLEY, 2 STEPS BROKEN - NEED REPAIRING AND CEMENT WORK FOR STEPS AT III FLOOR O	Sarathy. A.	Work completesd		Shanmugapriya. J. - Nutrition & Dietetics	20/06/2023
Comp. Dt. : 24/06/2023 Status : Completed								
1977	23060910	DIET DEPARMENT	NEED REPAIRING WORK FOR TROLLEY WHEEL - STUCK NOT WORKING	Sarathy. A.	Wheel repaired.		Shanmugapriya. J. - Nutrition & Dietetics	07/07/2023
1978	23060924	DIET DEPARMENT	NEED SERVICE FOR ALL TROLLEYS	Sarathy. A.	Work completed		Shanmugapriya. J. - Nutrition & Dietetics	07/07/2023
Dept Name : OPD - Work Shop Comp. Dt. : 05/05/2022 Status : Completed								
1979	22050158	CTVS-ROOM NO.225 -2ND FLOOR	NEED REPAIRING WORK FOR DOOR - SOUND PROBLEM	Ekambaram. K.	Door repairing work completed		Suvitha. R. - OPD	12/05/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 07/05/2022 Status : Completed								
1980	22050234	Injection Room - OPD	NEED REPAIRING WORK FOR DOOR - SOUND & NOT CLOSING PROPER	Ekambaram. K.	Door service and repaired, problem solved		Jaculine Mary. A. - ENT & Ophthal Ward	12/05/2022
Comp. Dt. : 11/05/2022 Status : Completed								
1981	22050373	Orthopaedics - OPD	NEED TO FIX STOOL BUSH	Sarathy. A.	Bush fixed, work completed		Durgadevi. J - OPD	18/05/2022
Comp. Dt. : 13/05/2022 Status : Completed								
1982	22050475	DENTAL OPD -2ND FLOOR	X-RAY UNIT STAND NEED TO DO PAINTING WORK	Manivannan. A.	Painting work completed		Kanakarani. R. - OPD	18/06/2022
Comp. Dt. : 10/06/2022 Status : Completed								
1983	22060381	Orthopaedics - OPD	WINDOW DOOR CANNOT CLOSE	Pachaimuthusamy. D.	Door repaired.		Durgadevi. J - OPD	21/06/2022
Comp. Dt. : 29/06/2022 Status : Completed								
1984	22061045	Paediatrics - OPD	NEED TO FIX TOWEL STANDS 3NOS NEAR SINK	Ekambaram. K.	Towel stands fixed.		Subashree. R. - OPD	05/07/2022
1985	22061046	DENTAL OPD -2ND FLOOR	NEED PARTITION NEAR WASH BASIN	Parthiban.K.,Ekambaram. K.,Sundaramoorthy. G.	New partition fixed, work completed		Lakshmid devi. A - OPD	16/11/2022
1986	22061072	PSYCHIATRY OPD	NEED TO REFIX DOOR STOPPER FOR ROOM NO 77 & 78 - NOT WORKING	Ekambaram. K.	Door stopper fixed		Bhuvaneswari. G. - P.H.C. - Tiruvonnainallur	05/07/2022
Comp. Dt. : 01/07/2022 Status : Completed								
1987	22070021	Surgery OPD	NEED TO FIX 2 NAILS	Ekambaram. K.	Nail fixed, problem solved		Sarala. P. - OPD	09/07/2022
1988	22070027	OG-OPD	NEED REPAIRING & REFIX PLYWOOD SHEET FOR DAMAGE PLACES LIKE DOORS & CUPBOARD DAOOR ALSO SOUND PROBLE	Pachaimuthusamy. D.,Parthiban.K.,Ekambaram. K.	Plywood sheet refixed, cupboard door and locker repaired and serviced, problem solved		Velangkanni. K. - OPD	20/07/2022
1989	22070032	Nephrology OPD	NEED REPAIRING WORK FOR MAIN DOOR CLOSER - NOT WORKING	Pachaimuthusamy. D.	Main door and door closer repaired and serviced, problem solved		Jenifer. K. - OPD	09/07/2022
Comp. Dt. : 21/07/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1990	22070812	CSSD	GAUZE BIN BROKEN - NEED TO CHANGE	Moorthy. L.	Gauze bin repaired, problem solved		Sarala. P. - OPD	01/08/2022
	Comp. Dt. : 26/07/2022							
	Status : Completed							
1991	22070939	PLASTIC SURGERY OPD-223	NEED REPAIRING WORK FOR DOOR LOCK - NOT WORKING & SOUND PROBLEM OPD NO 214	Ekambaram. K.	Door repaired and serviced, problem solved		Tamilarasi. A. - OPD	05/08/2022
	Comp. Dt. : 01/08/2022							
	Status : Completed							
1992	22080047	DENTAL OPD -2ND FLOOR	NEED TO REFIX PLYWOOD SHEET FOR TABLE	Parthiban.K.	2 nos. new MDF sheet fixed.		Kanakarani. R. - OPD	24/09/2022
	Comp. Dt. : 02/08/2022							
	Status : Completed							
1993	22080094	Orthopaedics - OPD	NEED TO REFIX PHONE STAND - BROKE	Ekambaram. K.	Phone stand refixed, problem solved		Durgadevi. J - OPD	08/08/2022
	Comp. Dt. : 06/08/2022							
	Status : Completed							
1994	22080244	TB & Chest OPD	NEED REPAIRING WORK FOR WHEEL CHAIR WHEEL - BROKEN	Sarathy. A.	Wheel chair wheel refixed in properly, problem solved		Jothi.R. - OPD	17/08/2022
	Comp. Dt. : 10/08/2022							
	Status : Completed							
1995	22080355	Paediatrics - OPD	NEED TO REFIX DOOR STOPPER	Ekambaram. K.	New door stopper changed, problem solved		Subashree. R. - OPD	23/08/2022
1996	22080380	DENTAL OPD -2ND FLOOR	NEED TO REFIX DENTAL CHAIR WITH SCREW - CHAIR UN FIX - UNCOMFORTABLE	Sarathy. A.	Dental chair screw refixed, problem solved		Lakshmi Devi. R. - OPD	23/08/2022
	Comp. Dt. : 12/08/2022							
	Status : Completed							
1997	22080460	DENTAL OPD -2ND FLOOR	NEED TO REFIX DENTAL CHAIR [AGAIN] NEED SUPPORTER ON 13.08.2022 AT 8.45 A.M.	Ekambaram. K.	Dental chair refixed, work completed		Lakshmi Devi. R. - OPD	23/08/2022
	Comp. Dt. : 20/08/2022							
	Status : Completed							
1998	22080659	Nephrology OPD	NEED TO CHANGE BUSH FOR PATIENT STOOL	Sarathy. A.	Patient stool - new bush fixed, problem solved		Jenifer. K. - OPD	26/08/2022
	Comp. Dt. : 22/08/2022							
	Status : Completed							


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1999	22080693	Paediatrics - OPD	NEED TO REFIX PHONE STAND & HAND TOWEL STANDS [RINGS]	Parthiban.K.	Refixed in phone astand and towel rod, work completed		Subashree. R. - OPD	01/09/2022
	Comp. Dt. : 23/08/2022							
	Status : Completed							
2000	22080759	DERMATOLOGY OPD	NEED TO REFIX DOOR STOPPER FOR ROOM NO 73	Ekambaram. K.	New Door stopper fixed, problem solved		Indumathi. T. - OPD	01/09/2022
	Comp. Dt. : 25/08/2022							
	Status : Completed							
2001	22080827	PSYCHIATRY OPD	NEED TO FIX NAILS & DOOR REPAIRING WORK FOR ROOM NO 71	Venkatesan. R.	Nail fixed.		Bhuvaneswari. G. - P.H.C. - Tiruvonnainallur	09/09/2022
	Comp. Dt. : 26/08/2022							
	Status : Completed							
2002	22080917	PSYCHIATRY OPD	NEED WELDING WORK FOR "S" TYPE CHAIR & STAND	Sarathy. A.	Chair welded.		Bhuvaneswari. G. - P.H.C. - Tiruvonnainallur	09/09/2022
	Comp. Dt. : 29/08/2022							
	Status : Completed							
2003	22080969	Orthopaedics - OPD	NEED REPAIRING WORK FOR "S" TYPE CHAIRS 2NOS	Sarathy. A.	Chair repaired.		Durgadevi. J - OPD	09/09/2022
	Comp. Dt. : 01/09/2022							
	Status : Completed							
2004	22090045	OG-OPD	NEED REPAIRING WORK FOR TABLE DRAW - BROKEN	Parthiban.K.	New drawer fixed.		Velangkanni. K. - OPD	08/09/2022
	Comp. Dt. : 13/09/2022							
	Status : Completed							
2005	22090490	OG-OPD	NEED REPAIRING WORK FOR "S" TYPE & ROLLING CHAIR 2NOS	Sarathy. A.	Chair repaired and serviced, problem solved		Velangkanni. K. - OPD	29/09/2022
	Comp. Dt. : 14/09/2022							
	Status : Completed							
2006	22090542	General Medicine - OPD	NEED REPAIRING WORK FOR "S" TYPE CHAIR	Sarathy. A.	Chair repaired and serviced, problem solved		Bharathi.D. - OPD	29/09/2022
	Comp. Dt. : 15/09/2022							
	Status : Completed							
2007	22090595	Nephrology OPD	DOOR CLOSER NOISE PROBLEM	Ekambaram. K.	Door closer adjusted, problem solved		Jenifer. K. - OPD	29/09/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL,
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 17/09/2022 Status : Completed								
2008	22090667	Orthopaedics - OPD	NEED TO REPALCE DRESS HANGER STAND [FIX OTHER PLACE]	Ekambaram. K.	Hanger fixed, problem solved		Durgadevi. J - OPD	29/09/2022
Comp. Dt. : 21/09/2022 Status : Completed								
2009	22090831	OG-OPD	ROLLING CHAIR WHEEL BROKEN - NEED TO REFIX	Sarathy. A.	Wheel chair repaired and serviced, problem solved		Velangkanni. K. - OPD	29/09/2022
Comp. Dt. : 26/09/2022 Status : Completed								
2010	22091001	Paediatrics - OPD	NEED TO REFIX HAND TOWEL STAND	Ekambaram. K.	Wrong complaint		Subashree. R. - OPD	08/10/2022
Comp. Dt. : 27/09/2022 Status : Completed								
2011	22091075	Ophthalmology - OPD	NEED TO CHECK SCREEN SPRING RINGS - NOT FIXED & DAMAGE - NEED TO REFIX	Ekambaram. K.	Screen sping and hook fixed, problem solved		Seetha. R. - OPD	08/10/2022
Comp. Dt. : 29/09/2022 Status : Completed								
2012	22091178	DENTAL OPD -2ND FLOOR	NEED TO BE REPLACED WOODEN RACK [CHANGE TO ANOTHER PLACE]	Ekambaram. K.	Wooden rack replaced and refixed, problem solved		Lakshmi Devi. R. - OPD	08/10/2022
Comp. Dt. : 06/10/2022 Status : Completed								
2013	22100082	PSYCHIATRY OPD	NEED TO REPLACE PHONE STAND [ANOTHER PLACE]	Ekambaram. K.	Phone stand refixed, work completed		Bhuvaneswari. G. - P.H.C. - Tiruvannainallur	12/10/2022
Comp. Dt. : 07/10/2022 Status : Completed								
2014	22100159	ENT OPD	NEED REPAIRING WORK FOR RESTROOM DOOR LOCK - ROOM NO 30	Ekambaram. K.	Rest room door refixed in properly, problem solved		Ezhilarasi. M. - OPD	12/10/2022
Comp. Dt. : 15/10/2022 Status : Completed								
2015	22100485	Paediatrics - OPD	NEED REPAIRING WORK FOR BREAST FEEDING ROOM DOOR - BROKEN	Ekambaram. K.	Door repaired and refixed, problem solved		Subashree. R. - OPD	21/10/2022
Comp. Dt. : 17/10/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2016	22100550	IVF ART CLINIC-INSIDE OF OG OPD(NO.68)	NEED REPAIRING WORK FOR DOCTOR'S ROOM REST ROOM DOOR - DAMAGED BY RAT - NEED TO CLOSE DAMAGED PARTS	Ekambaram. K.,Venkatesan. R.,Sundaramoorthy. G.	3nos. SS mesh fixed.		Rajasekari. R. - OPD	29/10/2022
	Comp. Dt. : 18/10/2022							
	Status : Completed							
2017	22100571	Ophthalmology - OPD	KEY MISSING - NEED TO BROKE TABLE LOCK	Sundaramoorthy. G.	Lock repaired.		Seetha. R. - OPD	29/10/2022
	Comp. Dt. : 22/10/2022							
	Status : Completed							
2018	22100752	TB & Chest OPD	ALL DOOR LOCK PROBLEM AND NEED TO FIX TABLE DRAW LOCK---RMO SIR ROOM	Ekambaram. K.,Sundaramoorthy. G.,Manivannan. A.	New lock fixed, problem solved		Jothi.R. - OPD	16/11/2022
	Comp. Dt. : 26/10/2022							
	Status : Completed							
2019	22100835	Ophthalmology - OPD	X-RAY LOBE WHITE SHEET NEED TO BE CHANGE	Manivannan. A.	Sheet refixed.		Seetha. R. - OPD	03/11/2022
	Comp. Dt. : 29/10/2022							
	Status : Completed							
2020	22100943	Orthopaedics - OPD	NEED TO FIX X-RAY LOBBY HANGER	Ekambaram. K.,Sundaramoorthy. G.,Manivannan. A.	Hanger fixed, problem solved		Durgadevi. J - OPD	08/11/2022
	Comp. Dt. : 03/11/2022							
	Status : Completed							
2021	22110055	Ophthalmology - OPD	GOSS BIN WELDING WORK	Sarathy. A.	Gauze bin welded, work completed		Seetha. R. - OPD	16/11/2022
2022	22110095	Orthopaedics - OPD	TABLE LOCKER LOCK PROBLEM	Ekambaram. K.	Lock repaired and serviced, problem solved		Durgadevi. J - OPD	06/12/2022
	Comp. Dt. : 07/11/2022							
	Status : Completed							
2023	22110237	DENTAL OPD	VIP CLINIC -TOWEL STAND NEED TO BE FIX	Ekambaram. K.	Towel rod fixed, problem solved		Kanakarani. R. - OPD	18/11/2022
	Comp. Dt. : 09/11/2022							
	Status : Completed							
2024	22110374	Paediatrics - OPD	INN REST ROOM-WINDOW NEED TO BE COVER WITH PLYWOOD	Ekambaram. K.	Plywood fixed, work completed		Subashree. R. - OPD	18/11/2022
	Comp. Dt. : 11/11/2022							


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
2025	22110466	DENTAL OPD -2ND FLOOR	AUTOMATIC DOOR CLOSER PROBLEM	Ekambaram. K.	New door closer and lock changed, problem solved		Kanakarani. R. - OPD	06/12/2022
Comp. Dt. : 14/11/2022								
Status : Completed								
2026	22110517	TB & Chest OPD	WHEEL CHAIR WHEEL BROKEN,NEED TO BE REFIX	Sarathy. A.	Wheel chair repaired.		Durgadevi. J - OPD	21/11/2022
Comp. Dt. : 15/11/2022								
Status : Completed								
2027	22110619	ENT OPD	ROOM NO.25-DOOR CLOSER PROBLEM	Ekambaram. K.	New door closer fixed.		Ezhilarasi. M. - OPD	21/11/2022
Comp. Dt. : 19/11/2022								
Status : Completed								
2028	22110834	CARDIOLOGY OPD	DOOR LOCK PROBLEM	Ekambaram. K.	Door lock opened, problem solved		Radhika. R. - OPD	01/12/2022
Comp. Dt. : 21/11/2022								
Status : Completed								
2029	22110869	DENTAL OPD -2ND FLOOR	VIP CLINIC DOOR NOT CLOSING PROPERLY	Ekambaram. K.	Door repaired and serviced, problem solved		Lakshmi Devi. R. - OPD	01/12/2022
Comp. Dt. : 23/11/2022								
Status : Completed								
2030	22110984	Ophthalmology - OPD	NOTICE BOARD NEED TO BE REFIX	Ekambaram. K.	Notice board refixed, problem solved		Seetha. R. - OPD	01/12/2022
Comp. Dt. : 29/11/2022								
Status : Completed								
2031	22111230	DENTAL OPD -2ND FLOOR	NEED TO REFIX NAILS 5NOS	Ekambaram. K.	Nail fixed, problem solved		Kanakarani. R. - OPD	06/12/2022
Comp. Dt. : 01/12/2022								
Status : Completed								
2032	22120034	Ophthalmology - OPD	NEED TO FIX NOTICE BOARD & NEED REPAIRING WORK FOR X RAY LOBBY	Ekambaram. K.	Board fixed.		Seetha. R. - OPD	10/12/2022
2033	22120035	OG-OPD	NEED TO REFIX NAILS & TOWEL WING	Ekambaram. K.	Nail fixed.		Velangkanni. K. - OPD	10/12/2022
Comp. Dt. : 07/12/2022								
Status : Completed								
2034	22120285	PSYCHIATRY OPD	CABIN ROOM DOOR LOCK DAMAGED,NEW LOCK NEED TO BE FIX	Ekambaram. K.	New lock changed, work completed		Bhuvaneswari. G. - P.H.C. - Tiruvonnainallur	19/12/2022

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2035	22120287	PSYCHIATRY OPD	TELEPHONE STAND NEED TO REPLACE AND REFIX INTO ANOTHER PLACE	Ekambaram. K.	Telephone stand refixed		Bhuvaneswari. G. - P.H.C. - Tiruvonnainallur	19/12/2022
Comp. Dt. :		10/12/2022						
Status :		Completed						
2036	22120467	UROLOGY--OPD	NEED TO CHECK TILES - AIR CRACK AND DAMAGED -	Murugavel	Tiles refixed, JK White cement pointing work completed		Lavanya. M. - OPD	19/12/2022
Comp. Dt. :		12/12/2022						
Status :		Completed						
2037	22120528	PSYCHIATRY OPD	BANNER FIXING WORK NEED TO DO IN AUDITORIUM	Manivannan. A.	Baner fixed, work completed		Bhuvaneswari. G. - P.H.C. - Tiruvonnainallur	19/12/2022
2038	22120558	DENTAL VIP CLINIC-SPECIAL OPD-2ND FLOOR	MIRROR NEED TO BE FIX ABOVE WASH BASIN SINK	Ekambaram. K.	Mirror fixed, work completed		Priyadharshini. S. - OPD	19/12/2022
2039	22120559	DENTAL VIP CLINIC-SPECIAL OPD-2ND FLOOR	MAIN DOOR NOT CLOSING PROPERLY,NEED TO BE REPAIR	Ekambaram. K.	New door closer fixed, problem solved		Priyadharshini. S. - OPD	19/12/2022
Comp. Dt. :		13/12/2022						
Status :		Completed						
2040	22120612	Surgery OPD	NEED TO REFIX WHITE BOARD	Manivannan. A.	Board fixed		Indhira. M. - OPD	23/12/2022
2041	22120613	CTVS-ROOM NO.225 -2ND FLOOR	PROBLEM IN CHETAL FORCIP	Ekambaram. K.	forceps welded.		Suvitha. R. - OPD	23/12/2022
Comp. Dt. :		16/12/2022						
Status :		Completed						
2042	22120789	Orthopaedics - OPD	NEED TO REFIX BUSH FOR TABLE & PATIENT STOOL 10 NOS	Sarathy. A.	Bush fixed.		Durgadevi. J - OPD	23/12/2022
2043	22120790	Orthopaedics - OPD	NEED TO REFIX TOWEL RING FOR ROOM NO 65	Ekambaram. K.	Wrong complaint.		Durgadevi. J - OPD	23/12/2022
Comp. Dt. :		20/12/2022						
Status :		Completed						
2044	22120881	UROLOGY--OPD	NEED PAINTING WORK FOR ROOM & REST ROOM	Manimaran. A.	Wall cleaned and painting work completed		Lavanya. M. - OPD	30/12/2022
Comp. Dt. :		21/12/2022						
Status :		Completed						
2045	22120947	Paediatric Surgery - OPD	BEROW REPAIR PROBLEM	Ekambaram. K.,Sundaramoorthy. G.,Pachaimuthusamy . D.	Bero repaired and serviced, problem solved		Subashree. R. - OPD	29/12/2022
2046	22120963	NEUROLOGY OPD-2ND FLOOR	WALL PAINTING WORK	Manimaran. A.	Wall cleaned and painting work completed		Radhika. R. - OPD	29/12/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 22/12/2022 Status : Completed								
2047	22121037	SKILL LAB - MEDICAL COLLEGE	NEED TO FIX BANNAR	Manivannan. A.	Banner fixed, work completed		Subashree. R. - OPD	29/12/2022
Comp. Dt. : 23/12/2022 Status : Completed								
2048	22121097	NEUROLOGY OPD-2ND FLOOR	CEILING REWORK	Murugavel	False Ceiling refixed, work completed		Radhika. R. - OPD	02/01/2023
Comp. Dt. : 24/12/2022 Status : Completed								
2049	22121112	Orthopaedics - OPD	ORTHO DEMO ROOM DOOR REPAIR WORK	Ekambaram. K.	Door repaired and serviced, problem solved		Durgadevi. J - OPD	02/01/2023
Comp. Dt. : 28/12/2022 Status : Completed								
2050	22121293	GENERAL SURGERY OPD-55	PATIENT SCREENING FOLDING SCREEN NEED TO BE REFIX	Ekambaram. K.	Screen rod 10' length fixed, problem solved		Indhira. M. - OPD	05/01/2023
Comp. Dt. : 02/01/2023 Status : Completed								
2051	23010036	UROLOGY--OPD	MAIN DOOR NOISE PROBLEM	Ekambaram. K.	Door repaired and serviced, problem solved		Lavanya. M. - OPD	12/01/2023
Comp. Dt. : 06/01/2023 Status : Completed								
2052	23010269	IVF ART CLINIC-INSIDE OF OG OPD(NO.68)	CUPBOARD DOOR PROBLEM(3060)	Ekambaram. K.	Cupboard door repaired.		Rajasekari. R. - OPD	11/01/2023
Comp. Dt. : 07/01/2023 Status : Completed								
2053	23010303	Ophthalmology - OPD	S-TYPER CHAIR 6 NO'S GOT DAMAGED-NEED TO BE REPAIR	Venkatesan. R.	Work completed.		Seetha. R. - OPD	11/01/2023
Comp. Dt. : 10/01/2023 Status : Completed								
2054	23010419	DENTAL OPD -2ND FLOOR	CUPBOARD DOOR NOT WORKING	Ekambaram. K.	12" Telescopic wheel 1set changed		Lakshmi Devi. R. - OPD	23/01/2023
Comp. Dt. : 25/01/2023 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2055	23010926	DERMATOLOGY OPD	NEED TO CHECK GLASS DOOR AT DERMO & ECHO ENTRANCE DOOR - BROKEN - NEED URGENT SERVICE	Ekambaram. K., Sundaramoorthy. G., Pachaimuthusamy . D.	Door alteration work and novapan shelf fixed, work completed		Indumathi. T. - OPD	30/01/2023
Comp. Dt. : 30/01/2023 Status : Completed								
2056	23011067	Orthopaedics - OPD	NEED PAINTING & PLYWOOD SHEET CHANGING WORK FOR TABLE	Manimaran. A., Viswa. V., Ekambaram. K.	New plywood sheet changed, painting work completed		Durgadevi. J - OPD	11/02/2023
Comp. Dt. : 04/02/2023 Status : Completed								
2057	23020120	Orthopaedics - OPD	NEED TO REFIX BUSH FOR PATIENT STOOL & FOOT STOOL	Sarathy. A.	Patient stool and foot stool - new bush fixed		Durgadevi. J - OPD	11/02/2023
Comp. Dt. : 07/02/2023 Status : Completed								
2058	23020232	Ophthalmology - OPD	NEED TO REFIX BUSH FOR PATIENT STOOL - 10 NOS	Sarathy. A.	10Nos of patient stool bush fixed, work completed		Seetha. R. - OPD	16/02/2023
Comp. Dt. : 08/02/2023 Status : Completed								
2059	23020262	Orthopaedics - OPD	NEED MASION FOR HOLES PACKING WORK IN ORTHO OPD DEMO ROOM	Murugavel	Holes packing work completed		Durgadevi. J - OPD	16/02/2023
2060	23020308	Surgery OPD	TILES PACKING WORK IN DOCTORS RESTROOM - ROOM NO. 59	Murugavel	Tiles refixed, JK white cement pointing work completed		Indhira. M. - OPD	16/02/2023
Comp. Dt. : 09/02/2023 Status : Completed								
2061	23020338	OG-OPD	BERO CUPBOARD PROBLEM	Ekambaram. K.	Cup board refixed in properly		Velangkanni. K. - OPD	16/02/2023
Comp. Dt. : 10/02/2023 Status : Completed								
2062	23020389	TB & Chest OPD	BERO LOCK PROBLEM	Ekambaram. K.	Bero lock refixed in properly		Jothi.R. - OPD	16/02/2023
2063	23020398	TB & Chest OPD	BERO PAINTING WORK	Manimaran. A.	Bero painting work completed		Jothi.R. - OPD	08/03/2023
2064	23020399	Orthopaedics - OPD	NEED 10 NEW MEDICINE BOX	Ekambaram. K.	NEW MEDICINE BOX ISSUED.		Durgadevi. J - OPD	04/05/2023
Comp. Dt. : 13/02/2023 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2065	23020457	POW & SICU	NEED TO CHECK COT WHEEL - STUCK	Sarathy. A.	4Nos of cot wheel repaired and refixed in properly		Velangkanni. K. - OPD	17/02/2023
2066	23020487	Paediatrics - OPD	NEED TO REFIX BOARD	Ekambaram. K.	Board fixed		Subashree. R. - OPD	17/02/2023
Comp. Dt. : 17/02/2023 Status : Completed								
2067	23020680	Orthopaedics - OPD	NEED PAINTING WORK FOR PATIENT COUCH 1NO & FOOT STOOL 3 NOS	Manimaran. A.	Couch and stool painting work completed		Durgadevi. J - OPD	23/02/2023
Comp. Dt. : 18/02/2023 Status : Completed								
2068	23020729	OG-OPD	NEED REPAIRING WORK FOR PATIENT STOOL	Sarathy. A.	wrong complant, Stool painting work completed		Velangkanni. K. - OPD	23/02/2023
Comp. Dt. : 22/02/2023 Status : Completed								
2069	23020841	Orthopaedics - OPD	(1063) 7NOS FOOT STOOL ,1 PATIENT STOOL,ONE SIDE LOCKER TABLE,1,WHEEL CHAIR ,1 TROLLY AND 3NOS COUCH	Manimaran. A.	All things are painted, work completed		Durgadevi. J - OPD	01/03/2023
2070	23020843	Orthopaedics - OPD	3 NOS BLACK COLOUR CHAIN CHAIR PAINTING WORK AND ALSO WELDING WORK	Manimaran. A.,Viswa. V.,Sarathy. A.	Welding work and painting work completed		Durgadevi. J - OPD	01/03/2023
2071	23020849	GENERAL SURGERY OPD-55	ONE PATIENT STRUCTURE PAINTING WORK	Manimaran. A.	Stretcher painting work completed		Indhira. M. - OPD	01/03/2023
Comp. Dt. : 27/02/2023 Status : Completed								
2072	23021035	CTVS-ROOM NO.225 -2ND FLOOR	KEY MISSING - LOCKER NOT ABLE TO OPEN	Ekambaram. K.	KEY OPENED		Suvitha. R. - OPD	07/03/2023
Comp. Dt. : 28/02/2023 Status : Completed								
2073	23021046	TB & Chest OPD	ONE BERO PAINTING WORK	Manimaran. A.	BERO PAINTED		Jothi.R. - OPD	07/03/2023
Comp. Dt. : 02/03/2023 Status : Completed								
2074	23030077	OG-OPD	NEED TO REFIX MIRROR FOR HOD MADAM REST ROOM	Ekambaram. K.	Mirror fixed		Velangkanni. K. - OPD	09/03/2023
Comp. Dt. : 03/03/2023 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2075	23030138	TB & Chest OPD	NEED REPAIRING WORK FOR REVOLVING CHAIR	Ekambaram. K.	Chair repaired, problem solved		Jothi.R. - OPD	09/03/2023
		Comp. Dt. : 16/03/2023 Status : Completed						
2076	23030629	ENT OPD	NEED REPAIRING WORK FOR DOOR STUCK - [ROOM NO 30 - HOD ROOM]	Ekambaram. K.	DOOR REPAIRED		Ezhilarasi. M. - OPD	23/03/2023
2077	23030630	IVF ART CLINIC-INSIDE OF OG OPD(NO.68)	NEED RED LINE PAINT WORK FOR RECOVERY ROOM & OT	Manimaran. A.	REDLINE PAINTED.		Rajasekari. R. - OPD	04/05/2023
2078	23030631	IVF ART CLINIC-INSIDE OF OG OPD(NO.68)	NEED WHITE PAINT WORK FOR PATINET WAITING HALL [PATIENT SITTING CHAIR BACK SIDE WALL]	Manimaran. A.	PAINTING WORK COMPLETTED.		Rajasekari. R. - OPD	23/03/2023
		Comp. Dt. : 18/03/2023 Status : Completed						
2079	23030747	CARDIOLOGY OPD	NEED PAINTING WORK FOR WHEEL CHAIR	Manimaran. A.	Painting work completed		Radhika. R. - OPD	31/03/2023
		Comp. Dt. : 20/03/2023 Status : Completed						
2080	23030776	PSYCHIATRY OPD	NEED TO REFIX PATIENT SITTING CHAIR SCREW	Ekambaram. K.	Chair Screw refixed		Indumathi. T. - OPD	31/03/2023
2081	23030803	GASTROENTROLOGY OPD-2ND FLOOR	NEED TO FIX NEW LOCK FOR DOOR	Ekambaram. K.	New lock fixed		Suvitha. R. - OPD	31/03/2023
2082	23030818	Orthopaedics - OPD	NEED REPAIRING WORK FOR "S" TYPE CHAIR HANDLE	Ekambaram. K.	Handle refixed		Durgadevi. J - OPD	31/03/2023
		Comp. Dt. : 22/03/2023 Status : Completed						
2083	23030895	Ophthalmology - OPD	NEED TO REFIX DOOR STOPER [DAMAGE] FOR ROOM NO 80,81 & 82	Sundaramoorthy. G.	DOOR STOPPER FIXED.		Seetha. R. - OPD	01/04/2023
		Comp. Dt. : 25/03/2023 Status : Completed						
2084	23031082	SPECIALITY OPD	NEED TO REFIX SCREEN SPRING [30 NOS] FOR SPECIALITY & GROUND FLOOR ALL OPD,S	Ekambaram. K.	SPRING FIXED.		Suvitha. R. - OPD	01/04/2023
2085	23031083	SPECIALITY OPD	NEED TO CHECK FOLDER SCREEN WHEEL FOR ALL OPD [SPECIALITY & GROUND FLOOR ALL OPD]	Ekambaram. K.,Sundaramoorthy. G.,Sarathy. A.	SPRING FIXED.		Suvitha. R. - OPD	01/04/2023
		Comp. Dt. : 27/03/2023						


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
2086	23031138	OG-OPD	TILES BROKEN - NEED TOUCHUP WORK AT DEMO ROOM	Parivallal. P.	WORK COMPLETED		Velangkanni. K. - OPD	01/04/2023
Comp. Dt. : 28/03/2023								
Status : Completed								
2087	23031166	Ophthalmology - OPD	NEED TO FIT X RAY LOBBY	Ekambaram. K.	X-Ray lobby fixed, work completed		Seetha. R. - OPD	13/04/2023
2088	23031199	Ophthalmology - OPD	NEED REPAIRING WORK FOR "S" TYPE CHAIR HANDLE - BROKEN	Ekambaram. K.	Chair handle refixed, problem solved		Seetha. R. - OPD	13/04/2023
Comp. Dt. : 29/03/2023								
Status : Completed								
2089	23031256	Injection Room - OPD	NEED REPAIRING WORK FOR DOOR - STUCK - ROOM NO 53	Ekambaram. K.	Door repaired and serviced, problem solved		Badmasri. P. - OPD	13/04/2023
2090	23031257	COMMON FEMALE RESTROOM NEAR ORTHO OPD	NEED REPAIRING WORK FOR ALL RESTROOM DOOR LOCKER - LOCK NOT WORKING	Ekambaram. K.	Door lock repaired and serviced, problem solved		Badmasri. P. - OPD	13/04/2023
2091	23031267	Ophthalmology - OPD	NEED URGENT SERVICE - TRIALSET BOX STUCK	Ekambaram. K., Sarathy. A., Manivannan. A.	Box repaired and serviced, problem solved		Seetha. R. - OPD	13/04/2023
Comp. Dt. : 03/04/2023								
Status : Completed								
2092	23040069	General Medicine - OPD	NEED REPAIRING WORK FOR SCREEN WHEEL - STUCK	Sarathy. A.	Screen wheel replaced, problem solved		Bharathi.D. - OPD	18/04/2023
Comp. Dt. : 04/04/2023								
Status : Completed								
2093	23040103	Surgery OPD	NEED TO FIX " BORAD"	Ekambaram. K.	Board fixed, work completed		Indhira. M. - OPD	18/04/2023
Comp. Dt. : 08/04/2023								
Status : Completed								
2094	23040223	General Medicine - OPD	NEED TO CHANGE BUSH FOR TABLE	Sarathy. A.	Table bush fixed		Bharathi.D. - OPD	20/04/2023
Comp. Dt. : 16/04/2023								
Status : Completed								
2095	23040473	ANAESTHESIA OPD NEAR SUGERY OPD	NEED TO REFIX " BOARD" - OPD NO 54	Ekambaram. K.	BOARD FIXED		Badmasri. P. - OPD	02/05/2023
2096	23040481	TB & Chest OPD	NEED REPAIRING WORK FOR ROLLING CHAIR - UNFIX AT HOD ROOM	Sarathy. A.	CHAIR WHEEL REPLACED		Seetha. R. - OPD	02/05/2023

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 22/04/2023 Status : Completed								
2097	23040707	Ophthalmology - OPD	NEED REPAIRING WORK FOR WHEEL CHAIR WHEEL - STUCK	Sarathy. A.	WHEEL REPLACED.		Seetha. R. - OPD	02/05/2023
Comp. Dt. : 03/05/2023 Status : Completed								
2098	23050108	Orthopaedics - OPD	NEED REPAIRING WORK FOR X RAY LOBBY	Ekambaram. K.	XRAY LOBBY FIXED		Durgadevi. J - OPD	17/05/2023
Comp. Dt. : 04/05/2023 Status : Completed								
2099	23050170	Surgery OPD	NEED REPAIRING WORK FOR BERO HANDLE - BROKEN	Ekambaram. K.	HANDLE FIXED		Indhira. M. - OPD	17/05/2023
Comp. Dt. : 20/05/2023 Status : Completed								
2100	23050825	DENTAL OPD -2ND FLOOR	NEED TO FIX NAIL	Ekambaram. K.	NAIL FIXED.		Lakshmi Devi. R. - OPD	01/06/2023
Comp. Dt. : 23/05/2023 Status : Completed								
2101	23050929	PSYCHIATRY OPD	NEED REPAIRING WORK FOR CALLING BELL - SCREW & SPARE DAMAGE NEED TO CHANGE	Ekambaram. K.	WRONG COMPLAINT		Indumathi. T. - OPD	03/06/2023
Comp. Dt. : 30/05/2023 Status : Completed								
2102	23051195	CARDIOLOGY OPD	NEED TO REFIX SCREW FOR FOOT STOOL	Ekambaram. K.	Screw fixed		Radhika. R. - OPD	20/06/2023
Comp. Dt. : 01/06/2023 Status : Completed								
2103	23060040	DENTAL OPD -2ND FLOOR	NEED PAINTING WORK FOR DENTAL SPECIAL CLINIC & OPD	Manimaran. A.	Work completed		Sarala. V. - OPD	05/08/2023
Comp. Dt. : 06/06/2023 Status : Completed								
2104	23060170	UROLOGY--OPD	NEED REPAIRING WORK FOR DOOR - NOT CLOSING PROPER	Ekambaram. K.	Door serviced		Lavanya. M. - OPD	20/06/2023
Comp. Dt. : 12/06/2023 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2105	23060414	DERMATOLOGY OPD	NEED REPAIRING WORK FOR DOOR STOPPER [ROOM NO 73] & FIXING TOWEL STAND FOR [ROOM NO 72]	Ekambaram. K.	2 nos door stopper fixed		Jothiammal. S. - OPD	20/06/2023
Comp. Dt. : 14/06/2023 Status : Completed								
2106	23060504	PRE ANATHESIA	NEED TO REFIX HEIGHT SCALE - OPD NO 54	Ekambaram. K.	Heigh scale fixed.		Badmasri. P. - OPD	27/06/2023
Comp. Dt. : 15/06/2023 Status : Completed								
2107	23060567	DENTAL OPD -2ND FLOOR	(1210) HOD SIR ROOM DOOR STOPPER NOT WORKING PROPERLY	Ekambaram. K.	Door stopper 3nos fixed.		Sarala. V. - OPD	27/06/2023
Comp. Dt. : 19/06/2023 Status : Completed								
2108	23060678	Paediatrics - OPD	NEED TO BROKE CUPBOARD LOCK	Ekambaram. K.	Lock opened		Subashree. R. - OPD	27/06/2023
2109	23060679	Paediatrics - OPD	NEED NEW PHONE STAND	Ekambaram. K.	New stand fixed.		Subashree. R. - OPD	27/06/2023
Comp. Dt. : 26/06/2023 Status : Completed								
2110	23060990	NEUROLOGY OPD-2ND FLOOR	NEED CEMENT WORK FOR CEILING - WATER LEAKAGE - NEED URGENT SERVICE	Parivallal. P.	Civil execution complaint.		Radhika. R. - OPD	07/07/2023
Dept Name : Operation Theatre - Work Shop Comp. Dt. : 09/05/2022 Status : Completed								
2111	22050267	OG OT	NEED TO REFIX DOOR STOPPER	Pachaimuthusamy. D.	New door stopper fixed, problem solved		Sathia. R. - Operation Theatre	18/05/2022
Comp. Dt. : 11/05/2022 Status : Completed								
2112	22050372	OG OT	NEED TO CHANGE WHEEL CHAIR WHEEL AND HANDLE	Sarathy. A.	Wheel chair wheel and handle refixed, problem solved		Sathia. R. - Operation Theatre	18/05/2022
Comp. Dt. : 12/05/2022 Status : Completed								
2113	22050427	New OT	WALL FORMED WITH FUNGUS -REQUEST TO DO WALL PAINTING	Manimaran. A.	Fungus cleaned and painted.		ayapratha. S. - Operation Theatre	18/06/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 18/05/2022								
Status : Completed								
2114	22050667	OG OT	NEED TO REFIX MONITOR STAND	Ekambaram. K.	Monitor stand refixed, problem solved		Sathia. R. - Operation Theatre	28/05/2022
Comp. Dt. : 20/05/2022								
Status : Completed								
2115	22050745	New OT	NEED PENDING PAINT WORK & REFIX NOTICE BOARD & MALE DOCTOR'S ROOM HANGER	Manivannan. A., Manimaran. A., Ekambaram. K.	Fugus cleaned and painting work completed, Notice board and hanger refixed in properly, problem solv		Jayapratha. S. - Operation Theatre	28/05/2022
2116	22050773	New OT	NEED REPAIRING WORK FOR NOR COATING CUPBOARD LOCK - DAMAGE & NOT WORKING	Ekambaram. K.	New MP lock fixed.		Kousalya. S. - Operation Theatre	18/06/2022
Comp. Dt. : 25/05/2022								
Status : Completed								
2117	22050938	ORTHO OT	NEED REPAIRING WORK FOR STORE ROOM DOOR - DAMAGE & BROKENED	Ekambaram. K.	Welding work completed		Mahalakshmi. G. - Operation Theatre	10/06/2022
2118	22050955	ORTHO OT	NEED CEMENT PATCHING WORK FOR STORE ROOM CEILING - CEILING DAMAGE	Murugavel	Welding work completed		Mahalakshmi. G. - Operation Theatre	10/06/2022
Comp. Dt. : 01/06/2022								
Status : Completed								
2119	22060017	Main OT	NEED TO CLOSE FALSE CEILING - NEED URGENT SERVICE	Murugavel	False ceiling closed.		Mahalakshmi. G. - Operation Theatre	10/06/2022
Comp. Dt. : 02/06/2022								
Status : Completed								
2120	22060051	ORTHO OT	NEED REPAIRING WORK FOR DRAW - BROKENED	Pachaimuthusamy. D.	Draw repaired.		Mahalakshmi. G. - Operation Theatre	10/06/2022
Comp. Dt. : 03/06/2022								
Status : Completed								
2121	22060102	Main OT	NEED REPAIRING WORK FOR TROLLEY WHEEL -NOT WORKING	Sarathy. A.	4m new wheel fixed.		Ayisha Bee. M. A. - Operation Theatre	10/06/2022
2122	22060118	ORTHO OT	NEED TO CHANGE WHEEL FOR PATIENT STRUCTURE	Sarathy. A.	8nos of wheel fixed.		Saravanan. P. - Operation Theatre	10/06/2022
Comp. Dt. : 07/06/2022								
Status : Completed								
2123	22060252	SPECIALITY OT	NEED TO REFIX HANGER FOR RECOVERY MONITOR	Ekambaram. K.	Hanger fixed.		Sobiya. N. - Operation Theatre	13/06/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 14/06/2022 Status : Completed								
2124	22060525	SPECIALITY OT	NEED CARPENDER FOR FIXING NOTICE BOARD	Ekambaram. K.	Notice Board fixed, problem solved		Mahalakshmi. G. - Operation Theatre	01/07/2022
Comp. Dt. : 15/06/2022 Status : Completed								
2125	22060568	Main OT	NEED TO FIX NORCOTING CUPBOARD FOR ENTRANCE	Ekambaram. K.	New Cupboard fixed, work completed		Shankari. G. - Operation Theatre	01/07/2022
Comp. Dt. : 16/06/2022 Status : Completed								
2126	22060616	ORTHO OT	NEED TO REFIX FALSE CEILING IN STORE ROOM - DAMAGE & BROKEN	Pachaimuthusamy. D.	Wrong complaint		Mahalakshmi. G. - Operation Theatre	01/07/2022
Comp. Dt. : 20/06/2022 Status : Completed								
2127	22060704	SPECIALITY OT	NEED REPAIRING WORK FOR PATIENT STRUCTURE WHEEL [4NOS] WHEEL NOT WORKING	Sarathy. A.	Structure wheel replaced, problem solved		Jayakumar. K. - Operation Theatre	01/07/2022
Comp. Dt. : 21/06/2022 Status : Completed								
2128	22060765	SPECIALITY OT	NEED TO REFIX HANGER	Pachaimuthusamy. D.	Hanger refixed, problem solved		Sobiya. N. - Operation Theatre	02/07/2022
2129	22060774	SPECIALITY OT	NEED REPAIRING WORK FOR DOOR	Ekambaram. K.	Door repaired and serviced, problem solved		Evangelin. S. - Operation Theatre	02/07/2022
Comp. Dt. : 22/06/2022 Status : Completed								
2130	22060786	New OT	NEED REPAIRING WORK FOR WHEEL CHAIR WHEEL - BROKEN	Sarathy. A.	4Nos of wheel replaced, problem solved		Jayapratha. S. - Operation Theatre	02/07/2022
Comp. Dt. : 29/06/2022 Status : Completed								
2131	22061061	ORTHO OT	NEED TO REFIX PATLOCK FOR STOREROOM DOOR	Pachaimuthusamy. D.	Pad lock fixed		Shankari. G. - Operation Theatre	05/07/2022
Comp. Dt. : 01/07/2022 Status : Completed								
2132	22070003	Casualty	NEED REPAIRING WORK FOR WHEEL CHAIR - WHEEL NOT WORKING	Sarathy. A.	Wheel chair wheels refixed and serviced, problem solved		Murugu. V. - Operation Theatre	09/07/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 02/07/2022								
Status : Completed								
2133	22070050	Main OT	NEED REPAIRING WORK FOR WHEEL CHAIR WHEEL	Sarathy. A.	Wheel chair wheel changed, problem solved		Jayakumar. K. - Operation Theatre	09/07/2022
2134	22070060	ORTHO OT	NEED TO REFIX WALL SUCTION	Ekambaram. K.	Wall suction fixed, problem solved		Shankari. G. - Operation Theatre	20/07/2022
Comp. Dt. : 04/07/2022								
Status : Completed								
2135	22070081	Casualty	NEED REPAIRING WORK FOR WHEELCHAIR - CENTRAL AXLE BROKEND	Sarathy. A.	New axle fixed, work completed		Murugu. V. - Operation Theatre	09/07/2022
2136	22070122	ORTHO OT	NEED SHARPENING WORK FOR SCISSORS	Sarathy. A.	8Nos of scissors sharpened, work completed		Mahalakshmi. G. - Operation Theatre	09/07/2022
Comp. Dt. : 05/07/2022								
Status : Completed								
2137	22070166	Main OT	NEED TO CHANGE SURGERY WHEEL 4 NOS - BROKENED	Sarathy. A.	New 4Nos of wheel changed, problem solved		Saravanan. P. - Operation Theatre	18/07/2022
Comp. Dt. : 06/07/2022								
Status : Completed								
2138	22070188	OG OT	NEED REPAIRING WORK FOR RESTROOM DOOR 2 NOS [MALE DOCTOR'S ROOM + OTHER]	Pachaimuthusamy. D.	Novapan door fixed, work completed		Sasikala. S. - Operation Theatre	18/07/2022
Comp. Dt. : 08/07/2022								
Status : Completed								
2139	22070294	SURGERY OT	NEED REPAIRING WORK FOR DOOR STOPPER - BOTH SIDE PROBLEM - NOT WORKING	Ekambaram. K.	Door stopper changed, problem solved		Jagatheeswaran. G. - Operation Theatre	18/07/2022
2140	22070299	ORTHO OT	NEED PAINTING WORK FOR DOCTOR'S ROOM & SIDE ROOM	Manimaran. A.	Duty Doctor room - painting work completed		Mahalakshmi. G. - Operation Theatre	18/07/2022
Comp. Dt. : 09/07/2022								
Status : Completed								
2141	22070363	OG OT	NEED REPAIRING WORK FOR DOOR - BROKEN	Ekambaram. K.	Door repaired and serviced, problem solved		Amudha. V. - Operation Theatre	20/07/2022
Comp. Dt. : 13/07/2022								
Status : Completed								
2142	22070516	SPECIALITY OT	NEED REPAIRING WORK FOR DOOR - CLOSING DIFFICULT	Ekambaram. K.	Door repaired and serviced, problem solved		Jayakumar. K. - Operation Theatre	01/08/2022

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 18/07/2022								
Status : Completed								
2143	22070676	ORTHO OT	NEED TO REFIX NARCOTTING CUPBOARD	Ekambaram. K.	Narcotting cupboard refixed, work completed		Shankari. G. - Operation Theatre	01/08/2022
2144	22070677	OG OT	NEED REPAIRING WORK FOR DOOR - STRUCK	Ekambaram. K.	Door repaired and serviced, problem solved		Amudha. V. - Operation Theatre	01/08/2022
Comp. Dt. : 20/07/2022								
Status : Completed								
2145	22070730	OG OT	NEED REPAIRING WORK FOR DOOR LOCK	Parthiban.K.	Door stopper fixed, door lock repaired, problem solved		Sasikala. S. - Operation Theatre	01/08/2022
Comp. Dt. : 26/07/2022								
Status : Completed								
2146	22070976	OG OT	NEED REPAIRING WORK FOR OT DOOR - NEED URGENT SERVICE	Ekambaram. K.	Door repaired and refixed in properly, problem solved		Amudha. V. - Operation Theatre	05/08/2022
Comp. Dt. : 03/08/2022								
Status : Completed								
2147	22080108	New OT	NEED REPAIRING WORK FOR UROLOGY OT DOOR - DOOR STOPPER PROBLEM	Ekambaram. K.	New door stopper changed, problem solved		Punitha. A. - Operation Theatre	08/08/2022
2148	22080137	OG OT	NEED WELDING WORK FOR SIDE TRAY - LEAKAGE	Sarathy. A.	Wrong complaint		Amudha. V. - Operation Theatre	08/08/2022
Comp. Dt. : 05/08/2022								
Status : Completed								
2149	22080217	EMERGENCY OT NEAR CASUALTY	NEED REPAIRING WORK FOR TROLLEY SIDE RAILS , WHEELS & BELT	Sarathy. A.	Trolley wheels, belt and sidrails are repaired and serviced, problem solved		Hari Hara Sudhan. K. - Operation Theatre	17/08/2022
Comp. Dt. : 11/08/2022								
Status : Completed								
2150	22080416	ORTHO OT	NEED WHITE CEMENT & PAINTING WORK FOR DOCTOR'S ROOM	Murugavel,Sankar. T. M.,Manimaran. A.	Masonry work and painting work completed		Shankari. G. - Operation Theatre	23/08/2022
Comp. Dt. : 17/08/2022								
Status : Completed								
2151	22080501	SURGERY OT	STERILIZER WATER LEAKAGE	Parthiban.K.	Leakage arrested, problem solved		Jagatheeswaran. G. - Operation Theatre	26/08/2022
Comp. Dt. : 18/08/2022								
Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2152	22080574	SPECIALITY OT	IN RECOVERY ROOM-PATIENT COT WHEEL BROKEN-NEED TO BE REPAIR	Sarathy. A.	Cot repaired and serviced, problem solved		Evangelin. S. - Operation Theatre	26/08/2022
		Comp. Dt. : 22/08/2022 Status : Completed						
2153	22080709	SURGERY OT	NEED WELDING WORK FOR STERILIZER [OLD SURGERY OT]	Sarathy. A.	Wrong complaint		Ramachandiran. M. - Operation Theatre	01/09/2022
		Comp. Dt. : 23/08/2022 Status : Completed						
2154	22080772	ORTHO OT	NEED TO CLOSE DOOR GAP WITH PLYWOOD SHEET	Ekambaram. K.	Plywood sheet fixed, problem solved		Shankari. G. - Operation Theatre	01/09/2022
		Comp. Dt. : 26/08/2022 Status : Completed						
2155	22080903	ORTHO OT	DUE TO CLOSING FAST , NEED ADJUSTMENT WORK FOR MAIN DOOR	Ekambaram. K.	Door serviced.		Shankari. G. - Operation Theatre	09/09/2022
		Comp. Dt. : 01/09/2022 Status : Completed						
2156	22090027	SPECIALITY OT	NEED TO REFIX CLAMP FOR FIXING MULTIPARA MONITOR	Murugavel	4nos. clamp fixed.		Jayapratha. S. - Operation Theatre	08/09/2022
2157	22090054	SPECIALITY OT	NEED REPAIRING WORK FOR OT ALL DOORS [4 OT DOORS]	Ekambaram. K., Sundaramoorthy. G., Venkatesan. R.	work completed.		Sobiya. N. - Operation Theatre	08/09/2022
		Comp. Dt. : 14/09/2022 Status : Completed						
2158	22090520	ORTHO OT	NEED TO REFIX PATLOCK FOR STORE ROOM DOOR	Ekambaram. K.	New 6" padlock 2Nos changed, problem solved		Mahalakshmi. G. - Operation Theatre	29/09/2022
		Comp. Dt. : 20/09/2022 Status : Completed						
2159	22090781	Main OT	NEED REPAIRING WORK FOR MAIN DOOR - BROKEN & SOUND PROBLEM	Sundaramoorthy. G., Venkatesan. R., Ekambaram. K.	Main door repaired and serviced, problem solved		Ramachandiran. M. - Operation Theatre	29/09/2022
		Comp. Dt. : 21/09/2022 Status : Completed						
2160	22090841	SPECIALITY OT	NEED TO CHANGE WHEEL IN STRUCTURE	Sarathy. A.	New wheel changed in stretcher, problem solved		Jayakumar. K. - Operation Theatre	29/09/2022

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHAKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 29/09/2022 Status : Completed								
2161	22091148	SPECIALITY OT	NEED TO REFIX CAP, MASK WOODEN BOX - DAMAGE & BROKEN	Ekambaram. K.	New cupboard fixed, work completed		Jayapratha. S. - Operation Theatre	12/10/2022
Comp. Dt. : 05/10/2022 Status : Completed								
2162	22100033	OG OT	NEED REPAIRING WORK FOR DOCTOR'S ROOM DOOR PATLOCK - DAMAGE & NOT CLOSING	Ekambaram. K.	New pad lock changed and refixed, problem solved		Ranjani. V. - Operation Theatre	12/10/2022
Comp. Dt. : 12/10/2022 Status : Completed								
2163	22100313	CSSD	TABLE WELDING WORK	Sarathy. A.	Table leg welded and bush fixed, problem solved		Ramamoorthy.T.K - Operation Theatre	20/10/2022
Comp. Dt. : 13/10/2022 Status : Completed								
2164	22100422	New OT	NEED REPAIRING WORK FOR RECOVERY ROOM COT HEAD END ROD - BROKEN & DAMAGE	Sarathy. A.	Cot head and rod welded and painting work completed		Kousalya. S. - Operation Theatre	16/11/2022
Comp. Dt. : 25/10/2022 Status : Completed								
2165	22100775	SPECIALITY OT	OUTER TROLLEY WHEEL NOT WORKING AND PAINTING WORK	Sarathy. A.	New wheel 6" 4 nos fixed.		Sobiya. N. - Operation Theatre	29/10/2022
Comp. Dt. : 29/10/2022 Status : Completed								
2166	22100945	OG OT	DOOR NOISE PROBLEM	Ekambaram. K.	Door repaired and serviced, problem solved		Amudha. V. - Operation Theatre	08/11/2022
Comp. Dt. : 04/11/2022 Status : Completed								
2167	22110120	ORTHO OT	2 NO'S WHEEL CHAIR SCREW NEED TO BE REFIX TIGHTLY	Sarathy. A.	New wheel changed, problem solved		Shankari. G. - Operation Theatre	16/11/2022
Comp. Dt. : 08/11/2022 Status : Completed								
2168	22110314	New OT	OUTER TROLLEY STRUCTURE ROD BENDING (INTERCOM NO. 1129)	Ekambaram. K.	Trolley and stretcher wheel changed, problem solved		Kousalya. S. - Operation Theatre	18/11/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2169	22110315	New OT	PATIENT WAITING ROOM CHAIR REPAIR	Sarathy. A.	Chair repaired and serviced, problem solved		Kousalya. S. - Operation Theatre	18/11/2022
	Comp. Dt. : 14/11/2022							
	Status : Completed							
2170	22110539	SPECIALITY OT	REQUEST TO CHECK ALL DOOR'S AND DOOR CLOSER AT ALL ROOMS	Ekambaram. K.	work completed.		Sobiya. N. - Operation Theatre	21/11/2022
	Comp. Dt. : 15/11/2022							
	Status : Completed							
2171	22110633	New OT	IN MALE SURGEON ROOM-HANGER REFIXING WORK NEED TO DO	Ekambaram. K.	Hanger fixed.		Kousalya. S. - Operation Theatre	21/11/2022
	Comp. Dt. : 17/11/2022							
	Status : Completed							
2172	22110709	OG OT	NORCOTIC BOX LOCK PROBLEM	Ekambaram. K.	Lock repaired and serviced, problem solved		Ranjani. V. - Operation Theatre	01/12/2022
	Comp. Dt. : 19/11/2022							
	Status : Completed							
2173	22110823	ORTHO OT	IN RECOVERY-PATIENT COT CANNOT ELEVATING	Ekambaram. K.	Cot welding work completed		Shankari. G. - Operation Theatre	01/12/2022
	Comp. Dt. : 22/11/2022							
	Status : Completed							
2174	22110919	ORTHO OT	NEED REPAIRING WORK FOR II DOOR BROKEN	Ekambaram. K.	Door repaired and serviced, problem solved		Mahalakshmi. G. - Operation Theatre	06/12/2022
2175	22110929	ORTHO OT	NEED CEMENT WORK FOR WASHING AREA & WASH BASIN	Murugavel	Cement plastering work completed		Mahalakshmi. G. - Operation Theatre	01/12/2022
	Comp. Dt. : 25/11/2022							
	Status : Completed							
2176	22111112	ORTHO OT	WALL PAINTING WORK NEED TO DO	Manimaran. A.	Wall painting work completed		Mahalakshmi. G. - Operation Theatre	06/12/2022
	Comp. Dt. : 26/11/2022							
	Status : Completed							
2177	22111156	SPECIALITY OT	LAPROSCOPIC MONITOR STAND PAINTING WORK NEED TO DO	Manimaran. A.	Monitor stand painting work completed		Jayapratha. S. - Operation Theatre	19/12/2022
	Comp. Dt. : 30/11/2022							
	Status : Completed							
2178	22111261	New OT	NEED PAINTING WORK	Manimaran. A.	painting work completed		Kousalya. S. - Operation Theatre	19/12/2022

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 01/12/2022								
Status : Completed								
2179	22120009	OG OT	NEED REPAIRING WORK FOR DOOR - SOUND & CLOSING PROBLEM	Ekambaram. K.	Door repaired.		Amudha. V. - Operation Theatre	10/12/2022
2180	22120047	EMERGENCY OT NEAR CASUALTY	NEED REPAIRING WORK FOR DOOR LOCK - NOT WORKING	Ekambaram. K.	Lock fixed.		Hemalatha.G. - Operation Theatre	10/12/2022
Comp. Dt. : 12/12/2022								
Status : Completed								
2181	22120519	OG OT	MEDICINE TROLLEY WHEEL PROBLEM	Sarathy. A.	Trolley wheel repaired and refixed, problem solved		Ranjani. V. - Operation Theatre	19/12/2022
Comp. Dt. : 14/12/2022								
Status : Completed								
2182	22120643	SPECIALITY OT	NEED REPAIRING WORK FOR DOOR - NOT CLOSING PROPER AT OT NO 6	Ekambaram. K.	Door serviced.		Jayapratha. S. - Operation Theatre	23/12/2022
Comp. Dt. : 21/12/2022								
Status : Completed								
2183	22120944	OG OT	OT MAIN DOOR PROBLEM	Ekambaram. K., Sundaramoorthy. G., Pachaimuthusamy . D.	Door rework and serviced, refixed in properly, work completed		Sathia. R. - Operation Theatre	29/12/2022
2184	22120945	OG OT	NARCOTIC CUPBOARD LOCK PROBLEM	Ekambaram. K.	Cupboard lock repaired and serviced, problem solved		Sathia. R. - Operation Theatre	23/01/2023
Comp. Dt. : 30/12/2022								
Status : Completed								
2185	22121350	Main OT	HISTOPATHOLOGY BOARD NEED TO BE FIX	Ekambaram. K.	Board fixed, problem solved		Shankari. G. - Operation Theatre	05/01/2023
Comp. Dt. : 31/12/2022								
Status : Completed								
2186	22121405	SPECIALITY OT	PATIENT TROLLEY WHEEL BROKEN, NEED TO BE REPAIR	Sarathy. A.	New wheel changed, problem solved		Jayapratha. S. - Operation Theatre	05/01/2023
Comp. Dt. : 03/01/2023								
Status : Completed								
2187	23010084	OG OT	IN DOCTOR'S ROOM-WHITE WASH NEED TO DO IMMEDIATELY	Manimaran. A.	Room painting work completed		Amudha. V. - Operation Theatre	23/01/2023
Comp. Dt. : 11/01/2023								

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
2188	23010437	SURGERY OT	OLD SURGERY OT-WIRE CHAIR REPAIR WORK	Manivannan. A.	S Type chair repaired		Ramachandiran. M. - Operation Theatre	23/01/2023
2189	23010438	SURGERY OT	IN OLD SURGERY OT-DOOR LOCK PROBLEM	Ekambaram. K.	Door lock changed, problem solved		Ramachandiran. M. - Operation Theatre	23/01/2023
Comp. Dt. : 13/01/2023								
Status : Completed								
2190	23010548	UROLOGY	NEED REPAIRNG WORK FOR MALE STAFF DRESS CHANGING ROOM DOOR LOCK - PROBLEM (UROLOGY NEW OT)	Ekambaram. K.	Door lock repaired and serviced, problem solved		Punitha. A. - Operation Theatre	30/01/2023
Comp. Dt. : 18/01/2023								
Status : Completed								
2191	23010621	Main OT	NEED REPAIRING WORK FOR BERO LOCK	Ekambaram. K.	Bero lock repaired and serviced, problem solved		Shankari. G. - Operation Theatre	30/01/2023
Comp. Dt. : 20/01/2023								
Status : Completed								
2192	23010719	SURGERY OT	NEED TO CHECK NORCOTTING CUPBOARD LOCK - NOT WORKING NEED URGENT SERVICE	Ekambaram. K.	Cupboard lock repaired and serviced, problem solved		Anitha. R. - Operation Theatre	30/01/2023
Comp. Dt. : 25/01/2023								
Status : Completed								
2193	23010903	ALL OPERATION THEATER(OT)	NEED TO CHECK ALL DOOR'S FOR ALL OT"S	Ekambaram. K.	All OT's door checked, no complaints		Shankari. G. - Operation Theatre	16/02/2023
Comp. Dt. : 30/01/2023								
Status : Completed								
2194	23011072	ORTHO OT	NEED REPAIRING WORK FOR OPTHAL BERO LOCK NOT WORKING	Ekambaram. K.	Lock changed, problem solved		Shankari. G. - Operation Theatre	11/02/2023
Comp. Dt. : 31/01/2023								
Status : Completed								
2195	23011107	OG OT	NEED REPAIRING WORK FOR OUTER TROLLEY - DAMAGE	Ekambaram. K.	New wheel 4Nos changed, problem solved		Sathia. R. - Operation Theatre	11/02/2023
2196	23011123	OG OT	NEED REPAIRING WORK FOR INSTRUMENT TROLLEY	Sarathy. A.	Trolley wheel changed, problem solved		Subashini. E. - Operation Theatre	11/02/2023
Comp. Dt. : 18/02/2023								
Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2197	23020718	SPECIALITY OT	NEED REPAIRING WORK FOR DEMO ROOM DOOR - SOUND - BROKEN	Ekambaram. K.	Door closer adjusted, problem solved		Jayapratha. S. - Operation Theatre	23/02/2023
	Comp. Dt. : 22/02/2023							
	Status : Completed							
2198	23020863	ORTHO OT	25 TILES CHANGE WORK	Murugavel	25Nos of Tiles fixed, JK white cement pointing work completed		Saravanan. P. - Operation Theatre	01/03/2023
	Comp. Dt. : 28/02/2023							
	Status : Completed							
2199	23021052	SURGERY OT	(1159) NEED TO LOCK CRR I ROOM	Ekambaram. K.	PADLOCK FIXED.		Ramachandiran. M. - Operation Theatre	07/03/2023
	Comp. Dt. : 03/03/2023							
	Status : Completed							
2200	23030147	SURGERY OT	NEED PAINTING WORK	Manimaran. A.	PAINTING WORK COMPLETED		Manibharathi. S. - Operation Theatre	04/05/2023
	Comp. Dt. : 06/03/2023							
	Status : Completed							
2201	23030235	SURGERY OT	NEED REPAIRING WORK FOR FEMALE SURGEN ROOM DOOR - BROKEN	Ekambaram. K.	Door repaired and serviced, problem solved		Ramachandiran. M. - Operation Theatre	09/03/2023
	Comp. Dt. : 07/03/2023							
	Status : Completed							
2202	23030296	UROLOGY	GLASS DOOR BROKEN - NEED REPAIRING WORK AT UROLOGY OT	Ekambaram. K.	DOOR REPAIRED.		Banupriya. M. - Operation Theatre	14/03/2023
	Comp. Dt. : 14/03/2023							
	Status : Completed							
2203	23030535	EMERGENCY OT NEAR CASUALTY	NEE TO REFIX MONITOR STAND	Ekambaram. K.	WORK COMPLETED.		Hemalatha.G. - Operation Theatre	23/03/2023
2204	23030566	ORTHO OT	NEED REPAIRING WORK FOR BERO & PIGEON LOCKER	Ekambaram. K.	WORK COMPLETED		Mahalakshmi. G. - Operation Theatre	23/03/2023
	Comp. Dt. : 16/03/2023							
	Status : Completed							
2205	23030644	OG OT	NEED PAINTING WORK FOR SCRUB STAND	Manimaran. A.	WORK COMPLETED		Sathia. R. - Operation Theatre	23/03/2023
	Comp. Dt. : 17/03/2023							
	Status : Completed							
2206	23030712	OG OT	NEED TO REFIX DOOR BUSH	Ekambaram. K.	Door bush refixed		Ranjani. V. - Operation Theatre	31/03/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2207	23030727	ORTHO OT	NEED REPAIRING WORK FOR WOODEN CUPBOARD - AT ENTRANCE	Ekambaram. K.	Cupboard repaired and serviced		Shankari. G. - Operation Theatre	31/03/2023
Comp. Dt. : 20/03/2023 Status : Completed								
2208	23030802	SURGERY OT	NEED REPAIRING WORK FOR DOOR LOCK [OLD SURGERY OT DOCTOR'S ROOM]	Ekambaram. K.	Door lock repaired and serviced		Ramachandiran. M. - Operation Theatre	31/03/2023
Comp. Dt. : 23/03/2023 Status : Completed								
2209	23030976	UROLOGY--OPD	NEED REPAIRING WORK FOR GLASS DOOR 2NOS - SOUND & STUCK	Ekambaram. K.	WORK COMPLETED		Banupriya. M. - Operation Theatre	01/04/2023
Comp. Dt. : 27/03/2023 Status : Completed								
2210	23031136	SURGERY OT	NEED REPAIRING WORK FOR INSTRUMENT TROLLEY - STUCK	Sarathy. A.	TROLLY REPAIRED.		Ramachandiran. M. - Operation Theatre	01/04/2023
Comp. Dt. : 11/04/2023 Status : Completed								
2211	23040328	SPECIALITY OT	NEED REPAIRING WORK FOR OT DOORS [4NOS]& PATIENT INTRALLOY STUCK	Ekambaram. K., Sundaramoorthy. G., Pachaimuthusamy . D.	Wrong complaint		Anitha. R. - Operation Theatre	20/04/2023
Comp. Dt. : 19/04/2023 Status : Completed								
2212	23040600	ORTHO OT	NEED TO REFIX DOOR CLOSER AT OT NO 3 [INSIDE DOOR]	Ekambaram. K.	DOOR CLOSER REFIXED		Mahalakshmi. G. - Operation Theatre	02/05/2023
Comp. Dt. : 20/04/2023 Status : Completed								
2213	23040645	ORTHO OT	NEED TO REFIX AC PIPELINE ROD - BROKEN AND THE SUPPORT RAD HANGSOFF AT AC WING SIDE	Ekambaram. K.	WORK COMPLETED		Mahalakshmi. G. - Operation Theatre	02/05/2023
Comp. Dt. : 25/04/2023 Status : Completed								
2214	23040805	ORTHO OT	NEED REPAIRING WORK FOR WOODEN LOCK	Ekambaram. K.	WORK COMPLETED		Mahalakshmi. G. - Operation Theatre	02/05/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 02/05/2023 Status : Completed								
2215	23050071	SPECIALITY OT	NEED TO REFIX PATLOCK FOR BERO	Ekambaram. K.	PADLOCK FIXED		Daiseyrani. A. - Operation Theatre	17/05/2023
Comp. Dt. : 03/05/2023 Status : Completed								
2216	23050078	SURGERY OT	NEED PAINTING WORK - OLD SURGERY OT	Manimaran. A.	WALL CLEANED AND PAINTED		Ramachandiran. M. - Operation Theatre	17/05/2023
Comp. Dt. : 08/05/2023 Status : Completed								
2217	23050271	SPECIALITY OT	NEED REPAIRING WORK FOR CUPBOARD PATLOG & LOCKER FOR ONCOLOGY	Ekambaram. K.	PADLOCK FIXED		Sobiya. N. - Operation Theatre	18/05/2023
2218	23050272	SPECIALITY OT	NEED PAINTING WORK FOR DEMOROOM INSIDE RESTROOM	Manimaran. A.	FUNGUS CLEANED AND PAINTED		Sobiya. N. - Operation Theatre	18/05/2023
Comp. Dt. : 17/05/2023 Status : Completed								
2219	23050707	New OT	NEED REPAIRING WORK FOR DOOR STOPPER	Ekambaram. K.	DOOR STOPPER FIXED.		Logesh. D. - Operation Theatre	01/06/2023
Comp. Dt. : 18/05/2023 Status : Completed								
2220	23050759	Endoscopy	NEED PAINTING WORK FOR IV STAND & FOOT STOOL	Manimaran. A.	PAINTING WORK COMPLETED		Ramya. P. - OPD	01/06/2023
Comp. Dt. : 20/05/2023 Status : Completed								
2221	23050839	ORTHO OT	NEED TO REFIX DOOR CLOSER FOR OT NO 2 & 3	Ekambaram. K.	DOOR CLOSER FIXED.		Mahalakshmi. G. - Operation Theatre	01/06/2023
Comp. Dt. : 26/05/2023 Status : Completed								
2222	23051062	Main OT	NEED REPAIRING WORK FOR DOOR [INSIDE OT]	Ekambaram. K.	PADLOCK FIXED		Shankari. G. - Operation Theatre	03/06/2023
2223	23051063	Main OT	NEED WHITE CEMENT WORK FOR TILES TOUCHUP	Parivallal. P.	JK WHITE APPLIED		Shankari. G. - Operation Theatre	03/06/2023
2224	23051064	New OT	NEED REPAIRING WORK FOR COT- WHEEL STUCK	Sarathy. A.	COT WHEEL REPLACED		Udhaya Kumar. C. - Operation Theatre	03/06/2023
Comp. Dt. : 31/05/2023 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2225	23051255	Main OT	NEED REPAIRING WORK FOR BERO LOCK - DAMAGE - NOT WORKING	Ekambaram. K.	Lock fixed		Shankari. G. - Operation Theatre	20/06/2023
Comp. Dt. : 05/06/2023 Status : Completed								
2226	23060128	OG OT	NEED TO CHANGE STRETCHER WHEEL - STUCK	Sarathy. A.	Wheel changed.		Sathia. R. - Operation Theatre	20/06/2023
Comp. Dt. : 06/06/2023 Status : Completed								
2227	23060172	EMERGENCY OT NEAR CASUALTY	NEED REPAIRING WORK FOR DOOR HANDLE - BROKEN	Ekambaram. K.	Handle fixed		Hemalatha.G. - Operation Theatre	20/06/2023
Comp. Dt. : 09/06/2023 Status : Completed								
2228	23060307	ORTHO OT	NEED TO CHANGE GLASS DOOR - BROKEN - II DOOR	Ekambaram. K.	Nova pan sheet fixed		Mahalakshmi. G. - Operation Theatre	20/06/2023
2229	23060308	ORTHO OT	NEED REPAIRING WORK FOR TROLLEY WHEEL - STUCK	Sarathy. A.	Wheel replaced		Mahalakshmi. G. - Operation Theatre	20/06/2023
Comp. Dt. : 13/06/2023 Status : Completed								
2230	23060452	SPECIALITY OT	NEED TO FIX NEW DRESS HANGE FOR DOCTOR'S USE	Ekambaram. K.	Cot repaired wheel fixed		Jagatheeswaran. G. - Operation Theatre	20/06/2023
2231	23060475	ORTHO OT	NEED REPAIRING WORK FOR RECOVERY COT WHEEL & INSTRUMENT TROLLEY WHEEL	Sarathy. A.	Cot repaired and wheel fixed		Mahalakshmi. G. - Operation Theatre	20/06/2023
Comp. Dt. : 15/06/2023 Status : Completed								
2232	23060524	CTVS INSIDE ORTHO OT	(1112) MALE STAFF DRESS CHANGE ROOM DOOR GLASS BROKEN.	Ekambaram. K.	Wrong complaint		Pavadharani. S. - Operation Theatre	27/06/2023
Comp. Dt. : 19/06/2023 Status : Completed								
2233	23060688	SURGERY OT	NEED REPAIRING WORK FOR NORCOATING CUPBOARD - 2ND LOCK NOT WORKING	Ekambaram. K.	Lock fixed.		Sobiya. N. - Operation Theatre	27/06/2023
Comp. Dt. : 20/06/2023 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2234	23060730	SPECIALITY OT	NEED TO CHECK WHETHER, ALL DOOR STOPPER WERE WORKING OTHERWISE NEED TO REFIT	Ekambaram. K.	Wrong complained.		Jayapratha. S. - Operation Theatre	27/06/2023
2235	23060731	SPECIALITY OT	WINDOW GLASS DOOR BROKEN NEED REPAIRING WORK FOR OUTSIDE CARITOR	Ekambaram. K.	Wrong complaint		Jayapratha. S. - Operation Theatre	27/06/2023
Comp. Dt. : 24/06/2023 Status : Completed								
2236	23060899	SURGERY OT	NEED CARPENTER FOR BOARD FIXING WORK	Ekambaram. K.	Board fixed.		Ramachandiran. M. - Operation Theatre	07/07/2023
Comp. Dt. : 26/06/2023 Status : Completed								
2237	23060956	SPECIALITY OT	NEED REPAIRING & REFIX SCREW FOR OT DOOR - NO 4 & 6	Ekambaram. K.	Screw fixed.		Anitha. R. - Operation Theatre	07/07/2023
Comp. Dt. : 28/06/2023 Status : Completed								
2238	23061072	ORTHO OT	NEED REPAIRING WORK FOR LAST DOOR NEAR WASH BASIN - LOCK AND WALL FRAME PROBLEM	Ekambaram. K., Sundaramoorthy. G., Ganesh. S.	Work completed		Mahalakshmi. G. - Operation Theatre	08/07/2023
Dept Name : ORTHOPAEDICS - Work Shop Comp. Dt. : 27/05/2022 Status : Completed								
2239	22051024	COMMON FEMALE RESTROOM NEAR ORTHO OPD	NEED REPAIRING & REFIX DOOR LOCK - DAMAGE & BROKENED	Pachaimuthusamy. D.	Door lock fixed.		Manjula. P. - ORTHOPAEDICS	10/06/2022
Comp. Dt. : 24/08/2022 Status : Completed								
2240	22080793	Orthopaedics - OPD	NEED PAINTING WORK FOR ROOM NO 64 & 65	Manimaran. A.	2 room painted.		Manjula. P. - ORTHOPAEDICS	09/09/2022
Comp. Dt. : 18/11/2022 Status : Completed								
2241	22110760	Orthopaedics - OPD	KEY MISSING - NEED TO BREAK TABLE DRAW LOCKER ROOM NO 64	Ekambaram. K.	Lock opened, problem solved		Manjula. P. - ORTHOPAEDICS	01/12/2022
Dept Name : PAEDIATRICS - Work Shop Comp. Dt. : 18/11/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2242	22110794	Audiometry & Speech Therapy	NEED TO FIX NEW DOOR STOPER	Ekambaram. K.	New door closer changed, problem solved		Manju @ Brinda. V. - PAEDIATRICS	01/12/2022
		Comp. Dt. : 16/02/2023 Status : Completed						
2243	23020653	PICU & NICU	(SECOND FLOOR NICU) DR'S REST ROOM--NEED TO FIX NEW PADLOCK	Ekambaram. K.	2Nos of Padlock fixed, work completed		Thambiprabagarane. K. - PAEDIATRICS	23/02/2023
		Comp. Dt. : 10/03/2023 Status : Completed						
2244	23030393	Paediatrics - OPD	NEED TO FIX NAILS 25NOS FOR PHOTO FIXING AT PAEDIATRICS MUESIUM	Ekambaram. K.	PHOTO FIXED		Manju @ Brinda. V. - PAEDIATRICS	23/03/2023
		Comp. Dt. : 08/04/2023 Status : Completed						
2245	23040240	Audiometry & Speech Therapy	NEED TO REFIX BUSH & DOOR STOPPER FOR DOOR	Ekambaram. K.	New door stopper and bush fixed, problem solved		Manju @ Brinda. V. - PAEDIATRICS	20/04/2023
		Comp. Dt. : 23/05/2023 Status : Completed						
2246	23050918	Audiometry & Speech Therapy	NEED REPAIRING WORK FOR DOOR - DOOR STOPER PROBLEM	Ekambaram. K.	DOOR CLOSER FIXED		Manju @ Brinda. V. - PAEDIATRICS	03/06/2023
		Dept Name : Paediatrics Ward - Work Shop Comp. Dt. : 11/05/2022 Status : Completed						
2247	22050378	Paediatrics - Ward 308	NEED TO FIX DEMO ROOM PATLOCK	Pachaimuthusamy. D.	New padlock fixed, problem solved		Chitra. P. - Paediatrics Ward	18/05/2022
		Comp. Dt. : 17/05/2022 Status : Completed						
2248	22050597	Paediatrics - Ward 309	NEED REPAIRING WORK FOR BERO LOCK - NOT WORKING	Ekambaram. K.	Pad lock fixed.		Chitra. P. - Paediatrics Ward	18/06/2022
		Comp. Dt. : 04/06/2022 Status : Completed						
2249	22060158	Paediatrics - Ward 310	NEED REPAIRING WORK FOR "S" TYPE CHAIR & BERO LOCK	Ekambaram. K., Venkatesan. R., Pachaimuthusamy. D.	Lock repaired.		Chitra. P. - Paediatrics Ward	10/06/2022
		Comp. Dt. : 07/06/2022 Status : Completed						


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2250	22060275	Paediatrics - Ward 309	NEED REPAIRING WORK FOR BERO LOCK [OR] FIX A PATLOCK	Ekambaram. K.	pad lock fixed.		Kayalvizhi. G. - Paediatrics Ward	13/06/2022
	Comp. Dt. : 08/06/2022							
	Status : Completed							
2251	22060310	Paediatrics - Ward 309	NEED REPAIRING WORK FOR "S" TYPE CHAIR AT DEMO ROOM	Ekambaram. K.	s type chair repaired.		Chitra. P. - Paediatrics Ward	13/06/2022
	Comp. Dt. : 29/06/2022							
	Status : Completed							
2252	22061050	Paediatrics - Ward 310	NEED REPAIRING WORK FOR "S" TYPE CHAIRS 2 NOS	Sarathy. A.	S types c hairs repaired and painted		Chitra. P. - Paediatrics Ward	05/07/2022
	Comp. Dt. : 07/07/2022							
	Status : Completed							
2253	22070290	Paediatrics - Ward 309	NED TO FIX NAILS FOR FIXING BOARDS	Ekambaram. K.	Board fixed with nails, problem solved		Chitra. P. - Paediatrics Ward	18/07/2022
	Comp. Dt. : 16/09/2022							
	Status : Completed							
2254	22090621	DIALYSIS IN 2ND FLOOR	NEED REPAIRING WORK FOR DOOR LOCK - LOCK NOT WORKING	Ekambaram. K.	Door lock repaired and serviced, problem solved		Parameswari. S. - Paediatrics Ward	29/09/2022
	Comp. Dt. : 28/09/2022							
	Status : Completed							
2255	22091110	Paediatrics - Ward 309	NEED REPAIRING WORK FOR PATIENT REST ROOM DUCT DOOR - DAMAGE & BROKEN NEED URGENT SERVICE	Ekambaram. K.	Duct door repaired and refixed, problem solved		Chitra. P. - Paediatrics Ward	08/10/2022
	Comp. Dt. : 05/10/2022							
	Status : Completed							
2256	22100057	Paediatrics - Ward 310	NEED TO REFIX COT SIDE RAILS & CHECK ALL COT SIDE RAILS & SCREWS	Sarathy. A.	Cot repaired and cot side rails and screw refixed in properly, problem solved		Chitra. P. - Paediatrics Ward	12/10/2022
	Comp. Dt. : 04/11/2022							
	Status : Completed							
2257	22110136	Paediatrics - Ward 309	FOLDING SCREEN WHEEL NEED TO BE CHANGE	Sarathy. A.	Screen wheel changed, problem solved		Chitra. P. - Paediatrics Ward	16/11/2022
	Comp. Dt. : 08/11/2022							
	Status : Completed							


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2258	22110281	Paediatrics - Ward 309	2 NO'S BERO RACK DAMGED IN 309 AND 310	Ekambaram. K.,Sundaramoorthy. G.,Manivannan. A.	Bero rack bolt fixed, problem solved		Chitra. P. - Paediatrics Ward	18/11/2022
Comp. Dt. : 18/11/2022 Status : Completed								
2259	22110743	Paediatrics Ward	NEED TO REFIX PATLOCK FOR DOOR FOR WARD NO 309 & 310	Ekambaram. K.	3Nos padlock fixed, problem solved		Chitra. P. - Paediatrics Ward	01/12/2022
Comp. Dt. : 08/12/2022 Status : Completed								
2260	22120348	Paediatrics - Ward 308	NEED TO REFIX BROKEND WINDOW GLASS DOOR [1NO]	Ekambaram. K.	Door refixed in properly, problem solved		Chitra. P. - Paediatrics Ward	19/12/2022
Comp. Dt. : 13/12/2022 Status : Completed								
2261	22120566	Paediatrics - Ward 308	DOOR LOCK PROBLEM IN DEMO ROOM - DOOR NOT OPENED	Ekambaram. K.	Door repaired.		Naveena. N. - Paediatrics Ward	23/12/2022
Comp. Dt. : 28/12/2022 Status : Completed								
2262	22121266	Paediatrics - Ward 308	TILES BROKEN IN DEMO ROOM	Murugavel	Tiles refixed, JK white cement pointing work completed		Hemalatha. P. - Paediatrics Ward	05/01/2023
Comp. Dt. : 29/12/2022 Status : Completed								
2263	22121325	Paediatrics - Ward 308	COT SIDE RAILS AND BOLT NEED TO BE RETIGHTEN	Sarathy. A.	Cot side rails refixed, bolt refixed, problem solved		Chitra. P. - Paediatrics Ward	05/01/2023
Comp. Dt. : 02/01/2023 Status : Completed								
2264	23010004	Paediatrics - Ward 308	2 NO'S TABLE REPAIR WORK NEED TO DO	Ekambaram. K.	2Nos of table repaired and serviced, problem solved		Sivaranjani. S. - Male Medical Ward	12/01/2023
Comp. Dt. : 03/01/2023 Status : Completed								
2265	23010112	Paediatrics - Ward 310	PATIENT COT BOLT NEED TO BE RETIGHT PROPERLY	Sarathy. A.	Cot bolt and nut refixed in properly, problem solved		Chitra. P. - Paediatrics Ward	12/01/2023
2266	23010113	Paediatrics - Ward 310	2 NO'S TABLE REPAIR WORK NEED TO DO	Sarathy. A.	Table repaired and serviced, problem solved		Chitra. P. - Paediatrics Ward	12/01/2023
Comp. Dt. : 04/01/2023								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
2267	23010183	Paediatrics - Ward 308	PATIENT WHEEL CHAIR REPAIRING WORK	Sarathy. A.	Wheel chair serviced, problem solved		Chitra. P. - Paediatrics Ward	12/01/2023
2268	23010184	Paediatrics - Ward 309	PAED WARD-308,309,310-3 FOLDING SCREEN WHEEL FIXING WORK NEED TO DO	Sarathy. A.,Ekambaram. K.,Sundaramoorthy. G.	Folding screen wheel refixed, problem solved		Chitra. P. - Paediatrics Ward	12/01/2023
Comp. Dt. : 20/01/2023								
Status : Completed								
2269	23010693	Paediatrics - Ward 309	NEED WELDING WORK FOR CHEATLE FORCEPS	Sarathy. A.	Welding work completed		Chitra. P. - Paediatrics Ward	30/01/2023
2270	23010694	Paediatrics - Ward 309	CRASH CART PROBLEM - NEED TO REFIX - NOT ABLE TO OPEN	Ekambaram. K.	Crash cart repaired and refixed in properly		Chitra. P. - Paediatrics Ward	16/02/2023
Comp. Dt. : 14/02/2023								
Status : Completed								
2271	23020555	Paediatrics - Ward 308	NEED TO REFIX WINDOW GLASS	Ekambaram. K.	Window glass refixed in properly		Naveena. N. - Paediatrics Ward	17/02/2023
Comp. Dt. : 15/02/2023								
Status : Completed								
2272	23020569	Paediatrics Ward	NEED REPAIRING WORK FOR COT [30 NOS] FOR WARD NO 307 & 308	Sarathy. A.	30Nos of cot checked, some cot repaired and serviced, problem solved		Chitra. P. - Paediatrics Ward	17/02/2023
Comp. Dt. : 17/02/2023								
Status : Completed								
2273	23020700	Paediatrics Ward	NEED REPAIRING WORK FOR PATIENT LOCKER & STOOL - WARD NO 307 & 308	Ekambaram. K.	Patient locker repaired, stool bush fixed, work completed		Chitra. P. - Paediatrics Ward	23/02/2023
Comp. Dt. : 21/02/2023								
Status : Completed								
2274	23020785	Male Medical - Ward 302	NEED REPAIRING WORK FOR RESTROOM DOOR LOCK - LOCK DAMAGE	Ekambaram. K.	New door lock fixed, work completed		Sosilistha. C. - Paediatrics Ward	01/03/2023
Comp. Dt. : 18/03/2023								
Status : Completed								
2275	23030744	Paediatrics - Ward 308	NEED TO REFIX BED SIDE RAILS SCREWS	Sarathy. A.	Bed Side rail screws refixed		Kayalvizhi. G. - Paediatrics Ward	31/03/2023
Comp. Dt. : 08/04/2023								
Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2276	23040239	Paediatrics Ward	DUE TO AVIOD OF OUT PATIENT ENTRY IN NIGHT TIME IN WARD - NEED TO FIX PADLOCK FOR DOOR INSIDE	Ekambaram. K.	New padlock fixed		Chitra. P. - Paediatrics Ward	20/04/2023
Comp. Dt. : 11/04/2023 Status : Completed								
2277	23040327	Paediatrics - Ward 308	NEED TO PUT HOLE FOR RECORD NOTES	Ekambaram. K.	Holes drilled in record notes		Chitra. P. - Paediatrics Ward	20/04/2023
Comp. Dt. : 13/04/2023 Status : Completed								
2278	23040422	Female Medical - Ward 307	TILES BROKEN - NEED TOUCH UP WORK AT WARD INSIDE	Parivallal. P.	18Nos of tiles refixed, JK white cement pointing work completed		Chitra. P. - Paediatrics Ward	20/04/2023
Comp. Dt. : 24/04/2023 Status : Completed								
2279	23040728	Paediatrics - Ward 308	CRASH CART STUCK	Ekambaram. K.	WORK COMPLETED		Kayalvizhi. G. - Paediatrics Ward	02/05/2023
Comp. Dt. : 04/05/2023 Status : Completed								
2280	23050178	Paediatrics - Ward 308	NEED TO REFIX SCREW [PLASTIC] FOR HEIGHT SCALE	Ekambaram. K.	HEIGHT SCALE FIXED		Chitra. P. - Paediatrics Ward	17/05/2023
Comp. Dt. : 09/05/2023 Status : Completed								
2281	23050390	Paediatrics - Ward 309	NEED WELDING WORK FOR PATIENT COUCH	Sarathy. A.	COUCH REPAIRED		Chitra. P. - Paediatrics Ward	18/05/2023
Comp. Dt. : 09/06/2023 Status : Completed								
2282	23060331	Female Medical - Ward 307	NEED REPAIRING WORK FOR NURSE'S CABIN [PAEDIATRICS 307]	Ekambaram. K.	Wrong complaint		Chitra. P. - Paediatrics Ward	20/06/2023
Comp. Dt. : 21/06/2023 Status : Completed								
2283	23060772	Female Medical - Ward 307	NEED TO REFIX MONITOR STAND AT PAEDIATRIC WARD 307	Ekambaram. K.	stand fixed.		Kayalvizhi. G. - Paediatrics Ward	27/06/2023
Dept Name : PATHOLOGY - Work Shop Comp. Dt. : 06/02/2023 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2284	23020153	PATHOLOGY IN COLLEGE	NEED REPAIRING WORK FOR DOOR LOCK - LOCK NOT WORKING	Ekambaram. K.	Door lock repaired and serviced, refixed in properly		Sathia Rajesh. C. - PATHOLOGY	16/02/2023
		Comp. Dt. : 22/04/2023 Status : Completed						
2285	23040710	FNAC ROOM	NEED TO REFIX BOARD	Ekambaram. K.	WORK COMPLETED		Vijayalakshmi. R. - PATHOLOGY	02/05/2023
		Comp. Dt. : 17/05/2023 Status : Completed						
2286	23050723	FNAC ROOM	NEED REPAIRING WORK FOR "S" TYPE CHAIR	Ekambaram. K.	CHAIR REPAIRED.		Muthamil.K. - PATHOLOGY	01/06/2023
		Dept Name : Pharmacy - Work Shop Comp. Dt. : 17/06/2022 Status : Completed						
2287	22060643	Pay Pharmacy	CASH DRAW LOCK STUCK	Pachaimuthusamy. D.	Draw lock repaired, problem solved		Silambuselvan. P. - Pharmacy	01/07/2022
		Comp. Dt. : 23/08/2022 Status : Completed						
2288	22080739	Pay Pharmacy	NEED REPAIRING WORK FOR CASH TABLE DRAW - DAMAGE BROEKN & STUCK	Parthiban.K.	Table draw repaired and serviced, refixed in properly, problem solved		Silambuselvan. P. - Pharmacy	01/09/2022
		Comp. Dt. : 25/08/2022 Status : Completed						
2289	22080830	Pay Pharmacy	NEED REPAIRING WORK FOR CASH TABLE TRAY - STUCK	Ekambaram. K.	New plywood fixed.		Silambuselvan. P. - Pharmacy	09/09/2022
		Comp. Dt. : 30/08/2022 Status : Completed						
2290	22081007	Pay Pharmacy	NEED TO REFIX DOOR [DAMAGE & BROKEN] FOR SINK UNDER SHELF AT LUNCH ROOM	Ekambaram. K.	Civil execution complaint		Silambuselvan. P. - Pharmacy	09/09/2022
		Comp. Dt. : 15/09/2022 Status : Completed						
2291	22090593	Pay Pharmacy	CASH TRAY DRAWER NEED TO BE FIX	Ekambaram. K.	Cash drawer repaired and refixed in properly, problem solved		Rameshkumar. R. - Pharmacy	12/10/2022
		Comp. Dt. : 12/10/2022 Status : Completed						


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2292	22100324	Pay Pharmacy	TROLLY WHEEL NEED TO BE FIXED	Sarathy. A.	Trolley new wheel fixed, problem solved		Sivabalan. S. - Pharmacy	20/10/2022
	Comp. Dt. : 17/10/2022							
	Status : Completed							
2293	22100528	Pay Pharmacy	NEED REPAIRING WORK FOR CASH DRAW - STUCK	Ekambaram. K.	Drawer repaired.		Silambuselvan. P. - Pharmacy	29/10/2022
	Comp. Dt. : 28/10/2022							
	Status : Completed							
2294	22100885	Free Pharmacy	WINDOW DOOR PROBLEM	Ekambaram. K.	Door repaired.		Thilagavathi. T. - Pharmacy	03/11/2022
	Comp. Dt. : 17/11/2022							
	Status : Completed							
2295	22110734	Pay Pharmacy	MATERIAL SHIFTING TROLLY WHEEL BROKEN,NEED TO BE REPAIR	Sarathy. A.	Wheel base welded, problem solved		Sivabalan. S. - Pharmacy	01/12/2022
	Comp. Dt. : 03/01/2023							
	Status : Completed							
2296	23010115	Free Pharmacy	WIRE CHAIR GOT DAMAGED,NEED TO REPAIR	Sarathy. A.	Chair wire rearranged, problem solved		Thilagavathi. T. - Pharmacy	12/01/2023
	Comp. Dt. : 07/02/2023							
	Status : Completed							
2297	23020259	Free Pharmacy	WIRE CHAIR GOT DAMAGED NEED TO BE REPAIR	Manivannan. A.	Wire chair bolt refixed		Jhansirani. T. - Pharmacy	16/02/2023
	Comp. Dt. : 27/02/2023							
	Status : Completed							
2298	23021012	Free Pharmacy	NEED TO FIX "NAME BOARD CHAIN"	Manivannan. A.	WORK COMPLETED.		Thilagavathi. T. - Pharmacy	07/03/2023
2299	23021029	Pay Pharmacy	NEED CARPENTER HELP - AMT FELLDOWN BETWEEN THE GAP OF TABLE & CASH DRAW	Ekambaram. K.	WORK COMPLETED.		Silambuselvan. P. - Pharmacy	07/03/2023
	Comp. Dt. : 28/02/2023							
	Status : Completed							
2300	23021075	Pay Pharmacy	CASH DRAW PROBLEM	Ekambaram. K.	DRAWER REPAIRED		Rameshkumar. R. - Pharmacy	07/03/2023
	Comp. Dt. : 03/03/2023							
	Status : Completed							


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2301	23030133	Pay Pharmacy	NEED REPAIRING WORK FOR CASH DRAW - UNFIX	Ekambaram. K.	Cash draw repaired and serviced, problem solved		Silambuselvan. P. - Pharmacy	09/03/2023
	Comp. Dt. : 10/03/2023							
	Status : Completed							
2302	23030403	Pay Pharmacy	NEED REPAIRING WORK FOR CASH DRAW [BOTTOM] NEED URGENT SERVICE	Ekambaram. K.,Sundaramoorthy. K.,Ganesh. S.	DRAWING REPAIRED		Rameshkumar. R. - Pharmacy	23/03/2023
	Comp. Dt. : 13/03/2023							
	Status : Completed							
2303	23030510	Pay Pharmacy	NEED REPAIRING WORK FOR CASH DRAW- AGAIN STUCK	Ekambaram. K.	DRAWER REPAIRED		Silambuselvan. P. - Pharmacy	23/03/2023
	Comp. Dt. : 21/03/2023							
	Status : Completed							
2304	23030889	Pay Pharmacy	NEED TO FIX NEW DOOR STOPPER	Ekambaram. K.	New door stopper fixed		Rameshkumar. R. - Pharmacy	31/03/2023
	Comp. Dt. : 04/04/2023							
	Status : Completed							
2305	23040116	Pay Pharmacy	NEED REPAIRING WORK FOR KEY BOARD TRAY - STUCK	Ekambaram. K.	Key board refixed, work completed		Silambuselvan. P. - Pharmacy	19/04/2023
	Comp. Dt. : 06/05/2023							
	Status : Completed							
2306	23050242	Pay Pharmacy	NEED TO REMOVE / REARRANGE SHOWCASE GLASS	Ekambaram. K.	GLASS FIXED		Silambuselvan. P. - Pharmacy	17/05/2023
	Comp. Dt. : 23/06/2023							
	Status : Completed							
2307	23060882	Pay Pharmacy	NEED TO REFIX DOOR STOPER & SCREW	Ekambaram. K.	Door stopper fixed.		Silambuselvan. P. - Pharmacy	07/07/2023
	Comp. Dt. : 24/06/2023							
	Status : Completed							
2308	23060895	MEDICAL STORE IN BASEMENT	NEED REPAIRING WORK FOR DOOR STOPPER - STUCK	Ekambaram. K.	Door closer adjusted.		Selvan. A. - Pharmacy	07/07/2023
	Dept Name : Physical Education - Work Shop							
	Comp. Dt. : 19/01/2023							
	Status : Completed							

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2309	23010684	PLAY GROUND	NEED PAINTING WORK FOR FLAG HOISTING POST	Manimaran. A.	31Nos of Post painted, work completed		Vijayakumar. M. - Physical Education	30/01/2023
Dept Name : PHYSIOLOGY - Work Shop Comp. Dt. : 08/02/2023 Status : Completed								
2310	23020309	PHYSIOLOGY-- -COLLEGE	BEROW LOCK BROKEN	Ekambaram. K.	Bero lock repaired and serviced		Shanthini. M. - BIOCHEMISTRY	16/02/2023
Dept Name : Physiotherapy - Work Shop Comp. Dt. : 24/08/2022 Status : Completed								
2311	22080798	Physiotherapy	NEED TO FIX MESH FOR WINDOWS [3 NOS]	Ekambaram. K.,Venkatesan. R.,Sundaramoorthy. G.	3m SS mesh newly fixed.		Ezhilan.K. - Physiotherapy	09/09/2022
Comp. Dt. : 14/10/2022 Status : Completed								
2312	22100478	Physiotherapy	NEED WLEDING & REPAIRING WORK FOR PATIENT SITTING STEEL CHAIR	Sarathy. A.	Wheel fixed and welding work completed		Ezhilan.K. - Physiotherapy	21/10/2022
Comp. Dt. : 11/11/2022 Status : Completed								
2313	22110461	Physiotherapy	HOD SIR TABLE BROKEN-REPAIR WORK NEED TO DO	Ekambaram. K.	Table screw refixed, problem solved		Ezhilan.K. - Physiotherapy	18/11/2022
Comp. Dt. : 16/04/2023 Status : Completed								
2314	23040461	Physiotherapy	DUE TO PAINTING WORK REMOVED BOARD AND STRICKERS ARE NEED TO BE AGAIN REFIXED	Ekambaram. K.	BOARD REFIXED		Shyamala.P. - Physiotherapy	02/05/2023
Dept Name : PICU & NICU - Work Shop Comp. Dt. : 09/05/2022 Status : Completed								
2315	22050287	PICU	NEED REPAIRING WORK FOR BERO DOUBLE LOCK - PROBLEM	Ekambaram. K.	New padlock fixed, problem solved		Thirushayeni. A. - PICU & NICU	18/05/2022
Comp. Dt. : 19/05/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2316	22050717	NICU	NEED REPAIRING WORK FOR BERO LOCK - LOCK NOT WORKING	Pachaimuthusamy. D.	Lock repaired.		Parameswari. P. - PICU & NICU	18/06/2022
	Comp. Dt. : 05/07/2022							
	Status : Completed							
2317	22070171	NICU	WARMER WHEEL NOT WORKING	Sarathy. A.	Ward all wheel chairs wheel repaired and serviced, problem solved		Gobiya. G. - PICU & NICU	18/07/2022
	Comp. Dt. : 06/07/2022							
	Status : Completed							
2318	22070202	NICU	NEED REPAIRING WORK FOR " OUT DOOR"	Pachaimuthusamy. D.	Door repaired and serviced, problem solved		Gobiya. G. - PICU & NICU	20/07/2022
	Comp. Dt. : 13/07/2022							
	Status : Completed							
2319	22070503	PICU	NEED REPAIRING WORK FOR DOOR - SOUND PROBLEM	Ekambaram. K.	Door repaired and serviced, door lock changed, work completed		Vijayalakshmi. C. - PICU & NICU	01/08/2022
	Comp. Dt. : 19/10/2022							
	Status : Completed							
2320	22100650	NICU	WARMER MACHINE BOLT AND NUT LOOSE POSITION	Ekambaram. K.	Wheel refixed.		Parameswari. P. - PICU & NICU	29/10/2022
2321	22100651	NICU	WARMER WELDING WORK	Sarathy. A.	Work completed.		Sarumathi. A. - PICU & NICU	29/10/2022
	Comp. Dt. : 14/11/2022							
	Status : Completed							
2322	22110496	PICU	NEED TO FIX NAILS FOR FIXING NOTICE BOARD	Ekambaram. K.	Nail fixed.		Thirushayeni. A. - PICU & NICU	21/11/2022
	Comp. Dt. : 19/11/2022							
	Status : Completed							
2323	22110809	NICU	NEED PAINTING WORK FOR TABLES (3NOS)	Manimaran. A.	3Nos of Table painting work completed		Parameswari. P. - PICU & NICU	01/12/2022
	Comp. Dt. : 05/12/2022							
	Status : Completed							
2324	22120191	NICU	MAIN DOOR NOT CLOSING PROPERLY	Ekambaram. K.	Door repaired.		Revathy. I. - PICU & NICU	10/12/2022
	Comp. Dt. : 06/12/2022							
	Status : Completed							
2325	22120255	NICU	DOOR LOCK NEED TO BE REMOVE	Ekambaram. K.	Door lock removed, work completed		Parameswari. P. - PICU & NICU	19/12/2022

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 19/12/2022								
Status : Completed								
2326	22120850	NICU	HOT AND COLD WATER NEW STAND AND SCREW FIXING WORK	Sarathy. A.	New stand fixed, work completed		Parameswari. P. - PICU & NICU	30/12/2022
Comp. Dt. : 29/12/2022								
Status : Completed								
2327	22121338	PICU	BIOMEDICAL WASTAGE BOARD NEED TO BE REFIX	Ekambaram. K.	Biomedical waste board fixed, work completed		Sarumathi. A. - PICU & NICU	05/01/2023
Comp. Dt. : 02/01/2023								
Status : Completed								
2328	23010040	NICU	DUCT DOOR NEED TO BE CLOSE	Ekambaram. K.	Duct door closed, problem solved		Parameswari. P. - PICU & NICU	12/01/2023
Comp. Dt. : 03/01/2023								
Status : Completed								
2329	23010083	NEW NICU & PICU-2ND FLOOR	REQUEST TO FIX NEW LOCK AND KEY FOR REST ROOM	Ekambaram. K.	New Pad lock fixed, problem solved		Poovathal. K. - PICU & NICU	12/01/2023
Comp. Dt. : 09/01/2023								
Status : Completed								
2330	23010367	NEW NICU & PICU-2ND FLOOR	IN PICU-WHITE BOARD NEED TO BE FIX ON WALL	Ekambaram. K.	Board fixed, work completed		Poovathal. K. - PICU & NICU	23/01/2023
Comp. Dt. : 27/01/2023								
Status : Completed								
2331	23010959	NEW NICU & PICU-2ND FLOOR	IN PICU-INNER SIDE MAIN DOOR GLASS BROKEN,NEED TO CHANGE IT	Ekambaram. K.	New Glass fixed, work completed		Poovathal. K. - PICU & NICU	30/01/2023
2332	23010983	NICU	NEED TO REFIX REST ROOM DOOR LOCK [IN & OUT] 10 NOS - DAMAGE & BROKEN	Ekambaram. K.	10 Nos of 6" aldrop lock fixed, poblem solved		Poovathal. K. - PICU & NICU	30/01/2023
Comp. Dt. : 31/01/2023								
Status : Completed								
2333	23011114	RICU	NEED REPAIRING WORK FOR CARDIAC TABLE WHEEL - UNFIX	Sarathy. A.	Table wheel replaced, problem solved		Jenifer. S. - PICU & NICU	11/02/2023
Comp. Dt. : 04/02/2023								
Status : Completed								
2334	23020122	PICU	NEED TO REPASTE STRICKER FOR GLASS DOOR	Ekambaram. K.	Wrong complaint		Poovathal. K. - PICU & NICU	11/02/2023

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHAL KUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 15/02/2023 Status : Completed								
2335	23020589	NICU	NEED TO REMOVE MONITOR STAND	Ekambaram. K.	Stand removed		Parameswari. P. - PICU & NICU	17/02/2023
Comp. Dt. : 06/03/2023 Status : Completed								
2336	23030241	PICU	NEED TO PASTE STRICKER	Ekambaram. K.	Civil dept complaint, Inform to ward sister		Poovathal. K. - PICU & NICU	09/03/2023
Comp. Dt. : 24/04/2023 Status : Completed								
2337	23040742	PICU	NEED REPAIRING WORK FOR "SS" BIN - BROKEN	Ekambaram. K.	SS BIN REPAIRED		Umamaheswari. P. - PICU & NICU	02/05/2023
Comp. Dt. : 02/05/2023 Status : Completed								
2338	23050002	PICU	NEED REPAIRING WORK FOR MAIN DOOR HANDLE - BROKEN	Ekambaram. K.	WOKR COMPLETED		Umamaheswari. P. - PICU & NICU	17/05/2023
Comp. Dt. : 09/05/2023 Status : Completed								
2339	23050350	NICU	NEED TO CHANGE ROLLING CHAIR WHEEL - BROKEN	Ekambaram. K., Sundaramoorthy. G., Manivannan. A.	CHAIR WHEEL CHANGED.		Parameswari. P. - PICU & NICU	18/05/2023
Comp. Dt. : 18/05/2023 Status : Completed								
2340	23050775	NICU	NEED REPAIRING & PAINTING WORK FOR BERO	Manimaran. A., Viswa. V., Sundaramoorthy. K.	BERO PAINTED.		Sameetha. S. - PICU & NICU	01/06/2023
Comp. Dt. : 25/05/2023 Status : Completed								
2341	23051005	PICU	NEED PAINTING WORK FOR BERO	Manimaran. A.	BERO PAINTED		Vijayalakshmi. C. - PICU & NICU	03/06/2023
Comp. Dt. : 27/05/2023 Status : Completed								
2342	23051092	PICU	NEED REPAIRING WORK FOR DOOR LOCK FOR MAIN DOOR NO 2 & PATIENT RESTROOM DOOR	Ekambaram. K.	WORK COMPLETED		Divya. M. - PICU & NICU	03/06/2023
Comp. Dt. : 29/05/2023 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2343	23051161	PICU	NEED REPAIRING WORK FOR REST ROOM DOOR NO 2 - BROKEN	Ekambaram. K.	WORK COMPLETED		Divya. M. - PICU & NICU	03/06/2023
Comp. Dt. : 31/05/2023 Status : Completed								
2344	23051223	PICU	NEED REPAIRING AND PAINTING WORK FOR BERO [2NOS]	Manimaran. A.	Bero painted		Vinodhini. V. - PICU & NICU	20/06/2023
Comp. Dt. : 03/06/2023 Status : Completed								
2345	23060098	NICU	NEED BOARD ALTER WORK	Ekambaram. K.	Board fixed		Shenbagavalli. M. - PICU & NICU	20/06/2023
Comp. Dt. : 16/06/2023 Status : Completed								
2346	23060578	PICU & NICU	BOTH BOARD PAINTING WORK(1273)	Manimaran. A.	Baord name writing work completed		Sarumathi. A. - PICU & NICU	27/06/2023
Comp. Dt. : 21/06/2023 Status : Completed								
2347	23060750	PICU	NEED PAINTING WORK FOR " NAME BOARDS"	Ramesh. S.	Name written		Umamaheswari. P. - PICU & NICU	27/06/2023
Dept Name : POW & SICU - Work Shop Comp. Dt. : 10/05/2022 Status : Completed								
2348	22050322	POW & SICU	NEED REPAIRING WORK FOR REST ROOM DOOR LOCK & HANDLE AT MALE ORTHO	Ekambaram. K.	Rest room door and lock refixed, problem solved		Jamuna. K - POW & SICU	18/05/2022
Comp. Dt. : 11/05/2022 Status : Completed								
2349	22050379	SICU	3NOS COT FOOT BOARD BROKEN(1320)	Sarathy. A.	Cot footboard welded, problem solved		Muthulakshmi. A. - POW & SICU	26/05/2022
2350	22050380	SICU	CRASH CARD DRAW- OPEN CLOSER PROBLEM	Ekambaram. K.	Crash card draw service and repaired, problem solved		Muthulakshmi. A. - POW & SICU	18/05/2022
Comp. Dt. : 01/06/2022 Status : Completed								
2351	22060010	POW & SICU	NEED TO REFIX BUSH FOR IV STAND - WHEEL FOR - PATIENT STRUCTURE [3NOS], MEDICINE & DRESSING TROLLE	Sarathy. A.	Work completed. 5" wheel 8nos fixed. 4" wheel 4nos. fixed.		Jamuna. K - POW & SICU	10/06/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 14/06/2022								
Status : Completed								
2352	22060522	SICU	NEED TO CHECK ENTRANCE PARTITION DOOR - BROKENED	Pachaimuthusamy. D.	Door refixed in properly, problem solved		Dhivagar. K. - POW & SICU	01/07/2022
Comp. Dt. : 15/06/2022								
Status : Completed								
2353	22060562	POW & SICU	CRASH CART NOT WORKING + NEED A NEW STAND FOR PUTTING FILES NEAR NURSE'S CABIN	Ekambaram. K.	New Stand fixed, work completed		Jamuna. K - POW & SICU	01/07/2022
Comp. Dt. : 05/07/2022								
Status : Completed								
2354	22070172	POW & SICU	NEED TO SEAL AN AIR CONDITINER WINDOW GAP - NEED CEMNET WORK	Murugavel	Window gap filled with cement, problem solved		Jamuna. K - POW & SICU	18/07/2022
Comp. Dt. : 06/07/2022								
Status : Completed								
2355	22070213	POW & SICU	NEED REPAIRING WORK FOR DOORS [4 NOS]	Ekambaram. K.,Venkatesan. R.,Sundaramoorthy. G.	Door repairing work completed		Valarmathy. K. - POW & SICU	18/07/2022
2356	22070223	POW & SICU	NEED REPAIRING WORK FOR COT - BROKEN	Sarathy. A.	Cot repairing and service work, work completed		Jamuna. K - POW & SICU	18/07/2022
2357	22070225	POW & SICU	NEED TO FIX BUSH FOR IV STAND	Sarathy. A.	Bush fixed, problem solved		Praveena. E. - POW & SICU	18/07/2022
Comp. Dt. : 07/07/2022								
Status : Completed								
2358	22070285	POW & SICU	NEED TO REFIX SCREEN SPRING 15 NOS	Ekambaram. K.	Screen spring refixed, problem solved		Jamuna. K - POW & SICU	18/07/2022
Comp. Dt. : 08/07/2022								
Status : Completed								
2359	22070353	POW & SICU	FALSE CEILING THERMOCOL DAMAGE & FALLING DOWN	Pachaimuthusamy. D.,Manivannan. A.,Ekambaram. K.	False ceiling thermocol refixed, problem solved		Jamuna. K - POW & SICU	18/07/2022
Comp. Dt. : 26/07/2022								
Status : Completed								
2360	22070956	SICU	NEED TO REFIX MONITOR & REPAIRING WORK FOR DOOR - SOUND PROBLEM	Ekambaram. K.	Door repaired and serviced, refixed in properly, problem solved		Aruldevi. S. - POW & SICU	05/08/2022

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 02/08/2022								
Status : Completed								
2361	22080070	POW & SICU	NEED TO REFIX WHELL CHAIR WHEEL SAFETY BELT	Sarathy. A.	Wheel chair belt fixed, problem solved		Gayathri. K. - POW & SICU	08/08/2022
Comp. Dt. : 12/08/2022								
Status : Completed								
2362	22080453	POW & SICU	NEED REPAIRING WORK FOR DOOR STOPPER - SOUND & NOT CLOSING PROPER	Ekambaram. K.	New door stopper changed, problem solved		Pragadeesh. V. - POW & SICU	23/08/2022
Comp. Dt. : 17/08/2022								
Status : Completed								
2363	22080527	POW & SICU	1 NO.DRESSING TROLLY AND 3 NO'S COT WHEELS NEED TO BE CHANGE(SENDING TO WORKSHOP_-1320	Sarathy. A.	Dressing trolley and cot wheels are damaged, change the new wheel, problem solved		Arulmozhi. D. - POW & SICU	26/08/2022
2364	22080528	POW & SICU	BED SIDE SCREEN ROD REFIXING WORK NEED TO DO	Sarathy. A.	Screen rod fixed, problem solved		Arulmozhi. D. - POW & SICU	26/08/2022
Comp. Dt. : 23/08/2022								
Status : Completed								
2365	22080773	POW & SICU	NEED REPAIRING WORK FOR DOOR - PROBLEM IN CLOSING	Pachaimuthusamy. D.	New door stopper fixed, work completed		Jamuna. K - POW & SICU	01/09/2022
Comp. Dt. : 25/08/2022								
Status : Completed								
2366	22080849	POW & SICU	NEED TO REFIX COT SIDE RAILS & BUSG + STRUCTURE BUSH	Sarathy. A.	Work completed.		Jamuna. K - POW & SICU	09/09/2022
Comp. Dt. : 01/09/2022								
Status : Completed								
2367	22090056	POW & SICU	NEED REFIX BUSH & REPAIRING WORK FOR COT SIDE RAILS	Sarathy. A.	Bush fixed.		Pragadeesh. V. - POW & SICU	08/09/2022
Comp. Dt. : 08/09/2022								
Status : Completed								
2368	22090334	POW & SICU	NEED WELDING WORK FOR COT FOOT PATH	Sarathy. A.	Cot foot board welded and refixed, problem solved		Jamuna. K - POW & SICU	29/09/2022
Comp. Dt. : 10/09/2022								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
2369	22090402	POW & SICU	NEED REPAIRING WORK FOR FRIDGE STAND - BROKEN	Sarathy. A.	Wrong complaint		Jamuna. K - POW & SICU	29/09/2022
Comp. Dt. : 22/09/2022								
Status : Completed								
2370	22090895	POW & SICU	NEED STAND FOR KETTLE	Ekambaram. K., Sundaramoorthy. G., Venkatesan. R.	New stand fixed, problem solved		Jamuna. K - POW & SICU	06/12/2022
Comp. Dt. : 29/09/2022								
Status : Completed								
2371	22091155	POW & SICU	NEED TO FIX STAND FOR HOT WATER KETTLE & REPAIRING WORK FOR COT HEAD END - BROKEN	Sarathy. A., Sundaramoorthy. G., Ekambaram. K.	Stand fixed, cot head welding work completed		Arulmozhi. D. - POW & SICU	08/10/2022
2372	22091166	POW & SICU	NEED PAINTING WORK FOR RESTROOM	Manimaran. A.	Rest room fully painting work completed		Valarmathy. K. - POW & SICU	08/10/2022
Comp. Dt. : 10/10/2022								
Status : Completed								
2373	22100223	POW & SICU	NEED TO ADJUST MONITOR STAND	Ekambaram. K., Sundaramoorthy. G., Venkatesan. R.	Monitor stand repaired, problem solved		Jamuna. K - POW & SICU	12/10/2022
Comp. Dt. : 18/10/2022								
Status : Completed								
2374	22100575	POW & SICU	NEED TO REFIX COT HEAD END & WHEEL - COT 2NOS	Sarathy. A.	Work completed.		Valarmathy. K. - POW & SICU	29/10/2022
Comp. Dt. : 20/10/2022								
Status : Completed								
2375	22100687	POW & SICU	MASON WORK IN SEPTIC WARD REST ROOM	Murugavel	Work completed.		Jamuna. K - POW & SICU	29/10/2022
Comp. Dt. : 26/10/2022								
Status : Completed								
2376	22100802	POW & SICU	NEED TO FIX DOOR STOPPER	Ekambaram. K.	Door closer fixed.		Silambarasi. A. - POW & SICU	03/11/2022
Comp. Dt. : 28/10/2022								
Status : Completed								
2377	22100900	POW & SICU	WHEEL CHAIR WHEEL AND COT WHEEL PROBLEM-NEED TO BE REPAIR	Sarathy. A.	Work completed.		Lakshmi. R. - POW & SICU	03/11/2022
Comp. Dt. : 29/10/2022								

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
2378	22100944	POW & SICU	WALL TILES BROKEN - NEED TOUCH UP WORK	Murugavel	Tiles touch up work completed		Jamuna. K - POW & SICU	08/11/2022
2379	22100946	POW & SICU	NEED TO DOOR PAINTING WORK	Manimaran. A.	Door painting work completed		Jamuna. K - POW & SICU	06/12/2022
Comp. Dt. : 08/11/2022								
Status : Completed								
2380	22110289	POW & SICU	NEED TO PAINTING WORK FOR DOOR AND WALL	Manimaran. A.	Painting work completed		Pragadeesh. V. - POW & SICU	18/11/2022
Comp. Dt. : 15/11/2022								
Status : Completed								
2381	22110602	POW & SICU	SLIPPER STAND BROKEN-WELDING WORK NEED TO DO	Sarathy. A.	Stand welded.		Jamuna. K - POW & SICU	21/11/2022
Comp. Dt. : 17/11/2022								
Status : Completed								
2382	22110727	POW & SICU	BERO LOCK 2 NO'S NEED TO BE REPAIR AND HANDLE BROKEN	Ekambaram. K.	Bero lock repaired and serviced, handle refixed in properly, problem solved		Jamuna. K - POW & SICU	01/12/2022
2383	22110728	POW & SICU	DOOR STOPPER 4 NO'S NEED TO FIX	Ekambaram. K.	4Nos of door stopper fixed, problem solved		Jamuna. K - POW & SICU	01/12/2022
Comp. Dt. : 18/11/2022								
Status : Completed								
2384	22110774	POW & SICU	NEED TO REARRANGE MASK , SHOE SHELF & MULTI PURPOSE LOCK FOR CUPBOARD	Ekambaram. K.	Lock changed, problem solved		Jamuna. K - POW & SICU	01/12/2022
Comp. Dt. : 01/12/2022								
Status : Completed								
2385	22120049	POW & SICU	STERILLIUM STAND AND MULTIPLE LOCK NEED TO REFIX	Ekambaram. K.	New stand fixed.		Jamuna. K - POW & SICU	10/12/2022
Comp. Dt. : 03/12/2022								
Status : Completed								
2386	22120125	SICU	FUNGUS FORMING - NEED PAINTING WORK	Manimaran. A.	Fungus cleaned and painted.		Jamuna. K - POW & SICU	10/12/2022
Comp. Dt. : 29/12/2022								
Status : Completed								
2387	22121314	POW & SICU	NEED TO CHANGE MONITOR TROLLY WHEEL	Sarathy. A.	New wheel changed, problem solved		Jamuna. K - POW & SICU	05/01/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 04/01/2023 Status : Completed								
2388	23010174	POW & SICU	NEED TO FIX MULTIPURPOSE LOCK FOR CUPBOARD	Ekambaram. K.	4Nos of lock changed, problem solved		Jamuna. K - POW & SICU	23/01/2023
Comp. Dt. : 05/01/2023 Status : Completed								
2389	23010218	POW & SICU	WHEEL CHAIR WHEEL NEED TO BE REPAIR	Sarathy. A.	Wheel refixed.		Jamuna. K - POW & SICU	11/01/2023
Comp. Dt. : 20/01/2023 Status : Completed								
2390	23010735	POW & SICU	NEED TO REFIX SCREEN STAND & CLAMP	Ekambaram. K.	Clamp refixed		Jamuna. K - POW & SICU	30/01/2023
Comp. Dt. : 24/01/2023 Status : Completed								
2391	23010856	POW & SICU	NEED TO REFIX COT WHEEL 2 NOS - DAMAGE & BROKEN	Sarathy. A.	Cot wheel replaced, work completed		Praveena. E. - POW & SICU	30/01/2023
Comp. Dt. : 13/02/2023 Status : Completed								
2392	23020451	POW & SICU	NEED TO CHANGE COT WHEEL 4 NOS	Sarathy. A.	new cot wheel 4Nos repalced		Arunkumar. D. - POW & SICU	17/02/2023
Comp. Dt. : 16/02/2023 Status : Completed								
2393	23020610	SICU	NEED WATER DISPENSER STAND	Ekambaram. K.	New stand fixed, work completed		Jamuna. K - POW & SICU	08/03/2023
Comp. Dt. : 22/02/2023 Status : Completed								
2394	23020847	POW & SICU	NEED TO FIX APRON STAND 3NOS	Ekambaram. K.	Stand fixed, work completed		Jamuna. K - POW & SICU	01/03/2023
Comp. Dt. : 23/02/2023 Status : Completed								
2395	23020896	POW & SICU	NEED REPAIRING WORK FOR VENTILATOR WHEEL - STUCK	Sarathy. A.	Wheel fixed, work completed		Jamuna. K - POW & SICU	01/03/2023
Comp. Dt. : 28/02/2023 Status : Completed								
2396	23021050	SICU	ONE BATHROOM LOCK BROKEN.	Ekambaram. K.	LOCK FIXED.		Jamuna. K - POW & SICU	07/03/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 01/03/2023								
Status : Completed								
2397	23030034	POW & SICU	NEED TO FIX NAILS	Ekambaram. K.	Board fixed		Jamuna. K - POW & SICU	09/03/2023
Comp. Dt. : 02/03/2023								
Status : Completed								
2398	23030083	POW & SICU	NEED TO FIX GOWN RACK STAND [2NOS]	Ekambaram. K.	Rack stand fixed		Jamuna. K - POW & SICU	09/03/2023
Comp. Dt. : 06/03/2023								
Status : Completed								
2399	23030210	POW & SICU	NEED TO REFIX DOOR STOPPER	Ekambaram. K.	New door stopper changed		Silambarasi. A. - POW & SICU	09/03/2023
Comp. Dt. : 10/03/2023								
Status : Completed								
2400	23030423	POW & SICU	TILES BROKEN - NEED TOUCHUP WORK AT RESTROOM [2NOS]	Parivallal. P.	WORK COMPLETED		Jamuna. K - POW & SICU	23/03/2023
Comp. Dt. : 15/03/2023								
Status : Completed								
2401	23030589	SICU	NEED REPAIRING WORK FOR COT - FOOT END SHEET BROKEN - NEED URGENT SERVICE	Sarathy. A.	WORK COMPLETED		Lakshmi. R. - POW & SICU	23/03/2023
Comp. Dt. : 16/03/2023								
Status : Completed								
2402	23030674	POW & SICU	NEED REPAIRING WORK FOR TABLE - BROKEN	Ekambaram. K.	WORK COMPLETED		Jamuna. K - POW & SICU	23/03/2023
2403	23030675	POW & SICU	NEED TO REFIX MONITOR STAND	Ekambaram. K.	WORK COMPLETED		Jamuna. K - POW & SICU	23/03/2023
Comp. Dt. : 18/03/2023								
Status : Completed								
2404	23030753	POW & SICU	NEED REPAIRING WORK FOR RESTROOM DOOR LOCK 2NOS	Ekambaram. K.	Door lock repaired and refixed		Jamuna. K - POW & SICU	31/03/2023
Comp. Dt. : 21/03/2023								
Status : Completed								
2405	23030874	POW & SICU	NEED TO REFIX COT & WHEEL CHAIR WHEEL 2NOS & COT SIDE RAILS 5NOS + MONITOR STAND	Sarathy. A.	Cot, wheel chair and monitor stand refixed		Gunavathi. G. - POW & SICU	31/03/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
2406	23031049	POW & SICU	NEED TO REFIX MONITOR STAND 6 NOS	Ekambaram. K.,Sundaramoorthy. G.,Veerappan. D.	WORK COMPLETED		Jamuna. K - POW & SICU	01/04/2023
2407	23031050	POW & SICU	NEED REPAIRING WORK FOR COT FOOT END	Sarathy. A.	WORK COMPLETED		Jamuna. K - POW & SICU	01/04/2023
Comp. Dt. : 28/03/2023								
Status : Completed								
2408	23031158	POW & SICU	NEED REPAIRING WORK FOR COT - BEND	Sarathy. A.	Cot leg repaired and serviced, problem solved		Jamuna. K - POW & SICU	13/04/2023
Comp. Dt. : 04/04/2023								
Status : Completed								
2409	23040114	POW & SICU	NEED REPAIRING WORK FOR COT WHEEL - STUCK	Sarathy. A.	Cot wheel replaced, problem solved		Jamuna. K - POW & SICU	19/04/2023
2410	23040122	SICU	TILES BROKEN NEED TOUCHUP WORK AT RESTROOM	Parivallal. P.	TILE FIXED.		Arulmozhi. D. - POW & SICU	05/05/2023
Comp. Dt. : 06/04/2023								
Status : Completed								
2411	23040203	POW & SICU	NEED PAINTING WORK - 2 ROOMS [FUNGUS FORMED]	Manimaran. A.	Fungus removed, painting work completed		Jamuna. K - POW & SICU	20/04/2023
Comp. Dt. : 11/04/2023								
Status : Completed								
2412	23040300	NICU	NEED TO REFIX PATLOCK FOR DOCTOR'S ROOM	Ekambaram. K.	New Padlock fixed		Renugadevi. J. - POW & SICU	20/04/2023
Comp. Dt. : 13/04/2023								
Status : Completed								
2413	23040418	POW & SICU	NEED PAINTING WORK FOR FULL ROOM	Manimaran. A.	Painting work completed		Jamuna. K - POW & SICU	20/04/2023
Comp. Dt. : 25/04/2023								
Status : Completed								
2414	23040833	POW & SICU	NEED TO FIT SCREEN RODS FOR 3 ROOMS	Ekambaram. K.	SCREEN ROD FIXED		Arulmozhi. D. - POW & SICU	17/05/2023
Comp. Dt. : 04/05/2023								
Status : Completed								
2415	23050180	POW & SICU	NEED REPAIRING WORK FOR COT - SEPTIC WARD	Ekambaram. K.	COT REPAIRED		Aruldevi. S. - POW & SICU	17/05/2023
Comp. Dt. : 18/05/2023								
Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2416	23050730	POW & SICU	NEED TO REFIX WHEEL FOR VENTILATOR MACHINE & COT 10 NOS	Ekambaram. K.,Sundaramoorthy. G.,Sarathy. A.	WHEEL REPLACED.		Jayapradha. J. - POW & SICU	01/06/2023
Comp. Dt. : 22/05/2023 Status : Completed								
2417	23050876	POW & SICU	NEED TO CHECK ALL ROOM WINDOW DOORS & DOORS - STUCK	Ekambaram. K.	WORK COMPLETED		Jamuna. K - POW & SICU	01/06/2023
Comp. Dt. : 23/05/2023 Status : Completed								
2418	23050900	POW & SICU	NEED TO CHANGE WHEEL FOR STRETCHER - STUCK	Sarathy. A.	6 NOS STRETCHER WHEEL CHANGED.		Jamuna. K - POW & SICU	03/06/2023
Comp. Dt. : 05/06/2023 Status : Completed								
2419	23060145	POW & SICU	NEED TO REFIX SCREEN CLAMP	Ekambaram. K.	Clamp fixed		Jamuna. K - POW & SICU	20/06/2023
Comp. Dt. : 14/06/2023 Status : Completed								
2420	23060517	POW & SICU	NEED TO REFIX BUSH FOR BED SIDE LOCKERS [5NOS]	Ekambaram. K.	bush fixed.		Jamuna. K - POW & SICU	05/08/2023
Comp. Dt. : 28/06/2023 Status : Completed								
2421	23061052	POW & SICU	NEED TO CHANGE & REPAIRING WORK FOR MONITOR STAND & STANDING STAND +COT & STRETCHER WHEEL [TOTAL 1	Ekambaram. K.,Sundaramoorthy. G.,Ganesh. S.	Work completed		Jamuna. K - POW & SICU	08/07/2023
Dept Name : Power Laundry - Work Shop Comp. Dt. : 11/05/2022 Status : Completed								
2422	22050395	LAUNDRY	NEED TO TIGHTEN DRYER PLAY WHEEL	Sarathy. A.	Fly wheel refixed in properly, now problem solved		Manikandan.M - Power Laundry	18/05/2022
Comp. Dt. : 13/05/2022 Status : Completed								
2423	22050455	Power Laundry	DRYER PLAY WHEEL LOOSE POSITION.		Dryer flywheel welded and refixed, problem solved		Manikandan.M - Power Laundry	27/05/2022
Comp. Dt. : 19/05/2022								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
2424	22050697	LAUNDRY	NEED TO SHIFT CLOTH DRYING PIPELINE TO ANOTHER PLACE	Pachaimuthusamy. D.	Wrong complaint		Manikandan.M - Power Laundry	28/05/2022
Comp. Dt. : 26/05/2022								
Status : Completed								
2425	22050989	LAUNDRY	NEED REPAIRING WORK FOR TROLLEY WHEEL [DRESS TROLLEY]	Sarathy. A.	Bed welded		Manikandan.M - Power Laundry	10/06/2022
Comp. Dt. : 06/06/2022								
Status : Completed								
2426	22060200	LAUNDRY	WASHING MACHINE - NO 1 MAIN BEARING SOUND PROBLEM	Sarathy. A.	work completed		Manikandan.M - Power Laundry	20/07/2022
Comp. Dt. : 15/06/2022								
Status : Completed								
2427	22060573	LAUNDRY	NEED WELDING WORK FOR OT TROLLEY	Sarathy. A.	Trolley handle welding work completed		Manikandan.M - Power Laundry	01/07/2022
Comp. Dt. : 11/07/2022								
Status : Completed								
2428	22070404	LAUNDRY	NEED WELDING WORK FOR PLAY WHEEL FOR DRIYER NO 1	Sarathy. A.	Flywheel shaft refixed.		Manikandan.M - Power Laundry	24/09/2022
Comp. Dt. : 02/08/2022								
Status : Completed								
2429	22080078	LAUNDRY	NEED WELDING WORK FOR ROOM DRYER	Moorthy. L.	Welding work completed		Manikandan.M - Power Laundry	08/08/2022
2430	22080079	LAUNDRY	NEED TO CHECK WALL - WATER LEAKAGE AT EXTENTION LAUNDRY	Sankar. T. M.	Wall sepage problem, cement pointing work done, now leakage arrested, problem solved		Manikandan.M - Power Laundry	08/08/2022
Comp. Dt. : 13/08/2022								
Status : Completed								
2431	22080465	Power Laundry	NEED REPAIRING WORK & GENERAL SERVICE FOR TROLLEY	Sarathy. A.	Trolley wheel repaired and serviced, problem solved		Punnamurthy. R - Power Laundry	23/08/2022
Comp. Dt. : 14/09/2022								
Status : Completed								
2432	22090516	LAUNDRY	NEED TO CHECK WASHING MACHINE 1 - PLAY WHEEL PROBLEM	Sarathy. A.	Washing machine new belt and play wheel changed, problem solved		Manikandan.M - Power Laundry	29/09/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 26/09/2022 Status : Completed								
2433	22090998	LAUNDRY	SOIL TROLLEY CENTRALIZED BEARING DAMAGE	Sarathy. A.	Soil trolley wheel repaired, problem solved		Manikandan.M - Power Laundry	08/10/2022
Comp. Dt. : 10/10/2022 Status : Completed								
2434	22100250	LAUNDRY	NEED REPAIRING AND SERVICE FOR TROLLEY - 4 WHEELS DAMAGED & BROKEN	Sarathy. A.	Trolley wheels changed, problem solved		Manikandan.M - Power Laundry	06/12/2022
Comp. Dt. : 18/10/2022 Status : Completed								
2435	22100602	LAUNDRY	DRYER 3 BOLD NNED TO CUT	Sarathy. A.,Sundaramoorthy. G.,Moorthy. L.	Bolt removed, problem solved		Manikandan.M - Power Laundry	06/12/2022
2436	22100616	LAUNDRY	DRYER 3 MESH WELDING WORK	Sarathy. A.	New mesh fixed.		Manikandan.M - Power Laundry	29/10/2022
Comp. Dt. : 28/10/2022 Status : Completed								
2437	22100930	Power Laundry	WASHING MACHINE NO.2 DRUM ALIGNMENT WORK NEED TO DO	Ekambaram. K.	Drum alignment work completed		Manikandan.M - Power Laundry	06/12/2022
Comp. Dt. : 17/11/2022 Status : Completed								
2438	22110701	Power Laundry	WASHING MACHINE NO.1 NOT WORKING	Ganesan. A.	Washing machine serviced, problem solved		Manikandan.M - Power Laundry	01/12/2022
Comp. Dt. : 21/11/2022 Status : Completed								
2439	22110880	Power Laundry	TROLLY WHEEL NEED TO BE REPAIR	Sarathy. A.	Trolleey wheel changed, problem solved		Manikandan.M - Power Laundry	01/12/2022
Comp. Dt. : 21/01/2023 Status : Completed								
2440	23010771	LAUNDRY	NEED WELDING WORK FOR LAUNDARY TROLLEY	Sarathy. A.	Trolley handle welded, work completed		Punniamurthy. R - Power Laundry	30/01/2023
Comp. Dt. : 02/02/2023 Status : Completed								
2441	23020070	LAUNDRY	NEED MASON WORK FOR FLOOR & CHAMBER	Murugavel	Mason work completed		Punniamurthy. R - Power Laundry	11/02/2023
Comp. Dt. : 17/02/2023								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
2442	23020710	LAUNDRY	NEED REPAIRING WORK FOR TROLLEY WHEEL	Sarathy. A.	Trolley wheel repaired and refixed, problem solved		Punnamurthy. R - Power Laundry	23/02/2023
Comp. Dt. : 21/02/2023								
Status : Completed								
2443	23020820	LAUNDRY	NEED REPAIRING WORK FOR TROLLEY WHEEL	Sarathy. A.	Trolley wheel refixed, work completed		Manikandan.M - Power Laundry	01/03/2023
Comp. Dt. : 25/02/2023								
Status : Completed								
2444	23020973	LAUNDRY	NED REPAIRING WORK FOR LAUNDRY TROLLEY WHEEL BEARING - CUT	Sarathy. A.	TROLLEY WHEEL REPAIRED.		Manikandan.M - Power Laundry	07/03/2023
Comp. Dt. : 13/04/2023								
Status : Completed								
2445	23040410	LAUNDRY	TROLLEY PLAY WHEEL BEARING	Sarathy. A.	WHEEL REPAIRED		Manikandan.M - Power Laundry	17/05/2023
Comp. Dt. : 08/05/2023								
Status : Completed								
2446	23050306	LAUNDRY	NEED TO FIX "SOIL CLOSED TROLLEY DOOR	Ekambaram. K.	Work completed		Manikandan.M - Power Laundry	05/08/2023
2447	23050307	LAUNDRY	NEED TO FIX " BIO MEDICAL WASTE" BOARD	Ekambaram. K.	BOARD FIXED		Manikandan.M - Power Laundry	18/05/2023
Comp. Dt. : 18/05/2023								
Status : Completed								
2448	23050751	LAUNDRY	NEED TROLLEY SERVICE & REPAIRING WORK	Sarathy. A.	NEW BEARING (8NOS) CHANGED.		Punnamurthy. R - Power Laundry	01/06/2023
Comp. Dt. : 19/05/2023								
Status : Completed								
2449	23050822	LAUNDRY	NEED WELDING WORK FOR SAIL TROLLEY	Sarathy. A., Manivannan. A., Moorthy. L.	TROLLEY WELDED		Manikandan.M - Power Laundry	01/06/2023
Dept Name : Printing Press - Work Shop								
Comp. Dt. : 12/08/2022								
Status : Completed								
2450	22080435	Printing Press	NEED A WOODEN BOX FOR KEPT PLATES	Ekambaram. K.	New box made and issued.		Vijayasekar. K. - Printing Press	24/09/2022
Comp. Dt. : 12/12/2022								
Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2451	22120556	Printing Press	5 NO'S RACK GOT DAMAGED,REPAIR WORK NEED TO DO	Ekambaram. K.	Rack shelf repaired, problem solved		Shanmugam. R. - Printing Press	19/12/2022
Comp. Dt. : 18/01/2023 Status : Completed								
2452	23010611	Work Shop	NEED REPAIRING & SERVICE FOR TRICYCLE	Ekambaram. K.	New Tyre 2Nos fixed, painted the tricycle, work completed		Shanmugam. R. - Printing Press	30/01/2023
Dept Name : Quality Department - Work Shop Comp. Dt. : 19/05/2022 Status : Completed								
2453	22050701	NAC OFFICE 4TH FLOOR	NEED TO REFIX DOOR CLOSER - DAMAGE & NOT WORKING	Ekambaram. K.	Door closer adjusted and serviced, problem solved		Suganthi. M. - Quality Department	28/05/2022
Comp. Dt. : 16/06/2022 Status : Completed								
2454	22060602	NAC OFFICE 4TH FLOOR	NEED CARPENTER HELP FOR OFFICE ROOM ARRANGEMENT	Ekambaram. K.	Holes drilling work completed		Suganthi. M. - Quality Department	01/07/2022
Dept Name : Radio Diagnosis - Work Shop Comp. Dt. : 10/05/2022 Status : Completed								
2455	22050356	MRI	NEED REPAIRING WORK FOR DOOR - LOCK AND DOOR STOPPER NOT WORKING	Ekambaram. K.	Door and lock repaired, door stopper refixed, problem solved		Sivabalan. P. - Radio Diagnosis	18/05/2022
Comp. Dt. : 17/05/2022 Status : Completed								
2456	22050611	XRy	NEED REPAIRING WORK FOR REST ROOM DOOR LOCK - BROKEN	Pachaimuthusamy. D.	Door repaired and serviced, door lock changed, problem solved		Thamizhpandiyan. G - Radio Diagnosis	27/05/2022
Comp. Dt. : 23/05/2022 Status : Completed								
2457	22050844	MRI	NEED TO REFIX MAIN DOOR - DOOR STOPPER	Pachaimuthusamy. D.	Door stopper fixed, problem solved		Dayalan. E - Radio Diagnosis	28/05/2022
Comp. Dt. : 01/06/2022 Status : Completed								
2458	22060040	CT Scan	NEED TO REFIX DOOR HANDLE - BROKENED - BASEMENT CT - NEED URGENT SERVICE	Pachaimuthusamy. D.	Handle fixed.		Dayalan. E - Radio Diagnosis	10/06/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 09/07/2022 Status : Completed								
2459	22070398	CT Scan	NEED REPAIRING WORK FOR DOOR & LOCK - NOT WORKING	Ekambaram. K.	Door and lock repaired and serviced, problem solved		Mahendran.V. - Radio Diagnosis	20/07/2022
Comp. Dt. : 21/07/2022 Status : Completed								
2460	22070793	BASEMENT SCAN	NEED REPAIRING WORK FOR DOOR - SOUND PROBLEM	Ekambaram. K.	Door repaired and serviced, problem solved		Sangeetha. S. - Radio Diagnosis	01/08/2022
Comp. Dt. : 22/08/2022 Status : Completed								
2461	22080701	XRy	NEED REPAIRING WORK FOR FEMALE RESTROOM DOOR AT BASEMENT - DEMAGE & BROKEN	Ekambaram. K.	Door repaired and serviced, problem solved		Manikandan.V. - Radio Diagnosis	01/09/2022
Comp. Dt. : 24/08/2022 Status : Completed								
2462	22080792	CT Scan	NEED REPAIRING WORK FOR DOOR - PROBLEM IN CLOSING	Ekambaram. K.	Door repaired.		Mahendran.V. - Radio Diagnosis	09/09/2022
Comp. Dt. : 21/09/2022 Status : Completed								
2463	22090807	CT Scan	NEED TO REFIX DOOR CLOSER - NOT WORKING	Ekambaram. K.	New door changed, work completed		Mahendran.V. - Radio Diagnosis	29/09/2022
Comp. Dt. : 28/09/2022 Status : Completed								
2464	22091143	XRy	NEED TO REFIX PATLOCK	Ekambaram. K.	Padlock fixed, problem solved		Manikandan.V. - Radio Diagnosis	08/10/2022
Comp. Dt. : 30/09/2022 Status : Completed								
2465	22091224	BASEMENT SCAN	NEED PAINTING WORK FOR BASEMENT SCAN ROOM 1,2,& 3	Manimaran. A.	All room painting work completed		Abirami. P. - Radio Diagnosis	08/10/2022
2466	22091225	MRI	NEED TO REFIX DOOR STOPPER - DAMAGE & BROKEN	Ekambaram. K.	New Door closer fixed, problem solved		Mahendran.V. - Radio Diagnosis	12/10/2022
Comp. Dt. : 06/10/2022 Status : Completed								
2467	22100083	XRy	NEED TO REFIX DOOR STOPPER FOR ROOM NO 3	Ekambaram. K.	New Door stopper fixed, problem solved		Manikandan.V. - Radio Diagnosis	12/10/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2468	22100087	SCAN - GROUND FLOOR - BLOOD BANK OPP	NEED PAINTING WORK FOR CEILING	Manimaran. A.	Ceiling cleaned and painting work completed		Abirami. P. - Radio Diagnosis	12/10/2022
	Comp. Dt. : 15/10/2022							
	Status : Completed							
2469	22100493	CT Scan	DOOR HANDLE BROKEN (BASEMENT)	Ekambaram. K.	Door handle fixed, problem solved		Abirami. P. - Radio Diagnosis	21/10/2022
	Comp. Dt. : 17/10/2022							
	Status : Completed							
2470	22100506	CT Scan	NEED TO REFIX DOOR HANDLE - HANDLE BROKEN	Ekambaram. K.	Handle fixed.		Mahendran.V. - Radio Diagnosis	29/10/2022
	Comp. Dt. : 03/11/2022							
	Status : Completed							
2471	22110091	RADIOLOGY	IN DEMO ROOM-PAINTING WORK NEED TO DO	Manimaran. A.	Painting work completed		Abirami. P. - Radio Diagnosis	16/11/2022
	Comp. Dt. : 09/11/2022							
	Status : Completed							
2472	22110339	RADIOLOGY	PATIENT WAITING AREA CHAIR NEED TO DO PAINTING WORK	Manimaran. A.	Chair painted, work completed		Sangeetha. S. - Radio Diagnosis	18/11/2022
	Comp. Dt. : 19/11/2022							
	Status : Completed							
2473	22110820	RADIOLOGY	DOOR GET DOWN-NEED TO BE REPAIR	Ekambaram. K.	Door repaired and refixed in properly, problem solved		Manikandan. G. - Radio Diagnosis	01/12/2022
	Comp. Dt. : 28/11/2022							
	Status : Completed							
2474	22111196	RADIOLOGY	IN USG ROOM-DOOR NEED TO BE REPAIR	Ekambaram. K.	Door repaired and serviced, problem solved		Abirami. P. - Radio Diagnosis	06/12/2022
	Comp. Dt. : 12/12/2022							
	Status : Completed							
2475	22120552	SCAN - GROUND FLOOR - BLOOD BANK OPP	MAIN DOOR NEED TO BE REPAIR,NOT CLOSING PROPERLY	Ekambaram. K.	Door repaired and serviced, door closer changed, problem solved		Sudha. D - Radio Diagnosis	19/12/2022
	Comp. Dt. : 13/12/2022							
	Status : Completed							
2476	22120598	CT Scan	NEED CARPENTER FOR FIXING SCREEN 2 NOS	Ekambaram. K.	Door closer fixed.		Adilakshmi. T. - Radio Diagnosis	23/12/2022

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 14/12/2022								
Status : Completed								
2477	22120626	XRay	NEED REPAIRING WORK FOR DOOR - BROKEN - ROOM NO 8	Ekambaram. K.	New wall hinges fixed.		Manikandan.V. - Radio Diagnosis	23/12/2022
2478	22120653	SCAN - GROUND FLOOR - BLOOD BANK OPP	NEED REPAIRING WORK FOR DOOR - STUCK PROBLEM	Ekambaram. K.	Work completed.		Kanimozhi. D. - Radio Diagnosis	23/12/2022
Comp. Dt. : 15/12/2022								
Status : Completed								
2479	22120700	SCAN - GROUND FLOOR - BLOOD BANK OPP	NEED REPAIRING WORK FOR DOOR - SOUND & NOT CLOSING	Ekambaram. K.	New door closer fixed, problem solved		Sudha. D - Radio Diagnosis	23/12/2022
Comp. Dt. : 24/12/2022								
Status : Completed								
2480	22121106	XRay	NEED TO FIX DOOR CLOSER	Ekambaram. K.	New door closer changed, problem solved		Manikandan.V. - Radio Diagnosis	02/01/2023
2481	22121119	RADIOLOGY	ROLLING CHAIR NEED TO BE REPAIR	Sarathy. A.	Chair repaired, problem solved		Abirami. P. - Radio Diagnosis	23/01/2023
Comp. Dt. : 17/02/2023								
Status : Completed								
2482	23020702	BASEMENT SCAN	NEED WELDING WORK FOR BOOK RACK	Sarathy. A.	Book rack welding work completed		Abirami. P. - Radio Diagnosis	23/02/2023
Comp. Dt. : 15/03/2023								
Status : Completed								
2483	23030591	SCAN - GROUND FLOOR - BLOOD BANK OPP	NEED TO REFIX " NAME BOARD "	Ekambaram. K.	BOARD FIXED.		Abirami. P. - Radio Diagnosis	23/03/2023
Comp. Dt. : 24/03/2023								
Status : Completed								
2484	23031027	XRay	NEED TO FIX BOARDS	Ekambaram. K.	BOARD 40 NOS. FIXED.		Manikandan.V. - Radio Diagnosis	01/04/2023
Comp. Dt. : 22/04/2023								
Status : Completed								
2485	23040712	SCAN - GROUND FLOOR - BLOOD BANK OPP	NEED TO REFIX / REARRANGE AC LINE WOODEN BOX	Ekambaram. K.	WORK COMPLETED		Sudha. D - Radio Diagnosis	02/05/2023
Comp. Dt. : 28/04/2023								
Status : Completed								
2486	23040984	CT Scan	NEED REPAIRING WORK FOR DOOR LOCK - STUCK	Ekambaram. K.	Door dismantled and refixed the door, problem solved		Manikandan.V. - Radio Diagnosis	08/05/2023

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHAL KUPPAM
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 20/06/2023 Status : Completed								
2487	23060723	XRay	NEED TO REFIT DOOR STOPPER FOR MAIN DOOR - NEW X RAY ROOM NEAR MRD	Ekambaram. K.	Work completed		Manikandan.V. - Radio Diagnosis	27/06/2023
Dept Name : Reception - Work Shop Comp. Dt. : 02/06/2022 Status : Completed								
2488	22060054	CASHCOUNTER IN RECEPTION	TABLE DRAW - STUCK	Pachaimuthusamy. D.	draw repaired.		Ranjithkumar. P. - Reception	10/06/2022
Comp. Dt. : 04/06/2022 Status : Completed								
2489	22060150	CASHCOUNTER IN RECEPTION	NEED REPAIRING WORK FOR CASH DRAW - NOT CLOSING PROPER - NEED URGENT SERVICE	Ekambaram. K.	New telescopic wheel fixed.		Ranjithkumar. P. - Reception	10/06/2022
Comp. Dt. : 25/08/2022 Status : Completed								
2490	22080822	CASHCOUNTER IN RECEPTION	NEED REPAIRING WORK FOR CASH TABLE DRAW LOCK - NEED URGENT SERVICE	Ekambaram. K.	Drawer refixed.		Ranjithkumar. P. - Reception	09/09/2022
Comp. Dt. : 05/09/2022 Status : Completed								
2491	22090156	CASHCOUNTER IN RECEPTION	NEED REPAIRING WORK FOR CASH TABLE DRAW - SO DIFFICULT FOR PUTTING CASH	Parthiban.K.	Drawer repaired.		Ranjithkumar. P. - Reception	24/09/2022
Comp. Dt. : 20/04/2023 Status : Completed								
2492	23040648	Reception	NEED TO CHECK FALSE CEILING - BORKEN - AND FAN HANGS OFF - COUNTER NO 10	Ekambaram. K.,Sundaramoorthy. G.,Pachaimuthusamy . D.	FALSE CEILING REFIXED		Sankari. K. - Reception	02/05/2023
Dept Name : RICU - Work Shop Comp. Dt. : 09/05/2022 Status : Completed								
2493	22050309	RICU	NEED REPAIRING WORK FOR DOOR - SOUND PROBLEM	Pachaimuthusamy. D.	New door closer refixed, problem solved		Sheela. B. - RICU	18/05/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 06/06/2022 Status : Completed								
2494	22060232	RICU	Need repairing work for cardiac table and cot wheel not working	Sarathy. A.,Ekambaram. K.,Sundaramoorthy. G.	5" wheel 6nos fixed. Cardiac table wheel replaced.		Deva @ Devanathan. P. - RICU	10/06/2022
Comp. Dt. : 16/06/2022 Status : Completed								
2495	22060620	RICU	NEED REPAIRING WORK FOR NURSE'S CABIN DOOR LOCK - LOCK BROKEND	Pachaimuthusamy. D.	Door lock repaired and serviced, problem solved		Tamililakkiya. K. - RICU	01/07/2022
Comp. Dt. : 13/07/2022 Status : Completed								
2496	22070496	RICU	NEED TO SET A NEW CHAMBER FOR RESTROOM -- RESTROOM WATER COMING INSIDE	Murugavel	New Chamber built, work completed		Deva @ Devanathan. P. - RICU	01/08/2022
Comp. Dt. : 20/08/2022 Status : Completed								
2497	22080672	RICU	NEED TO REFIX PATLOCK FOR RESTROOM DOOR	Ekambaram. K.	New padlock fixed, problem solved		Tamililakkiya. K. - RICU	26/08/2022
Comp. Dt. : 24/08/2022 Status : Completed								
2498	22080799	RICU	NEED TO REFIX SIDE RAILS	Sarathy. A.	Side rail fixed.		Tamililakkiya. K. - RICU	09/09/2022
Comp. Dt. : 01/09/2022 Status : Completed								
2499	22090006	RICU	NEED TO REFIX COT SIDE RAILS	Sarathy. A.	Side nail fixed.		Abirami. J. - RICU	08/09/2022
Comp. Dt. : 15/09/2022 Status : Completed								
2500	22090590*	RICU	NEED TO FIX MULTIPARA MONITOR STAND	Sarathy. A.	Monitor stand fixed, problem solved		Tamililakkiya. K. - RICU	20/10/2022
Comp. Dt. : 11/10/2022 Status : Completed								
2501	22100289	RICU	NEED TO REFIX MAIN ENTRANCE DOOR HANDLE - BROKEN	Ekambaram. K.	Door handle fixed, problem solved		Tamililakkiya. K. - RICU	12/10/2022
Comp. Dt. : 18/10/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2502	22100595	RICU	NEED TO REFIX PATIENT BED SIDE RAILS - NEED URGENT SERVICE	Sarathy. A.	Side rail fixed.		Tamililakkiya. K. - RICU	29/10/2022
Comp. Dt. : 14/11/2022 Status : Completed								
2503	22110556	RICU	CAN CUTTING WORK NEED TO DO FOR SOME MEDICINE FIXING PURPOSE	Sarathy. A.	Work completed.		Tamililakkiya. K. - RICU	21/11/2022
Comp. Dt. : 05/12/2022 Status : Completed								
2504	22120181	RICU	VENTILATOR TROLLY WHEEL NEED TO BE REPAIR	Ekambaram. K.	Side rail fixed.		Silambarasan. S. - RICU	10/12/2022
Comp. Dt. : 12/01/2023 Status : Completed								
2505	23010534	RICU	NEED TO FIX COT WHEEL & SIDE RAILING	Sarathy. A.	Side rail refixed in properly, problem solved		Nanthini. M. - RICU	30/01/2023
Comp. Dt. : 13/02/2023 Status : Completed								
2506	23020498	ICU	NEED REPAIRING WORK FOR DOOR CLOSER - BROKEN AT EXTN ICU	Ekambaram. K.	Door closer adjusted, problem solved		Susila. M. - RICU	17/02/2023
Comp. Dt. : 21/02/2023 Status : Completed								
2507	23020803	RICU	NEED PAINTING WORK FOR FOOT STOOL	Manimaran. A.	Stool painting work completed		Tamililakkiya. K. - RICU	01/03/2023
Comp. Dt. : 27/02/2023 Status : Completed								
2508	23021036	RICU	NEED REPAIRING WORK FOR FOOT STOOL - BROKEN	Ekambaram. K.	FOOT STOOL REPAIRED.		Tamililakkiya. K. - RICU	07/03/2023
Comp. Dt. : 14/03/2023 Status : Completed								
2509	23030531	RICU	NEED REPAIRING WORK FOR CARTIAC TABLE WHEEL - STUCK	Sarathy. A.	TABLE WHEEL REPLACED		Tamililakkiya. K. - RICU	23/03/2023
2510	23030539	RICU	TILES BROKEN - NEED TOUCH UP WORK	Parivallal. P.	TILES REFIXED		Tamililakkiya. K. - RICU	23/03/2023
Comp. Dt. : 30/03/2023 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2511	23031279	RICU	NEED REPAIRING & WELDING WORK FOR COT FOOT END - BROKEN	Sarathy. A.,Moorthy. L.,Manivannan. A.	Cot leg welded, work completed		Silambarasan. S. - RICU	13/04/2023
Comp. Dt. : 13/04/2023 Status : Completed								
2512	23040389	RICU	NEED TO REEFIX PATLOCK FOR REST ROOM DOOR	Ekambaram. K.	New padlock fixed		Tamililakkiya. K. - RICU	20/04/2023
Comp. Dt. : 31/05/2023 Status : Completed								
2513	23051256	RICU	TILES BROKEN - NEED TOUCHUP WORK	Parivallal. P.	Wrong complaint		Tamililakkiya. K. - RICU	20/06/2023
Comp. Dt. : 21/06/2023 Status : Completed								
2514	23060779	RICU	DOOR GLASS BROKEN FROM BATHROOM	Ekambaram. K.	Wrong complaint		Tamililakkiya. K. - RICU	27/06/2023
Dept Name : Security - SIS - Work Shop Comp. Dt. : 03/05/2023 Status : Completed								
2515	23050116	ICU	NEED REPAIRING WORK FOR ENTRANCE GATE - BROKEN	Ekambaram. K.	MAIN DOOR REPAIRED		Murugesan. M. - Security - SIS	17/05/2023
Comp. Dt. : 12/06/2023 Status : Completed								
2516	23060386	ICU	NEED REPAIRING WORK FOR MAIN DOOR - NEED URGENT SERVICE	Ekambaram. K.	Main door repaired		Radhakrishnan. R. - Security - SIS	20/06/2023
Dept Name : SMV Allied Health Sciences - Work Shop Comp. Dt. : 24/11/2022 Status : Completed								
2517	22111050	MICROBIOLOGY IN COLLEGE	DOOR LOCK NEED TO BE REPAIR IN REST ROOM	Ekambaram. K.	Door lock fixed, problem solved		Raffik Moideen. M. - SMV Allied Health Sciences	01/12/2022
Dept Name : Special Clinic - Work Shop Comp. Dt. : 21/05/2022 Status : Completed								
2518	22050801	SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	NEED REPAIRING WORK FOR ROLLING CHAIR - WHEEL PROBLEM	Sarathy. A.	Chair damaged, moved to scrap godown		Thamizhselvi. S. - Administration	28/05/2022
Comp. Dt. : 03/06/2022								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
2519	22060145	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	NEED REPAIRING WORK FOR KEYBOARD DRAW	Pachaimuthusamy. D.	Key board draw repaired.		Kabilan. R. - Special Clinic - Office	10/06/2022
Comp. Dt. : 06/06/2022								
Status : Completed								
2520	22060192	SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	NEED REPAIRING WORK FOR MAIN DOOR SOUND PROBLEM & NOT CLOSING PROPER	Pachaimuthusamy. D.	Door repaired.		Divya. K. - Special Clinic - Office	10/06/2022
Comp. Dt. : 30/06/2022								
Status : Completed								
2521	22061099	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	NEED REPAIRING WORK FOR DOOR - SOUND PROBLEM & OPEN & CLOSE	Pachaimuthusamy. D.	Door repaired		Christy. S. - Special OPD	05/07/2022
Comp. Dt. : 01/07/2022								
Status : Completed								
2522	22070044	SPECIAL WARD - A1	TILES BROKEN - NEED TOUCHUP WORK - NEED URGENT SERVICE	Murugavel	Tiles refixed, JK White cement pointing work completed		Sivapriya. P. - Special Ward	09/07/2022
Comp. Dt. : 20/07/2022								
Status : Completed								
2523	22070739	Reception	NEED TO REPLACE ROLLING CHAIR WHEEL - BROKED - 1 NO	Sarathy. A.	Rolling chair wheel screw fixed, problem solved		Baskar. G. - Special Clinic - Reception	01/08/2022
Comp. Dt. : 25/08/2022								
Status : Completed								
2524	22080841	DIALYSIS NEW UNIT IN 1ST FLOOR	NEED REPAIRING WORK FOR DOOR - SOUND PROBLEM	Ekambaram. K.	Door repaired hinges fixed.		Nandhini.M. - Special Clinic - Reception	09/09/2022
Comp. Dt. : 03/09/2022								
Status : Completed								
2525	22090143	Reception	NEED REFIX WHEEL ADJUSTMENT FOR ROLLING CHAIR	Sarathy. A.	Chair repaired.		Baskar. G. - Special Clinic - Reception	08/09/2022
Comp. Dt. : 11/10/2022								
Status : Completed								
2526	22100308	Special Ward - C	PROBLEM IN KEYBOARD TRAY - NEED TO REFIX WHEEL OR SCREW FOR KEYBOARD TRAY	Sarathy. A.	Keyboard tray wheel changed, problem solved		Vijai. M. - Medical Records	13/10/2022

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 19/10/2022 Status : Completed								
2527	22100642	SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	DRAW KEY OPEN CLOSER PROBLEM	Ekambaram. K.	Key repaired.		Rani. B. - Special Clinic - Office	29/10/2022
Dept Name : Special Clinic - Dialysis - Work Shop Comp. Dt. : 24/02/2023 Status : Completed								
2528	23020942	DIALYSIS NEW UNIT IN 1ST FLOOR	NEED REPAIR WORK AT RECEPTION'S CABIN IN DIALYSIS I UNIT	Ekambaram. K.	WORK COMPLETED		Swathika. K. - Special Clinic - Dialysis	07/03/2023
Comp. Dt. : 25/02/2023 Status : Completed								
2529	23020984	DIALYSIS NEW UNIT IN 1ST FLOOR	NEED TO REMOVE THE WINDOW BLIND AT 1ST FLOOR DIALYSIS.	Ekambaram. K.	WORK COMPLETED		Swathika. K. - Special Clinic - Dialysis	07/03/2023
Dept Name : Special Clinic - Office - Work Shop Comp. Dt. : 26/04/2023 Status : Completed								
2530	23040879	SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	NEED REPAIRING WORK FOR DOOR - SOUND PROBLEM	Ekambaram. K.	Door repaired and serviced, problem solved		Monica Sales. D. - Special Clinic - Office	08/05/2023
Dept Name : Special Clinic - Reception - Work Shop Comp. Dt. : 28/02/2023 Status : Completed								
2531	23021067	Reception	SOME CHAIR PART REMOVE WORK IN RECEPTION	Ekambaram. K.	CHAIR REPAIRED		Baskar. G. - Special Clinic - Reception	07/03/2023
Comp. Dt. : 28/04/2023 Status : Completed								
2532	23040945	SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	NEED REPAIRING WORK FOR DOOR - STUCK & SOUND	Ekambaram. K.	Door repaired and serviced, problem solved		Savitha. K. - Special Clinic - Reception	08/05/2023
Dept Name : Special OPD - Work Shop Comp. Dt. : 14/03/2023 Status : Completed								
2533	23030546	SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	NEED REPAIRING WORK FOR ENTRANCE DOOR - UNFIX SOUND PROBLEM	Ekambaram. K.	DOOR REPAIRED		Uma Maheswari. D. - Special OPD	23/03/2023
Comp. Dt. : 18/05/2023								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
2534	23050741	Reception	NEED REPAIRING WORK FOR ROLLING CHAIR	Sarathy. A.	ROLLING CHAIR REPAIRED.		Uma Maheswari. D. - Special OPD	01/06/2023
Comp. Dt. : 19/06/2023								
Status : Completed								
2535	23060646	Reception	NEED REPAIRING WORK FOR ROLLING CHAIR - HANDLE & SEAT BACK BROKEN	Ekambaram. K.	Handlel fixed.		Uma Maheswari. D. - Special OPD	27/06/2023
Comp. Dt. : 27/06/2023								
Status : Completed								
2536	23061013	Reception	NEED REPAIRING WORK FOR ROLLING CHAIR WHEEL - STUCK [2 NOS]	Sarathy. A.,Moorthy. L.,Veerappan. D.	Chair repaired.		Uma Maheswari. D. - Special OPD	08/07/2023
Dept Name : Special Ward - Work Shop								
Comp. Dt. : 11/05/2022								
Status : Completed								
2537	22050377	SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	MOSQUITO NET IN WINDOW DAMAGED	Ekambaram. K.	Mosquito net refixed, problem solved		Dhatchayani.N. - Special Ward	18/05/2022
2538	22050393	Special Ward - C	DOOR REFIX WORK(1424)	Pachaimuthusamy. D.	Door refixed, problem solved		Sangeetha. S. - Special Ward	18/05/2022
Comp. Dt. : 19/05/2022								
Status : Completed								
2539	22050723	SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	NEED TO REFIX KEYBOARD DRAW - STRUCK & BROKEND	Ekambaram. K.	Keyboard draw new wheel fixed, problem solved		Dhatchayani.N. - Special Ward	28/05/2022
Comp. Dt. : 27/05/2022								
Status : Completed								
2540	22051022	Special Ward - A	TILES DAMAGE NEED TOUCHUP WORK FOR ROOM NO 9	Sankar. T. M.	Tiles refixed and JK white applied		Arulperunjothi. M. - Special Ward	10/06/2022
Comp. Dt. : 04/06/2022								
Status : Completed								
2541	22060173	SPECIAL WARD - A1	NEED TO REFIX DOOR STOPPER FOR ROOM NO 2	Ekambaram. K.	Door stoper fixed.		Manjula. R. - Special Ward	10/06/2022
Comp. Dt. : 06/06/2022								
Status : Completed								
2542	22060224	Special Ward - A	TILES BROKEN NEED TOUCHUP WORK	Murugavel	Tiles refixed.		Manjula. R. - Special Ward	18/06/2022

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2543	22060225	Special Ward - A	NEED TO PASTE PLYWOOD SHEET FOR TEAPOY FOR ROOM NO 6	Pachaimuthusamy. D.,Ekambaram. K.,Venkatesan. R.	Mica pasted.		Manjula. R. - Special Ward	10/06/2022
	Comp. Dt. : 09/06/2022							
	Status : Completed							
2544	22060332	SPECIAL WARD - A1	NEED REPAIRING WORK FOR REST ROOM DOOR LOCK - CLOSED BUT NOT ABLE TO OPENED NEED URGENT SERVICE FOR	Ekambaram. K.	Welding work completed		Manjula. R. - Special Ward	13/06/2022
	Comp. Dt. : 10/06/2022							
	Status : Completed							
2545	22060363	Special Ward - C	PAINTING WORK FOR WASH BASIN STAND AND STOOL	Sarathy. A.,Moorthy. L.,Sundaramoorthy. G.	Painting work completed.		Vinidha. R. - Special Ward	21/06/2022
	Comp. Dt. : 14/06/2022							
	Status : Completed							
2546	22060511	Special Ward - A	NEED TO BROKEN UN WANTED LOCK 2NOS [KEY MISSING]	Pachaimuthusamy. D.	Lock opened, problem solved		Revathi. S. - Special Ward	01/07/2022
	Comp. Dt. : 17/06/2022							
	Status : Completed							
2547	22060649	Special Ward - C	NEED REPAIRING WORK FOR COT - BROKENED	Sarathy. A.	Cot wheel changed, problem solved		Venmathi. K. - Special Ward	01/07/2022
	Comp. Dt. : 23/06/2022							
	Status : Completed							
2548	22060856	MIT College	NEED WELDING WORK FOR PIPE	Sarathy. A.	Pipe welding work completed		Jayanthi. A. - Special Ward	02/07/2022
	Comp. Dt. : 28/06/2022							
	Status : Completed							
2549	22060999	Special Ward - C	NEED PAINTING WORK FOR NURSE'S CABIN	Manimaran. A.	Painting work completed		Sangeetha. S. - Special Ward	20/07/2022
	Comp. Dt. : 30/06/2022							
	Status : Completed							
2550	22061093	Special Ward - A	NEED TO CHECK ALL WORKSHOP ITEMS FOR ALL ROOMS	Parthiban.K.,Pachaimuthusamy. D.,Sarathy. A.	Cot wheel, IV stand bush, Cardiac table welding work completed		Bharathi. R. - Special Ward	05/07/2022
2551	22061139	Special Ward - A	NEED TO REFIX MULTIPLE LOCK FOR CUPBOARD DOOR FOR ROOM NO 2	Ekambaram. K.	Multiple lock refixed.		Bharathi. R. - Special Ward	05/07/2022
	Comp. Dt. : 01/07/2022							


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
2552	22070004	Special Ward - A	NEED TO CHANGE WHEEL [15 NOS] FOR MEDICINE , DRESSING TROLLEYS & WHEEL CHAIR & COTS	Sarathy. A.	New 5" wheel, 4" Wheel 10Nos fixed, work completed		Manjula. R. - Special Ward	09/07/2022
Comp. Dt. : 04/07/2022								
Status : Completed								
2553	22070097	SPECIAL WARD - A1	NEED TO CHECK ALL WORKSHOP ITEMS FOR ALL ROOMS	Pachaimuthusamy. D.,Ekambaram. K.,Sarathy. A.	Check all rooms, rectify the door padlock and door stopper problems, all workshop items ok.		Manjula. R. - Special Ward	09/07/2022
2554	22070106	SPECIAL WARD - A1	NEED FLOOR POINTING WORK FOR ALL ROOMS	Murugavel	All toilet room - pointing work checked, some places pointing work completed.		Manjula. R. - Special Ward	09/07/2022
Comp. Dt. : 05/07/2022								
Status : Completed								
2555	22070144	Special Ward - A	NEED TO FIX MOSQUITO NET FOR ALL ROOMS	Ekambaram. K.,Sundaramoorthy. G.,Venkatesan. R.	Mosquito net fixed, work completed		Bharathi. R. - Special Ward	18/07/2022
2556	22070167	Special Ward - A	TILES BROKENED NEED TOUCHUP WORK	Murugavel	Tiles refixed, JK White cement pointing work completed		Bharathi. R. - Special Ward	18/07/2022
Comp. Dt. : 06/07/2022								
Status : Completed								
2557	22070228	Special Ward - A	NEED PAINTING WORK AT ROOM NO 2	Manimaran. A.	Painting work completed		Reena. N. - Special Ward	18/07/2022
Comp. Dt. : 07/07/2022								
Status : Completed								
2558	22070233	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	NEED TO CHECK DOOR & WOODEN PLY WOOD PARTICIAN SIDE DAMAGE	Pachaimuthusamy. D.	Civil Admin work, need support service (Pest control service) so Inform to Mr.Murugan Project manage		Dhatchayani.N. - Special Ward	20/07/2022
2559	22070278	SPECIAL WARD---B	NEED WALL PAINTING WORK	Manimaran. A.	Painting work completed		Reena. N. - Special Ward	18/07/2022
Comp. Dt. : 08/07/2022								
Status : Completed								
2560	22070329	Special Ward - C	NEED TO REFIX TROLLEY WHEEL [6 NOS]	Sarathy. A.	Trolley wheel repaired and refixed, problem solved		Sangeetha. S. - Special Ward	18/07/2022
Comp. Dt. : 12/07/2022								
Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2561	22070457	SPECIAL WARD - A1	NEED TO FIX NEW DOOR FOR NURSE'S CABIN	Pachaimuthusamy. D.	New Door fixed, problem solved		Manjula. R. - Special Ward	20/07/2022
2562	22070460	SPECIAL WARD---B	NEED TO REFIX BUSH FOR DOOR ROOM NO 6	Ekambaram. K.	Door bush fixed, problem solved		Gayathiri. V. - Special Ward	20/07/2022
Comp. Dt. : 14/07/2022 Status : Completed								
2563	22070552	SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	NEED TO REMOVE BLOCK SHEET	Ekambaram. K.	Black sheet removed, problem solved		Dhatchayani.N. - Special Ward	01/08/2022
Comp. Dt. : 20/07/2022 Status : Completed								
2564	22070732	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	NEED REPAIRING WORK FOR GLASS DOOR - STOPPER PROBLEM	Ekambaram. K.	New sliding door fixed.		Elakkiya. S. - Special Ward	24/09/2022
Comp. Dt. : 22/07/2022 Status : Completed								
2565	22070816	Special Ward - C	NEED TO CHANGE WINDOW GLASS DOOR - BROKEN	Ekambaram. K.	Window glass door refixed in properly, problem solved		Sangeetha. S. - Special Ward	05/08/2022
Comp. Dt. : 23/07/2022 Status : Completed								
2566	22070859	Special Ward - A	NEED TO REFIX DOOR STOPPER	Pachaimuthusamy. D.	New door stopper refixed, problem solved		Manjula. R. - Special Ward	05/08/2022
Comp. Dt. : 26/07/2022 Status : Completed								
2567	22070971	Special Ward - C	NEED REPAIRING WORK FOR MALE DOCTOR'S ROOM DOOR & DOOR LOCK - SOUND PROBELM & NOT WORKING	Ekambaram. K.	Door and door lock repaired and serviced, problem solved		Muthulakshmi. A. - Special Ward	05/08/2022
Comp. Dt. : 02/08/2022 Status : Completed								
2568	22080073	SPECIAL WARD---B	NEED TO REFIX COT SIDE RAILS FOR ROOM NO B 20 & 22	Sarathy. A.	Cot side rails fixed, work completed		Reena. N. - Special Ward	08/08/2022
Comp. Dt. : 04/08/2022 Status : Completed								
2569	22080171	SPECIAL WARD A THIRD FLOOR	NEAR NURSES CABIN-1 NO.FLOOR TIES BROKEN,NEED TO BE CHABGE IT	Murugavel	Tiles refixed, JK White cement pointing work done		Bharathi. D. - Special Ward	17/08/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2570	22080174	SPECIAL WARD -B IN FOURTH FLOOR	BACKSIDE STEPS-WALL PAINTING GOT WASTED -REQUEST TO DO PAINTING ON WALLS	Manimaran. A.	Staircase hand rail painted.		Reena. N. - Special Ward	24/09/2022
		Comp. Dt. : 08/08/2022 Status : Completed						
2571	22080283	SPECIAL WARD---B	NEED PAINTING WORK FOR IV STAND, BED SIDE LOCKERS & BACK REST	Manimaran. A.	Painting work completed		Reena. N. - Special Ward	23/08/2022
		Comp. Dt. : 09/08/2022 Status : Completed						
2572	22080302	Special Ward - A	NEED TO REFIX DOOR STOPPER FOR ROOM NO 4,6,7 & TREATMENT ROOM	Parthiban.K.	All room workshop materials checked, no complaint and door stopper changed, now problem solved		Ezhilarasi. P. - Special Ward	23/08/2022
2573	22080313	Special Ward - A	NEED ALL WORKSHOP ITEMS GENERAL SERVICE FOR ALL ROOMS	Ekambaram. K.,Parthiban.K.,Sundaramoorthy. G.	All workshop materials checked, no complaints		Ezhilarasi. P. - Special Ward	23/08/2022
		Comp. Dt. : 11/08/2022 Status : Completed						
2574	22080397	Special Ward - A	NEED TO CHECK ALL ROOM DOOR STOPPER & NEED TO REFIX	Ekambaram. K.	All room workshop materials checked, no complaints		Bharathi. R. - Special Ward	23/08/2022
		Comp. Dt. : 18/08/2022 Status : Completed						
2575	22080565	SPECIAL WARD A1-FOURTH FLOOR	DRAWER NOT CLOSING PROPERLY IN ALL ROOMS	Ekambaram. K.	37Nos of new telescotric wheel changed, problem solved		Manjula. R. - Special Ward	26/08/2022
		Comp. Dt. : 25/08/2022 Status : Completed						
2576	22080850	SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	NEED URGENT SERVICE - FALSE CEILING DAMAGE - WATER DROP IN SIDE THE OFFICE	Pachaimuthusamy. D.	work completed.		Elakkiya. S. - Special Ward	09/09/2022
		Comp. Dt. : 26/08/2022 Status : Completed						
2577	22080904	Special Ward - A	NEED TO CHECK ALL ROOM WINDOWS - CLOSING PROBLEM	Ekambaram. K.	Womdpws cjeclod/		Bharathi. R. - Special Ward	09/09/2022
		Comp. Dt. : 27/08/2022 Status : Completed						


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2578	22080946	SPECIAL WARD - A1	TILES BROKEN - NEED TOUCHUP WORK AT OPPOSITE TO NURSE'S STATION	Murugavel	Tiles refixed JK white applied.		Manjula. R. - Special Ward	09/09/2022
		Comp. Dt. : 29/08/2022 Status : Completed						
2579	22081000	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	NEED PAINTING WORK FOR WHEEL CHAIR	Manimaran. A.	Wheel chair painted.		Elakkiya. S. - Special Ward	09/09/2022
		Comp. Dt. : 01/09/2022 Status : Completed						
2580	22090039	Special Ward - A	TILES BROKEN - NEED TOUCHUP WORK AT ROOM NO 5	Murugavel	16m of tiles refixed and JK white applied.		Bharathi. R. - Special Ward	08/09/2022
		Comp. Dt. : 05/09/2022 Status : Completed						
2581	22090167	Special Ward - C	NEED TO REFIX SCREEN ROD - DAMAGE	Ekambaram. K.	Screen rod fixed.		Dhatchayani.N. - Special Ward	24/09/2022
2582	22090193	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	TABLE DRAW NOT OPENED - [DR. SENTHIL]	Ekambaram. K.	Table drawer serviced, refixed in properly, problem solved		Elakkiya. S. - Special Ward	12/10/2022
		Comp. Dt. : 07/09/2022 Status : Completed						
2583	22090258	SPECIAL WARD - A1	NEED TO REFIX PATLOCK FOR MAIN DOOR	Ekambaram. K.	Pad lock fixed		Manjula. R. - Special Ward	24/09/2022
		Comp. Dt. : 13/09/2022 Status : Completed						
2584	22090507	SPECIAL WARD - A1	NEED TO CHECK SIDE RAILS & DOOR LOCK FOR ROOM NO 8 & 9	Sarathy. A.	Side rails and door lock repaired and serviced, problem solved		Manjula. R. - Special Ward	29/09/2022
		Comp. Dt. : 14/09/2022 Status : Completed						
2585	22090558	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	NEED PAINTING WORK FOR PATIENT STOOL & WHEEL CHAIR	Sarathy. A.	Painting work completed		Elakkiya. S. - Special Ward	29/09/2022
		Comp. Dt. : 19/09/2022 Status : Completed						
2586	22090726	SPECIAL WARD---B	NEED REPAIRING WORK FOR COT - BEND	Sarathy. A.	Cot bush fixed, problem solved		Reena. N. - Special Ward	29/09/2022
		Comp. Dt. : 23/09/2022 Status : Completed						


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2587	22090928	Special Ward - C	DOCTOR'S ROOM DOOR LOCK KEY MISSING - NEED TO BROKE DOOR LOCK	Ekambaram. K.	broken the door lock, Lock opened, problem solved		Sangeetha. S. - Special Ward	08/10/2022
		Comp. Dt. : 24/09/2022 Status : Completed						
2588	22090986	Special Ward - C	NEED TO REFIX REST ROOM DOOR LOCK FOR PANTRY & DOCTOR'S ROOM	Ekambaram. K.	Rest room door refixed, problem solved		Dhatchayani.N. - Special Ward	08/10/2022
		Comp. Dt. : 26/09/2022 Status : Completed						
2589	22090994	Special Ward - C	NEED TO REFIX METAL LOCK FOR CUPBOARD DOOR - BOTH SIDE	Ekambaram. K.	Cupboard door lock fixed, problem solved		Abirami. G. - Special Ward	08/10/2022
		Comp. Dt. : 28/09/2022 Status : Completed						
2590	22091138	SPECIAL WARD - A1	NEED TO REFIX DOOR BUSH FOR ROOM 7 - NEED URGENT SERVICE	Ekambaram. K.	Door stopper fixed, problem solved		Bharathi. R. - Special Ward	08/10/2022
		Comp. Dt. : 03/10/2022 Status : Completed						
2591	22100012	Special Ward - C	NEED REPAIRING WORK FOR FEMALE SIDE RESTROOM DOOR - BROKEN	Ekambaram. K.	Rest room door repaired and serviced, work completed		Vinidha. R. - Special Ward	12/10/2022
		Comp. Dt. : 06/10/2022 Status : Completed						
2592	22100093	Special Ward - A	NEED REPAIRING WORK FOR WINDOW DOORS - NOT CLOSING & SOUND PROBLEM	Ekambaram. K.	Window doors repaired and serviced, problem solved		Kowsalya. A. - Special Ward	12/10/2022
		Comp. Dt. : 13/10/2022 Status : Completed						
2593	22100420	SPECIAL WARD---B	NEED REPAIRING WORK FOR BERO LOCK & BACK SIDE EXIT WAY DOOR	Sundaramoorthy. G.	Lock fixed, work completed		Reena. N. - Special Ward	20/10/2022
		Comp. Dt. : 14/10/2022 Status : Completed						
2594	22100440	SPECIAL WARD---B	NEED TO REFIX DOOR STOPER FOR ROOM NO B25 , B19	Ekambaram. K.,Venkatesan. R.,Sundaramoorthy. G.	Door stopper fixed, problem solved		Jayanthi. A. - Special Ward	28/10/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2595	22100461	SPECIAL WARD---B	NEED TO REFIX BUSH [20NOS] FOR COT & WALKER	Sarathy. A.	Bush fixed.		Reena. N. - Special Ward	29/10/2022
Comp. Dt. : 15/10/2022 Status : Completed								
2596	22100483	Special Ward - C	NEED TO REFIX SCREEN ROD - BROKEN - NEED URGENT SERVICE	Sarathy. A.,Ekambaram. K.,Venkatesan. R.	Screen rod fixed.		Sangeetha. S. - Special Ward	29/10/2022
Comp. Dt. : 03/11/2022 Status : Completed								
2597	22110063	SPECIAL WARD -C IN FOURTH FLOOR	ALL STRETCHER'S AND COT SIDE RAILS NEED TO BE FIX	Sarathy. A.	Side rails fixed, work completed		Vinidha. R. - Special Ward	16/11/2022
Comp. Dt. : 14/11/2022 Status : Completed								
2598	22110527	SPECIAL WARD A1-FOURTH FLOOR	OPP TO NURSES CABIN-FLOOR TILES AIR CRACK PROBLEM-TOUCHUP WORK NEEDED	Murugavel	Tiles refixed and JK white applied.		Manjula. R. - Special Ward	21/11/2022
Comp. Dt. : 15/11/2022 Status : Completed								
2599	22110597	SPECIAL WARD A THIRD FLOOR	IN ROOM NO.7-UNWANTED NAILS NEED TO BE REMOVE	Ekambaram. K.	Nail removed.		Bharathi. D. - Special Ward	21/11/2022
Comp. Dt. : 12/12/2022 Status : Completed								
2600	22120555	SPECIAL WARD - A1	PATIENT COT NEED TO BE REPAIR	Sarathy. A.	Cot repaired and serviced, problem solved		Manjula. R. - Special Ward	19/12/2022
Comp. Dt. : 16/12/2022 Status : Completed								
2601	22120748	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	CUPBOARD NAILS REMOVING AND REPAIRING WORK	Ekambaram. K.	New door closer fixed.		Dhatchayani.N. - Special Ward	23/12/2022
2602	22120749	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	NEED TO DO PAINTING WORK	Manimaran. A.	Nail removed.		Dhatchayani.N. - Special Ward	23/12/2022
2603	22120788	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	NEED TO REFIX DOOR BEADING - DAMAGE & BROKEN	Ekambaram. K.	Wall painting work completed.		Divya. M. - Special Ward	23/12/2022
Comp. Dt. : 19/12/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2604	22120838	SPECIAL WARD A THIRD FLOOR	NEED TO CHECK DOOR STOPPER PROBLEM - ALL ROOMS	Ekambaram. K.	Monitor stand fixed, door stopper fixed, problem solved		Revathi. S. - Special Ward	30/12/2022
Comp. Dt. : 21/12/2022 Status : Completed								
2605	22120976	Special Ward - A	NEW X-RAY LOBBY FIXING WORK	Ekambaram. K.	New X-Ray lobby fixed, work completed		Bharathi. R. - Special Ward	30/12/2022
Comp. Dt. : 26/12/2022 Status : Completed								
2606	22121147	Special Ward - C	SCREEN ROD WELDING WORK (FEAMLE WARD)	Sarathy. A.	Screen rod welded and refixed, work completed		Abirami. G. - Special Ward	02/01/2023
Comp. Dt. : 04/01/2023 Status : Completed								
2607	23010173	SPECIAL WARD A1-FOURTH FLOOR	IN ROOM NO.2-BATHROOM DOOR ENTRANCE -MASON WORK NEED TO DO	Ekambaram. K.,Sundaramoorthy. G.,Murugavel	Door entrance mason work completed		Manjula. R. - Special Ward	12/01/2023
Comp. Dt. : 05/01/2023 Status : Completed								
2608	23010198	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	NEED REPAIRING WORK FOR ECG ROOM DOOR LOCK -DAMAGE & BROKEN	Ekambaram. K.	Door repaired.		Dhatchayani.N. - Special Ward	11/01/2023
Comp. Dt. : 07/01/2023 Status : Completed								
2609	23010302	SPECIAL WARD -B IN FOURTH FLOOR	DOOR FOOT STOPPER NEED TO BE FIX	Ekambaram. K.	Door stopper fixed.		Sangeetha. S. - Special Ward	11/01/2023
Comp. Dt. : 09/01/2023 Status : Completed								
2610	23010335	SPECIAL WARD A1-FOURTH FLOOR	IN ROOM NO.1-NEED TO BE REFIX PATIENT COT BUSH	Sarathy. A.	Cot bush fixed, problem solved		Sivapriya. P. - Special Ward	23/01/2023
Comp. Dt. : 13/01/2023 Status : Completed								
2611	23010555	Special Ward - A	FLUSH WATER LEAKAGE IN ROOM NO 2	Ganesan. A.	Wrong complaint, Msg inform to Plumbing dept		Ezhilarasi. P. - Special Ward	30/01/2023
Comp. Dt. : 20/01/2023 Status : Completed								
2612	23010708	SPECIAL WARD - A1	NEED TO FIX A DOOR FOR NURSE'S CABIN	Ekambaram. K.	New door fixed, work completed		Ezhilarasi. P. - Special Ward	16/02/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2613	23010733	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	KEYBOARD DRAWER PROBLEM	Ekambaram. K.,Sundaramoorthy. G.,Pachaimuthusamy . D.	Keyboard drawer repaired and serviced, problem solved		Elakkiya. S. - Special Ward	16/02/2023
Comp. Dt. :		28/01/2023						
Status :		Completed						
2614	23011027	SPECIAL WARD - A1	NEED REPAIRING WORK FOR BERO & LOCK	Ekambaram. K.	Bero and lock repaired and serviced, problem solved		Manjula. R. - Special Ward	16/02/2023
Comp. Dt. :		03/02/2023						
Status :		Completed						
2615	23020096	SPECIAL WARD---B	NEED TO REFIX COT SCREW - LOOSE PROBLEM	Sarathy. A.	Cot screw refixed, problem solved		Sangeetha. S. - Special Ward	11/02/2023
Comp. Dt. :		09/02/2023						
Status :		Completed						
2616	23020330	SPECIAL WARD - A1	SIDE RAISER ADJUSTMENT FIXING WORK	Ekambaram. K.,Sundaramoorthy. G.,Sarathy. A.	All room - patient cot side rails refixed in properly		Manjula. R. - Special Ward	16/02/2023
Comp. Dt. :		14/02/2023						
Status :		Completed						
2617	23020516	Special Ward - A	NEED REPAIRING WORK FOR COT - ROOM NO 7	Ekambaram. K.,Sundaramoorthy. G.,Sarathy. A.	Cot repaired, problem solved		Sivapriya. P. - Special Ward	17/02/2023
Comp. Dt. :		18/02/2023						
Status :		Completed						
2618	23020722	SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	NEED TO REMOVE GLASS DOOR FOR SPECIAL CLINIC OPD -- RECEPTION	Ekambaram. K.	Glass door partition removed, work completed		Dhatchayani.N. - Special Ward	23/02/2023
Comp. Dt. :		22/02/2023						
Status :		Completed						
2619	23020859	Paediatrics - Ward 309	ALL COTS BOLD NET ADJUSTMENT WORK	Ekambaram. K.	Cot bold and nut refixed, work completed		Hemachandra. P. - Special Ward	01/03/2023
Comp. Dt. :		04/03/2023						
Status :		Completed						
2620	23030180	SPECIAL WARD - A1	NEED WALL PAINTING	Manimaran. A.	WALL PAINTING WORK COMPLETGED		Manjula. R. - Special Ward	04/05/2023
2621	23030182	SPECIAL WARD - A1	NEED TO CHECK ALL WORKSHOP ITEMS AT ALL ROOMS	Pachaimuthusamy. D.	WORK COMPLETED		Manjula. R. - Special Ward	04/05/2023
Comp. Dt. :		06/03/2023						
Status :		Completed						


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2622	23030225	Special Ward - C	NEED CEMENT WORK FOR DOORS [8NOS] & REFIX SCREEN ROD	Murugavel	Mason work completed		Dhatchayani.N. - Special Ward	09/03/2023
Comp. Dt. : 10/03/2023 Status : Completed								
2623	23030415	SPECIAL WARD - A1	NEED TO REFIX BUSH FOR BABY CRADLE	Ekambaram. K.,Sundaramoorthy. G.,Sarathy. A.	BUSH FIXED.		Manjula. R. - Special Ward	23/03/2023
Comp. Dt. : 11/03/2023 Status : Completed								
2624	23030462	SPECIAL WARD---B	NEED TO REFIX TILES FOR RESTROOM WALL	Parivallal. P.	TILES REFIXED		Sangeetha. S. - Special Ward	23/03/2023
Comp. Dt. : 20/03/2023 Status : Completed								
2625	23030812	SPECIAL WARD - A1	NEED REPAIRING WORK FOR WHEEL CHAIR WHELL - BROKEN	Sarathy. A.	Wheel chair wheel welded, work completed		Shalini. S. - Special Ward	31/03/2023
2626	23030830	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	RACK BROKEN	Ekambaram. K.,Sundaramoorthy. G.,Pachaimuthusamy . D.	RACK REFIXED.		Elakkiya. S. - Special Ward	04/05/2023
Comp. Dt. : 22/03/2023 Status : Completed								
2627	23030905	Paediatrics - Ward 310	NEED REPAIRING WORK FOR WHEEL CHAIR WHEEL - STUCK - FEMALE MEDICAL WARD 310	Sarathy. A.	WHEEL CHAIR REPAIRED.		Hemachandra. P. - Special Ward	01/04/2023
Comp. Dt. : 23/03/2023 Status : Completed								
2628	23030977	SPECIAL WARD - A1	FALSE CEILING BROKEN - NEED REPAIRING WORK ROOM NO 3 & 4	Veerappan. D.	WORK COMPLETED		Manjula. R. - Special Ward	01/04/2023
Comp. Dt. : 24/03/2023 Status : Completed								
2629	23030986	SPECIAL WARD---B	NEED REPAIRING WORK FOR CUPBOARD LOCK - DAMAGE - ROOM NO 2	Ekambaram. K.	LOCK REFIXED.		Revathi. S. - Special Ward	01/04/2023
2630	23030997	SPECIAL WARD---B	TILES BROKEN - NEED TO REFIX FOR RESTROOM	Parivallal. P.	COT REPAIRED.		Sangeetha. S. - Special Ward	01/04/2023
Comp. Dt. : 25/03/2023 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2631	23031051	Female Medical Ward	NEED REPAIRING WORK FOR COT [BEND 2NOS] , CRUSH CART WHEEL , MEDICINE TROLLEY WHEEL & SUCTION APPAR	Ekambaram. K.,Sarathy. A.,Moorthy. L.	COT REPAIRED.		Hemachandra. P. - Special Ward	01/04/2023
2632	23031053	SPECIAL WARD---B	NEED REPAIRING WORK FOR CUPBOARD LOCKER - STUCK - ROOM NO 2	Ekambaram. K.,Sundaramoorthy. G.,Veerappan. D.	CUP BOARD LOCK FIXED.		Bharathi. R. - Special Ward	01/04/2023
Comp. Dt. : 27/03/2023 Status : Completed								
2633	23031104	Special Ward - C	NEED TO REFIX SCREEN ROD - BROKEN	Ekambaram. K.	SCREEN ROD FIXED.		Kavipriya. P. - Special Ward	01/04/2023
Comp. Dt. : 28/03/2023 Status : Completed								
2634	23031221	SPECIAL WARD - A1	NEED REPAIRING WORK FOR RESTROOM DOOR - STUCK	Ekambaram. K.	Door repaired and serviced, problem solved		Manjula. R. - Special Ward	13/04/2023
Comp. Dt. : 31/03/2023 Status : Completed								
2635	23031329	SPECIAL WARD---B	NEED TO REFIX DOOR STOPER FOR ROOM NO B7 -B8	Ekambaram. K.	Door stopper fixed, problem solved		Sangeetha. S. - Special Ward	13/04/2023
Comp. Dt. : 01/04/2023 Status : Completed								
2636	23040004	Paediatrics Ward	NEED REPAIRING WORK FOR CRASH CART - STUCK	Ekambaram. K.	Crash cart repaired and serviced, problem solved		Ezhilarasi. P. - Special Ward	19/04/2023
Comp. Dt. : 08/04/2023 Status : Completed								
2637	23040244	Special Ward - A	NEED TO CHECK FALSE CEILING DAMAGE & BROKEN IN ROOM NO 3 & 4 & DUE TO FUNGUS FORMED NEED PAINTING	Ekambaram. K.,Pachaimuthusamy. D.,Manivannan. A.	Damaged false ceiling removed		Revathi. S. - Special Ward	20/04/2023
Comp. Dt. : 10/04/2023 Status : Completed								
2638	23040276	SPECIAL WARD---B	NEED WALL PAINTING WORK FOR ROOM NO B1	Manimaran. A.	Wall painting work completed		Sangeetha. S. - Special Ward	20/04/2023
Comp. Dt. : 20/04/2023 Status : Completed								
2639	23040634	Special Ward - A	NEED REPAIRING WORK FOR CUPBOARD DOOR - BROKEN - ROOM NO 2	Ekambaram. K.	CUPBOARD FLY HINGES FIXED.		Bharathi. R. - Special Ward	02/05/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2640	23040683	Special Ward - A	NEED CEMENT WORK FOR RESTROOM CHAMBER - BROKEN - DRAINAGE WATER COMING INSIDE THE ROOM - ROOM NO 7	Parivallal. P.	WORK COMPLETED		Ragavi. P. - Special Ward	02/05/2023
Comp. Dt. : 24/04/2023 Status : Completed								
2641	23040756	Special Ward - C	NEED REPAIRING WORK FOR RESTROOM DOOR DAMAGE AT ROOM NO 409	Ekambaram. K.	RESTROOM DOOR REFIXED		Muthulakshmi. A. - Special Ward	02/05/2023
Comp. Dt. : 28/04/2023 Status : Completed								
2642	23040961	Special Ward - C	NEED TO REFIT SCREEN ROD - BROKEN - [PATIENT SIDE - ROOM NO 410]	Ekambaram. K.	Screen Rod refixed, work completed		Muthulakshmi. A. - Special Ward	08/05/2023
Comp. Dt. : 08/05/2023 Status : Completed								
2643	23050291	Special Ward - C	NEED CANE CUTTING WORK	Sarathy. A.	CANE CUTTING WORK COMPLETED		Muthulakshmi. A. - Special Ward	18/05/2023
2644	23050296	Paediatrics Ward	CRASH CART STUCK - WARD NO 309 ,310	Ekambaram. K.	Repairing work completed		Ezhilarasi. P. - Special Ward	05/08/2023
Comp. Dt. : 09/05/2023 Status : Completed								
2645	23050360	Paediatrics - Ward 310	NEED REPAIRING WORK FOR REST ROOM DOOR LOCK - BROKEN	Ekambaram. K.	RESTROOM DOOR REPAIRED		Ezhilarasi. P. - Special Ward	18/05/2023
Comp. Dt. : 12/05/2023 Status : Completed								
2646	23050523	SPECIAL WARD - A1	TILES BROKEN - AIR LOCK NEED TOUCHUP WORK AT OPPOSITE TO NURSE'S CABIN	Parivallal. P.	TILES REPLACED		Manjula. R. - Special Ward	18/05/2023
Comp. Dt. : 15/05/2023 Status : Completed								
2647	23050583	Special Ward - A	NEED REPAIRING WORK FOR CUPBOARD DOOR LOCK - ROOM NO 2	Ekambaram. K.	Door lock repaired and serviced, problem solved		Revathi. S. - Special Ward	23/05/2023
Comp. Dt. : 16/05/2023 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2648	23050669	Paediatrics - Ward 310	NEED REPAIRING WORK FOR NURSE'S STATION CUPBOARD DOOR & PATIENT SIDE WINDOW GLASS DOOR	Ekambaram. K.	Work completed		Hemachandra. P. - Special Ward	05/08/2023
Comp. Dt. : 19/05/2023 Status : Completed								
2649	23050819	Paediatrics Ward	NEED TO REFIX BUSH FOR COT & PATIENT STOOL 14 NOS	Ekambaram. K.	BUSH FIXED.		Hemachandra. P. - Special Ward	01/06/2023
Comp. Dt. : 20/05/2023 Status : Completed								
2650	23050847	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	NEED REPAIRING WORK FOR SCREEN BLIND FOR DR. SENTHIL SIR ROOM	Ekambaram. K.	WORK COMPLETED		Pushpa. K. - Special Ward	01/06/2023
Comp. Dt. : 24/05/2023 Status : Completed								
2651	23050950	Paediatrics Ward	NEED REPAIRING WORK FOR CRASH CART - STUCK & DOOR LOCK DAMGE AND BROKEN	Ekambaram. K.	WORK COMPLETED		Ezhilarasi. P. - Special Ward	03/06/2023
Comp. Dt. : 27/05/2023 Status : Completed								
2652	23051084	SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	NEED REPAIRING / ADJUSTMENT WORK FOR ROLLING CHAIR	Ekambaram. K.,Sundaramoorthy. G.,Manivannan. A.	ROLLING CHAIR ADJUSTING WORK COMPLETED		Dhatchayani. N. - Special Ward	03/06/2023
Comp. Dt. : 30/05/2023 Status : Completed								
2653	23051211	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	NEED REPAIRING WORK FOR DRAW WOOD - DAMAGE & BROKEN AT LAST ROOM	Ekambaram. K.	Drawer repaired		Elakkiya. S. - Special Ward	20/06/2023
Comp. Dt. : 31/05/2023 Status : Completed								
2654	23051217	Special Ward - A	NEED REFIX SCREW FOR REST ROOM DOOR LOCK FOR ROOM NO 7	Ekambaram. K.	Lock repaired		Gayathri. P. - Special Ward	20/06/2023
Comp. Dt. : 05/06/2023 Status : Completed								
2655	23060115	Special Ward - C	NEED TO REFIX SCREEN ROD & CLAMP - SCREEN FELL DOWN AT ROOM NO 410	Ekambaram. K.	Screen clamp fixed		Logeswari. P. - Special Ward	20/06/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 07/06/2023		Status : Completed						
2656	23060215	Special Ward - A	NEED COT REPAIRING WORK - ELEVATING PROBLEM IN ROOM NO 3	Sarathy. A.	Work completed		Prithika. V. - Special Ward	20/06/2023
2657	23060228	SPECIAL WARD---B	NEED REPAIRING WORK FOR DOOR STOPPER - ROOM SIDE	Ekambaram. K.	Door stoopper fixed		Suganya. K. - Special Ward	20/06/2023
2658	23060232	Special Ward - A	NEED REPAIRING WORK FOR COT WHEEL STUCK	Sarathy. A.	Work completed		Revathi. S. - Special Ward	20/06/2023
Comp. Dt. : 08/06/2023		Status : Completed						
2659	23060268	Special Ward - A	NEED TO REFIX HEIGHT SCALE	Ekambaram. K.	Wheel fixed		Revathi. S. - Special Ward	20/06/2023
2660	23060276	SPECIAL WARD---B	NEED REPAIRING WORK FOR MEDICINE , DRESSING & COT TROLLEY WHEEL - STUCK	Sarathy. A.	Wheel fixed		Sangeetha. S. - Special Ward	20/06/2023
Comp. Dt. : 12/06/2023		Status : Completed						
2661	23060422	SPECIAL WARD---B	NEED REPAIRING WORK FOR WINDOW DOOR - NOT ABLE TO OPEN	Ekambaram. K.	Door repaired		Sangeetha. S. - Special Ward	20/06/2023
Comp. Dt. : 13/06/2023		Status : Completed						
2662	23060454	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	NEED REPAIRING WORK FOR CUPBOARD DOOR-DAMAGE	Ekambaram. K.	Cupboard changed		Elakkiya. S. - Special Ward	20/06/2023
2663	23060470	Paediatrics Ward	NEED REPAIRING WORK FOR WHEEL CHAIR WHEEL - WARD NO 309 & 310	Sarathy. A.	Wheel chair repaired		Ezhilarasi. P. - Special Ward	20/06/2023
Comp. Dt. : 14/06/2023		Status : Completed						
2664	23060509	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	DUE TO DRAINAGE WATER LEAK - WOODEN PART DAMAGE AND STAIN - NEED WHITE CEMENT WORK FOR DR. SENTHIL	Parivallal. P.	Work completed		Elakkiya. S. - Special Ward	27/06/2023
Comp. Dt. : 17/06/2023		Status : Completed						
2665	23060623	Special Ward - A	NEED REPAIRING WORK FOR COT - HANDLE BROKEN - ROOM NO 1	Ekambaram. K.	Handle fixed.		Revathi. S. - Special Ward	27/06/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 20/06/2023 Status : Completed								
2666	23060702	Paediatrics - Ward 309	NEED REPAIRING WORK FOR NIRSE'S CABIN - BROKEN & REFIX MOSQUITO NET FOR ALL WINDOW'S AT MALE MEDICAL	Ekambaram. K.	Nurse's cabin door repaired.		Hemachandra. P. - Special Ward	27/06/2023
Comp. Dt. : 21/06/2023 Status : Completed								
2667	23060740	Special Ward - C	NEED TO REFIX SCREEN ROD	Ekambaram. K.	Screen rod fixed.		Divya. M. - Special Ward	27/06/2023
Comp. Dt. : 22/06/2023 Status : Completed								
2668	23060799	Special Ward - A	NEED TO REFIX X RAY LOBBY	Ekambaram. K.	X ray lobby fixed.		Revathi. S. - Special Ward	07/07/2023
Comp. Dt. : 23/06/2023 Status : Completed								
2669	23060842	Special Ward - C	NEED TO REFIX SCREEN ROD - FELL DOWN -NEED URGENT SERVICE	Ekambaram. K.	Scren rod fixed.		Vinidha. R. - Special Ward	07/07/2023
2670	23060849	Special Ward - A	NEED TO REFIX PATLOCK FOR CUPBOARD - ROOM NO 5	Ekambaram. K.	Work completed		Revathi. S. - Special Ward	07/07/2023
2671	23060853	Special Ward - A	NEED TO FIX NEW DOOR STOPPER FOR ROOM NO 1	Ekambaram. K.	Work completed		Revathi. S. - Special Ward	07/07/2023
2672	23060866	SPECIAL WARD---B	NEED ADJUSTMENT WORK FOR COT - BEND	Sarathy. A.	Work completed		Sangeetha. S. - Special Ward	07/07/2023
Comp. Dt. : 24/06/2023 Status : Completed								
2673	23060906	SPECIAL WARD---B	WHEEL CHAIR WHEEL STUCK - NEED REPAIRING WORK	Sarathy. A.	2 nos. wheel changed.		Sangeetha. S. - Special Ward	07/07/2023
Comp. Dt. : 27/06/2023 Status : Completed								
2674	23061014	SPECIAL WARD - A1	NEED TO CHECK RESTROOM DOOR - NOT ABLE TO OPEN - ROOM NO 5	Ekambaram. K.,Sundaramoorthy. G.,Ganesh. S.	Door repaired.		Manjula. R. - Special Ward	08/07/2023
Comp. Dt. : 28/06/2023 Status : Completed								
2675	23061075	SPECIAL WARD - A1	NEED TO REFIX RESTROOM CARBAR FOR ROOM NO 2 - BROKEN	Ekambaram. K.,Sundaramoorthy. G.,Ganesh. S.	Work completed		Manjula. R. - Special Ward	08/07/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Dept Name : Surgical Oncology - Work Shop Comp. Dt. : 26/10/2022 Status : Completed								
2676	22100803	ONCOLOGY DEPT-2ND FLOOR-SPECIAL OPD	DOOR NOISE PROBLEM	Ekambaram. K.	Door repaired.		Dhivya Bharathi. P. - Surgical Oncology	03/11/2022
Comp. Dt. : 19/06/2023 Status : Completed								
2677	23060684	ONCOLOGY DEPT-2ND FLOOR-SPECIAL OPD	NEED TO FIX A NEW TOWEL STAND	Ekambaram. K.	Towel stand fixed.		Dhivya Bharathi. P. - Surgical Oncology	27/06/2023
Dept Name : Tailoring Department - Work Shop Comp. Dt. : 06/06/2022 Status : Completed								
2678	22060201	Tailoring Department	NEED REPAIRING WORK FOR BERO & PAINTING ALSO	Ekambaram. K.,Venkatesan. R.,Manimaran. A.	Bero painting work completed		Ilayaraja.S. - Tailoring Department	20/07/2022
Comp. Dt. : 11/03/2023 Status : Completed								
2679	23030471	PRESS	DUE TO UN AVIOD OF PUBLIC USE - NEED TO PROVIDE PATLOCK [3 NOS] FOR COMMON RESTROOM NEAR PRESS -	Ekambaram. K.	WORK COMPLETED		Ilayaraja.S. - Tailoring Department	23/03/2023
Dept Name : Tele Exchange - Work Shop Comp. Dt. : 08/06/2022 Status : Completed								
2680	22060308	EDP IN UNDERGROUND	NEED A NEW SWITCH RACK STAND	Venkatesan. R.	1" angle used. New stand 3'x3'x2.1/2' (1no)		Padmanaban. G. - Tele Exchange	13/06/2022
Comp. Dt. : 12/09/2022 Status : Completed								
2681	22090463	Main Gate	NEED CEMENT WORK FOR CAMERA POST AT MAIN OUTWAY GATE ENTRANCE	Murugavel	2Nos camera post concrete work completed		Vivek. A. - Tele Exchange	29/09/2022
Comp. Dt. : 23/09/2022 Status : Completed								
2682	22090927	Nursing College	NEED WELDING WORK FOR CAMERA FIXING POST	Venkatesan. R.	camera Post welded, work completed		Vivek. A. - Tele Exchange	08/10/2022
Comp. Dt. : 21/10/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2683	22100711	Tele Exchange	REQUEST TO FIX NEW RACK	Ekambaram. K.,Parthiban.K.,Sundaramoorthy. G.	New Rack fixed, problem solved		Vivek. A. - Tele Exchange	06/12/2022
		Comp. Dt. : 28/11/2022 Status : Completed						
2684	22111194	Nursing College	NEED WELDING WORK FOR CAMERA POST AT NURSING COLLEGE ENTRANCE	Sarathy. A.	Post welding work completed		Vivek. A. - Tele Exchange	19/12/2022
		Comp. Dt. : 21/12/2022 Status : Completed						
2685	22120993	Nursing College	CAMERA WELDING WORK IN ENTRANCE	Sarathy. A.	Welding work completed		Vivek. A. - Tele Exchange	23/01/2023
		Comp. Dt. : 10/01/2023 Status : Completed						
2686	23010400	TELEPHONE DEPARTMENT IN EDP(UNDERGROUND)	SYSTEM TIME NEED TO BE CHANGE	Ganesan. A.	Wrong complaint		Padmanaban. G. - Tele Exchange	23/01/2023
		Comp. Dt. : 25/01/2023 Status : Completed						
2687	23010904	TELEPHONE DEPARTMENT IN EDP(UNDERGROUND)	NEED TO FIX A NEW RACK	Ekambaram. K.	New Rack fixed, work completed		Vivek. A. - Tele Exchange	30/01/2023
		Comp. Dt. : 09/02/2023 Status : Completed						
2688	23020324	Tele Exchange	TELEPHONE MDF PLATE CUTTING WORK	Sarathy. A.	Cutting work completed		Vivek. A. - Tele Exchange	16/02/2023
		Comp. Dt. : 29/05/2023 Status : Completed						
2689	23051135	JR Quarters	NEED TO REMOVE CAMERA CLAMP	Ekambaram. K.	CLAMP REMOVED.		Padmanaban. G. - Tele Exchange	03/06/2023
		Comp. Dt. : 14/06/2023 Status : Completed						
2690	23060511	EDP IN UNDERGROUND	NEED TO FIX TV STAND	Sarathy. A.,Ekambaram. K.,Sundaramoorthy. G.	Stand fixed.		Padmanaban. G. - Tele Exchange	27/06/2023
2691	23060512	EDP IN UNDERGROUND	NEED TO PROVIDE NEW SHELF	Ekambaram. K.	New sheet fixed 4'x2'x1'		Padmanaban. G. - Tele Exchange	27/06/2023
		Dept Name : Transport - Work Shop Comp. Dt. : 02/09/2022						


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
2692	22090079	Casualty	NEED TO FIX STRUCTURE BED IN AMBULANCE	Ekambaram. K.	Bed fixed.		Ramalingam. J. - Transport	08/09/2022
Comp. Dt. : 26/09/2022								
Status : Completed								
2693	22091021	COMMERCIAL BLOCK	NEED REPAIRING WORK FOR DRIVER'S ROOM DOOR - DAMAGE & BROKEN AT COMMERCIAL BLOCK	Ekambaram. K.	Driver room door repaired, pad lock fixed, problem solved		Arunkumar. K. - Transport	08/10/2022
Comp. Dt. : 10/01/2023								
Status : Completed								
2694	23010391	BUS SHED IN HOSPITAL CAMPUS	MASON WORK	Murugavel	Motor bed built, work completed		Sasikumar. P. - Transport	23/01/2023
Comp. Dt. : 27/02/2023								
Status : Completed								
2695	23021015	BUS SHED IN MUTHUYALPET	NEED IRON WORK	Ekambaram. K.	WORK COMPLETED		Sasikumar. P. - Transport	07/03/2023
Comp. Dt. : 22/03/2023								
Status : Completed								
2696	23030917	Transport	NEED REPAIRING WORK FOR BERO LOCK - NOT WORKING	Ekambaram. K.	LOCK REPAIRED.		Sasikumar. P. - Transport	01/04/2023
Comp. Dt. : 23/03/2023								
Status : Completed								
2697	23030959	COMMERCIAL BLOCK	NEED TO FIX DOOR PATLOCK FOR TRANSPORT DRIVER'S ROOM	Ekambaram. K.	LOCK FIXED.		Arunkumar. K. - Transport	01/04/2023
2698	23030963	COMMERCIAL BLOCK	NEED PAINTING WORK - COMMERCIAL BLOCK GODOWN	Manimaran. A.	PAINTING WORK COMPLETED		Sasikumar. P. - Transport	04/05/2023
Comp. Dt. : 20/05/2023								
Status : Completed								
2699	23050841	Transport	NEED WELDING WORK FOR FAN	Sarathy. A.	WELDING WORK COMPLETED		Sasikumar. P. - Transport	01/06/2023
Dept Name : UHC Villupuram - Work Shop								
Comp. Dt. : 14/10/2022								
Status : Completed								
2700	22100464	UHC Villupuram	NEED TO REFIX " NO PARKING" BOARD	Ekambaram. K.	Board refixed, problem solved		Sankari. J. - UHC Villupuram	06/12/2022

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 08/04/2023 Status : Completed								
2701	23040243	UHC Villupuram	NEED REPAIRING WORK FOR MEDICINE TROLLEY WHEEL STUCK & CHANGE BUSH 12 NOS FOR TABLE & PATIENT STOOL	Sarathy. A.	WORK COMPLETED		Sankari. J. - UHC Villupuram	05/05/2023
Comp. Dt. : 27/05/2023 Status : Completed								
2702	23051099	UHC Villupuram	NEED SERVICE FOR SHUTTER	Ekambaram. K., Sundaramoorthy. G., Manivannan. A.	GREASE PACKED AT SHUTTER.		Sankari. J. - UHC Villupuram	03/06/2023
Comp. Dt. : 02/06/2023 Status : Completed								
2703	23060081	UHC Villupuram	NEED REPAIRING WORK FOR MAIN DOOR LOCK & RESTROOM DOOR - DAMAGE & BROKEN	Ekambaram. K.	Padlock fixed.		Rathinamala. A. - UHC Villupuram	05/08/2023
Dept Name : Veterinary Science - Work Shop Comp. Dt. : 18/07/2022 Status : Completed								
2704	22070655	Animal House	NEED PAINTING WORK FOR RACK	Manimaran. A.	Work completed.		Rajaram. P. - Veterinary Science	24/09/2022
Dept Name : Ward - Work Shop Comp. Dt. : 13/07/2022 Status : Completed								
2705	22070502	PHYSIOLOGY-- COLLEGE	NEED TO REPASTE MICA FOR TABLES [3NOS]	Pachaimuthusamy. D.	Mica fixed in table, work completed		Gowri.V. - PHYSIOLOGY	01/08/2022
Dept Name : Work Shop - Work Shop Comp. Dt. : 13/05/2022 Status : Completed								
2706	22050489	FOUNDER STATUE-NEAR MIT COLLEGE	TILES BROKEN.	Murugavel	Tiles refixed, JK white cement pointing work done		Murugavel - Civil - Maintenance	27/05/2022
Comp. Dt. : 22/11/2022 Status : Completed								
2707	22110955	Endoscopy	NEED WELDING WORK	Sarathy. A.	Grill welding work completed		Moorthy. L. - Work Shop	01/12/2022
Comp. Dt. : 05/01/2023 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2708	23010247	BUS SHED IN HOSPITAL CAMPUS	MASON WORK DONE -FOUNDATION BASE	Murugavel	Work completed.		Murugavel - Civil - Maintenance	11/01/2023
Comp. Dt. : 06/01/2023 Status : Completed								
2709	23010273	BUS SHED IN HOSPITAL CAMPUS	NEED MATION WORK FOR BUS SHED FOUNDATION	Murugavel	Bus shed near foundation work completed with mason		Murugavel - Civil - Maintenance	12/01/2023
Work Type : Network Cables Dept Name : Male Ortho Ward - Work Shop Comp. Dt. : 27/03/2023 Status : Completed								
2710	23031133	Male Surgery - Ward 203	NEED REPAIRING WORK FOR COT - BEND	Sarathy. A.	COT REPAIRED.		Vanitha. P. - Male Ortho Ward	01/04/2023
Work Type : Work Dept Name : Air Condition Department - Work Shop Comp. Dt. : 16/09/2022 Status : Completed								
2711	22090648	DIALYSIS IN 2ND FLOOR	NEED TO FIX METAL STEPS STAND FOR DIALYSIS II FLOOR BACKSIDE	Sarathy. A.	Repeated complaint		Panneer Selvam. P. - Air Condition Department	20/10/2022
Comp. Dt. : 27/09/2022 Status : Completed								
2712	22091087	AHU Room-1ST FLOOR	NEED PAINTING WORK - SINGLE WALL - FOR POOJA	Manimaran. A.	Painting work completed		Panneer Selvam. P. - Air Condition Department	08/10/2022
Dept Name : Civil - Execution - Work Shop Comp. Dt. : 16/06/2022 Status : Completed								
2713	22060614	MEDICAL COLLEGE	Need Carpenter and Welder for Medical College South wing west side existing GI sheet removed and ref	Pachaimuthusamy. D.,Ekambaram. K.,Sarathy. A.	All carpenter work completed		Murugan.N. - Civil - Execution	20/07/2022
Comp. Dt. : 17/10/2022 Status : Completed								
2714	22100539	professor quarters	Room No:6, 9, 10 - Need to change and repaire all window & door frame & shutters	Parthiban.K.,Ekambaram. K.,Sundaramoorthy. G.	Repeated complaint		Murugan.N. - Civil - Execution	29/10/2022
Comp. Dt. : 29/11/2022								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
2715	22111242	Casualty	REQUEST TO DO ALL DOOR'S PAINTING WORK	Manimaran. A.	All door painting work completed		Praveen Kumar. K. - Civil - Execution	06/12/2022
Comp. Dt. : 02/01/2023								
Status : Completed								
2716	23010046	COMMERCIAL BLOCK	Civil Execution store room - Bero lock to be change	Ekambaram. K.	New Pad lock fixed, problem solved		Murugan.N. - Civil - Execution	12/01/2023
Dept Name : Civil - Maintenance - Work Shop								
Comp. Dt. : 24/01/2023								
Status : Completed								
2717	23010887	MIT AUDITORIUM BACKSIDE	NEED A NEW CHAMBER AT MIT BUS STAND NEAR MIT AUDITORIUM BACKSIDE	Murugavel	New chamber built, work completed		Kumar. V. - Civil - Maintenance	30/01/2023
Comp. Dt. : 06/03/2023								
Status : Completed								
2718	23030218	PG-QUATERS	NEED A NEW CHAMBER AT BACKSIDE OF PG QUARTERS	Murugavel	New chamber built, work completed		Kumar. V. - Civil - Maintenance	09/03/2023
Dept Name : Clinical Department - Work Shop								
Comp. Dt. : 31/03/2023								
Status : Completed								
2719	23031361	CLINICAL DEPARTMENT IN 2ND FLOOR	NEED CARPENTER WORK FOR FIXING POSTERS AT MUSEUM ROOM	Ekambaram. K.	Door repaired and serviced, problem solved		Saranya. S. - Clinical Department	13/04/2023
Dept Name : Derm,Pulmo,Psych Ward - Work Shop								
Comp. Dt. : 23/09/2022								
Status : Completed								
2720	22090953	PSYCHIATRY WARD	NEED TO PREFIX PATIENT ROTATING STOOL TAP 2NOS	Sarathy. A.	Cot repaired, stool screw fixed, problem solved		Sarathkumar. R. - Derm,Pulmo,Psych Ward	08/10/2022
Dept Name : Dialysis - Work Shop								
Comp. Dt. : 12/01/2023								
Status : Completed								
2721	23010514	ICU	REQUEST TO MAKE NEW WOODEN BOX FOR MEDICINE STORAGE	Ekambaram. K.	New box maked, that box shifting and handover to the dept		Piravinkumar. A. - Dialysis	30/01/2023
Dept Name : Electrical Maintenance - Work Shop								
Comp. Dt. : 29/06/2022								
Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2722	22061071	Electrical Maintenance	NEED NEW SET UP BOX WOODEN STAND 10 NOS	Pachaimuthusamy. D.,Parthiban.K.,Eka mbaram. K.	New Wooden stand fixed, work completed		Vaithianathan.M - Electrical Maintenance	20/07/2022
Dept Name : ENT & Ophthal Ward - Work Shop Comp. Dt. : 25/11/2022 Status : Completed								
2723	22111099	ENT WARD-407	LOCKER PAINTING WORK NEED TO DO	Manimaran. A.	Painting work completed		Jayalakshmi. J. - ENT & Ophthal Ward	06/12/2022
Comp. Dt. : 05/12/2022 Status : Completed								
2724	22120172	ENT WARD-407	10 NO'S LOCKER PAINTING WORK NEED TO DO	Manimaran. A.	10 nos. locker painted.		Jayalakshmi. J. - ENT & Ophthal Ward	10/12/2022
Dept Name : Gas Power Plant - Work Shop Comp. Dt. : 06/05/2023 Status : Completed								
2725	23050249	Gas Power Plant	NEED TO PROVIDE A NEW SMALL IRON STOOL	Ekambaram. K.	NOT AVAILABLE		Mahi Mohan Ram.S. - Gas Power Plant	17/05/2023
Dept Name : Hospital Infection Control - Work Shop Comp. Dt. : 19/09/2022 Status : Completed								
2726	22090744	FEVER CLINIC	NEED TO FIX POSTER FOR " BIO MEDICAL WASTE"	Manivannan. A.	Bio medical poster fixed, problem solved		Anitha. N. - Hospital Infection Control	29/09/2022
Comp. Dt. : 28/10/2022 Status : Completed								
2727	22100911	HICC	REQUEST FOR NEW SCREEN ROD NEED TO BE FIX AT SIZE10FT	Ekambaram. K.	5 nos. screen rod fixed.		Mohana. M. - Hospital Infection Control	03/11/2022
Dept Name : Medical Records - Work Shop Comp. Dt. : 15/11/2022 Status : Completed								
2728	22110617	Medical Records	REQUEST TO MAKE 2 NO'S NEW WRITING PAD	Ekambaram. K.	2nos writing pad issued.		Martin Prabu.V. - Medical Records	21/11/2022
Comp. Dt. : 05/12/2022 Status : Completed								
2729	22120166	Hospital	NEED TO PROVIDE A TEMPORARY DOOR AT 5TH FLOOR FOR MRD	Ekambaram. K.	Door fixed, work completed		Martin Prabu.V. - Medical Records	19/12/2022
Comp. Dt. : 09/03/2023								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
2730	23030377	Hospital	NEED TO FIX " SINGLE USE PLASTIC FREE CAMPUS BOARD " 20 NOS	Ekambaram. K.	BOARD FIXED		Martin Prabu.V. - Medical Records	23/03/2023
Comp. Dt. : 28/03/2023								
Status : Completed								
2731	23031218	Work Shop	NEED FLEX BANNER FITTING WORK FOR TATA AC VEHICLE	Ekambaram. K.	Banner fixing work completed		Martin Prabu.V. - Medical Records	13/04/2023
Dept Name : Nursing Office - Work Shop								
Comp. Dt. : 25/11/2022								
Status : Completed								
2732	22111086	ORTHO OT	REQUEST TO DO WALL PAINTING(FUNGUS FORMED)	Manimaran. A.	Painting work completed		Rajalakshmi. N. - Nursing Office	19/12/2022
Comp. Dt. : 15/04/2023								
Status : Completed								
2733	23040449	Special Ward	NEED TO REFIX HANGER [FOR DRESS] FOR A & A1 WARD - 20 ROOMS	Ekambaram. K.	Hanger refixed, problem solved		Tamilarasi.C. - Nursing Office	20/04/2023
Dept Name : OPD - Work Shop								
Comp. Dt. : 07/11/2022								
Status : Completed								
2734	22110241	Orthopaedics - OPD	NEED NEW SUGGESTION BOX	Ekambaram. K.	Suggestion box issued.		Durgadevi. J - OPD	18/11/2022
Comp. Dt. : 23/11/2022								
Status : Completed								
2735	22110999	IVF ART CLINIC-INSIDE OF OG OPD(NO.68)	REQUEST TO MAKE NEW STAND FOR CPU	Parthiban.K.,Viswa. V.,Ekambaram. K.	CPU stand fixed, problem solved		Rajasekari. R. - OPD	01/12/2022
Comp. Dt. : 16/12/2022								
Status : Completed								
2736	22120758	Orthopaedics - OPD	REQUEST TO MAKE NEW MEDICINE BOX AND WOODEN BOX	Ekambaram. K.	2 nos box issued.		Durgadevi. J - OPD	23/12/2022
Comp. Dt. : 03/02/2023								
Status : Completed								
2737	23020076	Paediatrics - OPD	NEED CARPENTER HELP FOR MUSIUM SETUP	Ekambaram. K.	Frame's fixed, work completed		Subashree. R. - OPD	11/02/2023
Dept Name : Operation Theatre - Work Shop								

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 15/11/2022 Status : Completed								
2738	22110606	ORTHO OT	REQUEST TO DO PAINTING WORK FOR ALL THE FOOT STOOL AND IV STAND	Manimaran. A.	IV stand painted.		Mahalakshmi. G. - Operation Theatre	21/11/2022
Dept Name : Ophthalmology - Work Shop Comp. Dt. : 02/05/2023 Status : Completed								
2739	23050046	EYE Bank	NEED MANPOWER 2NOS FOR SCREEN FIXING WORK	Ekambaram. K.	WRONG COMPLAINT		Rajeswari.V. - Ophthalmology	17/05/2023
Dept Name : Physical Education - Work Shop Comp. Dt. : 01/04/2023 Status : Completed								
2740	23040001	Boys hostel	NEED TO FIX PHOTO FRAME	Ekambaram. K.	Board fixed, problem solved		Vijayakumar. M. - Physical Education	19/04/2023
Dept Name : PICU & NICU - Work Shop Comp. Dt. : 10/11/2022 Status : Completed								
2741	22110427	NEW NICU & PICU-2ND FLOOR	REQUEST TO MAKE NEW CPU AND UPS STAND	Ekambaram. K., Parthiban.K., Sundaramoorthy. G.	New stand issued		Krishnaveni. S. - PICU & NICU	18/11/2022
2742	22110440	NEW NICU & PICU-2ND FLOOR	REQUEST TO MAKE NEW STAND FOR HOT AND COLD WATER DISPENSER	Ekambaram. K.	New stand issued		Poovathal. K. - PICU & NICU	18/11/2022
College Name : SMVNC Work Type : Complaint Dept Name : Work Shop - Work Shop Comp. Dt. : 04/05/2022 Status : Completed								
2743	22050111	Nursing College	NEED A NEW CHAMBER FOR III FLOOR COOLER & ALTERNATIVE ARRANGEMENT FOR GROUND & I FLOOR COOLER	Murugavel	Cooler bed built, work completed		TAMILPULAVENDRAN - SMVNC	12/05/2022
Comp. Dt. : 25/06/2022 Status : Completed								
2744	22060920	Nursing College	NEED REPAIRING WORK FOR REST ROOM DOOR FOR I FLOOR FEMALE RESTROOM	Ekambaram. K.	Rest room door repaired		RAYASEELAN - SMVNC	05/07/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 17/08/2022 Status : Completed								
2745	22080503	Nursing College	IN CLASS ROOM-TEACHING BOARD BROKEN	Pachaimuthusamy. D.,Ekambaram. K.,Sundaramoorthy. G.	Board fixed, work completed		THAMIZHVENDAPULA VAR - SMVNC	26/08/2022
Comp. Dt. : 26/08/2022 Status : Completed								
2746	22080876	Nursing College	NEED TO PROVIDE PLAY WOOD SHELF FOR PUTTING FILE AT UNDER THE XEROX MACHINE COMPUTER TABLE	Pachaimuthusamy. D.	New plywood fixed.		KIRUBHA - SMVNC	09/09/2022
Comp. Dt. : 12/09/2022 Status : Completed								
2747	22090443	Nursing College	NEED PAINTING WORK FOR PAEDIATRIC COT	Manimaran. A.	Painting work completed		RAJARAJESWARI - SMVNC	12/10/2022
Comp. Dt. : 21/10/2022 Status : Completed								
2748	22100736	Nursing College	IN 2ND FLOOR-READING ROOM-DOOR LOCK GOT STRUCKED	Ekambaram. K.	Handle fixed.		KIRUBA - SMVNC	29/10/2022
Comp. Dt. : 27/10/2022 Status : Completed								
2749	22100862	Nursing College	LIBRARY ROOM DOOR NOT CLOSING PROPERLY	Ekambaram. K.	Door repaired. 10 nos. board fixed.		KIRUBA - SMVNC	08/11/2022
Comp. Dt. : 17/11/2022 Status : Completed								
2750	22110723	Nursing College	REQUEST TO DO COT(3 NO'S)PAINTING WORK	Manimaran. A.	22Nos of Chair, 3Nos of cot painting work completed		DHANDAPANI - SMVNC	01/12/2022
Comp. Dt. : 01/12/2022 Status : Completed								
2751	22120029	Nursing College	NEED REPAIRING WORK FOR KEYBOARD RACK - STUCK	Ekambaram. K.	Keyboard fixed.		DHANDAPANI - SMVNC	10/12/2022
Comp. Dt. : 22/12/2022 Status : Completed								
2752	22121039	Nursing College	IRON NAIL FIXING WORK FOR PHOTO HANG	Ekambaram. K.	Iron nail and photo frame fixed, work completed		DHANDAPANI - SMVNC	30/12/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 04/01/2023								
Status : Completed								
2753	23010179	Nursing College	IN 3RD FLOOR-PEDEATRIC HOD ROOM-BERO DOOR HANDLE AND LOCK NEED TO BE REFIX	Ekambaram. K.	3Nos of bero lock changed, problem solved		SARASWATHI - SMVNC	23/01/2023
Comp. Dt. : 13/01/2023								
Status : Completed								
2754	23010556	Nursing College	NEED TO FIX WHITE BOARD	Ekambaram. K.	White board fixed, problem solved		RAJARAJESWARI - SMVNC	30/01/2023
Comp. Dt. : 18/01/2023								
Status : Completed								
2755	23010635	Nursing College	NEED WELDING WORK	Sarathy. A.	Welding work completed		RAJARAJESWARI - SMVNC	30/01/2023
Comp. Dt. : 06/02/2023								
Status : Completed								
2756	23020202	Nursing College	NEED PAINTING WORK FOR PAEDIATRIC COT	Sundaramoorthy. K.	All cot painting work completed		RAJARAJESWARI - SMVNC	16/02/2023
Comp. Dt. : 10/02/2023								
Status : Completed								
2757	23020383	Nursing College	2ND AND 3RD FLOOR RESTROOM WATER LEAKAGE	Ganesan. A.	Plumbing dept complaint, inform to complaints		GURUNATHAN - SMVNC	16/02/2023
Comp. Dt. : 14/02/2023								
Status : Completed								
2758	23020545	Nursing College	NEED WELDING AND PAINTING WORK	Manimaran. A.	Welding and painting work completed		RAJARAJESWARI - SMVNC	17/02/2023
Comp. Dt. : 10/03/2023								
Status : Completed								
2759	23030406	Nursing College	NEED TO FIX A DOOR FOR PARTITION PART AT III FLOOR	Ekambaram. K.	NEW DOOR CLOSER FIXED		DHANDAPANI - SMVNC	23/03/2023
Comp. Dt. : 22/03/2023								
Status : Completed								
2760	23030896	Nursing College	NEED TO REFIX BERO HANDLE [2NOS] FOR LIBRARY	Ekambaram. K.	HANDLE FIXED.		KIRUBHA - SMVNC	01/04/2023
Comp. Dt. : 28/03/2023								
Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2761	23031151	Nursing College	NEED TO FIT NOTICE BOARD AT PRINCIPAL OFFICE	Ekambaram. K.	Notice board fixed, work completed		DHANDAPANI - SMVNC	13/04/2023
Comp. Dt. : 06/04/2023 Status : Completed								
2762	23040187	Nursing College	NEED REPAIRING WORK FOR MAIN DOOR LOCK + DRILLING WORK AT NURSING COLLEGE	Ekambaram. K.	drilling work completed, door lock repaired, problem solved		KIRUBHA - SMVNC	20/04/2023
Comp. Dt. : 20/04/2023 Status : Completed								
2763	23040642	Nursing College	NEED TO REFIX BOARD FOR CLASS ROOM & LIBRARY	Ekambaram. K.	BOARD FIXED		DHANDAPANI - SMVNC	02/05/2023
Comp. Dt. : 16/06/2023 Status : Completed								
2764	23060580	Nursing College	MAIN DOOR CLOSER PROBLEM	Ekambaram. K.	Work completed		SHANMUGAM - SMVNC	27/06/2023
Comp. Dt. : 21/06/2023 Status : Completed								
2765	23060769	Nursing College	NEED WELDING WORK FOR STEEL RACK & REPAIRING WORK FOR WOODEN CUPBOARD LOCKER FOR LIBRARY	Ekambaram. K.	Work completed		KIRUBHA 9751936995 - SMVNC	27/06/2023
Work Type : Work Dept Name : Work Shop - Work Shop Comp. Dt. : 17/02/2023 Status : Completed								
2766	23020679	Nursing College	NEED PAINTING WORK FOR COT 4NOS	Manimaran. A.	4Nos of cot painting work completed		DHANDAPANI - SMVNC	23/02/2023

College Name : SMVPT

Work Type : Complaint

Dept Name : Work Shop - Work Shop

Comp. Dt. : 13/05/2022

Status : Completed

2767 22050472 Polytechnic college IN HOD ROOM-FLOOR TILES GAP-WHITE CEMENT PACKAGING WORK

Murugavel

Tiles gap JK white cement pointing work done

Comp. Dt. : 30/05/2022

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

SANTHANAM - SMVPT

27/05/2022

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
2768	22051077	WORKSHOP-POLYTECH NIC COLL	NEED TO FIX CARPENTER VICE	Ekambaram. K.	Vice fixed.		VENKATRAMAN - SMVPT	10/06/2022
Comp. Dt. : 21/06/2022								
Status : Completed								
2769	22060770	WORKSHOP-POLYTECH NIC COLL	NEED REPAIRING WORK FOR WORKSHOP SHUTTER - STUCK	Ekambaram. K.	Shutter repaired, problem solved		SANTHANAM - SMVPT	02/07/2022
Comp. Dt. : 03/11/2022								
Status : Completed								
2770	22110088	B.ED COLLEGE	NEED CARPENTER FOR SOME URGENT WORK	Ekambaram. K.,Sundaramoorthy. G.,Parthiban.K.	New partition fixed, work completed		SRIMAN - SMVPT	16/11/2022
Comp. Dt. : 17/12/2022								
Status : Completed								
2771	22120812	Polytechnic college	MIRROR NEED TO BE REFIX	Ekambaram. K.	Mirror refixed.		SANTHANAM - SMVPT	23/12/2022
Comp. Dt. : 14/03/2023								
Status : Completed								
2772	23030573	WORKSHOP-POLYTECH NIC COLL	NEED CEMENT WORK	Murugavel	WORK COMPLETED.		SANTHANAM - SMVPT	23/03/2023
Comp. Dt. : 24/04/2023								
Status : Completed								
2773	23040737	Polytechnic college	NEED TO FIX A PATLOCK FOR RESTROOM IN [INSIDE THE CLASSROOM] AT III FLOOR	Ekambaram. K.	PADLOCK FIXED		SANTHANAM - SMVPT	02/05/2023
Comp. Dt. : 20/05/2023								
Status : Completed								
2774	23050844	Polytechnic college	NEED REPAIRING & REFIX WINDOW FOR PHYSICS LAB - WINDOW BROKEN	Ekambaram. K.	LAB DOOR FIXED.		SANTHANAM - SMVPT	01/06/2023
Comp. Dt. : 21/06/2023								
Status : Completed								
2775	23060757	Polytechnic college	NEED TO CHECK ALL FLOOR TILES IN RESTROOM - WATER LEAKAGE	Parivallal. P.	Wrong complaint		SANTHANAM - SMVPT	05/08/2023

College Name : VCE

Work Type : Complaint

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Dept Name : Work Shop - Work Shop Comp. Dt. : 13/08/2022 Status : Completed								
2776	22080476	B.ED COLLEGE	KEY MISSING - NEED TO BROKE BERO LOCK	Ekambaram. K.	Lock opened.		SRIMAN - VCE	23/08/2022
Comp. Dt. : 20/02/2023 Status : Completed								
2777	23020754	B.ED COLLEGE	NEED REPAIRING WORK FOR DOOR LOCK - BROKEN	Ekambaram. K.	Door lock repaired and serviced, problem solved		SRIMAN - VCE	01/03/2023
Comp. Dt. : 09/06/2023 Status : Completed								
2778	23060314	B.ED COLLEGE	NEED TO REFIT COLLEGE NAME BOARD - FELL DOWN	Ekambaram. K.	Board fixed		VENKATESAN - VCE	20/06/2023
Comp. Dt. : 24/06/2023 Status : Completed								
2779	23060917	B.ED COLLEGE	DUE TO INSPECTION PURPOSE , NEED TO FIX "BOARD" 2 NOS - NEED URGENT SERVICE	Ekambaram. K.	New plywood partiton fixed.		VENKATESAN - VCE	07/07/2023
Work Type : Work Dept Name : Work Shop - Work Shop Comp. Dt. : 24/02/2023 Status : Completed								
2780	23020956	B.ED COLLEGE	NEED CARPENTER HELP FOR REFIXING " FOUNDER CHAIRMEN SIR'S PHOTO"	Manivannan. A.	PHOTO FIXED.		SRIMAN - VCE	07/03/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.



Sri Manakula Vinayagar Medical College and Hospital

Complaint Status Report From 01-05-2022 To 30-06-2023

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
College Name :		MIT						
Work Type :		Complaint						
Dept Name :		Air Condition Department - Air Condition Department						
Comp. Dt. :		04/05/2022						
Status :		Completed						
1	22050099	MIT College	AC WATER LEAKAGE IN DIGITAL LAB	Sasikumar. S.	Ductable AC indoor unit cleaned and serviced.		SAHANABEGUM - MIT	06/06/2022
Comp. Dt. :		13/05/2022						
Status :		Completed						
2	22050471	MIT College	IN 1ST FLOOR-MMM LAB-A/C NOT WORKING	Sasikumar. S.	One unit PC board wiring problem. joint and taped it. Another unit capacitor problem.		KAVITHA - MIT	02/06/2022
Comp. Dt. :		20/05/2022						
Status :		Completed						
3	22050765	MIT College	AC NOT WORKING I FLOOR A V ROOM	Sasikumar. S.	Ducatable unit indoor blower motor problem. Removed for rewinding purpose.		GUBERAN - MIT	20/06/2022
Comp. Dt. :		24/05/2022						
Status :		Completed						
4	22050909	MIT College	NEED TO CHECK COOLER - COOLING PROBLEM IN "A" WING	Sasikumar. S.	Wire burnt. New wire replaced.		RAVI - MIT	06/08/2022
Comp. Dt. :		09/06/2022						
Status :		Completed						
5	22060335	MIT MESS	FRIDGE NOT WORKING	Udhaya Shankar. P.	Not management fridge		RAVI - MIT	06/08/2022
Comp. Dt. :		13/06/2022						
Status :		Completed						
6	22060455	MIT College	AC NOT WORKING AT ADMISSION CELL - PRINCIPAL ROOM CONFERENCE ROOM	Udhaya Shankar. P.	Rat bitten the wire. Rejoined and taped it		KAVITHA - MIT	06/08/2022
Comp. Dt. :		15/06/2022						
Status :		Completed						

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
7	22060572	MIT PRINCIPAL ROOM	NEED TO CHECK AC - NOT WORKING AT ADMISSION CELL - NEED URGENT SERVICE	Sasikumar. S.	PC board serviced and refixed.		KAVITHA - MIT	27/06/2022
	Comp. Dt. : 29/06/2022							
	Status : Completed							
8	22061034	CASHCOUNTER IN RECEPTION	AC WATER LEAKAGE AT CONFERENCE HALL NEAR PRINCIPAL OFFICE	Panneer Selvam. P.	Drain hose changed.		SASIKUMAR - MIT	05/09/2022
	Comp. Dt. : 11/07/2022							
	Status : Completed							
9	22070431*	MIT College	AC NOT WORKING - II FLOOR SIMULATION LAB	Sasikumar. S.	Wiring problem. New wire changed.		GUBERAN - MIT	07/10/2022
	Comp. Dt. : 23/07/2022							
	Status : Completed							
10	22070861	MIT College	NEED A NEW PIPE LINE CONNECTION FOR AC AT SIMULATION LAB	Sasikumar. S.	New pipe line fixed for AC wiring.		ANANTHAN - MIT	09/09/2022
	Comp. Dt. : 27/07/2022							
	Status : Completed							
11	22071037	MIT PRINCIPAL ROOM	AC NOT WORKING - NEED URGENT SERVICE	Sasikumar. S.	Indoor unit serviced.		SAMSUTHEN - MIT	05/09/2022
	Comp. Dt. : 08/08/2022							
	Status : Completed							
12	22080276	MIT College	AC NOT WORKING AT CONFERENCE ROOM DINING HALL NEAR PRINCIPAL OFFICE	Sasikumar. S.	PC board problem. PC board serviced.		KAVITHA - MIT	09/09/2022
	Comp. Dt. : 17/08/2022							
	Status : Completed							
13	22080511	MIT College	IN CONFERENCE ROOM-A/C NOT WORKING	Sasikumar. S.	Rat bitten the wire. Rejoined the wire.		KAVITHA - MIT	09/09/2022
	Comp. Dt. : 27/08/2022							
	Status : Completed							
14	22080943	MIT College	AC NOT WORKING AT CONFERENCE HALL	Sasikumar. S.	Wiring problem rectified.		ARUN - MIT	09/09/2022
	Comp. Dt. : 05/09/2022							
	Status : Completed							
15	22090188	MIT College	AC NOT WORKING AT ADMISSION ROOM	Sasikumar. S.	Rat bitten the wire. rejoined the wire.		KAVITHA - MIT	09/09/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 12/09/2022								
Status : Completed								
16	22090434	MIT College	AC NOT WORKED AT OPPOSITE TO PRINCIPAL OFFICE CONFERENCE HALL	Sasikumar. S.	Rat bitten the wire. Wire joint and taped it.		KAVITHA - MIT	21/09/2022
Comp. Dt. : 15/09/2022								
Status : Completed								
17	22090587	MIT---PLACEMENT CELL	AC NOT WORKING	Babu. D.,Vijay. M.,Panneer Selvam. P.	Remote mode changed.		KAVITHA - MIT	21/09/2022
18	22090604	MIT College	AC NOT WORKING IV FLOOR SERVER ROOM	Sasikumar. S.	Drain tray block removed.		KAVITHA - MIT	21/09/2022
Comp. Dt. : 21/09/2022								
Status : Completed								
19	22090822	MIT College	AC NOT WORKING - III FLOOR CSE LAB	Sasikumar. S.	8.5 TR ductable unit. Rat bitten the power supply wire inside false ceiling. Rejoint and taped the w		SAKTHI - MIT	22/09/2022
Comp. Dt. : 12/10/2022								
Status : Completed								
20	22100341	Mit ladies hostel	AC COOLER WATER LEAKAGE IN ROOM 82	Sasikumar. S.,Udhaya Shankar. P.,Babu. D.	Leakage arrested.		AROKIAMARY - MIT	19/10/2022
21	22100344	MIT Auditorium	AC NOT WORKING	Sasikumar. S.,Udhaya Shankar. P.,Babu. D.	Breaker trip. ON it.		ANANDHAN - MIT	18/10/2022
Comp. Dt. : 13/10/2022								
Status : Completed								
22	22100389	MIT College	AC NOT WORKING - NEED URGENT SERVICE AT PRINCIPAL OFFICE OPP CONFERENCE HALL	Sasikumar. S.,Udhaya Shankar. P.,Babu. D.	Wire loose connection.		KAVITHA - MIT	28/10/2022
23	22100397	MIT AUDITORIUM BACKSIDE	AC WATER LEAKAGE - AC NO 1	Sasikumar. S.,Udhaya Shankar. P.,Babu. D.	Drain tray cleaned and serviced with water.		ANANTHAN - MIT	28/10/2022
Comp. Dt. : 18/10/2022								
Status : Completed								
24	22100567	MIT College	AC NOT WORKING AT CONFERENCE ROOM - OPP TO PRINCIPAL OFFICE	Sasikumar. S.,Udhaya Shankar. P.,Babu. D.	Wire loose connection. Wire adjustment done.		SASIKUMAR - MIT	28/10/2022
Comp. Dt. : 20/10/2022								
Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
25	22100681	MIT College	AC NOT WORKING IN CONFERENCE HALL	Sasikumar. S.,Udhaya Shankar. P.,Babu. D.	Wire loose connection.		SASIKUMAR - MIT	28/10/2022
	Comp. Dt. : 28/10/2022							
	Status : Completed							
26	22100898	MIT College	IN AO OFFICE ROOM-A/C NOT WORKING	Sasikumar. S.,Udhaya Shankar. P.,Babu. D.	Compressor terminal wiring burnt. Burnt wire rejoint and taped.		GUBERAN - MIT	28/10/2022
	Comp. Dt. : 04/11/2022							
	Status : Completed							
27	22110135	MIT AUDITORIUM BACKSIDE	OUTERDOOR A/C FAN MOTOR NOT WORKING	Sasikumar. S.,Udhaya Shankar. P.,Babu. D.	Outdoor blade changed.		ANANDHAN - MIT	30/11/2022
	Comp. Dt. : 07/11/2022							
	Status : Completed							
28	22110229	MIT College	AC NOT WORKING IN PRINCIPAL SIR CONFERENCE HALL LUNCH HALL	Sasikumar. S.,Udhaya Shankar. P.,Babu. D.	Rat bitten the wire. Wire rejoined and insulated.		KALAISELVI - MIT	08/11/2022
	Comp. Dt. : 16/11/2022							
	Status : Completed							
29	22110679	MIT College	IN 1ST FLOOR-DIGITAL LAB(AV ROOM)-A/C WATER LEAKAGING PROBLEM	Sasikumar. S.,Udhaya Shankar. P.,Babu. D.	PC board wire rat bitten. Retaped it and insulation done.		KAVITHA - MIT	21/11/2022
	Comp. Dt. : 19/11/2022							
	Status : Completed							
30	22110827	MIT College	IN 2ND FLOOR-ACL LAB-A/C LESS COOLING PROBLEM	Sasikumar. S.,Udhaya Shankar. P.,Babu. D.	Drain tray cleaned.		GUBERAN - MIT	30/11/2022
	Comp. Dt. : 28/11/2022							
	Status : Completed							
31	22111193	MIT College	NEED TO CHECK COOLER - NOT WORKING AT IV FLOOR	Sasikumar. S.,Udhaya Shankar. P.,Babu. D.	Condenser coil changed.		ANANTHAN - MIT	30/11/2022
	Comp. Dt. : 30/11/2022							
	Status : Completed							
32	22111296	SIMULATION LAB-MIT	A/C NOT WORKING	Sasikumar. S.,Udhaya Shankar. P.,Babu. D.	10 mfd capacitor changed.		ANADHAN - MIT	01/12/2022
	Comp. Dt. : 12/12/2022							
	Status : Completed							


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
33	22120527	MIT AUDITORIUM BACKSIDE	AC NO.6 NOT WORKING	Babu. D.	Rat bitten the wire. Wire rejoin and insulated.		KAVITHA - MIT	12/12/2022
	Comp. Dt. : 13/12/2022							
	Status : Completed							
34	22120616	MIT College	AC NOT WORKING - I FLOOR CAD LAB	Babu. D.	Breaker trip. Manually on it.		ANANTHAN - MIT	14/12/2022
	Comp. Dt. : 22/12/2022							
	Status : Completed							
35	22121022	MIT College	AC NOT COOLING IN 4TH FLOOR CB LAB	Babu. D.	R22 gas top up done. Indoor unit serviced.		ANANTHAN - MIT	24/12/2022
	Comp. Dt. : 21/02/2023							
	Status : Completed							
36	23020828	MIT College	AC NOT WORKING I FLOOR DIGITAL LIBRARY	Thulasi Daran. R.	CAPACITOR 15 MFD CHANGED.		BALA - MIT	28/02/2023
	Comp. Dt. : 27/02/2023							
	Status : Completed							
37	23021000	MIT CSC LAB 2	AC NOT WORKING - MIT COLLEGE IV FLOOR CSE LAB	Babu. D.	BREAKER CHANGED.		BASKARAN COMP.SEC. - MIT	05/05/2023
	Comp. Dt. : 03/03/2023							
	Status : Completed							
38	23030143	MIT AUDITORIUM BACKSIDE	AC NOT WORKING - NO 6	Thulasi Daran. R.	HP LP SWITCH WIRE RAT BITTEN. REJOINED THE WIRE AND INSULATED.		KAVITHA - MIT	09/03/2023
	Comp. Dt. : 06/03/2023							
	Status : Completed							
39	23030220	MIT AUDITORIUM BACKSIDE	AC 2 NOS NOT WORKING	Babu. D.	RAT BITTEN THE WIRE. REJOINED THE WIRE AND INSULATED.		ANANTHAN - MIT	08/03/2023
	Comp. Dt. : 25/03/2023							
	Status : Completed							
40	23031047	MIT College	AC NOT WORKING - III FLOOR IT LAB	Babu. D.	RAT BITTEN THE WIRE. REJOINED AND INSULATED. INDOOR UNIT SERVICED.		SRIDHAR - MIT	25/03/2023
	Comp. Dt. : 28/03/2023							
	Status : Completed							
41	23031203	MIT College	AC NOT WORKING II FLOOR ECE LAB & IV FLOOR	Babu. D.	RAT BITTEN THE WIRE. REJOINED AND INSULATED.		KAVITHA - MIT	03/04/2023

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHAL KUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 18/04/2023 Status : Completed								
42	23040567	MIT AUDITORIUM BACKSIDE	7,9,4 AC NOT WORKING	Sasikumar. S.	pc board serviced and refixed.		ANANTHAN - MIT	22/04/2023
Comp. Dt. : 19/04/2023 Status : Completed								
43	23040598	MIT AUDITORIUM BACKSIDE	AC NOT WORKING - NO 4 ,7 & 9	Udhaya Shankar. P.	pc board serviced and refixed.		ANANTHAN - MIT	22/04/2023
Comp. Dt. : 20/04/2023 Status : Completed								
44	23040680	MIT College	COOLER NOT WORKING AT I , II & III FLOORS	Babu. D.	2ND AND 3RD FLOOR COOLER PROBLEM RECTIFIED. 1ST FLOOR COOLER R22 GAS CHARGED (1200), 60 MFD CAPACITO		RAVI - MIT	28/04/2023
Comp. Dt. : 15/05/2023 Status : Completed								
45	23050589	MIT College	AC WATER LEAKAGE AT III FLOOR CSE LAB SERVER ROOM -	Babu. D.	drain tray cleaned and serviced.		BASKARAN COMP.SEC. - MIT	17/05/2023
Comp. Dt. : 16/05/2023 Status : Completed								
46	23050655	MIT College	AC [5NOS] NOT WORKING - III FLOOR IT LAB	Babu. D.	Wire burnt. Power supply directed.		SRIDHAR - MIT	17/05/2023
47	23050663	MIT College	AC NOT WORKING - MIT OFFICE ROOM	Babu. D.	RAT BITTEN THE WIRE. WIRE REJOINED AND INSULATED.		SIVASUBRAMANIYAN - MIT	20/05/2023
Comp. Dt. : 19/05/2023 Status : Completed								
48	23050823	MIT College	AC WATER LEAKAGE- II FLOOR ADVANCE COMMUNICATION LAB	Babu. D.	AC UNIT COIL AND FILTER SERVICED.		KAVITHA - MIT	22/05/2023
Comp. Dt. : 25/05/2023 Status : Completed								
49	23050997	MIT College	AC WATER LEAKAGE AT IV FLOOR CT LAB	Babu. D.	drain tray cleaned and serviced.		BASKARAN COMP.SEC. - MIT	31/05/2023
50	23051007	MIT College	COOLER NOT WORKING AT IV FLOOR "B" WING	Babu. D.	COOLER UNIT CONDEMNED		GUBERAN - MIT	29/05/2023
Comp. Dt. : 26/05/2023 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
51	23051049	MIT College	AC CABLE DAMAGE BY RAT & AC NOT WORKING AT III FLOOR CSE LAB	Babu. D.	RAT BITTEN THE WIRE. WIRE REJOINED AND INSULATED.		KAVITHA - MIT	29/05/2023
Comp. Dt. : 27/05/2023 Status : Completed								
52	23051081	MIT College	AC WATER LEAKAGE AT IV FLOOR CSE LAB [AC NO 4]	Babu. D.	drain tray cleaned and serviced.		BASKARAN COMP.SEC. - MIT	31/05/2023
Comp. Dt. : 17/06/2023 Status : Completed								
53	23060624	MIT College	AC [2NOS] NOT WORKING AT III FLOOR CSE LAB	Babu. D.	Breaker trip. Manually ON		ANANTHAN - MIT	19/06/2023
Comp. Dt. : 26/06/2023 Status : Completed								
54	23060973	MIT COLLEGE-PLACEMENT ROOM	AC NOT WORKING	Babu. D.	45 MFD CAPACITOR CHANGE IT.		JAYAKUMAR - MIT	28/06/2023

College Name : Others

Work Type : Complaint

Dept Name : Air Condition Department - Air Condition Department

Comp. Dt. : 19/10/2022

Status : Completed

55	22100624	MIT College	AC NOT WORKING IN CONFERENCE HALL	Sasikumar. S.,Udhaya Shankar. P.,Babu. D.	Rat bitten the wire. Wire rejoined and insulated.		KAVITHA - Others	21/10/2022

College Name : SMVMCH

Work Type : Complaint

Dept Name : BIOCHEMISTRY - Air Condition Department

Comp. Dt. : 06/02/2023

Status : Completed

56	23020175	BIOCHEMISTRY-- -COLLEGE	AC NOT WORKING - CR LAB	Sasikumar. S.	NEUTRAL WIRE DISCONNECTED. REJOINT THE WIRE AND INSULATION APPLIED.		Anusuya. J. - BIOCHEMISTRY	07/02/2023

Dept Name : Canteen - Boys Hostel - Air Condition Department

Comp. Dt. : 25/10/2022

Status : Completed

57	22100781	Boys hostel P.H-III	AC WATER LEAKAGE	Sasikumar. S.,Udhaya Shankar. P.,Babu. D.	Drain tray cleaned.		Meenubalan. M. - Canteen - Boys Hostel	27/10/2022

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 02/11/2022								
Status : Completed								
58	22110023	Boys hostel P.H-III	AC WATER LEAKAGE IN ROOM NO.41	Sasikumar. S.,Udhaya Shankar. P.,Babu. D.	Indoor unit drain tray cleaned and serviced.		Sambasivam. K. - Canteen - Boys Hostel	03/11/2022
59	22110045	Boys hostel P.H-III	IN ROOM NO.15 A/C REMOTE SENSOR NOT WORKING	Sasikumar. S.,Udhaya Shankar. P.,Babu. D.	Serviced PC board refixed in AC unit.		Sambasivam. K. - Canteen - Boys Hostel	15/11/2022
Comp. Dt. : 04/11/2022								
Status : Completed								
60	22110141	Kitchen - Boys Hostel	DINING HALL1-HOT AND COOLER MACHINE HEATER LINE NOT WORKING	Sasikumar. S.,Udhaya Shankar. P.,Babu. D.	Heater coil need to change. Company should solve the problem.		Sambasivam. K. - Canteen - Boys Hostel	09/02/2023
Comp. Dt. : 24/11/2022								
Status : Completed								
61	22111054	Boys hostel	IN MILK STORAGE AREA-FREEZER SWITCH NOT WORKING	Sasikumar. S.,Udhaya Shankar. P.,Babu. D.	Switch problem rectified.		Elumalai. M. - Canteen - Boys Hostel	30/11/2022
Comp. Dt. : 03/12/2022								
Status : Completed								
62	22120124	BOYS HOSTEL-DINING HALL	HOT AND COOL HEATER NOT WORKING (DRINKING WATER)	Sasikumar. S.,Udhaya Shankar. P.,Babu. D.	Complaint should be attended by company labour. Informed to company		Sambasivam. K. - Canteen - Boys Hostel	09/02/2023
Dept Name : Canteen-Girls Hostel - Air Condition Department								
Comp. Dt. : 11/05/2022								
Status : Completed								
63	22050370	Ladies hostel Phase-I	IN ROOM NOS 53 AND 71-A/C NOT WORKING	Sasikumar. S.	Indoor unit blower and coil serviced. MCB breaker trip. ON it.		Revathy. N. - Canteen-Girls Hostel	06/06/2022
Comp. Dt. : 12/05/2022								
Status : Completed								
64	22050424	Ladies hostel Phase-II	4TH AND 2ND FLOOR COOLER NOT COOLING	Sasikumar. S.	Water cooler olp & relay thermoster problem. Need to changed.		Malliga. K. - Canteen-Girls Hostel	06/06/2022
Comp. Dt. : 10/06/2022								
Status : Completed								
65	22060373	Ladies hostel Phase-I	IN ROOM NO.58 A/C NEED TO BE REFIX	Udhaya Shankar. P.	AC unit refixed.		Revathy. N. - Canteen-Girls Hostel	27/06/2022
Comp. Dt. : 04/08/2022								
Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
66	22080160	Ladies hostel Phase-I	IN ROOM NO.25 A/C NEED TO BE SERVICE	Sasikumar. S.	Indoor unit serviced.		Revathy. N. - Canteen-Girls Hostel	09/09/2022
Comp. Dt. : 17/08/2022 Status : Completed								
67	22080507	Ladies hostel Phase-I	IN ROOM NO.10 A/C NEED TO BE SERVICE	Sasikumar. S.	Indoor unit serviced.		Revathy. N. - Canteen-Girls Hostel	09/09/2022
Comp. Dt. : 18/08/2022 Status : Completed								
68	22080572	Ladies hostel Phase-I	IN ROOM NO.12 A/C WATER LEAKAGING PROBLEM	Sasikumar. S.	Indoor unit serviced.		Revathy. N. - Canteen-Girls Hostel	09/09/2022
Comp. Dt. : 02/09/2022 Status : Completed								
69	22090088	Ladies hostel Phase-I	AC NOT WORKING	Sasikumar. S.	Indoor unit pc board problem. PC board serviced and fixed.		Revathy. N. - Canteen-Girls Hostel	09/09/2022
Comp. Dt. : 15/09/2022 Status : Completed								
70	22090579	Ladies hostel Phase-I	AC NOT WORKING	Panneer Selvam. P.,Babu. D.,Thulasi Daran. R.	PC board burnt. Resoldering and fixed.		Revathy. N. - Canteen-Girls Hostel	21/09/2022
Comp. Dt. : 08/11/2022 Status : Completed								
71	22110304	Ladies hostel Phase-I	NEED TO FIX AC IN 4TH FLOOR - 10 NOS	Babu. D.,Sasikumar. S.,Udhaya Shankar. P.	All the 10 unit installed.		Revathy. N. - Canteen-Girls Hostel	29/11/2022
Comp. Dt. : 26/12/2022 Status : Completed								
72	22121162	J.R Quateres	HOT WATER NOT COMING IN COOLER	Sasikumar. S.	Switch directed to the power supply due to thermostat problem.		Virgin Mary - Canteen-Girls Hostel	27/12/2022
Dept Name : Cath Lab - Air Condition Department Comp. Dt. : 26/07/2022 Status : Completed								
73	22070981	Cath Lab	NEED TO CHECK AC COOLING - AC NOT WORKING	Manikandan. A. R.	Capacitor 50 mfd changed.		Muthukumaran. S. - Cath Lab	05/09/2022
Dept Name : Civil - Execution - Air Condition Department Comp. Dt. : 22/12/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
74	22121036	Orthopaedics - OPD	AC OUTLINE REMOVING WORK IN ORTHO DEMO CLASS	Ramesh. P.	Plumbing complaint.		Sivamurugan. M - Civil - Execution	23/12/2022
Dept Name : Computer Department - Air Condition Department Comp. Dt. : 20/05/2022 Status : Completed								
75	22050738	EDP IN UNDERGROUND	New AC installation in EDP server room	Panneer Selvam. P.	New AC installed.		Selvam. D. - Computer Department	20/06/2022
Comp. Dt. : 26/05/2022 Status : Completed								
76	22050968	EDP IN UNDERGROUND	Sever room AC no cooling	Panneer Selvam. P.	Outdoor unit serviced.		Selvam. D. - Computer Department	20/06/2022
77	22050969	EDP IN UNDERGROUND	New AC need to install in sever room	Panneer Selvam. P.	New AC installed.		Selvam. D. - Computer Department	20/06/2022
Comp. Dt. : 19/04/2023 Status : Completed								
78	23040617	BASEMENT AUDITORIUM	Ac water leakage and ac not working	Vasanthakumar. V.	DRAIN TRAY CLEANED AND SERVICED. RAT BITTEN WIRE REJOINED AND INSULATED.		Selvam. D. - Computer Department	24/04/2023
Comp. Dt. : 24/05/2023 Status : Completed								
79	23050957	BASEMENT AUDITORIUM	AC WATER LEAKAGE - 9TH AC	Vasanthakumar. V.	DRAIN TRAY AND DRAIN LINE CLEANED AND SERVICED.		Shafiullah. R. - Computer Department	25/05/2023
Dept Name : FORENSIC MEDICINE - Air Condition Department Comp. Dt. : 20/12/2022 Status : Completed								
80	22120894	A.P Quateres	AC NOT WORKING IN DEAN QUATERES (AP1) 1ST FLOOR	Sasikumar. S.	Drain tray cleaned and water service done.		Mathavi. B. - FORENSIC MEDICINE	21/12/2022
Comp. Dt. : 16/03/2023 Status : Completed								
81	23030660	FORENSIC MEDICINE	DEAN SIR QUATERS AC NOT WORKING	Sasikumar. S.	BUSH ADJUSTMENT DONE		Mathavi. B. - FORENSIC MEDICINE	17/03/2023
Dept Name : Guest House - Indian Bank - Air Condition Department Comp. Dt. : 24/05/2023 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
82	23050959	Guest House - Director Quarters	AC WATER LECKAGE AT ROOM NO 101	Phillipkumar. D.	DRAIN TRAY CLEANED AND SERVICED.		John. H. - Guest House - Indian Bank	29/05/2023
Dept Name : Library - Air Condition Department Comp. Dt. : 24/05/2023 Status : Completed								
83	23050973	Library	AC WATER LEAKAGE AT 11 FLOOR	Udhaya Shankar. P.	DRAIN TRAY CLEANED AND SERVICED.		Elangovan.N. - Library	25/05/2023
Dept Name : Marketing Team - Air Condition Department Comp. Dt. : 16/03/2023 Status : Completed								
84	23030666	Special Ward - A	ROOM NO 5 AC WATER LEAKAGE	Vasanthakumar. V.	DRAIN TRAY CLEANED AND SERVICED.		Vijayalakshmi. V. - Marketing Team	17/03/2023
Dept Name : Medical Records - Air Condition Department Comp. Dt. : 18/04/2023 Status : Completed								
85	23040553	Female Surgery - Ward 207	FRIDGE NOT WORKING	Gnanapragasam. N.	BREAKER TRIP MANUALLY ON IT.		Pushparaj. J. - Medical Records	20/04/2023
Dept Name : Nephrology - Air Condition Department Comp. Dt. : 24/06/2023 Status : Completed								
86	23060922	DIALYSIS NEW UNIT IN 1ST FLOOR	WATER PURIFYER LEAKAGE	Vasanthakumar. V.	tap adjusted.		Aathimoolam. R. - Nephrology	27/06/2023
Dept Name : Operation Theatre - Air Condition Department Comp. Dt. : 23/06/2022 Status : Completed								
87	22060859	SPECIALITY OT	AC WATER LEAKAGE IN AHU ROOM	Panneer Selvam. P.	Plumbing department complaint.		Sobiya. N. - Operation Theatre	05/09/2022
Dept Name : Radio Diagnosis - Air Condition Department Comp. Dt. : 20/12/2022 Status : Completed								
88	22120941	XRay	IN CR ROOM AC WATER LEAKING	Gnanapragasam. N.	Drain tray cleaned and serviced.		Manikandan.V. - Radio Diagnosis	23/12/2022
Dept Name : Special Ward - Air Condition Department Comp. Dt. : 19/11/2022 Status : Completed								
89	22110816	Special Ward - A	COOLING WATER NOT COMING IN COOLER	Thulasi Daran. R.,Ramesh. P.,Pragash. P.	Water cooler switch burnt. Direct it.		Shrathi. R. - Special Ward	22/11/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 18/04/2023 Status : Completed								
90	23040544	Special Ward - A	COOLER WATER LEAKAGE	Gnanapragasam. N.	NEW TAP CHANGED.		Revathi. S. - Special Ward	16/05/2023
Comp. Dt. : 24/05/2023 Status : Completed								
91	23050958	Special Ward - A	AC NOT WORKING - ROOM NO 3	Vasanthakumar. V.	BREAKER TRIP. MANUALLY ON		Ragavi. P. - Special Ward	25/05/2023
College Name : SMVMCH-COL Work Type : Complaint Dept Name : ANATOMY - Air Condition Department Comp. Dt. : 06/06/2022 Status : Completed								
92	22060194	ANATOMY	AC SOUND PROBLEM IN HOS SIR ROOM	Udhaya Shankar. P.	Blower bush problem. Grease applied,. Sound rectified.		Sakthivel. S. - ANATOMY	27/06/2022
Comp. Dt. : 01/09/2022 Status : Completed								
93	22090030	ANATOMY	FRIDGE NOT WORKING	Sasikumar. S.	Freezer fan stand broken. Stand pasted.		Mathivanan.B. - ANATOMY	09/09/2022
Comp. Dt. : 04/05/2023 Status : Completed								
94	23050142	ANATOMY	AC NOT WORKING [HOD ROOM]	Saravanan. C.	WORK COMPLETED		Mathivanan.B. - ANATOMY	07/06/2023
Dept Name : BIOCHEMISTRY - Air Condition Department Comp. Dt. : 09/06/2022 Status : Completed								
95	22060336	BIOCHEMISTRY	AC WATER LEAKAGE	Ramesh. P.	Indoor unit serviced.		Srinivasamurugan. V. - BIOCHEMISTRY	27/06/2022
Comp. Dt. : 30/06/2022 Status : Completed								
96	22061112	Central Research Lab	AC NOT WORKING	Sasikumar. S.	Rat bitten the wire. Wire rejoined and taped it.		Anusuya. J. - BIOCHEMISTRY	09/09/2022
Comp. Dt. : 18/08/2022 Status : Completed								
97	22080598	Biochemistry Lab-Hospital	IN CR LAB-REFRIDGEREATOR NOT WORKING	Sasikumar. S.	No problem. Working normally.		Anusuya. J. - BIOCHEMISTRY	05/09/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 06/09/2022 Status : Completed								
98	22090201	Central Research Lab	AC NOT WORKING	Babu. D.,Manikandan. A. R.,Elumalai. J.	Rat bitten the wire. Wire rejoined and taped it.		Anusuya. J. - BIOCHEMISTRY	09/09/2022
Comp. Dt. : 15/09/2022 Status : Completed								
99	22090617	Central Research Lab	AC NOT WORKING	Sasikumar. S.	New compressor changed.		Anusuya. J. - BIOCHEMISTRY	21/09/2022
Comp. Dt. : 20/04/2023 Status : Completed								
100	23040668	BIOCHEMISTRY--COLLEGE	AC NOT WORKING AT DEMO ROOM NO 1	Sasikumar. S.	BREAKER TRIP. MANUALLY ON IT		Suganthi. P. - BIOCHEMISTRY	18/05/2023
Dept Name : Canteen-Girls Hostel - Air Condition Department Comp. Dt. : 02/09/2022 Status : Completed								
101	22090089	Ladies hostel Phase-I	ROOM NUMBER 44 AC NOT WORKING	Sasikumar. S.	PC board removed and serviced.		Revathy. N. - Canteen-Girls Hostel	09/09/2022
Dept Name : COMMUNITY MEDICINE - Air Condition Department Comp. Dt. : 16/06/2022 Status : Completed								
102	22060608	COMMUNITY MEDICINE DEPT IN MEDICAL COLLEGE	AC NOT WORKING IN HOD ROOM	Sasikumar. S.	Indoor unit serviced.		Muthuvel. A. - COMMUNITY MEDICINE	06/08/2022
Comp. Dt. : 22/08/2022 Status : Completed								
103	22080711	COMMUNITY MEDICINE DEPT IN MEDICAL COLLEGE	AC NOT WORKING IN PROF ROOM	Udhaya Shankar. P.	Outdoor wire burnt. New wire changed.		Muthuvel. A. - COMMUNITY MEDICINE	05/09/2022
Dept Name : Computer Department - Air Condition Department Comp. Dt. : 13/06/2022 Status : Completed								
104	22060479	DIGITAL LAB	DUE RAT INSIDE THE AC - NEED AC SERVICE	Udhaya Shankar. P.	Removed the rat. and service the unit		Valamburi. R. - Computer Department	06/08/2022
Comp. Dt. : 15/06/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
105	22060547	DIGITAL LAB	DUE TO DEATH OF RAT BAD SMELL SPEARD - NEED AC SERVICE URGENT	Sasikumar. S.	Removed the dead rat. Gas top up work done		Jayaraj. J. - Computer Department	06/08/2022
Comp. Dt. : 03/09/2022 Status : Completed								
106	22090141	DIGITAL LAB	NEED TO CHECK AC COOLING AT SERVER ROOM	Sasikumar. S.	Gas charged. Unit is working		Shafiullah. R. - Computer Department	21/09/2022
Comp. Dt. : 20/04/2023 Status : Completed								
107	23040665	DIGITAL LAB	AC NOT WORKING	Sasikumar. S.	Connector serviced and refixed.		Venkatesh. S. - Computer Department	22/04/2023
Comp. Dt. : 05/06/2023 Status : Completed								
108	23060150	DIGITAL LAB	NEED TO CHECK AC COOLING	Sasikumar. S.	WIRE REJOINED AND INSULATED.		Madhubalan. S. - Computer Department	07/06/2023
Dept Name : Director Office - Air Condition Department Comp. Dt. : 30/05/2022 Status : Completed								
109	22051068	LECTURE HALL V	NEED AC SERVICE [FOR ALL AC'S]	Sasikumar. S.	All unit AC serviced.		Prasanna.B. - Director Office	20/06/2022
Comp. Dt. : 08/06/2022 Status : Completed								
110	22060317	MEU HALL IN MEDICAL COLLEGE	AC NOT WORKING	Sasikumar. S.	Wiring problem. rejoined the wire with insulation tap		Prasanna.B. - Director Office	27/06/2022
Comp. Dt. : 27/06/2022 Status : Completed								
111	22060977	Lecture Hall 3	AHU 1 NO NOT WORKING	Sasikumar. S.	Stator switch problem. Switch changed.		Prasanna.B. - Director Office	09/09/2022
Comp. Dt. : 01/09/2022 Status : Completed								
112	22090011	LECTURE HALL 1 AND 2 IN MEDICAL COLLEGE	AC NOT WORKING -, NEED URGENT SERVICE	Sasikumar. S.	Power problem. Problem rectified.		Prasanna.B. - Director Office	09/09/2022
Comp. Dt. : 05/09/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
113	22090195	Director Office	NEED TO CHECK AC COOLING - AC NOT WORKING	Sasikumar. S.	Rat bitten the wire. Rejoined the wire		Raman. P. - Director Office	09/09/2022
	Comp. Dt. : 07/09/2022							
	Status : Completed							
114	22090255	LECTURE HALL V	AC WATER LEAKAGE	Ramesh. P.	Drain tray cleaned and serviced.		Prasanna.B. - Director Office	07/09/2022
	Comp. Dt. : 18/11/2022							
	Status : Completed							
115	22110784	Lecture Hall1	NEED TO CHECK AC AT LECTURE HALL 1	Sasikumar. S.,Babu. D.,Udhaya Shankar. P.	Bearing changed.		Prasanna.B. - Director Office	25/11/2022
	Comp. Dt. : 07/12/2022							
	Status : Completed							
116	22120329	Lecture Hall1	AC NOT WORKING	Sasikumar. S.,Udhaya Shankar. P.,Babu. D.	Outdoor fan capacitor changed.		Prasanna.B. - Director Office	10/12/2022
	Comp. Dt. : 26/12/2022							
	Status : Completed							
117	22121188	MEDICAL COLLEGE	2NOS AC NOT WORKING IN LECTURE HALL	Sasikumar. S.	New breaker changed.		Prasanna.B. - Director Office	27/12/2022
	Comp. Dt. : 28/12/2022							
	Status : Completed							
118	22121304	Director Office	IN DINING HALL-A/C NOT WORKING	Sasikumar. S.	Drain line changed.		Maithily. M. - Director Office	30/12/2022
	Comp. Dt. : 19/01/2023							
	Status : Completed							
119	23010675	Lecture Hall1	DUE TO STARTING CLASSES NEED TO CHECK ALL AC MACHINES	Sasikumar. S.	ALL AC CHECKING, Good working condition.		Bala Murugan.K. - Director Office	23/01/2023
	Comp. Dt. : 20/02/2023							
	Status : Completed							
120	23020764	LECTURE HALL V	AC WATER LEAKAGE	Sasikumar. S.	DRAIN TRAY CLEANED AND SERVICED.		Prasanna.B. - Director Office	21/02/2023
	Comp. Dt. : 22/03/2023							
	Status : Completed							
121	23030934	Lecture Hall1	AC NOT WORKING	Sasikumar. S.	BREAKER TRIP. MANUALLY ON		Prasanna.B. - Director Office	25/03/2023
	Comp. Dt. : 11/04/2023							

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
122	23040310	Council Room	AC NOT WORKING	Sasikumar. S.	RAT BITTEN WIRING CONNECTION REJOINING AND INSULATED.		Karthikeyan. R. - Director Office	13/04/2023
Comp. Dt. : 22/04/2023								
Status : Completed								
123	23040714	Dean Office	AC WATER LEAKAGE - NEED URGENT SERVICE	Sasikumar. S.	DRAIN TRAY CLEANED AND SERVICED.		Karthikeyan. R. - Director Office	24/04/2023
Comp. Dt. : 06/05/2023								
Status : Completed								
124	23050229	LECTURE HALL V	NEED ALL AC SERVICE	Sasikumar. S.	ALL AC UNIT SERVICED.		Prasanna.B. - Director Office	11/05/2023
Comp. Dt. : 08/05/2023								
Status : Completed								
125	23050303	MEDICAL COLLEGE I FLOOR	COOLER NOT WORKING	Manikandan. A. R.	COOLER BOTTOM BASE FIXED.		Bala Murugan.K. - Director Office	25/05/2023
Comp. Dt. : 26/06/2023								
Status : Completed								
126	23060972	Lecture Hall1	AC NOT WORKING	Sasikumar. S.	Old Actuator changed.		Prasanna.B. - Director Office	03/07/2023
Dept Name : FORENSIC MEDICINE - Air Condition Department								
Comp. Dt. : 08/06/2022								
Status : Completed								
127	22060292	DEAN HOUSE	NEED AC SERVICE & CLEANING WORK - PROF QUARTERS NO 2	Sasikumar. S.	2nos,. indoor unit serviced.		Mathavi. B. - FORENSIC MEDICINE	27/06/2022
Comp. Dt. : 07/09/2022								
Status : Completed								
128	22090264	FORENSIC MEDICINE (3RD FLOOR) IN COLLEGE	AC WATER LEAKAGE AT DEMO ROOM	Sasikumar. S.	Drain block removed and serviced.		Mathavi. B. - FORENSIC MEDICINE	07/09/2022
Comp. Dt. : 29/12/2022								
Status : Completed								
129	22121339	FORENSIC MEDICINE (3RD FLOOR) IN COLLEGE	IN DEAN SIR ROOM-A/C NOT WORKING	Sasikumar. S.	Contactoer changed.		Mathavi. B. - FORENSIC MEDICINE	31/12/2022
Comp. Dt. : 28/03/2023								
Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
130	23031206	FORENSIC MEDICINE (3RD FLOOR) IN COLLEGE	AC NOT WORKING	Manikandan. A. R.	LOCK ADJUSTMENT DONE. CABIN REDUCED.		Mathavi. B. - FORENSIC MEDICINE	29/03/2023
Comp. Dt. : 19/04/2023 Status : Completed								
131	23040592	FORENSIC MEDICINE (3RD FLOOR) IN COLLEGE	AC WATER LEKAGE - [HOD ROOM] - NEED URGENT SERVICE	Sasikumar. S.	Drain tray cleaned and serviced.		Mathavi. B. - FORENSIC MEDICINE	22/04/2023
Dept Name : Housekeeping - Air Condition Department Comp. Dt. : 15/02/2023 Status : Completed								
132	23020605	MEDICAL COLLEGE LIBRARY	NEED TO CHECK AC COOLING AT GROUND FLOOR	Sasikumar. S.	RAT BITTEN THE WIRE. REJOIN AND INSULATED,		Elangchezhiyan. R. - Housekeeping	17/02/2023
Comp. Dt. : 16/04/2023 Status : Completed								
133	23040466	MEDICAL COLLEGE LIBRARY	NEED TO CHECK AC COOLING - AC NOT WORKING AT GROUND FLOOR	Sasikumar. S.	Breaker changed.		Elangchezhiyan. R. - Housekeeping	22/04/2023
Dept Name : Library - Air Condition Department Comp. Dt. : 09/07/2022 Status : Completed								
134	22070371	MEDICAL COLLEGE LIBRARY	AC SOUND PROBLEM AT GROUND FLOOR	Sasikumar. S.	Rat inside the blower. Removed the rat		Elangovan.N. - Library	06/08/2022
Comp. Dt. : 13/07/2022 Status : Completed								
135	22070493	MEDICAL COLLEGE LIBRARY	AC SOUND PROBLEM AT GROUND FLOOR	Sasikumar. S.	Outdoor fan blade problem. Change the blade.		Lakshmi Gandhan.S. - Library	06/08/2022
Comp. Dt. : 15/07/2022 Status : Completed								
136	22070569	MEDICAL COLLEGE LIBRARY	NEED CLEANING WORK - DUE TO DEATH OF RAT - BAD SMELL IN GROUND FLOOR READING HALL -	Sasikumar. S.	Removed the rat		Elangovan.N. - Library	06/08/2022
Comp. Dt. : 16/07/2022 Status : Completed								
137	22070617	medical college library 2nd floor	NEED TO CHECK COOLER - NOT WORKING	Sasikumar. S.	Outdoor unit wire burnt, Rejoint the wire. Unit is working.		Elangovan.N. - Library	09/09/2022

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 10/12/2022								
Status : Completed								
138	22120476	MEDICAL COLLEGE LIBRARY	IN 1ST FLOOR-A/C NO.1 NOT WORKING	Sasikumar. S.	fan motor refixing work is done		Lakshmi Gandhan.S. - Library	22/12/2022
Comp. Dt. : 15/12/2022								
Status : Completed								
139	22120737	MEDICAL COLLEGE LIBRARY	AC WATER LEAKAGE - GROUND FLOOR	Sasikumar. S.	Indoor unit cleaned and serviced.		Elangovan.N. - Library	20/12/2022
Comp. Dt. : 31/12/2022								
Status : Completed								
140	22121390	MEDICAL COLLEGE LIBRARY	IN 1ST FLOOR-LESS COOLING FROM A/C	Sasikumar. S.	Outdoor fan capacitor change it.		Elangovan.N. - Library	11/01/2023
Comp. Dt. : 23/02/2023								
Status : Completed								
141	23020914	MEDICAL COLLEGE LIBRARY	AC NOT WORKING	Sasikumar. S.	WIRE LOOSE CONNECTION. TIGHTENED THE WIRE CONNECTION.		Elangovan.N. - Library	28/02/2023
Comp. Dt. : 29/03/2023								
Status : Completed								
142	23031268	medical college library 2nd floor	AC - TRIP PROBLEM	Sasikumar. S.	NEW BREAKER CHANGED.		Elangovan.N. - Library	03/04/2023
Comp. Dt. : 19/05/2023								
Status : Completed								
143	23050820	medical college library 2nd floor	AC WATER LEAKAGE	Sasikumar. S.	DRAIN TRAY CLEAN AND SERVICED.		Elangovan.N. - Library	22/05/2023
Comp. Dt. : 20/05/2023								
Status : Completed								
144	23050840	MEDICAL COLLEGE LIBRARY	AC NOT WORKING AT GROUND FLOOR LIBRARY	Sasikumar. S.	OUTDOOR FAN MOTOR CAPACITOR CHANGE IT, 3 MFD.		Kumar. A. - Library	22/05/2023
Comp. Dt. : 12/06/2023								
Status : Completed								
145	23060421	MEDICAL COLLEGE LIBRARY	NEED TO CLOSE AC DUCT DOOR AT GROUND FLOOR	Udhaya Shankar. P.	DOOR CLOSED PROPERLY		Elangovan.N. - Library	14/06/2023
Comp. Dt. : 15/06/2023								
Status : Completed								
146	23060536	Library	2ND FLOOR A/C -COOLING PROBLEM	Sasikumar. S.	Rat bitten the wire. Wire rejoin and insulated.		Elangovan.N. - Library	16/06/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Dept Name : MICROBIOLOGY - Air Condition Department Comp. Dt. : 02/05/2022 Status : Completed								
147	22050036	LECTURE HALL V	AC WATER LEAKAGE IN LECTURER HALL V	Sasikumar. S.	Indoor unit serviced.		Buvana. C. - MICROBIOLOGY	06/06/2022
Comp. Dt. : 06/05/2022 Status : Completed								
148	22050220	MICROBIOLOGY IN COLLEGE	NEED AC SERVICE FOR LECTURER HALL NO 5	Sasikumar. S.	Indoor unit serviced.		Gopal. R. - MICROBIOLOGY	06/06/2022
Comp. Dt. : 28/05/2022 Status : Completed								
149	22051047	MICROBIOLOGY IN COLLEGE	DEEP FREEZER DISPLAY "-80"	Sasikumar. S.	Not AC department problem		Anandh. P. - MICROBIOLOGY	06/08/2022
Comp. Dt. : 30/05/2022 Status : Completed								
150	22051076	MICROBIOLOGY IN COLLEGE	D FREEZER [-80] NOT WORKING	Sasikumar. S.	Not AC department problem.		Gopal. R. - MICROBIOLOGY	06/08/2022
151	22051105	MICROBIOLOGY IN COLLEGE	NEED TO CHECK AC COOLING - AC NOT WORKING AT II FLOOR PCR LAB	Sasikumar. S.	PC board problem. Removed the PC board and serviced.		Udhaya Sankar. R. - MICROBIOLOGY	06/08/2022
Comp. Dt. : 01/06/2022 Status : Completed								
152	22060023	LECTURE HALL V	NEED AC SERVICE	Sasikumar. S.	5nos. split AC unit serviced		Raffik Moideen. M. - SMV Allied Health Sciences	20/06/2022
Comp. Dt. : 26/07/2022 Status : Completed								
153	22070973	MICROBIOLOGY IN COLLEGE	NEED TO CHECK AC COOLING - AC WATER LEAKAGE & NOT WORKING	Sasikumar. S.	Indoor unit serviced.		Gopal. R. - MICROBIOLOGY	09/09/2022
Comp. Dt. : 01/08/2022 Status : Completed								
154	22080039	MICROBIOLOGY IN COLLEGE	AC WATER LEAKAGE	Sasikumar. S.	Indoor unit serviced.		Praveenkumar. S. - MICROBIOLOGY	09/09/2022
Comp. Dt. : 26/08/2022 Status : Completed								
155	22080907	MICROBIOLOGY IN COLLEGE	NEED AC MECHANIC HELP	Sasikumar. S.	AC cabin removed.		Gopal. R. - MICROBIOLOGY	09/09/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 07/09/2022								
Status : Completed								
156	22090271	MICROBIOLOGY IN COLLEGE	NEED TO CHECK FRIDGE - PROBLEM IN CONTROLLER	Sasikumar. S.	Controller changed.		Anandh. P. - MICROBIOLOGY	09/09/2022
Comp. Dt. : 07/10/2022								
Status : Completed								
157	22100164	MICROBIOLOGY IN COLLEGE	DEEP FREEZER NOT WORKING	Sasikumar. S.	Freezer unit condemn		Buvana. C. - MICROBIOLOGY	12/10/2022
Comp. Dt. : 11/10/2022								
Status : Completed								
158	22100275	MICROBIOLOGY IN COLLEGE	AC WATER LEAKAGE	Sasikumar. S.	Water leakage arrested,		Gopal. R. - MICROBIOLOGY	12/10/2022
Comp. Dt. : 11/11/2022								
Status : Completed								
159	22110463	MICROBIOLOGY IN COLLEGE	IN CR LAB-REFRIDGERATOR NOT WORKING	Sasikumar. S.,Udhaya Shankar. P.,Babu. D.	Refridgerator defreezing work done.		Anandh. P. - MICROBIOLOGY	14/11/2022
Comp. Dt. : 18/11/2022								
Status : Completed								
160	22110800	MICROBIOLOGY IN COLLEGE	AC - WATER LEAKAGE	Sasikumar. S.,Udhaya Shankar. P.,Babu. D.	Foam damaged. new foam changed.		Praveenkumar. S. - MICROBIOLOGY	22/11/2022
Comp. Dt. : 28/11/2022								
Status : Completed								
161	22111183	MICROBIOLOGY IN COLLEGE	A/C WATER LEAKAGING PROBLEM	Sasikumar. S.,Udhaya Shankar. P.,Babu. D.	Indoor unit serviced.		Praveenkumar. S. - MICROBIOLOGY	30/11/2022
Comp. Dt. : 29/11/2022								
Status : Completed								
162	22111243	MICROBIOLOGY IN COLLEGE	A/C WATER LEAKAGING PROBLEM	Sasikumar. S.,Udhaya Shankar. P.,Babu. D.	Rat bitten the wire. wire then rejoined and insulated.		Praveenkumar. S. - MICROBIOLOGY	01/12/2022
Comp. Dt. : 02/12/2022								
Status : Completed								
163	22120097	MICROBIOLOGY IN COLLEGE	AC WATER LEAKAGE	Sasikumar. S.,Udhaya Shankar. P.,Babu. D.	Drain tray cleaned and serviced.		Yuvaraj. P. - MICROBIOLOGY	14/12/2022
Comp. Dt. : 06/12/2022								
Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
164	22120218	MICROBIOLOGY IN COLLEGE	AC NOT WORKING	Sasikumar. S.,Udhaya Shankar. P.,Babu. D.	Indoor unit coil service.		Anandh. P. - MICROBIOLOGY	10/12/2022
	Comp. Dt. : 04/01/2023 Status : Completed							
165	23010177	MICROBIOLOGY IN COLLEGE	IN PCR ROOM-A/C NOT WORKING	Sasikumar. S.	R-32 GAS TOP UP 1KG Work is done.		Mageswari. R. - MICROBIOLOGY	23/01/2023
	Comp. Dt. : 18/03/2023 Status : Completed							
166	23030746	MICROBIOLOGY IN COLLEGE	NEED TO CHECK AC COOLING	Sasikumar. S.	INDOOR AND OUTDOOR CLEANED AND SERVICED.		Kanimozhi. K. - MICROBIOLOGY	25/03/2023
	Comp. Dt. : 30/03/2023 Status : Completed							
167	23031315	MICROBIOLOGY IN COLLEGE	NEED TO CHECK FRIDGE - WATER LEAKAGE	Sasikumar. S.	DRAIN TRAY CLEANED AND SERVICED.		Nivethighaa. G. - MICROBIOLOGY	03/04/2023
	Comp. Dt. : 08/05/2023 Status : Completed							
168	23050322	MICROBIOLOGY IN COLLEGE	WATER LEAKAGE IN FRIDGE	Manikandan. A. R.	DRAIN PIPE CLEAN AND SERVICED.		Mageswari. R. - MICROBIOLOGY	11/05/2023
	Comp. Dt. : 12/05/2023 Status : Completed							
169	23050494	MICROBIOLOGY IN COLLEGE	NEED TO CHECK AC - PROBEM IN COOLING	Sasikumar. S.	50 MFD CAPACITOR CHANGED.		Sathiya. G. - MICROBIOLOGY	16/05/2023
	Comp. Dt. : 18/05/2023 Status : Completed							
170	23050725	MICROBIOLOGY IN COLLEGE	AC NOT WORKING	Sasikumar. S.	50 MFD CAPACITOR CHANGED.		Sathiya. G. - MICROBIOLOGY	19/05/2023
	Comp. Dt. : 06/06/2023 Status : Completed							
171	23060184	MICROBIOLOGY IN COLLEGE	NEED AC SERVICE	Sasikumar. S.	DRAIN TRAY CLEANED AND SERVICED.		Gopal. R. - MICROBIOLOGY	09/06/2023
	Comp. Dt. : 08/06/2023 Status : Completed							
172	23060277	MICROBIOLOGY IN COLLEGE	NEED TO CHECK AC COOLING - AC NOT WORKING AT BACTERIOLOGY ROOM	Sasikumar. S.	R22 GAS TOP UP.. 20PSI		Mageswari. R. - MICROBIOLOGY	12/06/2023
	Comp. Dt. : 26/06/2023							


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
173	23060935	MICROBIOLOGY IN COLLEGE	B O D MACHINE [2NOS] NOT WORKING	Sasikumar. S.	Not an AC complaint		Mageswari. R. - MICROBIOLOGY	27/06/2023
Dept Name : MS Office - Air Condition Department								
Comp. Dt. : 28/10/2022								
Status : Completed								
174	22100888	SKILL LAB - MEDICAL COLLEGE	SKILL LAB AC NOT WORKING IN ROOM NO. 1	Sasikumar. S.,Udhaya Shankar. P.,Babu. D.	Remote mode changed.		Prabhakaran. S. - Medical Records	28/10/2022
Comp. Dt. : 27/04/2023								
Status : Completed								
175	23040919	SKILL LAB - MEDICAL COLLEGE	AC NOT WORKING	Vasanthakumar. V.	ELECTRICAL POWER DISTRIBUTION PROBLEM.		Elumalai. M. - MS Office	29/04/2023
Dept Name : PATHOLOGY - Air Condition Department								
Comp. Dt. : 09/06/2022								
Status : Completed								
176	22060355	PATHOLOGY IN COLLEGE	AC NOT WORKING	Udhaya Shankar. P.	Compressor problem. Need to change		Thavamani. K. - PATHOLOGY	06/08/2022
Comp. Dt. : 13/09/2022								
Status : Completed								
177	22090477	PATHOLOGY IN COLLEGE	NEED TO CHECK FRIDGE TEMPERATURE	Sasikumar. S.	New probe fixed.		Kalaichelvi.M. - PATHOLOGY	21/09/2022
Comp. Dt. : 28/10/2022								
Status : Completed								
178	22100879	PATHOLOGY IN COLLEGE	AC NOT WORKING	Sasikumar. S.,Udhaya Shankar. P.,Babu. D.	Capacitor Problem. New Capcitor 50 mfd changed.		Sathia Rajesh. C. - PATHOLOGY	28/10/2022
Comp. Dt. : 29/11/2022								
Status : Completed								
179	22111202	PATHOLOGY IN COLLEGE	TEMPERATURE PROBE NOT WORKING	Sasikumar. S.	New probe changed.		Sathia Rajesh. C. - PATHOLOGY	30/11/2022
Comp. Dt. : 25/04/2023								
Status : Completed								
180	23040804	PATHOLOGY IN COLLEGE	AC NOT WORKING	Udhaya Shankar. P.	55 mfd capacitor changed.		Sathia Rajesh. C. - PATHOLOGY	28/04/2023
Comp. Dt. : 08/05/2023								
Status : Completed								
181	23050261	PATHOLOGY IN COLLEGE	AC NOT WORKING AT LAB	Udhaya Shankar. P.	RAT BITTEN WIRE REJOINED AND INSULATED.		Kalaichelvi.M. - PATHOLOGY	09/05/2023

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHAL KUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 02/06/2023 Status : Completed								
182	23060076	PATHOLOGY	NEED TO CHECK AC - COOLING PROBLEM	Sasikumar. S.	INDOOR AND OUTDOOR SERVICED...		Thavamani. K. - PATHOLOGY	12/06/2023
Comp. Dt. : 23/06/2023 Status : Completed								
183	23060885	PATHOLOGY IN COLLEGE	AC NOT WORKING	Sasikumar. S.	R22 gas 1.25kg filled.		Sathia Rajesh. C. - PATHOLOGY	26/06/2023
Dept Name : PHARMACOLOGY - Air Condition Department Comp. Dt. : 09/02/2023 Status : Completed								
184	23020339	PHARMACOLOGY	AC NOT WORKING IN RESEARCH LAB	Manikandan. A. R.	PC BOARD SERVICED AND REFIXED.		Panchali. P. - PHARMACOLOGY	22/02/2023
Dept Name : PHYSIOLOGY - Air Condition Department Comp. Dt. : 06/05/2022 Status : Completed								
185	22050200	PHYSIOLOGY--COLLEGE	AC NOT WORKING IN HOD ROOM	Sasikumar. S.	leak arrest and gas charged with vaccum. unit is working.		Shanthini. M. - BIOCHEMISTRY	29/05/2022
Comp. Dt. : 03/06/2022 Status : Completed								
186	22060096	PHYSIOLOGY--COLLEGE	AC NOT WORKING IN HOD ROOM	Sasikumar. S.	Compressor problem. Spare compressor changed.		Balasankar. P. - PHYSIOLOGY	20/06/2022
Comp. Dt. : 17/03/2023 Status : Completed								
187	23030693	PHYSIOLOGY--COLLEGE	AC NOT WORKING - HOD ROOM	Sasikumar. S.	REMOTE BATTERY CHANGED.		Balasankar. P. - PHYSIOLOGY	20/03/2023
Dept Name : SMV Allied Health Sciences - Air Condition Department Comp. Dt. : 09/12/2022 Status : Completed								
188	22120423	LECTURE HALL V	NEED AC SERVICE	Babu. D.,Sasikumar. S.,Udhaya Shankar. P.	Indoor unit cleaned and serviced.		Raffik Moideen. M. - SMV Allied Health Sciences	20/12/2022
Comp. Dt. : 27/01/2023 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
189	23010987	LECTURE HALL V	IN COLLEGE SIDE LECTURE HALL 5-A/C WATER LEAKAGING PROBLEM	Sasikumar. S.	Drain dray clean and serviced.		Selvasundari. R. - SMV Allied Health Sciences	31/01/2023
Comp. Dt. :		30/05/2023						
Status :		Completed						
190	23051188	LECTURE HALL V	NEED AC - TECHNICIAN FOR CHECKING ALL AC ITEMS - GENERAL SERVICE	Sasikumar. S.	INDOOR UNIT COIL AND FILTER SERVICED.		Raffik Moideen. M. - SMV Allied Health Sciences	31/05/2023

College Name : SMVMCH-HOS

Work Type : Complaint

Dept Name : Administration - Air Condition Department

Comp. Dt. : 04/05/2022

Status : Completed

191	22050090	AO Office	ICE WATER NOT COMING IN COOLER	Pragash. P.	Hot and Cold condenser leak. condenser serviced		Gomathy. K. - Administration	29/05/2022

Comp. Dt. : 09/05/2022

Status : Completed

192	22050270	AO Office	DUE DEATHH OF RAT - BAD SMELL - NEED AC SERVICE AT RECEPTION	Babu. D.	Duct grill cleaned and serviced. Refixed the grill		Elumalai.K.A. - Administration	02/06/2022

Comp. Dt. : 27/05/2022

Status : Completed

193	22051027	General Stores[Linen]	AC NOT WORKING AT LAB REAGENT STORE AREA	Panneer Selvam. P.	Waiting for new split AC		Motheeswarar. R.S. - Administration	20/06/2022

Comp. Dt. : 20/06/2022

Status : Completed

194	22060709	AO Office	AC NOT WORKING - RECEPTION AREA	Manikandan. A. R.	Remote reset		Elumalai.K.A. - Administration	27/06/2022

Comp. Dt. : 15/07/2022

Status : Completed

195	22070585	AO Office	PROBLEM IN AIR COOLER	Panneer Selvam. P.	Filter cleaned.		Karthik. K. - Administration	05/09/2022

Comp. Dt. : 08/09/2022

Status : Completed

196	22090326	General Stores[Linen]	AC NOT WORKING - A Z STORAGE AREA	Panneer Selvam. P.,Babu. D.,Amarajothi.V.	Standby AC refixed.		Motheeswarar. R.S. - Administration	13/09/2022

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 09/09/2022 Status : Completed								
197	22090359	General Stores[Linen]	AC NOT WORKING AT V A Z STORAGE AREA	Thulasi Daran. R.,Ramesh. P.,Pragash. P.	Standby AC refixed. Unit is working.		Motheeswarar. R.S. - Administration	13/09/2022
Comp. Dt. : 14/09/2022 Status : Completed								
198	22090526	General Stores[Linen]	AC WATER LEAKAGE AT AGENT STORAGE ROOM	Panneer Selvam. P.,Amarajothi.V.,Babu. D.	Indoor unit water serviced.		Motheeswarar. R.S. - Administration	17/09/2022
Comp. Dt. : 16/09/2022 Status : Completed								
199	22090630	General Stores[Linen]	AC NOT WORKING	Panneer Selvam. P.,Babu. D.,Thulasi Daran. R.	Indoor unit serviced.		Arulkumaran. S. - Administration	17/09/2022
Comp. Dt. : 20/09/2022 Status : Completed								
200	22090773	AO Office	WATER LEAKAGE IN AC PIPELINE AT DINING HALL	Thulasi Daran. R.	Water leakage arrested		Karthik. K. - Administration	21/09/2022
Comp. Dt. : 21/09/2022 Status : Completed								
201	22090816	General Stores[Linen]	AT AGENT STORAGE AREA AC WATER LEAKAGE & NO COOLING - NEED TO CHECK	Babu. D.,Ramesh. P.,Pragash. P.	Low gas in unit. Gas charged. Unit working;		Motheeswarar. R.S. - Administration	26/09/2022
Comp. Dt. : 24/09/2022 Status : Completed								
202	22090987	AO Office	NEED TO CHECK AC AT RECORD ROOM - WATER LEAKAGE NEED URGENT SERVICE	Manikandan. A. R.,Babu. D.,Vijay. M.	Ductable unit serviced with water pressure pump.		Elumalai.K.A. - Administration	26/09/2022
Comp. Dt. : 29/09/2022 Status : Completed								
203	22091183	General Stores[Linen]	AC WATER LEAKAGE AT KIT STORAGE AREA	Vasanthakumar. V.	Water leakage arrested.		Motheeswarar. R.S. - Administration	06/10/2022
Comp. Dt. : 05/10/2022 Status : Completed								
204	22100049	General Stores[Linen]	AC NOT WORKING IN REAGENT STORAGE AREA	Panneer Selvam. P.,Vijay. M.,Vasanthakumar. V.	Spare A/C unit fixed.		Motheeswarar. R.S. - Administration	29/11/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 09/11/2022								
Status : Completed								
205	22110358	GENERAL STORE	REFRIDGERATOR WATER LEAKAGING PROBLEM	Elumalai. J.	Work in progress.		Manikandan. S. - Administration	11/11/2022
Comp. Dt. : 11/11/2022								
Status : Completed								
206	22110477*	GENERAL STORE	FRIDGE NOT WORKING	Elumalai. J.	Compressor changed.		Manikandan. S. - Administration	29/11/2022
Comp. Dt. : 15/11/2022								
Status : Completed								
207	22110576	GENERAL STORE	FRIDGE PROBLEM-WIRE CONNECTION NEED TO BE CHECK	Gnanapragasam. N.	New compressor changed.		Motheeswarar. R.S. - Administration	29/11/2022
Comp. Dt. : 06/12/2022								
Status : Completed								
208	22120257	GENERAL STORE	REFRIDGERATOR NO COOLING	Vijay. M.	New condensor coil cooling coil stainer and capillary tube change it.		Manikandan. S. - Administration	11/01/2023
Comp. Dt. : 09/12/2022								
Status : Completed								
209	22120410	General Stores[Linen]	FRIDGE NOT WORKING [AGAIN PROBLEM]	Vijay. M.	New condensor coil cooling coil stainer and capillary tube change it,		Motheeswarar. R.S. - Administration	11/01/2023
Comp. Dt. : 13/03/2023								
Status : Completed								
210	23030498	General Stores[Linen]	AC NOT WORKING - RE AGENT STORAGE AREA	Ramesh. P.	COMPRESSOR WIRE BURNT. NEW CLIP WIRE CHANGED.		Motheeswarar. R.S. - Administration	14/03/2023
Comp. Dt. : 23/03/2023								
Status : Completed								
211	23030983	AO Office	AC NOT WORKING IN ENTRANCE	Manikandan. A. R.	CONNECTOR SERVICED AND REFIXED.		Elumalai.K.A. - Administration	29/03/2023
Comp. Dt. : 30/03/2023								
Status : Completed								
212	23031321	AO Office	AC NOT WORKING	Ramesh. P.	Contactora changed.		Karthik. K. - Administration	01/04/2023
Comp. Dt. : 10/04/2023								
Status : Completed								
213	23040274	General Stores[Linen]	AC NOT WORKING	Gnanapragasam. N.	NEW 50 MFD CAPACITOR CHANGE		Manikandan. S. - Administration	11/04/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 09/05/2023 Status : Completed								
214	23050364	AO Office	AC WATER LEAKGE AT DINNING ROOM	Pragash. P.	DRAIN TRAY CLEAN AND SERVICED.		Kadhiravan. C. - Administration	11/05/2023
Comp. Dt. : 24/05/2023 Status : Completed								
215	23050945	AO Office	NEED TO SERVICE WATER PURIFIER	Ramesh. P.	WATER PURIFIER CLEANED AND SERVICED.		Gomathy. K. - Administration	25/05/2023
Comp. Dt. : 02/06/2023 Status : Completed								
216	23060077	AO Office	AC NOT WORKING AT RECEPTION	Pragash. P.	POWER PROBLEM		Elumalai.K.A. - Administration	06/06/2023
Dept Name : Audit Wing - Air Condition Department Comp. Dt. : 02/05/2023 Status : Completed								
217	23050038	AO Office	AC NOT WORKING	Vasanthakumar. V.	36 MFD CAPACITOR CHANGED.		Hari Ram Singh. B. - Audit Wing	05/05/2023
Dept Name : BIOCHEMISTRY - Air Condition Department Comp. Dt. : 02/09/2022 Status : Completed								
218	22090094	GENERAL STORE	AC NOT WORKING	Panneer Selvam. P.	Standby AC refixed.		Srinivasamurugan. V. - BIOCHEMISTRY	13/09/2022
Comp. Dt. : 13/12/2022 Status : Completed								
219	22120608	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	AC WATER FLOW - NEED URGENT SERVICE	Ramesh. P.	Drain tray cleaned and serviced.		Ramya. B. - BIOCHEMISTRY	14/12/2022
Comp. Dt. : 06/02/2023 Status : Completed								
220	23020158	BIOCHEMISTRY	FRIDGE PANEL NOT WORKING	Gnanapragasam. N.	PROBE CHANGED.		Srinivasamurugan. V. - BIOCHEMISTRY	13/02/2023
Comp. Dt. : 03/04/2023 Status : Completed								
221	23040046	BIOCHEMISTRY	NEED TO CHECK AC COOLING - AC NOT WORKING	Vasanthakumar. V.	INDOOR AND OUTDOOR CLEANED AND SERVICED.		Ranjitha. M - BIOCHEMISTRY	04/04/2023
Comp. Dt. : 28/06/2023 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
222	23061042	BIOCHEMISTRY	NEED TO CHECK FRIDGE TEMPERATURE PANEL - NOT WORKING	Amarajothi.V.	New battery changed.		Srinivasamurugan. V. - BIOCHEMISTRY	28/06/2023
Dept Name : BLOOD BANK - Air Condition Department Comp. Dt. : 18/05/2022 Status : Completed								
223	22050659	Blood Bank	AC NOT WORKING	Panneer Selvam. P.	Outdoor unit fan motor problem. Rewinding work done		Sivasankari.I. - BLOOD BANK	27/06/2022
Comp. Dt. : 03/06/2022 Status : Completed								
224	22060140	Blood Bank	AC WATER LEAKAGE	Panneer Selvam. P.	Indoor unit serviced.		Sivasankari.I. - BLOOD BANK	27/06/2022
Comp. Dt. : 10/06/2022 Status : Completed								
225	22060403	Blood Bank	A/C WATER LEAKAGING PROBLEM	Manikandan. A. R.	Indoor unit serviced.		Sangavi. S. - BLOOD BANK	27/06/2022
Comp. Dt. : 26/08/2022 Status : Completed								
226	22080872	Blood Bank	AC NOT WORKING	Panneer Selvam. P.	1.5 TR compressor changed. Capillary tube, stainer, R 22 gas 1.5kg changed.		Ganesh. V. - BLOOD BANK	20/09/2022
Comp. Dt. : 05/10/2022 Status : Completed								
227	22100074	Blood Bank	AC NOT WORKING	Gnanapragasam. N.,Vasanthakumar. V.,Vijay. M.	45 mfd capacitor changed.		Ganesh. V. - BLOOD BANK	06/10/2022
Comp. Dt. : 25/11/2022 Status : Completed								
228	22111121	Blood Bank	NEED TO CHECK AC COOLING - AC NOT WORKING	Vasanthakumar. V.,Gnanapragasam. N.,Manikandan. A. R.	Compressor changed.		Sivasankari.I. - BLOOD BANK	24/01/2023
Comp. Dt. : 24/01/2023 Status : Completed								
229	23010852	Blood Bank	AC NOT WORKING	Vasanthakumar. V.	Capacitor 50 mfd changed.		Ganesh. V. - BLOOD BANK	25/01/2023
Comp. Dt. : 10/02/2023 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
230	23020369	Blood Bank	AC WATER LEAKAGE	Vijay. M.	DRAIN TRAY CLEANED AND DRAIN PIPE LINE BLOCK REMOVED.		Sangavi. S. - BLOOD BANK	13/02/2023
	Comp. Dt. : 13/02/2023							
	Status : Completed							
231	23020490	Blood Bank	FRIDGE NOT WORKING	Vijay. M.	RELAY CHANGED		Ganesh. V. - BLOOD BANK	14/02/2023
	Comp. Dt. : 27/02/2023							
	Status : Completed							
232	23021031	Blood Bank	AC WATER LEAKAGE & POWER PROBLEM	Gnanapragasam. N.	DRAIN LINE CLEANING WORK DONE		Divyabharathi. A. - BLOOD BANK	28/02/2023
	Comp. Dt. : 13/03/2023							
	Status : Completed							
233	23030503	Blood Bank	STABILIZER NOT WORKING	Gnanapragasam. N.	ELECTRICAL DEPARTMENT COMPLAINT		Ganesh. V. - BLOOD BANK	14/03/2023
	Comp. Dt. : 01/04/2023							
	Status : Completed							
234	23040023	Blood Bank	AC WATER LEAKAGE	Vasanthakumar. V.	DRAIN TRAY CLEANED AND SERVICED.		Ganesh. V. - BLOOD BANK	03/04/2023
	Comp. Dt. : 04/04/2023							
	Status : Completed							
235	23040102	Blood Bank	NEED TO CHECK AC COOLING IN COMPONENT ROOM	Phillipkumar. D.	R22 GAS (25 PSI)TOP UP AND 50 MFD CAPACITOR CHANGED.		Thirumangai. S. - BLOOD BANK	04/04/2023
	Comp. Dt. : 16/05/2023							
	Status : Completed							
236	23050657	Blood Bank	AC NOT WORKING - SOUND PROBLEM & WATER LEAKAGE	Phillipkumar. D.	DRAIN TRAY CLEANED AND SERVICED. SWING MOTOR PROBE ADJUSTED.		Lakshmi.K. - BLOOD BANK	18/05/2023
	Comp. Dt. : 29/05/2023							
	Status : Completed							
237	23051132	Blood Bank	AC WATER LEAKAGE	Vasanthakumar. V.	dDRAIN TRAY CLEANED AND SERVICED.		Ganesh. V. - BLOOD BANK	31/05/2023
	Comp. Dt. : 30/05/2023							
	Status : Completed							
238	23051202	Blood Bank	AC NOT WORKING & ALSO BURNT SMELL	Vasanthakumar. V.	unit condmned.		Radhika. S. - BLOOD BANK	19/06/2023
	Comp. Dt. : 07/06/2023							

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
239	23060235	Blood Bank	NEED TO CHECK AC COOLING AT RECEPTION	Ramesh. P.	MODE CHANGED MANUALLY		Sangavi. S. - BLOOD BANK	08/06/2023
Comp. Dt. : 19/06/2023								
Status : Completed								
240	23060658	Blood Bank	AC NOT WORKING	Gnanapragasam. N.	Breaker trip. manually on		Ganesh. V. - BLOOD BANK	19/06/2023
Comp. Dt. : 30/06/2023								
Status : Completed								
241	23061132	Blood Bank	AC NOT WORKING	Phillipkumar. D.,Vasanthakumar. V.,Vijay. M.	3 pin plug burnt. New pin changed.		Sangavi. S. - BLOOD BANK	01/07/2023
Dept Name : Canteen - Boys Hostel - Air Condition Department								
Comp. Dt. : 06/05/2022								
Status : Completed								
242	22050205	Boys hostel P.H-III	NEED TO CHECK AC COOLING FOR ROOM NO 16	Sasikumar. S.	Checked the unit working. Indoor unit celaned and serviced.		Sambasivam. K. - Canteen - Boys Hostel	06/06/2022
Comp. Dt. : 09/05/2022								
Status : Completed								
243	22050254	Boys hostel P.H-III	NEED AC SERVICE - AC NOT COOLING ROOM NO 33	Sasikumar. S.	Outdoor unit not working. 55mfd capacitor changed.		Sambasivam. K. - Canteen - Boys Hostel	06/06/2022
Comp. Dt. : 17/05/2022								
Status : Completed								
244	22050632	Boys hostel P.H-III	NEED AC SERVICE - AC NOT COOLING ROOM NO 15	Sasikumar. S.	Indoor unit serviced.		Sambasivam. K. - Canteen - Boys Hostel	20/06/2022
Comp. Dt. : 17/06/2022								
Status : Completed								
245	22060646	Boys hostel P.H-III	AC WATER LEAKAGE - ROOM NO 10	Sasikumar. S.	Indoor unit serviced		Sambasivam. K. - Canteen - Boys Hostel	27/06/2022
Comp. Dt. : 14/07/2022								
Status : Completed								
246	22070537	Boys hostel Phase-II	NEED TO CHECK COOLER COOLING AT IV FLOOR & DINNING HALL NO II	Sasikumar. S.	Serviced the cooler		Sambasivam. K. - Canteen - Boys Hostel	06/08/2022
Comp. Dt. : 29/07/2022								
Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
247	22071049	Boys hostel P.H-III	AC NOT WORKING - COOLING PROBLEM & WATER LEAKAGE - NEED SERVICE FOR ROOM NO 33	Sasikumar. S.	Terminal wire burnt.		Sambasivam. K. - Canteen - Boys Hostel	09/09/2022
Comp. Dt. : 03/08/2022 Status : Completed								
248	22080125*	Dining Hall	NEED TO CHECK COOLER - NOT WORKING AT DINING HALL NO 1	Sasikumar. S.	New Compressor changed.		Sambasivam. K. - Canteen - Boys Hostel	14/12/2022
249	22080126	Boys hostel Phase-II	NEED TO CHECK COOLER - SHOCK PROBLEM AT IV FLOOR	Sasikumar. S.	Water enters inside compressor. Problem rectified.		Sambasivam. K. - Canteen - Boys Hostel	09/09/2022
Comp. Dt. : 06/08/2022 Status : Completed								
250	22080232	Boys hostel P.H-III	AC WATER LEAKAGE - ROOM NO 36	Sasikumar. S.	10 cu gas topup		Sambasivam. K. - Canteen - Boys Hostel	09/09/2022
Comp. Dt. : 09/08/2022 Status : Completed								
251	22080308	Boys hostel P.H-III	NEED AC GENERAL SERVICE FOR ROOM NO 11 ,12,15,16,17 & 20	Sasikumar. S.	Indoor unit serviced.		Sambasivam. K. - Canteen - Boys Hostel	09/09/2022
Comp. Dt. : 11/08/2022 Status : Completed								
252	22080399	Boys hostel P.H-III	NEED TO CHECK AC COOLING - NEED AC SERVICE - ROOM NO 33 - NEED URGENT SERVICE	Sasikumar. S.	Indoor unit serviced.		Sambasivam. K. - Canteen - Boys Hostel	09/09/2022
Comp. Dt. : 20/08/2022 Status : Completed								
253	22080678	Boys hostel P.H-III	AC WATER LEAKAGE ROOM NO 41	Sasikumar. S.	Indoor unit serviced.		Sambasivam. K. - Canteen - Boys Hostel	09/09/2022
Comp. Dt. : 30/08/2022 Status : Completed								
254	22081024	Boys hostel P.H-III	DUE TO RAIN WATER COMING INSIDE THE ROOM NEED TO CLOSED AIR PIPE HOLES - ROOM NO 44	Sasikumar. S.	Holes packed.		Sambasivam. K. - Canteen - Boys Hostel	09/09/2022
Comp. Dt. : 05/09/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
255	22090169	Boys hostel P.H-III	NEED TO CHECK AC COOLING FOR ROOM NO 33	Sasikumar. S.	Capacitor problem. New capacitor changed.		Sambasivam. K. - Canteen - Boys Hostel	09/09/2022
Comp. Dt. : 05/10/2022 Status : Completed								
256	22100040	Boys hostel P.H-III	AC REMOTE NOT WORKING - ROOM NO 14	Pragash. P.	New remote handed over		Sambasivam. K. - Canteen - Boys Hostel	12/10/2022
Comp. Dt. : 18/10/2022 Status : Completed								
257	22100560	Boys hostel P.H-III	AC NOT WORKING - ROOM NO 6	Sasikumar. S.,Udhaya Shankar. P.,Babu. D.	Outdoor capacitor 55mfd + fan capacitor 5 mfd changed.		Mathubalan. M. - Canteen - Boys Hostel	19/10/2022
Comp. Dt. : 01/12/2022 Status : Completed								
258	22120005	Boys hostel P.H-III	AC REMOTE SENSOR NOT WORKING - ROOM NO 2 ,9 20	Sasikumar. S.,Udhaya Shankar. P.,Babu. D.	Remote battery changed.		Sambasivam. K. - Canteen - Boys Hostel	02/12/2022
259	22120008	Boys hostel P.H-III	AC NOT WORKING TRIP PROBLEM - ROOM NO 35	Babu. D.,Sasikumar. S.,Udhaya Shankar. P.	Breaker trip. New compressor, Capacitor, Stainer changed. R22 (1.5 kg) gas charged.		Sambasivam. K. - Canteen - Boys Hostel	02/12/2022
Comp. Dt. : 08/12/2022 Status : Completed								
260	22120349	BOYS HOSTEL MESS	NEED TO REFIX VEGITABLE CUTTER BLADE [COMPLAINT DEVERTED FROM WORKSHOP DEPARTMENT]	Babu. D.	Complaint forwarded to Work shop.		Elumalai. M. - Canteen - Boys Hostel	20/12/2022
Comp. Dt. : 17/02/2023 Status : Completed								
261	23020685	Boys hostel P.H-III	AC WATER LEAKAGE - ROOM NO 31	Babu. D.	DRAIN TRAY CLEANED AND SERVICED.		Sambasivam. K. - Canteen - Boys Hostel	18/02/2023
Comp. Dt. : 17/03/2023 Status : Completed								
262	23030715	Boys hostel P.H-III	AC DISPLAY NOT WORKING ROOM NO 14	Babu. D.	DISPLAY CHANGED.		Sambasivam. K. - Canteen - Boys Hostel	25/03/2023
Comp. Dt. : 10/04/2023 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
263	23040287	Boys hostel	NEED TO CHECK COOLING TUBE AT MILK ROOM	Babu. D.	NEW FAN MOTOR FIXED.		Elumalai. M. - Canteen - Boys Hostel	13/04/2023
Comp. Dt. : 11/05/2023 Status : Completed								
264	23050443	Boys hostel P.H-III	AC NOT WORKING - ROOM NO 9	Sasikumar. S.	BURNED WIRE REJOINED AND INSULATED.		Sambasivam. K. - Canteen - Boys Hostel	12/05/2023
Comp. Dt. : 13/05/2023 Status : Completed								
265	23050538	Boys hostel P.H-III	COOLER NOT WORKING AT III FLOOR	Babu. D.	breaker trip manually on		Sambasivam. K. - Canteen - Boys Hostel	17/05/2023
Comp. Dt. : 22/05/2023 Status : Completed								
266	23050871	Boys hostel	NEED TO CHECK FREEZER COOLING - PROBLEM	Babu. D.	NEW FAN MOTOR FIXED.		Elumalai. M. - Canteen - Boys Hostel	25/05/2023
Comp. Dt. : 24/05/2023 Status : Completed								
267	23050967	Boys hostel P.H-III	AC SENSOR PROBLEM - ROOM NO 14	Babu. D.	work completed		Sambasivam. K. - Canteen - Boys Hostel	07/06/2023
Comp. Dt. : 30/05/2023 Status : Completed								
268	23051185	Boys hostel P.H-III	AC WATER LEAKAGE - ROOM NO 33	Babu. D.	DRAIN TRAY CLEANED AND SERVICED		Sambasivam. K. - Canteen - Boys Hostel	31/05/2023
Comp. Dt. : 19/06/2023 Status : Completed								
269	23060648	Boys hostel P.H-III	AC WATER LEAKAGE - ROOM NO 12	Babu. D.	Drain tray cleaned and serviced.		Mathubalan. M. - Canteen - Boys Hostel	20/06/2023
Comp. Dt. : 26/06/2023 Status : Completed								
270	23060988	Boys hostel P.H-III	NEED TO CHECK AC COOLING - ROOM NO 36	Babu. D.	55 MFD CAPACITOR CHANGE IT.		Sambasivam. K. - Canteen - Boys Hostel	28/06/2023
Comp. Dt. : 02/07/2023 Status : Completed								
Dept Name : Canteen-Girls Hostel - Air Condition Department								
Comp. Dt. : 02/05/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
271	22050008	Ladies hostel Phase-I	AC NOT WORKING - ROOM NO 54	Sasikumar. S.	Stablizer relay weak. Stablizer is removed and direct the powersupply		Revathy. N. - Canteen-Girls Hostel	29/05/2022
Comp. Dt. : 04/05/2022 Status : Completed								
272	22050097	Ladies hostel Phase-I	AC REMOTE NOT WORKING - ROOM NO 5	Sasikumar. S.	New AC remote given.		Revathy. N. - Canteen-Girls Hostel	06/06/2022
Comp. Dt. : 06/05/2022 Status : Completed								
273	22050191	Ladies hostel Phase-I	NEED AC SERVICE FOR ROOM NO 53 & NEED NEW STABILIZER FOR ROOM NO 1,29,& 51	Sasikumar. S.	Room no.53, indoor unit serviced. 3nos of new stablizer fixed.		Revathy. N. - Canteen-Girls Hostel	06/06/2022
Comp. Dt. : 09/05/2022 Status : Completed								
274	22050248	Ladies hostel Phase-I	NEED AC SERVICE FOR ROOM NO 25,44,53	Sasikumar. S.	room no. 53 remote problem. New remote given. Stablizer problem at room no. 44. Direct the power sup		Revathy. N. - Canteen-Girls Hostel	06/06/2022
275	22050282	JR Quarters	NEED TO FIX COOLER FOR ROOM NO 4	Sasikumar. S.	New cooler fixed.		Virgin Mary - Canteen-Girls Hostel	06/06/2022
Comp. Dt. : 26/05/2022 Status : Completed								
276	22050979	Ladies hostel Phase-I	NEED AC SERVICE FOR ROOM NO 52	Sasikumar. S.	Indoor unit serviced & Outdoor unit 5mfd capcitor changed.		Revathy. N. - Canteen-Girls Hostel	20/06/2022
277	22050991	Ladies hostel Phase-I	AC WATER LEAKAGE - ROOM NO 3	Sasikumar. S.	Indoor unit serviced.		Revathy. N. - Canteen-Girls Hostel	20/06/2022
Comp. Dt. : 13/06/2022 Status : Completed								
278	22060459	Ladies hostel Phase-I	NEED TO INSTALL NEW AC - ROOM NO 58	Sasikumar. S.	New AC installed.		Revathy. N. - Canteen-Girls Hostel	27/06/2022
Comp. Dt. : 21/06/2022 Status : Completed								
279	22060772	Ladies hostel Phase-I	NEED INSTALLATION WORK FOR NEW COOLER [3 NOS]	Udhaya Shankar. P.	2nos. new cooler installed. 1no. problem.		Revathy. N. - Canteen-Girls Hostel	27/06/2022
Comp. Dt. : 24/06/2022 Status : Completed								
280	22060869	LADIES HOSTEL MESS	NEED TO CHECK COOLER - NOT COOLING	Sasikumar. S.	New cooler problem. Need to replace		Revathy. N. - Canteen-Girls Hostel	06/08/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 29/06/2022 Status : Completed								
281	22061053	Ladies hostel Phase-I	AC NOT WORKING - ROOM NO 29	Sasikumar. S.	Indoor unit serviced.		Revathy. N. - Canteen-Girls Hostel	06/08/2022
Comp. Dt. : 04/07/2022 Status : Completed								
282	22070119	Ladies hostel Phase-I	AC NOT WORKING - ROOM NO 44	Sasikumar. S.	Indoor unit serviced.		Revathy. N. - Canteen-Girls Hostel	06/08/2022
Comp. Dt. : 29/07/2022 Status : Completed								
283	22071057	JR Quarters	NEED NEW COOLER INSTALLATION WORK FOR I FLOOR	Sasikumar. S.	New cooler fixed.		Virgin Mary - Canteen-Girls Hostel	09/09/2022
Comp. Dt. : 20/08/2022 Status : Completed								
284	22080665	Ladies hostel Phase-I	NEED TO REFIX I & II FLOOR COOLER	Sasikumar. S.	Cooler fixed.		Revathy. N. - Canteen-Girls Hostel	09/09/2022
Comp. Dt. : 29/08/2022 Status : Completed								
285	22080956	Ladies hostel Phase-I	NEED AC SERVICE - WATER LEAKAGE - ROOM NO 1,3,4,24,45 & 55	Sasikumar. S.	Indoor unit serviced.		Revathy. N. - Canteen-Girls Hostel	09/09/2022
Comp. Dt. : 13/10/2022 Status : Completed								
286	22100395	Ladies hostel Phase-I	AC NOT WORKING ROOM NO 41	Sasikumar. S., Udhaya Shankar. P., Babu. D.	Outdoor capacitor 45 mfd + 4 mfd fan capacitor changed.		Revathy. N. - Canteen-Girls Hostel	19/10/2022
Comp. Dt. : 02/12/2022 Status : Completed								
287	22120074	Ladies hostel Phase-I	AC NOT WORKING - ROOM NO.78	Sasikumar. S., Udhaya Shankar. P., Babu. D.	Stablizer removed. Direct the power supply		Revathy. N. - Canteen-Girls Hostel	03/12/2022
Comp. Dt. : 05/12/2022 Status : Completed								
288	22120155	Ladies hostel Phase-I	AC NOT WORKING ROOM NO 17	Sasikumar. S., Udhaya Shankar. P., Babu. D.	Capacitor changed.		Revathy. N. - Canteen-Girls Hostel	14/12/2022
Comp. Dt. : 27/02/2023 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
289	23021039	Ladies hostel Phase-I	AC & REMOTE NOT WORKING ROOM NO 78	Sasikumar. S.	MODE CHANGED MANUALLY		Revathy. N. - Canteen-Girls Hostel	28/02/2023
	Comp. Dt. : 17/03/2023							
	Status : Completed							
290	23030692	Ladies hostel Phase-I	NEED TO CHECK AC COOLING ROOM NO 16	Babu. D.	CONTACTOR CHANGED.		Revathy. N. - Canteen-Girls Hostel	20/03/2023
	Comp. Dt. : 28/03/2023							
	Status : Completed							
291	23031214	Ladies hostel Phase-I	AC NOT WORKING ROOM NO 24	Udhaya Shankar. P.	BREAKER TRIP. MANUALLY ON		Revathy. N. - Canteen-Girls Hostel	03/04/2023
	Comp. Dt. : 29/03/2023							
	Status : Completed							
292	23031247	Ladies hostel Phase-I	AC NOT WORKING ROOM NO 22	Sasikumar. S.	R22 GAS TOP UP (30 PSI)		Revathy. N. - Canteen-Girls Hostel	03/04/2023
	Comp. Dt. : 11/04/2023							
	Status : Completed							
293	23040324	Ladies hostel Phase-II	AC WATER LEAKAGE NEED URGENT SERVICE - ROOM NO 113	Sasikumar. S.	DRAIN TRAY CLEANED AND SERVICED.		Malliga. K. - Canteen-Girls Hostel	15/04/2023
	Comp. Dt. : 13/04/2023							
	Status : Completed							
294	23040396	Ladies hostel Phase-I	AC NOT WORKING ROOM NO 24	Sasikumar. S.	45 MFD CAPCITOR CHANGED.		Revathy. N. - Canteen-Girls Hostel	15/04/2023
295	23040411	Ladies hostel Phase-I	AC NOT WORKIGN ROOM NO 14	Sasikumar. S.	OUTDOOR FAN MOTOR CAPCITOR 5 MFD CHANGED		Revathy. N. - Canteen-Girls Hostel	15/04/2023
	Comp. Dt. : 26/04/2023							
	Status : Completed							
296	23040872	LADIES HOSTEL MESS	COOLER NOT WORKING	Sasikumar. S.	Drain tray adjusted and screw tighten		Revathy. N. - Canteen-Girls Hostel	28/04/2023
297	23040877	Ladies hostel Phase-I	AC NOT WORKING - ROOM NO 25	Sasikumar. S.	OUTDOOR SPARE FANMOTOR FIXED.		Revathy. N. - Canteen-Girls Hostel	29/04/2023
	Comp. Dt. : 12/05/2023							
	Status : Completed							
298	23050477	Ladies hostel Phase-I	AC NOT WORKING - ROOM NO 14	Sasikumar. S.	RAT BITTEN THE WIRE. WIRE REJOINED AND INSULATED.		Revathy. N. - Canteen-Girls Hostel	16/05/2023
	Comp. Dt. : 13/05/2023							
	Status : Completed							
299	23050549	Ladies hostel Phase-II	PROBLEM IN III FLOOR COOLER	Sasikumar. S.	NEW FAN MOTOR FIXED.		Malliga. K. - Canteen-Girls Hostel	25/05/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 15/05/2023 Status : Completed								
300	23050569	Ladies hostel Phase-I	AC NOT WORKING - ROOM NO 22	Sasikumar. S.	ALTERNATIVE OUTDOOR FANMOTOR CHANGE IT.WORK HAS BEEN DONE.		Revathy. N. - Canteen-Girls Hostel	22/05/2023
Comp. Dt. : 19/05/2023 Status : Completed								
301	23050791	Ladies hostel Phase-II	AC WATER LEAKAGE - ROOM NO 101	Sasikumar. S.	DRAIN TRAY CLEANED AND SERVICED.		Malliga. K. - Canteen-Girls Hostel	20/05/2023
Comp. Dt. : 07/06/2023 Status : Completed								
302	23060247	Ladies hostel Phase-II	COOLER NOT WORKING AT III FLOOR	Sasikumar. S.	NEW COOLER FAN MOTOR FIXED		Malliga. K. - Canteen-Girls Hostel	09/06/2023
Comp. Dt. : 09/06/2023 Status : Completed								
303	23060341	Ladies hostel Phase-II	AC NOT WORKING - ROOM NO 12	Sasikumar. S.	RAT BITTEN THE WIRE. WIRE REJOINED AND INSULATED.		Revathy. N. - Canteen-Girls Hostel	13/06/2023
Comp. Dt. : 13/06/2023 Status : Completed								
304	23060442	Ladies hostel Phase-II	AC WATER LEAKGE ROOM NO 101 & LEAKAGE WATER GOES TO ROOM NO 77	Manikandan. A. R.	drain tray cleaned and serviced.		Malliga. K. - Canteen-Girls Hostel	14/06/2023
Comp. Dt. : 26/06/2023 Status : Completed								
305	23060961	JR Quarters	COOLER LEAKAGE AT I FLOOR & GROUND FLOOR	Sasikumar. S.	New foam fixed.		Virgin Mary - Canteen-Girls Hostel	28/06/2023
Comp. Dt. : 28/06/2023 Status : Completed								
306	23061054	Ladies hostel Phase-II	COOLER NOT WORKING AT III FLOOR	Sasikumar. S.	Drain tray cleaned and serviced.		Malliga. K. - Canteen-Girls Hostel	04/07/2023
Dept Name : CARDIOLOGY - Air Condition Department Comp. Dt. : 28/05/2022 Status : Completed								
307	22051041	ECHO CARDIO GRAM	NEED TO CHECK AC COOLING	Pragash. P.	Indoor unit serviced.		Aarthi. A. - CARDIOLOGY	27/06/2022
Comp. Dt. : 09/07/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
308	22070358	ECHO CARDIO GRAM	NEED TO CHECK AC COOLING	Panneer Selvam. P.	Indoor unit water service.		Aarthi. A. - CARDIOLOGY	05/09/2022
Comp. Dt. : 19/07/2022 Status : Completed								
309	22070718	SUPER SPECILAITY OPD IN 2ND FLOOR	AC WOUND PROBLEM - IN EYE BANK	Vijay. M.,Thulasi Daran. R.,Ramesh. P.	Indoor unit water serviced.		Priyanka. M. - CARDIOLOGY	05/09/2022
Comp. Dt. : 27/08/2022 Status : Completed								
310	22080942	ECHO CARDIO GRAM	AC NOT WORKING	Pragash. P.,Ramesh. P.,Vasanthakumar. V.	Pc board serviced and refixed. r22 Gas charged to 1 kg		Aarthi. A. - CARDIOLOGY	10/09/2022
Comp. Dt. : 12/09/2022 Status : Completed								
311	22090452	EYE Bank	AC NOT WORKING - II FLOOR EYE BANK	Babu. D.,Vijay. M.,Manikandan. A. R.	Power problem. Problem rectified.		Priyanka. M. - CARDIOLOGY	13/09/2022
Comp. Dt. : 10/11/2022 Status : Completed								
312	22110436	Cath Lab	A/C WATER LEAKAGING PROBLEM	Elumalai. J.	Drain tray cleaned and serviced.		Deva Arul Selva Sagayaraj. A. - CARDIOLOGY	11/11/2022
Comp. Dt. : 24/11/2022 Status : Completed								
313	22111062	EYE Bank	A/C NOT WORKING	Udhaya Shankar. P.	Breaker trip. ON it manually		Priyanka. M. - CARDIOLOGY	26/11/2022
Comp. Dt. : 13/04/2023 Status : Completed								
314	23040409	ECHO CARDIO GRAM	NEED TO CHECK AC COOLING	Phillipkumar. D.	INDOOR FILTER AND COIL CHANGED.		Chitra. V. - CARDIOLOGY	15/04/2023
Comp. Dt. : 26/06/2023 Status : Completed								
315	23060991	Cath Lab	AC NOT WORKING	Phillipkumar. D.	55 mfd capacitor changed. Drain tray cleaned and serviced.		Deva Arul Selva Sagayaraj. A. - CARDIOLOGY	27/06/2023
Dept Name : Cardiothoracic ICU - Air Condition Department Comp. Dt. : 02/05/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
316	22050015	CT-ICU ROOM-NEAR ORTHO OT RECOVERY ROOM	FRIDGE TEMPERATURE PANEL NOT WORKING	Babu. D.	New probe changed.		Isaivani. R. - Cardiothoracic ICU	06/06/2022
317	22050038	CT-ICU ROOM-NEAR ORTHO OT RECOVERY ROOM	NEED AC GRILL SERVICE	Pragash. P.	AHU and Grill serviced.		Gunasegar. K. - Cardiothoracic ICU	06/06/2022
Comp. Dt. : 27/06/2022								
Status : Completed								
318	22060952	SPECIAL WARD---B	AC WATER LEAKAGE	Ramesh. P.	Drain tray cleaned and serviced.		Nilavu. K. - Cardiothoracic POW	05/09/2022
Comp. Dt. : 09/05/2023								
Status : Completed								
319	23050362	CTVS-FEMALE PRE-OP ROOM INSIDE SPECIAL WARD B	AC NOT WORKING & WATER LEAKAGE	Gnanapragasam. N.	DRAIN PIPE LINE BLOCK REMOVED.		Rosaria Baska Rani - Cardiothoracic ICU	11/05/2023
Comp. Dt. : 31/05/2023								
Status : Completed								
320	23051241	CT-ICU ROOM-NEAR ORTHO OT RECOVERY ROOM	AC NOT WORKING	Vijay. M.	AHU COIL FULLY CLEANED AND SERVICED.		Sadham Husain. S. - Cardiothoracic ICU	01/06/2023
321	23051261	CT-POST OPERATIVE WARD IN 4TH FLOOR	NEED TO CHECK AC - POWER PROBLEM - [MALE PRE OPP]	Vasanthakumar. V.	POWER PROBLEM		Rosaria Baska Rani - Cardiothoracic ICU	06/06/2023
Dept Name : Cardiothoracic POW - Air Condition Department								
Comp. Dt. : 01/06/2022								
Status : Completed								
322	22060026	CT-POST OPERATIVE WARD IN 4TH FLOOR	AC WATER LEAKAGE	Thulasi Daran. R.	Oil chock removed.Flush and gas charged.		Praveena. M. - Cardiothoracic POW	20/06/2022
Comp. Dt. : 30/06/2022								
Status : Completed								
323	22061105	CT POW -SPECIAL WARD B	AC WATER LEAKAGE	Manikandan. A. R.	Indoor unit serviced.		Jenifer Mary. P. - Cardiothoracic POW	06/08/2022
Comp. Dt. : 02/07/2022								
Status : Completed								
324	22070054	CT POW -SPECIAL WARD B	AC WATER LEAKAGE	Ramesh. P.	Indoor unit serviced with water pressure pump		Praveena. M. - Cardiothoracic POW	05/09/2022
Comp. Dt. : 13/10/2022								
Status : Completed								
325	22100378	CT POW -SPECIAL WARD B	AC [2 NOS] NOT WORKING [WATER LEAKAGE & COOLING] AT FEMALE PRE OPP	Pragash. P.	Remote mode changed manually		Jenifer Mary. P. - Cardiothoracic POW	19/10/2022

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 13/12/2022 Status : Completed								
326	22120586	CT-POST OPERATIVE WARD IN 4TH FLOOR	AC NOT WORKING	Ramesh. P.	Rat bitten the wire. Rejoined and insulated.		Jenifer Mary. P. - Cardiothoracic POW	14/12/2022
Comp. Dt. : 23/03/2023 Status : Completed								
327	23030943	CT POW -SPECIAL WARD B	AC WATER LEAKAGE & AC NOT WORKING	Ramesh. P.	DRAIN TRAY CLEANED.		Sathiavani. A. - Cardiothoracic POW	25/03/2023
Comp. Dt. : 20/04/2023 Status : Completed								
328	23040629	CTVS-FEMALE PRE-OP ROOM INSIDE SPECIAL WARD B	AC NOT WORKING IN LUNG ROOM NEED URGENT SERVICE [INTERCOM NO 1459]	Vijay. M.	REMOTE COOL MODE CHANGE IT		Sathiavani. A. - Cardiothoracic POW	20/04/2023
Comp. Dt. : 07/06/2023 Status : Completed								
329	23060241	CT-POST OPERATIVE WARD IN 4TH FLOOR	AC WATER LEAKAGE - [INTERCOM NO 1459]	Vijay. M.	drain tray cleaned and serviced.		Sathiavani. A. - Cardiothoracic POW	08/06/2023
Comp. Dt. : 26/06/2023 Status : Completed								
330	23060985	CT POW -SPECIAL WARD B	AC NOT WORKING	Phillipkumar. D.	Wire burnt. New wire changed and insulated.		Sathiavani. A. - Cardiothoracic POW	10/07/2023
Comp. Dt. : 27/06/2023 Status : Completed								
331	23061012	CT POW -SPECIAL WARD B	AC NOT WORKING	Phillipkumar. D.	Wire burnt. New wire changed and insulated.		Srimathi. V. - Cardiothoracic POW	10/07/2023
Dept Name : Cath Lab - Air Condition Department Comp. Dt. : 13/05/2022 Status : Completed								
332	22050462	CARDIOLOGY OPD	A/C WATER LEAKAGING PROBLEM	Thulasi Daran. R.	Indoor unit serviced.		Muthukumaran. S. - Cath Lab	02/06/2022
Comp. Dt. : 10/11/2022 Status : Completed								
333	22110390	Cath Lab	AC WATER LEAKAGE	Pragash. P.	Drain tray cleaned and serviced.		Muthukumaran. S. - Cath Lab	11/11/2022
Comp. Dt. : 24/06/2023 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
334	23060904	Cath Lab	AC WATER LEAKAGE	Vasanthakumar. V.	55 mfd capacitor changed and drain tray cleaned and serviced.		Muthukumaran. S. - Cath Lab	27/06/2023
Comp. Dt. : 27/06/2023 Status : Completed								
335	23061002	Cath Lab	AC WATER LEAKAGE - REPEAT COMPLAINT	Pragash. P.	55 mfd capacitor changed. Drain pipe cleaned and serviced.		Muthukumaran. S. - Cath Lab	27/06/2023
Dept Name : Civil - Execution - Air Condition Department Comp. Dt. : 22/12/2022 Status : Completed								
336	22121035	Orthopaedics - OPD	NEED TO FIX AC COVER IN ORTHO DEMO ROOM	Ramesh. P.	AC cover fixed.		Sivamurugan. M - Civil - Execution	23/12/2022
Dept Name : Civil - Maintenance - Air Condition Department Comp. Dt. : 09/06/2022 Status : Completed								
337	22060343	Hospital	AC WATER LEAKAGE - "B" WING WEST SIDE	Panneer Selvam. P.	Indoor unit serviced.		Prakash. V. - Civil - Maintenance	05/09/2022
Comp. Dt. : 22/05/2023 Status : Completed								
338	23050894	AO Office	NEED SERVICE FOR WATER PURIFYER - NEED URGENT SERVICE	Ramesh. P.	PURIFIER SERVICED.		Gurunathan. V. - Civil - Maintenance	25/05/2023
Dept Name : Clinical Department - Air Condition Department Comp. Dt. : 06/05/2022 Status : Completed								
339	22050212	CLINICAL DEPARTMENT IN 2ND FLOOR	AC NOT WORKING I SEMINOR ROOM [LEFT SIDE]	Panneer Selvam. P.	Mode is changed and reset. Unit is working properly		Kheerthikaa. V. - Clinical Department	29/05/2022
Comp. Dt. : 10/05/2022 Status : Completed								
340	22050327	CLINICAL DEPARTMENT IN 2ND FLOOR	NEED TO CHECK AC - NOT WORKING & COOLING - ROOM NO 1 [BOTH SIDE]	Thulasi Daran. R.	2nos. Indoor unit serviced.		Vidhyavathi. S. - Clinical Department	02/06/2022
Comp. Dt. : 13/05/2022 Status : Completed								
341	22050488	CLINICAL DEPARTMENT IN 4th FLOOR	A/C-NOT WORKING	Pragash. P.	Gas leak. Gas top up right side.		Bhuvana.M. - Clinical Department	05/09/2022
Comp. Dt. : 02/06/2022								

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
342	22060079	Dean (Academic) Office	AC NOT WORKING [DEAN SIR ROOM]	Sasikumar. S.	PC board serviced & fixed.		Vidhyavathi. S. - Clinical Department	20/06/2022
Comp. Dt. : 11/06/2022								
Status : Completed								
343	22060422	CLINICAL DEPARTMENT IN 2ND FLOOR	AC WATER LEAKAGE AT SEMINOR ROOM [LEFT SIDE]	Pragash. P.	Indoor unit serviced.		Shuruthi. B. - Clinical Department	27/06/2022
Comp. Dt. : 17/06/2022								
Status : Completed								
344	22060642	CLINICAL DEPARTMENT IN 4th FLOOR	AC NOT WORKING AT SEMINOR ROOM	Ramesh. P.	Copper pipe changed put vaccum gas charged.		Bhuvana.M. - Clinical Department	22/09/2022
Comp. Dt. : 07/07/2022								
Status : Completed								
345	22070249	CLINICAL DEPARTMENT IN 2ND FLOOR	AC NOT WORKING AT SEMINOR ROOM	Ramesh. P.	Compressor changed.		Vidhyavathi. S. - Clinical Department	05/09/2022
Comp. Dt. : 12/07/2022								
Status : Completed								
346	22070464	CLINICAL DEPARTMENT IN 2ND FLOOR	AC NOT WORKING IN SEMINOR ROOM	Thulasi Daran. R.	1.5 TR new compressor changed. Stainer and capillary changed. Gas top up.		Vidhyavathi. S. - Clinical Department	05/09/2022
Comp. Dt. : 20/07/2022								
Status : Completed								
347	22070741	CLINICAL DEPARTMENT IN 3RD FLOOR	AC NOT WORKING ROOM NO 3	Thulasi Daran. R.	Gas leakage occurs. Gas topup		Selvi. A. - Clinical Department	05/09/2022
Comp. Dt. : 22/08/2022								
Status : Completed								
348	22080714	General Medicine - OPD	AC NOT WORKING AT DEMO ROOM	Panneer Selvam. P.	Burnt wire replaced with new wire.		Selvi. A. - Clinical Department	05/09/2022
Comp. Dt. : 15/09/2022								
Status : Completed								
349	22090603	CLINICAL DEPARTMENT IN 3RD FLOOR	AC NOT WORKING - LEFT SIDE ROOM NO 3	Vijay. M.	Power problem.		Selvi. A. - Clinical Department	17/09/2022
Comp. Dt. : 22/11/2022								
Status : Completed								
350	22110962	CLINICAL DEPARTMENT IN 4th FLOOR	AC NOT WORKING NEED URGENT SERVICE FOR ROOM NO.3	Pragash. P.	Unit serviced and cleaned.		Vimal. P. - Clinical Department	29/11/2022

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 27/01/2023 Status : Completed								
351	23010985	CLINICAL DEPARTMENT IN 4th FLOOR	AC NOT WORKING ROOM NO 3	Manikandan. A. R.	Capacitor and wire clip changed.		Patchammal. K. - Clinical Department	02/02/2023
Comp. Dt. : 16/02/2023 Status : Completed								
352	23020615	CLINICAL DEPARTMENT IN 3RD FLOOR	SEMINAR HALL A/C-COOLING PROBLEM	Ramesh. P.	NEW 50 MFD CAPACITOR CHANGE IT.		Selvi. A. - Clinical Department	17/02/2023
Comp. Dt. : 20/02/2023 Status : Completed								
353	23020756	CLINICAL DEPARTMENT IN 4th FLOOR	AC NOT WORKING - SEMINOR ROOM	Ramesh. P.	50 MFD CAPCITOR CHANGED.		Vimal. P. - Clinical Department	28/02/2023
Comp. Dt. : 25/03/2023 Status : Completed								
354	23031085	CLINICAL DEPARTMENT IN 3RD FLOOR	AC NOT WORKING ROOM NO 1 [RIGHT SIDE]	Phillipkumar. D.	INDOOR BUSH ADJUSTED.		Manimegalai. M. - Clinical Department	29/03/2023
Comp. Dt. : 19/04/2023 Status : Completed								
355	23040602	CLINICAL DEPARTMENT IN 2ND FLOOR	AC NOT WORKING AT SEMINOR ROOM	Vijay. M.	50 mfd capacitor changed.		Patchammal. K. - Clinical Department	22/04/2023
Comp. Dt. : 15/05/2023 Status : Completed								
356	23050601	CLINICAL DEPARTMENT IN 2ND FLOOR	AC NOT WORKING ROOM NO 9	Vasanthakumar. V.	45 MFD CAPACITOR CHANGED.		Bhuvana.M. - Clinical Department	16/05/2023
Comp. Dt. : 17/05/2023 Status : Completed								
357	23050699	CLINICAL DEPARTMENT IN 2ND FLOOR	AC NOT WORKING - ROOM NO 7	Vijay. M.	55 MFD CAPACITOR CHANGED. BATTER 2NOS. CHANGED.		Bhuvana.M. - Clinical Department	19/05/2023
Comp. Dt. : 05/06/2023 Status : Completed								
358	23060159	CLINICAL DEPARTMENT IN 3RD FLOOR	AC NOT WORKING [SEMINOR ROOM RIGHT SIDE]	Gnanapragasam. N.	MOTOR PROBLEM. 3 MFD CAPACITOR CHANGED.		Selvi. A. - Clinical Department	07/06/2023
Comp. Dt. : 15/06/2023 Status : Completed								
359	23060560	CLINICAL DEPARTMENT IN 4th FLOOR	OPHTHAL HOD SIR ROOM A/C-NOT WORKING	Phillipkumar. D.	Breaker trip. Manually ON		Juguna. D. - Clinical Department	16/06/2023


Dr. KAGNE. R.N
 DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
360	23060732	Paediatrics - Ward 309	AC NOT WORKING AT DEMO ROOM	Phillipkumar. D.	BREAKER TRIP MANUALLY ON IT..		Manimegalai. M. - Clinical Department	21/06/2023
Comp. Dt. : 22/06/2023								
Status : Completed								
361	23060841	CLINICAL DEPARTMENT IN 4th FLOOR	AC NOT WORKING - CONFERENCE HALL	Vasanthakumar. V.	compressor wire burned. wire rejoined and insulated.		Vijayalakshmi.N - Clinical Department	23/06/2023
Comp. Dt. : 30/06/2023								
Status : Completed								
362	23061091	CLINICAL DEPARTMENT IN 2ND FLOOR	AC COOLING PROBLEM - NEED TO CHECK - LEFT SIDE ROOM NO 3 [DEAN ACA - SIR ROOM]	Phillipkumar. D.	Mode changed manually.		Vidhyavathi. S. - Clinical Department	01/07/2023
Dept Name : CLINICAL PATHOLOGY - Air Condition Department								
Comp. Dt. : 06/05/2022								
Status : Completed								
363	22050186	Clinical Pathology	NEED TO CHECK AC COOLING	Babu. D.	Indoor unit gas lock. Unit removed seperately and serviced. Unit is working.		Vinod Gnana Kumar. D. - CLINICAL PATHOLOGY	06/06/2022
Comp. Dt. : 28/06/2022								
Status : Completed								
364	22060985	Clinical Pathology	NEED TO CHECK AC COOLING & AC NOT WORKING	Manikandan. A. R.	Unit replaced with another unit (O General 2tr)		Vinod Gnana Kumar. D. - CLINICAL PATHOLOGY	05/09/2022
Comp. Dt. : 26/07/2022								
Status : Completed								
365	22070965	Clinical Pathology	AC WATER LEAKAGE	Pragash. P.	Unit changed.		Vinod Gnana Kumar. D. - CLINICAL PATHOLOGY	05/09/2022
Comp. Dt. : 05/10/2022								
Status : Completed								
366	22100019*	Clinical Pathology	AC WATER LEAKAGE	Thulasi Daran. R.,Gnanapragasam. N.,Vijay. M.	Water leakage arrest. Drain tray line cleaned.		Sivasakthi. D. - CLINICAL PATHOLOGY	25/10/2022
Comp. Dt. : 20/10/2022								
Status : Completed								
367	22100655	Clinical Pathology	AC WATER LEAKAGE	Thulasi Daran. R.	Indoor unit cleaned and serviced.		Vinod Gnana Kumar. D. - CLINICAL PATHOLOGY	21/10/2022
Comp. Dt. : 07/11/2022								

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
368	22110232	Pathology Lab	AC WATER LEAKAGE	Elumalai. J.	Leakage arrested.		Valli. G. - CLINICAL PATHOLOGY	10/11/2022
Comp. Dt. : 08/11/2022								
Status : Completed								
369	22110319	Pathology Lab	AC WATER LEAKAGE	Vasanthakumar. V.	Leakage arrested.		Valli. G. - CLINICAL PATHOLOGY	10/11/2022
Comp. Dt. : 13/12/2022								
Status : Completed								
370	22120610	Clinical Pathology	AC WATER LEAKAGE	Ramesh. P.	Indoor unit serviced		Valli. G. - CLINICAL PATHOLOGY	17/12/2022
Comp. Dt. : 14/12/2022								
Status : Completed								
371	22120654	Clinical Pathology	AC WATER LEAKAGE	Manikandan. A. R.	Drain tray cleaned and serviced. R-22 Gas charged.		Vinod Gnana Kumar. D. - CLINICAL PATHOLOGY	15/12/2022
Comp. Dt. : 09/02/2023								
Status : Completed								
372	23020352	Pathology Lab	AC WATER LEAKAGE	Vijay. M.	Drain tray cleaned and gas topup done 20 psi.		Sivasakthi. D. - CLINICAL PATHOLOGY	10/02/2023
Comp. Dt. : 01/04/2023								
Status : Completed								
373	23040002	Clinical Pathology	AC WATER LEAKAGE	Ramesh. P.	DRAIN TRAY CLEANED AND SERVICED.		Vinod Gnana Kumar. D. - CLINICAL PATHOLOGY	03/04/2023
Comp. Dt. : 04/05/2023								
Status : Completed								
374	23050166	Clinical Pathology	AC WATER LEAKAGE	Vasanthakumar. V.	DRAIN TRAY CLEANED AND SERVICED.		Gowri. S. - CLINICAL PATHOLOGY	05/05/2023
Comp. Dt. : 11/05/2023								
Status : Completed								
375	23050447	Clinical Pathology	AC WATER LEAKAGE	Vijay. M.	DRAIN TRAY CLEANED AND SERVICED.		Velvizhi. R. - CLINICAL PATHOLOGY	16/05/2023
Comp. Dt. : 09/06/2023								
Status : Completed								
376	23060329	Clinical Pathology	NEED TO CHECK AC COOLING - AC NOT WORKING	Phillipkumar. D.	Indoor and outdoor unit serviced.		Vinod Gnana Kumar. D. - CLINICAL PATHOLOGY	13/06/2023

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHAL KUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Dept Name : COMMUNITY MEDICINE - Air Condition Department Comp. Dt. : 17/02/2023 Status : Completed								
377	23020676	COMMUNITY MEDICINE DEPT IN MEDICAL COLLEGE	AC NOT WORKING - [M.E DEPT]	Sasikumar. S.	REMOTE BATTERY CHANGED.		Raghavendran. V. - COMMUNITY MEDICINE	18/02/2023
Comp. Dt. : 13/04/2023 Status : Completed								
378	23040399	Medical Education Unit	AC REMOTE NOT WORKING	Sasikumar. S.	NEW BATTERY CHANGED.		Raghavendran. V. - COMMUNITY MEDICINE	15/04/2023
Dept Name : Computer Department - Air Condition Department Comp. Dt. : 04/05/2022 Status : Completed								
379	22050068	BASEMENT AUDITORIUM	AC NOT WORKING	Panneer Selvam. P.	mcb breaker trip. ON it. Unit is working.		Selvam. D. - Computer Department	16/05/2022
Comp. Dt. : 24/05/2022 Status : Completed								
380	22050848	BASEMENT AUDITORIUM	NEED TO CHECK ALL AC - NOT WORKING	Panneer Selvam. P.	All AC unit checked and serviced.		Balachandar. A. - Computer Department	20/06/2022
Comp. Dt. : 12/08/2022 Status : Completed								
381	22080431	DIGITAL LAB	AC NOT WORKING	Sasikumar. S.	Gas charged.		Raja.B - Computer Department	05/09/2022
Comp. Dt. : 29/09/2022 Status : Completed								
382	22091147	BASEMENT AUDITORIUM	AC NOT WORKING	Vasanthakumar. V.	Electrical power problem. DG machine working. Unit ON and OFF.		Selvam. D. - Computer Department	30/09/2022
Comp. Dt. : 05/10/2022 Status : Completed								
383	22100075	EDP IN UNDERGROUND	AC REMOTE NOT WORKING	Elumalai. J.,Gnanapragasam. N.,Panneer Selvam. P.	Display jack loose connection. Refixed it.		Jayaraj. J. - Computer Department	07/10/2022
Comp. Dt. : 03/11/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
384	22110066	EDP IN UNDERGROUND	IN SERVER ROOM-A/C LESS COOLING PROBLEM	Panneer Selvam. P.	Contactor changed newly,.		Jayaraj. J. - Computer Department	05/11/2022
Comp. Dt. : 18/02/2023 Status : Completed								
385	23020725	Hospital 2nd floor H-Wing	AC NOT WORKING IN ELECTRICAL ROOM	Ramesh. P.	BREAKER TRIP. MANUALLY ON IT.		Balachandar. A. - Computer Department	21/02/2023
Comp. Dt. : 07/03/2023 Status : Completed								
386	23030248	EDP IN UNDERGROUND	NEED TO CHECK AC COOLING - AC NOT WORKING	Vijay. M.	R22 GAS TOP UP (1.6 KG)		Shafiullah. R. - Computer Department	09/03/2023
Comp. Dt. : 17/04/2023 Status : Completed								
387	23040518	DIGITAL LAB	AC NOT WORKING	Sasikumar. S.	CONTACTOR SERVICED AND REFIXED.		Venkatesh. S. - Computer Department	20/04/2023
Comp. Dt. : 19/05/2023 Status : Completed								
388	23050777	AUDITORIUM IN BASEMENT	NEED TO ON AC	Ramesh. P.	ALL UNIT ON AND OFF MAINTENANCE WORK		Shafiullah. R. - Computer Department	20/05/2023
Dept Name : Derm,Pulmo,Psych Ward - Air Condition Department Comp. Dt. : 01/08/2022 Status : Completed								
389	22080030	PSYCHIATRY WARD	NEED TO CHECK AC COOLING AT ECG ROOM	Vijay. M.,Vasanthakumar. V.,Manikandan. A. R.	Gas top up		Sarathkumar. R. - Derm,Pulmo,Psych Ward	05/09/2022
Comp. Dt. : 03/08/2022 Status : Completed								
390	22080111	PSYCHIATRY WARD	AC NOT WORKING AT ECG ROOM	Ramesh. P.	Outdoor stand damaged. Refixed at other location.		Ashok Kumar. S. - Derm,Pulmo,Psych Ward	05/09/2022
Comp. Dt. : 04/08/2022 Status : Completed								
391	22080166	PSYCHIATRY WARD	A/C NOT WORKING	Vijay. M.,Vasanthakumar. V.,Manikandan. A. R.	Gas top up		Ashok Kumar. S. - Derm,Pulmo,Psych Ward	05/09/2022
Comp. Dt. : 28/11/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
392	22111184	PSYCHIATRY WARD	IN ECT ROOM-A/C NOT WORKING	Vasanthakumar. V.	Breaker trip. ON it manually.		Sarathkumar. R. - Derm,Pulmo,Psych Ward	30/11/2022
Comp. Dt. : 02/12/2022 Status : Completed								
393	22120091	Male Psychiatry - Ward 405	AC NOT WORKING IN ECG ROOM	Vasanthakumar. V.	Rat bitten the wire. Wire rejoined and insulation done.		Sarathkumar. R. - Derm,Pulmo,Psych Ward	10/12/2022
Comp. Dt. : 14/12/2022 Status : Completed								
394	22120635	PSYCHIATRY WARD	AC NOT WORKING IN ECG ROOM	Vijay. M.	PC board serviced and refixed.		Sarathkumar. R. - Derm,Pulmo,Psych Ward	14/01/2023
Comp. Dt. : 20/01/2023 Status : Completed								
395	23010689	Male Psychiatry - Ward 405	AC NOT WORKING AT ECG ROOM	Vasanthakumar. V.	Rat bitten wire,then rejoin and insulated.		Sarathkumar. R. - Derm,Pulmo,Psych Ward	23/01/2023
Comp. Dt. : 22/04/2023 Status : Completed								
396	23040691	Male Psychiatry - Ward 405	AC WATER LEAKAGE	Vasanthakumar. V.	INDOOR UNIT CLEANED AND SERVICED.		Bharathi. A - Derm,Pulmo,Psych Ward	24/04/2023
Dept Name : Dermatology & Vener. - Air Condition Department Comp. Dt. : 23/09/2022 Status : Completed								
397	22090939	DERMATOLOGY OPD	NEED TO CHECK AC 2NOS [NOT WORKING , NO COOLING] AT POOVATHERAPHY	Manikandan. A. R.,Ramesh. P.,Pragash. P.	New motor changed.		Jayachandran. M. - Dermatology & Vener.	12/10/2022
Dept Name : Dialysis - Air Condition Department Comp. Dt. : 28/06/2022 Status : Completed								
398	22061022	DIALYSIS NEW UNIT IN 1ST FLOOR	NEED TO CHECK COOLER - NOT WORKING	Thulasi Daran. R.	3 pin top problem. New one changed.		Sumathira. C - Dialysis	05/09/2022
Comp. Dt. : 23/08/2022 Status : Completed								
399	22080748	DIALYSIS IN 2ND FLOOR	NEED TO CHECK AC COOLING	Ramesh. P.	filter removed and serviced.		Kayalvizhi. V. - Dialysis	05/09/2022
Comp. Dt. : 06/09/2022								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
400	22090214	DIALYSIS NEW UNIT IN 1ST FLOOR	AC WATER LEAKAGE	Thulasi Daran. R.	Drain tray cleaned and serviced.		Sarathambal. R. - Dialysis	07/09/2022
Comp. Dt. : 09/09/2022								
Status : Completed								
401	22090382	DIALYSIS IN 2ND FLOOR	AC WATER LEAKAGE	Ramesh. P.,Thulasi Daran. R.,Pragash. P.	Drain tray cleaning work done.		Kalaimani. P. - Dialysis	10/09/2022
Comp. Dt. : 13/02/2023								
Status : Completed								
402	23020482	DIALYSIS IN 2ND FLOOR	NEED TO CHECK AC COOLING	Gnanapragasam. N.	RAT BITTEN THE WIRE. REJOINED AND TAPED IT		Arthy. T. - Dialysis	14/02/2023
Comp. Dt. : 27/04/2023								
Status : Completed								
403	23040899	DIALYSIS IN 2ND FLOOR	AC NOT WORKING	Ramesh. P.	breaker trip. manually on.		Ranjitha. A - Dialysis	28/04/2023
Comp. Dt. : 29/04/2023								
Status : Completed								
404	23040996	DIALYSIS IN 2ND FLOOR	AC WATER LEAKAGE	Gnanapragasam. N.	DRAIN TRAY CLEAN AND SERVICED.		Pragathi. D. - Dialysis	03/05/2023
Dept Name : Director Office - Air Condition Department								
Comp. Dt. : 28/12/2022								
Status : Completed								
405	22121296*	Director Office	AC NOT WORKING IN CONFERENCE HALL	Sasikumar. S.	Rat bitten the wire. Rejoint the wire and insulated. Drain tray cleaned. Drain tray to be changed.		Jayasridhar. K. - Director Office	30/12/2022
Comp. Dt. : 20/04/2023								
Status : Completed								
406	23040632	LECTURE HALL V	AC NOT WORKING	Sasikumar. S.	40 mfd capacitor changed.		Prasanna.B. - Director Office	22/04/2023
Dept Name : Electrical Maintenance - Air Condition Department								
Comp. Dt. : 14/06/2022								
Status : Completed								
407	22060485	POWER RAISING ROOM NEAR MD OFFICE(1ST FLOOR)	AC NOT WORKING	Panneer Selvam. P.	Indoor unit serviced.		Vaithianathan.M - Electrical Maintenance	27/06/2022
Comp. Dt. : 12/07/2022								
Status : Completed								

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
408	22070448*	POWER RAISING ROOM NEAR MD OFFICE(1ST FLOOR)	AC NOT WORKING	Panneer Selvam. P.	Fan motor changed in outdoor unit.		Vaithianathan.M - Electrical Maintenance	05/09/2022
		Comp. Dt. : 04/08/2022 Status : Completed						
409	22080177	BASEMENT AUDITORIUM	AC WATER LEAKAGE - AC NO 11	Manikandan. A. R.	Drain tray damaged. Drain tray changed.		Vaithianathan.M - Electrical Maintenance	05/09/2022
		Comp. Dt. : 15/09/2022 Status : Completed						
410	22090606	POWER RAISING ROOM NEAR MD OFFICE(1ST FLOOR)	AC WATER LEAKAGE	Panneer Selvam. P.	Drain tray cleaned.		Vaithianathan.M - Electrical Maintenance	17/09/2022
		Comp. Dt. : 28/09/2022 Status : Completed						
411	22091103	VC HOUSE	AC NOT WORKING - NEED URGENT SERVICE - VC SIR ROOM PONDY HOUSE	Ramesh. P.	Indoor unit serviced with water pressure pump.		Sridharan. R - Electrical Maintenance	30/09/2022
		Comp. Dt. : 10/10/2022 Status : Completed						
412	22100198	MRI POWER ROOM	NEED TO CHECK AC COOLING - AC NOT WORKING IN MRI UPS ROOM	Panneer Selvam. P.,Amarajothi.V.,Vasanthakumar. V.	Break trip. ON it manually		Vaithianathan.M - Electrical Maintenance	11/10/2022
		Comp. Dt. : 08/11/2022 Status : Completed						
413	22110296	BASEMENT AUDITORIUM	AC WATER LEAKAGE	Pragash. P.	Drain tray cleaned and serviced.		Sathishkumar. R. - Electrical Maintenance	09/11/2022
		Comp. Dt. : 29/12/2022 Status : Completed						
414	22121332	BASEMENT AUDITORIUM	A/C NO.11-WATER LEAKAGING PROBLEM	Manikandan. A. R.	Drain dray fixing and serviced		Sathishkumar. R. - Electrical Maintenance	04/01/2023
		Comp. Dt. : 18/02/2023 Status : Completed						
415	23020726	POWER RAISING ROOM NEAR MD OFFICE(1ST FLOOR)	AC [2NOS] NOT WORKING	Ramesh. P.	R-22 GAS TOP UP DONE. (65 PSI)		Vaithianathan.M - Electrical Maintenance	03/03/2023
		Dept Name : EMERGENCY MEDICINE - Air Condition Department Comp. Dt. : 09/07/2022 Status : Completed						


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
416	22070395	marchuary	NEED TO CHECK AC COOLING - PROBLEM	Pragash. P.	Remote mode changed manually		Kanimozhi. E. - EMERGENCY MEDICINE	05/09/2022
	Comp. Dt. : 20/08/2022							
	Status : Completed							
417	22080674	Casualty	AC NOT WORKING IN [A P] DOCTOR'S ROOM	Panneer Selvam. P.	Breaker trip. Manully trip ON		Kanimozhi. E. - EMERGENCY MEDICINE	05/09/2022
	Comp. Dt. : 28/01/2023							
	Status : Completed							
418	23011004	marchuary	FREEZER NOT WORKING	Ramesh. P.	Breaker triped then manually on it.		Racida. R. - EMERGENCY MEDICINE	30/01/2023
419	23011012	Casualty	NEED TO CHECK FRIDGE - TEMPERATURE PROBLEMS	Panneer Selvam. P.	probe wire adjustment.work is done,		Kanimozhi. E. - EMERGENCY MEDICINE	31/01/2023
	Comp. Dt. : 13/04/2023							
	Status : Completed							
420	23040429	Casualty	FRIDGE NOT WORKING	Phillipkumar. D.	NEW PROBE CHANGED.		Racida. R. - EMERGENCY MEDICINE	15/04/2023
	Comp. Dt. : 24/04/2023							
	Status : Completed							
421	23040778	Female Casulaty	AC NOT WORKING & AC SWITCH PROBLEM	Vasanthakumar. V.	BREAKER TRIP. MANUALLY ON.		Sowmiya. S. - EMERGENCY MEDICINE	26/04/2023
	Comp. Dt. : 05/05/2023							
	Status : Completed							
422	23050208	Casualty	AC NOT WORKING AT PRIORITY I	Vijay. M.	FAN MOTOR WARRANTY CLAIMED AND REFIXED.		Sasirekha. K. - EMERGENCY MEDICINE	29/05/2023
	Comp. Dt. : 19/05/2023							
	Status : Completed							
423	23050811	Female Casulaty	AC NOT WORKING	Vasanthakumar. V.	BREAKER TRIP. MANUALLY ON		Kalaivani. N. - EMERGENCY MEDICINE	27/05/2023
	Comp. Dt. : 16/06/2023							
	Status : Completed							
424	23060575	Casualty	FRIDGE TEMPERATURE NOT WORKING	Vasanthakumar. V.	battery and probe changed.		Racida. R. - EMERGENCY MEDICINE	17/06/2023

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 22/06/2023 Status : Completed								
425	23060796	Casualty	AC OUTLET LET WATER LEAKAGE , WATER SPREAD INSIDE THE RECOVERY ROOM - NEED URGENT SERVICE	Vasanthakumar. V.	Drain pipe line cleaned and serviced.		Sasirekha. K. - EMERGENCY MEDICINE	23/06/2023
Dept Name : Endoscopy - Air Condition Department Comp. Dt. : 14/09/2022 Status : Completed								
426	22090521	Endoscopy	AC WATER LEAKAGE	Panneer Selvam. P.,Babu. D.,Pragash. P.	Indoor drain tray cleaned.		Vijayalakshmi. G. - Endoscopy	17/09/2022
Comp. Dt. : 06/10/2022 Status : Completed								
427	22100090	MINOR OT NEAR ENDOSCOPY	FRIDGE NOT WORKING	Thulasi Daran. R.	Fridge inside switch problem. Problem rectified.		Ananthi. S. - P.H.C. - Tiruvonnainallur	07/10/2022
Comp. Dt. : 25/02/2023 Status : Completed								
428	23020961	Endoscopy	AC NOT WORKING	Ramesh. P.	50 MFD CAPACITOR CHANGED.		Tamilselvi. E. - Endoscopy	28/02/2023
Dept Name : ENT & Ophthal Ward - Air Condition Department Comp. Dt. : 01/06/2023 Status : Completed								
429	23060046	Female Medical - Ward 305	PROBLEM IN FRIDGE	Vasanthakumar. V.	WIRE BURNT. WIRE REJOINT AND INSULATED.		Bhuvaneswari. M. - ENT & Ophthal Ward	06/06/2023
Comp. Dt. : 09/06/2023 Status : Completed								
430	23060342	Female Medical - Ward 305	PROBLEM IN FRIDGE - HEAT	Phillipkumar. D.	Timer asdjustement done		Bhuvaneswari. M. - ENT & Ophthal Ward	19/06/2023
Dept Name : Female Medical Ward - Air Condition Department Comp. Dt. : 25/05/2022 Status : Completed								
431	22050944	Female Medical - Ward 305	FRIDGE NOT WORKING	Thulasi Daran. R.	Breaker trip. ON it		Vaitheeswari. A. - Female Medical Ward	27/06/2022
Comp. Dt. : 22/06/2023 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
432	23060810	Female Medical - Ward 305	FRIDGE NOT WORKING - COOLING PROBLEM	Vasanthakumar. V.	New timer and bulb changed.		Gomathy. G. - Female Medical Ward	25/07/2023
Dept Name : Female Ortho Ward - Air Condition Department Comp. Dt. : 03/03/2023 Status : Completed								
433	23030115	Female Ortho - Ward 401	FRIDGE NOT WORKING	Pragash. P.	RELAY OLP UNPLUGGED AND CONNECTED PROPERLY		Dhansulakshmi. K. - Female Ortho Ward	09/03/2023
Comp. Dt. : 21/03/2023 Status : Completed								
434	23030838	Female Ortho - Ward 402	FRIDGE NOT WORKING	Manikandan. A. R.	Stablizer removed and wire directly connected to power supply		Anbuselvi. P. - Female Ortho Ward	23/03/2023
Dept Name : Female Surgery - Air Condition Department Comp. Dt. : 17/04/2023 Status : Completed								
435	23040536	V I P DENTAL CLINIC II FLOOR	AC WATER LEAKAGE	Vijay. M.	DRAIN TRAY CLEAN AND SERVICED.		Jayasree. S. - TB & Chest / Psychiatry	20/04/2023
Comp. Dt. : 26/04/2023 Status : Completed								
436	23040842	V I P DENTAL CLINIC II FLOOR	AC NOT WORKING	Ramesh. P.,Vijay. M.,Phillipkumar. D.	BREAKER TRIP. MANUALLY ON.		Jayasree. S. - TB & Chest / Psychiatry	26/04/2023
Dept Name : Gas Power Plant - Air Condition Department Comp. Dt. : 13/06/2022 Status : Completed								
437	22060468	Printing Press	AC NOT WORKING	Ramesh. P.	compressor terminal burnt. New wire fixed.		Mahi Mohan Ram.S. - Gas Power Plant	27/06/2022
Comp. Dt. : 18/08/2022 Status : Completed								
438	22080569	Gas Power Plant	A/C SOUND PROBLEM	Thulasi Daran. R.	Sound arrest and serviced.		Mahi Mohan Ram.S. - Gas Power Plant	05/09/2022
Comp. Dt. : 13/10/2022 Status : Completed								
439	22100401	Printing Press	AC NOT WORKING AT DESIGNER ROOM	Panneer Selvam. P.	Unit to be condemned.		Mahi Mohan Ram.S. - Gas Power Plant	18/10/2022
Comp. Dt. : 19/04/2023 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
440	23040615	Printing Press	AC NOT WORKING [MACHINES ARE AFFECTED WITHOUT A C]	Vasanthakumar. V.	ALTERNATE COMPRESSOR ARRANGED.		Mahi Mohan Ram.S. - Gas Power Plant	29/05/2023
Comp. Dt. : 02/06/2023 Status : Completed								
441	23060062	Printing Press	AC NOT WORKING	Vasanthakumar. V.	TERMINAL WIRE BURN, TERMINAL CLIP CHANGED.		Mahi Mohan Ram.S. - Gas Power Plant	06/06/2023
Comp. Dt. : 30/06/2023 Status : Completed								
442	23061095	Printing Press	PROBLEM IN AC & COOLER	Phillipkumar. D.	Drain tray cleaned and serviced.		Mahi Mohan Ram.S. - Gas Power Plant	01/07/2023
Dept Name : Gastroenterology - Air Condition Department Comp. Dt. : 19/12/2022 Status : Completed								
443	22120869	GASTROENTROLOGY OPD-2ND FLOOR	AC NOT WORKING	Gnanapragasam. N.	Breaker trip. Manually ON		Vanitha. G. - NEUROLOGY	21/12/2022
Dept Name : Guest House - Indian Bank - Air Condition Department Comp. Dt. : 04/05/2022 Status : Completed								
444	22050093	Guest House - Indian Bank	AC NOT WORKING - ROOM NO 205 [SECRETARY SIR GUEST ROOM]	Panneer Selvam. P.	Stablizer problem. Stablizer removed and conected directly to the power supply.		John. H. - Guest House - Indian Bank	06/06/2022
Comp. Dt. : 19/05/2022 Status : Completed								
445	22050715	Guest House - Indian Bank	NEED AC SERVICE FOR ALL ROOM S [12 NOS]	Panneer Selvam. P.	Stablizer problem. Stablizer is removed and direct the power supply		John. H. - Guest House - Indian Bank	20/06/2022
Comp. Dt. : 29/06/2022 Status : Completed								
446	22061059	Guest House - Indian Bank	AC NOT WORKING ROOM NO 103	Panneer Selvam. P.	Stablizer removed. Direct connection given to the power supply		John. H. - Guest House - Indian Bank	05/09/2022
Comp. Dt. : 30/06/2022 Status : Completed								
447	22061131	Guest House - Indian Bank	DUE TO FOREIGNERS VISIT - NEED TO CHECK AC RELATED ITEMS FOR ALL ROOMS	Babu. D.	General checkup done.		John. H. - Guest House - Indian Bank	05/09/2022

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 19/09/2022 Status : Completed								
448	22090737	Guest House - Indian Bank	AC WATER LEAKAGE - ROOM NO 203	Panneer Selvam. P.,Babu. D.,Pragash. P.	drain tray cleaned		John. H. - Guest House - Indian Bank	20/09/2022
Comp. Dt. : 20/12/2022 Status : Completed								
449	22120914	Guest House - Indian Bank	AC NOT WORKING IN ROOM NO 206	Gnanapragasam. N.	New capacitor change work is done		John. H. - Guest House - Indian Bank	22/12/2022
Comp. Dt. : 08/02/2023 Status : Completed								
450	23020274	Guest House - Indian Bank	AC WATER LEAKAGE IN ROOM NO. 101	Vasanthakumar. V.	Indoor unit cleaned and serviced.		John. H. - Guest House - Indian Bank	10/02/2023
Comp. Dt. : 26/04/2023 Status : Completed								
451	23040878	Guest House - Indian Bank	AC NOT WORKING - ROOM NO 103	Vasanthakumar. V.	gas refilled		John. H. - Guest House - Indian Bank	24/05/2023
Dept Name : Gynac Ward - Air Condition Department Comp. Dt. : 03/06/2022 Status : Completed								
452	22060113	Labour Room	AC NOT WORKING	Ramesh. P.	Chiller problem AHU working.		Kanimozhi. S. - Labour Ward	20/06/2022
Comp. Dt. : 09/12/2022 Status : Completed								
453	22120444	Obstetrics - Ward 208	NEED TO CHECK AC TEMPERATURE	Pragash. P.	Probe adjustment done.		Sangeetha. J. - Gynac Ward	14/12/2022
Dept Name : Hospital Infection Control - Air Condition Department Comp. Dt. : 09/11/2022 Status : Completed								
454	22110362	HICC ROOM IN 4TH FLOOR-403	IN REFRIDGERATOR -WATER BUBBLES FORMING AROUND FRIDGE OUTER SIDE	Panneer Selvam. P.	Water line block removed and cleaned.		Mohana. M. - Hospital Infection Control	11/11/2022
Dept Name : Housekeeping - Air Condition Department Comp. Dt. : 27/07/2022 Status : Completed								
455	22071020	CHILDREN'S PARK	NEED TO CHECK AC PIPE LINE AT CHILDREN'S PARK - DRAINAGE WATER LEAKAGE	Babu. D.	Leak arrest		langchezhiyan. R. - Housekeeping	05/09/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 22/09/2022								
Status : Completed								
456	22090897	Labour Room	NEED TO CHECK AC PIPELINE - DUE TO CONTINUOUS WATER LEAKAGE - SEPTIC ROOM W.C SEAT DAMAGE	Ramesh. P.,Pragash. P.,Vijay. M.	Insulation work done. Water leak arrest.		Vengadesan. K. - Housekeeping	11/10/2022
Comp. Dt. : 08/11/2022								
Status : Completed								
457	22110277	SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	AC WATER LEAKAGE IN DR.SENTHIL SIR ROOM	Panneer Selvam. P.	Rain water complaint.		Elangchezhiyan. R. - Housekeeping	10/11/2022
Comp. Dt. : 10/02/2023								
Status : Completed								
458	23020368	SPECIAL WARD---B	AC WATER LEAKAGE BED NO 22,23	Gnanapragasam. N.	Drain tray cleaned and serviced.		Elangchezhiyan. R. - Housekeeping	10/02/2023
Comp. Dt. : 27/04/2023								
Status : Completed								
459	23040939	Surgery OPD	AC WATER LEAKAGE - ENDOSCOPY	Ramesh. P.	DRAINTRAY CLEANED AND SERVICED.		Balasubramaniam. G. - Housekeeping	29/04/2023
Dept Name : ICU - Air Condition Department								
Comp. Dt. : 08/06/2022								
Status : Completed								
460	22060302	SICU	AC WATER LEAKAGE - FEMALE SICU	Thulasi Daran. R.	Drain tray cleaned.		Regina Mary. S. - ICU	05/09/2022
Comp. Dt. : 26/07/2022								
Status : Completed								
461	22070968	ICCU	AC NOT WORKING	Ramesh. P.	Indoor unit ahu water serviced.		Bhavani. P. - ICCU	05/09/2022
Dept Name : ICU - Air Condition Department								
Comp. Dt. : 31/05/2022								
Status : Completed								
462	22051112	ICU	NEED TO CHECK AC - NOT WORKING	Pragash. P.	AHU working. Old chiller problem. compressor gas leak.		Latha. K. - ICU	20/06/2022
Comp. Dt. : 07/07/2022								
Status : Completed								
463	22070232	ICU	NEED AC SERVICE - DUST	Panneer Selvam. P.	Grill dust cleaning work.		Latha. K. - ICU	05/09/2022

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 15/09/2022 Status : Completed								
464	22090577	ICU	AC COOLING NOT WORKING	Panneer Selvam. P.,Babu. D.,Manikandan. A. R.	Power problem.		Regina Mary. S. - ICU	17/09/2022
Comp. Dt. : 21/09/2022 Status : Completed								
465	22090823	RICU	AC NOT WORKING	Thulasi Daran. R.,Babu. D.,Manikandan. A. R.	Power problem. AHU filter and coil serviced.		Jayabharathi. R. - ICU	26/09/2022
Comp. Dt. : 08/04/2023 Status : Completed								
466	23040216	ICU	AC NOT WORKING	Ramesh. P.	BELT ADJUSTMENT AND DRAIN TRAY CLEANED.		Jayabharathi. R. - ICU	08/04/2023
Comp. Dt. : 25/04/2023 Status : Completed								
467	23040834	ICU	DUE TO FUMIGATION NEED AC GRILL SERVICE	Sasikumar. S.	ALL GRILL CLEANING WORK COMPLETED		Regina Mary. S. - ICU	26/04/2023
Comp. Dt. : 16/05/2023 Status : Completed								
468	23050668	ICU	PROBLEM IN - AC COOLING	Pragash. P.	BREAKER TRIP. MANUALLY ON IT.		Jayabharathi. R. - ICU	19/05/2023
Dept Name : Labour Ward - Air Condition Department Comp. Dt. : 02/06/2022 Status : Completed								
469	22060049	Labour Room	AC NOT WORKING	Panneer Selvam. P.	AHU chiller problem. Compressor gas leak. Want to rectify with AMC person		Sevvanthi. T. - Labour Ward	20/06/2022
470	22060053	Labour Room	AC NOT WORKING	Panneer Selvam. P.	Chiller problem. Compressor gas leak. Want to service with AMC person;		Kodhai. T. - Labour Ward	20/06/2022
Comp. Dt. : 04/06/2022 Status : Completed								
471	22060164	Labour Room	NEED TO CHECK AC COOLING - LABOUR ROOM & LABOUR POST OPP	Thulasi Daran. R.	Low cubic feet per minute.		Thenmozhi. J. - Labour Ward	05/09/2022
Comp. Dt. : 06/06/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
472	22060184	labour room -pow	NEED TO CHECK AC - NOT WORKING	Panneer Selvam. P.	Low Cubic feet per minute		Suriya Prakash Pavion. S. - Labour Ward	05/09/2022
	Comp. Dt. : 15/06/2022							
	Status : Completed							
473	22060558	Labour Room	DUE TO DEATH OF RAT BAD SMELL SPREAD - NEED AC SERVICE URGENT AT AP ROOM	Thulasi Daran. R.	Indoor unit servied.		Sathiyavathi. S. - Labour Ward	27/06/2022
	Comp. Dt. : 26/08/2022							
	Status : Completed							
474	22080891	labour room -pow	NEED AC SERVICE	Panneer Selvam. P.	Grill cleaning work done		Thenmozhi. J. - Labour Ward	05/09/2022
	Comp. Dt. : 29/08/2022							
	Status : Completed							
475	22080973	Labour Room	NEED AC SERVICE	Thulasi Daran. R.	Low cube feet per minute.		Usharani. A. - Labour Ward	05/09/2022
	Comp. Dt. : 05/09/2022							
	Status : Completed							
476	22090183	Labour Room	AC NOT WORKING	Panneer Selvam. P.,Babu. D.,Vijay. M.	Work in progress.		Sathiyavathi. S. - Labour Ward	07/09/2022
	Comp. Dt. : 15/09/2022							
	Status : Completed							
477	22090607	labour room -pow	NEED TO CHECK AC COOLING	Panneer Selvam. P.,Babu. D.,Thulasi Daran. R.	Power trip. Problem solved.		Thenmozhi. J. - Labour Ward	17/09/2022
	Comp. Dt. : 05/10/2022							
	Status : Completed							
478	22100028	Labour Room	AC NOT WORKING IN A P ROOM	Panneer Selvam. P.	Breaker problem. Manually ON it.		Sathiyavathi. S. - Labour Ward	07/10/2022
	Comp. Dt. : 16/12/2022							
	Status : Completed							
479	22120757	Labour Room	FRIDGE TEMPERATURE NOT WORKING	Ramesh. P.	Rat bitten the wire. Wire rejoined and insulated.		Sathiyavathi. S. - Labour Ward	17/12/2022
	Comp. Dt. : 17/12/2022							
	Status : Completed							
480	22120826	Labour Room	IN A.P DOCTOR ROOM-A/C NOT WORKING	Gnanapragasam. N.	PC board wire connection tighten.		Sathiyavathi. S. - Labour Ward	21/12/2022
	Comp. Dt. : 15/02/2023							


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
481	23020609	labour room -pow	AC WATER LEAKAGE	Gnanapragasam. N.	Drain dray clean and serviced,		Brema. V. - Labour Ward	17/02/2023
Comp. Dt. : 11/04/2023								
Status : Completed								
482	23040296	Labour Room	FRIDGE TEMPERATURE PANEL NOT WORKING	Vijay. M.	NEW PROBE CHANGED.		Sathiyavathi. S. - Labour Ward	15/04/2023
Comp. Dt. : 12/04/2023								
Status : Completed								
483	23040385	Labour Room	FRIDGE PANEL NOT WORKING	Phillipkumar. D.	NEW PROBE CHANGED.		Kirupavathy. S. - Labour Ward	15/04/2023
Comp. Dt. : 02/05/2023								
Status : Completed								
484	23050012	Labour Room	AC WATER LEAKAGE	Vasanthakumar. V.	DRAIN TRAY CLEAN AND SERVICED.		Kodhai. T. - Labour Ward	03/05/2023
Comp. Dt. : 08/05/2023								
Status : Completed								
485	23050295	Labour Room	TEMPERATURE PROBLEM IN FRIDGE	Pragash. P.	NEW BATTERY CHANGED.		Kodhai. T. - Labour Ward	09/05/2023
Comp. Dt. : 11/05/2023								
Status : Completed								
486	23050449	Labour Room	AC WATER LEAKAGE	Pragash. P.	drain tray cleaned and serviced		Krishnadevi. D. - Labour Ward	12/05/2023
Comp. Dt. : 17/05/2023								
Status : Completed								
487	23050673	Labour Room	AC WATER LEAKAGE	Vijay. M.	drain tray cleaned and serviced.		Kirupavathy. S. - Labour Ward	18/05/2023
488	23050718	Labour Room	AC WATER LEAKAGE	Vasanthakumar. V.	DRAIN TRAY CLEANED ADN SERVICED.		Kanimozhi. S. - Labour Ward	19/05/2023
Comp. Dt. : 25/05/2023								
Status : Completed								
489	23051002	Labour Room	AC NOT WORKING AT AP ROOM	Phillipkumar. D.	BREAKER TRIP. MANUALLY SWITCHED ON		Sathiyavathi. S. - Labour Ward	27/05/2023
Dept Name : Library - Air Condition Department								
Comp. Dt. : 09/05/2023								
Status : Completed								
490	23050348	MEDICAL COLLEGE LIBRARY	AC NOT WORKING AT GROUND FLOOR LIBRARY	Sasikumar. S.	ELECTRICAL COMPLAINT.		Elangoan. N. - Library	29/05/2023

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHAKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Dept Name : Male Medical Ward - Air Condition Department Comp. Dt. : 18/02/2023 Status : Completed								
491	23020715	Male Medical - Ward 301	NEED TO CHECK FRIDGE TEMPERATURE - ICE CUBES FORMED	Ramesh. P.	ICE FORMATION CLEARED. FRIDGE SERVICED.		Soniya Gandhi. A. - Male Medical Ward	20/02/2023
Comp. Dt. : 03/04/2023 Status : Completed								
492	23040077	Male Medical - Ward 301	AC PANEL NOT WORKING	Vasanthakumar. V.	PROBE CHANGED.		Soniya Gandhi. A. - Male Medical Ward	04/04/2023
Dept Name : Marketing Team - Air Condition Department Comp. Dt. : 01/07/2022 Status : Completed								
493	22070013	SPECIAL WARD---B	NEED TO CHECK AC COOLING - ROOM NO B 10-11-12	Babu. D.	Water tray cleaning work done.		Prithivi. G. - Marketing Team	05/09/2022
Comp. Dt. : 04/07/2022 Status : Completed								
494	22070085	SPECIAL WARD---B	AC NOT WORKING - ROOM NO 10 , 11 , 12	Ramesh. P.	Drain tray cleaned.		Prithivi. G. - Marketing Team	05/09/2022
Comp. Dt. : 22/07/2022 Status : Completed								
495	22070819	IVF ART CLINIC-INSIDE OF OG OPD(NO.68)	AC NOT WORKING	Panneer Selvam. P.	Display jack loose connection. Refixed and rectified the problem.		Sathiya. M. - Marketing Team	08/09/2022
Comp. Dt. : 19/09/2022 Status : Completed								
496	22090716	SPECIAL WARD---B	AC WATER LEAKAGE - B22-B23	Panneer Selvam. P.	Indoor unit serviced.		Gokulraj. K. - Marketing Team	26/09/2022
Dept Name : MICROBIOLOGY - Air Condition Department Comp. Dt. : 12/05/2022 Status : Completed								
497	22050421	microbiology lab	A/C-WATER LEAKAGE PROBLEM	Pragash. P.	Indoor unit serviced.		Karthik. S. - MICROBIOLOGY	02/06/2022
Comp. Dt. : 17/06/2022 Status : Completed								
498	22060650	MICROBIOLOGY	NEED TO CHECK FRIDGE - WATER LEAKAGE - NEED URGENT SERVICE	Ramesh. P.	Tray block. Block removed.		Gunitha. P. - MICROBIOLOGY	27/06/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 27/06/2022 Status : Completed								
499	22060942	MICROBIOLOGY	AC WATER LEAKAGE	Panneer Selvam. P.	Indoor unit water serviced.		Karthik. S. - MICROBIOLOGY	05/09/2022
Comp. Dt. : 05/07/2022 Status : Completed								
500	22070152	MICROBIOLOGY	NEED TO CHECK AC COOLING	Panneer Selvam. P.	Indoor unit serviced		Karthik. S. - MICROBIOLOGY	05/09/2022
Comp. Dt. : 21/11/2022 Status : Completed								
501	22110852	MICROBIOLOGY IN COLLEGE	A/C NOT WORKING	Sasikumar. S.,Udhaya Shankar. P.,Babu. D.	Grill cleaning work done.		Praveenkumar. S. - MICROBIOLOGY	30/11/2022
Comp. Dt. : 25/11/2022 Status : Completed								
502	22111088	MICROBIOLOGY IN COLLEGE	IN RTPCR LAB-A/C WATER LEAKAGING PROBLEM	Sasikumar. S.,Udhaya Shankar. P.,Babu. D.	Indoor unit serviced		Yuvaraj. P. - MICROBIOLOGY	30/11/2022
Comp. Dt. : 06/03/2023 Status : Completed								
503	23030204	MICROBIOLOGY	AC WATER LEAKAGE	Gnanapragasam. N.	DRAIN LINE CLEANED.		Karthik. S. - MICROBIOLOGY	08/03/2023
Dept Name : MS Office - Air Condition Department Comp. Dt. : 12/09/2022 Status : Completed								
504	22090458	MS Office	NEED TO CHECK AC COOLING FOR D M S MADAM OFFICE	Thulasi Daran. R.,Pragash. P.,Ramesh. P.	AC outdoor unit removed for civil work.		Manikandan. A. - MS Office	13/09/2022
Comp. Dt. : 23/11/2022 Status : Completed								
505	22110976	SKILL LAB - MEDICAL COLLEGE	AC NOT WORKING	Sasikumar. S.,Udhaya Shankar. P.,Babu. D.	Breaker trip. Manually ON it.		Prabhakaran. S. - Medical Records	25/11/2022
Comp. Dt. : 28/02/2023 Status : Completed								
506	23021084	MS Office	MS SIR ROOM A/C-NOT WORKING	Gnanapragasam. N.	45 MFD CAPACITOR CHANGED.		Manikandan. A. - MS Office	01/03/2023
Comp. Dt. : 29/03/2023 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
507	23031263	MS Office	NEED TO CHECK AC - COOLING PROBLEM AT M.S SIR OFFICE - NEED URGENT SERVICE	Vasanthakumar. V.	Outdoor unit cleaned and serviced.		Hemavathi. P. - MS Office	01/04/2023
Comp. Dt. : 05/04/2023 Status : Completed								
508	23040162	MS Office	NEED TO CHECK AC COOLING - COOLING PROBLEM IN M S SIR OFFICE - NEED URGENT SERVICE	Ramesh. P.	OUTDOOR UNIT SERVICED		Hemavathi. P. - MS Office	11/04/2023
Comp. Dt. : 08/06/2023 Status : Completed								
509	23060286	CHILDREN'S PARK	AC PIPE LINE WATER LEAKAGE	Vasanthakumar. V.	DRAIN PIPELINE WATER LEAKAGE ARREST		Sundarrajan. R. - MS Office	09/06/2023
Dept Name : Nephrology - Air Condition Department Comp. Dt. : 10/06/2022 Status : Completed								
510	22060387	DIALYSIS NEW UNIT IN 1ST FLOOR	A/C LESS COOLING PROBLEM	Panneer Selvam. P.	Chiller sensor problem. Sensor removed and direct it.		Aathimoolam. R. - Nephrology	20/06/2022
Comp. Dt. : 27/07/2022 Status : Completed								
511	22071030	DIALYSIS NEW UNIT IN 1ST FLOOR	NEED TO CHECK AC - NOT WORKING - NO COOLING - NEED URGENT SERVICE	Ramesh. P.	Indoor unit AHU serviced.		Neelavathi. T. - Nephrology	05/09/2022
Comp. Dt. : 29/07/2022 Status : Completed								
512	22071082	DIALYSIS NEW UNIT IN 1ST FLOOR	AC NOT WORKING	Ramesh. P.	Indoor unit serviced.		Kamal. B. - Nephrology	05/09/2022
Comp. Dt. : 05/08/2022 Status : Completed								
513	22080189	DIALYSIS NEW UNIT IN 1ST FLOOR	NEED TO CHECK AC COOLING - AC NOT WORKING	Panneer Selvam. P.	Indoor unit AHU water service done		Aathimoolam. R. - Nephrology	05/09/2022
Comp. Dt. : 09/08/2022 Status : Completed								
514	22080333	DIALYSIS NEW UNIT IN 1ST FLOOR	NEED TO CHECK AC COOLING	Thulasi Daran. R.	AHU water serviced.		Karthik. A. - Nephrology	05/09/2022
Comp. Dt. : 30/09/2022 Status : Completed								

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
515	22091220	DIALYSIS IN 2ND FLOOR	NEED TO CHECK AC NOT WORKING - POSITIVE ROOM	Pragash. P.,Ramesh. P.,Vijay. M.	breaker trip. Breaker ON manually		Jiva. K. - Nephrology	06/10/2022
Comp. Dt. : 01/03/2023 Status : Completed								
516	23030025	DIALYSIS IN 2ND FLOOR	AC NOT WORKING	Phillipkumar. D.	STABILIZER REMOVED. CONNECTED DIRECTLY WITH POWER SUPPLY		Suganya. B. - Nephrology	03/03/2023
Comp. Dt. : 14/03/2023 Status : Completed								
517	23030540	DIALYSIS IN 2ND FLOOR	AC WATER LEAKAGE	Ramesh. P.	DRAIN TRAY CLEANED AND SERVICED.		Suganya. B. - Nephrology	16/03/2023
Comp. Dt. : 24/04/2023 Status : Completed								
518	23040741	DIALYSIS IN 2ND FLOOR	NEED TO CHECK AC COOLING - AC NOT WORKING	Vasanthakumar. V.	breaker trip manually on it.		Suganya. B. - Nephrology	25/04/2023
Comp. Dt. : 04/05/2023 Status : Completed								
519	23050120	DIALYSIS IN 2ND FLOOR	AC NOT WORKING	Vasanthakumar. V.	BREAKER TRIP. MANUALLY ON		Preetha. E. - Nephrology	05/05/2023
Comp. Dt. : 16/05/2023 Status : Completed								
520	23050658	DIALYSIS NEW UNIT IN 1ST FLOOR	AC COOLING PROBLEM	Vasanthakumar. V.	INDOOR UNIT SERVICED		Aathimoolam. R. - Nephrology	16/05/2023
Comp. Dt. : 19/05/2023 Status : Completed								
521	23050793	DIALYSIS IN 2ND FLOOR	NEED TO CHECK AC COOLING -	Panneer Selvam. P.	REMOTE MODE CHANGED.		Suganya. B. - Nephrology	20/05/2023
Comp. Dt. : 31/05/2023 Status : Completed								
522	23051263	DIALYSIS NEW UNIT IN 1ST FLOOR	NEED SERVICE FOR WATER PURIFIER - WATER COMING DUST	Vijay. M.	CLEANED AND SERVICED WITH WATER		Suganya. D. - Nephrology	01/06/2023
Comp. Dt. : 21/06/2023 Status : Completed								
523	23060773	DIALYSIS IN 2ND FLOOR	NEED TO CHANGE AC DRAIN LINE TUBE - DAMAGE & WATER LEAKAGE	Gnanapragasam. N.	Drain pipe line packed with tape.		Suganya. B. - Nephrology	23/06/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Dept Name : NEUROLOGY - Air Condition Department Comp. Dt. : 11/02/2023 Status : Completed								
524	23020445	EEG	NEED TO CHECK AC COOLING - AC NOT WORKING	Gnanapragasam. N.	R-22 GAS TOP UP DONE (15 PSI)		Vasuki. P. - NEUROLOGY	14/02/2023
Dept Name : Nursing Office - Air Condition Department Comp. Dt. : 24/05/2022 Status : Completed								
525	22050877	SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	AC NOT WORKING	Babu. D.	Outdoor unit serviced and gas checked.		Tamilarasi.C. - Nursing Office	20/06/2022
Comp. Dt. : 07/06/2022 Status : Completed								
526	22060256	SPECIAL WARD---B	AC WATER LEAKAGE - ROOM NO B3 & B6	Manikandan. A. R.	Indoor unit cleaned and serviced.		Tamilarasi.C. - Nursing Office	05/09/2022
Comp. Dt. : 14/06/2022 Status : Completed								
527	22060527	SICU	AC NOT WORKING NEED URGENT SERVICE	Thulasi Daran. R.	Drain tray cleaned.		Greeta Guna Seelan - Nursing Office	05/09/2022
Comp. Dt. : 30/07/2022 Status : Completed								
528	22071113	Special Ward - C	NEED TO CHECK FRIDGE TEMPERATURE - COOLING PROBLEM	Ramesh. P.	Probe changed.		Tamilarasi.C. - Nursing Office	05/09/2022
Comp. Dt. : 19/08/2022 Status : Completed								
529	22080621	SPECIAL WARD---B	AC WATER LEAKAGE	Babu. D.,Vasanthakumar. V.,Vijay. M.	Indoor unit serviced.		Tamilarasi.C. - Nursing Office	05/09/2022
Comp. Dt. : 30/09/2022 Status : Completed								
530	22091206	SICU	AC NOT WORKING - MOST URGENT	Babu. D.,Manikandan. A. R.,Thulasi Daran. R.	Power problem.		Tessy Hillary Scurvilles - Nursing Office	06/10/2022
Comp. Dt. : 29/11/2022 Status : Completed								
531	22111201	NICU	NEED AC SERVICE [OLD NICU WARD 101]	Vijay. M.	Indoor unit serviced.		owlin.P. - Nursing Office	01/12/2022
Comp. Dt. : 04/01/2023								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
		Status : Completed						
532	23010132	ICCU	AC CLEANING WORK	Vijay. M.	Grill set cleaned.		Powlin.P. - Nursing Office	05/01/2023
		Comp. Dt. : 07/01/2023						
		Status : Completed						
533	23010301	ICU	WARD FUMICATION WORK-A/C DUST NEED TO BE CLEAN	Amarajothi.V.	A/C unit cleaned and serviced.		Powlin.P. - Nursing Office	10/01/2023
		Comp. Dt. : 12/01/2023						
		Status : Completed						
534	23010505	ICU	NEW AC NOT WORKING	Ramesh. P.	Blower fan motor changed.		Powlin.P. - Nursing Office	25/01/2023
		Comp. Dt. : 21/03/2023						
		Status : Completed						
535	23030835	PICU	AC WATER LEAKAGE AT DOCTOR'S ROOM	Manikandan. A. R.	DRAIN TRAY CLEANED.		Powlin.P. - Nursing Office	23/03/2023
		Comp. Dt. : 27/03/2023						
		Status : Completed						
536	23031125	DENTAL OPD -2ND FLOOR	NEED TO CHECK AC COOLING	Ramesh. P.	REMOTE MODE CHANGED MANUALLY.		Sarala. V. - OPD	03/04/2023
		Comp. Dt. : 11/04/2023						
		Status : Completed						
537	23040299	NICU	WATER LEAKAGE IN FRIDGE	Amarajothi.V.	BREAKER TRIP MANUALLY ON IT.		Shenbagavalli. M. - PICU & NICU	11/04/2023
		Comp. Dt. : 12/04/2023						
		Status : Completed						
538	23040357	Casualty	NEED TO CHECK FRIDGE TEMPERATURE PANEL - NOT WORKING	Phillipkumar. D.	NEW PROBE CHANGED.		Tessy Hillary Scurvilles - Nursing Office	15/04/2023
		Comp. Dt. : 24/04/2023						
		Status : Completed						
539	23040773	CTVS-FEMALE PRE-OP ROOM INSIDE SPECIAL WARD B	AC NOT WORKING	Ramesh. P.	OUTDOOR FAN MOTOR AND NEW FAN BLADE REFIXED.		Tamilarasi.C. - Nursing Office	03/05/2023
		Comp. Dt. : 26/05/2023						
		Status : Completed						
540	23051020	SPECIAL WARD - A1	AC NOT WORKING ROOM NO 4 & 9	Ramesh. P.	REMOTE MODE CHANGED.		Sivapriya. N. - Nursing Office	29/05/2023
		Comp. Dt. : 15/06/2023						


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
541	23060566	CTVS INSIDE ORTHO OT	A/C-NOT WORKING	Ramesh. P.	COIL AND FILTER SERVICED.		Devika.R - Nursing Office	17/06/2023
Comp. Dt. : 24/06/2023								
Status : Completed								
542	23060898	ORTHO OT	AC WATER LEAKAGE	Vasanthakumar. V.	Drain tray cleaned and serviced.		Devika.R - Nursing Office	26/06/2023
Comp. Dt. : 26/06/2023								
Status : Completed								
543	23060943	IVF ART CLINIC-INSIDE OF OG OPD(NO.68)	FRIDGE NOT WORKING - NEED URGENT SERVICE	Ramesh. P.	Tray cleaned and serviced.		Greeta Guna Seelan - Nursing Office	28/06/2023
Dept Name : Nutrition & Dietetics - Air Condition Department								
Comp. Dt. : 21/07/2022								
Status : Completed								
544	22070798	DIET DEPARMENT	NEED TO CHECK AC PANEL - NOT WORKING	Vijay. M.,Babu. D.,Manikandan. A. R.	Indoor unit serviced.		Shanmugapriya. J. - Nutrition & Dietetics	07/09/2022
Comp. Dt. : 30/09/2022								
Status : Completed								
545	22091189	DIET DEPARMENT	NEED TO CHECK FRIDGE DOOR - NOT CLOSING PROPER	Babu. D.	Door problem. Door adjustment done.		Shanmugapriya. J. - Nutrition & Dietetics	07/10/2022
Comp. Dt. : 22/11/2022								
Status : Completed								
546	22110911	DIET DEPARMENT	DUE TO RAT PROBLEM NEED TO REFIX AC CABLES AT V FLOOR	Vasanthakumar. V.	A/C cables refixed.		Shanmugapriya. J. - Nutrition & Dietetics	30/11/2022
Dept Name : OPD - Air Condition Department								
Comp. Dt. : 02/05/2022								
Status : Completed								
547	22050056	General Medicine - OPD	AC NOT WORKING IN DEMO ROOM	Panneer Selvam. P.	mcb breaker trip. Checked and ON it.		Sivaranjani. P. - OPD	06/06/2022
548	22050059	Nephrology OPD	AC NOT WORKING - OPD NO 215	Amarajothi.V.	50 mfd capacitor changed. and filter served. Unit is working		Jenifer. K. - OPD	29/05/2022
Comp. Dt. : 04/05/2022								
Status : Completed								
549	22050076	CARDIOLOGY OPD	AC NOT WORKING	Ramesh. P.	New compressor changed.		Radhika. R. - OPD	06/06/2022
Comp. Dt. : 05/05/2022								

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
550	22050130	General Medicine - OPD	AC NOT WORKING IN DEMO ROOM	Pragash. P.	Breaker problem. New breaker changed and unit is working properly.		Bharathi.D. - OPD	29/05/2022
Comp. Dt. : 06/05/2022								
Status : Completed								
551	22050172	ONCOLOGY DEPT-2ND FLOOR-SPECIAL OPD	AC WATER LEAKAGE - NEED URGENT SERVICE	Thulasi Daran. R.	Indoor unit cleaned and serviced.		Lakshmid devi. A - OPD	06/06/2022
Comp. Dt. : 09/05/2022								
Status : Completed								
552	22050262	ONCOLOGY DEPT-2ND FLOOR-SPECIAL OPD	NEED TO CHECK AC COOLING	Ramesh. P.	Compressor terminal burnt. New connector changed.		Lakshmid devi. A - OPD	06/06/2022
Comp. Dt. : 11/05/2022								
Status : Completed								
553	22050389	IVF ART CLINIC-INSIDE OF OG OPD(NO.68)	A/C-NOT WORKING	Pragash. P.	Rat bitten the wire. Wire is then jointed and insulated.		Rajasekari. R. - OPD	20/06/2022
Comp. Dt. : 17/05/2022								
Status : Completed								
554	22050595	CARDIOLOGY OPD	AC NOT WORKING	Thulasi Daran. R.	New Compressor fixed. AC unit is working.		Radhika. R. - OPD	06/06/2022
Comp. Dt. : 19/05/2022								
Status : Completed								
555	22050686	CTVS-ROOM NO.225 -2ND FLOOR	AC NOT WORKING	Panneer Selvam. P.	Handset mode is changed. Unit is working.		Suvitha. R. - OPD	29/05/2022
556	22050691	Nephrology OPD	NEED TO CHECK AC COOLING	Thulasi Daran. R.	Indoor unit serviced.		Jenifer. K. - OPD	27/06/2022
Comp. Dt. : 20/05/2022								
Status : Completed								
557	22050761	GASTROENTROLOGY OPD-2ND FLOOR	AC NOT WORKING - NEED URGENT SERVICE	Babu. D.	2nos. indoor unit serviced.		Bharathi.D. - OPD	20/06/2022
Comp. Dt. : 25/05/2022								
Status : Completed								
558	22050950	CARDIOLOGY OPD	NEED TO CHECK AC COOLING	Pragash. P.	1no. new compressor changed.		Radhika. R. - OPD	20/06/2022
Comp. Dt. : 31/05/2022								
Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
559	22051119	IVF ART CLINIC-INSIDE OF OG OPD(NO.68)	AC WATER LEAKAGE & FUNGUS FORMED THE PLYWOOD SHEET - SHEET NEED TO BE CHANGE	Ramesh. P.	Rat bitten the sensor & power cord. Wire insulated the power cord. Wire joint and taped it.		Rajasekari. R. - OPD	20/06/2022
Comp. Dt. :		01/06/2022						
Status :		Completed						
560	22060012	ONCOLOGY DEPT-2ND FLOOR-SPECIAL OPD	AC NOT WORKING - OPD NO 216	Panneer Selvam. P.	Gas leak. Compressor terminal burned. New clip wire changed.		Tamilarasi. A. - OPD	20/06/2022
Comp. Dt. :		03/06/2022						
Status :		Completed						
561	22060135	CTVS-ROOM NO.225 -2ND FLOOR	AC NOT WORKING	Panneer Selvam. P.	Remote not working. Mode changed manually		Suvitha. R. - OPD	05/09/2022
Comp. Dt. :		06/06/2022						
Status :		Completed						
562	22060193	IVF ART CLINIC-INSIDE OF OG OPD(NO.68)	AC WATER LEKAGE - NEED URGENT SERVICE	Ramesh. P.	Indoor unit serviced.		Rajasekari. R. - OPD	27/06/2022
Comp. Dt. :		14/06/2022						
Status :		Completed						
563	22060503	NEUROLOGY OPD-2ND FLOOR	PROBLEM IN AC COOLING	Babu. D.	Stablizer wire loose connection. Rectified it.		Radhika. R. - OPD	05/09/2022
Comp. Dt. :		17/06/2022						
Status :		Completed						
564	22060641	NEUROLOGY OPD-2ND FLOOR	AC NOT WORKING	Panneer Selvam. P.	MCB breaker trilp. ON it		Radhika. R. - OPD	27/06/2022
Comp. Dt. :		24/06/2022						
Status :		Completed						
565	22060875	IVF ART CLINIC-INSIDE OF OG OPD(NO.68)	NEED TO CHECK AC - NOT WORKING - OT INSIDE	Thulasi Daran. R.	Contactora problem. contactor changed.		Rajasekari. R. - OPD	05/09/2022
Comp. Dt. :		27/06/2022						
Status :		Completed						
566	22060978	NEURO SURGERY OPD	AC WATER LEAKAGE	Ramesh. P.	V belt problem. Problem rectified.		Lavanya. M. - OPD	06/08/2022
Comp. Dt. :		02/07/2022						
Status :		Completed						
567	22070067	Nephrology OPD	NEED TO CHECK AC - NOT WORKING - NEED URGENT SERVICE	Ramesh. P.	Indoor unit water serviced.		Suvitha. R. - OPD	05/09/2022

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 14/07/2022 Status : Completed								
568	22070558	CARDIOLOGY OPD	need to check ac cooling	Pragash. P.	remote mode manually changed.		Radhika. R. - OPD	05/09/2022
Comp. Dt. : 20/07/2022 Status : Completed								
569	22070763	DENTAL OPD -2ND FLOOR	AC NOT WORKING - NEED TO CHECK COOLING	Panneer Selvam. P.	pc board serviced and refixed.		Lakshmi Devi. R. - OPD	05/09/2022
Comp. Dt. : 22/07/2022 Status : Completed								
570	22070837	General Medicine - OPD	AC NOT WORKING IN DEMO ROOM	Thulasi Daran. R.	Burnt wire changed with new one.		Sivaranjani. P. - OPD	05/09/2022
Comp. Dt. : 02/08/2022 Status : Completed								
571	22080064	Paediatrics - OPD	AC WATER LEAKAGE AT SCAN ROOM	Babu. D.	Drain tray cleaned and serviced.		Velangkanni. K. - OPD	05/09/2022
Comp. Dt. : 11/08/2022 Status : Completed								
572	22080410	DERMATOLOGY OPD	NEED TO CHECK AC COOLING AT PUVA THERAPY ROOM	Babu. D.	Honey comb destroyed inside indoor unit. Cleaned and refixed.		Indumathi. T. - OPD	05/09/2022
573	22080417	CARDIOLOGY OPD	AC SOUND & COOLING PROBLEM	Manikandan. A. R.	Indoor fan motor bush changed.		Radhika. R. - OPD	05/09/2022
Comp. Dt. : 19/08/2022 Status : Completed								
574	22080625	General Medicine - OPD	AC NOT WORKING	Panneer Selvam. P.	Burnt wire changed.		Sivaranjani. P. - OPD	05/09/2022
Comp. Dt. : 24/08/2022 Status : Completed								
575	22080814	DENTAL OPD -2ND FLOOR	AC NOT WORKING AT HOD ROOM	Thulasi Daran. R.	Remote mode changed manually.		Lakshmi Devi. R. - OPD	05/09/2022
Comp. Dt. : 25/08/2022 Status : Completed								
576	22080845	TB & Chest OPD	AC NOT WORKING	Thulasi Daran. R.	Remote mode changed manually.		Jothi.R. - OPD	05/09/2022
Comp. Dt. : 30/08/2022 Status : Completed								
577	22081019	NEUROLOGY OPD-2ND FLOOR	AC WATER LEAKAGE	Babu. D.,Vijay. M.,Manikandan. A. R.	Drain tray cleaned and serviced.		ayanya. M. - OPD	05/09/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 06/09/2022 Status : Completed								
578	22090242	Nephrology OPD	AC WATER LEAKAGE	Panneer Selvam. P.,Babu. D.,Manikandan. A. R.	Drain tray cleaned and serviced.		Jenifer. K. - OPD	07/09/2022
Comp. Dt. : 09/09/2022 Status : Completed								
579	22090362*	Surgery OPD	AC NOT WORKING AT DEMO ROOM	Panneer Selvam. P.,Amarajothi.V.,Babu. D.	Breaker trip. Then Breaker ON.		Indhira. M. - OPD	10/09/2022
Comp. Dt. : 13/09/2022 Status : Completed								
580	22090471*	Nephrology OPD	AC SOUND PROBLEM - OPD NO 215	Panneer Selvam. P.,Amarajothi.V.,Thulasi Daran. R.	Work in progress		Jenifer. K. - OPD	20/09/2022
Comp. Dt. : 16/09/2022 Status : Completed								
581	22090638	Surgery OPD	AC NOT WORKING - ROOM NO 52	Panneer Selvam. P.,Babu. D.,Vijay. M.	Breaker trip. Manually ON		Indhira. M. - OPD	17/09/2022
Comp. Dt. : 21/09/2022 Status : Completed								
582	22090826	ENT OPD	AC NOT WORKING AT DEMO ROOM	Pragash. P.,Manikandan. A. R.,Ramesh. P.	Breaker trip ON it.		Kamala.D. - OPD	22/09/2022
Comp. Dt. : 28/09/2022 Status : Completed								
583	22091113	CARDIOLOGY OPD	NEED TO CHECK AC COOLING - AC NOT WORKING	Manikandan. A. R.,Thulasi Daran. R.,Vijay. M.	Remote mode changed manually and reset it.		Radhika. R. - OPD	30/09/2022
Comp. Dt. : 03/10/2022 Status : Completed								
584	22100015	Nephrology OPD	AC NOT WORKING	Elumalai. J.,Gnanapragasam. N.,Panneer Selvam. P.	Breaker trip. ON it manually		Jenifer. K. - OPD	07/10/2022
Comp. Dt. : 10/10/2022 Status : Completed								
585	22100249	NEUROLOGY OPD-2ND FLOOR	AC NOT WORKING - OPD NO 222	Manikandan. A. R.	Power problem. No complaints		avanya. M. - OPD	11/10/2022
Comp. Dt. : 13/10/2022								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
586	22100415	DERMATOLOGY OPD	NEED AC REMOTE	Ramesh. P.,Thulasi Daran. R.,Manikandan. A. R.	AC remote handed over.		Indumathi. T. - OPD	26/10/2022
Comp. Dt. : 17/11/2022								
Status : Completed								
587	22110712	IVF ART CLINIC-INSIDE OF OG OPD(NO.68)	NEED AC SERVICE [ALL AC'S]	Pragash. P.	All unit serviced.		Rajasekari. R. - OPD	22/11/2022
Comp. Dt. : 22/11/2022								
Status : Completed								
588	22110941	DENTAL OPD -2ND FLOOR	NEED TO CHECK AC TEMPERATURE - UNBALANCED	Thulasi Daran. R.,Vijay. M.,Pragash. P.	Unit working properly.		Priyadharshini. S. - OPD	29/11/2022
Comp. Dt. : 24/11/2022								
Status : Completed								
589	22111063	CTVS-ROOM NO.225 -2ND FLOOR	A/C NOT WORKING	Udhaya Shankar. P.	Breaker trip. ON it manually.		Suvitha. R. - OPD	28/11/2022
Comp. Dt. : 02/12/2022								
Status : Completed								
590	22120082	SPECIAL OPD IN 2ND FLOOR	AC NOT WORKING	Ramesh. P.	Indoor unit serviced.		Kamala.D. - OPD	10/12/2022
591	22120094	CTVS-ROOM NO.225 -2ND FLOOR	AC- TRIP PROBLEM	Ramesh. P.	Breaker trip. ON it manually.		Suvitha. R. - OPD	10/12/2022
Comp. Dt. : 14/12/2022								
Status : Completed								
592	22120658	General Medicine - OPD	AC NOT WORKING - DEMO ROOM	Ramesh. P.	New AC installation work done. Wire connection given.		Bharathi.D. - OPD	16/12/2022
Comp. Dt. : 16/12/2022								
Status : Completed								
593	22120770	General Medicine - OPD	A/c not working at demo room	Ramesh. P.	MCB breaker changed.		Bharathi.D. - OPD	21/12/2022
Comp. Dt. : 19/12/2022								
Status : Completed								
594	22120833	OG-OPD	AC NOT COOLING	Gnanapragasam. N.	Wiring problem rectified.		Velangkanni. K. - OPD	20/12/2022
Comp. Dt. : 07/01/2023								
Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
604	23050321	NEUROLOGY OPD-2ND FLOOR	AC NOT WORKING	Pragash. P.	STABILIZER PROBLEM. DIRECTLY CONNECTED TO THE POWER SUPPLY		Radhika. R. - OPD	09/05/2023
Comp. Dt. : 11/05/2023 Status : Completed								
605	23050440	IVF ART CLINIC-INSIDE OF OG OPD(NO.68)	NEED TO CHECK COOLER [FREEZER] DOOR - NOT CLOSING PROPER	Pragash. P.	DRAIN PIPELINE CLEANED AND SERVICED.		Rajasekari. R. - OPD	27/05/2023
606	23050463	Nephrology OPD	AC WATER LEAKAGE	Vasanthakumar. V.	CEILING WATER LEAKAGE. CIVIL MAINTENANCE COMPLAINT.		Jenifer. K. - OPD	12/05/2023
Comp. Dt. : 15/05/2023 Status : Completed								
607	23050561	NEURO SURGERY OPD	AC NOT WORKING	Ramesh. P.	BREAKER TRIP MANUALLY ON IT		Radhika. R. - OPD	16/05/2023
Comp. Dt. : 18/05/2023 Status : Completed								
608	23050733	CARDIOLOGY OPD	AC NOT WORKING - COOLING PROBLEM	Phillipkumar. D.	BREAKER TRIP. MANUALLY ON		Radhika. R. - OPD	20/05/2023
Comp. Dt. : 23/05/2023 Status : Completed								
609	23050902	Nephrology OPD	AC SOUND PROBLEM - OPD NO 251	Ramesh. P.	DRAIN TRAY CLEANED AND SERVICED. M-SEAL PACKING WORK DONE IN DAMAGED DRAIN TRAY.		Jenifer. K. - OPD	27/05/2023
Comp. Dt. : 06/06/2023 Status : Completed								
610	23060186	OG-OPD	AC NOT WORKING AT DENO ROOM	Ramesh. P.	POWER PROBLEM.		Velangkanni. K. - OPD	07/06/2023
Comp. Dt. : 08/06/2023 Status : Completed								
611	23060271	Nephrology OPD	AC SOUND PROBLEM - OPD NO 215	Ramesh. P.	BLOWER SOUND ARRESTED.		Jenifer. K. - OPD	09/06/2023
Comp. Dt. : 09/06/2023 Status : Completed								
612	23060330	OG-OPD	AC NOT WORKING AT DEMO ROOM	Vasanthakumar. V.	REMOTE MODE CHANGED.		Velangkanni. K. - OPD	13/06/2023
Comp. Dt. : 13/06/2023 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
613	23060446	OG-OPD	AC NOT WORKING IN SCAN ROOM	Gnanapragasam. N.	40 mfd capacitor changed.		Adhilakshmi. A. - OPD	14/06/2023
	Comp. Dt. : 20/06/2023							
	Status : Completed							
614	23060733	OG-OPD	AC WATER LEAKAGE	Phillipkumar. D.	DRAIN TRAY CLEAN AND SERVICED.		Adhilakshmi. A. - OPD	21/06/2023
	Comp. Dt. : 21/06/2023							
	Status : Completed							
615	23060754	Dental Special Clinic	AC NOT WORKING	Phillipkumar. D.	Breaker trip manually ON		Jayasree. S. - TB & Chest / Psychiatry	23/06/2023
616	23060784	Nephrology OPD	AC NOT WORKING OPD NO 215	Vijay. M.	Outdoor unit refixed in another location and gas charged.		Jenifer. K. - OPD	23/06/2023
	Comp. Dt. : 26/06/2023							
	Status : Completed							
617	23060942	DENTAL OPD -2ND FLOOR	NEED TO CHECK FRIDGE PANEL - NOT WORKING	Ramesh. P.	New probe changed.		Lakshmi Devi. R. - OPD	27/06/2023
	Comp. Dt. : 27/06/2023							
	Status : Completed							
618	23060995	IVF ART CLINIC-INSIDE OF OG OPD(NO.68)	AC NOT WORKING IN OT	Phillipkumar. D.	INDOOR SWING MOTOR ADJUSTMENT.		Rajasekari. R. - OPD	28/06/2023
619	23061023	DENTAL OPD	AC NOT WORKING	Phillipkumar. D.	PC board serviced and refixed.		Sarala. V. - OPD	07/07/2023
	Dept Name : Operation Theatre - Air Condition Department							
	Comp. Dt. : 05/05/2022							
	Status : Completed							
620	22050118	EMERGENCY OT NEAR CASUALTY	AC NOT WORKING	Thulasi Daran. R.	Contactora problem. Rat bitten the wire inside the false ceiling. Joint and taped it. Unit is working		Hemalatha.G. - Operation Theatre	06/06/2022
	Comp. Dt. : 16/05/2022							
	Status : Completed							
621	22050575	ORTHO OT	AC WATER LEAKAGE	Ramesh. P.	AHU drain tray serviced.		Bhuvaneswari. I. - Operation Theatre	06/06/2022
	Comp. Dt. : 20/05/2022							
	Status : Completed							
622	22050768	ORTHO OT	AC WATER LEAKAGE AT RECOVERY ROOM SIDE	Panneer Selvam. P.	Water leakage and coil blocked. Filter and coil is cleaned. Unit is working.		Mahalakshmi. G. - Operation Theatre	29/05/2022

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHAKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 01/06/2022 Status : Completed								
623	22060014	OG OT	AC NOT WORKING IN OT NO 10	Thulasi Daran. R.	Chiller problem. AHU working.		Sasikala. S. - Operation Theatre	20/06/2022
Comp. Dt. : 02/06/2022 Status : Completed								
624	22060083	New OT	AC NOT WORKING AT RECOVERY ROOM OT NO 8 & 9	Panneer Selvam. P.	Hepa filter serviced. AHU serviced.		Gayathri. K. - Operation Theatre	20/06/2022
Comp. Dt. : 06/06/2022 Status : Completed								
625	22060202	New OT	AC NOT WORKING	Pragash. P.	Power supply cut. ON it		Jagatheeswaran. G. - Operation Theatre	27/06/2022
Comp. Dt. : 17/06/2022 Status : Completed								
626	22060636	OG OT	AC NOT WORKING	Thulasi Daran. R.	AHU belt changed (No.42))		Ramamoorthy.T.K - Operation Theatre	27/06/2022
Comp. Dt. : 21/06/2022 Status : Completed								
627	22060745	OG OT	NEED TO CHECK AC - COOLING PROBLEM	Amarajothi.V.	AHU belt changed.		Ramamoorthy.T.K - Operation Theatre	27/06/2022
Comp. Dt. : 14/07/2022 Status : Completed								
628	22070550	OG OT	NEED TO CHECK AC COOLING	Ramesh. P.	Low cubic feet per minute		Amudha. V. - Operation Theatre	05/09/2022
Comp. Dt. : 22/07/2022 Status : Completed								
629	22070843	SPECIALITY OT	NEED TO CHECK AC - WATER LEAKAGE [2 NOS]	Thulasi Daran. R.	Civil complaint.		Revathi. M. - Operation Theatre	05/09/2022
Comp. Dt. : 29/07/2022 Status : Completed								
630	22071059	OG OT	AC NOT WORKING	Thulasi Daran. R.	Low cubic feet per minute		Amudha. V. - Operation Theatre	05/09/2022
Comp. Dt. : 01/08/2022 Status : Completed								
631	22080010	OG OT	AC NOT WORKING	Panneer Selvam. P.	low cubic feet per minute.		Amudha. V. - Operation Theatre	05/09/2022
Comp. Dt. : 05/08/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
632	22080200	ORTHO OT	AC NOT WORKING IN RECOVERY ROOM	Thulasi Daran. R.	Indoor fan motor changed. Outdoor gas leak condenser coil welding work done.		Mahalakshmi. G. - Operation Theatre	05/09/2022
633	22080218	EMERGENCY OT NEAR CASUALTY	NEED TO CHECK FRIDGE-COOLING PROBLEM	Thulasi Daran. R.	Door not closed properly.		Hari Hara Sudhan. K. - Operation Theatre	05/09/2022
Comp. Dt. : 08/08/2022 Status : Completed								
634	22080289	SPECIALITY OT	NEED AC WIND SERVICE	Thulasi Daran. R.	AHU serviced.		Hemalatha.G. - Operation Theatre	05/09/2022
Comp. Dt. : 08/09/2022 Status : Completed								
635	22090301	SPECIALITY OT	NEED TO CHECK AC MACHINE SWITCH - SHOCK PROBLEM	Pragash. P.	Problem rectified.		Sobiya. N. - Operation Theatre	10/09/2022
Comp. Dt. : 27/09/2022 Status : Completed								
636	22091085	EMERGENCY OT NEAR CASUALTY	FRIDGE NOT WORKING - NEED TO CHECK COOLING	Panneer Selvam. P.,Pragash. P.,Gnanapragasam. N.	No problem occurs. Door not closed properly.		Hemalatha.G. - Operation Theatre	07/10/2022
Comp. Dt. : 28/09/2022 Status : Completed								
637	22091118	New OT	NEED TO CHECK AC COOLING - AC NOT WORKING AT DOCTOR'S ROOM NO 3	Thulasi Daran. R.	New capacitor (50 mfd + 5 mfd) changed. Unit is working. Gas topup kept 70 psi.		Kousalya. S. - Operation Theatre	30/09/2022
638	22091119	New OT	FRIDGE & FRIDGE INSIDE LIGHT NOT WORKING NEED TO CHECK	Thulasi Daran. R.	Light adjusted.		Ramachandiran. M. - Operation Theatre	11/10/2022
Comp. Dt. : 10/10/2022 Status : Completed								
639	22100219	SPECIALITY OT	AC SOUND PROBLEM	Panneer Selvam. P.,Manikandan. A. R.,Pragash. P.	power problem. Motor vibration due low voltage		Narayanan.R. - Operation Theatre	11/10/2022
640	22100220	SPECIALITY OT	AC SOUND PROBLEM	Panneer Selvam. P.,Pragash. P.,Ramesh. P.	power problem. Motor vibration due low voltage.		Narayanan.R. - Operation Theatre	11/10/2022
Comp. Dt. : 12/10/2022 Status : Completed								
641	22100332	EMERGENCY OT NEAR CASUALTY	FRIDGE NOT COOLING	Panneer Selvam. P.	Refridgerator condemned.		Marine. S. - Operation Theatre	26/11/2022
Comp. Dt. : 14/10/2022								


Dr. KAGNE. R.N
 DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
642	22100452	SPECIALITY OT	AC NOT WORKING	Vijay. M.,Vasanthakumar. V.,Panneer Selvam. P.	Breaker trip. ON it.		Revathi. M. - Operation Theatre	18/10/2022
643	22100469	SPECIALITY OT	AC NOT WORKING - OT NO 7	Panneer Selvam. P.,Vijay. M.,Vasanthakumar. V.	Power problem.		Gayathri. G. - Operation Theatre	18/10/2022
Comp. Dt. : 25/10/2022								
Status : Completed								
644	22100771	SPECIALITY OT	FRIDGE LIGHT NOT WORKING	Pragash. P.,Ramesh. P.,Vasanthakumar. V.	Fridge wire adjustment done.		Narayanan.R. - Operation Theatre	28/10/2022
Comp. Dt. : 14/11/2022								
Status : Completed								
645	22110503	OG OT	FRIDGE TEMPERATUE NOT WORKING	Amarajothi.V.	Probe wire adjusted.		Ranjani. V. - Operation Theatre	29/11/2022
Comp. Dt. : 23/11/2022								
Status : Completed								
646	22111004	New OT	A/C NOT WORKING-(OLD SURGERY OT)	Ramesh. P.	Breaker trip. ON it manually		Ramachandiran. M. - Operation Theatre	28/11/2022
Comp. Dt. : 25/11/2022								
Status : Completed								
647	22111080	ORTHO OT	A/C PIPELINE WATER LEAKAGING PROBLEM	Ramesh. P.	Drain line cleaned and serviced.		Ramachandiran. M. - Operation Theatre	29/11/2022
Comp. Dt. : 03/12/2022								
Status : Completed								
648	22120114	Main OT	AC NOT WORKING IN RECOVERY ROOM	Vasanthakumar. V.	Spare PC board fixed.		Shankari. G. - Operation Theatre	10/12/2022
Comp. Dt. : 05/12/2022								
Status : Completed								
649	22120158	SPECIALITY OT	AC NOT WORKING - OT NO 4	Panneer Selvam. P.	Water pipeline stainer cleaned.		Jayapratha. S. - Operation Theatre	10/12/2022
650	22120178	Main OT	IN RECOVERY ROOM-A/C NOT WORKING	Vasanthakumar. V.	PC board problem. Spare PC board changed.		Shankari. G. - Operation Theatre	10/12/2022
651	22120180	SPECIALITY OT	A/C WATER LEAKAGING PROBLEM	Ramesh. P.	Drain tray cleaned and serviced.		Revathi. M. - Operation Theatre	10/12/2022
Comp. Dt. : 06/12/2022								
Status : Completed								
652	22120267	Main OT	A/C WATER LEAKAGING PROBLEM	Ramesh. P.	Drain tray cleaned and serviced.		Shankari. G. - Operation Theatre	14/12/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 07/12/2022 Status : Completed								
653	22120321	SPECIALITY OT	AC WATER LEAKAGE AT MALE SURGEN'S ROOM	Pragash. P.	Drain tray cleaned and serviced.		Sobiya. N. - Operation Theatre	10/12/2022
Comp. Dt. : 12/12/2022 Status : Completed								
654	22120565	SPECIALITY OT	OT.4-A/C NOT WORKING	Ramesh. P.	Rat bitten the wire. Rejoined and insulated.		Gayathri. G. - Operation Theatre	14/12/2022
Comp. Dt. : 11/02/2023 Status : Completed								
655	23020436	SPECIALITY OT	AC NOT WORKING - OT NO 7	Vasanthakumar. V.	BREAKER TRIP. MANUALLY ON IT		Murugan. M. - Operation Theatre	13/02/2023
Comp. Dt. : 15/02/2023 Status : Completed								
656	23020601	SPECIALITY OT	NEED TO CHECK AC PIPELINE - CEILING WATER LEAKAGE AT EMERGENCY OT INSIDE WALL	Panneer Selvam. P.	EXPANSION JOINT PROBLEM.		Sobiya. N. - Operation Theatre	18/02/2023
Comp. Dt. : 20/02/2023 Status : Completed								
657	23020777	OG OT	NEED AC CLEANING WORK	Pragash. P.	INDOOR UNIT CLEANED AND SERVICED WITH WATER		Manibharathi. S. - Operation Theatre	21/02/2023
Comp. Dt. : 11/03/2023 Status : Completed								
658	23030445	OG OT	AC NOT WORKING - OT NO 12 - NEED URGENT SERVICE	Pragash. P.	COIL REWINDED AND REFIXED IN THE UNIT		Ranjani. V. - Operation Theatre	20/03/2023
Comp. Dt. : 07/04/2023 Status : Completed								
659	23040213	New OT	AC NOT WORKING - OT NO 9	Thulasi Daran. R.	MOTOR BELT CHANGED.		Gayathri. G. - Operation Theatre	08/04/2023
Comp. Dt. : 18/04/2023 Status : Completed								
660	23040542	SURGERY OT	2NOS AC NOT WORKING IN OLD SURGERY OT -1129	Vasanthakumar. V.	3 PHASE MOTOR REWINDED AND REFIXED.		Ramachandiran. M. - Operation Theatre	03/05/2023
Comp. Dt. : 02/05/2023 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
661	23050027	SURGERY OT	AC NOT WORKING [OLD SURGERY OT]	Phillipkumar. D.	BREAKER TRIPPED MANUALLY ON IT.		Ramachandiran. M. - Operation Theatre	03/05/2023
Comp. Dt. : 09/05/2023 Status : Completed								
662	23050343	ORTHO OT	AC WATER LEAKAGE - ORTHO OT INSIDE - SIDE ROOM	Gnanapragasam. N.	DRAIN TRAY CLEAN AND SERVICED.		Mahalakshmi. G. - Operation Theatre	11/05/2023
Comp. Dt. : 18/05/2023 Status : Completed								
663	23050738	ORTHO OT	NEED URGENT SERVICE - AC NO 2 NOT WORKING - CASE GOING ON	Vasanthakumar. V.	MOTOR BELT CHANGED		Iyyappan. K. - Operation Theatre	18/05/2023
Comp. Dt. : 31/05/2023 Status : Completed								
664	23051224	New OT	AC WATER LEAKAGE [HOD ROOM]	Vasanthakumar. V.	INDOOR UNIT SERVICED.		Punitha. A. - Operation Theatre	31/05/2023
Comp. Dt. : 09/06/2023 Status : Completed								
665	23060318	OG OT	FRIDGE PANEL NOT WORKING	Ramesh. P.	PROBE NEW BATTERY CHANGED.		Sobiya. S. - Operation Theatre	12/06/2023
Comp. Dt. : 21/06/2023 Status : Completed								
666	23060762	ORTHO OT	AC WATER LEAKAGE AT RECOVERY	Phillipkumar. D.	Drain tray cleaned and serviced.		Iyyappan. K. - Operation Theatre	23/06/2023
Comp. Dt. : 30/06/2023 Status : Completed								
667	23061137	SURGERY OT	AC NOT WORKING - 7 TH OT - [OLD SURGERY OT]	Vasanthakumar. V.,Vijay. M.,Phillipkumar. D.	3 phase motor rewinded and refixed.		Ramachandiran. M. - Operation Theatre	07/07/2023
Dept Name : P.H.C. - Tiruvennainallur - Air Condition Department Comp. Dt. : 27/12/2022 Status : Completed								
668	22121220	THIRUVENNAINALLUR HOSPITAL(SMVMCH)	A/C WATER LEAKAGING PROBLEM	Sasikumar. S.	Drain dray clean and serviced.		Kanagasabai. D. - P.H.C. - Tiruvennainallur	11/01/2023
Dept Name : PAEDIATRICS - Air Condition Department Comp. Dt. : 13/05/2023 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
669	23050548	NICU	NEED TO CHECK AC COOLING - PROBLEM - NICU 11-1 OUTBORN	Ramesh. P.	BREAKER TRIP. MANUALLY ON IT		INDHUJA. M - PAEDIATRICS	18/05/2023
Dept Name : Paediatrics Ward - Air Condition Department Comp. Dt. : 18/05/2022 Status : Completed								
670	22050658	GASTROENTROLOGY OPD-2ND FLOOR	AC NOT WORKING - OPD NO 225	Pragash. P.	Capacitor 50 mfd changed.		Indumathi. T. - OPD	05/09/2022
Dept Name : PHARMACOLOGY - Air Condition Department Comp. Dt. : 22/12/2022 Status : Completed								
671	22121017	PHARMACOLOGY	FRIDGE NOT WORKING	Sasikumar. S.	OLP and relay changed.		Devanathan. S. - PHARMACOLOGY	24/12/2022
Dept Name : Pharmacy - Air Condition Department Comp. Dt. : 06/05/2022 Status : Completed								
672	22050170	Pay Pharmacy	AC WATER LEAKAGE	Pragash. P.	Indoor unit cleaned and serviced.		Silambuselvan. P. - Pharmacy	06/06/2022
Comp. Dt. : 25/06/2022 Status : Completed								
673	22060931	Pay Pharmacy	NEED TO CHECK AC - COOLING PROBLEM	Panneer Selvam. P.	Indoor unit serviced.		Silambuselvan. P. - Pharmacy	07/09/2022
Comp. Dt. : 26/07/2022 Status : Completed								
674	22070974	Pay Pharmacy	NEED TO CHECK AC [3NOS] PROBLEM IN COOLING	Babu. D.	3 unit indoor unit water serviced.		Silambuselvan. P. - Pharmacy	05/09/2022
Comp. Dt. : 10/10/2022 Status : Completed								
675	22100199	MEDICAL STORE IN BASEMENT	DUE DEATH OF RAT IN FALSE CEILING - BAD SMELL - NEED AC SERVICE [2NOS]	Vasanthakumar. V., Vijay. M., Elumalai. J.	Problem solved.		Sujatha.S. - Pharmacy	11/10/2022
Comp. Dt. : 28/10/2022 Status : Completed								
676	22100897	Pay Pharmacy	A/C COOLING PROBLEM	Pragash. P.	Indoor unit coil serviced with water.		Vasanthamurugan. S. - Pharmacy	29/10/2022
Comp. Dt. : 28/12/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
677	22121298	Pay Pharmacy	FRIDGE WATER LEAKAGE	Panneer Selvam. P.	Drain tray cleaned.		Ramya. R. - Pharmacy	31/12/2022
Comp. Dt. : 29/12/2022 Status : Completed								
678	22121334	Pay Pharmacy	REFRIGERATOR WATER LEAKAGING PROBLEM	Vijay. M.	Drain tray cleaned.		Rameshkumar. R. - Pharmacy	31/12/2022
Comp. Dt. : 03/02/2023 Status : Completed								
679	23020084	Pay Pharmacy	NEED TO CHECK FRIDGE BURN SMELL - NEED URGENT SERVICE	Ramesh. P.	3 pin socket problem. New socket fixed.		Silambuselman. P. - Pharmacy	04/02/2023
Comp. Dt. : 18/02/2023 Status : Completed								
680	23020720	Pay Pharmacy	AC - DISPLAY PROBLEM	Gnanapragasam. N.	DISPLAY IS NOT AVAILABLE IN THE MARKET.		Silambuselman. P. - Pharmacy	26/04/2023
Comp. Dt. : 23/03/2023 Status : Completed								
681	23030947	Pay Pharmacy	NEED TOCHECK AC - WATER LEAKAGE	Ramesh. P.	DRAIN TRAY AND DRAIN PIPELINE CLEANED.		Silambuselman. P. - Pharmacy	25/03/2023
Comp. Dt. : 19/05/2023 Status : Completed								
682	23050801	Pay Pharmacy	AC WATER LEAKAGE	Vasanthakumar. V.	drain tray clean and serviced.		Silambuselman. P. - Pharmacy	22/05/2023
Dept Name : PICU & NICU - Air Condition Department Comp. Dt. : 07/07/2022 Status : Completed								
683	22070265	PICU	AC NOT WORKING	Panneer Selvam. P.	Indoor unit serviced with water		Poovathal. K. - PICU & NICU	05/09/2022
Comp. Dt. : 27/07/2022 Status : Completed								
684	22070992	PICU	NEED TO CHECK FRIDGE TEMPARETURE - DISPLAYING WRONG	Panneer Selvam. P.	Indoor unit pump down and serviced.		Poovathal. K. - PICU & NICU	06/08/2022
Comp. Dt. : 13/08/2022 Status : Completed								
685	22080469	PICU	NEED AC GENERAL SERVICE & CLEANING WORK	Amarajothi.V.	Grill cleaning work done.		Poovathal. K. - PICU & NICU	05/09/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 03/09/2022 Status : Completed								
686	22090123	PICU	NEED TO CHECK FRIDGE TEMPARATURE - DISPLAY IN HIGH	Panneer Selvam. P.	New temperature probe changed.		Arya. K. - PICU & NICU	07/09/2022
Comp. Dt. : 20/09/2022 Status : Completed								
687	22090800	PICU	NEED TO CHECK FRIDGE - WRONGLY DISPLAYED, HIGH TEMPARETURE	Pragash. P.,Babu. D.,Panneer Selvam. P.	Probe adjustment done.		Vijayalakshmi. C. - PICU & NICU	21/09/2022
Comp. Dt. : 28/09/2022 Status : Completed								
688	22091095	PICU	AC NOT WORKING	Panneer Selvam. P.,Pragash. P.,Vijay. M.	Remote mode changed manually and reset it.		Umamaheswari. P. - PICU & NICU	30/09/2022
Comp. Dt. : 21/10/2022 Status : Completed								
689	22100709	PICU	AC WATER LEAKAGE	Vasanthakumar. V.,Elumalai. J.,Vijay. M.	Water leakage arrested.		Poovathal. K. - PICU & NICU	26/10/2022
Comp. Dt. : 25/10/2022 Status : Completed								
690	22100783	NICU	AC NOT WORKING	Ramesh. P.	Contacto problem. Problem rectified.		Parameswari. P. - PICU & NICU	26/10/2022
Comp. Dt. : 27/10/2022 Status : Completed								
691	22100849	NICU	AC NOT WORKING	Manikandan. A. R.	New contactor changed.		Parameswari. P. - PICU & NICU	28/10/2022
Comp. Dt. : 31/10/2022 Status : Completed								
692	22100988	PICU	FRIDGE TEMPERATURE NOT WORKING	Gnanapragasam. N.	Probe adjustment done.		Poovathal. K. - PICU & NICU	02/11/2022
Comp. Dt. : 02/11/2022 Status : Completed								
693	22110019	NICU	A/C NOT WORKING	Pragash. P.	Indoor unit serviced.		Parameswari. P. - PICU & NICU	05/11/2022
Comp. Dt. : 15/11/2022 Status : Completed								
694	22110618	NEW NICU & PICU-2ND FLOOR	A/C NOT WORKING	Panneer Selvam. P.	A/C working normally		Parameswari. P. - PICU & NICU	28/11/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 08/12/2022 Status : Completed								
695	22120383	NICU	A/C SWITCH NOT WORKING	Vasanthakumar. V.	Breaker trip. Manually ON it.		Parameswari. P. - PICU & NICU	10/12/2022
Comp. Dt. : 06/01/2023 Status : Completed								
696	23010290	NICU	(1275) A/C-WATER LEAKAGE PROBLEM	Ramesh. P.	New drain line fixed.		Parameswari. P. - PICU & NICU	10/01/2023
Comp. Dt. : 13/01/2023 Status : Completed								
697	23010545	NICU	NEED TO CHECK AC - WATER LEAKAGE & TEMPERATURE PROBLEM	Manikandan. A. R.	Drain tray cleaned and serviced.		Parameswari. P. - PICU & NICU	14/01/2023
Comp. Dt. : 04/02/2023 Status : Completed								
698	23020121	PICU	AC NOT WORKING	Gnanapragasam. N.	Breaker trip manually ON it.		Poovathal. K. - PICU & NICU	06/02/2023
Comp. Dt. : 15/02/2023 Status : Completed								
699	23020590	NICU	FRIDGE PANEL PROBE NOT WORKING	Gnanapragasam. N.	WIRE CONNECTION NOT PROPERLY THEN PROPERLY CONNECTED THE WIRE,		Parameswari. P. - PICU & NICU	17/02/2023
Comp. Dt. : 24/02/2023 Status : Completed								
700	23020950	PICU	AC NOT WORKING	Phillipkumar. D.	BREAKER TRIP. MANUALLY ON IT.		Poovathal. K. - PICU & NICU	28/02/2023
Comp. Dt. : 08/03/2023 Status : Completed								
701	23030319	PICU	AC WATER LEAKAGE AT CARITOR	Gnanapragasam. N.	Need to check it by company AC Technician		Divya. M. - PICU & NICU	01/04/2023
Comp. Dt. : 28/03/2023 Status : Completed								
702	23031167	PICU	AC NOT WORKING	Amarajothi.V.	BREAKER TRIP. MANUALLY ON		Umamaheswari. P. - PICU & NICU	29/03/2023
Comp. Dt. : 04/04/2023 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
703	23040134	PICU	NEED TO CHECK FRIDGE DOOR , PROBE & TEMPERATURE PANEL - PROBLEM	Vasanthakumar. V.	RELAY PROBLEM. RELAY CHANGED.		Poovathal. K. - PICU & NICU	06/06/2023
		Comp. Dt. : 31/05/2023 Status : Completed						
704	23051264	PICU	AC WATER LEAKAGE AT STORE ROOM	Vijay. M.	DRAIN TRAY CLEANED AND SERVICED.		Thirushayeni. A. - PICU & NICU	01/06/2023
		Comp. Dt. : 09/06/2023 Status : Completed						
705	23060322	NICU	AC WATER LEAKAGE	Vijay. M.	Drain trayb and drain line cleaned.		Sarumathi. A. - PICU & NICU	13/06/2023
		Dept Name : POW & SICU - Air Condition Department Comp. Dt. : 17/05/2022 Status : Completed						
706	22050587	SICU	AC NOT WORKING	Babu. D.	Outdoor unit serviced.		Jamuna. K - POW & SICU	20/06/2022
		Comp. Dt. : 20/06/2022 Status : Completed						
707	22060717	POW & SICU	AC NOT WORKING [4 ROOMS]	Panneer Selvam. P.	Indoor unit serviced.		Jamuna. K - POW & SICU	05/09/2022
		Comp. Dt. : 14/07/2022 Status : Completed						
708	22070553	POW & SICU	NEED TO CHECK FRIDGE LIGHT	Panneer Selvam. P.	Wire loose connection. Work rectified.		Valarmathy. K. - POW & SICU	05/09/2022
		Comp. Dt. : 17/08/2022 Status : Completed						
709	22080519	POW & SICU	A/C NOT WORKING	Panneer Selvam. P.	Drain tray cleaned.		Aruldevi. S. - POW & SICU	05/09/2022
		Comp. Dt. : 08/09/2022 Status : Completed						
710	22090309	POW & SICU	AC WATER LEAKAGE	Panneer Selvam. P.,Babu. D.,Vasanthakumar. V.	Drain tray cleaned and serviced.		Jamuna. K - POW & SICU	09/09/2022
		Comp. Dt. : 19/09/2022 Status : Completed						
711	22090729	POW & SICU	NEED TO REFIX AC - FRONT DOOR REMOVED AT DOCTOR'S ROOM	Panneer Selvam. P.,Ramesh. P.,Pragash. P.	Door fixing work done		Prasini. S. - POW & SICU	20/09/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 20/09/2022 Status : Completed								
712	22090776	POW & SICU	NEED TO CHECK FRIDGE INSIDE LIGHT & TEMPERATURE - PROBLEM	Pragash. P.,Panneer Selvam. P.,Babu. D.	Probe adjustment done		Jamuna. K - POW & SICU	21/09/2022
Comp. Dt. : 24/09/2022 Status : Completed								
713	22090985	POW & SICU	AC WATER LEAKAGE	Thulasi Daran. R.,Pragash. P.,Ramesh. P.	Drain tray cleaned.		Jamuna. K - POW & SICU	28/09/2022
Comp. Dt. : 28/09/2022 Status : Completed								
714	22091105	SICU	AC NOT WORKING	Babu. D.,Manikandan. A. R.,Vijay. M.	PC board problem. Removed for service.		Lakshmi. R. - POW & SICU	30/09/2022
Comp. Dt. : 18/10/2022 Status : Completed								
715	22100576	SICU	AC WATER LEAKAGE	Panneer Selvam. P.	Drain tray cleaned and serviced.		Valarmathy. K. - POW & SICU	21/10/2022
Comp. Dt. : 20/10/2022 Status : Completed								
716	22100657	POW & SICU	AC WATER LEAKAGE	Pragash. P.,Ramesh. P.,Panneer Selvam. P.	Drain tray cleaned and serviced.		Jamuna. K - POW & SICU	21/10/2022
Comp. Dt. : 05/12/2022 Status : Completed								
717	22120149	POW & SICU	AC WATER LEAKAGE	Vasanthakumar. V.	Drain tray cleaning and serviced.		Jamuna. K - POW & SICU	10/12/2022
Comp. Dt. : 16/12/2022 Status : Completed								
718	22120779	POW & SICU	NEED TO CHECK AC COOLING	Ramesh. P.	Mode changed. Unit is working.		Jamuna. K - POW & SICU	20/12/2022
Comp. Dt. : 30/12/2022 Status : Completed								
719	22121351	POW & SICU	2 NO'S A/C NOT WORKING	Ramesh. P.	Breaker trip. Manually ON it.		Jamuna. K - POW & SICU	31/12/2022
Comp. Dt. : 13/01/2023 Status : Completed								
720	23010546	POW & SICU	DAIKIN REMOTE NOT WORKING	Manikandan. A. R.	Daiken remote battery changed.		Jamuna. K - POW & SICU	14/01/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 17/02/2023 Status : Completed								
721	23020684	POW & SICU	NEED TO CHECK WATER DISPENSER LIGHT - NOT WORKING	Ramesh. P.	WIRING PROBLEM. WIRE CONNECTION CHECKED.		Jamuna. K - POW & SICU	18/02/2023
Comp. Dt. : 22/02/2023 Status : Completed								
722	23020844	SICU	A/C-NOT WORKING	Phillipkumar. D.	R-32 GAS(130 PSI) TOP UP DONE.		Jamuna. K - POW & SICU	01/03/2023
Comp. Dt. : 17/03/2023 Status : Completed								
723	23030710	POW & SICU	AC NOT WORKING [2NOS]	Gnanapragasam. N.	PC BOARD SERVICED AND REFIXED. ANOTHER LOCATION REFIXED.		Jamuna. K - POW & SICU	15/04/2023
Comp. Dt. : 16/04/2023 Status : Completed								
724	23040463	SICU	AC WATER LEAKAGE	Vijay. M.	DRAIN TRAY CLEAN AND SERVICED.		Gunavathi. G. - POW & SICU	20/04/2023
Comp. Dt. : 24/04/2023 Status : Completed								
725	23040719	POW & SICU	AC WATER LEAKAGE	Ramesh. P.	DRAIN TRAY CLEAN AND SERVICED.		Jamuna. K - POW & SICU	25/04/2023
Comp. Dt. : 25/04/2023 Status : Completed								
726	23040798	POW & SICU	AC WATER LEAKAGE	Ramesh. P.	drain tray clean and serviced.		Silambarasi. A. - POW & SICU	25/04/2023
Comp. Dt. : 27/04/2023 Status : Completed								
727	23040937	POW & SICU	AC WATER LEAKAGE	Vasanthakumar. V.	drain tray cleaned and serviced.		Jamuna. K - POW & SICU	28/04/2023
Comp. Dt. : 02/05/2023 Status : Completed								
728	23050016	POW & SICU	AC BOARD FELL DOWN	Vasanthakumar. V.	PANEL REFIXED.		Pragadeesh. V. - POW & SICU	03/05/2023
Comp. Dt. : 09/05/2023 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
729	23050366	SPECIAL WARD---B	AC NOT WORKING - AC WATER LEAKAGE ROOM NO B4-B5-B6	Pragash. P.	DRAIN TRAY CLEAN AND SERVICED.		Jayapriya. M. - POW & SICU	11/05/2023
	Comp. Dt. : 12/05/2023							
	Status : Completed							
730	23050476	POW & SICU	AC WATER LEAKAGE	Phillipkumar. D.	DRAIN TRAY CLEANED AND SERVICED.		Renugadevi. J. - POW & SICU	16/05/2023
	Comp. Dt. : 16/05/2023							
	Status : Completed							
731	23050650	POW & SICU	AC NOT WORKING	Ramesh. P.	50 mfd capcitor and thermal connector changed respectively for 2 units.		Jamuna. K - POW & SICU	17/05/2023
	Comp. Dt. : 22/05/2023							
	Status : Completed							
732	23050870	POW & SICU	AC WATER LEAKAGE	Ramesh. P.	DRAIN TRAY CLEANED AND SERVICED.		Praveena. E. - POW & SICU	25/05/2023
	Comp. Dt. : 01/06/2023							
	Status : Completed							
733	23060011	POW & SICU	AC WATER LEAKAGE AT POW SICU & SEPTIC WARD	Vasanthakumar. V.	DOOR OPENED IN ALL ROOMS. NEED TO FIX DOOR CLOSER		Nivetha. A. - POW & SICU	06/06/2023
	Comp. Dt. : 08/06/2023							
	Status : Completed							
734	23060305	POW & SICU	AC NOT WORKING	Vasanthakumar. V.	POWER SUPPLY BURNT. BURNED WIRE REJOINED AND INSULATED.		Praveena. E. - POW & SICU	09/06/2023
	Comp. Dt. : 14/06/2023							
	Status : Completed							
735	23060498	POW & SICU	AC NOT WORKING	Vasanthakumar. V.	breaker trip. manually on		Jamuna. K - POW & SICU	14/06/2023
	Comp. Dt. : 17/06/2023							
	Status : Completed							
736	23060635	POW & SICU	AC WATER LEAKAGE	Vasanthakumar. V.	Drain tray cleaned and serviced.		Jamuna. K - POW & SICU	19/06/2023
	Comp. Dt. : 23/06/2023							
	Status : Completed							
737	23060860	POW & SICU	AC - WATER LEAKAGE	Panneer Selvam. P.	Drain tray cleaned and serviced. Indoor unit coil serviced.		Jamuna. K - POW & SICU	26/06/2023

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 24/06/2023 Status : Completed								
738	23060919	POW & SICU	AC WATER LEAKAGE AT SEPTIC ROOM	Vasanthakumar. V.	Drain tray cleaned and serviced. Indoor unit coil serviced.		Jamuna. K - POW & SICU	26/06/2023
Comp. Dt. : 26/06/2023 Status : Completed								
739	23060989	POW & SICU	AC WATER LEAKAGE	Phillipkumar. D.	Drain tray cleaned and serviced.		Arunkumar. D. - POW & SICU	28/06/2023
Dept Name : Printing Press - Air Condition Department Comp. Dt. : 23/05/2022 Status : Completed								
740	22050834	Printing Press	NEED TO CHECK AC SOUND PROBLEM	Sasikumar. S.	compressor terminal burned. Changed new clip wire.		Vijayasekar. K. - Printing Press	20/06/2022
Comp. Dt. : 03/06/2022 Status : Completed								
741	22060127	Printing Press	AC NOT WORKING	Ramesh. P.	Compressor terminal burnt. Wire is joined and taped		Shanmugam. R. - Printing Press	27/06/2022
Comp. Dt. : 12/08/2022 Status : Completed								
742	22080434	Printing Press	PROBLEM IN AC NEARED PRINTING MACHINE	Manikandan. A. R.	Indoor unit serviced		Vijayasekar. K. - Printing Press	05/09/2022
Comp. Dt. : 20/09/2022 Status : Completed								
743	22090772	Printing Press	AC NOT WORKING	Thulasi Daran. R.	Materials not available.		Thirunavukarassu. K. - Printing Press	28/09/2022
Comp. Dt. : 17/05/2023 Status : Completed								
744	23050700	Printing Press	AC NOT WORKING	Ramesh. P.	ALTERNATE COMPRESSOR ARRANGED.		Thirunavukarassu. K. - Printing Press	29/05/2023
Dept Name : Quality Department - Air Condition Department Comp. Dt. : 25/05/2022 Status : Completed								
745	22050957	NAC OFFICE 4TH FLOOR	AC NOT WORKING	Thulasi Daran. R.	New Compressor (2ton), capillary, stainer, gas, 50 mfd capacitor changed.		Suganthi. M. - Quality Department	05/09/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 01/06/2022								
Status : Completed								
746	22060015	NAC OFFICE 4TH FLOOR	AC NOT WORKING	Pragash. P.	New compressor changed. Gas charged. Stainer changed. cabiliary, 50 mfd capacitor changed.		Suganthi. M. - Quality Department	05/09/2022
Comp. Dt. : 14/06/2022								
Status : Completed								
747	22060531	NAC OFFICE 4TH FLOOR	AC SOUND PROBLEM - WATER LEAKAGE	Babu. D.	Sound arrest		Suganthi. M. - Quality Department	05/09/2022
Comp. Dt. : 08/08/2022								
Status : Completed								
748	22080280	NAC OFFICE 4TH FLOOR	AC NOT WORKING	Manikandan. A. R.	Compressor changed.		Suganthi. M. - Quality Department	05/09/2022
Comp. Dt. : 16/02/2023								
Status : Completed								
749	23020652	CLINICAL DEPARTMENT IN 4th FLOOR	NABH ROOM A/C-COOLING PROBLEM	Vasanthakumar. V.	GAS CHARGED. (1.6 KG) R-22 GASS		Suganthi. M. - Quality Department	08/03/2023
Comp. Dt. : 18/03/2023								
Status : Completed								
750	23030737	NABH OFFICE	NEED TO CHECK AC COOLING - AC NOT WORKING	Vasanthakumar. V.	R22 gas charged (65 psi)		Suganthi. M. - Quality Department	23/03/2023
Comp. Dt. : 12/04/2023								
Status : Completed								
751	23040373	NABH OFFICE	AC NOT WORKING [HOSPITAL IV FLOOR]	Vijay. M.	R22 GAS CHARGED (900 KG)		Suganthi. M. - Quality Department	05/05/2023
Dept Name : Radio Diagnosis - Air Condition Department								
Comp. Dt. : 10/05/2022								
Status : Completed								
752	22050313	BASEMENT SCAN	AC WATER LEAKAGE AT FAX ROOM	Panneer Selvam. P.	Indoor unit serviced		Jayalakshmi. D. - Radio Diagnosis	29/05/2022
753	22050355	BASEMENT SCAN	AC SOUND PROBLEM - NEED TO CHECK	Panneer Selvam. P.	New bush changed. No sound occurs.		Mahendran.V. - Radio Diagnosis	29/05/2022
Comp. Dt. : 12/05/2022								
Status : Completed								
754	22050436	RADIOLOGY	IN X-RAY ROOM-A/C WATER LEAKAGING PROBLEM	Panneer Selvam. P.	Indoor unit cleaned and serviced.		Manikandan. G. - Radio Diagnosis	29/05/2022

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 17/05/2022 Status : Completed								
755	22050618	CT Scan	AC SOUND PROB LEM	Panneer Selvam. P.	Bush is changed. problem solved.		Sushmitha. K. - Radio Diagnosis	29/05/2022
Comp. Dt. : 16/06/2022 Status : Completed								
756	22060628	Ultra Sound	AC WATER LEAKAGE - ROOM NO 2	Manikandan. A. R.	Indoor unit serviced.		Sudha. D. - Radio Diagnosis	27/06/2022
Comp. Dt. : 21/07/2022 Status : Completed								
757	22070772	CT Scan	AC NOT WORKING - ROOM NO B23	Panneer Selvam. P.	Indoor unit fan motor bush changed.		Thamizhselvi. M. - Radio Diagnosis	05/09/2022
Comp. Dt. : 22/07/2022 Status : Completed								
758	22070814	CT Scan	AC NOT WORKING	Panneer Selvam. P.,Vijay. M.,Amarajothi.V.	Indoor unit cleaned and serviced.		Mahendran.V. - Radio Diagnosis	05/09/2022
Comp. Dt. : 23/07/2022 Status : Completed								
759	22070864*	RADIOLOGY	AC WATER LEAKAGE IN FAX ROOM	Ramesh. P.	Outdoor unit gas leak arrest.Capillary, stainer changed and gas charged. New compressor 2TR changed.		Jayalakshmi. D. - Radio Diagnosis	05/09/2022
Comp. Dt. : 01/09/2022 Status : Completed								
760	22090031	CT Scan	AC NOT WORKING	Vijay. M.	Indoor unit bush changed.		Thamizhselvi. M. - Radio Diagnosis	05/09/2022
Comp. Dt. : 06/09/2022 Status : Completed								
761	22090199	CT Scan	NEED TO CHECK AC - SOUND PROBLEM	Panneer Selvam. P.,Amarajothi.V.,Babu. D.	Sound arrest. Blower bush changed.		Mahendran.V. - Radio Diagnosis	08/09/2022
Comp. Dt. : 22/09/2022 Status : Completed								
762	22090907	BASEMENT SCAN	NEED TO CHECK AC PIPELINE - WATER LEAKAGE AT ROOM NO 2	Panneer Selvam. P.,Manikandan. A. R.,Vasanthakumar. V.	R22 Gas topup 500g		Sudha. D. - Radio Diagnosis	28/09/2022
Comp. Dt. : 11/10/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
763	22100298	BASEMENT SCAN	AC WATER LEAKAGE - ROOM NO 15	Panneer Selvam. P.,Pragash. P.,Thulasi Daran. R.	Drain tray cleaned and serviced.		Abirami. P. - Radio Diagnosis	18/10/2022
	Comp. Dt. : 17/10/2022							
	Status : Completed							
764	22100519	RADIOLOGY	NEED TO CHECK AC-WATER LEAKAGE	Panneer Selvam. P.,Vasanthakumar. V.,Vijay. M.	Drain tray cleaned and serviced.		Jayalakshmi. D. - Radio Diagnosis	18/10/2022
	Comp. Dt. : 14/11/2022							
	Status : Completed							
765	22110516	SCAN - GROUND FLOOR - BLOOD BANK OPP	A/C LESS COOLING PROBLEM	Thulasi Daran. R.	Indoor unit serviced with water.		Sudha. D. - Radio Diagnosis	15/11/2022
	Comp. Dt. : 10/12/2022							
	Status : Completed							
766	22120477	RADIOLOGY	IN CR ROOM-A/C NOT WORKING	Vasanthakumar. V.	Put vaccum and gas charged. Leak arrest.		Manikandan. G. - Radio Diagnosis	16/12/2022
	Comp. Dt. : 12/12/2022							
	Status : Completed							
767	22120530	RADIOLOGY	IN X-RAY DARK ROOM-A/C NOT WORKING	Pragash. P.	Rat bitten the wire. Wire rejoined and insulated.		Manikandan.V. - Radio Diagnosis	17/12/2022
	Comp. Dt. : 19/01/2023							
	Status : Completed							
768	23010681	BASEMENT SCAN	AC NOT WORKING - ROOM NO 1	Vasanthakumar. V.	R-22 gas top up. work is done		Sudha. D - Radio Diagnosis	23/01/2023
	Comp. Dt. : 23/01/2023							
	Status : Completed							
769	23010842	BASEMENT SCAN	AC NOT WORKING - ROOM NO 2	Ramesh. P.	R-22 Gas top up and serviced.		Sudha. D - Radio Diagnosis	30/01/2023
	Comp. Dt. : 01/02/2023							
	Status : Completed							
770	23020011	XRy	AC NOT WORKING AT HOD ROOM & C R ROOM	Ramesh. P.	Breaker trip manually ON it.		Manikandan.V. - Radio Diagnosis	02/02/2023
	Comp. Dt. : 02/02/2023							
	Status : Completed							
771	23020057	RADIOLOGY	AC WATER LEAKAGE IN FAX ROOM	Gnanapragasam. N.	Indoor unit cleaned and serviced.		Jayalakshmi. D. - Radio Diagnosis	04/02/2023
	Comp. Dt. : 07/02/2023							
	Status : Completed							


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
772	23020237	SCAN - GROUND FLOOR - BLOOD BANK OPP	AC NOT WORKING	Vasanthakumar. V.	2.5 mfd capcitor changed in indoor unit		Sudha. D - Radio Diagnosis	10/02/2023
Comp. Dt. : 08/02/2023 Status : Completed								
773	23020270	SCAN - GROUND FLOOR - BLOOD BANK OPP	AC PROBLEM	Vasanthakumar. V.	2.5 mfd capcitor changed in indoor unit		Sudha. D - Radio Diagnosis	10/02/2023
Comp. Dt. : 09/02/2023 Status : Completed								
774	23020355	RADIOLOGY	1ST ROOM A/C- NOT WORKING	Vasanthakumar. V.	Indoor unit capacitor changed. 2.5 mfd		Sudha. D. - Radio Diagnosis	10/02/2023
Comp. Dt. : 11/02/2023 Status : Completed								
775	23020439	SCAN - GROUND FLOOR - BLOOD BANK OPP	AC WATER LEAKAGE	Vasanthakumar. V.	BLOWER FAN MOTOR CHANGED.		Sudha. D - Radio Diagnosis	14/02/2023
Comp. Dt. : 22/02/2023 Status : Completed								
776	23020866	USG	GROUND FLOOR USG ROOM A/C--WATER LEAKAGE PROBLEM(1092)	Ramesh. P.	DRAIN TRAY CLEANED AND SERVICED.		Sankari. D. - Radio Diagnosis	28/02/2023
Comp. Dt. : 02/03/2023 Status : Completed								
777	23030080	MRI	AC NOT WORKING	Ramesh. P.	BREAKER TRIP. MANUALLY ON IT.		Sushmitha. K. - Radio Diagnosis	03/03/2023
Comp. Dt. : 14/03/2023 Status : Completed								
778	23030570	Ultra Sound	AC NOT WORKING	Vasanthakumar. V.	RAT BITTEN THE WIRE. WIRE REJOINED AND INSULATED.		Sankari. D. - Radio Diagnosis	16/03/2023
Comp. Dt. : 15/03/2023 Status : Completed								
779	23030585	RADIOLOGY	AC NOT WORKING - FAX ROOM	Vasanthakumar. V.	BREAKER TRIP. MANUALLY ON IT.		Jayalakshmi. D. - Radio Diagnosis	16/03/2023
Comp. Dt. : 18/03/2023 Status : Completed								
780	23030745	SCAN - GROUND FLOOR - BLOOD BANK OPP	AC NOT WORKING - ROOM NO 1	Vasanthakumar. V.	BREAKER TRIP. MANUALLY ON		Kanimozhi. D. - Radio Diagnosis	20/03/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 30/03/2023 Status : Completed								
781	23031319	SCAN - GROUND FLOOR - BLOOD BANK OPP	AC WATER LEAKAGE - NEED TO CHECK	Vasanthakumar. V.	Drain tray cleaned and gas top up 30 psi		Kanimozhi. D. - Radio Diagnosis	01/04/2023
Comp. Dt. : 12/04/2023 Status : Completed								
782	23040350	BASEMENT SCAN	AC WATER LEAGAGE	Pragash. P.	DRAIN TRAY CLEANED AND SERVICED.		Abirami. P. - Radio Diagnosis	13/04/2023
Comp. Dt. : 26/04/2023 Status : Completed								
783	23040852	BASEMENT SCAN	AC WATER LEAKAGE AT LIBRARY	Ramesh. P.,Vijay. M.,Phillipkumar. D.	DRAIN TRAY CLEANED AND SERVICED.		Sudha. D - Radio Diagnosis	27/04/2023
Comp. Dt. : 02/05/2023 Status : Completed								
784	23050041	XRay	AC NOT WORKING AT CR ROOM	Phillipkumar. D.	DRAIN TRAY CLEANED AND SERVICED.		Manikandan.V. - Radio Diagnosis	05/05/2023
785	23050072	RADIOLOGY	AC WATER LEAKAGE AT FAX ROOM	Gnanapragasam. N.	CAPACITOR CHANGED.		Jayalakshmi. D. - Radio Diagnosis	03/05/2023
Comp. Dt. : 15/05/2023 Status : Completed								
786	23050584	XRay	AC WATER LEAKAGE AT LIBRARY ROOM	Vijay. M.	DRAIN TRAY CLEANED AND SERVICED.		Manikandan.V. - Radio Diagnosis	16/05/2023
Comp. Dt. : 30/05/2023 Status : Completed								
787	23051171	SCAN - GROUND FLOOR - BLOOD BANK OPP	AC NOT WORKING - COOLING PROBLEM	Ramesh. P.	CONTACTOR CHANGED.		Sudha. D - Radio Diagnosis	31/05/2023
Comp. Dt. : 01/06/2023 Status : Completed								
788	23060022	RADIOLOGY	AC WATER LEAKAGE	Vasanthakumar. V.	drain tray cleaning.		Jayalakshmi. D. - Radio Diagnosis	03/06/2023
Comp. Dt. : 03/06/2023 Status : Completed								
789	23060109	BASEMENT SCAN	AC COOLING PROBLEM	Vasanthakumar. V.	POWER PROBLEM		Sudha. D. - Radio Diagnosis	06/06/2023
Comp. Dt. : 05/06/2023 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
790	23060129	BASEMENT SCAN	AC NOT WORKING - BASEMENT ULTRA ROOM NO 1	Vasanthakumar. V.	POWER PROBLEM		Abirami. P. - Radio Diagnosis	06/06/2023
Comp. Dt. : 06/06/2023 Status : Completed								
791	23060189	RADIOLOGY	AC WATER LEAKAGE	Gnanapragasam. N.	DRAIN TRAY CLEANED AND SERVICED.		Jayalakshmi. D. - Radio Diagnosis	07/06/2023
Comp. Dt. : 15/06/2023 Status : Completed								
792	23060537	USG	GROUND FLOOR USG ROOM A/C-COOLING PROBLEM	Phillipkumar. D.	Remote mode changed.		Kanimozhi. D. - Radio Diagnosis	16/06/2023
Comp. Dt. : 27/06/2023 Status : Completed								
793	23061011	RADIOLOGY	AC WATER LEAKAGE AT FAX ROOM	Phillipkumar. D.	Drain tray cleaned and serviced.		Jayalakshmi. D. - Radio Diagnosis	28/06/2023
Dept Name : RICU - Air Condition Department Comp. Dt. : 18/05/2022 Status : Completed								
794	22050648	RICU	AC NOT WORKING	Ramesh. P.	Old chiller problem rectified.		Deva @ Devanathan. P. - RICU	20/06/2022
Comp. Dt. : 03/06/2022 Status : Completed								
795	22060133	RICU	AC NOT WORKING	Pragash. P.	Filter serviced.		Sheela. B. - RICU	27/06/2022
Comp. Dt. : 10/06/2022 Status : Completed								
796	22060380	RICU	A/C WATER LEAKAGING PROBLEM	Amarajothi.V.	AHU coil and tray line serviced.		Prasanna. S.U. - RICU	27/06/2022
Comp. Dt. : 26/10/2022 Status : Completed								
797	22100796	SICU	AC WATER LEAKAGE	Panneer Selvam. P.	Drain tray cleaned and serviced.		Yuvarani. P. - RICU	28/10/2022
Comp. Dt. : 06/01/2023 Status : Completed								
798	23010255	RICU	ALL A/C-CLEANING WORK	Amarajothi.V.	Indoor unit cleaned and serviced.		Tamilalakkiya. K. - RICU	10/01/2023
Comp. Dt. : 15/05/2023 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
799	23050595	RICU	NEED AC SERVICE	Vasanthakumar. V.	ALL GRILL CLEANED.		Tamililakkiya. K. - RICU	17/05/2023
Dept Name : Security - SIS - Air Condition Department Comp. Dt. : 29/09/2022 Status : Completed								
800	22091159	MEDICAL COLLEGE LIBRARY	DUE TO DEATH OF RAT AT AC FALSE CEILING PLACE - BAD SMELL - NEED AC TECHNICIAN HELP AT OWN BOOK R	Ramesh. P.	Removed the rat inside the false ceiling not in AC unit.		Elavazhagan. A. - Security - SIS	30/09/2022
Dept Name : Special Clinic - Air Condition Department Comp. Dt. : 04/05/2022 Status : Completed								
801	22050077	SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	AC WATER LEAKAGE	Thulasi Daran. R.	Indoor unit serviced.		Monica Sales. D. - Special Clinic - Office	19/05/2022
Comp. Dt. : 07/05/2022 Status : Completed								
802	22050237	SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	NEED TO REFIX AC WING	Pragash. P.	Swing motor flap problem. Removed and refixed.		Monica Sales. D. - Special Clinic - Office	06/06/2022
Comp. Dt. : 25/05/2022 Status : Completed								
803	22050954	SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	NEED TO CHECK AC COOLING	Babu. D.	Outdoor unit serviced.		Monica Sales. D. - Special Clinic - Office	20/06/2022
Comp. Dt. : 03/06/2022 Status : Completed								
804	22060114	SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	NEED TO CHECK AC COOLING -	Panneer Selvam. P.	Indoor unit serviced.		Monica Sales. D. - Special Clinic - Office	27/06/2022
Comp. Dt. : 22/06/2022 Status : Completed								
805	22060813	SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	AC NOT WORKING	Ramesh. P.	Indoor unit serviced.		Athilakshmi. K - Special Clinic - Office	27/06/2022
Comp. Dt. : 29/07/2022 Status : Completed								
806	22071081	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	AC NOT WORKING	Panneer Selvam. P.	Indoor unit serviced with water pressure pump		Sananya. S. - Clinical Department	05/09/2022

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 17/08/2022 Status : Completed								
807	22080544	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	IN LAB-(LAST ROOM)A/C WATER LEAKAGING PROBLEM AND NOT WORKING	Thulasi Daran. R.	Cassette unit serviced.		Christy. S. - Special OPD	05/09/2022
Dept Name : Special Clinic - Dialysis - Air Condition Department Comp. Dt. : 23/03/2023 Status : Completed								
808	23030967	DIALYSIS NEW UNIT IN 1ST FLOOR	AC WATER LEAKAGE	Ramesh. P.	DRAIN PIPE LINE CLEANED.		Swathika. K. - Special Clinic - Dialysis	25/03/2023
Dept Name : Special Clinic - Office - Air Condition Department Comp. Dt. : 19/04/2023 Status : Completed								
809	23040571	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	AC NOT WORKING	Vasanthakumar. V.	BEARKER TRIP MANUALLY ON IT.		Krithika. J. - Special Clinic - Office	20/04/2023
Comp. Dt. : 22/04/2023 Status : Completed								
810	23040688	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	NEED TO CHECK AC - NOT WORKING	Vasanthakumar. V.	PROBLEM RECTIFIED.		Krithika. J. - Special Clinic - Office	06/05/2023
Comp. Dt. : 24/04/2023 Status : Completed								
811	23040749	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	AC NOT WORKING - NEED URGENT SERVICE	Panneer Selvam. P.	PC BOARD SERVICED AND REFIXED.		Krithika. J. - Special Clinic - Office	16/05/2023
Comp. Dt. : 12/05/2023 Status : Completed								
812	23050479	SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	AC NOT WORKING	Ramesh. P.	BREAKER TRIP. MANUALLY ON IT.		Monica Sales. D. - Special Clinic - Office	16/05/2023
Comp. Dt. : 20/05/2023 Status : Completed								
813	23050830	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	NEED TO CHECK AC - NOT WORKING	Vasanthakumar. V.	DRAIN TRAY CLEAN AND SERVICED.		Krithika. J. - Special Clinic - Office	22/05/2023
Comp. Dt. : 26/05/2023 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
814	23051058	SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	AC NOT WORKING	Ramesh. P.	New Indoor and Outdoor unit installation work done.		Monica Sales. D. - Special Clinic - Office	24/06/2023
Comp. Dt. : 27/05/2023 Status : Completed								
815	23051075	SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	AC NOT WORKING	Ramesh. P.	REPEATED COMPLAINT.		Thamizhselvi. S. - Administration	27/05/2023
Dept Name : Special Clinic - Reception - Air Condition Department Comp. Dt. : 19/05/2023 Status : Completed								
816	23050781	SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	AC WATER LEAKAGE	Panneer Selvam. P.	DRAIN TRAY CLEANED AND SERVICED.		Savitha. K. - Special Clinic - Reception	20/05/2023
Dept Name : Special Ward - Air Condition Department Comp. Dt. : 04/05/2022 Status : Completed								
817	22050079	SPECIAL WARD - A1	AC NOT WORKING - ROOM NO 2	Thulasi Daran. R.	Mode changed. Unit is working.		Prithika. V. - Special Ward	29/05/2022
Comp. Dt. : 05/05/2022 Status : Completed								
818	22050119	SPECIAL WARD---B	AC NOT WORKING	Panneer Selvam. P.	Changed the mode. Unit is working.		Reena. N. - Special Ward	29/05/2022
Comp. Dt. : 06/05/2022 Status : Completed								
819	22050169	Special Ward - C	NEED TO CHECK FRIDGE DOOR - NOT CLOSING PROPERLY	Pragash. P.	Fridge door adjusted. Door casket adjusted. Door closing properly.		Abirami. G. - Special Ward	29/05/2022
Comp. Dt. : 16/05/2022 Status : Completed								
820	22050521	Special Ward - A	AC NOT WORKING - ROOM NO 5	Thulasi Daran. R.	PC board problem. Removed it for service.		Revathi. S. - Special Ward	20/06/2022
Comp. Dt. : 23/05/2022 Status : Completed								
821	22050835	SPECIAL WARD---B	AC WATER LEAKAGE	Thulasi Daran. R.	Drain block. Drain coil and filter serviced.		Reena. N. - Special Ward	29/05/2022
Comp. Dt. : 24/05/2022 Status : Completed								
822	22050870	Special Ward - A	NEED TO CHECK FRIDGE TEMPERATURE	Manikandan. A. R.	temperature probe changed.		Revathi. S. - Special Ward	05/09/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 03/06/2022 Status : Completed								
823	22060107	Special Ward - C	AC NOT WORKING ROOM NO 4	Manikandan. A. R.	45 mfd capacitor changed.		Manjula. R. - Special Ward	20/06/2022
Comp. Dt. : 07/06/2022 Status : Completed								
824	22060254	Special Ward - A	AC NOT WORKING ROOM NO 8	Manikandan. A. R.	PC board serviced and refixed.		Manjula. R. - Special Ward	05/09/2022
Comp. Dt. : 13/06/2022 Status : Completed								
825	22060441	SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	NEED TO CHAECK AC COOLING - [SENTHIL SIR ROOM]	Thulasi Daran. R.	Indoor unit serviced.		Dhatchayani.N. - Special Ward	27/06/2022
Comp. Dt. : 14/06/2022 Status : Completed								
826	22060514	Special Ward - A	NEED AC SERVICE FOR ALL ROOM - ALL ROOM AC WATER LEAKAGE	Panneer Selvam. P.	General checkup done.		Reena. N. - Special Ward	05/09/2022
Comp. Dt. : 20/06/2022 Status : Completed								
827	22060735	SPECIAL WARD - A1	AC NOT WORKING - ROOM NO 9	Babu. D.	Remote mode changed manually		Manjula. R. - Special Ward	05/09/2022
Comp. Dt. : 21/06/2022 Status : Completed								
828	22060746	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	NEED TO CHECK AC - NOT WORKING AT DR. RAMYA MADAM ROOM	Babu. D.	Indoor unit board serviced.		Elakkiya. S. - Special Ward	27/06/2022
Comp. Dt. : 24/06/2022 Status : Completed								
829	22060904	SPECIAL WARD---B	AC WATER LEAKAGE - ROOM NO 19	Pragash. P.	Water drain tray cleaning work done.		Jayanthi. A. - Special Ward	05/09/2022
Comp. Dt. : 27/06/2022 Status : Completed								
830	22060965	Special Ward - A	AC NOT WORKING ROOM NO 5 [DELUXE ROOM]	Panneer Selvam. P.	All rooms AC checked. No complaints		Bharathi. R. - Special Ward	05/09/2022
Comp. Dt. : 30/06/2022 Status : Completed								
831	22061092	Special Ward - A	NEED TO CHECK ALL AC ITEMS FOR ALL ROOMS	Ramesh. P.	General checkup done. all rooms AC working		Bharathi. R. - Special Ward	05/09/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 04/07/2022								
Status : Completed								
832	22070096	SPECIAL WARD - A1	NEED TO CHECK ALL AC ITEMS FOR ALL ROOMS	Manikandan. A. R.	General check up done.		Manjula. R. - Special Ward	05/09/2022
Comp. Dt. : 05/07/2022								
Status : Completed								
833	22070158	SPECIAL WARD---B	AC NOT WORKING - STRIGHT ROOM	Panneer Selvam. P.	Water leakage occurs. Drain tray cleaned aand serviced.		Reena. N. - Special Ward	05/09/2022
Comp. Dt. : 07/07/2022								
Status : Completed								
834	22070234	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	AC NOT WORKING NEED TO CHECK	Babu. D.	PC board serviced and refixed.		Dhatchayani.N. - Special Ward	05/09/2022
Comp. Dt. : 21/07/2022								
Status : Completed								
835	22070776	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	AC WATER LEAKAGE IN OPD ROOM	Manikandan. A. R.	Indoor unit cleaned and serviced with water pressure pump		Dhatchayani.N. - Special Ward	05/09/2022
Comp. Dt. : 25/07/2022								
Status : Completed								
836	22070917	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	AC NOT WORKING [DR RAMYA MADAM ROOM]	Babu. D.	Indoor cassette unit serviced.		Elakkiya. S. - Special Ward	05/09/2022
Comp. Dt. : 02/08/2022								
Status : Completed								
837	22080097	SPECIAL WARD - A1	AC NOT WORKING - ROOM NO 7 & 8	Thulasi Daran. R.	Room no.7 pc board serviced and refixed; Room no.8 drain pipe hose changed.		Manjula. R. - Special Ward	05/09/2022
Comp. Dt. : 09/08/2022								
Status : Completed								
838	22080312	Special Ward - A	NEED ALL AC ITEMS GENERAL SERVICE FOR ALL ROOMS	Babu. D.,Vijay. M.,Vasanthakumar. V.	General checkup done.		Ezhilarasi. P. - Special Ward	05/09/2022
Comp. Dt. : 18/08/2022								
Status : Completed								
839	22080601	SPECIAL WARD -B IN FOURTH FLOOR	IN ROOM NO.B1 AND B3 A/C WATER LEAKAGING PROBLEM	Manikandan. A. R.	Drain tray cleaned.		Vaviya. M. - Special Ward	05/09/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 19/08/2022								
Status : Completed								
840	22080623	SPECIAL WARD A1-FOURTH FLOOR	AC NOT WORKING IN ROOM NO. 8	Pragash. P.	remote mode changed manually		Manjula. R. - Special Ward	05/09/2022
841	22080641	SPECIAL WARD A THIRD FLOOR	FRIDGE TEMPERATURE NOT WORKING	Manikandan. A. R.	Temperature Probe changed.		Bharathi. D. - Special Ward	05/09/2022
Comp. Dt. : 22/08/2022								
Status : Completed								
842	22080723	Special Ward - C	NEED TO CHECK WATER PURIFYER - HOT WATER NOT COMING	Pragash. P.	3 pin top problem. Electrical department complaint.		Sangeetha. S. - Special Ward	05/09/2022
Comp. Dt. : 29/08/2022								
Status : Completed								
843	22080985	SPECIAL WARD---B	AC WATER LEAKAGE - ROOM NO B21 [2 NOS]	Pragash. P.	Drain tray cleaned.		Reena. N. - Special Ward	05/09/2022
Comp. Dt. : 05/09/2022								
Status : Completed								
844	22090161	Special Ward - A	NEED TO CHECK ALL AC ITEMS FOR ALL ROOMS	Panneer Selvam. P.	General checkup completed.		Bharathi. R. - Special Ward	07/09/2022
Comp. Dt. : 13/09/2022								
Status : Completed								
845	22090478	SPECIAL WARD---B	AC WATER LEAKAGE	Pragash. P.,Panneer Selvam. P.,Babu. D.	drain tray cleaning work done		Kaviya. M. - Special Ward	20/09/2022
Comp. Dt. : 15/09/2022								
Status : Completed								
846	22090575	SPECIAL WARD---B	NEED TO AC COOLING NOT WORKING	Panneer Selvam. P.,Babu. D.,Ramesh. P.	Power problem.		Reena. N. - Special Ward	17/09/2022
Comp. Dt. : 26/10/2022								
Status : Completed								
847	22100826	Special Ward - A	IN ROOM NO-8,A/C-COOLING PROBLRM	Thulasi Daran. R.	Indoor unit serviced.		Abirami. G. - Special Ward	28/10/2022
Comp. Dt. : 31/10/2022								
Status : Completed								
848	22100998	SPECIAL WARD - A1	ALL A/C-CLEANING WORK	Vasanthakumar. V.	All AC unit checked. General service done.		Ragavi. P. - Special Ward	02/11/2022
Comp. Dt. : 08/11/2022								
Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
849	22110318	Special Ward - A	AC NOT COOLING IN ROOM NO. 8	Vasanthakumar. V.	R-22 gas charged.		Bharathi. R. - Special Ward	17/11/2022
	Comp. Dt. : 21/11/2022							
	Status : Completed							
850	22110850	SPECIAL WARD A THIRD FLOOR	IN ROOM NO.5-A/C NOT WORKING	Manikandan. A. R.	Breaker trip. ON it manually,.		Jayabarathi. P. - Special Ward	22/11/2022
	Comp. Dt. : 06/12/2022							
	Status : Completed							
851	22120252	SPECIAL WARD A THIRD FLOOR	IN ROOM NO.2-A/C NOT WORKING	Pragash. P.	Rat bitten the wire. Rejoined and insulated.		Bharathi. D. - Special Ward	14/12/2022
	Comp. Dt. : 15/12/2022							
	Status : Completed							
852	22120683	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	NEED TO CHECK AC NEAR ELECTRICAL CABLE HOLE - WATER LEAKAGE AT DR. RAMYA MADAM ROOM	Vijay. M.	Damaged pipe line insulated.		Dhatchayani.N. - Special Ward	16/12/2022
	Comp. Dt. : 27/12/2022							
	Status : Completed							
853	22121217	SPECIAL WARD A1-FOURTH FLOOR	IN ROPOM NO.2-A/C WATER LEAKAGING PROBLEM	Vasanthakumar. V.	Drain line cleaned		Ragavi. P. - Special Ward	28/12/2022
	Comp. Dt. : 29/12/2022							
	Status : Completed							
854	22121342	SPECIAL WARD A1-FOURTH FLOOR	IN ROOM NO.2-A/C WATER LEAKAGING PROBLEM	Vasanthakumar. V.	Drain tray cleaned and serviced.		Sivapriya. P. - Special Ward	30/12/2022
	Comp. Dt. : 30/12/2022							
	Status : Completed							
855	22121371	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	IN DOCTOR ROOM-A/C WATER LEAKAGING PROBLEM	Ramesh. P.	Drain tray cleaned and serviced.		Dhatchayani.N. - Special Ward	05/01/2023
	Comp. Dt. : 04/01/2023							
	Status : Completed							
856	23010172	SPECIAL WARD A1-FOURTH FLOOR	IN ROOM NO.2-A/C WATER LEAKAGING PROBLEM	Gnanapragasam. N.	Indoor unit cleaned and serviced.		Manjula. R. - Special Ward	10/01/2023
	Comp. Dt. : 08/02/2023							
	Status : Completed							
857	23020271	SPECIAL WARD---B	AC WATER LEAKAGE	Gnanapragasam. N.	Drain tray cleaned and serviced.		Sangeetha. S. - Special Ward	10/02/2023
	Comp. Dt. : 09/02/2023							

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
858	23020347	Special Ward - A	AC COOLING PROBLEM IN ROOM NO 5	Vasanthakumar. V.	MODE CHANGED MANUALLY		Bharathi. R. - Special Ward	13/02/2023
Comp. Dt. : 16/02/2023								
Status : Completed								
859	23020651	SPECIAL WARD - A1	ROOM NO-7,A/C-NOT WORKING	Amarajothi.V.	Change the new mcb.work is done,		Manjula. R. - Special Ward	17/02/2023
Comp. Dt. : 02/03/2023								
Status : Completed								
860	23030063	SPECIAL WARD---B	AC WATER LEAKAGE - ROOM NO B4-B5	Pragash. P.	DRAIN TRAY CLEANED AND SERVICED.		Sangeetha. S. - Special Ward	03/03/2023
Comp. Dt. : 04/03/2023								
Status : Completed								
861	23030183	SPECIAL WARD - A1	NEED TO CHECK ALL AC ITEMS AT ALL ROOMS	Manikandan. A. R.	ALL A/C UNIT CHECKED.		Manjula. R. - Special Ward	09/03/2023
Comp. Dt. : 11/03/2023								
Status : Completed								
862	23030469	SPECIAL WARD - A1	AC WATER LEAKAGE - ROOM NO 10	Phillipkumar. D.	INDOOR UNIT CLEANED AND SERVICED		Sivapriya. P. - Special Ward	13/03/2023
Comp. Dt. : 16/03/2023								
Status : Completed								
863	23030655	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	AC WATER LEAKAGE [SPECIAL OP LASTROOM]	Ramesh. P.	DRAIN TRAY PIPE LINE INSULATED AND TAPED		Elakkiya. S. - Special Ward	17/03/2023
Comp. Dt. : 22/03/2023								
Status : Completed								
864	23030914	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	AC NOT WORKING [DR RAMYA MADAM ROOM]	Vasanthakumar. V.	Sensor wire loose connection. connected properly.		Elakkiya. S. - Special Ward	23/03/2023
Comp. Dt. : 03/04/2023								
Status : Completed								
865	23040083	SPECIAL WARD - A1	AC NOT WORKING - ROOM NO 4 & 9	Vasanthakumar. V.	BREAKER TRIP, MANUALLY ON. REMOTE MODE CHANGED.		Manjula. R. - Special Ward	04/04/2023
Comp. Dt. : 06/04/2023								
Status : Completed								
866	23040174	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	AC WATER LEAKAGE AT DR ROOM	Pragash. P.	Expansion joint problem.		Dhatchayani.N. - Special Ward	08/04/2023

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHAL KUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 13/04/2023								
Status : Completed								
867	23040391	SPECIAL WARD---B	AC NOT WORKING - ROOM NO B11-B12	Ramesh. P.	55 MFD CAPCITOR CHANGED.		Sangeetha. S. - Special Ward	15/04/2023
Comp. Dt. : 17/04/2023								
Status : Completed								
868	23040499	Special Ward - A	NEED TO CHECK AC - PROBLEM IN ROOM NO 7	Vijay. M.	COPPER PIPE LINE INSULATED AND TAPE IT.		Revathi. S. - Special Ward	20/04/2023
Comp. Dt. : 20/04/2023								
Status : Completed								
869	23040658	DIALYSIS IN 2ND FLOOR	AC WATER LEAKAGE - OPD NO 215	Phillipkumar. D.	drain tray cleaned and serviced.		Suganya. D. - Special Ward	22/04/2023
Comp. Dt. : 27/04/2023								
Status : Completed								
870	23040894	SPECIAL WARD - A1	AC NOT WORKING - ROOM NO 3	Ramesh. P.	R22 GAS 1200 KG TOP UP		Shalini. S. - Special Ward	03/05/2023
Comp. Dt. : 28/04/2023								
Status : Completed								
871	23040981	SPECIAL WARD - A1	AC WATER LEAKAGE ROOM NO 8	Pragash. P.	DRAIN TRAY CLEANED AND SERVICED.		Manjula. R. - Special Ward	03/05/2023
Comp. Dt. : 04/05/2023								
Status : Completed								
872	23050154	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	AC WATER LEAKAGE AT DOCTOR ROOM	Vasanthakumar. V.	DRAIN TRAY AND DRAIN PIPELINE CLEANED.		Dhatchayani.N. - Special Ward	05/05/2023
Comp. Dt. : 09/05/2023								
Status : Completed								
873	23050383	Special Ward - A	AC WATER LEAKAGE - ROOM NO 4	Vasanthakumar. V.	DRAIN TRAY CLEAN AND SERVICED.		Revathi. S. - Special Ward	11/05/2023
Comp. Dt. : 15/05/2023								
Status : Completed								
874	23050565	SPECIAL WARD - A1	AC NOT WORKING - ROOM NO 7 & 11	Ramesh. P.	PC BOARD SERVICED AND REFIXED. BREAKER TRIP. MANUALLY ON IT.		Nivetha. R. - Special Ward	24/05/2023
875	23050599	SPECIAL WARD - A1	AC NOT WORKING ROOM NO 9	Vasanthakumar. V.	BREAKER TRIP. MANUALLY ON IT.		Nivetha. R. - Special Ward	16/05/2023
876	23050616	SPECIAL WARD - A1	AC NOT WORKING - ROOM NO 1 & 9	Ramesh. P.	BREAKER TRIP. MANUALLY ON		Shalini. S. - Special Ward	17/05/2023
Comp. Dt. : 18/05/2023								
Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
877	23050724	SPECIAL WARD---B	NEED TO CHECK AC PIPELINE - WATER LEAKAGE AT ALL ROOMS	Phillipkumar. D.	DRAIN PIPELINE CLEANED.		Sangeetha. S. - Special Ward	24/05/2023
Comp. Dt. : 20/05/2023 Status : Completed								
878	23050842	SPECIAL WARD---B	FRIDGE NOT WORKING	Ramesh. P.	NEW BULB CHANGED.		Sangeetha. S. - Special Ward	27/05/2023
Comp. Dt. : 22/05/2023 Status : Completed								
879	23050857	SPECIAL WARD---B	AC NOT WORKING ROO NO B4-B5	Ramesh. P.	COMPRESSER CHANGED.		Bhavani. A. - Special Ward	06/06/2023
Comp. Dt. : 26/05/2023 Status : Completed								
880	23051033	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	AC NOT WORKING [DR. SENDHIL SIR ROOM]	Ramesh. P.	BREAKER TRIP MANUALLY ON IT.		Dhatchayani.N. - Special Ward	27/05/2023
Comp. Dt. : 29/05/2023 Status : Completed								
881	23051154	SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	AC NOT WORKING - COOLING PROBLEM	Vasanthakumar. V.	FILTER COIL SERVICED.		Dhatchayani.N. - Special Ward	07/06/2023
Comp. Dt. : 30/05/2023 Status : Completed								
882	23051172	SPECIAL WARD---B	AC NOT WORKING [STRIGHT ROOM]	Pragash. P.	Gas filled. R22 gas (65 psi)		Sangeetha. S. - Special Ward	23/06/2023
Comp. Dt. : 07/06/2023 Status : Completed								
883	23060242	SPECIAL WARD - A1	AC NOT WORKING ROOM NO 8	Vijay. M.	breaker trip. manually on		Manjula. R. - Special Ward	08/06/2023
Comp. Dt. : 08/06/2023 Status : Completed								
884	23060295	SPECIAL WARD---B	AC WATER LEAKAGE AT DOCTOR'S ROOM	Ramesh. P.	DRAIN TRAY CLEANED AND SERVICED.		Suganya. K. - Special Ward	09/06/2023
Comp. Dt. : 15/06/2023 Status : Completed								
885	23060541	SPECIAL WARD - A1	ROOM NO-3,A/C-NOT WORKING	Phillipkumar. D.	Breaker trip. Manually On		Nivetha. R. - Special Ward	16/06/2023
Comp. Dt. : 17/06/2023 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
886	23060619	SPECIAL WARD---B	AC NOT WORKING - ROOM NO B10 - B12	Vasanthakumar. V.	Breaker trip. Manually ON.		Jayabarathi. P. - Special Ward	19/06/2023
Comp. Dt. : 19/06/2023 Status : Completed								
887	23060667	SPECIAL WARD - A1	NEED TO CHECK FRIDGE PANEL - NOT WORKING	Vasanthakumar. V.	New probe and battery changed.		Manjula. R. - Special Ward	20/06/2023
Comp. Dt. : 23/06/2023 Status : Completed								
888	23060859	SPECIAL WARD - A1	AC NOT WORKING ROOM NO 5	Panneer Selvam. P.	Breaker trip. Manually ON.		Shalini. S. - Special Ward	24/06/2023
Dept Name : Tailoring Department - Air Condition Department Comp. Dt. : 27/05/2023 Status : Completed								
889	23051088	Tailoring Department	COOLER NOT WORKING	Ramesh. P.	CONDENSER PIPELINE CHANGED.		Ilayaraja.S. - Tailoring Department	06/06/2023
Dept Name : Tele Exchange - Air Condition Department Comp. Dt. : 23/05/2022 Status : Completed								
890	22050833	EDP IN UNDERGROUND	NEED NEW AC INSTALLATION WORK AT SERVER ROOM	Panneer Selvam. P.	New AC installed.		Vivek. A. - Tele Exchange	20/06/2022
Comp. Dt. : 24/06/2022 Status : Completed								
891	22060865	EDP IN UNDERGROUND	NEED TO CHECK AC COOLING AT SERVER ROOM	Thulasi Daran. R.	All room AC serviced.		Vivek. A. - Tele Exchange	05/09/2022
Comp. Dt. : 27/06/2022 Status : Completed								
892	22060953	EDP IN UNDERGROUND	NEED TO CHECK AC COOLING IN SERVER ROOM	Panneer Selvam. P.	New AC installation work done.		Vivek. A. - Tele Exchange	05/09/2022
Comp. Dt. : 11/08/2022 Status : Completed								
893	22080394	EDP IN UNDERGROUND	AC REMOTE NOT WORKING IN SERVER ROOM	Panneer Selvam. P.	New AC installation work done.		Vivek. A. - Tele Exchange	05/09/2022
Comp. Dt. : 09/03/2023 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
894	23030350	EDP IN UNDERGROUND	NEED TO CHECK AC - COOLING PROBLEM AT SERVER ROOM	Manikandan. A. R.	OUTDOOR UNIT COIL SERVICED		Padmanaban. G. - Tele Exchange	10/03/2023
Dept Name : UHC Villupuram - Air Condition Department Comp. Dt. : 01/07/2022 Status : Completed								
895	22070018	ASSOCIATIVE PROFESSOR QUARTERS	AC NOT WORKING QUARTERS NO B -11	Sasikumar. S.	Not a company unit. Personal AC		Asaithambi. R. - UHC Villupuram	06/08/2022
Comp. Dt. : 08/11/2022 Status : Completed								
896	22110286	UHC Villupuram	FRIDGE NOT WORKING	Panneer Selvam. P.	OLP relay changed.		Rathinamala. A. - UHC Villupuram	11/11/2022
Comp. Dt. : 06/06/2023 Status : Completed								
897	23060206	UHC Villupuram	FRIDGE NOT WORKING	Sasikumar. S.	BURNED WIRE REJOINED AND INSULATED.		Gomathi. M. - UHC Villupuram	09/06/2023
Dept Name : Veterinary Science - Air Condition Department Comp. Dt. : 08/07/2022 Status : Completed								
898	22070307	Animal House	AC NOT WORKING	Sasikumar. S.	Breaker trip. ON it		Rajaram. P. - Veterinary Science	06/08/2022
Dept Name : Ward - Air Condition Department Comp. Dt. : 09/05/2023 Status : Completed								
899	23050363	CLINICAL DEPARTMENT IN 4th FLOOR	AC NOT WORKING AT SEMINOR ROOM	Pragash. P.	BREAKER TRIPED MANUALLY ON IT.		Patchaiyammal.K - Ward	11/05/2023
Work Type : Work Dept Name : Nursing Office - Air Condition Department Comp. Dt. : 22/06/2022 Status : Completed								
900	22060815	IVF ART CLINIC-INSIDE OF OG OPD(NO.68)	NEED A NEW FRIDGE CONNECTION WORK	Babu. D.	New fridge connection work done		Greeta Guna Seelan - Nursing Office	27/06/2022
901	22060816	SPECIALITY OT	NEED NEW FRIDGE CONNECTION WORK	Panneer Selvam. P.,Amarajothi.V.,Babu. D.	New fridge connection given		Greeta Guna Seelan - Nursing Office	27/06/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

College Name : SMVNC

Work Type : Complaint

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Dept Name : Air Condition Department - Air Condition Department Comp. Dt. : 19/12/2022 Status : Completed								
902	22120860	Nursing College	AC NOT WORKING IN SEMINAR HALL	Babu. D.	Thermal wire burned. New wire connection given.		DHANDAPANI - SMVNC	20/12/2022
Comp. Dt. : 02/03/2023 Status : Completed								
903	23030095	Nursing College	AC NOT WORKING - II FLOOR SEMINOR HALL	Thulasi Daran. R.	CONNCTOR CLIP CHANGED.		DHANDAPANI - SMVNC	09/03/2023
Comp. Dt. : 21/03/2023 Status : Completed								
904	23030847	Nursing College	AC NOT WORKING AT II FLOOR	Babu. D.	50 mfd capacitor changed.		DHANDAPANI - SMVNC	23/03/2023
Comp. Dt. : 31/05/2023 Status : Completed								
905	23051245	Nursing College	AC NOT WORKING I FLOOR VP ROOM	Sasikumar. S.	MCB removed and connected directly to the powersupply		DHANDAPANI - SMVNC	01/06/2023

College Name : SMVPT

Work Type : Complaint

Dept Name : Air Condition Department - Air Condition Department

Comp. Dt. : 23/06/2022

Status : Completed

906	22060844	Polytechnic college	AC NOT WORKING IN PRINCIPAL OFFICE	Sasikumar. S.	Capacitor problem. New capacitor changed.		SANTHANAM - SMVPT	06/08/2022
Comp. Dt. : 26/07/2022 Status : Completed								
907	22070975	Polytechnic college	AC NOT WORKING AT I FLOOR	Sasikumar. S.	Wiring problem. Problem rectified.		SANTHANAM - SMVPT	09/09/2022
Comp. Dt. : 20/10/2022 Status : Completed								
908	22100669	Polytechnic college	AC NOT WORKING	Sasikumar. S.,Udhaya Shankar. P.,Babu. D.	PC board problem. PC board serviced and refixed.		SANTHANAM - SMVPT	28/10/2022
Comp. Dt. : 03/11/2022 Status : Completed								
909	22110078	Polytechnic college	A/C STABILIZER HAS BEEN CHANGED IN PRINCIPAL ROOM	Sasikumar. S.,Udhaya Shankar. P.,Babu. D.	New stabilizer changed.		SANTHANAM - SMVPT	04/11/2022

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 19/12/2022								
Status : Completed								
910	22120845	Polytechnic college	AC NOT WORKING IN 1ST FLOOR COMPUTER DEPARTMENT	Babu. D.	New contactor changed.		SANTHANAM - SMVPT	20/12/2022
Comp. Dt. : 12/04/2023								
Status : Completed								
911	23040358	Polytechnic college	AC NOT WORKING AT ADMISSION ROOM	Babu. D.	NEW CONTACTOR CHANGE IT.		SANTHANAM - SMVPT	13/04/2023
Comp. Dt. : 20/04/2023								
Status : Completed								
912	23040663	Polytechnic college	AC NOT WORKING AT I FLOOR	Babu. D.	Contactor changed.		SANTHANAM - SMVPT	22/04/2023
Comp. Dt. : 27/04/2023								
Status : Completed								
913	23040924	Polytechnic college	AC NOT WORKING - CENTRE I - EXAMS GOING ON	Babu. D.	capcitor changed.		MANJU - SMVPT	05/05/2023
Comp. Dt. : 01/06/2023								
Status : Completed								
914	23060042	Polytechnic college	AC NOT WORKING AT II FLOOR	Babu. D.	3 mfd capacitor changed.		SANTHANAM - SMVPT	07/06/2023

College Name : VCE

Work Type : Complaint

Dept Name : Air Condition Department - Air Condition Department

Comp. Dt. : 14/10/2022

Status : Completed

915	22100474	B.ED COLLEGE	AC NOT WORKING AT PRINCIPAL OFFICE - NEED URGENT SERVICE	Sasikumar. S.,Udhaya Shankar. P.,Babu. D.	Indoor unit serviced.		SRIMAN - VCE	18/10/2022

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.



Sri Manakula Vinayagar Medical College and Hospital

Complaint Status Report From 01-05-2022 To 30-06-2023

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
College Name : SMVMCH Work Type : Complaint Dept Name : BIOCHEMISTRY - Biomedical Comp. Dt. : 23/12/2022 Status : Completed								
1	22121098	BIOCHEMISTRY-- -COLLEGE	GEL DOCUMENT NOT WORKING	Sridhar. K.	SETTINGS ISSUE IT'S RECTIFIED NOW WORKING GOOD		Anusuya. J. - BIOCHEMISTRY	26/12/2022
Comp. Dt. : 18/04/2023 Status : Completed								
2	23040566	BIOCHEMISTRY-- -COLLEGE	INSTRUMENT SOME NOT WORKING	Gurumoorthy. G.	checked the all equipments and working good		Suganthi. P. - BIOCHEMISTRY	20/04/2023
Dept Name : BLOOD BANK - Biomedical Comp. Dt. : 31/12/2022 Status : Completed								
3	22121383	Blood Bank	CENTRIFUGE NOT WORKING	Sridhar. K.	carbon brush changed now working good		Asha. P. - BLOOD BANK	02/01/2023
Dept Name : CARDIOLOGY - Biomedical Comp. Dt. : 10/10/2022 Status : Completed								
4	22100226	ECG ROOM NEAR MEDICINE OPD	NEED TO CHECK ECG CABLE	Sridhar. K.	checked and found that power card issue.replaced the power card	AssetNo :16000290	Sivasankari. M. - CARDIOLOGY	10/10/2022
Dept Name : Dermatology & Vener. - Biomedical Comp. Dt. : 16/02/2023 Status : Completed								
5	23020649	DERMATOLOGY OPD	PUVA THERAPY LASER NOT WORKING	Sridhar. K.	fuse problem.the problem is rectified.		Jayachandran. M. - Dermatology & Vener.	17/02/2023
Dept Name : EMERGENCY MEDICINE - Biomedical Comp. Dt. : 21/07/2022 Status : Completed								
6	22070775	Casualty	BP APPARATUS NOT WORKING	Gurumoorthy. G.	CHECKED AND FOUND THE BULB ISSUE IT'S RECTIFIED NOW IT'S WORKING GOOD		animozhi. E. - EMERGENCY MEDICINE	21/07/2022

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 24/12/2022 Status : Completed								
7	22121104	Casualty	LARYNGOSCOPE NOT WORKING	Gurumoorthy. G.	checked and found the laryngoscop battery connection issue it's rectified now working good		Kazhagamani. V. - EMERGENCY MEDICINE	27/12/2022
Dept Name : FORENSIC MEDICINE - Biomedical Comp. Dt. : 10/05/2023 Status : Completed								
8	23050400	FORENSIC MEDICINE	FM PROBLM	Gurumoorthy. G.	WORKSHOP COMPLAINT		Ganga. G. - FORENSIC MEDICINE	11/05/2023
Dept Name : ICCU - Biomedical Comp. Dt. : 11/01/2023 Status : Completed								
9	23010497	ICCU	NIBP CUFF NOT WORKING	Vignesh. D.	nibp cuff replaced now working good		Ammu. R. - ICCU	11/01/2023
Dept Name : Labour Ward - Biomedical Comp. Dt. : 08/08/2022 Status : Completed								
10	22080288	Labour Room	BP APPARATUS NOT WORKING	Vignesh. D.	checked and found the bulb issue it's replaced now it's working good		Sathiyavathi. S. - Labour Ward	09/08/2022
Dept Name : Male Medical Ward - Biomedical Comp. Dt. : 15/07/2022 Status : Completed								
11	22070598	Male Medical - Ward 301	ECG MACHINE NOT WORKING	Sridhar. K.	stand by cable replaces now its working	AssetNo :16000290	Soniya Gandhi. A. - Male Medical Ward	23/07/2022
Dept Name : Nephrology - Biomedical Comp. Dt. : 18/04/2023 Status : Completed								
12	23040548	DIALYSIS NEW UNIT IN 1ST FLOOR	N-4 MACHINE PROBLEM	Sridhar. K.	checked and found that temperature sensor issue.the problem is rectified.	AssetNo :16000211	Kamal. B. - Nephrology	24/04/2023
Dept Name : OPD - Biomedical Comp. Dt. : 11/05/2022 Status : Completed								

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
13	22050400	OG-OPD	WEIGHT MACHINE NOT WORKING	Vignesh. D.	checked and found that battery issue, replaced new battery now working good.		Velangkanni. K. - OPD	12/05/2022
Comp. Dt. : 02/09/2022 Status : Completed								
14	22090092	Orthopaedics - OPD	BP-APPARATUS NOT WORK	Vignesh. D.	BULB REPLACED NOW IT'S WORKING GOOD		Durgadevi. J - OPD	03/09/2022
Comp. Dt. : 21/11/2022 Status : Completed								
15	22110866	Orthopaedics - OPD	2 NO'S BP APPARATUS NOT WORKING	Sridhar. K.	cuff. baldder replaced		Durgadevi. J - OPD	21/11/2022
Dept Name : P.H.C. - Tiruvennainallur - Biomedical Comp. Dt. : 17/08/2022 Status : Completed								
16	22080549	THIRUVENNAINALLUR HOSPITAL(SMVMCH)	CALORIMETER NOT WORKIG	Gurumoorthy. G.	checked and found that board problem. the problem is rectified.		Kanagasabai. D. - P.H.C. - Tiruvennainallur	31/10/2022
Comp. Dt. : 26/10/2022 Status : Completed								
17	22100827	THIRUVENNAINALLUR HOSPITAL(SMVMCH)	SEMI AUTO MACHINE NOT WORKING	Sridhar. K.	checked and found that lamp issue. replace the lamp		Kanagasabai. D. - P.H.C. - Tiruvennainallur	26/10/2022
Comp. Dt. : 14/11/2022 Status : Completed								
18	22110509	THIRUVENNAINALLUR HOSPITAL(SMVMCH)	IN ECG MACHINE -ECG BULB AND ELECTRODES CLAMP DAMAGES	Gurumoorthy. G.	checked and found that clamp electrode damage. purchase to new one		Kanagasabai. D. - P.H.C. - Tiruvennainallur	19/11/2022
Comp. Dt. : 15/11/2022 Status : Completed								
19	22110628	THIRUVENNAINALLUR HOSPITAL(SMVMCH)	ECG MACHINE NOT WORKING	Sridhar. K.	not services in condemnation.		Kanagasabai. D. - P.H.C. - Tiruvennainallur	21/11/2022
Comp. Dt. : 17/11/2022 Status : Completed								
20	22110739	THIRUVENNAINALLUR HOSPITAL(SMVMCH)	IFT MACHINE-2 SET MAIN CABLE AND 3 SET OUTPUT CABLE NEED TO BE SERVICE	Sridhar. K.	ift cable served		Kanagasabai. D. - P.H.C. - Tiruvennainallur	21/11/2022
Comp. Dt. : 24/11/2022								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
21	22111073	THIRUVENNAINALLUR HOSPITAL(SMVMCH)	CALORIMETER NEED TO DO SERVICE	Sridhar. K.	serviced now its working		Kanagasabai. D. - P.H.C. - Tiruvonnainallur	25/11/2022
Comp. Dt. : 11/01/2023								
Status : Completed								
22	23010466	THIRUVENNAINALLUR HOSPITAL(SMVMCH)	X-RAY MACHINE NOT WORKING	Gurumoorthy. G.	fuse replaced now working good		Kanagasabai. D. - P.H.C. - Tiruvonnainallur	11/01/2023
Dept Name : Paediatrics Ward - Biomedical								
Comp. Dt. : 10/05/2023								
Status : Completed								
23	23050409	Paediatrics - Ward 308	WEIGHT MACHINE NOT WORKING	Gurumoorthy. G.	replaced the battery		Chitra. P. - Paediatrics Ward	10/05/2023
Dept Name : Physiotherapy - Biomedical								
Comp. Dt. : 18/04/2023								
Status : Completed								
24	23040549	pysiotherapy	MOISER HEAT MACHINE NOT WORKING	Sridhar. K.	switch problem.replaced the switch.		Ezhilan.K. - Physiotherapy	19/04/2023
Dept Name : PICU & NICU - Biomedical								
Comp. Dt. : 07/10/2022								
Status : Completed								
25	22100145	NICU	C PAP MACHINE NOT WORKING	Vignesh. D.	CHECKED AND FOUND THE O2 HIGH PRESSURE ISSUE IT'S RECTIFIED NOW WORKING GOOD.		Gobiya. G. - PICU & NICU	10/10/2022
Dept Name : POW & SICU - Biomedical								
Comp. Dt. : 16/02/2023								
Status : Completed								
26	23020641	SICU	O2 FLOW METER NOT WORKING	Vignesh. D.	connector issue.the problem is rectified.		Valarmathy. K. - POW & SICU	17/02/2023

College Name : SMVMCH-COL

Work Type : Complaint

Dept Name : BIOCHEMISTRY - Biomedical

Comp. Dt. : 16/06/2022

Status : Completed

27 22060624 BIOCHEMISTRY--COLLEGE

HOT PLATE NOT WORKING

Sridhar. K.

WIRE LOOSE CONNECTION ISSUE IT'S RECTIFIED NOW IT'S WORKING GOOD

Anusuya. J. - BIOCHEMISTRY

01/07/2022

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 04/07/2022 Status : Completed								
28	22070083	BIOCHEMISTRY-- -COLLEGE	PROBLEM IN MAGNETIC STERILE	Sridhar. K.	GENRAL SERVICES ITS NOW WORKING		Anusuya. J. - BIOCHEMISTRY	05/07/2022
Comp. Dt. : 18/10/2022 Status : Completed								
29	22100565	BIOCHEMISTRY-- -COLLEGE	WEIGHT MACHINE NOT WORKING	Sridhar. K.	MAIN BOARD SERVICED NOW WORKING		Suganthi. P. - BIOCHEMISTRY	16/12/2022
Comp. Dt. : 22/11/2022 Status : Completed								
30	22110918	BIOCHEMISTRY-- -COLLEGE	GEL DOGUMENT NOT WORKING AT RESEARCH LAB	Sridhar. K.	uv light cable serviced		Anusuya. J. - BIOCHEMISTRY	24/11/2022
Comp. Dt. : 13/02/2023 Status : Completed								
31	23020491	BIOCHEMISTRY-- -COLLEGE	CENTRIFUGE NOT WORKING	Sridhar. K.	serviced now working		Anusuya. J. - BIOCHEMISTRY	14/02/2023
Comp. Dt. : 03/03/2023 Status : Completed								
32	23030152	BIOCHEMISTRY-- -COLLEGE	NEED TO FIX SPECTROMETER	Sridhar. K.	fixed done now working good		Anusuya. J. - BIOCHEMISTRY	04/03/2023
Comp. Dt. : 13/04/2023 Status : Completed								
33	23040413	BIOCHEMISTRY-- -COLLEGE	P H MOTOR NOT WORKING - P C R LAB	Sridhar. K.	WIRE CONNECTION ISSUE IT'S RECTIFIED NOW WORKING GOOD		Anusuya. J. - BIOCHEMISTRY	18/04/2023
Comp. Dt. : 08/06/2023 Status : Completed								
34	23060265	BIOCHEMISTRY-- -COLLEGE	MACHINE CABLE NOT WORKING	Sridhar. K.	ac dc adapter missing.need for purchase to new one		Suganthi. P. - BIOCHEMISTRY	16/06/2023
Comp. Dt. : 15/06/2023 Status : Completed								
35	23060549	BIOCHEMISTRY-- -COLLEGE	ELISA WASHER NOT WORKING (BIOCHEMISTRY CR LAB)	Sridhar. K.	GENRAL SERVICE WORKING		Anusuya. J. - BIOCHEMISTRY	19/06/2023
Dept Name : FORENSIC MEDICINE - Biomedical Comp. Dt. : 13/10/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
36	22100413	FORENSIC MEDICINE (3RD FLOOR) IN COLLEGE	NEED TO REFIX MICROCOPY	Sridhar. K.	FIXED WORKING COMPLETED.REPLACE PORWER CARD		Mathavi. B. - FORENSIC MEDICINE	19/10/2022
Comp. Dt. : 10/11/2022 Status : Completed								
37	22110385	FORENSIC MEDICINE (3RD FLOOR) IN COLLEGE	NEED TO REFIX MICROSCOPE	Sridhar. K.	fix working completed.		Mathavi. B. - FORENSIC MEDICINE	14/11/2022
Dept Name : MICROBIOLOGY - Biomedical Comp. Dt. : 09/05/2022 Status : Completed								
38	22050261	MICROBIOLOGY IN COLLEGE	AUTOCLAVE MACHINE IN WASHING ROOM NOT WORKING	Sridhar. K.	checked and found that coil is defective.replaced the new coil.nowits working good.		Mageswari. R. - MICROBIOLOGY	09/05/2022
Comp. Dt. : 16/05/2022 Status : Completed								
39	22050549	MICROBIOLOGY IN COLLEGE	NEED TO CHANGE WOODEN ROPE	Sridhar. K.	checked and found that rope issue,replaced new rope now working good.		Anandh. P. - MICROBIOLOGY	01/06/2022
Comp. Dt. : 28/05/2022 Status : Completed								
40	22051048	MICROBIOLOGY IN COLLEGE	DEEP FREEZER DISPLAY "-80"	Sridhar. K.	checked and found problem in switch connector disconnected so solder it properly problem rectified.		Anandh. P. - MICROBIOLOGY	30/05/2022
Comp. Dt. : 17/06/2022 Status : Completed								
41	22060662	MICROBIOLOGY IN COLLEGE	PROBLEM IN B O D	Sridhar. K.	checked and found that wire connection problem.the problem is rectfied.		Buvana. C. - MICROBIOLOGY	24/06/2022
Comp. Dt. : 04/07/2022 Status : Completed								
42	22070078	MICROBIOLOGY IN COLLEGE	PROBLEM IN - DEEP FREEZER - PCR LAB	Sridhar. K.	CABLE LOOSE ITS NOW WORKING		Yuvaraj. P. - MICROBIOLOGY	05/07/2022
Comp. Dt. : 20/07/2022 Status : Completed								
43	22070762	MICROBIOLOGY IN COLLEGE	NEEDLE DESTROYER NOT WORKING	Sridhar. K.	checked and found that rust problem.the problem is rectfied		Buvana. C. - MICROBIOLOGY	21/07/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 25/07/2022 Status : Completed								
44	22070884	MICROBIOLOGY IN COLLEGE	NEEDLE BURN MACHINE NOT WORKING	Sridhar. K.	checked and found that power card loose connection problem.the problem is rectified		Mathu. M. - MICROBIOLOGY	25/07/2022
Comp. Dt. : 26/09/2022 Status : Completed								
45	22091019	MICROBIOLOGY IN COLLEGE	NEED TO CHECK AUTOCLAVE MACHINE - WATER LEAKAGE - NEED URGENT SERVICE	Sridhar. K.	endoff services		Mageswari. R. - MICROBIOLOGY	03/10/2022
Comp. Dt. : 05/10/2022 Status : Completed								
46	22100062	MICROBIOLOGY IN COLLEGE	AUTOCLAVE NOT WORKING	Sridhar. K.	checked and found that drum dust and coil defective.issued the condemnation report		Mathu. M. - MICROBIOLOGY	06/10/2022
Comp. Dt. : 07/10/2022 Status : Completed								
47	22100163	MICROBIOLOGY IN COLLEGE	AUTOCLAVE NOT WORKING	Sridhar. K.	wire loose connection issue. it's rectified now working good		Buvana. C. - MICROBIOLOGY	12/10/2022
Comp. Dt. : 26/10/2022 Status : Completed								
48	22100822	MICROBIOLOGY IN COLLEGE	LAB AUTO CLAVE NOT WORKING	Sridhar. K.	heating coil replced		Buvana. C. - MICROBIOLOGY	26/10/2022
Comp. Dt. : 31/01/2023 Status : Completed								
49	23011097	MICROBIOLOGY IN COLLEGE	NEED TO CHECK LAMINOR HOOD DOOR - PROBLEM	Sridhar. K.	checked and found that rope broken.the problem is rectified.		Gopal. R. - MICROBIOLOGY	31/01/2023
Comp. Dt. : 03/04/2023 Status : Completed								
50	23040054	MICROBIOLOGY IN COLLEGE	AUTOCLAVE MACHINE NOT WORKING	Sridhar. K.	serviced now working		Gopal. R. - MICROBIOLOGY	03/04/2023
Comp. Dt. : 15/05/2023 Status : Completed								
51	23050604	MICROBIOLOGY IN COLLEGE	NEED TO CHANGE GASCUT FOR AUTOCLAVE	Sridhar. K.	checked and found that gascut issue.the problem is rectified.		Mageswari. R. - MICROBIOLOGY	17/05/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 13/06/2023 Status : Completed								
52	23060457	MICROBIOLOGY IN COLLEGE	PROBLEM IN B O D MACHINE	Sridhar. K.	GENRAL SERVICES WORKING		Mageswari. R. - MICROBIOLOGY	19/06/2023
Dept Name : PATHOLOGY - Biomedical Comp. Dt. : 06/05/2022 Status : Completed								
53	22050197	PATHOLOGY IN COLLEGE	EMBEDDING MACHINE NOT WORKING	Sridhar. K.	checked and found that internal problem,problem rectified now working good.		Sathia Rajesh. C. - PATHOLOGY	07/05/2022
Comp. Dt. : 10/06/2022 Status : Completed								
54	22060371	PATHOLOGY IN COLLEGE	HOT PLATE NOT WORKING	Sridhar. K.	NEED TO CHANGE HEATING COIL. coil replaced.now working good.		Sathia Rajesh. C. - PATHOLOGY	31/10/2022
Comp. Dt. : 12/08/2022 Status : Completed								
55	22080426	PATHOLOGY IN COLLEGE	NEED TO CHECK TISSUE PROCESSOR - NOT WORKING	Sridhar. K.	checked found that motor belt replaced now its working good		Sathia Rajesh. C. - PATHOLOGY	20/08/2022
56	22080436	PATHOLOGY IN COLLEGE	PROBLEM IN EMBEDDING WORK STATION	Sridhar. K.	tube adjustment now workingt		Sathia Rajesh. C. - PATHOLOGY	29/09/2022
Comp. Dt. : 24/09/2022 Status : Completed								
57	22090960	PATHOLOGY IN COLLEGE	EMBEDDING MACHINE NOT WORKING	Sridhar. K.	checked and found that nazzel wax is not flow.the problem is rectified		Sathia Rajesh. C. - PATHOLOGY	02/01/2023
Comp. Dt. : 12/12/2022 Status : Completed								
58	22120564	PATHOLOGY IN COLLEGE	MICROSCOPE NOT WORKING	Sridhar. K.	board serviced		Sathia Rajesh. C. - PATHOLOGY	02/01/2023
Comp. Dt. : 13/02/2023 Status : Completed								
59	23020501	PATHOLOGY IN COLLEGE	FORMALDEHYDE MONITOR NOT WORKING	Sridhar. K.	componey serviced		Sathia Rajesh. C. - PATHOLOGY	14/02/2023
Comp. Dt. : 27/04/2023 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
60	23040934	PATHOLOGY IN COLLEGE	COLD PLATE NOT WORKING	Sridhar. K.	checked and found that sensor wire issue.the problem is rectified.		Sathia Rajesh. C. - PATHOLOGY	02/05/2023
Comp. Dt. : 06/06/2023 Status : Completed								
61	23060176	PATHOLOGY IN COLLEGE	MICROSCOPY NOT WORKING	Sridhar. K.	replaced the lamp		Sathia Rajesh. C. - PATHOLOGY	06/06/2023
Dept Name : PHYSIOLOGY - Biomedical Comp. Dt. : 31/01/2023 Status : Completed								
62	23011124	PHYSIOLOGY--COLLEGE	MICROSCOPE NOT WORKING	Sridhar. K.	replaced the lamp		Jayanthi.A. - PHYSIOLOGY	31/01/2023
Comp. Dt. : 16/03/2023 Status : Completed								
63	23030653	PHYSIOLOGY--COLLEGE	MICROSCOPE NOT WORKING	Sridhar. K.	replaced the lamp		Shanthini. M. - BIOCHEMISTRY	24/03/2023
Comp. Dt. : 25/03/2023 Status : Completed								
64	23031045	PHYSIOLOGY--COLLEGE	NEED MICROSCOPE SERVICE - NOT WORKING	Vignesh. D.	replaced the lamp		Shanthini. M. - BIOCHEMISTRY	25/03/2023
Comp. Dt. : 20/04/2023 Status : Completed								
65	23040672	PHYSIOLOGY--COLLEGE	MICROSCOPY NOT WORKING	Gurumoorthy. G.	replaced the lamp		Jayanthi.A. - PHYSIOLOGY	28/04/2023
66	23040673	PHYSIOLOGY--COLLEGE	ECG MACHINE NOT WORKING	Gurumoorthy. G.	checked and found that ecg cable connection problem.the problem is rectified.		Jayanthi.A. - PHYSIOLOGY	02/05/2023
Dept Name : Radio Diagnosis - Biomedical Comp. Dt. : 28/10/2022 Status : Completed								
67	22100896	SCAN - GROUND FLOOR - BLOOD BANK OPP	ULTRASOUND SCAN MACHINE PROBLEM	Gurumoorthy. G.	checked and found that probe connection problem.the problem is rectified.	AssetNo :16000715	Sudha. D. - Radio Diagnosis	28/10/2022

College Name : SMVMCH-HOS

Work Type : Complaint

Dept Name : BIOCHEMISTRY - Biomedical

Comp. Dt. : 22/08/2022

Status : Completed

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
68	22080722	BIOCHEMISTRY	OVER NOISE PROBLEM IN CENTRIFUGE	Sridhar. K.	GENRAL SERVICES NOW WORKING		Srinivasamurugan. V. - BIOCHEMISTRY	26/08/2022
Comp. Dt. : 30/08/2022 Status : Completed								
69	22081003	BIOCHEMISTRY	CENTRIFUGE NOT WORKING	Vignesh. D.	carbon brush changed working good		Sangeetha. S. - BIOCHEMISTRY	01/09/2022
70	22081039	BIOCHEMISTRY	CENTRIFUGE NOT WORKING	Vignesh. D.	carbon brush changed now it's working good		Srinivasamurugan. V. - BIOCHEMISTRY	01/09/2022
Comp. Dt. : 05/09/2022 Status : Completed								
71	22090194	BIOCHEMISTRY	CALORIMETER [2NOS] NOT WORKING	Sridhar. K.	genral service now working		Suganthi. P. - BIOCHEMISTRY	06/09/2022
Comp. Dt. : 18/10/2022 Status : Completed								
72	22100603	Biochemistry Lab-Hospital	CENTERFUGE NOT WORKING	Sridhar. K.	armature replaced		Srinivasamurugan. V. - BIOCHEMISTRY	02/01/2023
Comp. Dt. : 26/10/2022 Status : Completed								
73	22100794	Biochemistry Lab-Hospital	CENTRIFUGE NOT WORKING	Sridhar. K.	carbon bush replaced, now its working good.		Srinivasamurugan. V. - BIOCHEMISTRY	26/10/2022
Comp. Dt. : 05/12/2022 Status : Completed								
74	22120183	Biochemistry Lab-Hospital	WEIGHT MACHINE NOT WORKING	Sridhar. K.	main board serviced now its working		Sathyamurugan. E. - BIOCHEMISTRY	24/12/2022
Comp. Dt. : 23/12/2022 Status : Completed								
75	22121045	Biochemistry Lab-Hospital	CENTRIFUGE NOT WORKING	Sridhar. K.	genral serviced now working		Srinivasamurugan. V. - BIOCHEMISTRY	24/12/2022
Comp. Dt. : 31/12/2022 Status : Completed								
76	22121387	Biochemistry Lab-Hospital	DISTAL WATER PLANT WATER LEAKAGING PROBLEM	Sridhar. K.	tube replaced now working good		Srinivasamurugan. V. - BIOCHEMISTRY	02/01/2023
Comp. Dt. : 04/02/2023 Status : Completed								
77	23020126	Orthopaedics - OPD	BP APPARATUS 2NOS NOT WORKING	Gurumoorthy. G.	replaced the battery		Durga Devi. I. - BIOCHEMISTRY	06/02/2023
Comp. Dt. : 07/02/2023 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
78	23020214	BIOCHEMISTRY	CENTRIFUGE NOT WORKING	Gurumoorthy. G.	replaced the carbon brush		Srinivasamurugan. V. - BIOCHEMISTRY	07/02/2023
Comp. Dt. : 09/02/2023 Status : Completed								
79	23020321	Biochemistry Lab-Hospital	CENTRIFUGE NOT WORKING	Gurumoorthy. G.	replaced the carbon brush		Srinivasamurugan. V. - BIOCHEMISTRY	10/02/2023
80	23020362	Biochemistry Lab-Hospital	CENTRIFUGE NOT WORKING	Sridhar. K.	replaced the carbon brush		Srinivasamurugan. V. - BIOCHEMISTRY	10/02/2023
Comp. Dt. : 14/03/2023 Status : Completed								
81	23030518	BIOCHEMISTRY	CENTRIFUGE NOT WORKING	Gurumoorthy. G.	replaced the carbon brush		Srinivasamurugan. V. - BIOCHEMISTRY	14/03/2023
Comp. Dt. : 17/03/2023 Status : Completed								
82	23030686	BIOCHEMISTRY	CENTRIFUGE NOT WORKING	Gurumoorthy. G.	replaced the carbon brush		Sathyamurugan. E. - BIOCHEMISTRY	24/03/2023
Comp. Dt. : 18/03/2023 Status : Completed								
83	23030735	BIOCHEMISTRY	CENTRIFUGE NOT WORKING	Vignesh. D.	carban brush replaced now working good		Sathyamurugan. E. - BIOCHEMISTRY	21/03/2023
Comp. Dt. : 25/03/2023 Status : Completed								
84	23031037	BIOCHEMISTRY	CENTRIFUGE NOT WORKING	Vignesh. D.	replaced the carbon brush		Srinivasamurugan. V. - BIOCHEMISTRY	25/03/2023
Comp. Dt. : 19/04/2023 Status : Completed								
85	23040601	BIOCHEMISTRY	CENTRIFUGE NOT WORKING	Gurumoorthy. G.	replaced the carbon brush		Srinivasamurugan. V. - BIOCHEMISTRY	20/04/2023
Comp. Dt. : 02/05/2023 Status : Completed								
86	23050042	BIOCHEMISTRY	CENTRIFUGE NOT WORKING	Gurumoorthy. G.	replaced the carbon brush		Srinivasamurugan. V. - BIOCHEMISTRY	03/05/2023
Comp. Dt. : 11/05/2023 Status : Completed								
87	23050464	BIOCHEMISTRY	CENTRIFUGE NOT WORKING	Gurumoorthy. G.	replaced the carbon brush.		Srinivasamurugan. V. - BIOCHEMISTRY	12/05/2023
Comp. Dt. : 29/05/2023 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
88	23051121	BIOCHEMISTRY	CENTRIFUGE NOT WORKING	Sridhar. K.	carbon brush replaced and serviced	AssetNo :16000880	Srinivasamurugan. V. - BIOCHEMISTRY	29/05/2023
Comp. Dt. : 07/06/2023 Status : Completed								
89	23060252	BIOCHEMISTRY	CENTRIFUGE [2NOS] NOT WORKING	Gokul. P. K.	carbonbrush replaced now working		Srinivasamurugan. V. - BIOCHEMISTRY	09/06/2023
Comp. Dt. : 08/06/2023 Status : Completed								
90	23060264	BIOCHEMISTRY-- -COLLEGE	WEIGHT MACHINE NOT WORKING	Sridhar. K.	machine serviced now working		Suganthi. P. - BIOCHEMISTRY	09/06/2023
Comp. Dt. : 21/06/2023 Status : Completed								
91	23060794	BIOCHEMISTRY	CENTRIFUGE NOT WORKING	Gokul. P. K.	replaced the carbon brush		Vishnu Priya. B. - BIOCHEMISTRY	22/06/2023
Comp. Dt. : 27/06/2023 Status : Completed								
92	23061032	BIOCHEMISTRY	CENTRIFUGE NOT WORKING	Sridhar. K.	CARBON BRUSH REPLACED NOW WORKING		Srinivasamurugan. V. - BIOCHEMISTRY	28/06/2023
Dept Name : BLOOD BANK - Biomedical Comp. Dt. : 20/05/2022 Status : Completed								
93	22050770	Blood Bank	BP APPARATUS NOT WORKING	Sridhar. K.	checked and found that bulb with valve problem,replaced new bulb with valve now working good.		Thirumangai. S. - BLOOD BANK	20/05/2022
Comp. Dt. : 23/05/2022 Status : Completed								
94	22050821	Blood Bank	CENTRIFUGE NOT WORKING	Vignesh. D.	checked and found problem in carbon bush defective so it replaced with the new one problem rectified		Sivasankari.I. - BLOOD BANK	23/05/2022
Comp. Dt. : 17/06/2022 Status : Completed								
95	22060653	Blood Bank	CENTRIFUGE NOT WORKING	Sridhar. K.	replaced the carbon brush		Sivasankari.I. - BLOOD BANK	18/06/2022
Comp. Dt. : 27/06/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
96	22060973	Blood Bank	CENTRIFUGE NOT WORKING	Sridhar. K.	checked and found that armature problem.the problem is rectified		Sivasankari.I. - BLOOD BANK	02/01/2023
	Comp. Dt. : 29/06/2022							
	Status : Completed							
97	22061057	Blood Bank	BP APPARATUS NOT WORKING	Vignesh. D.	CHECKED AND FOUND THE LOOSE CONNECTION ISSUE IT'S RECTIFIED NOW IT'S WORKING GOOD		Thirumangai. S. - BLOOD BANK	29/06/2022
	Comp. Dt. : 17/08/2022							
	Status : Completed							
98	22080502	Blood Bank	BP APPARATUS NOT WORKING	Gurumoorthy. G.	replaced the bladder		Thirumangai. S. - BLOOD BANK	17/08/2022
	Comp. Dt. : 05/10/2022							
	Status : Completed							
99	22100036	Blood Bank	NEED TO FIX INSTRUMENT HANDLE	Sridhar. K.	screw loos ,services its now working		Ganesh. V. - BLOOD BANK	06/10/2022
	Comp. Dt. : 02/11/2022							
	Status : Completed							
100	22110006	Blood Bank	THAWING WATER BATH MACHINE TEMPERATURE PROBLEM	Sridhar. K.	checked and found that coil problem.replaced the coil		Ganesh. V. - BLOOD BANK	03/11/2022
	Comp. Dt. : 16/11/2022							
	Status : Completed							
101	22110669	Blood Bank	HEMOMIXER MACHINE NOT WORKING	Sridhar. K.	power crod replace working		Ganesh. V. - BLOOD BANK	21/11/2022
	Comp. Dt. : 25/11/2022							
	Status : Completed							
102	22111111	Blood Bank	centrifuge not working	Vignesh. D.	CARBON BRUSH REPLACED NOW WORKING GOOD		Sivasankari.I. - BLOOD BANK	26/11/2022
	Comp. Dt. : 12/12/2022							
	Status : Completed							
103	22120537	Blood Bank	1 BP APPARATUS NOT WORKING	Sridhar. K.	GENRAL SERVICES WORKING		Thirumangai. S. - BLOOD BANK	12/12/2022
	Comp. Dt. : 04/02/2023							
	Status : Completed							
104	23020137	Blood Bank	B P APPARATUS NOT WORKING 2NOS	Gurumoorthy. G.	replaced the bulb with valve		Thirumangai. S. - BLOOD BANK	06/02/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 24/02/2023								
Status : Completed								
105	23020937	Blood Bank	CENTRIFUGE NOT WORKING	Gurumoorthy. G.	replaced the carbon brush		Kokilambal. U. - BLOOD BANK	27/02/2023
Comp. Dt. : 11/04/2023								
Status : Completed								
106	23040304	Blood Bank	CENTRIFUGE NOT WORKING	Sridhar. K.	replaced the carbon brush		Radhika. S. - BLOOD BANK	12/04/2023
Comp. Dt. : 15/05/2023								
Status : Completed								
107	23050614	Blood Bank	CENTRIFUGE NOT WORKING	Sridhar. K.	replaced the carbon brush		Radhika. S. - BLOOD BANK	17/05/2023
Comp. Dt. : 08/06/2023								
Status : Completed								
108	23060272	Blood Bank	CENTRIFUGE NOT WORKING	Gokul. P. K.	carbon brush replaced		Sangavi. S. - BLOOD BANK	09/06/2023
Comp. Dt. : 12/06/2023								
Status : Completed								
109	23060412	Blood Bank	CENTRIFUGE NOT WORKING	Gurumoorthy. G.	replaced the carbon brush		Ganesh. V. - BLOOD BANK	12/06/2023
Comp. Dt. : 21/06/2023								
Status : Completed								
110	23060763	Blood Bank	CENTRIFUGE NOT WORKING	Gokul. P. K.	replaced the carbon brush.		Radhika. S. - BLOOD BANK	21/06/2023
Dept Name : Blood Collection Centre - Biomedical								
Comp. Dt. : 11/05/2023								
Status : Completed								
111	23050465	Blood Bank	CENTRIFUGE NOT WORKING	Gurumoorthy. G.	replaced the carbon brush		Sathiya. S. - Blood Collection Centre	12/05/2023
Dept Name : Canteen - Boys Hostel - Biomedical								
Comp. Dt. : 07/07/2022								
Status : Completed								
112	22070236	Boys hostel	DIGITAL WEIGHT MACHINE NOT WORKING IN STORE ROOM	Sridhar. K.	services its now working		Elumalai. M. - Canteen - Boys Hostel	09/07/2022
Comp. Dt. : 11/04/2023								
Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
113	23040318	BOYS HOSTEL MESS	NEED TO CHECK WEIGHT MACHINE - NOT WORKING	Sridhar. K.	CHECKED AND FOUND THE WIRE CONNECTION ISSUE IT'S RECTIFIED NOW WORKING GOOD		Kesavaraj. P. - Canteen - Boys Hostel	18/04/2023
Dept Name : CARDIOLOGY - Biomedical Comp. Dt. : 06/05/2022 Status : Completed								
114	22050177	ECHO CARDIO GRAM	BP APPARATUS NOT WORKING	Vignesh. D.	replaced the bulb with valve		Ramani Palanivel.P. - CARDIOLOGY	07/05/2022
115	22050184	General Medicine - OPD	ECG MACHINE & CABLE NOT WORKING IN ECG ROOM	Vignesh. D.	checked and found that cable issue,problem rectified now working good.		Sivasankari. M. - CARDIOLOGY	07/05/2022
Comp. Dt. : 07/06/2022 Status : Completed								
116	22060257	General Medicine - OPD	ECG MACHINE NOT WORKING IN ECG ROOM	Gurumoorthy. G.	checked and found that ecg loose connection problem, problem rectified now working good.	AssetNo :16000290	Sivasankari. M. - CARDIOLOGY	09/06/2022
Comp. Dt. : 30/06/2022 Status : Completed								
117	22061128	General Medicine - OPD	ECG MACHINE NOT WORKING IN MEDICINE OPD ECG ROOM	Sridhar. K.	checked and found the cable issue. stand by cable changed. now its working	AssetNo :16000290	Sivasankari. M. - CARDIOLOGY	18/07/2022
Comp. Dt. : 06/07/2022 Status : Completed								
118	22070226	EYE Bank	ECG CABLE NOT WORKING - OPD ROOM NO 221	Vignesh. D.	checked and found the ecg cable other m/c cable replace its now working	AssetNo :16000847	Priyanka. M. - CARDIOLOGY	15/07/2022
Comp. Dt. : 23/08/2022 Status : Completed								
119	22080754	Cath Lab	NEED TO CHECK BATTERY BACKUP FOR MP20 MULTIPARA MONITOR	Gurumoorthy. G.	checked and found that battery connection problem.the problem is rectified.		Deva Arul Selva Sagayaraj. A. - CARDIOLOGY	14/10/2022
Comp. Dt. : 23/09/2022 Status : Completed								
120	22090932	ECG	ECG MACHINE NOT WORKING - II FLOOR ECG ROOM	Sridhar. K.	print module services its now working	AssetNo :16000847	Priyanka. M. - CARDIOLOGY	24/09/2022
Comp. Dt. : 20/10/2022								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
121	22100665	ECHO CARDIO GRAM	HOLTER MONITOR CABLE DAMAGED	Sridhar. K.	services its working		Aarthi. A. - CARDIOLOGY	21/10/2022
Comp. Dt. : 16/11/2022								
Status : Completed								
122	22110671	ECHO CARDIO GRAM	HOLTER MACHINE NOT WORKING	Gurumoorthy. G.	replaced track -48 cable working	AssetNo :16000331	Chitra. V. - CARDIOLOGY	24/11/2022
Comp. Dt. : 26/11/2022								
Status : Completed								
123	22111138	ECHO CARDIO GRAM	TMT MACHINE PRINTER NOT WORKING	Vignesh. D.	ECG CABLE LOOSE CONNECTION ISSUE RECTIFIED NOW WORKING		Ramani Palanivel.P. - CARDIOLOGY	01/12/2022
Comp. Dt. : 29/11/2022								
Status : Completed								
124	22111225	ECHO CARDIO GRAM	NEED TO CLEAN ECHO MACHINE FILLTER	Sridhar. K.	serviced echo machine		Ramani Palanivel.P. - CARDIOLOGY	30/11/2022
Comp. Dt. : 01/12/2022								
Status : Completed								
125	22120032	ECHO CARDIO GRAM	TMT SOFTWARE ISSUE	Sridhar. K.	SOFTWARE REINSTALL NOW WORKING GOOD	AssetNo :16000824	Ramani Palanivel.P. - CARDIOLOGY	01/12/2022
Comp. Dt. : 02/12/2022								
Status : Completed								
126	22120075	ECHO CARDIO GRAM	LEAD SETTING T M T MACHINE	Sridhar. K.	auto print report changed now its working	AssetNo :16000824	Ramani Palanivel.P. - CARDIOLOGY	02/12/2022
Comp. Dt. : 10/01/2023								
Status : Completed								
127	23010414	Cath Lab	MP20 MONITOR BATTERY NEED TO BE CHANGE	Gurumoorthy. G.	checked and found that battery connection problem.the problem is rectified.		Deva Arul Selva Sagayaraj. A. - CARDIOLOGY	10/01/2023
128	23010415	Cath Lab	PHILIPS MULTIPARA MONITOR BATTERY NEED TO BE CHANGE	Gurumoorthy. G.	checked and found that power connnection problem.the problem is rectified		Deva Arul Selva Sagayaraj. A. - CARDIOLOGY	10/01/2023
Comp. Dt. : 13/01/2023								
Status : Completed								
129	23010557	ECHO CARDIO GRAM	TMT PRINTER NOT WORKING	Sridhar. K.	cable adjustment now working		Ramani Palanivel.P. - CARDIOLOGY	14/01/2023
Comp. Dt. : 25/01/2023								
Status : Completed								

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
130	23010932	ECHO CARDIO GRAM	PHILIP"S ECHO MACHINE NOT WORKING	Sridhar. K.	cable issue it's rectified now working good		Ramani Palanivel.P. - CARDIOLOGY	25/01/2023
Comp. Dt. : 31/01/2023 Status : Completed								
131	23011096	SUPER SPECILAITY OPD IN 2ND FLOOR	NEED TO CHANGE ECG MACHINE CABLE	Sridhar. K.	checked and found that ecg cable connection problem.the problem is rectified.		Priyanka. M. - CARDIOLOGY	31/01/2023
Comp. Dt. : 23/02/2023 Status : Completed								
132	23020885	General Medicine - OPD	ECG MACHINE NOT WORKING	Sridhar. K.	checked and found that ecg module issue.the problem is rectified.		Sivasankari. M. - CARDIOLOGY	27/02/2023
Comp. Dt. : 11/05/2023 Status : Completed								
133	23050439	ECG	ECG CABLE PROBLEM - NEED TO CHANGE CABLE - II FLOOR ECG ROOM	Gurumoorthy. G.	replaced the ecg cable		Priyanka. M. - CARDIOLOGY	12/05/2023
Dept Name : Cardiothoracic ICU - Biomedical Comp. Dt. : 19/05/2022 Status : Completed								
134	22050718	CT-ICU ROOM-NEAR ORTHO OT RECOVERY ROOM	NEED TO CHECK STERNAL SHW - NOT WORKING	Gurumoorthy. G.	checked and found that saw collar and guide damaged replaced the collar and guide and serviced it pr		Aswani. J. - Cardiothoracic ICU	23/05/2022
Comp. Dt. : 09/07/2022 Status : Completed								
135	22070389	CT POW -SPECIAL WARD B	MULTIPARA MONITOR NOT WORKING	Sridhar. K.	genral services now working	AssetNo :16000018	Gayathri. S. - Cardiothoracic POW	11/07/2022
Comp. Dt. : 27/07/2022 Status : Completed								
136	22071039	CT-ICU ROOM-NEAR ORTHO OT RECOVERY ROOM	NEED TO CHECK ARTERIAL CABLE - NOT WORKING	Vignesh. D.	CABLE ISSUE NEED TO REPLACED NEW ONE		Isaivani. R. - Cardiothoracic ICU	29/07/2022
Comp. Dt. : 05/09/2022 Status : Completed								
137	22090180	CT-ICU ROOM-NEAR ORTHO OT RECOVERY ROOM	VENTILATOR NOT WORKING	Vignesh. D.	CHECKED AND DONE THE PREUSE CHECK ALL THE TEST PASSED NOW WORKING GOOD	AssetNo : 16000018	Sadham Husain. S. - Cardiothoracic ICU	05/09/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
138	22090181	CT-ICU ROOM-NEAR ORTHO OT RECOVERY ROOM	ELECTRONIC COT NOT WORKING	Vignesh. D.	CHECKED AND FOUND THE WHEEL ADJUSTMENT PROBLEM SERVICED DONE NOW WORKING GOOD.	AssetNo :16000334	Sadham Husain. S. - Cardiothoracic ICU	16/09/2022
Comp. Dt. : 22/09/2022 Status : Completed								
139	22090894	CT-ICU ROOM-NEAR ORTHO OT RECOVERY ROOM	MULTIPARA MONITOR NOT WORKING	Vignesh. D.	replaced new spo2 probe now working good	AssetNo :16000820	Aswani. J. - Cardiothoracic ICU	22/09/2022
Comp. Dt. : 05/10/2022 Status : Completed								
140	22100050	CT-ICU ROOM-NEAR ORTHO OT RECOVERY ROOM	VENTILATOR NOT WORKING	Vignesh. D.	gas connection issue it's rectified now working good		Sadham Husain. S. - Cardiothoracic ICU	05/10/2022
Comp. Dt. : 24/11/2022 Status : Completed								
141	22111074	CT-ICU ROOM-NEAR ORTHO OT RECOVERY ROOM	WARMER NOT WORKING	Vignesh. D.	warmer on/off switch problem temporary serviced now working good	AssetNo :16000520	Aswani. J. - Cardiothoracic ICU	29/11/2022
Comp. Dt. : 03/12/2022 Status : Completed								
142	22120113	CT-ICU ROOM-NEAR ORTHO OT RECOVERY ROOM	MULTIPARA MONITOR BATTERY NOT WORKING	Vignesh. D.	checked and found the battery charging issue it's replaced now working		Aswani. J. - Cardiothoracic ICU	27/12/2022
Comp. Dt. : 27/12/2022 Status : Completed								
143	22121194	CT-ICU ROOM-NEAR ORTHO OT RECOVERY ROOM	X-RAY MACHINE NOT WORKING	Vignesh. D.	checked and found that wire connection problem.the problem is rectified.	AssetNo :16000698	Sangeetha. M. - Cardiothoracic ICU	02/01/2023
Comp. Dt. : 18/01/2023 Status : Completed								
144	23010634	CT-ICU ROOM-NEAR ORTHO OT RECOVERY ROOM	NEED TO CHECK BATTERY CAPACITY FOR VENTILATOR	Vignesh. D.	checked and found that charging issue.rectified the complaint.now its working good.		Isaivani. R. - Cardiothoracic ICU	19/01/2023
Comp. Dt. : 06/03/2023 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
145	23030212	CT-ICU ROOM-NEAR ORTHO OT RECOVERY ROOM	X RAY MACHINE NOT WORKING	Gurumoorthy. G.	checked and found that power connection problem.the problem is rectified		Gunasegar. K. - Cardiothoracic ICU	08/03/2023
Comp. Dt. : 27/03/2023 Status : Completed								
146	23031128	CT-ICU ROOM-NEAR ORTHO OT RECOVERY ROOM	WARMER NOT WORKING	Vignesh. D.	serviced now working		Sadham Husain. S. - Cardiothoracic ICU	30/03/2023
Comp. Dt. : 08/05/2023 Status : Completed								
147	23050282	CTVS INSIDE ORTHO OT	DEFIBRILLATOR NOT WORKING	Vignesh. D.	checked and found that ecg cable issue.the problem is rectified.		Sadham Husain. S. - Cardiothoracic ICU	10/05/2023
Comp. Dt. : 22/06/2023 Status : Completed								
148	23060832	CT-ICU ROOM-NEAR ORTHO OT RECOVERY ROOM	POWERCARD [3NOS] NOT WORKING	Gurumoorthy. G.	replaced the power cord-3nos.		Sadham Husain. S. - Cardiothoracic ICU	22/06/2023
Dept Name : Cardiothoracic POW - Biomedical Comp. Dt. : 11/06/2022 Status : Completed								
149	22060407	CT-POST OPERATIVE WARD IN 4TH FLOOR	DISPLAY PROBLEM IN MONITOR	Vignesh. D.	checked and found that monitor hang problem,reboot the monitor now working good.	AssetNo :16000018	Praveena. M. - Cardiothoracic POW	14/06/2022
Comp. Dt. : 29/11/2022 Status : Completed								
150	22111214	CT POW -SPECIAL WARD B	CARDIAC MONITOR PROBE NOT WORKING	Sridhar. K.	PROBE REPLACED WORKING	AssetNo :16000020	Praveena. M. - Cardiothoracic POW	01/12/2022
151	22111215	CT POW -SPECIAL WARD B	BP CUFF - ECG CABLE NOT WORKING	Sridhar. K.	NIBP CUFF WITH HOSE REPLACED NOW WORKING GOOD		Praveena. M. - Cardiothoracic POW	01/12/2022
Comp. Dt. : 08/02/2023 Status : Completed								
152	23020288	CTVS	SPO2 PROBE NOT WORKING IN CTVS POW	Gurumoorthy. G.	spo2 connection problem.the problem is rectified		Praveena. M. - Cardiothoracic POW	08/02/2023
Dept Name : Cardiothoracic Surgery - Biomedical Comp. Dt. : 07/06/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
153	22060261	CTVS-ROOM NO.225 -2ND FLOOR	NEED TO REFILL IABP HELIUM CYLINDER	Vignesh. D.	checked and found problem in helium cylinder level below 30 percent.refilled the helium.	AssetNo :16000872	Mohammed Altaf. M. - Cardiothoracic Surgery	31/10/2022
Comp. Dt. : 26/05/2023 Status : Completed								
154	23051069	ORTHO OT	STEP DOWN STABILIZER NOT WORKING	Sridhar. K.	check the stabilizer now working	AssetNo :16000867	Vishakha. M. - Cardiothoracic Surgery	29/05/2023
Dept Name : CLINICAL PATHOLOGY - Biomedical Comp. Dt. : 19/05/2022 Status : Completed								
155	22050707	Clinical Pathology	CENTRIFUGE NOT WORKING	Gurumoorthy. G.	checked and found that carbon brush problem,replaced new caebon brush now working good.		Vinod Gnana Kumar. D. - CLINICAL PATHOLOGY	20/05/2022
Comp. Dt. : 23/05/2022 Status : Completed								
156	22050842	Clinical Pathology	CENTRIFUGE NOT WORKING	Vignesh. D.	checked and found problem in carbon bush damaged so it replaced with the new one problem rectified.		Velvizhi. R. - CLINICAL PATHOLOGY	24/05/2022
Comp. Dt. : 24/05/2022 Status : Completed								
157	22050871	Clinical Pathology	CENTRIFUGE NOT WORKING	Sridhar. K.	checked and found that cable loose connection.the problem is rectified.now its working good.		Vinod Gnana Kumar. D. - CLINICAL PATHOLOGY	25/05/2022
Comp. Dt. : 15/06/2022 Status : Completed								
158	22060571	Clinical Pathology	CENTRIFUGE NOT WORKING	Sridhar. K.	checked and found that carbon brush problem,replaced new carbon brush now working good.		Valli. G. - CLINICAL PATHOLOGY	15/06/2022
Comp. Dt. : 06/07/2022 Status : Completed								
159	22070186	Clinical Pathology	CENTRIFUGE NOT WORKING	Sridhar. K.	carban brush replace its now working		Vinod Gnana Kumar. D. - CLINICAL PATHOLOGY	07/07/2022

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHAL KUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 08/08/2022 Status : Completed								
160	22080252	Clinical Pathology	CENTRIFUGE NOT WORKING	Gurumoorthy. G.	replace the carbon brush its now working		Vinod Gnana Kumar. D. - CLINICAL PATHOLOGY	09/08/2022
Comp. Dt. : 01/09/2022 Status : Completed								
161	22090001	Clinical Pathology	CENTRIFUGE NOT WORKING	Sridhar. K.	replace carbon brush working		Vinod Gnana Kumar. D. - CLINICAL PATHOLOGY	02/09/2022
Comp. Dt. : 14/12/2022 Status : Completed								
162	22120651	Clinical Pathology	CENTRIFUGE NOT WORKING	Sridhar. K.	replaced the carbon brush		Vinod Gnana Kumar. D. - CLINICAL PATHOLOGY	15/12/2022
Comp. Dt. : 29/12/2022 Status : Completed								
163	22121309	Clinical Pathology	CENTRIFUGE NOT WORKING	Sridhar. K.	carbon brush replaced		Vinod Gnana Kumar. D. - CLINICAL PATHOLOGY	02/01/2023
Comp. Dt. : 30/12/2022 Status : Completed								
164	22121379	Pathology Lab	CENTRIFUGE NOT WORKING	Sridhar. K.	power cord loos its working		Vinod Gnana Kumar. D. - CLINICAL PATHOLOGY	31/12/2022
Comp. Dt. : 09/01/2023 Status : Completed								
165	23010362	Pathology Lab	CENTRIFUGE NOT WORKING	Sridhar. K.	carbon brush changed now working good		Vinothini. R. - CLINICAL PATHOLOGY	09/01/2023
Comp. Dt. : 23/01/2023 Status : Completed								
166	23010802	Clinical Pathology	CENTRIFUGE NOT WORKING	Vignesh. D.	replaced the carbon brush		Arulvizhi. K. - CLINICAL PATHOLOGY	23/01/2023
Comp. Dt. : 04/02/2023 Status : Completed								
167	23020146	Clinical Pathology	CENTRIFUGE NOT WORKING	Sridhar. K.	replaced the carbon brush		Vinod Gnana Kumar. D. - CLINICAL PATHOLOGY	06/02/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 07/02/2023 Status : Completed								
168	23020220	Clinical Pathology	CENTRIFUGE NOT WORKING	Gurumoorthy. G.	replaced the carbon brush		Vinod Gnana Kumar. D. - CLINICAL PATHOLOGY	07/02/2023
Comp. Dt. : 15/02/2023 Status : Completed								
169	23020607	Clinical Pathology	CENTRIFUGE NOT WORKING	Sridhar. K.	replaced the carbon brush		Vinod Gnana Kumar. D. - CLINICAL PATHOLOGY	17/02/2023
Comp. Dt. : 27/02/2023 Status : Completed								
170	23021001	Clinical Pathology	CENTRIFUGE NOT WORKING	Gurumoorthy. G.	replaced the carbon brush		Vinod Gnana Kumar. D. - CLINICAL PATHOLOGY	27/02/2023
Comp. Dt. : 29/04/2023 Status : Completed								
171	23040987	Clinical Pathology	CENTRIFUGE NOT WORKING	Sridhar. K.	replaced the carbon brush		Vinod Gnana Kumar. D. - CLINICAL PATHOLOGY	02/05/2023
Comp. Dt. : 03/05/2023 Status : Completed								
172	23050080	Clinical Pathology	CENTRIFUGE NOT WORKING	Gurumoorthy. G.	replaced the carbon brush		Vinod Gnana Kumar. D. - CLINICAL PATHOLOGY	05/05/2023
Comp. Dt. : 04/05/2023 Status : Completed								
173	23050144	Clinical Pathology	MICROSCOPE NOT WORKING	Gurumoorthy. G.	replaced the lamp		Vinod Gnana Kumar. D. - CLINICAL PATHOLOGY	05/05/2023
Comp. Dt. : 19/05/2023 Status : Completed								
174	23050778	Clinical Pathology	CENTRIFUGE NOT WORKING	Gurumoorthy. G.	replaced the carbon brush		Reena. K. - CLINICAL PATHOLOGY	19/05/2023
Comp. Dt. : 22/05/2023 Status : Completed								
175	23050884	Clinical Pathology	CENTRIFUGE NOT WORKING	Gurumoorthy. G.	replaced the carbon brush		Velvizhi. R. - CLINICAL PATHOLOGY	23/05/2023
Comp. Dt. : 24/05/2023 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
176	23050946	Clinical Pathology	CENTRIFUGE NOT WORKING	Sridhar. K.	carbon brush replaced working		Malathi. M. - CLINICAL PATHOLOGY	24/05/2023
Comp. Dt. : 06/06/2023 Status : Completed								
177	23060187	Clinical Pathology	CENTRIFUGE NOT WORKING	Gurumoorthy. G.	replaced the carbon brush		Malathi. M. - CLINICAL PATHOLOGY	06/06/2023
Comp. Dt. : 08/06/2023 Status : Completed								
178	23060259	Clinical Pathology	CENTRIFUGE NOT WORKING	Sridhar. K.	need for company service		Vinod Gnana Kumar. D. - CLINICAL PATHOLOGY	16/06/2023
Comp. Dt. : 12/06/2023 Status : Completed								
179	23060375	Clinical Pathology	CENTRIFUGE NOT WORKING	Sridhar. K.	carbon brush replaced		Vinod Gnana Kumar. D. - CLINICAL PATHOLOGY	12/06/2023
Comp. Dt. : 20/06/2023 Status : Completed								
180	23060689	Clinical Pathology	CENTRIFUGE NOT WORKING	Sridhar. K.	carbanbush replaced working		Vinod Gnana Kumar. D. - CLINICAL PATHOLOGY	21/06/2023
Dept Name : COVID Control Room - Biomedical Comp. Dt. : 09/05/2022 Status : Completed								
181	22050301	Casualty	DEFIBRILLATOR NOT WORKING	Vignesh. D.	checked and found the ecg cable issue.it's replaced now unit working good.	AssetNo :16000832	Kanimozhi. E. - EMERGENCY MEDICINE	09/05/2022
Comp. Dt. : 14/05/2022 Status : Completed								
182	22050501	Casualty	ECG MACHINE NOT WORKING	Vignesh. D.	checked and found problem in ecg cable so remove and checked with stimulator working good condition		Kanimozhi. E. - EMERGENCY MEDICINE	14/05/2022
Comp. Dt. : 16/05/2022 Status : Completed								
183	22050535	Casualty	BP APPARATUS NOT WORKING	Gurumoorthy. G.	replaced the bulb with valve		Kanimozhi. E. - EMERGENCY MEDICINE	16/05/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 30/05/2022 Status : Completed								
184	22051099	Casualty	ECG MACHINE NOT WORKING	Vignesh. D.	checked and found that cable problem, cable serviced and replaced problem rectified now working good.	AssetNo :16000863	Kanimozhi. E. - EMERGENCY MEDICINE	01/06/2022
Dept Name : COVID Ward - Biomedical Comp. Dt. : 12/05/2022 Status : Completed								
185	22050426	Female Ortho - Ward 401	THERMOMETR WALL CLOCK NOT WORKING	Gurumoorthy. G.	checked and found that board internal problem,need to condemed		Girija. G. - Female Ortho Ward	12/05/2022
Comp. Dt. : 13/05/2022 Status : Completed								
186	22050484	Female Ortho - Ward 401	NIBP CUFF NOT WORKING	Gurumoorthy. G.	checked and found that airleakage problem,replaced new cuff.now working good.		Girija. G. - Female Ortho Ward	18/05/2022
Comp. Dt. : 23/05/2022 Status : Completed								
187	22050828	Female Ortho - Ward 401	BP APPARATUS NOT WORKING	Gurumoorthy. G.	checked and found problem in dial and bulb with value defective so it replaced with the new one prob		Girija. G. - Female Ortho Ward	23/05/2022
Comp. Dt. : 24/05/2022 Status : Completed								
188	22050851	Female Ortho - Ward 401	MULPARA MONITOR NOT WORKING	Sridhar. K.	checked and found problem in power cord loose contact so remove and refix it problem rectified		Girija. G. - Female Ortho Ward	25/05/2022
Comp. Dt. : 10/06/2022 Status : Completed								
189	22060374	Female Ortho - Ward 401	NEBULIZER NOT WORKING	Vignesh. D.	CHECKED AND DONE THE GENERAL SERVICE NOW WORKING GOOD		Girija. G. - Female Ortho Ward	11/06/2022
Comp. Dt. : 30/06/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
190	22061096	Female Ortho Ward	MULTIPARA MONITOR NOT WORKING - WARD NO 401 & 402	Sridhar. K.	REPLACE POWER CORD ITS NOW WORKING	AssetNo :16000016	Girija. G. - Female Ortho Ward	01/07/2022
Comp. Dt. : 01/07/2022 Status : Completed								
191	22070011	Female Ortho - Ward 401	BP APPARATUS NOT WORKING	Gurumoorthy. G.	replaced the bladder		Girija. G. - Female Ortho Ward	01/07/2022
Comp. Dt. : 05/07/2022 Status : Completed								
192	22070174	Female Ortho - Ward 402	BP APPARATUS NOT WORKING	Gurumoorthy. G.	checked and replaced the bulb now working good		Girija. G. - Female Ortho Ward	06/07/2022
Comp. Dt. : 07/07/2022 Status : Completed								
193	22070246	Male Medical - Ward 301	ECG MACHINE NOT WORKING	Sridhar. K.	ecg cable standby replace its now working	AssetNo :16000288	Karthika. S. - Female Surgery	15/07/2022
Comp. Dt. : 18/07/2022 Status : Completed								
194	22070657	ENT WARD-407	SUCTION APPARATUS NOT WORKING	Gurumoorthy. G.	checked and found that oil and hose connection problem.the problem is rectfied		Jayalakshmi. J. - ENT & Ophthal Ward	18/07/2022
Dept Name : CSSD - Biomedical Comp. Dt. : 06/05/2022 Status : Completed								
195	22050216	CSSD	NEED TO CHECK HORIZONTAL AUTOCLAVE BOILER WATER LEAKAGE & E T O STERILLIZER AIR LEAKAGE	Gurumoorthy. G.	chedked and found that wiring problem,problem rectified,in eto machine tube problem,problem rectifie		Pazhanivel.S. - CSSD	07/05/2022
Comp. Dt. : 14/06/2022 Status : Completed								
196	22060510	CSSD	HORIZONTAL AUTOCLAVE MACHINE NOT WORKING	Vignesh. D.	checked and found that coil issue,replaced new coil and cleaned the tank.	AssetNo :16000131	Pazhanivel.S. - CSSD	15/06/2022
Comp. Dt. : 11/07/2022 Status : Completed								
197	22070402	CSSD	NEED TO CHECK AUTOCLAVE MACHINE DOOR - NOT CLOSING PROPERLY	Gurumoorthy. G.	checked and found that door arm damaged.replaced the new door arm	AssetNo :16000140	Pazhanivel.S. - CSSD	10/08/2022
Comp. Dt. : 26/07/2022								


Dr. KAGNE R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
198	22070941	CSSD	HORIZONTAL AUTOCLAVE NOT WORKING	Gurumoorthy. G.	wiring problem it's rectified now it's working good		Pazhanivel.S. - CSSD	26/07/2022
Comp. Dt. : 01/08/2022								
Status : Completed								
199	22080023	CSSD	AUTOCLAVE MACHINE NOT WORKING	Gurumoorthy. G.	checked and found that coil defective.replaced the coil	AssetNo :16000131	Pazhanivel.S. - CSSD	04/08/2022
Comp. Dt. : 18/08/2022								
Status : Completed								
200	22080595	CSSD	AUTOCLAVE MACHINE GASCUT LEAKAGING PROBLEM	Gurumoorthy. G.	checked and found that gasket air leakage.replaced the gascut washer.now its working good.	AssetNo :16000130	Vinnarasi. R - CSSD	10/09/2022
Comp. Dt. : 13/09/2022								
Status : Completed								
201	22090500	CSSD	AUTOCLAVE MACHINE NOT WORKING	Vignesh. D.	CHECKED AND FOUND THE COIL ISSUE. REPLACED THE NEW COIL NOW IT'S WORKING GOOD.(3NOS)		Vinnarasi. R - CSSD	14/09/2022
Comp. Dt. : 05/10/2022								
Status : Completed								
202	22100056	CSSD	E T O MACHINE NOT WORKING	Gurumoorthy. G.	checked and found hose connection problem.the problem is rectified		Pazhanivel.S. - CSSD	12/10/2022
Comp. Dt. : 11/11/2022								
Status : Completed								
203	22110454	CSSD	AUTOCLAVE MACHINE NOT WORKING	Sridhar. K.	heating coil replaced	AssetNo :16000131	Pazhanivel.S. - CSSD	15/11/2022
Comp. Dt. : 21/11/2022								
Status : Completed								
204	22110844	CSSD	HORIZONTAL AUTOCLAVE NOT WORKING	Sridhar. K.	heating coil replaced	AssetNo :16000130	Vinnarasi. R - CSSD	22/11/2022
Comp. Dt. : 23/11/2022								
Status : Completed								
205	22110979	CSSD	ETO MACHINE HOSE NEED TO BE CHANGE	Sridhar. K.	hose replaced	AssetNo :16000312	Pazhanivel.S. - CSSD	23/11/2022
206	22110980	CSSD	AUTOCLAVE MACHINE SILICON RUBBER SHEET NEED TO BE CHANGE	Sridhar. K.	replaced silicon sheet its now woking	AssetNo :16000975	Pazhanivel.S. - CSSD	23/11/2022

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 24/11/2022 Status : Completed								
207	22111075	CSSD	HORIZONTAL AUTOCLAVE MACHINE DOOR NOT OPENING	Vignesh. D.	DOOR ISSUE SERVICED NOW WORKING GOOD		Pazhanivel.S. - CSSD	26/11/2022
Comp. Dt. : 05/01/2023 Status : Completed								
208	23010211	CSSD	HORIZONTAL AUTOCLAVE MACHINE NOT WORKING	Gurumoorthy. G.	coil replaced now working		Vinnarasi. R - CSSD	05/01/2023
Comp. Dt. : 06/01/2023 Status : Completed								
209	23010259	CSSD	AUTOCLAVE MACHINE HORIZONTAL NOT WORKING	Gurumoorthy. G.	coil replaced now working		Pazhanivel.S. - CSSD	06/01/2023
Comp. Dt. : 11/01/2023 Status : Completed								
210	23010458	CSSD	AUTOCLAVE MACHINE NOT WORKING	Gurumoorthy. G.	coil replaced now working good		Vinnarasi. R - CSSD	11/01/2023
Comp. Dt. : 24/02/2023 Status : Completed								
211	23020947	CSSD	VASCULAR LEAKAGE IN AUTOCLAVE MACHINE BOILER	Gurumoorthy. G.	checked and found that steam bolts loose connection.the problem is rectified.		Pazhanivel.S. - CSSD	27/02/2023
Comp. Dt. : 20/03/2023 Status : Completed								
212	23030762	CSSD	AUTOCLAVE MACHINE NOT WORKING - NEED URGENT SERVICE	Gurumoorthy. G.	replaced the contactor		Pazhanivel.S. - CSSD	24/03/2023
Comp. Dt. : 22/03/2023 Status : Completed								
213	23030891	CSSD	AUTOCLAVE MACHINE NOT WORKING	Gurumoorthy. G.	checked and found that contactor issue.replaced the contactor.		Vinnarasi. R - CSSD	25/03/2023
Comp. Dt. : 12/05/2023 Status : Completed								
214	23050472	CSSD	AUTOCLAVE MACHINE NOT WORKING	Gurumoorthy. G.	checked and found that coil wire connections problem.the problem is rectified.		Vinnarasi. R - CSSD	12/05/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 16/05/2023 Status : Completed								
215	23050636	CSSD	AUTOGLAVE MACHINE NOT WORKING	Sridhar. K.	replaced the coil.		Rajakumari. M. - CSSD	17/05/2023
Comp. Dt. : 26/05/2023 Status : Completed								
216	23051036	CSSD	NEED TO CHANGE AUTOCLAVE MACHINE CABLE - DAMAGE & NOT WORKING	Sridhar. K.	coil cable isseu serviced autoclave working	AssetNo :16000131	Pazhanivel.S. - CSSD	26/05/2023
Comp. Dt. : 05/06/2023 Status : Completed								
217	23060131	CSSD	AIR LEAKAGE AT ETO GAS STERILIZER	Sridhar. K.	replaced tube now working		Pazhanivel.S. - CSSD	05/06/2023
Dept Name : Derm,Pulmo,Psych Ward - Biomedical Comp. Dt. : 12/05/2022 Status : Completed								
218	22050439	PSYCHIATRY WARD	PULSE OXIMETER PROBE NOT WORKING	Vignesh. D.	checked and found that spo2 probe fault,replaced new probe,now working good	AssetNo :16000731	Sarathkumar. R. - Derm,Pulmo,Psych Ward	12/05/2022
Comp. Dt. : 20/05/2022 Status : Completed								
219	22050744	TB AND CHEST WARD-405	BP APPARATUS NOT WORKING	Gurumoorthy. G.	checked and found that dial problem,needle adjusted now working good.		Sarathkumar. R. - Derm,Pulmo,Psych Ward	20/05/2022
Comp. Dt. : 04/06/2022 Status : Completed								
220	22060156	Male Ortho - Ward 403	BP APPARATUS NEEDLE DAMAGE - NAT WORKING	Vignesh. D.	checked and found problem in pressure guage needle broken so it remove and replace it problem rectif		Manjula. P. - Male Ortho Ward	04/06/2022
Comp. Dt. : 06/06/2022 Status : Completed								
221	22060207	PSYCHIATRY WARD	OT TABLE NOT WORKING IN ECG ROOM WARD NO 405	Sridhar. K.	checked and found problem in oil washer defective so it remove and refix it problem rectified.		Sarathkumar. R. - Derm,Pulmo,Psych Ward	06/06/2022
Comp. Dt. : 10/06/2022								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
222	22060391	PSYCHIATRY WARD	BP APPARATUS NOT WORKING	Vignesh. D.	BULB CHANGED NOW WORKING GOOD		Sarathkumar. R. - Derm,Pulmo,Psych Ward	11/06/2022
Comp. Dt. : 22/06/2022								
Status : Completed								
223	22060779	TB AND CHEST WARD-405	BP APPARATUS NOT WORKING	Vignesh. D.	CHECKED AND FOUND THE DIAL ISSUE IT CHANGED NOW WORKING GOOD		Sarathkumar. R. - Derm,Pulmo,Psych Ward	22/06/2022
Comp. Dt. : 03/08/2022								
Status : Completed								
224	22080133	PSYCHIATRY WARD	puls oximoniter not working	Sridhar. K.	spo2 cable connector loos problem rectified its working	AssetNo :16000731	Kavitha. S. - Derm,Pulmo,Psych Ward	04/08/2022
Comp. Dt. : 08/08/2022								
Status : Completed								
225	22080255	PSYCHIATRY WARD	SPO2 MONITOR NOT WORKING	Sridhar. K.	AC DC MODULE cable loose connection rectified now its working good		Sarathkumar. R. - Derm,Pulmo,Psych Ward	11/08/2022
Comp. Dt. : 10/08/2022								
Status : Completed								
226	22080370	PSYCHIATRY WARD	STETHOSCOPE NOT WORKING	Gurumoorthy. G.	CHESTPIECE AND EAR TUBE REPLACED AND NOW ITS WORKING GOOD		Sarathkumar. R. - Derm,Pulmo,Psych Ward	10/08/2022
Comp. Dt. : 18/08/2022								
Status : Completed								
227	22080563	PSYCHIATRY WARD	MULTIPARA MONITOR BP CUFF NOT WORKING	Gurumoorthy. G.	checked and found that nibp connector is missing.replaced the new nibp connector		Sarathkumar. R. - Derm,Pulmo,Psych Ward	18/08/2022
Comp. Dt. : 30/08/2022								
Status : Completed								
228	22081006	Female Psychiatry - Ward 406	PULSE OXI MONITOR NOT WORKING	Sridhar. K.	checked and found the issue it's rectified now working good		Kavitha. S. - Derm,Pulmo,Psych Ward	01/09/2022
Comp. Dt. : 08/09/2022								
Status : Completed								
229	22090314	PSYCHIATRY WARD	BP APPARATUS NOT WORKING	Vignesh. D.	bulb changed now it's working good		Sarathkumar. R. - Derm,Pulmo,Psych Ward	08/09/2022

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHAKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 19/09/2022 Status : Completed								
230	22090703	PSYCHIATRY WARD	BP APPARATUS NOT WORKING	Vignesh. D.	replaced the bulb with valve		Sarathkumar. R. - Derm,Pulmo,Psych Ward	24/09/2022
Comp. Dt. : 21/09/2022 Status : Completed								
231	22090833	PSYCHIATRY WARD	STETHOSCOPE NOT WORKING	Gurumoorthy. G.	replaced the ear piece		Sarathkumar. R. - Derm,Pulmo,Psych Ward	24/09/2022
Comp. Dt. : 26/09/2022 Status : Completed								
232	22091020	PSYCHIATRY WARD	LARYNGOSCOPY BLADE LIGHT NOT WORKING	Vignesh. D.	replaced the lamp		Sarathkumar. R. - Derm,Pulmo,Psych Ward	26/09/2022
Comp. Dt. : 07/10/2022 Status : Completed								
233	22100143	PSYCHIATRY WARD	BP APPARATUS 2NOS NOT WORKING	Vignesh. D.	replaced the bulb with valve		Sarathkumar. R. - Derm,Pulmo,Psych Ward	10/10/2022
Comp. Dt. : 10/10/2022 Status : Completed								
234	22100215	PSYCHIATRY WARD	BP APPARATUS [2 NOS] NOT WORKING	Gurumoorthy. G.	replaced the bulb with valve		Sarathkumar. R. - Derm,Pulmo,Psych Ward	10/10/2022
Comp. Dt. : 03/11/2022 Status : Completed								
235	22110056	Male Psychiatry - Ward 405	2 NO'S BP APPARATUS NOT WORKING	Vignesh. D.	replaced the bladder and bulb with valve		Sarathkumar. R. - Derm,Pulmo,Psych Ward	03/11/2022
236	22110107	PSYCHIATRY WARD	BP APPARATUS NOT WORKING	Gurumoorthy. G.	replaced the dial		Sarathkumar. R. - Derm,Pulmo,Psych Ward	03/11/2022
Comp. Dt. : 08/11/2022 Status : Completed								
237	22110307	PSYCHIATRY WARD	LARYNSEOPY ONE BLADE NOT WORKING	Sridhar. K.	genral services working		Sarathkumar. R. - Derm,Pulmo,Psych Ward	09/11/2022
Comp. Dt. : 01/12/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
238	22120046	Male Psychiatry - Ward 405	LARYNGOSCOPE BLADE LIGHT NOT WORKING	Sridhar. K.	serviced its now working		Sarathkumar. R. - Derm,Pulmo,Psych Ward	02/12/2022
Comp. Dt. : 07/12/2022 Status : Completed								
239	22120298	PSYCHIATRY WARD	PULSE OXIMETER NOT WORKING	Vignesh. D.	CHECKED AND FOUND THE SPO2 PROBE ISSUE IT'S REPLACED NOW WORKING GOOD(CR18PB9386)		Sarathkumar. R. - Derm,Pulmo,Psych Ward	07/12/2022
Comp. Dt. : 14/12/2022 Status : Completed								
240	22120634	PSYCHIATRY WARD	BP APPARATUS NOT WORKING	Gurumoorthy. G.	Replaced the bulb with valve		Sarathkumar. R. - Derm,Pulmo,Psych Ward	14/12/2022
241	22120659	PSYCHIATRY WARD	THERMOMETER BROKEN	Gurumoorthy. G.	REPLACED THE BATTERY		Sarathkumar. R. - Derm,Pulmo,Psych Ward	15/12/2022
Comp. Dt. : 23/12/2022 Status : Completed								
242	22121043	Male Psychiatry - Ward 405	BP APPARATUS NOT WORKING	Sridhar. K.	serviced now working		Sarathkumar. R. - Derm,Pulmo,Psych Ward	24/12/2022
Comp. Dt. : 02/01/2023 Status : Completed								
243	23010027	TB AND CHEST WARD-405	MULTIPARA MONITOR BP CUFF NOT WORKING	Sridhar. K.	cuff replaced working		Sarathkumar. R. - Derm,Pulmo,Psych Ward	03/01/2023
Comp. Dt. : 04/01/2023 Status : Completed								
244	23010131	Male Psychiatry - Ward 405	MULTIPARA MONITOR SP O2 PROBE PROBLEM	Sridhar. K.	spo2 probe replaced now working good	AssetNo :16000789	Sarathkumar. R. - Derm,Pulmo,Psych Ward	04/01/2023
Comp. Dt. : 30/01/2023 Status : Completed								
245	23011062	TB AND CHEST WARD-405	BP APPARATUS NOT WORKING	Sridhar. K.	REPLACED DAIL WORKING		Bharathi. A - Derm,Pulmo,Psych Ward	30/01/2023
Comp. Dt. : 10/02/2023 Status : Completed								
246	23020375	PSYCHIATRY WARD	NEBULIZER NOT WORKING	Sridhar. K.	motor wire connection problem.the problem is rectified		Sarathkumar. R. - Derm,Pulmo,Psych Ward	10/02/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 18/03/2023 Status : Completed								
247	23030733	Male Psychiatry - Ward 405	B P APPARATUS NOT WORKING	Vignesh. D.	bulb replaced		Sarathkumar. R. - Derm,Pulmo,Psych Ward	21/03/2023
Comp. Dt. : 22/03/2023 Status : Completed								
248	23030932	Male Psychiatry - Ward 405	BP APPARATUS NOT WORKING	Vignesh. D.	replaced the bulb with valve		Sarathkumar. R. - Derm,Pulmo,Psych Ward	25/03/2023
Comp. Dt. : 06/04/2023 Status : Completed								
249	23040192	Male Psychiatry - Ward 405	STETHOSCOPE NOT WORKING	Gurumoorthy. G.	service now working		Sarathkumar. R. - Derm,Pulmo,Psych Ward	08/04/2023
Comp. Dt. : 31/05/2023 Status : Completed								
250	23051220	Male Psychiatry - Ward 405	PULSE OXI METER NOT WORKING	Sridhar. K.	power charger issue.problem is rectified.		Sarathkumar. R. - Derm,Pulmo,Psych Ward	31/05/2023
Dept Name : Dermatology & Vener. - Biomedical Comp. Dt. : 24/05/2022 Status : Completed								
251	22050868	DERMATOLOGY OPD	OT PROCEDURE LIGHT NOT WORKING AT MINOR OT	Sridhar. K.	CHECKED AND FOUND PROBLEM IN LAMP FUSED SO IT REPLACED WITH THE NEW ONE PROBLEM RECTIFIED.		Jayachandran. M. - Dermatology & Vener.	24/05/2022
252	22050869	DERMATOLOGY OPD	OT PROCEDURE LIGHT NOT WORKING AT MINOR OT	Sridhar. K.	replaced the lamp		Jayachandran. M. - Dermatology & Vener.	25/05/2022
Comp. Dt. : 03/06/2022 Status : Completed								
253	22060132	DERMATOLOGY OPD	PROBLEM IN RADIO FREQUENCY CABLE	Sridhar. K.	checked and found problem in radio frequency cable disconnected so it remove and solder it properly		Jayachandran. M. - Dermatology & Vener.	03/06/2022
Comp. Dt. : 28/09/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
254	22091134	DERMATOLOGY OPD	MINOR OT LIGHT NOT WORKING -NEED TO CHANGE - ROOM NO 72	Gurumoorthy. G.	replaced the lamp		Jayachandran. M. - Dermatology & Vener.	28/09/2022
Comp. Dt. : 07/10/2022 Status : Completed								
255	22100146	DERMATOLOGY	CENTRIFUGE NOT WORKING IN PUVATHERAPHY ROOM	Sridhar. K.	carbon brush replaced now working good		Jayachandran. M. - Dermatology & Vener.	12/10/2022
Comp. Dt. : 17/12/2022 Status : Completed								
256	22120819	DERMATOLOGY OPD	MICROSCOPE NOT WORKING	Sridhar. K.	serviced now its working		Jayachandran. M. - Dermatology & Vener.	19/12/2022
Comp. Dt. : 02/03/2023 Status : Completed								
257	23030112	DERMATOLOGY OPD	DERMA MACHINE NOT WORKING	Sridhar. K.	checked the motor now working good		Jayachandran. M. - Dermatology & Vener.	04/03/2023
Comp. Dt. : 24/03/2023 Status : Completed								
258	23031023	DERMATOLOGY OPD	NEED TO CHECK MICRO DEM OPERATIVE MACHINE TUBE - DAMAGE & CUT	Sridhar. K.	checked and found that tubing problem.the problem is rectified.		Jayachandran. M. - Dermatology & Vener.	25/03/2023
Comp. Dt. : 30/06/2023 Status : Completed								
259	23061122	DERMATOLOGY OPD	OT LIGHT NOT WORKING AT MINOR OT	Gurumoorthy. G.	REPLACED THE LAMP		Jayachandran. M. - Dermatology & Vener.	01/07/2023
Dept Name : Dialysis - Biomedical Comp. Dt. : 12/05/2022 Status : Completed								
260	22050417	DIALYSIS NEW UNIT IN 1ST FLOOR	NEED TO CHANGE BP CUF BULB	Vignesh. D.	checked and found that bladder issue,replaced new bladder.now working good.		Sumathira. C - Dialysis	12/05/2022
Comp. Dt. : 23/05/2022 Status : Completed								
261	22050814	DIALYSIS NEW UNIT IN 1ST FLOOR	BP APPARATUS NOT WORKING	Gurumoorthy. G.	CHECKED AND FOUND BP BLADDER DAMAGED SO IT REPLACE NEW ONE PROBLEM RECTIFIED		Vikneswari. K. - Dialysis	23/05/2022
Comp. Dt. : 06/06/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
262	22060191	DIALYSIS NEW UNIT IN 1ST FLOOR	AIR LOCK IN BP CUFF	Sridhar. K.	checked and found problem in cuff defective so it replaced the new one problem rectified.		Sumathira. C - Dialysis	06/06/2022
Comp. Dt. : 22/06/2022								
Status : Completed								
263	22060804	DIALYSIS NEW UNIT IN 1ST FLOOR	DEFIBRILLATOR PRINTER NOT WORKING	Sridhar. K.	checked the printer found problem printer paper replace	AssetNo :16000825	Malathy. M. - Dialysis	02/07/2022
Comp. Dt. : 23/06/2022								
Status : Completed								
264	22060840	DIALYSIS IN 2ND FLOOR	DISPLAYING - "COMMUNICATION ERROR" IN SPO2 MONITOR	Vignesh. D.	checked and found the motherboard replaced now its working	AssetNo :16000011	Ranjitha. A - Dialysis	25/06/2022
265	22060850	DIALYSIS NEW UNIT IN 1ST FLOOR	NEED TO CHANGE BP APPARATUS - NOT WORKING	Vignesh. D.	checked and change bul now it's working good		Parameswari. S. - Paediatrics Ward	24/06/2022
Comp. Dt. : 06/07/2022								
Status : Completed								
266	22070185	DIALYSIS NEW UNIT IN 1ST FLOOR	BP APPARATUS NOT WORKING	Vignesh. D.	checked and done general service now working good		Sumathira. C - Dialysis	06/07/2022
Comp. Dt. : 11/07/2022								
Status : Completed								
267	22070442	DIALYSIS NEW UNIT IN 1ST FLOOR	BP APPARATUS NOT WORKING	Vignesh. D.	bulb changed now it's working good		Vikneswari. K. - Dialysis	11/07/2022
Comp. Dt. : 12/07/2022								
Status : Completed								
268	22070484	DIALYSIS NEW UNIT IN 1ST FLOOR	SPO2 & ECG CABLE NOT WORKING IN MULTIPARA MONITOR [PHILIPS]	Sridhar. K.	REPLACE SPO2, ECG CABLE ITS WORKING	AssetNo :16000096	Sarathambal. R. - Dialysis	12/07/2022
Comp. Dt. : 22/07/2022								
Status : Completed								
269	22070848	DIALYSIS NEW UNIT IN 1ST FLOOR	BP APPARATUS NOT WORKING	Sridhar. K.	BULB REPL;ACED NOW IT'S WORKING GOOD		Sumathira. C - Dialysis	23/07/2022
Comp. Dt. : 13/08/2022								
Status : Completed								
270	22080471	DIALYSIS NEW UNIT IN 1ST FLOOR	MULTIPARA MONITOR NOT WORKING	Sridhar. K.	key pad replaced	AssetNo :16000096	Sumathira. C - Dialysis	02/01/2023
Comp. Dt. : 19/08/2022								
Status : Completed								

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.


S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
271	22080649	DIALYSIS NEW UNIT IN 1ST FLOOR	BP APPARATUS 1 NO. NOT WORKING	Gurumoorthy. G.	replaced the bulb with valve		Malathy. M. - Dialysis	20/08/2022
	Comp. Dt. : 22/08/2022 Status : Completed							
272	22080712	DIALYSIS NEW UNIT IN 1ST FLOOR	PROBLEM IN N A P P HOSE	Sridhar. K.	nibp cuff and nibp hous replaced	AssetNo :16000094	Sumathira. C - Dialysis	25/08/2022
	Comp. Dt. : 25/08/2022 Status : Completed							
273	22080829	DIALYSIS NEW UNIT IN 1ST FLOOR	NEED TO CHECK PHILIPS MONITOR - PROBLEM IN BP READING	Sridhar. K.	nibp modue issue.replaced the nibp module	AssetNo :16000091	Sarathambal. R. - Dialysis	02/01/2023
	Comp. Dt. : 30/08/2022 Status : Completed							
274	22081030	DIALYSIS IN 2ND FLOOR	THERMO METER NOT WORKING	Vignesh. D.	battery changed now working good		Pragathi. D. - Dialysis	01/09/2022
	Comp. Dt. : 31/10/2022 Status : Completed							
275	22101028	DIALYSIS NEW UNIT IN 1ST FLOOR	BP APPARATUS BULB NOT WORKING	Sridhar. K.	replace bule its working		Malathy. M. - Dialysis	31/10/2022
276	22101036	DIALYSIS NEW UNIT IN 1ST FLOOR	STETHOSCOPE EAR PIECE LOOSE POSITION	Sridhar. K.	replace its working		Malathy. M. - Dialysis	31/10/2022
	Comp. Dt. : 11/11/2022 Status : Completed							
277	22110459	DIALYSIS IN 2ND FLOOR	1 BP APPARATUS NOT WORKING	Sridhar. K.	bladder replaced		Kalaimani. P. - Dialysis	11/11/2022
	Comp. Dt. : 15/11/2022 Status : Completed							
278	22110569	DIALYSIS IN 2ND FLOOR	FRESINIUS MACHINE NOT WORKING	Sridhar. K.	power supply. other machine spare replace	AssetNo :16000254	Monika. A. - Dialysis	18/11/2022
	Comp. Dt. : 06/12/2022 Status : Completed							
279	22120217	DIALYSIS NEW UNIT IN 1ST FLOOR	NEED TO CHECK BP APPARATUS BULB [2NOS] NOT WORKING	Sridhar. K.	replaced the bulb with valve		Malathy. M. - Dialysis	07/12/2022
	Comp. Dt. : 12/12/2022 Status : Completed							
280	22120554	DIALYSIS NEW UNIT IN 1ST FLOOR	ELECTRICAL WEIGHT MACHINE NOT WORKING	Sridhar. K.	serviced now working		Sarathambal. R. - Dialysis	14/12/2022
	Comp. Dt. : 10/01/2023							


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
281	23010378	DIALYSIS NEW UNIT IN 1ST FLOOR	FRESENIUS MACHINE PUMP GOT STRUCKED	Sridhar. K.	checked and found that wire connection problem.the problem is rectified.		Sarathambal. R. - Dialysis	10/01/2023
Comp. Dt. : 20/03/2023								
Status : Completed								
282	23030765	DIALYSIS NEW UNIT IN 1ST FLOOR	WEIGHT MACHINE NOT WORKING	Gurumoorthy. G.	power connection adapter rust issue.the problem is rectified.		Malathy. M. - Dialysis	24/03/2023
Comp. Dt. : 11/05/2023								
Status : Completed								
283	23050426	DIALYSIS IN 2ND FLOOR	B P APPARATUS NOT WORKING	Sridhar. K.	BADDER REPLACED		Vikneswari. K. - Dialysis	11/05/2023
Comp. Dt. : 22/05/2023								
Status : Completed								
284	23050874	DIALYSIS IN 2ND FLOOR	LARYNGOSCOPE NOT WORKING	Sridhar. K.	serviced now working		Ranjitha. A - Dialysis	23/05/2023
Comp. Dt. : 12/06/2023								
Status : Completed								
285	23060380	DIALYSIS NEW UNIT IN 1ST FLOOR	WEIGHT MACHINE NOT WORKING	Sridhar. K.	need service		Vikneswari. K. - Dialysis	12/06/2023
Comp. Dt. : 23/06/2023								
Status : Completed								
286	23060850	DIALYSIS NEW UNIT IN 1ST FLOOR	B P APPARATUS CUFF NOT WORKING	Sridhar. K.	bulb replaced and serviced working		Arthy. T. - Dialysis	23/06/2023
Comp. Dt. : 27/06/2023								
Status : Completed								
287	23060999	Male Psychiatry - Ward 405	NEBULIZER NOT WORKING	Gokul. P. K.	checked and found that wire short issue.connected the wires.		Sarathambal. R. - Dialysis	28/06/2023
Dept Name : Dressing - Biomedical								
Comp. Dt. : 07/09/2022								
Status : Completed								
288	22090278	CSSD	ETO GASTERMING MACHINE EDITION NOT WORKING	Gurumoorthy. G.	checked and found that software problem.the problem is rectified.		Palanivel. D. - Dressing	10/09/2022
Dept Name : EMERGENCY MEDICINE - Biomedical								
Comp. Dt. : 02/05/2022								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
289	22050019	Casualty	BP APPARATUS [2NOS] NOT WORKING	Gurumoorthy. G.	replaced the bulb with valve		Kazhagamani. V. - EMERGENCY MEDICINE	04/05/2022
Comp. Dt. : 05/05/2022								
Status : Completed								
290	22050151	Casualty	DEFIBRILLATOR NOT WORKING	Vignesh. D.	checked and found that ecg cable issue so it replaced the new one problem rectified		Kazhagamani. V. - EMERGENCY MEDICINE	10/05/2022
Comp. Dt. : 12/05/2022								
Status : Completed								
291	22050405	Casualty	CHANGE ECG CABLE	Vignesh. D.	checked and found that clamp electrode problem, replaced new clamp electrode. now working good.	AssetNo :16000284	Sasirekha. K. - EMERGENCY MEDICINE	12/05/2022
Comp. Dt. : 24/05/2022								
Status : Completed								
292	22050850	Casualty	SPOT LIGHT NOT WORKING - ROOM NO 38	Vignesh. D.	replaced the lamp		Kazhagamani. V. - EMERGENCY MEDICINE	25/05/2022
Comp. Dt. : 25/05/2022								
Status : Completed								
293	22050922	Casualty	LARYNGOSCOPE SET ADULT SIZE NOT WORKING	Sridhar. K.	checked and found problem in laryngoscope handle got battery stuck so it remove and serviced it prob		Kazhagamani. V. - EMERGENCY MEDICINE	25/05/2022
Comp. Dt. : 02/06/2022								
Status : Completed								
294	22060088	Casualty	MULTIPARA MONITOR BP CUFF NOT WORKING	Vignesh. D.	checked and found the bp cuff issue need to replaced new one.		Bhuvaneswari. M. - ENT & Ophthal Ward	04/06/2022
Comp. Dt. : 03/06/2022								
Status : Completed								
295	22060099	Casualty	NEED TO CHECK DEFIBRILLATOR	Vignesh. D.	checked and found problem in defibrillator battery not charging after remove and reconnect it proble	AssetNo :16000832	Bhuvaneswari. M. - ENT & Ophthal Ward	03/06/2022
296	22060121	Casualty	MULTIPARA MONITOR NOT WORKING	Sridhar. K.	checked and found problem in ecg cable so it remove and serviced it problem rectified.		Bhuvaneswari. M. - ENT & Ophthal Ward	03/06/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 04/06/2022 Status : Completed								
297	22060157	Ambulance	SUCTION APPARATUS NOT WORKING	Vignesh. D.	checked and found the power card issue it's replaced now it's working good		Bhuvaneswari. M. - ENT & Ophthal Ward	04/06/2022
Comp. Dt. : 06/06/2022 Status : Completed								
298	22060182	Casualty	LARYNGOSCOPY NOT WORKING	Sridhar. K.	checked and found problem in lamp defective so it replaced with the new one problem rectified.		Bhuvaneswari. M. - ENT & Ophthal Ward	06/06/2022
Comp. Dt. : 20/06/2022 Status : Completed								
299	22060691	Casualty	DEFIBRILLATOR NOT WORKING	Vignesh. D.	CHECKED AND FOUND THE ECG CABLE ISSUE. I'TS REPLACED NOW IT'S WORKING GOOD.	AssetNo :16000832	Kazhagamani. V. - EMERGENCY MEDICINE	20/06/2022
Comp. Dt. : 25/06/2022 Status : Completed								
300	22060932	Casualty	NEED TO CHECK TRANSPORT VENTILATOR	Gurumoorthy. G.	power supply reset now its working		Bhuvaneswari. M. - ENT & Ophthal Ward	25/06/2022
Comp. Dt. : 05/07/2022 Status : Completed								
301	22070168	Casualty	MULTIPARA MONITOR NOT WORKING	Vignesh. D.	checked and found the spo2 probe & ecg cable issue it's replaced now it's working good	AssetNo :16000089	Raja. A. - EMERGENCY MEDICINE	06/07/2022
Comp. Dt. : 18/07/2022 Status : Completed								
302	22070639	Casualty	LARYNGOSCOPE BLADE NOT WORKING	Gurumoorthy. G.	replaced the bulb		Kazhagamani. V. - EMERGENCY MEDICINE	18/07/2022
Comp. Dt. : 19/07/2022 Status : Completed								
303	22070701	Casualty	BP APPARATUS [CLOCK TYPE] NOT WORKING	Gurumoorthy. G.	replaced the bladder		Kazhagamani. V. - EMERGENCY MEDICINE	19/07/2022
Comp. Dt. : 08/08/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
304	22080274	Casualty	ECG MACHINE NOT WORKING	Vignesh. D.	cable changed now working good		Kanimozhi. E. - EMERGENCY MEDICINE	19/08/2022
		Comp. Dt. : 18/08/2022 Status : Completed						
305	22080578	Ambulance	MULTIPARA MONITOR SPO2 PROBE NOT WOKRING	Vignesh. D.	checked and found the front end modul issue it's replaced now working	AssetNo :16000097	Kazhagamani. V. - EMERGENCY MEDICINE	27/12/2022
		Comp. Dt. : 12/09/2022 Status : Completed						
306	22090426	Casualty	DEFIBRILLATOR NOT WORKING	Gurumoorthy. G.	checked and found the software issue it's rectified now working good		Kazhagamani. V. - EMERGENCY MEDICINE	16/09/2022
		Comp. Dt. : 16/09/2022 Status : Completed						
307	22090642	Casualty	BP APPARATUS [CLOCK TYPE] NOT WORKING	Gurumoorthy. G.	replaced the bulb with valve		Kazhagamani. V. - EMERGENCY MEDICINE	17/09/2022
		Comp. Dt. : 22/09/2022 Status : Completed						
308	22090885	Casualty	NEED TO CHECK USG MACHINE - NOT WORKING	Vignesh. D.	checked and delete the old files now working good	AssetNo :16000913	Sasirekha. K. - EMERGENCY MEDICINE	22/09/2022
		Comp. Dt. : 28/09/2022 Status : Completed						
309	22091140	Casualty	ECG MACHINE 2NOS NOT WORKING	Vignesh. D.	checked and found that ecg cable problem.replaced the ecg cable	AssetNo :16000286	Kanimozhi. E. - EMERGENCY MEDICINE	28/09/2022
		Comp. Dt. : 06/10/2022 Status : Completed						
310	22100105	Casualty	SUCTION APPARATUS NOT WORKING	Gurumoorthy. G.	chceked and found that tube connections problem.the problem is rectified.		Kanimozhi. E. - EMERGENCY MEDICINE	06/10/2022
		Comp. Dt. : 10/10/2022 Status : Completed						
311	22100239	Casualty	NEED TO CHECK MONITOR POWER CARD	Vignesh. D.	power card issue replaced now working good		Racida. R. - EMERGENCY MEDICINE	12/10/2022

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 12/10/2022								
Status : Completed								
312	22100337	Casualty	MUTLI PARA MONITOR 3 SENSOR PROBE PROBLEM	Vignesh. D.	checked and found that spo2 probe defective.replaced the new spo2 probe		Rajipriya. K. - EMERGENCY MEDICINE	14/10/2022
Comp. Dt. : 27/10/2022								
Status : Completed								
313	22100856	Casualty	NEBULIZER NOT WORKING	Vignesh. D.	checked and found that switch problem.the problem is rectified.		Sasirekha. K. - EMERGENCY MEDICINE	28/10/2022
Comp. Dt. : 14/11/2022								
Status : Completed								
314	22110541	Casualty	MONITOR SPO2 PROBE NOT WORKING	Vignesh. D.	checked and found that spo2 probe connection problem.the problem is rectified.		Kanimozhi. E. - EMERGENCY MEDICINE	19/11/2022
315	22110542	Casualty	1 BP APPARATUS NOT WORKING	Gurumoorthy. G.	services working		Kanimozhi. E. - EMERGENCY MEDICINE	14/11/2022
Comp. Dt. : 21/11/2022								
Status : Completed								
316	22110841	Casualty	DIFIBRILLATOR NOT WORKING	Gurumoorthy. G.	preview check done now working good		Sasirekha. K. - EMERGENCY MEDICINE	23/11/2022
Comp. Dt. : 22/11/2022								
Status : Completed								
317	22110910	Casualty	NEED TO CHECK ECG MACHINE DOOR AND POWER CART 2NOS - NOT WORKING	Vignesh. D.	10 lead ecg cable replaced now working good.bulb and clamp also replaced.	AssetNo :16000284	Kanimozhi. E. - EMERGENCY MEDICINE	23/11/2022
Comp. Dt. : 29/11/2022								
Status : Completed								
318	22111223	Casualty	MUTIPARA MONITOR NOT WORKING	Vignesh. D.	CHECKED AND FOUND THE MOTHER BOARD ISSUE it's replaced now working	AssetNo :16000008	Devi. S - EMERGENCY MEDICINE	27/12/2022
Comp. Dt. : 23/12/2022								
Status : Completed								
319	22121068	Casualty	VENTILATOR NOT WORKING	Vignesh. D.	checked and found the flow sensor issue it's replaced now working good	AssetNo :22121064	Kanimozhi. E. - EMERGENCY MEDICINE	27/12/2022

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 11/01/2023 Status : Completed								
320	23010478	Casualty	BP APPARATUS NOT WORKING	Vignesh. D.	bladder replaced working good		Dhanalakshmi. M. - EMERGENCY MEDICINE	11/01/2023
Comp. Dt. : 12/01/2023 Status : Completed								
321	23010527	Casualty	ECG MACHINE NOT WORKING	Vignesh. D.	checked and found the printer door issue it's rectified now working good		Kanimozhi. E. - EMERGENCY MEDICINE	14/01/2023
Comp. Dt. : 24/01/2023 Status : Completed								
322	23010862	Casualty	SPOT LIGHT NOT WORKING IN PROCEDURE ROOM	Vignesh. D.	replaced the lamp		Kanimozhi. E. - EMERGENCY MEDICINE	24/01/2023
Comp. Dt. : 30/01/2023 Status : Completed								
323	23011056	Casualty	PROBLEM IN VENTILATOR CHARGER	Gurumoorthy. G.	checked and found that wire connection problem.the problem is rectified.		Kanimozhi. E. - EMERGENCY MEDICINE	30/01/2023
Comp. Dt. : 01/03/2023 Status : Completed								
324	23030030	Casualty	NEED TO CHANGE BATTERY FOR VENTILATOR	Sridhar. K.	replaced the battery		Kazhagamani. V. - EMERGENCY MEDICINE	01/03/2023
325	23030040	Casualty	MULTIPARA MONITOR NOT WORKING	Sridhar. K.	replaced spo2' NIBP CUFF, HOSE NOW WORKING	AssetNo :16000097	Dhanalakshmi. M. - EMERGENCY MEDICINE	01/03/2023
Comp. Dt. : 02/03/2023 Status : Completed								
326	23030056	Casualty	HAMILTON VENTILATOR NOT WORKING	Gurumoorthy. G.	flow sensor issue. calibration done now working good.	AssetNo :16001064	Kazhagamani. V. - EMERGENCY MEDICINE	02/03/2023
Comp. Dt. : 03/03/2023 Status : Completed								
327	23030118	Casualty	SUCTION APPARATUS NOT WORKING	Vignesh. D.	checked and found the tube loose connection issue it's rectified now working good		Sasirekha. K. - EMERGENCY MEDICINE	04/03/2023
Comp. Dt. : 24/03/2023								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
328	23031012	Casualty	O2 FLOW METER BROKEN	Gurumoorthy. G.	key plugs issue.the problem is rectified.		Raja. A. - EMERGENCY MEDICINE	25/03/2023
Comp. Dt. : 20/04/2023								
Status : Completed								
329	23040620	Male Medical - Ward 301	B P APPARATUS [2NOS] NOT WORKING	Gurumoorthy. G.	replaced the bulb with valve and bladder		Kanimozhi. E. - EMERGENCY MEDICINE	20/04/2023
Comp. Dt. : 08/05/2023								
Status : Completed								
330	23050283	Casualty	DEFIBRILLATOR NOT WORKING	Vignesh. D.	checked and found that printer paper position problem.the problem is rectified.		Jasmin. G. - EMERGENCY MEDICINE	10/05/2023
Comp. Dt. : 12/05/2023								
Status : Completed								
331	23050470	Casualty	POWER CART NOT WORKING	Sridhar. K.	relaced the power cord		Raja. A. - EMERGENCY MEDICINE	12/05/2023
Comp. Dt. : 29/05/2023								
Status : Completed								
332	23051118	Casualty	NEED TO REFIX SPOT LIGHT CLOSER	Sridhar. K.	refixed the spot light		Kanimozhi. E. - EMERGENCY MEDICINE	30/05/2023
Comp. Dt. : 31/05/2023								
Status : Completed								
333	23051252	Casualty	B P APPARATUS NOT WORKING	Gurumoorthy. G.	replaced the bulb with valve		Kanimozhi. E. - EMERGENCY MEDICINE	02/06/2023
Comp. Dt. : 07/06/2023								
Status : Completed								
334	23060254	Casualty	ECG MACHINE NOT WORKING	Gurumoorthy. G.	checked and found that ECG is defective.replaced the new ECG cable(10 leads).	AssetNo :16000286	Kazhagamani. V. - EMERGENCY MEDICINE	09/06/2023
Comp. Dt. : 08/06/2023								
Status : Completed								
335	23060261	Male Medical - Ward 301	B.P.APPARATUS NOT WORKING	Gokul. P. K.	replaced the cuff		Sumithradevi. S. - EMERGENCY MEDICINE	09/06/2023

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Dept Name : Endoscopy - Biomedical Comp. Dt. : 13/07/2022 Status : Completed								
336	22070507	Endoscopy	SUCTION NOT WORKING	Gurumoorthy. G.	checked and found that tube loose connection problem.the problem is rectified.now its working good.		Vijayalakshmi. G. - Endoscopy	14/07/2022
Comp. Dt. : 22/07/2022 Status : Completed								
337	22070836	Endoscopy	ENDOSCOPY LAMP NOT WORKING	Gurumoorthy. G.	replaced the lamp		Vijayalakshmi. G. - Endoscopy	25/07/2022
Comp. Dt. : 01/09/2022 Status : Completed								
338	22090005	ENDOCRINOLOGY	NEED TO CHANGE LAMP	Sridhar. K.	replace lamp its now working	AssetNo :16000537	Ananthi. S. - P.H.C. - Tiruvonnainallur	02/09/2022
Comp. Dt. : 24/09/2022 Status : Completed								
339	22090981	Endoscopy	NEED TO CHANGE LAMP	Vignesh. D.	bulb replaced now working good		Vijayalakshmi. G. - Endoscopy	24/09/2022
Comp. Dt. : 05/10/2022 Status : Completed								
340	22100024	Endoscopy	NEED TO CHANGE ENDOSCOPY BULB	Gurumoorthy. G.	replaces lamp working		Ananthi. S. - P.H.C. - Tiruvonnainallur	05/10/2022
Comp. Dt. : 06/10/2022 Status : Completed								
341	22100091	MINOR OT NEAR ENDOSCOPY	SPOT LIGHT NOT WORKING	Sridhar. K.	replaced the lamp		Ananthi. S. - P.H.C. - Tiruvonnainallur	10/10/2022
Comp. Dt. : 09/11/2022 Status : Completed								
342	22110344	Endoscopy	ENDOSCOPY LAMP NEED TO BE CHANGE	Sridhar. K.	lamp replaced	AssetNo :16000539	Vijayalakshmi. G. - Endoscopy	10/11/2022
Comp. Dt. : 18/11/2022 Status : Completed								
343	22110780	Endoscopy	NEED TO REFIX SYSTEM AND ENDOSCOPY MACHINE CABLE	Gurumoorthy. G.	refixed the system and endoscopy machine.		Vijayalakshmi. G. - Endoscopy	19/11/2022
Comp. Dt. : 06/12/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
344	22120215	Endoscopy	NEED TO CHANGE ENDO LAMP	Gurumoorthy. G.	lamp replaced	AssetNo :16000537	Vijayalakshmi. G. - Endoscopy	10/12/2022
345	22120229	Minor O.T. - Surgical OP	FOCUS LIGHT NOT WORKING	Sridhar. K.	genral serviced working		Vijayalakshmi. G. - Endoscopy	10/12/2022
Comp. Dt. : 09/12/2022 Status : Completed								
346	22120426	Endoscopy	SUCTION NOT WORKING	Sridhar. K.	genral serviced working		Vijayalakshmi. G. - Endoscopy	10/12/2022
Comp. Dt. : 20/03/2023 Status : Completed								
347	23030807	Endoscopy	NEED TO CHANGE ENDOSCOPY LAMP	Gurumoorthy. G.	replaced the lamp		Vijayalakshmi. G. - Endoscopy	24/03/2023
Comp. Dt. : 31/03/2023 Status : Completed								
348	23031341	Endoscopy	SUCTION NOT WORKING	Sridhar. K.	tubing issue it's rectified working good		Vijayalakshmi. G. - Endoscopy	03/04/2023
Comp. Dt. : 13/05/2023 Status : Completed								
349	23050552	Endoscopy	LIGHT SOURCE VIDEO - CHANGE LAMP	Gurumoorthy. G.	replaced the lamp		Tamilselvi. E. - Endoscopy	17/05/2023
Comp. Dt. : 27/05/2023 Status : Completed								
350	23051079	Endoscopy	NEED TO CHANGE LIGHT SOURCE LAMP	Gurumoorthy. G.	replaced lamp working	AssetNo :16000537	Tamilselvi. E. - Endoscopy	29/05/2023
Dept Name : ENT & Ophthal Ward - Biomedical Comp. Dt. : 29/07/2022 Status : Completed								
351	22071042	ENT WARD-407	BP APPARATUS NOT WORKING	Vignesh. D.	BULB CHANGED NOW IT'S WORKING GOOD		Bhuvaneswari. M. - ENT & Ophthal Ward	29/07/2022
Comp. Dt. : 06/08/2022 Status : Completed								
352	22080227	ENT WARD-407	BP APPARATUS NOT WORKING	Vignesh. D.	replaced the bulb with valve		Jaculine Mary. A. - ENT & Ophthal Ward	06/08/2022
Comp. Dt. : 20/08/2022 Status : Completed								
353	22080668	Female Medical - Ward 305	LARYNGOSCOPE NOT WORKING	Vignesh. D.	genral service		Bhuvaneswari. M. - ENT & Ophthal Ward	20/08/2022
Comp. Dt. : 03/09/2022								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
354	22090119	Female Medical - Ward 305	BP APPARATUS NOT WORKING	Vignesh. D.	BLADDER CHANGED NOW IT'S WORKING GOOD		Bhuvaneswari. M. - ENT & Ophthal Ward	03/09/2022
355	22090145	Female Medical - Ward 305	PULSE OXIMETER NOT WORKING	Sridhar. K.	ac dc supply services its working		Bhuvaneswari. M. - ENT & Ophthal Ward	12/09/2022
Comp. Dt. : 05/09/2022								
Status : Completed								
356	22090148	Female Medical - Ward 305	NEED TO CHECK ALL MONITORS & PULSE OXI METER IN I M C U	Sridhar. K.	checked the monitor all working		Bhuvaneswari. M. - ENT & Ophthal Ward	12/09/2022
Comp. Dt. : 06/09/2022								
Status : Completed								
357	22090217	ENT WARD-407	BP APPARATUS NOT WORKING	Vignesh. D.	bulb changed now working good		Jayalakshmi. J. - ENT & Ophthal Ward	06/09/2022
Comp. Dt. : 21/09/2022								
Status : Completed								
358	22090829	Female Medical - Ward 305	MULTIPARA MONITOR NOT WORKING	Sridhar. K.	spo2 probe replaced now working good	AssetNo :16000014	Bhuvaneswari. M. - ENT & Ophthal Ward	22/09/2022
Comp. Dt. : 22/09/2022								
Status : Completed								
359	22090875	Female Medical - Ward 305	PULSEOXIMETER NOT WORKING	Sridhar. K.	spo2 cable connection problem.the problem is rectified		Bhuvaneswari. M. - ENT & Ophthal Ward	12/10/2022
360	22090877	Female Medical - Ward 305	PULSE OXI METER & BP APPARATUS NOT WORKING	Sridhar. K.	spo2 loose connection issue now working good		Bhuvaneswari. M. - ENT & Ophthal Ward	27/09/2022
Comp. Dt. : 27/09/2022								
Status : Completed								
361	22091065	Female Medical - Ward 305	DIGITAL THERMOMETER NOT WORKING	Vignesh. D.	BATTERY REPLACED NOW WORKING GOOD		Bhuvaneswari. M. - ENT & Ophthal Ward	27/09/2022
Comp. Dt. : 30/09/2022								
Status : Completed								
362	22091203	Female Medical - Ward 305	NEBULIZER & BP APPARATUS NOT WORKING	Gurumoorthy. G.	wire loose connection issue now working good.bulb replaced now working good		Bhuvaneswari. M. - ENT & Ophthal Ward	30/09/2022
Comp. Dt. : 10/10/2022								
Status : Completed								
363	22100232	ENT WARD	WEIGHT MACHINE NOT WORKING WARD NO 407 & 408	Sridhar. K.	replaced the battery		gila. V. - ENT & Ophthal Ward	12/10/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 12/10/2022								
Status : Completed								
364	22100323	Female Medical - Ward 305	2 NOS BP APPARATUS NOT WORKING	Vignesh. D.	bladder issue it's replaced now working good		Bhuvaneswari. M. - ENT & Ophthal Ward	12/10/2022
Comp. Dt. : 13/10/2022								
Status : Completed								
365	22100390	ENT WARD-407	THERMO METER NOT WORKING	Gurumoorthy. G.	replaced the battery		Jayalakshmi. J. - ENT & Ophthal Ward	14/10/2022
Comp. Dt. : 17/10/2022								
Status : Completed								
366	22100552	Female Medical - Ward 305	BP APPARATUS NOT WORKING	Sridhar. K.	bp cuff replacement now its working		Bhuvaneswari. M. - ENT & Ophthal Ward	18/10/2022
Comp. Dt. : 02/11/2022								
Status : Completed								
367	22110030	Female Medical - Ward 305	IMC-MULTIPARA MONITOR NOT WORKING	Sridhar. K.	power cade replaced it working		Bhuvaneswari. M. - ENT & Ophthal Ward	21/11/2022
Comp. Dt. : 04/11/2022								
Status : Completed								
368	22110118	Female Medical - Ward 305	BP APPARATUS NOT WORKING	Vignesh. D.	BULB REPLACED NOW WORKING GOOD		Bhuvaneswari. M. - ENT & Ophthal Ward	05/11/2022
369	22110151	ENT WARD-407	BP APPARATUS NOT WORKING	Vignesh. D.	BULB REPLACED NOW WORKING GOOD		Jayalakshmi. J. - ENT & Ophthal Ward	05/11/2022
Comp. Dt. : 10/11/2022								
Status : Completed								
370	22110409	Female Medical - Ward 305	1 BP APPARATUS NOT WORKING	Sridhar. K.	bulb replaced now working good		Bhuvaneswari. M. - ENT & Ophthal Ward	10/11/2022
Comp. Dt. : 14/11/2022								
Status : Completed								
371	22110510	ENT WARD-407	1 BP APPARATUS NOT WORKING	Sridhar. K.	services working		Jayalakshmi. J. - ENT & Ophthal Ward	14/11/2022
Comp. Dt. : 25/11/2022								
Status : Completed								
372	22111101	Female Medical - Ward 305	BP APPARATUS NOT WORKING	Vignesh. D.	BLADDER REPLACED NOW WORKING GOOD		Bhuvaneswari. M. - ENT & Ophthal Ward	26/11/2022
Comp. Dt. : 06/12/2022								
Status : Completed								
373	22120224	Female Medical - Ward 305	BP APPARATUS NOT WORKING	Vignesh. D.	replaced the bladder		Bhuvaneswari. M. - ENT & Ophthal Ward	07/12/2022
Comp. Dt. : 15/12/2022								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
374	22120728	Male Medical - Ward 302	B.P. APPARATUS NOT WORKING	Sridhar. K.	DAILL REPLACE WORKING		Bhuvaneswari. M. - ENT & Ophthal Ward	16/12/2022
Comp. Dt. : 19/12/2022								
Status : Completed								
375	22120865	ENT WARD-407	BP APPARATUS NOT WORKING	Vignesh. D.	replaced the bulb with valve		Agila. V. - ENT & Ophthal Ward	20/12/2022
Comp. Dt. : 27/12/2022								
Status : Completed								
376	22121196	ENT WARD-407	BP APPARATUS NOT WORKING	Vignesh. D.	serviced working		Jayalakshmi. J. - ENT & Ophthal Ward	28/12/2022
Comp. Dt. : 28/12/2022								
Status : Completed								
377	22121284	ENT WARD-408	1 BP APPARATUS NOT WORKING	Sridhar. K.	genral services done		Jayalakshmi. J. - ENT & Ophthal Ward	31/12/2022
Comp. Dt. : 30/12/2022								
Status : Completed								
378	22121344	Female Medical - Ward 305	PULSE OXIMETER NOT WORKING	Sridhar. K.	checked and found that spo2 probe connection problem.the problem is retified		Bhuvaneswari. M. - ENT & Ophthal Ward	02/01/2023
Comp. Dt. : 07/01/2023								
Status : Completed								
379	23010308	Female Medical - Ward 306	MULTIPARA MONITOR NOT WORKING	Sridhar. K.	CHECKED AND FOUND THE PROBE ISSUE IT'S RECTIFIED NOW WORKING GOOD		Bhuvaneswari. M. - ENT & Ophthal Ward	09/01/2023
Comp. Dt. : 10/01/2023								
Status : Completed								
380	23010375	Female Medical - Ward 305	BP APPARATUS NOT WORKING	Gurumoorthy. G.	replaced the bulb with valve		Bhuvaneswari. M. - ENT & Ophthal Ward	10/01/2023
Comp. Dt. : 27/01/2023								
Status : Completed								
381	23010943	Female Medical - Ward 305	BP APPARATUS NOT WORKING	Gurumoorthy. G.	REPLACED THE BULB WITH VALVE		Bhuvaneswari. M. - ENT & Ophthal Ward	28/01/2023
Comp. Dt. : 28/01/2023								
Status : Completed								
382	23010996	ENT WARD-407	BP APPARATUS NOT WORKING	Gurumoorthy. G.	REPLACED THE CUFF		Samundeeswari. E. - ENT & Ophthal Ward	28/01/2023

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 14/02/2023								
Status : Completed								
383	23020538	ENT WARD-407	BP APPARATUS NOT WORKING	Gurumoorthy. G.	serviced working		Jayalakshmi. J. - ENT & Ophthal Ward	14/02/2023
Comp. Dt. : 01/03/2023								
Status : Completed								
384	23030020	Female Medical - Ward 305	BP APPARATUS NOT WORKING	Sridhar. K.	SERVICED NOW WORKING		Bhuvaneswari. M. - ENT & Ophthal Ward	01/03/2023
Comp. Dt. : 09/03/2023								
Status : Completed								
385	23030346	Female Medical - Ward 305	BP APPARATUS NOT WORKING	Vignesh. D.	BULB REPLACED NOW WORKING GOOD		Bhuvaneswari. M. - ENT & Ophthal Ward	09/03/2023
Comp. Dt. : 21/03/2023								
Status : Completed								
386	23030873	Female Medical - Ward 305	BP APPARATUS NOT WORKING	Vignesh. D.	bulp replaced now working good		Bhuvaneswari. M. - ENT & Ophthal Ward	21/03/2023
Comp. Dt. : 22/03/2023								
Status : Completed								
387	23030923	ENT WARD-407	SUCTION APPARATUS NOT WORKING	Sridhar. K.	tube connections problem.the problem is rectified.		Jayalakshmi. J. - ENT & Ophthal Ward	25/03/2023
Comp. Dt. : 29/03/2023								
Status : Completed								
388	23031232	Female Medical - Ward 305	GLUCOMETER NOT WORKING	Vignesh. D.	battery replace		Bhuvaneswari. M. - ENT & Ophthal Ward	30/03/2023
Comp. Dt. : 04/04/2023								
Status : Completed								
389	23040093	ENT WARD-407	SUCTION NOT WORKING	Gurumoorthy. G.	Tube connection problem.the problem is rectified.		Agila. V. - ENT & Ophthal Ward	05/04/2023
Comp. Dt. : 15/04/2023								
Status : Completed								
390	23040446	ENT WARD-407	STETHOSCOPE BROKEN	Vignesh. D.	EAR PIECE CHANGED NOW WORKING GOOD		Jayalakshmi. J. - ENT & Ophthal Ward	18/04/2023
Comp. Dt. : 24/04/2023								
Status : Completed								
391	23040721	ENT WARD-407	STETHOSCOPE - BROKEN	Sridhar. K.	replaced the steth frame		Jayalakshmi. J. - ENT & Ophthal Ward	24/04/2023
Comp. Dt. : 27/04/2023								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
392	23040922	ICU	U S G MACHINE NOT WORKING	Vignesh. D.	adapter replaced		Maheswaran. D. - ENT & Ophthal Ward	02/05/2023
Comp. Dt. : 29/05/2023								
Status : Completed								
393	23051111	ENT WARD	SLIT LAMP NOT WORKING - WARD NO 407 & 408	Sridhar. K.	wire connection problem.the problem is rectified.		Agila. V. - ENT & Ophthal Ward	30/05/2023
Comp. Dt. : 30/05/2023								
Status : Completed								
394	23051169	Female Medical - Ward 305	WEIGHT MACHINE NOT WORKING	Sridhar. K.	rust issue.rust cleaned.		Bhuvaneswari. M. - ENT & Ophthal Ward	30/05/2023
Comp. Dt. : 06/06/2023								
Status : Completed								
395	23060191	Female Medical - Ward 305	BP APPARATUS NOT WORKING	Gurumoorthy. G.	replaced the bulb with valve		Bhuvaneswari. M. - ENT & Ophthal Ward	06/06/2023
Comp. Dt. : 24/06/2023								
Status : Completed								
396	23060918	Female Medical - Ward 305	B P APPARATUS NOT WORKING	Gokul. P. K.	genral serviced now working		Bhuvaneswari. M. - ENT & Ophthal Ward	26/06/2023
Dept Name : Female Medical Ward - Biomedical								
Comp. Dt. : 09/05/2022								
Status : Completed								
397	22050305	Female Medical - Ward 305	PULSE OXI METER NOT WORKING	Sridhar. K.	checked and found problem in spo2 cable loose contact so it remove and refix it problem rectified.		Vaitheeswari. A. - Female Medical Ward	10/05/2022
Comp. Dt. : 12/05/2022								
Status : Completed								
398	22050425	Female Medical - Ward 305	BP APPARATUS NOT WORKING	Sridhar. K.	checked and found that bladder and bulb problem,replaced new bladder and bulb now working good.		Vaitheeswari. A. - Female Medical Ward	12/05/2022
Comp. Dt. : 21/05/2022								
Status : Completed								
399	22050780	Female Medical - Ward 305	BP APPARATUS NOT WORKING	Gurumoorthy. G.	replaced the bulb with valve		Vaitheeswari. A. - Female Medical Ward	23/05/2022
Comp. Dt. : 25/05/2022								

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
400	22050951	Female Medical - Ward 305	BP APPARATUS NOT WORKING	Gurumoorthy. G.	GENERAL SERVIC DONE NOW IT'S WORKING GOOD		Johnsi Rani. N. - Female Medical Ward	25/05/2022
Comp. Dt. : 01/06/2022								
Status : Completed								
401	22060036	Female Medical - Ward 305	BP APPARATUS NOT WORKING	Gurumoorthy. G.	checked and found that bulb with valve problem,replaced new one now working good.		Vaitheeswari. A. - Female Medical Ward	02/06/2022
Comp. Dt. : 15/06/2022								
Status : Completed								
402	22060548	Female Medical - Ward 305	NEED TO CHECK MONITOR - NOT WORKING	Sridhar. K.	checked and found that monitor setting problem,setting changed now working good.		Vaitheeswari. A. - Female Medical Ward	15/06/2022
Comp. Dt. : 18/06/2022								
Status : Completed								
403	22060670	Female Medical - Ward 305	PULSE OXI METER NOT WORKING	Vignesh. D.	CHECKED AND FOUND THE SPO2 PROBE ISSUE IT'S CHANGED NOW IT'S WORKING GOOD		Vaitheeswari. A. - Female Medical Ward	18/06/2022
Comp. Dt. : 08/07/2022								
Status : Completed								
404	22070343	Female Medical - Ward 305	MONITOR PROBE NOT WORKING	Sridhar. K.	spo2 probe replaces now its working	AssetNo :16000030	Vaitheeswari. A. - Female Medical Ward	15/07/2022
Comp. Dt. : 11/07/2022								
Status : Completed								
405	22070440	Female Medical - Ward 305	BP APPARATUS NOT WORKING	Gurumoorthy. G.	replaced tha bladder		Vaitheeswari. A. - Female Medical Ward	11/07/2022
Comp. Dt. : 23/07/2022								
Status : Completed								
406	22070869	Female Medical - Ward 305	BP APPARATUS NOT WORKING	Vignesh. D.	CHECKED AND CHANGED THE BULB NOW WORKING GOOD		Vaitheeswari. A. - Female Medical Ward	23/07/2022
Comp. Dt. : 29/07/2022								
Status : Completed								
407	22071075	Female Medical - Ward 305	BP APPARATUS NOT WORKING	Vignesh. D.	bulb replaced now it's working good		Vaitheeswari. A. - Female Medical Ward	29/07/2022
Comp. Dt. : 30/07/2022								
Status : Completed								

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
408	22071087	Female Medical - Ward 305	PULSE OXI METER NOT WORKING	Sridhar. K.	spo2 probe replace working	AssetNo :16000721	Gnanasoundari. G - Female Medical Ward	30/07/2022
Comp. Dt. : 03/08/2022 Status : Completed								
409	22080134	Female Medical - Ward 306	PULSE OXI METER PROBE NOT WORKING	Sridhar. K.	spo2 probe replaced now its working good	AssetNo :16000730	Vaitheeswari. A. - Female Medical Ward	11/08/2022
Comp. Dt. : 04/08/2022 Status : Completed								
410	22080149	Biomedical	BP APPARATUS NOT WORKING	Sridhar. K.	genral services its now working		Vaitheeswari. A. - Female Medical Ward	05/08/2022
Comp. Dt. : 08/03/2023 Status : Completed								
411	23030340	Female Medical - Ward 305	SOUND PROBLEM IN MULTIPARA MONITOR	Gurumoorthy. G.	checked and found that alaram problem.the problem is rectified.		Maniarasy. K. - Female Medical Ward	13/03/2023
Comp. Dt. : 19/05/2023 Status : Completed								
412	23050817	Female Medical - Ward 305	MULTIPARA MONITOR PROBE NOT WORKING	Sridhar. K.	replaced the spo2 probe		Gomathy. G. - Female Medical Ward	19/05/2023
Comp. Dt. : 25/05/2023 Status : Completed								
413	23050990	Female Medical - Ward 305	BP APPARATUS NOT WORKING	Sridhar. K.	replaced the bulb		Gomathy. G. - Female Medical Ward	25/05/2023
Comp. Dt. : 14/06/2023 Status : Completed								
414	23060477	Female Medical - Ward 305	B P APPARATUS NOT WORKING	Gokul. P. K.	replaced the bulb with valve		Gnanasoundari. G - Female Medical Ward	15/06/2023
Dept Name : Female Ortho Ward - Biomedical Comp. Dt. : 07/06/2022 Status : Completed								
415	22060260	Male Ortho - Ward 404	ECG MACHINE NOT WORKING	Sridhar. K.	checked and found that cable loose connection problem,problem rectified now working good.	AssetNo :16000293	Gayathri. S. - Male Ortho Ward	09/06/2022
Comp. Dt. : 10/06/2022 Status : Completed								
416	22060400	Injection OPD - Female	IN ROOM NO.54 BP CUFF NOT WORKING	Vignesh. D.	checked and found that dial need le problem,needle adujust done,now working good.		padmasri. P. - OPD	13/06/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 22/07/2022 Status : Completed								
417	22070845	Female Ortho - Ward 401	BP APPARATUS NOT WORKING	Vignesh. D.	BULB CHANGED NOW IT'S WORKING GOOD		Punithavathi. E. - Female Ortho Ward	23/07/2022
Comp. Dt. : 29/07/2022 Status : Completed								
418	22071055	Female Ortho - Ward 401	BP APPARATUS 2NOS NOT WORKING	Vignesh. D.	BLADDER CHANGED NOW IT'S WORKING GOOD		Girija. G. - Female Ortho Ward	29/07/2022
Comp. Dt. : 02/08/2022 Status : Completed								
419	22080080	Female Ortho - Ward 401	BP APPARATUS [2NOS] & MULTIPARA MONIOTR NOT WORKING	Sridhar. K.	replace NIBP hous,cuff, m/p moniter its working and BP APP dial, cuff, bulb working	AssetNo :16000024	Girija. G. - Female Ortho Ward	03/08/2022
Comp. Dt. : 05/09/2022 Status : Completed								
420	22090186	Female Ortho - Ward 401	BP APPARATUS NOT WORKING	Vignesh. D.	BULB CHANGED NOW WORKING GOOD		Girija. G. - Female Ortho Ward	05/09/2022
Comp. Dt. : 21/09/2022 Status : Completed								
421	22090830	Female Ortho - Ward 401	PROBLEM IN MULTIPARA SP O2	Sridhar. K.	spo2 probe loose connection. problem rectified now it's working good	AssetNo :16000024	Girija. G. - Female Ortho Ward	22/09/2022
Comp. Dt. : 27/09/2022 Status : Completed								
422	22091051	Female Ortho - Ward 402	MULTIPARA MONITOR PROBE NOT WORKING	Sridhar. K.	replaces cuff its now working	AssetNo :16000025	Punithavathi. E. - Female Ortho Ward	28/09/2022
Comp. Dt. : 07/10/2022 Status : Completed								
423	22100127	Female Ortho - Ward 402	NEBULIZER NOT WORKING	Sridhar. K.	checked and found that wire connection problem.the problem is rectified		Anbuselvi. P. - Female Ortho Ward	10/10/2022
Comp. Dt. : 18/10/2022 Status : Completed								
424	22100579	Female Ortho - Ward 402	GLUCO METER NOT WORKING	Sridhar. K.	SERVICES IT NOW WORKING		Dhansulakshmi. K. - Female Ortho Ward	19/10/2022
Comp. Dt. : 27/10/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
425	22100851	Paediatrics - Ward 309	BP APPARATUS NOT WORKING	Sridhar. K.	replaced the bladder		Punitha. E. - Female Ortho Ward	27/10/2022
Comp. Dt. : 07/11/2022 Status : Completed								
426	22110221	Female Ortho - Ward 401	BP APPARATUS NOT WORKING	Vignesh. D.	SERVICES NOW WORKING		Girija. G. - Female Ortho Ward	07/11/2022
Comp. Dt. : 11/11/2022 Status : Completed								
427	22110487	Female Ortho - Ward 401	1 BP APPARATUS NOT WORKING	Sridhar. K.	genral servied its working		Girija. G. - Female Ortho Ward	14/11/2022
Comp. Dt. : 16/11/2022 Status : Completed								
428	22110674	Female Ortho - Ward 401	2 NO'S BP APPARATUS NOT WORKING	Sridhar. K.	repaced the bladder		Girija. G. - Female Ortho Ward	19/11/2022
Comp. Dt. : 02/12/2022 Status : Completed								
429	22120090	Female Ortho - Ward 402	MULTIPARA MONITOR SP O2 PROBE NOT WORKING	Sridhar. K.	spo2 probe replaced	AssetNo :16000016	Girija. G. - Female Ortho Ward	02/12/2022
Comp. Dt. : 14/02/2023 Status : Completed								
430	23020514	Female Ortho - Ward 402	MULTIPARA MONITOR NOT WORKING	Sridhar. K.	smps replaced		Girija. G. - Female Ortho Ward	14/02/2023
Comp. Dt. : 21/03/2023 Status : Completed								
431	23030837	Female Ortho - Ward 402	MULTIPARA MONITOR NOT WORKING	Gurumoorthy. G.	checked and found that display cable connection problem.the problem is rectified.		Anbuselvi. P. - Female Ortho Ward	24/03/2023
Comp. Dt. : 12/06/2023 Status : Completed								
432	23060379	Female Ortho - Ward 402	NEBULIZATION MACHINE NOT WORKING	Gokul. P. K.	wire connection problem.the problem is rectified.		Punithavathi. E. - Female Ortho Ward	12/06/2023
Comp. Dt. : 30/06/2023 Status : Completed								
433	23061128	Female Ortho - Ward 402	NEED TO CHECK NEBHULIZER CABLE - SHOCK PROBLEM	Gurumoorthy. G.	CONNECTED WIRES		Punithavathi. E. - Female Ortho Ward	01/07/2023
Dept Name : Female Surgery - Biomedical								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 12/05/2022 Status : Completed								
434	22050418	Male Surgery - Ward 204	BP CUFF PROBLEM	Gurumoorthy. G.	checked and found that bladder issue, replaced new bladder now working good		Sasikala. A. - Male Surgery	12/05/2022
Comp. Dt. : 25/08/2022 Status : Completed								
435	22080853	Male Surgery - Ward 203	PULSE OXIMETER NOT WORKING	Sridhar. K.	smpls connector replaces and services working	AssetNo :16000724	Saranya. R. - Female Surgery	27/08/2022
Comp. Dt. : 06/10/2022 Status : Completed								
436	22100084	Male Surgery	BP APPARATUS NOT WORKING WARD 203 & 204	Gurumoorthy. G.	replaced the bladder		Priyanka. V. - Female Surgery	06/10/2022
Comp. Dt. : 25/01/2023 Status : Completed								
437	23010916	Male Surgery - Ward 201	B P APPARATUS [2NOS] NOT WORKING	Vignesh. D.	bulp changed now working good		Priyanka. V. - Female Surgery	25/01/2023
Comp. Dt. : 13/03/2023 Status : Completed								
438	23030476	DENTAL OPD -2ND FLOOR	NEED TO CHECK DENTAL CHAIR PIPELINE CONNECTION - BROKEN - WATER LEAKAGE	Sridhar. K.	hose connection problem.the problem is rectified.		Jayasree. S. - TB & Chest / Psychiatry	14/03/2023
Comp. Dt. : 15/03/2023 Status : Completed								
439	23030617	Female Surgery - Ward 205	BP APPARATUS 2NOS NOT WORKING	Vignesh. D.	BULB REPLACED NOW WORKING GOOD		Vaidegi. S. - Female Surgery	15/03/2023
Comp. Dt. : 12/04/2023 Status : Completed								
440	23040383	Female Surgery - Ward 205	PULSE OXI METER NOT WORKING	Vignesh. D.	WIRE RECONNECTED NOW WORKING GOOD		Vaidegi. S. - Female Surgery	18/04/2023
Comp. Dt. : 09/05/2023 Status : Completed								
441	23050387	V I P DENTAL CLINIC II FLOOR	IN DENTAL CHAIR - WATER STUCK	Sridhar. K.	checked and found that blockage issue.the problem is rectified.		Jayasree. S. - TB & Chest / Psychiatry	12/05/2023
Dept Name : GENERAL MEDICINE - Biomedical Comp. Dt. : 09/06/2022								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
442	22060353	General Medicine - OPD	ECG MACHINE NOT WORKING	Sridhar. K.	checked and found that clamp electode problem,replaced new clamp electrode.now working good.	AssetNo :16000290	Rohini. B. - General Medicine	09/06/2022
Comp. Dt. : 02/03/2023								
Status : Completed								
443	23030101	General Medicine - OPD	ECG MACHINE NOT WORKING	Sridhar. K.	replaced ecg module working		Rohini. B. - General Medicine	02/03/2023
Dept Name : Gynac Ward - Biomedical								
Comp. Dt. : 12/05/2022								
Status : Completed								
444	22050438	Obstetrics - Ward 208	PULSE OXIMETER NOT WORKING	Gurumoorthy. G.	checked and found that power cord issue,replaced new power cord now working good.	AssetNo :16000575	Sangeetha. J. - Gynac Ward	12/05/2022
Comp. Dt. : 24/05/2022								
Status : Completed								
445	22050866	Obstetrics - Ward 207	THERMOMETER NOT WORKING	Sridhar. K.	replaced the battery		Ashwini. V. - Gynac Ward	25/05/2022
Comp. Dt. : 06/06/2022								
Status : Completed								
446	22060190	ORTHO OT	ARTHROSCOPY SYSTEM NOT WORKING	Sridhar. K.	checked and found problem in monitor so it tranfer to edp department		Logesh. M. - Operation Theatre	06/06/2022
Comp. Dt. : 07/06/2022								
Status : Completed								
447	22060269	Obstetrics - Ward 208	PULSE OXIMETER NEONATAL NOT WORKING	Gurumoorthy. G.	checked and found that cable internal problem,cable refixed now working ood.	AssetNo :16000575	Sangeetha. J. - Gynac Ward	09/06/2022
Comp. Dt. : 17/06/2022								
Status : Completed								
448	22060657	Obstetrics - Ward 207	NEED TO CHECK NEONATAL PULSE OXIMETER	Vignesh. D.	CHECKED AND FOUND THE SPO2 PROBE ISSUE. NEW PROBE REPLACED NOW IT'S WORKING GOOD		Vishnupriya. V. - Gynac Ward	18/06/2022
Comp. Dt. : 04/07/2022								
Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
449	22070099	Obstetrics - Ward 208	NEED TO CHECK WEIGHT MACHINE - NOT WORKING - 207 & 208	Sridhar. K.	genral service its now working		Suriya. S. - Hospital Infection Control	05/07/2022
	Comp. Dt. : 11/08/2022							
	Status : Completed							
450	22080402	Obstetrics - Ward 207	BP APPARATUS NOT WORKING	Sridhar. K.	change the bulb with valuve now its working good		Ashwini. V. - Gynac Ward	11/08/2022
	Comp. Dt. : 12/08/2022							
	Status : Completed							
451	22080449	Obstetrics - Ward 207	NEED TO CHECK AMBU BAG - BROKEN	Sridhar. K.	checked and found that bag leakage problem.the problem is rectified.		Ashwini. V. - Gynac Ward	17/08/2022
	Comp. Dt. : 24/08/2022							
	Status : Completed							
452	22080791	Obstetrics - Ward 207	BP APPARATUS [2NOS] NOT WORKING	Vignesh. D.	BULB AND BLADDER CHANGED NOW IT'S WORKING GOOD		Ashwini. V. - Gynac Ward	24/08/2022
	Comp. Dt. : 06/09/2022							
	Status : Completed							
453	22090203	Obstetrics - Ward 208	BP CUFF NOT WORKING	Vignesh. D.	bulb changed now working good		Kalaivani. J. - Operation Theatre	06/09/2022
	Comp. Dt. : 10/09/2022							
	Status : Completed							
454	22090387	Obstetrics - Ward 208	BP APPARATUS NOT WORKING	Vignesh. D.	BLADDER CHANGED NOW WORKING GOOD		Kalaivani. J. - Operation Theatre	10/09/2022
	Comp. Dt. : 18/10/2022							
	Status : Completed							
455	22100596	Obstetrics - Ward 207	PHOTOTHERAPHY NOT WORKING	Sridhar. K.	CFL BLUE BULB REPLACED NOW ITS WORKING GOOD	AssetNo :16000531	Ashwini. V. - Gynac Ward	19/10/2022
	Comp. Dt. : 19/10/2022							
	Status : Completed							
456	22100632	Obstetrics - Ward 207	USG DOPPLER MACHINE NOT WORKING	Sridhar. K.	SERVICE NOW WORKING		Ashwini. V. - Gynac Ward	19/10/2022
	Comp. Dt. : 22/10/2022							
	Status : Completed							
457	22100759	Obstetrics - Ward 207	BP APPARATUS NOT WORKING AND STETHOSCOPE NOT WORKING	Sridhar. K.	replaces spare its now working		Ashwini. V. - Gynac Ward	22/10/2022

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHAKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
458	22100760	Obstetrics - Ward 207	AMBUBAG NOT WORKING	Sridhar. K.	new one purchase.		Ashwini. V. - Gynac Ward	22/10/2022
Comp. Dt. : 31/10/2022 Status : Completed								
459	22101005	Obstetrics - Ward 207	THERMOMETER-2NOS,NOT WORKING	Gurumoorthy. G.	services its now working		Ashwini. V. - Gynac Ward	31/10/2022
Comp. Dt. : 07/11/2022 Status : Completed								
460	22110226	Obstetrics - Ward 207	PHOTOTHERAPY NOT WORKING	Sridhar. K.	REPLACES CFL ITS NOW WORKING		Kalaivani. J. - Operation Theatre	07/11/2022
Comp. Dt. : 19/12/2022 Status : Completed								
461	22120858	Obstetrics - Ward 208	WEIGHT MACHINE NOT WORKING	Sridhar. K.	battery replaced		Subasri. G. - Gynac Ward	21/12/2022
462	22120859	Obstetrics - Ward 207	BP APPARATUS NOT WORKING	Gurumoorthy. G.	replaced the bladder		Ashwini. V. - Gynac Ward	20/12/2022
Comp. Dt. : 27/01/2023 Status : Completed								
463	23010954	Obstetrics - Ward 208	BP APPARATUS NOT WORKING	Gurumoorthy. G.	replaced the bladder		Kalaivani. J. - Operation Theatre	28/01/2023
Comp. Dt. : 07/02/2023 Status : Completed								
464	23020215	Obstetrics - Ward 207	BP APPARATUS NOT WORKING	Gurumoorthy. G.	replaced the bulb with valve		Ashwini. V. - Gynac Ward	07/02/2023
Comp. Dt. : 16/02/2023 Status : Completed								
465	23020612	Gynac Ward	XRAY LOBBY NOT WORKING	Vignesh. D.	wire connection problem.the problem is rectified.		Ashwini. V. - Gynac Ward	17/02/2023
Comp. Dt. : 13/04/2023 Status : Completed								
466	23040398	Obstetrics - Ward 207	BABY WEIGHT MACHINE NOT WORKING	Sridhar. K.	CHECKED AND FOUND THE PROBLEM IT'S RECTIFIED NOW WORKING GOOD		Ashwini. V. - Gynac Ward	18/04/2023
Dept Name : ICCU - Biomedical Comp. Dt. : 05/05/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
467	22050147	ICCU	ECG CABLE & MULTIPARA MONITOR NOT WORKING	Vignesh. D.	checked and found that ecg problem, replaced new ecg cable now working good.	AssetNo :16000733	Ammu. R. - ICCU	07/05/2022
Comp. Dt. : 25/05/2022 Status : Completed								
468	22050953	ICCU	PHILIP'S MONITOR 3 LEAF CABLE NOT WORKING	Vignesh. D.	checked and found problem in ecg cable defective so it replaced with the new one problem rectified	AssetNo :16000783	Ammu. R. - ICCU	25/05/2022
Comp. Dt. : 02/06/2022 Status : Completed								
469	22060071	ICCU	VENTILATOR POWER CART NOT WORKING	Vignesh. D.	checked and found that power cord issue, replaced new power cord now working good	AssetNo :16000654	Mohamed Salahuddeen. M. - ICCU	02/06/2022
Comp. Dt. : 23/06/2022 Status : Completed								
470	22060845	ICCU	PNEUMATIC BP APPARATUS NOT WORKING	Vignesh. D.	checked and change the bulb and dial now it's working good		Ammu. R. - ICCU	24/06/2022
Comp. Dt. : 05/07/2022 Status : Completed								
471	22070180	ICCU	MULTIPARA MONITOR NOT WORKING	Vignesh. D.	checked and found the ecg cable issue it's replaced now it's working good	AssetNo :16000100	Ammu. R. - ICCU	06/07/2022
Comp. Dt. : 01/09/2022 Status : Completed								
472	22090049	ICCU	BP APPARATUS NOT WORKING	Vignesh. D.	genral services now working		Ammu. R. - ICCU	02/09/2022
Comp. Dt. : 16/09/2022 Status : Completed								
473	22090618	ICCU	NEED TO CHECK VENTILATOR POWER CART - NOT WORKING	Vignesh. D.	powercard replaced now working good		Kavitha. K. - ICCU	27/09/2022
Comp. Dt. : 05/10/2022 Status : Completed								
474	22100022	ICCU	NEED TO CHANGE MONITOR CABLE - UNFIX	Vignesh. D.	probe losse connection issue now woring good		Paradha. G. - ICCU	05/10/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 09/11/2022								
Status : Completed								
475	22110343	ICCU	MULTIPARA MONITOR NOT WORKING	Vignesh. D.	spo2 probe replaced working good	AssetNo :16000055	Mohamed Salahuddeen. M. - ICCU	10/11/2022
Comp. Dt. : 21/11/2022								
Status : Completed								
476	22110879	ICCU	1 BP APPARATUS NOT WORKING	Vignesh. D.	bulb replaced now working good		Ammu. R. - ICCU	23/11/2022
Comp. Dt. : 25/11/2022								
Status : Completed								
477	22111095	ICCU	X-RAY MACHINE NOT WORKING	Gurumoorthy. G.	x-ray exposure switch replaced now working good	AssetNo :16000697	Ammu. R. - ICCU	29/11/2022
Comp. Dt. : 09/12/2022								
Status : Completed								
478	22120429	ICCU	PROBLEM IN VENTILATOR FLOW	Vignesh. D.	checked and found that water blockage issue.rectified the complaint.now its working good.		Mohamed Salahuddeen. M. - ICCU	12/12/2022
Comp. Dt. : 20/12/2022								
Status : Completed								
479	22120901	ICCU	LARYNGOSCOPE NOT WORKING	Sridhar. K.	serviced now working		Ammu. R. - ICCU	21/12/2022
Comp. Dt. : 11/01/2023								
Status : Completed								
480	23010498	ICCU	SPO2 PROBE NOT WORKING	Vignesh. D.	spo2 probe replaced now working good		Ammu. R. - ICCU	11/01/2023
481	23010499	ICCU	ECG CABLE NOT WORKING	Vignesh. D.	ecg cable replaced now working good		Ammu. R. - ICCU	11/01/2023
Comp. Dt. : 13/01/2023								
Status : Completed								
482	23010580	ICCU	O2 FLOW METER NOT WORKING	Vignesh. D.	gas plant complaint		Ammu. R. - ICCU	14/01/2023
Comp. Dt. : 01/03/2023								
Status : Completed								
483	23030044	ICCU	MONITOR [ON - OFF] BUTTON NOT WORKING	Sridhar. K.	replaced the button		Hemasri. M. - ICCU	01/03/2023
Comp. Dt. : 20/03/2023								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
484	23030810*	ICCU	MAQUET VENTILATOR & MULTIPARA MONITOR NOT WORKING	Sridhar. K.	checked and found that board(PC 1772) is defective.the board is replaced.now its working good. displ	AssetNo :16000654	Ammu. R. - ICCU	03/04/2023
Comp. Dt. : 08/05/2023								
Status : Completed								
485	23050281	ICCU	MULTIPARA MONITOR [PHILIP'S] NOT WORKING	Vignesh. D.	checked and found that display wire connection problem.the problem is rectified.		Ammu. R. - ICCU	10/05/2023
Comp. Dt. : 23/05/2023								
Status : Completed								
486	23050939	ICCU	ECG MACHINE NOT WORKING	Sridhar. K.	checked and found that door broken.the problem is rectified.		Saradha. G. - ICCU	25/05/2023
Comp. Dt. : 25/05/2023								
Status : Completed								
487	23050988	ICCU	BP APPARATUS NOT WORKING	Sridhar. K.	bladder and bulb replaced		Mohamed Salahuddeen. M. - ICCU	25/05/2023
Dept Name : ICU - Biomedical								
Comp. Dt. : 03/06/2022								
Status : Completed								
488	22060120	ICU	INFUTION PUMP NOT WORKING	Vignesh. D.	checked and found problem in air detect sensor defective so it replaced from the old machine problem		Latha. K. - ICU	03/06/2022
Comp. Dt. : 10/06/2022								
Status : Completed								
489	22060399	ICU	INFUSION PUMP POWER CARD PROBLEM	Vignesh. D.	POWER CARD CHANGED NOW IT'S WORKING GOOD	AssetNo :16000756	Latha. K. - ICU	11/06/2022
490	22060401	ICU	X-RAY MACHINE NOT WORKING	Vignesh. D.	CHECKED AND FOUND THE CABLE ISSUE IT'S REPLACED NOW WORKING GOOD.	AssetNo :16000697	Latha. K. - ICU	14/06/2022
Comp. Dt. : 27/06/2022								
Status : Completed								

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
491	22060963	ICU	SPO2 PROBE NOT WORKING	Vignesh. D.	CHECKED AND FOUND THE SPO2 SENSOR ISSUE NEED TO REPLACED NEW ONE	AssetNo :16000095	Latha. K. - ICU	27/06/2022
492	22060964	ICU	BP APPARATUS & LARYNGOSCOPE NOT WORKING	Vignesh. D.	CHECKED AND FOUND THE BULB ISSUE IT'S REPLACED NOW IT'S WORKING GOOD		Latha. K. - ICU	27/06/2022
Comp. Dt. : 28/06/2022								
Status : Completed								
493	22060998	ICU	MULTIPARA MONITOR NOT WORKING	Vignesh. D.	checked and found the ecg cable issue it's changed now it's working good	AssetNo :16000056	Rajeshwari. P. - ICU	28/06/2022
Comp. Dt. : 05/07/2022								
Status : Completed								
494	22070130	ICU	SPO2 PROBE NOT WORKING IN MULTIPARA MONITOR	Vignesh. D.	checked and found the probe issue it's replaced now it's working good	AssetNo :16000764	Latha. K. - ICU	06/07/2022
Comp. Dt. : 07/07/2022								
Status : Completed								
495	22070247	ICU	VENTILATOR COMPRESSOR NOT WORKING	Vignesh. D.	checked and found problem in compressor smps. it's changed now it's working good	AssetNo :16000931	Latha. K. - ICU	07/07/2022
Comp. Dt. : 25/07/2022								
Status : Completed								
496	22070907	ICU	BP APPARATUS NOT WORKING	Vignesh. D.	CHECKED AND CHANGED THE BULB NOW WORKING GOOD		Regina Mary. S. - ICU	25/07/2022
Comp. Dt. : 09/08/2022								
Status : Completed								
497	22080335	ICU	SPO2 PROBE NOT WORKING	Vignesh. D.	checked and found that spo2 probe is defective.replaced the new spo2 probe	AssetNo :16000056	Regina Mary. S. - ICU	17/08/2022
Comp. Dt. : 08/09/2022								
Status : Completed								
498	22090325	ICU	"ERROR" DISPLAYING IN ECHO MACHINE	Vignesh. D.	checked and found the software issue it's rectified now working good	AssetNo :16000048	Chandra. S. - ICU	08/09/2022
Comp. Dt. : 21/09/2022								


DR. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
499	22090834	RICU	MULTIPARA MONITOR PROBE NOT WORKING	Vignesh. D.	CHECKED AND FIEND THE SPO2 PROBE ISSUE IT'S REPLACED NOW WORKING GOOD		Jayabharathi. R. - ICU	21/09/2022
Comp. Dt. : 02/11/2022								
Status : Completed								
500	22110027	ICU	VENTILATOR NOT WORKING	Vignesh. D.	o2 sensor REPLACED NOW WORKING GOOD	AssetNo :16000931	Hemamalini. A. - ICU	26/11/2022
Comp. Dt. : 04/11/2022								
Status : Completed								
501	22110142	ICU	ECG MACHINE NOT WORKING	Vignesh. D.	printer door issue.replaced the printer door		Regina Mary. S. - ICU	02/01/2023
Comp. Dt. : 07/11/2022								
Status : Completed								
502	22110225	ICU	PHILIPS MULTIPARA MONITOR NOT WORKING	Vignesh. D.	CHECKED AND FOUND THE ECG CABLE ISSUE IT'S REPLACED NOW WORKING GOOD	AssetNo :16000764	Regina Mary. S. - ICU	07/11/2022
Comp. Dt. : 14/11/2022								
Status : Completed								
503	22110491	ICU	VENTILATOR NOT WORKING	Vignesh. D.	ventilator setting issue it's rectified now working good		Hemamalini. A. - ICU	19/11/2022
Comp. Dt. : 25/11/2022								
Status : Completed								
504	22111116	ICU	MULTIPARA MONITOR SPO2 PROBE NOT WORKING	Vignesh. D.	checked and found the spo2 probe issue it's replaced now working good	AssetNo :16000782	Regina Mary. S. - ICU	29/11/2022
Comp. Dt. : 30/11/2022								
Status : Completed								
505	22111272	ICU	NEED TO CHANGE PHILIP'S MONITOR ECG CABLE-BROKEN	Vignesh. D.	ECG CABLE REPLACED NOW WORKING GOOD		Regina Mary. S. - ICU	01/12/2022
Comp. Dt. : 03/12/2022								
Status : Completed								
506	22120130	ICU	ECG MACHINE NOT WORKING	Vignesh. D.	cable loose connection issue it's rectified now working good		Regina Mary. S. - ICU	07/12/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 23/12/2022 Status : Completed								
507	22121051	ICU	PHILIPS MONITOR SP O2 NOT WORKING	Vignesh. D.	spo2 probe replaced now working good		Regina Mary. S. - ICU	27/12/2022
Comp. Dt. : 12/01/2023 Status : Completed								
508	23010524	ICU	ECG CABLE NOT WORKING	Vignesh. D.	CHECKED AND FOUND THE ECG CABLE ISSUE IT'S REPLACED NOW WORKING GOOD		Chandra. S. - ICU	12/01/2023
Comp. Dt. : 21/01/2023 Status : Completed								
509	23010776	ICU	INFUSION PUMP BOARD NOT WORKING	Vignesh. D.	checked and found that setting issue.setting issue rectified.		Regina Mary. S. - ICU	21/01/2023
510	23010782	ICU	MULTIPARA MONITOR NOT WORKING	Vignesh. D.	checked and found that power connection problem.the problem is rectified.		Latha. K. - ICU	21/01/2023
Comp. Dt. : 27/01/2023 Status : Completed								
511	23010984	ICU	INFUSION PUMP NOT WORKING	Gurumoorthy. G.	checked and found that wire connection problem.the problem is rectified		Hemamalini. A. - ICU	28/01/2023
Comp. Dt. : 07/02/2023 Status : Completed								
512	23020213	ICU	PHILIP'S MONITOR NOT WORKING	Sridhar. K.	checked and found that setting issue.the problem is rectified.		Regina Mary. S. - ICU	07/02/2023
Comp. Dt. : 22/02/2023 Status : Completed								
513	23020872	ICU	(1141) BP APPARATUS NOT WORKING-STEPDOWN ICU	Sridhar. K.	dail replaced working		Latha. K. - ICU	23/02/2023
Comp. Dt. : 01/03/2023 Status : Completed								
514	23030043	ICU	COMMON MONITOR NOT WORKING	Sridhar. K.	key replaced the replaced.		Regina Mary. S. - ICU	01/03/2023
Comp. Dt. : 08/03/2023 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
515	23030299	ICU	X RAY MACHINE NOT WORKING	Vignesh. D.	SWITCH PROBLEM IT RECTIFIED NOW WORKING GOOD	AssetNo :16000697	Regina Mary. S. - ICU	09/03/2023
Comp. Dt. : 30/03/2023 Status : Completed								
516	23031314	ICU	X RAY MACHINE NOT WORKING	Vignesh. D.	checked and found the switch problem it's rectified now working	AssetNo :16000697	Regina Mary. S. - ICU	03/04/2023
Comp. Dt. : 24/04/2023 Status : Completed								
517	23040729	ICU	PROBLEM IN ECHO MACHINE CHARGER	Gurumoorthy. G.	checked and found that wire connection problem.the problem is rectified.		Regina Mary. S. - ICU	24/04/2023
Comp. Dt. : 27/04/2023 Status : Completed								
518	23040898	ICU	ULTRA SOUND MACHINE NOT WORKING	Gurumoorthy. G.	checked and found that adapter wire connection problem.the problem is rectified.		Regina Mary. S. - ICU	02/05/2023
Comp. Dt. : 08/05/2023 Status : Completed								
519	23050284	ICU	MONITOR NOT WORKING	Vignesh. D.	checked and found that power wire connection problem.the problem is rectified.		Latha. K. - ICU	10/05/2023
520	23050323	ICU	B P CUF 2NOS NOT WORKING	Vignesh. D.	replaced the cuff		Regina Mary. S. - ICU	09/05/2023
Comp. Dt. : 18/05/2023 Status : Completed								
521	23050762	ICU	U S G MACHINE CHARGER NOT WORKING	Gurumoorthy. G.	checked and found that charger issue.the problem is rectified.		Jayabharathi. R. - ICU	19/05/2023
Comp. Dt. : 15/06/2023 Status : Completed								
522	23060563	ICU	X RAY MACHINE NOT WORKING	Gokul. P. K.	checked and found that power connection problem.the problem is rectified.		Regina Mary. S. - ICU	16/06/2023
Comp. Dt. : 30/06/2023 Status : Completed								
523	23061116	ICU	B P APPARATUS NOT WORKING	Gokul. P. K.	replaced the bulb with valve		Regina Mary. S. - ICU	30/06/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
524	23061120	ICU	SPO2 [PHILIP'S] MONITOR NOT WORKING	Gurumoorthy. G.	REPLACED THE SPO2 PROBE		Regina Mary. S. - ICU	01/07/2023
Dept Name : Labour Ward - Biomedical Comp. Dt. : 02/05/2022 Status : Completed								
525	22050052	Labour Room	BP APPARATUS NOT WORKING	Gurumoorthy. G.	replaced the bladder		Sathiyavathi. S. - Labour Ward	04/05/2022
Comp. Dt. : 16/05/2022 Status : Completed								
526	22050562	Labour Room	BP APPARATUS 2 NOS NOT WORKING	Gurumoorthy. G.	replaced the bladder		Sathiyavathi. S. - Labour Ward	16/05/2022
Comp. Dt. : 18/05/2022 Status : Completed								
527	22050663	Labour Room	STETHOSCOPE [2NOS] NOT WORKING	Gurumoorthy. G.	checked and found that chest piece replaed now working good..		Sathiyavathi. S. - Labour Ward	20/05/2022
Comp. Dt. : 20/05/2022 Status : Completed								
528	22050756	Labour Room	SPOT LIGHT [2NOS] NOT WORKING	Gurumoorthy. G.	checked and found that lamp problem replaced lamp now working good.		Sathiyavathi. S. - Labour Ward	20/05/2022
Comp. Dt. : 24/05/2022 Status : Completed								
529	22050915	EMERGENCY OT NEAR CASUALTY	SCOPY LIGHT NOT WORKING	Gurumoorthy. G.	replaced the lamp holder and lamp		Hari Hara Sudhan. K. - Operation Theatre	25/05/2022
Comp. Dt. : 01/06/2022 Status : Completed								
530	22060038	Labour Room	NFT MACHINE PROBE NOT WORKING	Vignesh. D.	checked and found that fhr probe problem,service and replaced the probe now working good.	AssetNo :16000314	Sathiyavathi. S. - Labour Ward	02/06/2022
Comp. Dt. : 09/06/2022 Status : Completed								
531	22060333	Labour Room	SPOT LIGHT NOT WORKING	Vignesh. D.	cable connection issue now it's working good		Sathiyavathi. S. - Labour Ward	09/06/2022
Comp. Dt. : 13/06/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
532	22060446	Labour Room	BP APPARATUS NOT WORKING	Vignesh. D.	checked and found that dial problem, replaced new dial now working good.		Aruldevi. M. - Labour Ward	13/06/2022
533	22060456	Labour Room	PEDIATRIC LARYNGOSCOPE NOT WORKING	Vignesh. D.	CHECKED AND FOUND THE ISSUE BATTERY ISSUE IT'S NREPLACED NOW IT'S WORKING GOOD		Sathiyavathi. S. - Labour Ward	14/06/2022
Comp. Dt. : 21/06/2022		Status : Completed						
534	22060757	Labour Room	NIBS CUFF NOT WORKING	Vignesh. D.	CHECKED AND FOUND NIBP CUFF CONNECTION ISSUE. IT RECTIFIED NOW IT'S WORKING GOOD	AssetNo :16000818	Sathiyavathi. S. - Labour Ward	22/06/2022
Comp. Dt. : 27/06/2022		Status : Completed						
535	22060939	Labour Room	BP APPARATUS [3NOS] NOT WORKING	Vignesh. D.	CHECKED AND FOUND THE BULB ISSUE IT'S CHANGED NOW IT'S WORKING GOOD		Brema. V. - Labour Ward	27/06/2022
Comp. Dt. : 09/07/2022		Status : Completed						
536	22070362	Labour Room	ECG & USG MACHINE NOT WORKING	Sridhar. K.	checked and found problem in ecg cable loose problem rectified		Sathiyavathi. S. - Labour Ward	12/07/2022
537	22070379	Labour Room	FETAL DOPPLER NOT WORKING	Sridhar. K.	checked and found that setting problem. rectified the setting issue.		Sathiyavathi. S. - Labour Ward	15/07/2022
Comp. Dt. : 17/08/2022		Status : Completed						
538	22080506	Labour Room	2 NO"S BP APPARATUS NOT WORKING	Vignesh. D.	replaced the bulb with valve and bladder		Sathiyavathi. S. - Labour Ward	17/08/2022
Comp. Dt. : 24/08/2022		Status : Completed						
539	22080813	Labour Room	N F T MACHINE PROBE NOT WORKING	Vignesh. D.	CHECKED AND FOUND THE PRIENTER ISSUE. adjusted the prienter door now working good		Sathiyavathi. S. - Labour Ward	01/09/2022
Comp. Dt. : 29/08/2022		Status : Completed						
540	22080984	Labour Room	LARYNGOSCOPE [PAEDIATRIC] NOT WORKING	Vignesh. D.	LOOSE CONNECTION ISSUE IT REFIXED NOW WORKING GOOD		Sathiyavathi. S. - Labour Ward	29/08/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 14/09/2022 Status : Completed								
541	22090537	Labour Room	SUCTION APPARATUS NOT WORKING	Vignesh. D.	TUBE LOOSE CONNECTION ISSUE IT'S RECTIFIED NOW WORKING GOOD		Krishnadevi. D. - Labour Ward	14/09/2022
Comp. Dt. : 15/09/2022 Status : Completed								
542	22090602	labour room -pow	CARDIAC MONITOR NOT WORKING	Vignesh. D.	cable issue it's replaced now working good		Sevvanthi. T. - Labour Ward	27/09/2022
Comp. Dt. : 21/09/2022 Status : Completed								
543	22090810	Labour Room	BP APPARATUS & THERMOMETER 2NOS - NOT WORKING	Vignesh. D.	BULB AND BATTERY CHANGED NOW WORKING GOOD		Sathiyavathi. S. - Labour Ward	21/09/2022
Comp. Dt. : 23/09/2022 Status : Completed								
544	22090934	labour room -pow	NEED TO CHANGE MONITOR PULSE OXI METER PROBE	Vignesh. D.	porbe replaced no working good		Priyanka. R. - Labour Ward	27/09/2022
Comp. Dt. : 28/09/2022 Status : Completed								
545	22091127	Labour Room	NEED TO CHECK MULTIPARA MONITOR SPO2 PROBE & N I BP CUFF - NOT WORKING	Vignesh. D.	checked and found the spo2 prob, nibp cuff & nibp hose replaced now working good.	AssetNo :16000818	Sathiyavathi. S. - Labour Ward	30/09/2022
Comp. Dt. : 05/10/2022 Status : Completed								
546	22100059	Labour Room	SPOT LIGHT NOT WORKING	Vignesh. D.	bulb replaced now working good		Kodhai. T. - Labour Ward	05/10/2022
Comp. Dt. : 06/10/2022 Status : Completed								
547	22100123	Labour Room	BP APPARATUS BULB NOT WORKING & BROKEN	Sridhar. K.	services now working		Krishnadevi. D. - Labour Ward	06/10/2022
Comp. Dt. : 12/10/2022 Status : Completed								
548	22100321	Labour Room	SPOT LIGHT NOT WORKING	Vignesh. D.	replaced the lamp holder		Krishnadevi. D. - Labour Ward	14/10/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
549	22100345	labour room -pow	MULTIPARA MONITOR N A BP PROBE NOT WORKING	Vignesh. D.	checked and found that nibp cuff defective.replaced the nibp cuff		Priyanka. R. - Labour Ward	14/10/2022
Comp. Dt. : 07/11/2022 Status : Completed								
550	22110259	Labour Room	FOCUS LIGHT NOT WORKING	Vignesh. D.	CHECKED AND FOUND THE BULB ISSUE IT'S REPLACED NOW WORKING GOOD		Kirupavathy. S. - Labour Ward	09/11/2022
Comp. Dt. : 09/11/2022 Status : Completed								
551	22110329	Labour Room	SPOT LIGHT NOT WORKING	Vignesh. D.	WIRE CONNECTION ISSUE IT'S REPLACED NOW WORKING GOOD		Krishnadevi. D. - Labour Ward	09/11/2022
Comp. Dt. : 17/11/2022 Status : Completed								
552	22110700	Labour Room	NST MACHINE NOT WORKING	Vignesh. D.	printer issue cleaned and fixed the printer door now working good		Sathiyavathi. S. - Labour Ward	19/11/2022
Comp. Dt. : 18/11/2022 Status : Completed								
553	22110772	Labour Room	PROBLEM IN N S T PRINTER	Vignesh. D.	printer issue it's rectified now working good		Usharani. A. - Labour Ward	19/11/2022
Comp. Dt. : 21/11/2022 Status : Completed								
554	22110875	Labour Room	NST MACHINE NOT WORKING	Gurumoorthy. G.	printer roller cleaned now working good		Kirupavathy. S. - Labour Ward	23/11/2022
Comp. Dt. : 23/11/2022 Status : Completed								
555	22110988	Labour Room	NST MACHINE PRINTING WAS NOT CLEAR	Vignesh. D.	PRINTER DOOR ADJUSED NOW WORKING GOOD		Kanimozhi. S. - Labour Ward	26/11/2022
Comp. Dt. : 24/11/2022 Status : Completed								
556	22111049	labour room -pow	MONITOR BP CUFF NOT WORKING	Vignesh. D.	checked and found that nibp cuff conector problem.the problem is rectified.		Brema. V. - Labour Ward	26/11/2022
Comp. Dt. : 26/11/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
557	22111123	Labour Room	MULTIPARA MONITOR NOT WORKING	Vignesh. D.	CHECKED AND FOUND THE NIBI CUFF LOOSE CONNECTION ISSUE IT'S REPLACED NOW WORKING GOOD		Brema. V. - Labour Ward	26/11/2022
Comp. Dt. : 28/11/2022 Status : Completed								
558	22111182	Labour Room	BP CUFF NOT WORKING	Vignesh. D.	replaced the cuff		Sathiyavathi. S. - Labour Ward	30/11/2022
559	22111189	labour room -pow	BP APPARATUS NOT WORKING	Vignesh. D.	replaced the bladder		Brema. V. - Labour Ward	29/11/2022
Comp. Dt. : 03/12/2022 Status : Completed								
560	22120105	labour room -pow	PULSE MONITOR NOT WORKING	Vignesh. D.	checked and found the probe loose connetion issue it's rectified now working good		Brema. V. - Labour Ward	07/12/2022
Comp. Dt. : 05/12/2022 Status : Completed								
561	22120208	Labour Room	2 NO'S BP CUFF NOT WORKING	Gurumoorthy. G.	NIBP CUFF replaced now working good		Kirupavathy. S. - Labour Ward	07/12/2022
Comp. Dt. : 19/12/2022 Status : Completed								
562	22120852	Labour Room	O2 HUMIDIFIER LEAKAGE	Sridhar. K.	GAS PLANT COMPLAINT		Kirupavathy. S. - Labour Ward	21/12/2022
Comp. Dt. : 20/12/2022 Status : Completed								
563	22120893	Labour Room	MULTIPARA MONITOR NOT WORKING	Vignesh. D.	NIBP MODULE REPLACED NOW WORKING GOOD	AssetNo :16000807	Sathiyavathi. S. - Labour Ward	21/12/2022
Comp. Dt. : 03/01/2023 Status : Completed								
564	23010094	Labour Room	2 NO'S NST MACHINE NOT WORKING	Vignesh. D.	CHECKED AND FOUND THE PROBLEM IN PRINTER ISSUE IT'S RECTIFIED NOW WORKING GOOD	AssetNo :16000834	Sathiyavathi. S. - Labour Ward	03/01/2023
Comp. Dt. : 13/01/2023 Status : Completed								
565	23010542	Labour Room	2 NOS BP APPARATUS NOT WORKING	Vignesh. D.	REPALED THE BLADDER		Sathiyavathi. S. - Labour Ward	14/01/2023
Comp. Dt. : 18/01/2023								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
566	23010646	labour room -pow	SPO2 PULSE OXIMETER PROBE NOT WORKING	Gurumoorthy. G.	replaced spo2 probe working		Brema. V. - Labour Ward	20/01/2023
Comp. Dt. : 01/02/2023								
Status : Completed								
567	23020004	Labour Room	BP APPARATUS NOT WORKING	Gurumoorthy. G.	replaced the bladder		Aruldevi. M. - Labour Ward	01/02/2023
Comp. Dt. : 03/02/2023								
Status : Completed								
568	23020104	Labour Room	NFT MACHINE PROBE NOT WORKING	Gurumoorthy. G.	checked and found that wire connection problem.the problem is rectified.		Sathiyavathi. S. - Labour Ward	06/02/2023
Comp. Dt. : 10/02/2023								
Status : Completed								
569	23020407	Labour Room	O2 LEAKAGE	Gurumoorthy. G.	KEY PLUG CONECTION PROBLEM.THE PROBLEM IS RECTIFIED		Kanimozhi. S. - Labour Ward	13/02/2023
570	23020408	Labour Room	BP APPARATUS NOT WORKING	Gurumoorthy. G.	serviced now working		Kanimozhi. S. - Labour Ward	13/02/2023
Comp. Dt. : 17/02/2023								
Status : Completed								
571	23020696	Labour Room	NST PROBE & BP APPARATUS NOT WORKING	Vignesh. D.	NST PROBE REPLACED NOW WORKING GOOD		Sathiyavathi. S. - Labour Ward	17/02/2023
Comp. Dt. : 21/02/2023								
Status : Completed								
572	23020814	labour room -pow	MULTIPARA MONITOR NOT WORKING	Vignesh. D.	replaced nibp cuff m/p monitor working		Brema. V. - Labour Ward	22/02/2023
Comp. Dt. : 28/02/2023								
Status : Completed								
573	23021061	Labour Room	BP APPARATUS NOT WORKING	Gurumoorthy. G.	serviced now working		Sathiyavathi. S. - Labour Ward	01/03/2023
Comp. Dt. : 04/03/2023								
Status : Completed								
574	23030160	Labour Room	B APPARATUS NOT WORKING	Vignesh. D.	bulb replaced now working good		Usharani. A. - Labour Ward	04/03/2023
Comp. Dt. : 14/03/2023								
Status : Completed								
575	23030551	Labour Room	BP CUFF 2NOS NOT WORKING	Sridhar. K.	replaced the cuff		Sathiyavathi. S. - Labour Ward	14/03/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 12/04/2023 Status : Completed								
576	23040355	Labour Room	B P APPARATUS NOT WORKING	Gurumoorthy. G.	replaced the bulb with valve		Sathiyavathi. S. - Labour Ward	12/04/2023
Comp. Dt. : 02/05/2023 Status : Completed								
577	23050011	Labour Room	SPOT LIGHT 5 NOS NOT WORKING	Gurumoorthy. G.	replaced the lamp		Kodhai. T. - Labour Ward	02/05/2023
Comp. Dt. : 04/05/2023 Status : Completed								
578	23050124	Labour Room	B. P APPARATUS NOT WORKING	Gurumoorthy. G.	replaced the bladder		Sathiyavathi. S. - Labour Ward	05/05/2023
Comp. Dt. : 22/05/2023 Status : Completed								
579	23050855	Labour Room	BP APPARATUS NOT WORKING	Gurumoorthy. G.	serviced now working		Sathiyavathi. S. - Labour Ward	23/05/2023
Comp. Dt. : 23/05/2023 Status : Completed								
580	23050899	Labour Room	MONITOR PROBE NOT WORKING	Gurumoorthy. G.	spo2 probe replaced	AssetNo :16000807	Santhiya. A. - Labour Ward	25/05/2023
Comp. Dt. : 29/05/2023 Status : Completed								
581	23051113	Labour Room	BP APPARATUS [3 NOS] NOT WORKING	Gurumoorthy. G.	replaced the bladder and duff		Kanimozhi. S. - Labour Ward	30/05/2023
582	23051140	labour room -pow	BP CUFF NOT WORKING	Gurumoorthy. G.	replaced the cuff		Brema. V. - Labour Ward	30/05/2023
Comp. Dt. : 14/06/2023 Status : Completed								
583	23060497	Labour Room	NEED TO CHECK B P APPARATUS & BP CUFF IN MONITOR NOT WORKING	Gokul. P. K.	replaced the cuff		Sathiyavathi. S. - Labour Ward	15/06/2023
Comp. Dt. : 17/06/2023 Status : Completed								
584	23060636	Labour Room	B P CUFF [2NOS] NOT WORKING	Gurumoorthy. G.	replaced the cuff		Sathiyavathi. S. - Labour Ward	19/06/2023
Comp. Dt. : 21/06/2023 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
585	23060749	labour room -pow	MULTIPARA MONITOR NOT WORKING	Gokul. P. K.	checked and found that cuff airleakage issue.the problem is rectified.		Brema. V. - Labour Ward	21/06/2023
Comp. Dt. :		23/06/2023						
Status :		Completed						
586	23060881	Labour Room	WARMER TEMPARETURE PROBLEM	Gurumoorthy. G.	checked the machine problem in temperature cable connection problem.the problem is rectified.		Sathiyavathi. S. - Labour Ward	26/06/2023
Comp. Dt. :		26/06/2023						
Status :		Completed						
587	23060963	labour room -pow	MULTIPARA MONITOR NOT WORKING [2 NOS]	Sridhar. K.	GENRAL SERVICES NOW WORKING		Brema. V. - Labour Ward	28/06/2023
Dept Name :		Library - Biomedical						
Comp. Dt. :		15/02/2023						
Status :		Completed						
588	23020564	DENTAL OPD -2ND FLOOR	NEED TO REFIX DENTAL CHAIR X RAY LOBBY - UNFIX	Sridhar. K.	fixed the x-ray lobby		Lakshmi Gandhan.S. - Library	17/02/2023
Dept Name :		Male Medical Ward - Biomedical						
Comp. Dt. :		10/05/2022						
Status :		Completed						
589	22050353	Male Medical - Ward 303	BP APPARATUS NOT WORKING	Vignesh. D.	replaced the bladder.		Vijayalakshmi. S. - Male Medical Ward	11/05/2022
590	22050357	Male Medical - Ward 302	BP CUFF NOT WORKING	Gurumoorthy. G.	replaced the cuff		Daniel Joseph - POW & SICU	11/05/2022
591	22050360	Male Medical - Ward 301	ECG MACHINE NOT WORKING	Sridhar. K.	checked and found that cable loose connection problem,cable refixed now working good.		Soniya Gandhi. A. - Male Medical Ward	12/05/2022
Comp. Dt. :		11/05/2022						
Status :		Completed						
592	22050392	Male Medical - Ward 304	NEBULIZER NOT WORKING	Gurumoorthy. G.	checked and found that found that power cable connection problem.the problem is rectfied.now its wor		Vijayalakshmi. S. - Male Medical Ward	12/05/2022
Comp. Dt. :		14/05/2022						
Status :		Completed						

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
593	22050503	Male Medical - Ward 301	BP CUFF NOT WORKING	Sridhar. K.	checked and found that nibp hose connection problem.the problem is rectified.		Yugapriya. M. - Male Medical Ward	14/05/2022
Comp. Dt. : 17/05/2022 Status : Completed								
594	22050588	Male Medical Ward	BP APPARATUS NOT WORKING 2NOS [WARD NO 301 & 302]	Gurumoorthy. G.	checked and found that dial nedle problem,adjsument done now working good.		Soniya Gandhi. A. - Male Medical Ward	18/05/2022
Comp. Dt. : 27/05/2022 Status : Completed								
595	22051025	Male Medical - Ward 304	LARYNGOSCOPE BLADE NOT WORKING	Gurumoorthy. G.	replaced the lamp		Vijayalakshmi. S. - Male Medical Ward	30/05/2022
Comp. Dt. : 30/05/2022 Status : Completed								
596	22051072	Male Medical - Ward 302	ECG MACHINE NOT WORKING	Gurumoorthy. G.	checked and found that ecg cable connection problem.the problem is rectified.	AssetNo :16000288	Soniya Gandhi. A. - Male Medical Ward	31/05/2022
Comp. Dt. : 02/06/2022 Status : Completed								
597	22060066	Male Medical - Ward 303	MONITOR NOT WORKING	Sridhar. K.	checked and found that display issue need to replace new one		Vijayalakshmi. S. - Male Medical Ward	29/07/2022
598	22060092	Male Medical - Ward 303	BP APPARATUS NOT WORKING	Vignesh. D.	checked and found that dial problem,replaced new dial now working good.		Vijayalakshmi. S. - Male Medical Ward	02/06/2022
Comp. Dt. : 13/06/2022 Status : Completed								
599	22060471	Male Medical - Ward 301	THERMOMETER NOT WORKING	Vignesh. D.	BOARD ISSUE IT'S CONDEMED. RECOMMENED TO PURCHASE NEW ONE		Soniya Gandhi. A. - Male Medical Ward	14/06/2022
Comp. Dt. : 20/06/2022 Status : Completed								
600	22060721	Male Medical - Ward 301	O2 CONCENTRATION NOT WORKING	Sridhar. K.	cable connection issue it's rectified now it's working good		Aravind. M. - Male Medical Ward	24/06/2022
Comp. Dt. : 27/06/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
601	22060958	Male Medical - Ward 301	NEBULIZER NOT WORKING	Sridhar. K.	CHECKED AND DONE THE GENERAL SERVICE NOW IT'S WORKING GOOD		Soniya Gandhi. A. - Male Medical Ward	27/06/2022
	Comp. Dt. : 29/06/2022 Status : Completed							
602	22061079	Male Medical - Ward 301	BP APPARATUS NOT WORKING	Gurumoorthy. G.	replaced the bladder		Soniya Gandhi. A. - Male Medical Ward	29/06/2022
	Comp. Dt. : 07/07/2022 Status : Completed							
603	22070272	Male Medical - Ward 303	NEED TO CHECK STETHOSCOPE & B P APPARATUS BULB - NOT WORKING	Gurumoorthy. G.	replaced the steth frame and bladder		Vijayalakshmi. S. - Male Medical Ward	09/07/2022
	Comp. Dt. : 22/07/2022 Status : Completed							
604	22070832	Male Medical - Ward 301	BP APPARATUS NOT WORKING	Gurumoorthy. G.	BULB REPLACED NOW IT'S WORKING GOOD		Soniya Gandhi. A. - Male Medical Ward	23/07/2022
	Comp. Dt. : 26/07/2022 Status : Completed							
605	22070948	Male Medical - Ward 301	SPO2 PROBE IN MULTIPARA NOT WORKING	Sridhar. K.	probe replaced now it's working good		Geedhanjali. I - Male Medical Ward	29/07/2022
	Comp. Dt. : 27/07/2022 Status : Completed							
606	22071014	Male Medical - Ward 301	BP APPARATUS 2NOS NOT WORKING	Vignesh. D.	checked and find the bulb issue it's replaced now it's working good		Vijayalakshmi. S. - Male Medical Ward	27/07/2022
	Comp. Dt. : 05/08/2022 Status : Completed							
607	22080196	Male Medical - Ward 302	BP APPARTUS [2NOS] NOT WORKING	Sridhar. K.	replace the bladder,cuff,bulb.now its working good		Vijayalakshmi. S. - Male Medical Ward	05/08/2022
	Comp. Dt. : 11/08/2022 Status : Completed							
608	22080422	Male Medical - Ward 301	multi para moniter not working,	Sridhar. K.	genral services now its working		Nirmalraj. R. - Male Medical Ward	13/08/2022
	Comp. Dt. : 13/08/2022 Status : Completed							
609	22080478	Male Medical - Ward 301	MONIOTR PROBE NOT WORKING	Sridhar. K.	spo2 probe replace now its working		Soniya Gandhi. A. - Male Medical Ward	22/08/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 18/08/2022								
Status : Completed								
610	22080561	Male Medical - Ward 301	BP APPARATUS NOT WORKING	Gurumoorthy. G.	bp cuff with bladder replacement		Soniya Gandhi. A. - Male Medical Ward	18/08/2022
Comp. Dt. : 05/09/2022								
Status : Completed								
611	22090153	Male Medical - Ward 301	DEFIBRILLATOR NOT WORKING	Sridhar. K.	CHECKED AND DONE THE PREUSE CHECK NOW WORKING GOOD	AssetNo :16000963	Soniya Gandhi. A. - Male Medical Ward	05/09/2022
Comp. Dt. : 15/09/2022								
Status : Completed								
612	22090614	Male Medical - Ward 301	BP APPARATUS NOT WORKING	Vignesh. D.	bulb changed now working good		Soniya Gandhi. A. - Male Medical Ward	16/09/2022
Comp. Dt. : 20/09/2022								
Status : Completed								
613	22090783	Male Medical - Ward 302	BP APPARATUS [2NOS] NOT WORKING	Gurumoorthy. G.	services its working		Soniya Gandhi. A. - Male Medical Ward	24/09/2022
Comp. Dt. : 29/09/2022								
Status : Completed								
614	22091174	Male Medical - Ward 301	WEIGHT MACHINE NOT WORKING	Sridhar. K.	genral services working		Soniya Gandhi. A. - Male Medical Ward	30/09/2022
Comp. Dt. : 05/10/2022								
Status : Completed								
615	22100061	Male Medical - Ward 301	THERMO METER NOT WORKING	Gurumoorthy. G.	battery changed now working good		Vijayalakshmi. S. - Male Medical Ward	05/10/2022
Comp. Dt. : 08/10/2022								
Status : Completed								
616	22100169	Male Medical - Ward 301	BP APPARATUS NOT WORKING	Gurumoorthy. G.	replced the bulb with valve		Soniya Gandhi. A. - Male Medical Ward	10/10/2022
Comp. Dt. : 13/10/2022								
Status : Completed								
617	22100418	Male Medical - Ward 303	BP APPARATUS CUFF NOT WORKING	Gurumoorthy. G.	replaced the cuff		Vijayalakshmi. S. - Male Medical Ward	14/10/2022
Comp. Dt. : 20/10/2022								
Status : Completed								
618	22100695	Male Medical - Ward 301	BP APPARITIS NOT WORKING	Sridhar. K.	services its now worknig		Karthika. S. - Female surgery	21/10/2022
Comp. Dt. : 26/10/2022								
Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
619	22100791	Male Medical - Ward 301	BP APPARATUS NOT WORKING	Gurumoorthy. G.	genral serviced working		Kanmani. R. - Male Medical Ward	26/10/2022
	Comp. Dt. : 27/10/2022 Status : Completed							
620	22100865	Male Medical - Ward 301	BP APPARATUS NOT WORKING	Sridhar. K.	REPLACED THE BLADDER		Vijayalakshmi. S. - Male Medical Ward	28/10/2022
	Comp. Dt. : 28/10/2022 Status : Completed							
621	22100908	Male Medical - Ward 301	BP APPARATUS NOT WORKING	Gurumoorthy. G.	REPLACED THE BULB WITH VALVE		Soniya Gandhi. A. - Male Medical Ward	28/10/2022
	Comp. Dt. : 14/11/2022 Status : Completed							
622	22110492	RICU	MONITOR NOT WORKING - 2 NOS	Vignesh. D.	BOARD SERICED NOW WORKING GOOD		Vijay. N. - Male Medical Ward	01/12/2022
623	22110536	Male Medical - Ward 301	MULTIPARA MOT WORKING	Sridhar. K.	re complaint		Soniya Gandhi. A. - Male Medical Ward	21/11/2022
	Comp. Dt. : 16/11/2022 Status : Completed							
624	22110673	Male Medical - Ward 301	MULTIPARA MONITOR NOT WORKING	Sridhar. K.	spo2 sensor, ext cable replaced	AssetNo :16000821	Vijayalakshmi. S. - Male Medical Ward	21/11/2022
	Comp. Dt. : 12/12/2022 Status : Completed							
625	22120523	Male Medical - Ward 301	ECG MACHINE NOT WORKING	Sridhar. K.	genral services working		Vijayalakshmi. S. - Male Medical Ward	15/12/2022
	Comp. Dt. : 23/12/2022 Status : Completed							
626	22121058	Male Medical - Ward 302	NEBULIZER NOT WORKING	Sridhar. K.	serviced now working		Soniya Gandhi. A. - Male Medical Ward	24/12/2022
	Comp. Dt. : 26/12/2022 Status : Completed							
627	22121190	Male Medical - Ward 301	ECG MACHINE NOT WORKING	Sridhar. K.	re complaint		Soniya Gandhi. A. - Male Medical Ward	28/12/2022
	Comp. Dt. : 31/12/2022 Status : Completed							
628	22121410	Male Medical - Ward 301	WALL MOUNTED SCUTION APPARATUS NOT WORKING	Sridhar. K.	gas plant complaint		Geedhanjali. I - Male Medical Ward	02/01/2023
	Comp. Dt. : 12/01/2023 Status : Completed							


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
629	23010536	Male Medical - Ward 301	DIGITAL WEIGHT MACHINE NOT WORKING	Sridhar. K.	battery replaced		Soniya Gandhi. A. - Male Medical Ward	13/01/2023
	Comp. Dt. : 31/01/2023							
	Status : Completed							
630	23011100	Male Medical - Ward 303	CPG MACHINE & B P APPARATUS NOT WORKING	Gurumoorthy. G.	replaced the battery and bulb with valve		Daniel Joseph - POW & SICU	31/01/2023
	Comp. Dt. : 06/02/2023							
	Status : Completed							
631	23020176	Male Medical - Ward 301	LARYXGOSCOPE PROBLEM	Gurumoorthy. G.	replaced the bulb		Karthikeyan. I. - Male Medical Ward	06/02/2023
632	23020190	Male Medical - Ward 303	BP APPARATUS 2NOS NOT WORKING	Gurumoorthy. G.	replaced the bulb with valve		Vijayalakshmi. S. - Male Medical Ward	06/02/2023
	Comp. Dt. : 10/03/2023							
	Status : Completed							
633	23030435	Male Medical - Ward 303	BP APPARATUS NOT WORKING	Vignesh. D.	replaced te bulb with valve		Vijayalakshmi. S. - Male Medical Ward	13/03/2023
	Comp. Dt. : 24/04/2023							
	Status : Completed							
634	23040743	Male Medical - Ward 302	B P APPARATUS NOT WORKING	Gurumoorthy. G.	replaced the bladder		Mohamed Irfan Ali. A. - Male Medical Ward	24/04/2023
	Comp. Dt. : 02/05/2023							
	Status : Completed							
635	23050008	Male Medical - Ward 303	B P APPARATUS NOT WORKING	Gurumoorthy. G.	replaced the bulb with valve		Vijayalakshmi. S. - Male Medical Ward	02/05/2023
	Comp. Dt. : 08/05/2023							
	Status : Completed							
636	23050263	Male Medical - Ward 303	NEED TO CHANGE B.P APPARATUS CUFF	Gurumoorthy. G.	replaced the cuff		Vijayalakshmi. S. - Male Medical Ward	09/05/2023
	Comp. Dt. : 17/05/2023							
	Status : Completed							
637	23050680	ICU	ECG MACHINE NOT WORKING - OLD ICU	Gurumoorthy. G.	checked and found that ECG cable issue.the problem is rectified.		Vijay. N. - Male Medical Ward	17/05/2023
	Comp. Dt. : 20/05/2023							
	Status : Completed							
638	23050827	Female Medical - Ward 306	WEIGHT MACHINE NOT WORKING	Gurumoorthy. G.	serviced now working		Sujitha. G. - Male Medical Ward	23/05/2023
	Comp. Dt. : 22/05/2023							


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
639	23050881	Male Medical - Ward 301	MULTIPARA MONITOR CABLE NOT WORKING	Sridhar. K.	ecg cable replaced	AssetNo :16000821	Geedhanjali. I - Male Medical Ward	23/05/2023
Comp. Dt. : 31/05/2023								
Status : Completed								
640	23051253	Male Medical - Ward 303	MULTIPARA MONITOR 2NOS NOT WORKING	Sridhar. K.	wire connection problem.the problem is rectified.		Vijayalakshmi. S. - Male Medical Ward	02/06/2023
Comp. Dt. : 22/06/2023								
Status : Completed								
641	23060834	Male Medical - Ward 301	BP APPARATUS NOT WORKING	Gokul. P. K.	replaced the dial		Geedhanjali. I - Male Medical Ward	22/06/2023
Dept Name : Male Ortho Ward - Biomedical								
Comp. Dt. : 13/05/2022								
Status : Completed								
642	22050470	Male Ortho - Ward 404	BP APPARATUS NOT WORKING	Gurumoorthy. G.	checked and found that dial problem replaced new dial,now working good.		Rajasree. R. - Male Ortho Ward	13/05/2022
Comp. Dt. : 24/05/2022								
Status : Completed								
643	22050902	Male Ortho Ward	ECG MACHINE NOT WORKING WARD NO 403 & 404	Sridhar. K.	CHECKED AND FOUND THE ISSUE GENERAL SERVICE DONE NOW IT'S WORKING GOOD		Rajasree. R. - Male Ortho Ward	25/05/2022
Comp. Dt. : 30/06/2022								
Status : Completed								
644	22061129	Male Ortho Ward	BP APPARATUS NOT WORKING - WARD NO 403 & 404	Vignesh. D.	bulb changed now it's working good		Rajasree. R. - Male Ortho Ward	30/06/2022
Comp. Dt. : 03/08/2022								
Status : Completed								
645	22080116	Male Ortho Ward	NEED TO CHECK BP APPARATUS CUFF [3NOS] DAMAGE	Sridhar. K.	CHECKED AND REPLACED THE BULB NOW IT'S WORKING GOOD		Rajasree. R. - Male Ortho Ward	03/08/2022
Comp. Dt. : 06/08/2022								
Status : Completed								
646	22080240	Male Ortho - Ward 403	ECG MACHINE NOT WORKING	Sridhar. K.	ecg cable lose connection problem rectified now its working	AssetNo :21000289	Rajasree. R. - Male Ortho Ward	09/08/2022
Comp. Dt. : 10/08/2022								

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
647	22080363	Male Ortho - Ward 404	NEED TO CHECK BP APPARATUS BULB - NOT WORKING	Sridhar. K.	GENERAL SERVICE NOW ITS WORKING GOOD		Maheswari. J. - Male Ortho Ward	10/08/2022
Comp. Dt. : 23/08/2022								
Status : Completed								
648	22080740	Male Ortho Ward	ECG MACHINE NOT WORKING - WARD NO 403 & 404	Gurumoorthy. G.	checked and found that ECG cable to electrode connection problem.the problem is rectified.	AssetNo :16000289	Rajasree. R. - Male Ortho Ward	23/08/2022
Comp. Dt. : 03/09/2022								
Status : Completed								
649	22090128	Male Ortho - Ward 403	THERMO METER NOT WORKING	Vignesh. D.	BATTERY CHANGED NOW WORKING GOOD		Jenit Jerlin. D. - Male Ortho Ward	03/09/2022
Comp. Dt. : 15/09/2022								
Status : Completed								
650	22090578	Male Ortho - Ward 403	BP APPARATUS 2NOS NOT WORKING	Vignesh. D.	bulb changed now working good		Vanitha. P. - Male Ortho Ward	16/09/2022
651	22090600	Male Ortho - Ward 404	X RAY MACHINE NOT WORKING	Sridhar. K.	3pin top issue it's replaced now working good		Vanitha. P. - Male Ortho Ward	27/09/2022
652	22090609	Male Ortho Ward	X RAY & ECG MACHINE NOT WORKING	Sridhar. K.	cable issue it's replaced now working good		Rajasree. R. - Male Ortho Ward	27/09/2022
Comp. Dt. : 17/09/2022								
Status : Completed								
653	22090681	Male Ortho - Ward 404	SUCTION APPARATUS NOT WORKING	Vignesh. D.	checked and found that hose connection problem.rectified the hose connection.		Rajasree. R. - Male Ortho Ward	24/09/2022
Comp. Dt. : 28/09/2022								
Status : Completed								
654	22091096	Male Ortho Ward	NEED TO CHECK MULTIPARA MONITOR N B C CUFF & ECG CABLE - NOT WORKING	Sridhar. K.	replaced the nibp hose,nibp cuff,ecg clamp electrode and ecg bulb	AssetNo :16000017	Rajasree. R. - Male Ortho Ward	28/09/2022
655	22091097	Male Ortho Ward	NEED TO CHANGE SUCTION APPARATUS BOTTLE - BROKEN AT WARD NO 403 & 404	Sridhar. K.	checked and found that hose connection problem.the problem is rectified		Rajasree. R. - Male Ortho Ward	28/09/2022
Comp. Dt. : 13/10/2022								
Status : Completed								
656	22100410	Male Ortho Ward	BP APPARATUS [2NOS] NOT WORKING - WARD NO 403 & 404	Vignesh. D.	replaced the bladder and cuff		Rajasree. R. - Male Ortho Ward	14/10/2022

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHAL KUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 18/10/2022 Status : Completed								
657	22100607	Male Ortho - Ward 403	ECG MACHINE NOT WORKING	Sridhar. K.	GENRAL SERVICES WORKING		Rajasree. R. - Male Ortho Ward	19/10/2022
Comp. Dt. : 03/11/2022 Status : Completed								
658	22110064	Male Ortho - Ward 404	THERMOMETER NOT WORKING	Gurumoorthy. G.	replaced the battery		Gayathri. S. - Male Ortho Ward	03/11/2022
Comp. Dt. : 04/11/2022 Status : Completed								
659	22110114	Male Surgery - Ward 203	BP APPARATUS NOT WORKING	Gurumoorthy. G.	BULB CHANGED NOW WORKING GOOD		Vanitha. P. - Male Ortho Ward	05/11/2022
Comp. Dt. : 09/11/2022 Status : Completed								
660	22110348	Male Ortho - Ward 403	X-RAY MACHINE NOT WORKING	Sridhar. K.	checked and found that wire connection problem.the problem is rectified.		Manikandan. V. - Male Ortho Ward	19/11/2022
661	22110353	Male Ortho - Ward 403	PORTABLE SUCTION APPARATUS NOT WORKING	Sridhar. K.	tupe loose its working		Manikandan. V. - Male Ortho Ward	21/11/2022
Comp. Dt. : 10/11/2022 Status : Completed								
662	22110418	Male Surgery - Ward 204	1 BP APPARATUS NOT WORKING	Vignesh. D.	bladder replaced now working good		Vanitha. P. - Male Ortho Ward	10/11/2022
Comp. Dt. : 15/11/2022 Status : Completed								
663	22110572	Male Ortho - Ward 403	ECG MACHINE LEAD NOT WORKING	Sridhar. K.	cable loose its now working		Manjula. P. - Male Ortho Ward	21/11/2022
Comp. Dt. : 29/11/2022 Status : Completed								
664	22111209	Male Ortho - Ward 403	ECG MACHINE NOT WORKING	Sridhar. K.	CABLE LOOSE CONNECTION ISSUE IT;S RECTIFIED NOW WORKING GOOD		Rajasree. R. - Male Ortho Ward	01/12/2022
665	22111210	Male Ortho - Ward 403	BP APPARATUS CUFF NOT WORKING	Gurumoorthy. G.	cuff, badder replaced		Rajasree. R. - Male Ortho Ward	30/11/2022
Comp. Dt. : 02/12/2022 Status : Completed								
666	22120053	Male Surgery - Ward 203	BP APPARATUS (2 nos) NOT WORKING	Sridhar. K.	serviced now working		Vanitha. P. - Male Ortho Ward	02/12/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 08/12/2022 Status : Completed								
667	22120386	Male Ortho - Ward 403	ECG MACHINE NOT WORKING	Sridhar. K.	COMPLAINT ALREADY REGISTERED		Rajasree. R. - Male Ortho Ward	08/12/2022
668	22120387	Male Ortho - Ward 404	ECG MACHINE NOT WORKING	Vignesh. D.	paper sensor replaced	AssetNo :16000289	Rajasree. R. - Male Ortho Ward	09/12/2022
Comp. Dt. : 15/12/2022 Status : Completed								
669	22120714	Male Ortho Ward	ECG MACHINE NOT WORKING	Sridhar. K.	checked and found that ecg cable connection problem.the problem is rectified.		Rajasree. R. - Male Ortho Ward	17/12/2022
Comp. Dt. : 17/12/2022 Status : Completed								
670	22120822	Male Surgery - Ward 203	PULSE OXIMETER NOT WORKING	Sridhar. K.	checked and found that spo2 sensor issue.replaced the spo2 cable		Vanitha. P. - Male Ortho Ward	02/01/2023
Comp. Dt. : 11/01/2023 Status : Completed								
671	23010471	Male Surgery - Ward 203	3 NO'S BP APPARATUS NOT WORKING	Vignesh. D.	bulb replaced now working good		Vanitha. P. - Male Ortho Ward	11/01/2023
Comp. Dt. : 01/02/2023 Status : Completed								
672	23020036	Male Surgery - Ward 203	BP APPARATUS 2NOS NOT WORKING	Gurumoorthy. G.	replaced the bulb with valve		Vanitha. P. - Male Ortho Ward	03/02/2023
Comp. Dt. : 02/02/2023 Status : Completed								
673	23020052	Male Ortho Ward	DIGITAL THERMOMETER NOT WORKING	Gurumoorthy. G.	replaced the battery		Rajasree. R. - Male Ortho Ward	04/02/2023
Comp. Dt. : 15/02/2023 Status : Completed								
674	23020567	Male Ortho - Ward 404	BP APPARATUS NOT WORKING	Sridhar. K.	replaced the bladder		Gayathri. S. - Male Ortho Ward	17/02/2023
Comp. Dt. : 22/02/2023 Status : Completed								
675	23020874	Male Ortho - Ward 404	ECG MACHINE NOT WORKING	Sridhar. K.	genral serviced now working		Rajasree. R. - Male Ortho Ward	23/02/2023
Comp. Dt. : 01/04/2023 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
676	23040016	Male Ortho - Ward 403	SUCTION NOT WORKING	Gurumoorthy. G.	tube issue it's rectified now working good		Rajasree. R. - Male Ortho Ward	03/04/2023
Comp. Dt. : 20/04/2023 Status : Completed								
677	23040677	Male Ortho - Ward 404	BP APPARATUS NOT WORKING	Sridhar. K.	replaced the bulb with valve		Gayathri. S. - Male Ortho Ward	24/04/2023
Comp. Dt. : 29/05/2023 Status : Completed								
678	23051134	Male Ortho - Ward 403	MULTIPARA MONITOR & BP APPARATUS NOT WORKING	Sridhar. K.	booting issue.the problem is rectified.		Manikandan. V. - Male Ortho Ward	30/05/2023
Comp. Dt. : 08/06/2023 Status : Completed								
679	23060267	Male Ortho - Ward 403	GLUCO METER NOT WORKING	Gurumoorthy. G.	replaced the battery		Rajasree. R. - Male Ortho Ward	09/06/2023
Dept Name : Male Surgery - Biomedical Comp. Dt. : 18/05/2022 Status : Completed								
680	22050676	Male Surgery - Ward 201	NEED TO REFIX BP APPARATUS VALVE - MISSING	Sridhar. K.	checked and found that bulb with valve problem,replaced new one now working good.		Sugumari. M. - Male Surgery	20/05/2022
Comp. Dt. : 24/05/2022 Status : Completed								
681	22050892	Female Surgery - Ward 205	BP APPARATUS NOT WORKING	Gurumoorthy. G.	replaced the bulb with valve		Vaidegi. S. - Female Surgery	25/05/2022
Comp. Dt. : 11/06/2022 Status : Completed								
682	22060421	Female Surgery	SUCTION APPARATUS NOT WORKING - WARD NO 205 & 206	Vignesh. D.	CHECKED POWER CABLE LOOSE CONNCETION ISSUE.IT'S RECTIFIED NOW IT'S WORKING GOOD		Subashini. D. - Gynac Ward	11/06/2022
Comp. Dt. : 22/06/2022 Status : Completed								
683	22060807	Female Surgery - Ward 205	MULTIPARA MONITOR NOT WORKING	Sridhar. K.	CHECKED AND FOUND THE SMPS ISSUE.REPLACED THE SMPS.NOW ITS WORKING GOOD.	Asset No : 16000009	Vinodhini. K. - Female Surgery	08/08/2022
Comp. Dt. : 23/06/2022								

Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
684	22060826	Male Surgery - Ward 201	DISPLAY PROBLEM IN PULSE OXIMETER	Vignesh. D.	checked and found the wire removed on the board side it's refixed now it's working good		Malathy. S - Male Surgery	24/06/2022
685	22060861	Female Surgery - Ward 206	PULSE OXIMETER NOT WORKING	Vignesh. D.	ac dc power supply cable services now its working	AssetNo :16000723	Saranya. V. - Female Surgery	28/06/2022
Comp. Dt. : 24/06/2022								
Status : Completed								
686	22060871	Male Surgery - Ward 201	BP APPARATUS NOT WORKING	Gurumoorthy. G.	replaced the bulb with valve		Sugumari. M. - Male Surgery	24/06/2022
Comp. Dt. : 29/06/2022								
Status : Completed								
687	22061077	Female Surgery - Ward 206	BP APPARATUS & THERMOMETER NOT WORKING	Gurumoorthy. G.	replaced the bulb with valve		Vaidegi. S. - Female Surgery	29/06/2022
Comp. Dt. : 05/07/2022								
Status : Completed								
688	22070131	Male Surgery - Ward 201	PULSE OXI METER NOT WORKING	Sridhar. K.	REPLACED NEW SPO2 PROBE NOW WORKING GOOD.	AssetNo :16000727	Kanimozhi. N - Male Surgery	05/07/2022
689	22070133	Male Surgery - Ward 201	SPO2 PROBE NOT WORKING	Sridhar. K.	RECOMPLAINT		Sugumari. M. - Male Surgery	05/07/2022
Comp. Dt. : 15/07/2022								
Status : Completed								
690	22070584	Male Surgery - Ward 201	THERMOMETER & GLUCOMETER NOT WORKING	Gurumoorthy. G.	replaced the battery		Sugumari. M. - Male Surgery	15/07/2022
Comp. Dt. : 19/07/2022								
Status : Completed								
691	22070722	Male Surgery - Ward 203	BP APPARATUS NOT WORKING	Sridhar. K.	bulb changed now it's working good		Mounica. B. - Male Surgery	20/07/2022
Comp. Dt. : 02/08/2022								
Status : Completed								
692	22080057	Male Surgery - Ward 201	BP APPARATUS NOT WORKING	Sridhar. K.	CHECKED AND REPLACED BLADDER NOW IT'S WORKING GOOD		Sugumari. M. - Male Surgery	03/08/2022
Comp. Dt. : 22/08/2022								
Status : Completed								
693	22080687	Male Surgery - Ward 201	THERMOMETER [2NOS] NOT WORKING	Sridhar. K.	services its working		Sugumari. M. - Male Surgery	22/08/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 26/08/2022								
Status : Completed								
694	22080889	Male Surgery - Ward 201	ECG MACHINE LIGHT NOT WORKING	Sridhar. K.	REPLACES BULB ELECTRODE ITS NOW WORKING	AssetNo :16000864	Kanimozhi. N - Male Surgery	26/08/2022
Comp. Dt. : 21/09/2022								
Status : Completed								
695	22090812	Male Surgery - Ward 201	NEED TO CHANGE STETHOSCOPE EAR PIECE - BROKEN	Gurumoorthy. G.	replaced the ear piece		Sugumari. M. - Male Surgery	24/09/2022
Comp. Dt. : 23/09/2022								
Status : Completed								
696	22090956	Male Surgery - Ward 201	BP APPARATUS NOT WORKING	Gurumoorthy. G.	BULB CHANGED NOW WORKING GOOD		Sugumari. M. - Male Surgery	23/09/2022
Comp. Dt. : 26/09/2022								
Status : Completed								
697	22091006	Male Surgery - Ward 201	THERMOMETER NOT WORKING	Sridhar. K.	replaced the battery		Sugumari. M. - Male Surgery	26/09/2022
Comp. Dt. : 27/09/2022								
Status : Completed								
698	22091041	Male Surgery - Ward 201	B P APPARATUS NOT WORKING	Vignesh. D.	BULB REPLACED NOW WORKING GOOD		Sugumari. M. - Male Surgery	27/09/2022
Comp. Dt. : 30/09/2022								
Status : Completed								
699	22091186	Male Surgery - Ward 201	BP APPARATUS [2NOS] NOT WORKING	Vignesh. D.	bulb replaced now working good		Sugumari. M. - Male Surgery	30/09/2022
Comp. Dt. : 17/10/2022								
Status : Completed								
700	22100520	Male Surgery - Ward 201	THERMO METER NOT WORKING	Vignesh. D.	services now working		Sugumari. M. - Male Surgery	17/10/2022
Comp. Dt. : 19/10/2022								
Status : Completed								
701	22100649	Male Surgery - Ward 201	(1216)SUCTION APPARATUS NOT WORKING	Sridhar. K.	services its working		Sugumari. M. - Male Surgery	22/10/2022
Comp. Dt. : 20/10/2022								
Status : Completed								
702	22100689	Male Surgery - Ward 201	BP APPARATUS NOT WORKING	Vignesh. D.	services its working		Kanimozhi. N - Male Surgery	21/10/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 03/11/2022								
Status : Completed								
703	22110065	Male Ortho - Ward 403	BP APPARATUS NOT WORKING	Gurumoorthy. G.	replaced the bulb with valve		Archana. G. - Male Surgery	03/11/2022
Comp. Dt. : 04/11/2022								
Status : Completed								
704	22110122	Male Surgery - Ward 201	2 NO'S BP APPARATUS NOT WORKING	Sridhar. K.	BLADDER REPLACED NOW WORKING GOOD		Sugumari. M. - Male Surgery	05/11/2022
Comp. Dt. : 10/11/2022								
Status : Completed								
705	22110419	Male Surgery - Ward 201	THERMOMETER NOT WORKING	Vignesh. D.	battery replaced now working good		Sugumari. M. - Male Surgery	10/11/2022
706	22110420	Male Surgery - Ward 201	2 NO'S BP APPARATUS NOT WORKING	Vignesh. D.	bulb replaced now working good		Sugumari. M. - Male Surgery	10/11/2022
Comp. Dt. : 18/11/2022								
Status : Completed								
707	22110747	Male Surgery - Ward 201	PULSE OXI METER & B.P APPARATUS NOT WORKING	Sridhar. K.	genral serviced now working		Sugumari. M. - Male Surgery	21/11/2022
Comp. Dt. : 26/12/2022								
Status : Completed								
708	22121134	Male Surgery - Ward 201	2NOS BP APPARATUS NOT WORKING	Vignesh. D.	bulb and bladder replaced now working good		Kanimozhi. N - Male Surgery	27/12/2022
Comp. Dt. : 31/12/2022								
Status : Completed								
709	22121400	Female Surgery - Ward 205	SUCTION APPARATUS VACCUM NOT WOKRING	Sridhar. K.	serviced done now working good		Archana. G. - Male Surgery	02/01/2023
Comp. Dt. : 11/01/2023								
Status : Completed								
710	23010468	Male Surgery - Ward 201	BP APPARATUS NOT WORKING	Sridhar. K.	bulb replaced now working good		Kanimozhi. N - Male Surgery	11/01/2023
Comp. Dt. : 01/02/2023								
Status : Completed								
711	23020040	Male Surgery - Ward 201	C B G MACHINE NOT WORKING	Gurumoorthy. G.	replaced the battery		Kanimozhi. N - Male Surgery	04/02/2023
Comp. Dt. : 16/02/2023								
Status : Completed								
712	23020625	Male Medical - Ward 303	THERMOMETER NOT WORKING	Vignesh. D.	replaced the battery		Abalakshmi. L. - Male Surgery	17/02/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 25/02/2023 Status : Completed								
713	23020959	Male Surgery - Ward 201	PROBLEM IN DEFIBRILLATOR PRINT	Sridhar. K.	checked and found that printer paper connection problem.the problem is rectified.		Kanimozhi. N - Male Surgery	27/02/2023
Comp. Dt. : 28/03/2023 Status : Completed								
714	23031171	Male Surgery - Ward 204	SUCTION NOT WORKING	Sridhar. K.	serviced now working		Ezhilarasi. E. - Male Surgery	30/03/2023
Comp. Dt. : 08/04/2023 Status : Completed								
715	23040231	Male Surgery - Ward 201	SUCTION APPARATUS NOT WORKING	Gurumoorthy. G.	hose connection problem.the problem is rectified.		Kanimozhi. N - Male Surgery	10/04/2023
Comp. Dt. : 25/04/2023 Status : Completed								
716	23040823	Male Medical - Ward 303	MONITOR NOT WORKING	Vignesh. D.	checked and found that setting issue.the problem is rectified.		Mahalakshmi. L. - Male Surgery	28/04/2023
Comp. Dt. : 28/04/2023 Status : Completed								
717	23040954	Male Surgery - Ward 202	SUCTION APPARATUS NOT WORKING	Gurumoorthy. G.	checked and found that tubeconnection problem.the problem is rectified.		Sangeedha. M. - Male Surgery	02/05/2023
718	23040958	Female Surgery - Ward 205	MONITOR NOT WORKING	Sridhar. K.	checked and found that spo2 sensor issue.replaced the new probe.		Raveena. K. - Male Surgery	02/05/2023
Comp. Dt. : 02/05/2023 Status : Completed								
719	23050009	Male Surgery - Ward 201	B P APPARATUS NOT WORKING	Gurumoorthy. G.	replaced the bladder		Kanimozhi. N - Male Surgery	02/05/2023
Comp. Dt. : 26/05/2023 Status : Completed								
720	23051028	Male Surgery - Ward 201	SPO2 MONITOR [2NOS] NOT WORKING NEED URGENT SERVICE	Sridhar. K.	replaced the probe		Malathy. S - Male Surgery	31/05/2023
Comp. Dt. : 31/05/2023 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
721	23051239	Male Surgery - Ward 201	PULSE OXI METER PROBE NOT WORKING	Sridhar. K.	spo2 probe connection problem.the problem is rectified.		Kanimozhi. N - Male Surgery	31/05/2023
Comp. Dt. : 28/06/2023 Status : Completed								
722	23061041	Male Surgery - Ward 203	B P APPARATUS NOT WORKING	Sridhar. K.	BADDER AND BULB REPLACED WORKING		Ezhilarasi. E. - Male Surgery	28/06/2023
723	23061059	Male Surgery - Ward 201	BP APPARATUS NOT WORKING [2NOS]	Sridhar. K.	BULB REPLACED WORKING		Malathy. S - Male Surgery	28/06/2023
Dept Name : Marketing Team - Biomedical Comp. Dt. : 29/08/2022 Status : Completed								
724	22080990	IVF ART CLINIC-INSIDE OF OG OPD(NO.68)	NEED TO CHECK CABLE FOR SCAN MACHINE - NOT WORKING	Sridhar. K.	checked and found the cable loose connection issue it's rectified now working good	AssetNo :16000910	Sathiya. M. - Marketing Team	01/09/2022
Comp. Dt. : 07/06/2023 Status : Completed								
725	23060226	IVF ART CLINIC-INSIDE OF OG OPD(NO.68)	WEIGHT MACHINE NOT WORKING	Gurumoorthy. G.	replaced the battery		Sathiya. M. - Marketing Team	09/06/2023
Dept Name : MICROBIOLOGY - Biomedical Comp. Dt. : 07/07/2022 Status : Completed								
726	22070248	MICROBIOLOGY	LOOP STERILIZER NOT WORKING	Sridhar. K.	power cable loose its working		Karthik. S. - MICROBIOLOGY	07/07/2022
Comp. Dt. : 25/10/2022 Status : Completed								
727	22100785	microbiology lab	BLOOD CULTURE NOT WORKING	Sridhar. K.	checked and found that lamp issue.replaced the lamp		Karthik. S. - MICROBIOLOGY	26/10/2022
Comp. Dt. : 11/01/2023 Status : Completed								
728	23010488	microbiology opd lab	INCUBATOR NOT WORKING	Sridhar. K.	cable issue rectified now working good		Karthik. S. - MICROBIOLOGY	11/01/2023
Comp. Dt. : 20/04/2023 Status : Completed								
729	23040622	MICROBIOLOGY	CENTRIFUGE NOT WORKING	Gurumoorthy. G.	replaced the carbon brush		aruljothi. S. - MICROBIOLOGY	24/04/2023
Dept Name : Nephrology - Biomedical								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 02/05/2022 Status : Completed								
730	22050013	DIALYSIS IN 2ND FLOOR	NEED TO CHECK FRESenius MACHINE - NOT WORKING	Sridhar. K.	checked and found problem in blood pump motor stucked so serviced it problem rectified.		Santhiya. S. - Nephrology	10/05/2022
Comp. Dt. : 04/05/2022 Status : Completed								
731	22050074	DIALYSIS NEW UNIT IN 1ST FLOOR	DIALYSIS FRESHENER MACHINE NOT WORKING	Gurumoorthy. G.	checked and found problem in micro solenoid value so it replaced with the new one problem rectified.		Neelavathi. T. - Nephrology	10/05/2022
Comp. Dt. : 28/05/2022 Status : Completed								
732	22051049	DIALYSIS NEW UNIT IN 1ST FLOOR	WATER LEAKAGE IN F2 MACHINE	Gurumoorthy. G.	checked and found problem in bicarb tube disconnected so it refix it problem rectified		Karthik. A. - Nephrology	30/05/2022
Comp. Dt. : 02/06/2022 Status : Completed								
733	22060085	DIALYSIS NEW UNIT IN 1ST FLOOR	OD SENSOR NOT WORKING IN F9 MACHINE	Sridhar. K.	checked and found that od sensor problem, replace new od sensor. now its working	AssetNo :16000258	Suganya. D. - Nephrology	23/07/2022
Comp. Dt. : 07/06/2022 Status : Completed								
734	22060242	DIALYSIS NEW UNIT IN 1ST FLOOR	F7 & F11 MACHINE NOT WORKING	Sridhar. K.	checked and found that sampling port,red,blue coupler,sampling valv replace.	AssetNo :16000776	Karthik. A. - Nephrology	05/07/2022
Comp. Dt. : 10/06/2022 Status : Completed								
735	22060364	DIALYSIS NEW UNIT IN 1ST FLOOR	F2 MACHINE WATER LEAKAGE PROBLEM	Sridhar. K.	checked and found that water leakage problem,tube refixed now working good.	AssetNo :16000255	Karthik. A. - Nephrology	13/06/2022
Comp. Dt. : 16/06/2022 Status : Completed								
736	22060609	DIALYSIS NEW UNIT IN 1ST FLOOR	DIALYSIS N2 MACHINE HARAL PUMP NOT WORKING	Sridhar. K.	checked and found that pump fixing problem.refixed the pump.	AssetNo :16000255	Suganya. D. - Nephrology	24/06/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULAVINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
737	22060627	DIALYSIS NEW UNIT IN 1ST FLOOR	F3 , F5 MACHINE NOT WORKING	Sridhar. K.	MEMBRANPUMPE TUPE LOOS ITS NOW WORKING	AssetNo :16000253	Aathimoolam. R. - Nephrology	05/07/2022
Comp. Dt. : 12/07/2022 Status : Completed								
738	22070455	DIALYSIS NEW UNIT IN 1ST FLOOR	PROBLEM IN F2 MACHINE ABD	Sridhar. K.	machine temporarily serviec its now working	AssetNo :16000255	Neelavathi. T. - Nephrology	13/10/2022
Comp. Dt. : 20/07/2022 Status : Completed								
739	22070746	DIALYSIS NEW UNIT IN 1ST FLOOR	F 9 MACHINE NOT WORKING	Sridhar. K.	checked and found that micro solonoid valve and pressure pump head replaced temporarily working.	AssetNo :16000258	Suganya. D. - Nephrology	06/10/2022
Comp. Dt. : 25/07/2022 Status : Completed								
740	22070885	DIALYSIS NEW UNIT IN 1ST FLOOR	N2 MACHINE NOT WORKING	Sridhar. K.	blood pump rolor assembly replace now its working	AssetNo :16001035	Neelavathi. T. - Nephrology	29/07/2022
Comp. Dt. : 03/08/2022 Status : Completed								
741	22080139	DIALYSIS NEW UNIT IN 1ST FLOOR	PROBLEM IN " B BRAUN " MACHINE	Sridhar. K.	FOUND THE BELOW BEARING REPLACES	AssetNo :16000767	Aathimoolam. R. - Nephrology	06/08/2022
Comp. Dt. : 09/08/2022 Status : Completed								
742	22080331	DIALYSIS NEW UNIT IN 1ST FLOOR	F 7 MACHINE NOT WORKING	Sridhar. K.	venous pressure zero error and venous presure zero error calibration done now its working good	AssetNo :16000256	Karthik. A. - Nephrology	11/08/2022
743	22080343	DIALYSIS IN 2ND FLOOR	F 8 MACHINE PUMP STUCK	Sridhar. K.	replace the blood pump moter from the other machine now its working.	AssetNo :16000257	Suganya. B. - Nephrology	06/10/2022
Comp. Dt. : 17/08/2022 Status : Completed								
744	22080489	DIALYSIS NEW UNIT IN 1ST FLOOR	F1 MACHINE CONNECTIVITY PROBLEM	Sridhar. K.	service done working good		Suganya. D. - Nephrology	18/10/2022
Comp. Dt. : 19/08/2022 Status : Completed								
745	22080631	DIALYSIS NEW UNIT IN 1ST FLOOR	NIPRO N1 MACHINE PROBLEM	Sridhar. K.	checked and found that blood pump rolor problem.replaced the blood pump rolar	AssetNo :16001035	Aathimoolam. R. - Nephrology	23/08/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 26/08/2022 Status : Completed								
746	22080863	DIALYSIS NEW UNIT IN 1ST FLOOR	NEED TO CHECK N2 MACHINE - NOT WORKING	Sridhar. K.	roller services its working		Suriya. A. - Nephrology	13/10/2022
Comp. Dt. : 12/09/2022 Status : Completed								
747	22090441	DIALYSIS NEW UNIT IN 1ST FLOOR	PROBLEM IN F11 MACHINE NOT WORKING, HPU ERROR	Sridhar. K.	TMP CALIBRATION DONE ITS NOW WORKING	AssetNo :16000776	Aathimoolam. R. - Nephrology	14/09/2022
Comp. Dt. : 15/09/2022 Status : Completed								
748	22090605	DIALYSIS IN 2ND FLOOR	PROBLEM IN F3 MACHINE	Sridhar. K.	temporarily services working	AssetNo :16000252	Aathimoolam. R. - Nephrology	03/10/2022
Comp. Dt. : 22/09/2022 Status : Completed								
749	22090889	DIALYSIS NEW UNIT IN 1ST FLOOR	PROBLEM IN F5 MACHINE positive pressure	Sridhar. K.	pm and services its now working	AssetNo :16000253	Neelavathi. T. - Nephrology	24/09/2022
Comp. Dt. : 30/09/2022 Status : Completed								
750	22091228	DIALYSIS NEW UNIT IN 1ST FLOOR	PROBLEM IN F10 MACHINE VENOUS PRESSURE ALARM	Sridhar. K.	membranpupm services working	AssetNo :16000774	Karthik. A. - Nephrology	03/10/2022
Comp. Dt. : 01/10/2022 Status : Completed								
751	22100009	DIALYSIS IN 2ND FLOOR	F3 MACHINE NOT WORKING	Sridhar. K.	desinfetion pump services its now working	AssetNo :16000252	Suganya. D. - Nephrology	03/10/2022
Comp. Dt. : 15/10/2022 Status : Completed								
752	22100503	DIALYSIS NEW UNIT IN 1ST FLOOR	NEED TO CHECK DIALYSIS MACHINE B3	Sridhar. K.	Rectified the acid pump struck problem checked found m/c working	AssetNo :16000766	Kamal. B. - Nephrology	17/10/2022
Comp. Dt. : 19/10/2022 Status : Completed								
753	22100627	DIALYSIS NEW UNIT IN 1ST FLOOR	NIPRO MACHINE PROBLEM	Sridhar. K.	RE RINGS M/C WORKING	AssetNo :16001036	Kamal. B. - Nephrology	19/10/2022
Comp. Dt. : 20/10/2022 Status : Completed								
754	22100684	DIALYSIS NEW UNIT IN 1ST FLOOR	b1 MACHINE NOT WORKING	Sridhar. K.	genral services its workig	AssetNo :16001036	Aathimoolam. R. - Nephrology	22/10/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KAUTHEERTHALKUPPAM
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 28/10/2022								
Status : Completed								
755	22100915	DIALYSIS NEW UNIT IN 1ST FLOOR	NEPHRO MACHINE NOT WOKRING	Sridhar. K.	checked and found that conductivity problem.done the conductivity calibration.now its working good.	AssetNo :16001036	Neelavathi. T. - Nephrology	31/10/2022
Comp. Dt. : 31/10/2022								
Status : Completed								
756	22101022	DIALYSIS IN 2ND FLOOR	F8 MACHINE NOT WORKING	Sridhar. K.	CONNECTIVITY ISSUE CHANGED THE OUTPUT BOARD NOW WORKING GOOD		Aathimoolam. R. - Nephrology	02/11/2022
Comp. Dt. : 11/11/2022								
Status : Completed								
757	22110482	DIALYSIS NEW UNIT IN 1ST FLOOR	FRESINIUS MACHINE NO.12 NOT WORKING	Sridhar. K.	venous pressure alarm leur lock ,tp protector strucked in leur lock and cleaned leur lock and venou	AssetNo :16000775	Neelavathi. T. - Nephrology	16/11/2022
Comp. Dt. : 07/12/2022								
Status : Completed								
758	22120286	DIALYSIS NEW UNIT IN 1ST FLOOR	B BRAUN MACHINE acid pump not working	Sridhar. K.	acid pump serviced working	AssetNo :16000768	Neelavathi. T. - Nephrology	10/12/2022
Comp. Dt. : 15/12/2022								
Status : Completed								
759	22120687	DIALYSIS IN 2ND FLOOR	PROBLEM IN N1 MACHINE	Sridhar. K.	conductvity calibration done		Gopinath. P. - Nephrology	31/12/2022
Comp. Dt. : 16/12/2022								
Status : Completed								
760	22120766	DIALYSIS NEW UNIT IN 1ST FLOOR	F11 DIALYSIS MACHINE NOT WORKING	Sridhar. K.	deacid motor replaced		Aathimoolam. R. - Nephrology	02/01/2023
Comp. Dt. : 09/01/2023								
Status : Completed								
761	23010371	DIALYSIS NEW UNIT IN 1ST FLOOR	NEPRO MACHINE N1 CONDUCTIVITY PROBLEM	Sridhar. K.	conductivity problem rectified now working good		Gnanasekaran. S. - Nephrology	09/01/2023
Comp. Dt. : 13/01/2023								
Status : Completed								
762	23010543	DIALYSIS NEW UNIT IN 1ST FLOOR	B5 MACHINE NOT WORKING	Sridhar. K.	acid pump serviced now working		Gopinath. P. - Nephrology	14/01/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
763	23010562	DIALYSIS NEW UNIT IN 1ST FLOOR	STUCK IN B1 MACHINE ACID PUMP	Sridhar. K.	acid pump serviced now working		Gopinath. P. - Nephrology	14/01/2023
Comp. Dt. : 01/02/2023 Status : Completed								
764	23020029	DIALYSIS IN 2ND FLOOR	B1 & B2 MACHINE NOT WORKING	Sridhar. K.	checked and found that hose connections problem.the problem is rectified.		Suganya. D. - Nephrology	03/02/2023
Comp. Dt. : 06/02/2023 Status : Completed								
765	23020187	DIALYSIS NEW UNIT IN 1ST FLOOR	PROBLEM IN F9 MACHINE	Sridhar. K.	checked and found that hose connection problem.the problem is rectified.		Padmarajarajan. M - Nephrology	06/02/2023
Comp. Dt. : 15/02/2023 Status : Completed								
766	23020587	DIALYSIS NEW UNIT IN 1ST FLOOR	MACHINE F11-FLOW ALARAM PROBLEM	Sridhar. K.	checked and found that setting issue.the problem is rectified		Kamal. B. - Nephrology	17/02/2023
767	23020588	DIALYSIS NEW UNIT IN 1ST FLOOR	MACHINE N2-DISINFECTION MACHINE NOT TAKEN	Sridhar. K.	PM AND ALL CALIBRATION DONE NOW WORKING GOOD	AssetNo :16001036	Kamal. B. - Nephrology	17/02/2023
Comp. Dt. : 17/02/2023 Status : Completed								
768	23020678	DIALYSIS NEW UNIT IN 1ST FLOOR	B5 MACHINE NOT WORKING	Sridhar. K.	MEMBRANE & MAINTENANCE KIT REPLACED NOW WORKING GOOD	AssetNo :16000765	Kamal. B. - Nephrology	17/02/2023
Comp. Dt. : 04/03/2023 Status : Completed								
769	23030166	DIALYSIS IN 2ND FLOOR	F8 MACHINE NOT WORKING	Sridhar. K.	checked and found that hose connection problem.the problem is rectified.		Neelavathi. T. - Nephrology	06/03/2023
Comp. Dt. : 06/04/2023 Status : Completed								
770	23040200	DIALYSIS NEW UNIT IN 1ST FLOOR	PROBLEM IN - F9 MACHINE FLOW ALARM	Sridhar. K.	checked and found that flow alaram wire connection problem.the problem is rectified.		Suganya. D. - Nephrology	10/04/2023
Comp. Dt. : 10/04/2023 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
771	23040268	DIALYSIS NEW UNIT IN 1ST FLOOR	NEED TO CHECK TEMPERATURE ALARM FOR B1 MACHINE - PRONLEM	Gurumoorthy. G.	alarm settings issue.the problem is rectified.		Kamal. B. - Nephrology	10/04/2023
Comp. Dt. :		20/04/2023						
Status :		Completed						
772	23040682	DIALYSIS NEW UNIT IN 1ST FLOOR	F7 & F10 MACHINE NOT WORKING	Sridhar. K.	check and found degaasing motor issue.it's serviced now working.	AssetNo :16000256	Gnanasekaran. S. - Nephrology	27/04/2023
Comp. Dt. :		27/04/2023						
Status :		Completed						
773	23040909	DIALYSIS NEW UNIT IN 1ST FLOOR	NIPRO MACHINE NOT WORKING	Sridhar. K.	serviced now working		Neelavathi. T. - Nephrology	05/05/2023
774	23040930	DIALYSIS NEW UNIT IN 1ST FLOOR	B BRAUN MACHINE PROBLEM	Sridhar. K.	replaced pressure sensor its working	AssetNo :16000767	Neelavathi. T. - Nephrology	29/04/2023
Comp. Dt. :		02/05/2023						
Status :		Completed						
775	23050003	DIALYSIS NEW UNIT IN 1ST FLOOR	F7 MACHINE NOT WORKING	Sridhar. K.	POWER CARD ISSUE IT'S RECTIFIED NOW WORKING GOOD		Kamal. B. - Nephrology	11/05/2023
776	23050070	DIALYSIS NEW UNIT IN 1ST FLOOR	N1 MACHINE NOT WORKING	Gurumoorthy. G.	serviced now working		Karthik. A. - Nephrology	05/05/2023
Comp. Dt. :		03/05/2023						
Status :		Completed						
777	23050079	DIALYSIS NEW UNIT IN 1ST FLOOR	B/ BRAUN MACHINE NOT WORKING	Sridhar. K.	checked and found that pressure sensor issue.repaced the pressure sensor.	AssetNo :16000767	Neelavathi. T. - Nephrology	10/05/2023
Comp. Dt. :		05/05/2023						
Status :		Completed						
778	23050218	DIALYSIS NEW UNIT IN 1ST FLOOR	F 9 MACHINE NOT WORKING	Sridhar. K.	ALARM ISSUE IT'S RECTIFIED NOW WORKING GOOD		Karthik. A. - Nephrology	11/05/2023
Comp. Dt. :		06/05/2023						
Status :		Completed						
779	23050219	DIALYSIS NEW UNIT IN 1ST FLOOR	PROBLEM IN FRESHINUS MACHINE	Sridhar. K.	FLOW ALARM ISSUE IT'S RECTIFIED NOW WORKING GOOD		Neelavathi. T. - Nephrology	11/05/2023
Comp. Dt. :		15/05/2023						
Status :		Completed						
780	23050611	DIALYSIS IN 2ND FLOOR	PROBLEM IN F6 MACHINE	Sridhar. K.	checked and found that flow alarm problem.the problem is rectified.		Aathimoolam. R. - Nephrology	17/05/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 20/05/2023 Status : Completed								
781	23050837	DIALYSIS NEW UNIT IN 1ST FLOOR	WEIGHT MACHINE NOT WORKING	Gurumoorthy. G.	cable loos its working		Kamal. B. - Nephrology	23/05/2023
Comp. Dt. : 29/05/2023 Status : Completed								
782	23051152	DIALYSIS NEW UNIT IN 1ST FLOOR	PROBLEM IN F9, F10	Sridhar. K.	checked and found that water leakage issue.bicarb tube fixed properly	AssetNo :16000774	Kamal. B. - Nephrology	31/05/2023
Comp. Dt. : 12/06/2023 Status : Completed								
783	23060419	DIALYSIS NEW UNIT IN 1ST FLOOR	F3 MACHINE NOT WORKING	Sridhar. K.	checked and found that touch pad problem.need to replace the touch pad	AssetNo :16000252	Aathimoolam. R. - Nephrology	15/06/2023
784	23060424	DIALYSIS NEW UNIT IN 1ST FLOOR	need to battery backup in F5,F6,F8 And bubble catcher door needed in F5,F12,F10,F3	Sridhar. K.	checked and found that bubble catcher door and battery issue.need to purchase for new one and replac		Suganya. D. - Nephrology	15/06/2023
Comp. Dt. : 15/06/2023 Status : Completed								
785	23060538	DIALYSIS NEW UNIT IN 1ST FLOOR	B BRAUN MACHINE GEAR PROBLEM	Sridhar. K.	gear pump need to purchase new one need for replacement		Kamal. B. - Nephrology	16/06/2023
Comp. Dt. : 20/06/2023 Status : Completed								
786	23060734	DIALYSIS NEW UNIT IN 1ST FLOOR	MANO METER PROBLEM IN B3 MACHINE	Sridhar. K.	MONOMETER CONNECTION BLUE AJUSTMENT IES WORKING		Aathimoolam. R. - Nephrology	21/06/2023
Comp. Dt. : 22/06/2023 Status : Completed								
787	23060825	DIALYSIS NEW UNIT IN 1ST FLOOR	BP APPARATUS NOT WORKING	Gokul. P. K.	replaced the bladder		Aathimoolam. R. - Nephrology	22/06/2023
Dept Name : NEUROLOGY - Biomedical Comp. Dt. : 19/10/2022 Status : Completed								
788	22100628	EEG	SECOND FLOOR NCS MACHINE PROBLEM	Sridhar. K.	compony services its working		asuki. P. - NEUROLOGY	26/10/2022
Comp. Dt. : 30/05/2023								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
789	23051209	CARDIOLOGY OPD	DIGITAL B P APPARATUS NOT WORKING [INTERCOM NO 3101]	Gurumoorthy. G.	cuff and badder replaced		Vanitha. G. - NEUROLOGY	31/05/2023
Dept Name : Nursing Office - Biomedical								
Comp. Dt. : 17/05/2022								
Status : Completed								
790	22050600	OG-OPD	FOCUS LIGHT NOT WORKING	Gurumoorthy. G.	checked and found that lamp problem, replaced now woking good.		Velangannie.N. - Nursing Office	19/05/2022
Comp. Dt. : 18/06/2022								
Status : Completed								
791	22060689	General Medicine - OPD	ECG MACHINE NOT WORKING	Sridhar. K.	replace the ecg cable 10 lead its now working	AssetNo :16000773	Sudha.L. - Nursing Office	30/06/2022
Comp. Dt. : 25/06/2022								
Status : Completed								
792	22060925	Male Surgery - Ward 201	PULSE OXI METER NOT WORKING	Sridhar. K.	monitor smps power supply assy cable serviec its now working	AssetNo :16000727	Devika.R - Nursing Office	30/06/2022
Comp. Dt. : 07/07/2022								
Status : Completed								
793	22070255	OG OT	BP APPARATUS NOT WORKING	Gurumoorthy. G.	replaced the bulb with valve		Velangannie.N. - Nursing Office	09/07/2022
Comp. Dt. : 08/07/2022								
Status : Completed								
794	22070304	Labour Room	NEED TO CHECK & CHANGE WARMER -2nos	Vignesh. D.	checked and found the side tray replaced now working good	AssetNo :16000347	Velangannie.N. - Nursing Office	27/12/2022
Comp. Dt. : 18/07/2022								
Status : Completed								
795	22070682	Female Casulaty	ECG MACHINE NOT WORKING	Sridhar. K.	checked and found the cable loose connection issue it's rectified now it's working good		Vanaja. A. - EMERGENCY MEDICINE	21/07/2022
Comp. Dt. : 12/09/2022								
Status : Completed								
796	22090442	Casualty	ECG MACHINE NOT WORKING	Gurumoorthy. G.	cable issue it's rectified now working good		Sudha.L. - Nursing Office	16/09/2022
Comp. Dt. : 19/10/2022								
Status : Completed								

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHAL KUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
797	22100617	RICU	MUTIPARA MONITOR NOT WORKING	Vignesh. D.	probe issue it's changed now working good		Powlin.P. - Nursing Office	02/11/2022
Comp. Dt. : 27/12/2022 Status : Completed								
798	22121211	Male Medical - Ward 301	ECG MACHINE NOT WORKING	Sridhar. K.	ecg module connector issue it's replaced now working good		Leena Grace. B. - Nursing Office	02/01/2023
Comp. Dt. : 24/02/2023 Status : Completed								
799	23020921	Paediatrics Ward	BP APPARATUS NOT WORKING - WARD NO 309 & 310	Vignesh. D.	replaced the bulb with valve		Tamilarasi.C. - Nursing Office	27/02/2023
Comp. Dt. : 20/03/2023 Status : Completed								
800	23030820	ICCU	VENTILATOR 2 NO [ICU & ICCU] NOT WORKING -	Gurumoorthy. G.	checked and found that cassette issue.cleaned the cassette.now its working good.		Powlin.P. - Nursing Office	31/03/2023
Comp. Dt. : 25/04/2023 Status : Completed								
801	23040789	Paediatrics - Ward 308	SUCTION NOT WORKING	Vignesh. D.	checked and found that tube connection problem.the problem is rectified.		Powlin.P. - Nursing Office	28/04/2023
Comp. Dt. : 16/05/2023 Status : Completed								
802	23050625	Obstetrics - Ward 208	NEED TO CHECK DIGITAL WEIGHT MACHINE - NOT WORKING - REMINDER III	Sridhar. K.	checked and found that power connection problem.the problem is rectified.		Powlin.P. - Nursing Office	17/05/2023
Comp. Dt. : 20/06/2023 Status : Completed								
803	23060721	Male Ortho	ECG MACHINE NOT WORKING - WARD NO 403 & 404	Sridhar. K.	checked and found that leads issue.the problem is rectified.		Sudha.L. - Nursing Office	21/06/2023
Comp. Dt. : 26/06/2023 Status : Completed								
804	23060953	Female Medical - Ward 306	ECG MACHINE NOT WORKING	Sridhar. K.	MOTHER BOARD ISSUE.		Rajalakshmi. N. - Nursing Office	05/08/2023
Dept Name : OPD - Biomedical Comp. Dt. : 13/05/2022								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
805	22050458	PSYCHIATRY OPD	2NOS BP APPARATUS NOT WORKING	Vignesh. D.	checked and found that bladder problem, replaced new one, dial adjusted in another bp apparatus. now w		Bhuvaneswari. G. - P.H.C. - Tiruvannainallur	13/05/2022
Comp. Dt. : 14/05/2022								
Status : Completed								
806	22050495	DENTAL OPD -2ND FLOOR	COMPRESSOR AIR LEAKAGE POBLEM AND AUTOCLAVE MACHINE PROBLEM	Sridhar. K.	checked and found problem in air value leakage so remove and serviced it problem rectified.		Lakshmi Devi. R. - OPD	14/05/2022
Comp. Dt. : 17/05/2022								
Status : Completed								
807	22050585	Minor O.T. - Surgical OP	NEED TO CHECK FOCUS LIGHT NOT WORKING	Sridhar. K.	checked and found that lamp problem replaced now working good.		Sarala. P. - OPD	19/05/2022
Comp. Dt. : 23/05/2022								
Status : Completed								
808	22050825	General Medicine - OPD	BP APPARATUS [7 NOS] NOT WORKING	Gurumoorthy. G.	checked and found problem in bulb with value -3 nos and bladder -1no defective so it replace with th		Bharathi.D. - OPD	23/05/2022
Comp. Dt. : 24/05/2022								
Status : Completed								
809	22050906	DENTAL OPD -2ND FLOOR	NEED TO REFIX DENTAL CHAIR LIGHT - DAMAGE	Sridhar. K.	REFIX THE LIGHT NOW UNIT WORKING GOOD		Kanakarani. R. - OPD	25/05/2022
Comp. Dt. : 27/05/2022								
Status : Completed								
810	22051013	DENTAL OPD -2ND FLOOR	AIR LEAKAGE IN COMPRESSOR	Sridhar. K.	checked and found problem in compressor air value leakage so tight it properly problem rectified.		Lakshmi Devi. R. - OPD	30/05/2022
811	22051032	ENT OPD	ENDOSCOPY NOT WORKING	Vignesh. D.	replaced the lamp		Ezhilarasi. M. - OPD	30/05/2022
Comp. Dt. : 28/05/2022								
Status : Completed								
812	22051043	OG-OPD	BP APPARATUS NOT WORKING	Vignesh. D.	checked and found problem in dial so removed and serviced it problem rectified		elangkanni. K. - OPD	28/05/2022

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 30/05/2022 Status : Completed								
813	22051090	Orthopaedics - OPD	BP APPARATUS [3NOS] NOT WORKING	Gurumoorthy. G.	replaced the bulb with valve and bladder.		Durgadevi. J - OPD	31/05/2022
814	22051092	ENT OPD	FOCUS LIGHT NOT WORKING	Vignesh. D.	checked and found that power cable connection problem.the problem is rectified		Ezhilarasi. M. - OPD	31/05/2022
Comp. Dt. : 01/06/2022 Status : Completed								
815	22060027	GASTROENTROLOGY OPD-2ND FLOOR	BP APPARATUS NOT WORKING -OPD NO 225	Gurumoorthy. G.	checked and found that bulb with valve problem,replaced new one now working good.		Suvitha. R. - OPD	02/06/2022
Comp. Dt. : 02/06/2022 Status : Completed								
816	22060059	OG-OPD	BP APPARATUS NOT WORKING	Gurumoorthy. G.	checked and found that bulb with valve problem,replaced new one now working good.		Velangkanni. K. - OPD	02/06/2022
817	22060091	Ophthalmology - OPD	NEED TO CHECK " B SCAN "	Sridhar. K.	checked and found that software corrupted in the cpu,updated the software now working good.		Seetha. R. - OPD	15/06/2022
Comp. Dt. : 07/06/2022 Status : Completed								
818	22060241	ENT WARD-407	BP APPARATUS NOT WORKING	Gurumoorthy. G.	replaced the bladder.		Jaculine Mary. A. - ENT & Ophthal Ward	08/06/2022
Comp. Dt. : 09/06/2022 Status : Completed								
819	22060339	ENT WARD-407	BP APPARATUS NOT WORKING	Vignesh. D.	changed the bulb now it's working good		Jaculine Mary. A. - ENT & Ophthal Ward	09/06/2022
Comp. Dt. : 10/06/2022 Status : Completed								
820	22060370	IVF ART CLINIC-INSIDE OF OG OPD(NO.68)	SCAN MACHINE ERROR-IMAGES NOT DISPLAYING CLEARLY	Sridhar. K.	checked and found that error showing in monitor.the problem is rectified.	Asset No :16000910	Rajasekari. R. - OPD	22/06/2022
Comp. Dt. : 14/06/2022 Status : Completed								

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
821	22060521	Surgery OPD	BP APPARATUS [5 NOS] NOT WORKING	Vignesh. D.	CHECKED AND REPLACED THE BULB AND BLADER NOW UNIT WORKING GOOD		Bharathi.D. - OPD	14/06/2022
Comp. Dt. : 16/06/2022 Status : Completed								
822	22060601	DENTAL OPD -2ND FLOOR	NEED TO REMOVE DENTAL CHAIR HANDLE	Sridhar. K.	dental chair handle removed now working good		Lakshmi Devi. R. - OPD	17/06/2022
Comp. Dt. : 22/06/2022 Status : Completed								
823	22060811	ENT OPD	ENDOSCOPY LIGHT SOURCE NOT WORKING	Sridhar. K.	replaced the lamp		Ezhilarasi. M. - OPD	24/06/2022
Comp. Dt. : 24/06/2022 Status : Completed								
824	22060887	OG-OPD	NEED TO CHECK FOCUS LIGHT - NOT WORKING	Gurumoorthy. G.	replaced the lamp holder and lamp		Velangkanni. K. - OPD	24/06/2022
Comp. Dt. : 01/07/2022 Status : Completed								
825	22070006	OG-OPD	B P APPARATUS CUFF NOT WORKING	Gurumoorthy. G.	replaced the bulb with valve		Velangkanni. K. - OPD	01/07/2022
826	22070022	ENT OPD	NEED TO CHANGE LIGHT SOURCE LIGHT - NOT WORKING	Gurumoorthy. G.	checked and found that lamp problem.replaced the new lamp		Ezhilarasi. M. - OPD	01/07/2022
Comp. Dt. : 04/07/2022 Status : Completed								
827	22070104	Nephrology OPD	BP APPARATUS NOT WORKING OPD NO 215	Vignesh. D.	CHECKED AND CHANGED THE BULB NOW IT'S WORKING GOOD		Jenifer. K. - OPD	04/07/2022
Comp. Dt. : 07/07/2022 Status : Completed								
828	22070282	OG-OPD	NEED TO REFIX BIOPSY LIGHT STAND	Sridhar. K.	services its now working		Velangkanni. K. - OPD	11/07/2022
Comp. Dt. : 08/07/2022 Status : Completed								
829	22070322	DERMATOLOGY OPD	WEIGHT MACHINE NOT WORKING	Sridhar. K.	checked and fount that fuse replace its now working		Jothiammal. S. - OPD	11/07/2022
Comp. Dt. : 09/07/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
830	22070367	General Medicine - OPD	BP APPARATUS 7 NOS NOT WORKING	Gurumoorthy. G.	replaced the bulb with valve and bladder		Bharathi.D. - OPD	11/07/2022
	Comp. Dt. : 12/07/2022							
	Status : Completed							
831	22070478	Orthopaedics - OPD	BP APPARATUS [5 NOS] NOT WORKING	Sridhar. K.	BP APP SERVICES ITS NOW WORKING		Durgadevi. J - OPD	12/07/2022
	Comp. Dt. : 14/07/2022							
	Status : Completed							
832	22070565	Ophthalmology - OPD	YOG LACER MACHINE NOT WORKING	Sridhar. K.	emergency switch trip problem rectified	AssetNo :16000700	Seetha. R. - OPD	15/07/2022
	Comp. Dt. : 20/07/2022							
	Status : Completed							
833	22070764	DENTAL OPD -2ND FLOOR	WATER NOT COMING IN ELECTRO HANDPIECE	Sridhar. K.	checked and found that water leakage in tube.the problem is rectified		Lakshmi Devi. R. - OPD	25/07/2022
	Comp. Dt. : 21/07/2022							
	Status : Completed							
834	22070773	General Medicine - OPD	BP APPARATUS [6 NOS] NOT WORKING	Gurumoorthy. G.	REPLACE THE BULB WITH VALUE AND BLADDER		Bharathi.D. - OPD	21/07/2022
	Comp. Dt. : 22/07/2022							
	Status : Completed							
835	22070831	Orthopaedics - OPD	BP APPARATUS NOT WORKING 4 NOS	Gurumoorthy. G.	BULB AND BLADDER REPLACED NOW WORKING GOOD		Durgadevi. J - OPD	23/07/2022
	Comp. Dt. : 26/07/2022							
	Status : Completed							
836	22070963	General Medicine - OPD	BP APPARATUS [3NOS] NOT WORKING	Vignesh. D.	checked and changed the dial and bulb now it's working good		Bharathi.D. - OPD	26/07/2022
	Comp. Dt. : 27/07/2022							
	Status : Completed							
837	22071011	General Medicine - OPD	BP APPARATUS 3NOS NOT WORKING	Vignesh. D.	changed the bulb and bladder now it's working good		Bharathi.D. - OPD	27/07/2022
838	22071012	OG-OPD	COLPOSCOPY NOT WORKING AT BIOPSY ROOM	Sridhar. K.	NEW SOFTWARE INSTALLATION SO NOW ITS WORKING	AssetNo :16000222	Velangkanni. K. - OPD	27/07/2022
839	22071015	OG-OPD	BP APPARATUS 3 NOS NOT WORKING	Vignesh. D.	bulb and bladder changed now it's working good		Velangkanni. K. - OPD	27/07/2022
	Comp. Dt. : 30/07/2022							
	Status : Completed							


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
840	22071108	Ophthalmology - OPD	BP APPARATUS NOT WORKING	Sridhar. K.	genral services now working		Seetha. R. - OPD	01/08/2022
	Comp. Dt. : 01/08/2022 Status : Completed							
841	22080051	DENTAL OPD -2ND FLOOR	NEED TO CHECK BRIGHTNESS FOR DENTAL CHAIR LIGHT	Sridhar. K.	sensor switch cleaning its working	AssetNo :16000873	Lakshmi Devi. R. - OPD	03/08/2022
	Comp. Dt. : 03/08/2022 Status : Completed							
842	22080129	DENTAL OPD -2ND FLOOR	NEED TO CHANGE - DENTAL CHAIR AIROTOR HANDPIECE DAMAGE	Sridhar. K.	purachse to new one		Kanakarani. R. - OPD	19/08/2022
	Comp. Dt. : 09/08/2022 Status : Completed							
843	22080304	ENT OPD	NEED TO CHECK LIGHT SOURCE LIGHT - NOT WORKING	Sridhar. K.	replace halagen lamp now its working	AssetNo :16000323	Ezhilarasi. M. - OPD	10/08/2022
844	22080332	DENTAL OPD -2ND FLOOR	IN DENTAL CHAIR UP & DOWN OPTION NOT WORKING	Sridhar. K.	CHAIR SIDE KEY BOARD AND CABLE SERVICES NOW ITS WORKING	AssetNo :16000249	Lakshmi Devi. R. - OPD	09/08/2022
	Comp. Dt. : 12/08/2022 Status : Completed							
845	22080441	DENTAL OPD -2ND FLOOR	STRAIGHT HANDPIECE NOT WORKING	Sridhar. K.	handpiece purchase new one		Kanakarani. R. - OPD	22/08/2022
	Comp. Dt. : 17/08/2022 Status : Completed							
846	22080542	DENTAL OPD -2ND FLOOR	MICROMOTOR HAND PIECE NOT WORKING	Sridhar. K.	micromoter contra angular hand piece perchase new one		Kanakarani. R. - OPD	19/08/2022
	Comp. Dt. : 24/08/2022 Status : Completed							
847	22080794	General Medicine - OPD	BP APPARATUS [3 NOS] NOT WORKING	Vignesh. D.	BULB CHANGED NOW WORKING GOOD		Bharathi.D. - OPD	24/08/2022
	Comp. Dt. : 26/08/2022 Status : Completed							
848	22080920	ENT OPD	LIGHT SOURCE LIGHT NOT WORKING	Sridhar. K.	light source bulb changed now working good		Ezhilarasi. M. - OPD	01/09/2022
	Comp. Dt. : 29/08/2022 Status : Completed							


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
849	22080971	General Medicine - OPD	BP APPARATUS [3NOS] NOT WORKING	Vignesh. D.	CHECKED AND CHANGED THE BULB NOW IT'S WORKING GOOD		Bharathi.D. - OPD	29/08/2022
Comp. Dt. : 06/09/2022 Status : Completed								
850	22090207	Nephrology OPD	BP APPARATUS NOT WORKING	Gurumoorthy. G.	bulb changed now working good		Jenifer. K. - OPD	06/09/2022
851	22090220	OG-OPD	BP APPARATUS NOT WORKING	Gurumoorthy. G.	bulb changed now working good		Velangkanni. K. - OPD	06/09/2022
Comp. Dt. : 15/09/2022 Status : Completed								
852	22090599	OG-OPD	BP APPARATUS NOT WORKING	Gurumoorthy. G.	bladder changed working good		Velangkanni. K. - OPD	16/09/2022
Comp. Dt. : 16/09/2022 Status : Completed								
853	22090641	Orthopaedics - OPD	BP APPARATUS NOT WORKING	Gurumoorthy. G.	replaced the bladder		Durgadevi. J - OPD	17/09/2022
Comp. Dt. : 19/09/2022 Status : Completed								
854	22090717	Obstetrics - OPD	BP APPARATUS NOT WORKING	Sridhar. K.	replaced the bladder		Velangkanni. K. - OPD	24/09/2022
Comp. Dt. : 20/09/2022 Status : Completed								
855	22090767	Ophthalmology - OPD	SLIT LAMP NOT WORKING	Sridhar. K.	genral services its now working		Seetha. R. - OPD	27/09/2022
Comp. Dt. : 21/09/2022 Status : Completed								
856	22090854	IVF ART CLINIC-INSIDE OF OG OPD(NO.68)	MULTIPARA MONITOR BP CUFF NOT WORKING	Sridhar. K.	genral services its working		Rajasekari. R. - OPD	24/09/2022
Comp. Dt. : 23/09/2022 Status : Completed								
857	22090912	Nephrology OPD	BP APPARATUS NOT WORKING	Vignesh. D.	BULB CHANGED WORKING GOOD		Jenifer. K. - OPD	23/09/2022
858	22090933	General Medicine - OPD	BP APPARATUS 3NOS NOT WORKING	Vignesh. D.	BLADDER CHANGED NOW WORKING GOOD		Bharathi.D. - OPD	23/09/2022
Comp. Dt. : 26/09/2022 Status : Completed								
859	22091014	CARDIOLOGY OPD	BP APPARATUS 2NOS NOT WORKING	Gurumoorthy. G.	replaced the bladder		Radhika. R. - OPD	26/09/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 30/09/2022								
Status : Completed								
860	22091198	General Medicine - OPD	BP APPARATUS [2NOS] NOT WORKING	Vignesh. D.	bulb and bladder replaced now working good		Bharathi.D. - OPD	30/09/2022
861	22091226	ENT OPD	NEED TO CHECK LIGHT SOURCE LIGHT - NOT WORKING	Sridhar. K.	transformer issue it's rectified now working good		Ezhilarasi. M. - OPD	05/10/2022
Comp. Dt. : 05/10/2022								
Status : Completed								
862	22100065	Surgery OPD	BP APPARATUS NOT WORKING	Vignesh. D.	bulb changed now working good		Indhira. M. - OPD	05/10/2022
863	22100066	General Medicine - OPD	2 BP APPARATUS NOT WORKING	Vignesh. D.	checked and changed the bladder now working good		Bharathi.D. - OPD	05/10/2022
864	22100072	OG-OPD	BP APPARATUS NOT WORKING	Gurumoorthy. G.	replaced the bulb with valve		Velangkanni. K. - OPD	05/10/2022
Comp. Dt. : 07/10/2022								
Status : Completed								
865	22100158	ENT OPD	FOCUS LIGHT NOT WORKING	Sridhar. K.	replaced the lamp.		Ezhilarasi. M. - OPD	10/10/2022
Comp. Dt. : 08/10/2022								
Status : Completed								
866	22100182	DENTAL OPD	NEED TO CHANGE X-RAY MACHINE	Sridhar. K.	shifting completed		Lakshmi Devi. R. - OPD	12/10/2022
867	22100189	DENTAL OPD	DENTAL CHAIR AIROTER HAND PIECE NOT WORKING	Sridhar. K.	service done.working done		Lakshmi Devi. R. - OPD	12/10/2022
Comp. Dt. : 12/10/2022								
Status : Completed								
868	22100333	IVF ART CLINIC-INSIDE OF OG OPD(NO.68)	WEIGHING MACHINE BATTERY CHANGE	Gurumoorthy. G.	battery replaced now working good		Nagalakshmi. M. - OPD	12/10/2022
Comp. Dt. : 17/10/2022								
Status : Completed								
869	22100527	UROLOGY--OPD	BP APPARATUD NOT WORKING	Sridhar. K.	services now working		Lavanya. M. - OPD	17/10/2022
Comp. Dt. : 20/10/2022								
Status : Completed								
870	22100654	General Medicine - OPD	BP APPARATUS NOT WORKING	Sridhar. K.	genral serviecs its now working		Bharathi.D. - OPD	20/10/2022
Comp. Dt. : 31/10/2022								
Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
871	22101021	ENT OPD	FOCUS LIGHT NOT WORKING	Sridhar. K.	replaces lamp.holderand services its working		Ezhilarasi. M. - OPD	31/10/2022
Comp. Dt. : 02/11/2022 Status : Completed								
872	22110013	Ophthalmology - OPD	FUNDUS CAMERA NOT WORKING	Sridhar. K.	CAMERA LENCE CLEANED WORKING	AssetNo :16000276	Seetha. R. - OPD	01/12/2022
873	22110021	General Medicine - OPD	2 NO'S BP APPARATUS NOT WORKING	Vignesh. D.	replaced the bladder and bulb with valve		Bharathi.D. - OPD	03/11/2022
Comp. Dt. : 03/11/2022 Status : Completed								
874	22110054	Ophthalmology - OPD	LENSOMETER NOT WORKING	Sridhar. K.	lensometer serviced now working good.		Seetha. R. - OPD	07/11/2022
Comp. Dt. : 07/11/2022 Status : Completed								
875	22110227	General Medicine - OPD	3NO'S BP APPARATUS NOT WORKING	Sridhar. K.	REPLACE BADDER AND SERVICED WORKING		Bharathi.D. - OPD	07/11/2022
876	22110251	Nephrology OPD	BP APPARATUS NOT WORKING	Sridhar. K.	GENRAL SERVICED ITS WORKING		Jenifer. K. - OPD	07/11/2022
Comp. Dt. : 10/11/2022 Status : Completed								
877	22110411	Nephrology OPD	1 BP APPARATUS NOT WORKING	Sridhar. K.	cuff;bladder replaced		Jenifer. K. - OPD	10/11/2022
878	22110426	General Medicine - OPD	2 NO'S BP APPARATUS NOT WORKING	Vignesh. D.	bulb replaced now working good		Bharathi.D. - OPD	10/11/2022
Comp. Dt. : 16/11/2022 Status : Completed								
879	22110691	DENTAL OPD -2ND FLOOR	WATER NOT COMING IN SCALAR MACHINE	Sridhar. K.	air regulator services		Kanakarani. R. - OPD	21/11/2022
Comp. Dt. : 17/11/2022 Status : Completed								
880	22110703	Orthopaedics - OPD	2 NO'S BP APPARATUS NOT WORKING	Vignesh. D.	bulb replaced now working good		Durgadevi. J - OPD	19/11/2022
Comp. Dt. : 22/11/2022 Status : Completed								
881	22110940	DENTAL OPD -2ND FLOOR	WATER NOT COMING IN DENTAL CHAIR SCALAR & NEED TO REFIX HANDLE SCREW	Sridhar. K.	regulator issue adjusted the regulator now its working good		Priyadharshini. S. - OPD	29/11/2022
Comp. Dt. : 26/11/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
882	22111125	DENTAL OPD -2ND FLOOR	DENTAL CHAIR COMPRESSOR CONNECTION PROBLEM	Sridhar. K.	TUBE LOOSE CONNECTION IT'S RECTIFIED		Lakshmi Devi. R. - OPD	01/12/2022
883	22111137	OG-OPD	SCAN MACHINE PROBE NOT WORKING	Vignesh. D.	checked and found that power connection problem.the problem is rectified		Velangkanni. K. - OPD	26/11/2022
Comp. Dt. : 30/11/2022 Status : Completed								
884	22111283	DENTAL OPD -2ND FLOOR	NEED TO CHECK DENTAL CHAIR MICROMOTOR	Sridhar. K.	SERVICED WORKING		Priyadharshini. S. - OPD	01/12/2022
Comp. Dt. : 03/12/2022 Status : Completed								
885	22120126	General Medicine - OPD	BP APPARATUS NOT WORKING	Vignesh. D.	BP APPARATUS DIAL REPLACED NOW WORKING GOOD		Bharathi.D. - OPD	03/12/2022
886	22120141	ANAESTHESIA OPD NEAR SUGERY OPD	WEIGHT MACHINE NOT WORKING IN ROOM NO. 54	Gurumoorthy. G.	genral serviced working		Badmasri. P. - OPD	10/12/2022
Comp. Dt. : 06/12/2022 Status : Completed								
887	22120223	Ophthalmology - OPD	P R P MACHINE SLIT LAMP LIGHT NOT WORKING	Sridhar. K.	replaced slit lamp working		Seetha. R. - OPD	08/12/2022
Comp. Dt. : 08/12/2022 Status : Completed								
888	22120396	Ophthalmology - OPD	B SCAN MACHINE NOT WORKING	Sridhar. K.	SERVICE DONE NOW WORKING GOOD		Seetha. R. - OPD	03/01/2023
Comp. Dt. : 10/12/2022 Status : Completed								
889	22120488	IVF ART CLINIC-INSIDE OF OG OPD(NO.68)	OT TOP LIGHT NOT WORKING	Sridhar. K.	checked and found that lamp loose connection issue.problem is rectified		Rajasekari. R. - OPD	13/12/2022
890	22120490	ENT OPD	LIGHT SOURCE NOT WORKING	Sridhar. K.	replaced the lamp		Ezhilarasi. M. - OPD	13/12/2022
Comp. Dt. : 12/12/2022 Status : Completed								
891	22120522	Paediatrics - OPD	WEIGHT MACHNE NOT WORKING	Sridhar. K.	company serviced working		Subashree. R. - OPD	17/12/2022
Comp. Dt. : 15/12/2022 Status : Completed								
892	22120693	CTVS-ROOM NO.225 -2ND FLOOR	WEIGHT MACHINE NOT WORKING	Sridhar. K.	BATTERY REPLACED WORKING		Suvitha. R. - OPD	16/12/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 16/12/2022 Status : Completed								
893	22120759	OG-OPD	BP APPARATUS NOT WORKING	Sridhar. K.	SERVICED WORKING		Velangkanni. K. - OPD	16/12/2022
Comp. Dt. : 20/12/2022 Status : Completed								
894	22120923	IVF ART CLINIC-INSIDE OF OG OPD(NO.68)	BP APPARATUS NOT WORKING	Sridhar. K.	serviced now working		Rajasekari. R. - OPD	21/12/2022
Comp. Dt. : 26/12/2022 Status : Completed								
895	22121144	Orthopaedics - OPD	NEED TO CHANGE DIGITAL WEIGHT MACHINE BATTERY	Gurumoorthy. G.	battery replaced now working		Durgadevi. J - OPD	27/12/2022
Comp. Dt. : 31/12/2022 Status : Completed								
896	22121386	DENTAL OPD -2ND FLOOR	IN DENTAL CHAIR-ERROTAL HAND PEICE NOT WORKING	Sridhar. K.	serviced working good		Kanakarani. R. - OPD	02/01/2023
Comp. Dt. : 04/01/2023 Status : Completed								
897	23010175	ENT OPD	LIGHT SOURCE BULB GOT FUSE	Sridhar. K.	bulb replaced now working good		Ezhilarasi. M. - OPD	04/01/2023
Comp. Dt. : 05/01/2023 Status : Completed								
898	23010215	General Medicine - OPD	2 NO'S BP APPARATUS NOT WORKING	Sridhar. K.	SERVICED NOW WORKING		Bharathi.D. - OPD	05/01/2023
Comp. Dt. : 06/01/2023 Status : Completed								
899	23010272	Ophthalmology - OPD	BP APPARATUS NOT WORKING	Vignesh. D.	bulb replaced now working good		Seetha. R. - OPD	06/01/2023
Comp. Dt. : 10/01/2023 Status : Completed								
900	23010387	DENTAL OPD -2ND FLOOR	MICROMOTOR HANDPEICE NOT WORKING	Sridhar. K.	checked and found that rust issue.cleaned the rust		Lakshmi Devi. R. - OPD	10/01/2023
Comp. Dt. : 18/01/2023 Status : Completed								
901	23010627	General Medicine - OPD	BP APPARATUS [4NOS] NOT WORKING	Gurumoorthy. G.	replaced the bulb with valve and bladder		Bharathi.D. - OPD	18/01/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 28/01/2023 Status : Completed								
902	23011007	DENTAL OPD -2ND FLOOR	NEED SERVICE FOR DENTAL CHAIR MICROMOTOR ENGINE	Sridhar. K.	CHECKED AND FOUND THAT RUST ISSUE.CLEANED THE RUST		Kanakarani. R. - OPD	28/01/2023
Comp. Dt. : 03/02/2023 Status : Completed								
903	23020110	DENTAL OPD -2ND FLOOR	FILLING INSTRUMENT BROKEN - NEED TO CHECK	Sridhar. K.	checked and found that broken the instrument.need to replace new one		Priyadharshini. S. - OPD	06/02/2023
Comp. Dt. : 04/02/2023 Status : Completed								
904	23020130	OG-OPD	FOCUS LIGHT NOT WORKING	Gurumoorthy. G.	replaced the lamp		Velangkanni. K. - OPD	06/02/2023
Comp. Dt. : 06/02/2023 Status : Completed								
905	23020165	ENT OPD	LIGHT SOURCE LIGHT NOT WORKING	Gurumoorthy. G.	replaced the lamp		Ezhilarasi. M. - OPD	06/02/2023
Comp. Dt. : 07/02/2023 Status : Completed								
906	23020231	Ophthalmology - OPD	BP APPARATUS 2 NOS NOT WORKING	Gurumoorthy. G.	replaced the bladder		Seetha. R. - OPD	07/02/2023
Comp. Dt. : 13/02/2023 Status : Completed								
907	23020458	OG OT	BP APPARATUS NOT WORKING	Gurumoorthy. G.	replaced the bulb with valve		Velangkanni. K. - OPD	13/02/2023
Comp. Dt. : 17/02/2023 Status : Completed								
908	23020691	General Medicine - OPD	BP APPARATUS 4 NOS NOT WORKING	Vignesh. D.	BULB AND BLADDER REPLACED NOW WORKING GOOD		Bharathi.D. - OPD	17/02/2023
Comp. Dt. : 21/02/2023 Status : Completed								
909	23020811	ENT OPD	LIGHT SOURCE LIGHT NOT WORKING	Vignesh. D.	replaced the new lamp working		Ezhilarasi. M. - OPD	22/02/2023
Comp. Dt. : 25/02/2023 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
910	23020964	Orthopaedics - OPD	BP APPARATUS NOT WORKING	Vignesh. D.	replaced the cuff		Durgadevi. J - OPD	27/02/2023
911	23020974	General Medicine - OPD	BP APPARATUS 3 NOS NOT WORKING	Vignesh. D.	replaced the bladder		Bharathi.D. - OPD	27/02/2023
Comp. Dt. :		02/03/2023						
Status :		Completed						
912	23030096	OG-OPD	BP APPARATUS NOT WORKING	Gurumoorthy. G.	serviced now working		Velangkanni. K. - OPD	02/03/2023
913	23030097	ENT OPD	LIGHT SOURCE LIGHT NOT WORKING	Sridhar. K.	replaced lamp now working		Ezhilarasi. M. - OPD	02/03/2023
Comp. Dt. :		06/03/2023						
Status :		Completed						
914	23030200	Ophthalmology - OPD	FOCUS LIGHT NOT WORKING	Sridhar. K.	replaced the lamp		Seetha. R. - OPD	06/03/2023
Comp. Dt. :		08/03/2023						
Status :		Completed						
915	23030310	DENTAL OPD -2ND FLOOR	WATER NOT COMING IN DENTAL CHAIR AROTAL	Sridhar. K.	hose connection problem.the problem is rectified		Lakshmi Devi. R. - OPD	13/03/2023
Comp. Dt. :		09/03/2023						
Status :		Completed						
916	23030380	OG-OPD	NEED TO CHECK WEIGHT MACHINE - NOT WORKING	Gurumoorthy. G.	replaced the battery		Velangkanni. K. - OPD	13/03/2023
Comp. Dt. :		13/03/2023						
Status :		Completed						
917	23030478	CARDIOLOGY OPD	BP APPARATUS NOT WORKING	Gurumoorthy. G.	replaced the lamp		Radhika. R. - OPD	14/03/2023
Comp. Dt. :		14/03/2023						
Status :		Completed						
918	23030558	ENT OPD	NEED TO CHANGE LIGHT SOURCE LIGHT - NOT WORKING	Gurumoorthy. G.	replaced the lamp		Ezhilarasi. M. - OPD	14/03/2023
Comp. Dt. :		20/03/2023						
Status :		Completed						
919	23030823	OG-OPD	NEED TO CHANGE FOCUS LIGHT LAMP - NOT WORKING	Sridhar. K.	replaced the lamp		Velangkanni. K. - OPD	24/03/2023
Comp. Dt. :		21/03/2023						
Status :		Completed						
920	23030867	DENTAL OPD -2ND FLOOR	X RAY MACHINE NOT WORKING	Sridhar. K.	settings issue.the problem is rectified		Lakshmi Devi. R. - OPD	24/03/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 22/03/2023 Status : Completed								
921	23030919	DENTAL OPD -2ND FLOOR	DENTAL CHAIR LIGHT NOT WORKING	Gurumoorthy. G.	checked and found that lamp wire connection problem.the problem is rectified.		Lakshmi Devi. R. - OPD	25/03/2023
Comp. Dt. : 27/03/2023 Status : Completed								
922	23031117	TB & Chest OPD	WEIGHT MACHINE NOT WORKING	Vignesh. D.	genral services working		Jothi.R. - OPD	28/03/2023
Comp. Dt. : 29/03/2023 Status : Completed								
923	23031241	DENTAL OPD -2ND FLOOR	NEED TO CHECK DENTAL CHAIR AIROTOR TUBE - WATER NOT COMING	Sridhar. K.	service done now working good		Lakshmi Devi. R. - OPD	03/04/2023
Comp. Dt. : 13/04/2023 Status : Completed								
924	23040392	Nephrology OPD	B P APPARATUS NOT WORKING	Vignesh. D.	BULP REPLACED NOW WORKING		Jenifer. K. - OPD	18/04/2023
Comp. Dt. : 17/04/2023 Status : Completed								
925	23040515	OG-OPD	NEED TO CHANGE BATTERY FOR WEIGHT MACHINE	Vignesh. D.	BATTERY REPLACED WORKING		Velangkanni. K. - OPD	18/04/2023
926	23040534	Nephrology OPD	BP APPARATUS NOT WORKING	Vignesh. D.	BLADDER ISSUE RECTIFIED WORKING		Jenifer. K. - OPD	18/04/2023
Comp. Dt. : 19/04/2023 Status : Completed								
927	23040604	OG-OPD	MEASUREMENT NUMBERS NOT DISPLAY - NEED TO CHANGE HEIGHT SCALE -	Gurumoorthy. G.	scale adjustment problem. the problem is rectified.		Velangkanni. K. - OPD	20/04/2023
Comp. Dt. : 24/04/2023 Status : Completed								
928	23040725	Orthopaedics - OPD	NEED TO CHANGE BATTERY FOR DIGITAL WEIGHT MACHINE	Sridhar. K.	replaced the battery		Durgadevi. J - OPD	24/04/2023
929	23040734	Ophthalmology - OPD	BP APPARATUS NOT WORKING	Gurumoorthy. G.	replaced the bulb with valve		Seetha. R. - OPD	24/04/2023
930	23040735	DERMATOLOGY OPD	BP APPARATUS NOT WORKING	Gurumoorthy. G.	replaced the bladder		Seetha. R. - OPD	24/04/2023
Comp. Dt. : 25/04/2023								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
931	23040802	DERMATOLOGY OPD	OT LIGHT NOT WORKING	Vignesh. D.	replaced the lamp		Jothiammal. S. - OPD	02/05/2023
Comp. Dt. : 02/05/2023								
Status : Completed								
932	23050010	Paediatrics - OPD	WEIGHT MACHINE NOT WORKING	Gurumoorthy. G.	replaced the battery		Subashree. R. - OPD	02/05/2023
Comp. Dt. : 15/05/2023								
Status : Completed								
933	23050564	CTVS-ROOM NO.225 -2ND FLOOR	DIGITAL WEIGHT MACHINE NOT WORKING	Vignesh. D.	replaced the battery		Suvitha. R. - OPD	17/05/2023
Comp. Dt. : 18/05/2023								
Status : Completed								
934	23050749	Paediatrics - OPD	BP APPARATUS NOT WORKING	Gurumoorthy. G.	replaced the bulb with valve		Subashree. R. - OPD	18/05/2023
Comp. Dt. : 22/05/2023								
Status : Completed								
935	23050851	Paediatrics - OPD	WEIGHT MACHINE NOT WORKING	Gurumoorthy. G.	charger connection problem.the problem is rectified.		Murugeswari. V. - OPD	23/05/2023
Comp. Dt. : 23/05/2023								
Status : Completed								
936	23050908	Nephrology OPD	STETHOSCOPE NOT WORKING	Sridhar. K.	replaced now working		Jenifer. K. - OPD	23/05/2023
Comp. Dt. : 24/05/2023								
Status : Completed								
937	23050951	Nephrology OPD	BP APPARATUS NOT WORKING	Sridhar. K.	cuff badder replaced now working		Suvitha. R. - OPD	24/05/2023
938	23050971	IVF ART CLINIC-INSIDE OF OG OPD(NO.68)	TOP LIGHT [INSIDE OT] NOT WORKING	Sridhar. K.	ot light serviced working	AssetNo :16000876	Nagalakshmi. M. - OPD	29/05/2023
Comp. Dt. : 25/05/2023								
Status : Completed								
939	23050999	NEUROLOGY OPD-2ND FLOOR	BP APPARATUS NOT WORKING	Sridhar. K.	serviced now working		Radhika. R. - OPD	27/05/2023
Comp. Dt. : 26/05/2023								
Status : Completed								
940	23051022	TB & Chest OPD	B P APPARATUS NOT WORKING	Sridhar. K.	serviced now working		Kamala.D. - OPD	27/05/2023

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 27/05/2023								
Status : Completed								
941	23051082	OG-OPD	BP APPARATUS [4NOS] NOT WORKING	Sridhar. K.	bulb replaced working		Velangkanni. K. - OPD	29/05/2023
Comp. Dt. : 01/06/2023								
Status : Completed								
942	23060018	General Medicine - OPD	B P APPARATUS [2NOS] NOT WORKING	Gurumoorthy. G.	replaced the bulb with valve		Bharathi.D. - OPD	02/06/2023
Comp. Dt. : 03/06/2023								
Status : Completed								
943	23060101	Biomedical	BP APPARATUS NOT WORKING	Sridhar. K.	BP APP SERVICED NOW WORKING		Radhika. R. - OPD	03/06/2023
Comp. Dt. : 07/06/2023								
Status : Completed								
944	23060233	CARDIOLOGY OPD	BP APPARATUS NOT WORKING	Gokul. P. K.	replaced the bulb with valve		Radhika. R. - OPD	09/06/2023
Comp. Dt. : 12/06/2023								
Status : Completed								
945	23060390	General Medicine - OPD	BP APPARATUS 4 NOS NOT WORKING	Sridhar. K.	replaced the bulb with valve and bladder		Bharathi.D. - OPD	12/06/2023
Comp. Dt. : 16/06/2023								
Status : Completed								
946	23060601	OG-OPD	BP APPARATUS NOT WORKING(1059)	Gokul. P. K.	SERVICED BP APPARATUS		Adhilakshmi. A. - OPD	16/06/2023
Comp. Dt. : 21/06/2023								
Status : Completed								
947	23060761	Surgery OPD	B P CUFF DAMAGE - NEED TO CHANGE	Gokul. P. K.	replaced the cuff and bulb with valve.		Indhira. M. - OPD	21/06/2023
Comp. Dt. : 26/06/2023								
Status : Completed								
948	23060944	IVF ART CLINIC-INSIDE OF OG OPD(NO.68)	MULTIPARA MONITOR NOT WORKING	Gurumoorthy. G.	checked and found that button issue.the problem is rectified.		Nagalakshmi. M. - OPD	27/06/2023
949	23060968	DENTAL OPD -2ND FLOOR	COMPRESSURE NOT WORKING	Sridhar. K.	GENRAL SERVICED NOW WORKING		Lakshmi Devi. R. - OPD	27/06/2023
Dept Name : Operation Theatre - Biomedical								
Comp. Dt. : 04/05/2022								
Status : Completed								

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
950	22050073	New OT	SPO2 MONITOR [STAR 55] NOT WORKING	Gurumoorthy. G.	chcked and found problem in mother connection problem.the problem is rectified		Palaniraja. G. - Operation Theatre	18/07/2022
951	22050087	ORTHO OT	C ARM MACHINE NOT WORKING	Gurumoorthy. G.	checked and found problem in foot lock assembly so remove and service it problem rectified.		Sendhil Kumar. C. - Operation Theatre	05/05/2022
Comp. Dt. : 05/05/2022 Status : Completed								
952	22050144	New OT	C ARM CONNECT MONITOR NOT WORKING	Gurumoorthy. G.	checked and found problem in trolly cable,replaced new trolly cable.now working good.	AssetNo :16000202	Palaniraja. G. - Operation Theatre	18/05/2022
Comp. Dt. : 10/05/2022 Status : Completed								
953	22050349	SURGERY OT	DIATHERMY COVIDIEN MACHINE BIPOLAR CABLE NOT WORKING	Gurumoorthy. G.	checked and found that foot switch connection problem.the problem is rectfied.now its working good.		Sobiya. N. - Operation Theatre	12/05/2022
Comp. Dt. : 11/05/2022 Status : Completed								
954	22050390	OG OT	MOTOR SUCTION NOT WORKING	Sridhar. K.	checked and found problem in power cord loose contact so removed and refix it problem rectified		Ramamoorthy.T.K - Operation Theatre	14/05/2022
Comp. Dt. : 20/05/2022 Status : Completed								
955	22050752	OG OT	DIATHERMY NOT WORKING	Gurumoorthy. G.	checked and found that foot switch wire connection problem.the problem is rectfied.now its working g		Ramamoorthy.T.K - Operation Theatre	23/05/2022
Comp. Dt. : 23/05/2022 Status : Completed								
956	22050841	OG OT	OT TABLE NOT WORKING	Gurumoorthy. G.	checked and found problem in fuse defective so it replaced with the new one problem rectified		Priyadarshini. B. - Operation Theatre	24/05/2022
Comp. Dt. : 24/05/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
957	22050880	New OT	NIPB PROBLEM IN RECOVERY MONITOR	Gurumoorthy. G.	CHECKED AND FOUND THE NIBP MODULE ISSUE SO REPLACED THE NIBP MODULE FROM THE OLD MACHINE NOW UNIT WO	AssetNo :16000062	Kousalya. S. - Operation Theatre	25/05/2022
Comp. Dt. : 25/05/2022 Status : Completed								
958	22050934	OG OT	ANESTHESIA BOYLE'S MACHINE NOT WORKING	Gurumoorthy. G.	CHECKED AND FOUND PROBLEM IN O2 SENSOR DEFECTIVE NEED TO BE REPLACED now the machine is working	AssetNo :16000917	Sathia. R. - Operation Theatre	25/05/2022
Comp. Dt. : 26/05/2022 Status : Completed								
959	22050986	EMERGENCY OT NEAR CASUALTY	DIATHERMY NOT WORKING	Vignesh. D.	checked and found that foot switch issue.the problem is rectified.now its working good.	AssetNo :16000260	Narayanan.R. - Operation Theatre	30/05/2022
Comp. Dt. : 28/05/2022 Status : Completed								
960	22051042	OG OT	LAPAROSCOPY RECORDING SYSTEM - NOT WORKING	Gurumoorthy. G.	checked and found problem in recording system software corrupted. software reinstaled now it's worki		Vinotha. G. - Operation Theatre	02/07/2022
961	22051045	New OT	COVIDIEN DIATHERMY MACHINE NOT WORKING	Sridhar. K.	checked and found problem in fuse connector loose contact so it remove and refix it problem rectifie		Jayapratha. S. - Operation Theatre	30/05/2022
Comp. Dt. : 31/05/2022 Status : Completed								
962	22051136	New OT	SPO2 PROBE NOT WORKING IN MULTIPARA MONITOR	Gurumoorthy. G.	checked and found that spo2 probe sensor is defective.replaced the new spo2 probe.now its working go	AssetNo :16000816	Kousalya. S. - Operation Theatre	31/05/2022
Comp. Dt. : 01/06/2022 Status : Completed								
963	22060016	Main OT	SYNTHE DRILL NOT WORKING	Gurumoorthy. G.	checked and found that synthes hand piece and ream bit is internal bearing.the problem is rectified		Mahalakshmi. G. - Operation Theatre	02/01/2023
Comp. Dt. : 02/06/2022								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
964	22060052	ORTHO OT	NIBP NOT WORKING	Gurumoorthy. G.	nibp modul issue.the problem is rectified.		Mahalakshmi. G. - Operation Theatre	02/01/2023
965	22060075	Main OT	G E BOYLES MACHINE O2 SENSOR NOT WORKING	Gurumoorthy. G.	checked and found that o2 sensor connection problem.the problem is rectified.		Sendhil Kumar. C. - Operation Theatre	22/06/2022
966	22060082	New OT	NEW OT ULTRA SOUND MACHINE NOT WORKING	Gurumoorthy. G.	checked and found that booting problem,unit restarted now working good.	AssetNo :16000973	Jayapratha. S. - Operation Theatre	02/06/2022
Comp. Dt. : 03/06/2022								
Status : Completed								
967	22060112	ORTHO OT	DIATHERMY [OPHTHAL] NOT WORKING	Vignesh. D.	checked and refixed the power card now unit working good	AssetNo :16000261	Radhika. R. - Operation Theatre	04/06/2022
968	22060117	ORTHO OT	DIATHERMY MACHINE NOT WORKING	Vignesh. D.	checked and found problem in earth plate connector loose contact so it remove and refix it problem r		Sendhil Kumar. C. - Operation Theatre	03/06/2022
Comp. Dt. : 06/06/2022								
Status : Completed								
969	22060228	SPECIALITY OT	DISPLAY PROBLEM IN PHILIP'S MONITOR	Gurumoorthy. G.	checked and found that display wiring problem,refixed the display cable now working good.		Evangelin. S. - Operation Theatre	09/06/2022
Comp. Dt. : 07/06/2022								
Status : Completed								
970	22060270	ORTHO OT	MANMAN MOTOR NOT WORKING	Sridhar. K.	checked and found that motor issue .serviced in company now it's working good.	AssetNo :16001061	Mahalakshmi. G. - Operation Theatre	05/07/2022
Comp. Dt. : 08/06/2022								
Status : Completed								
971	22060316	EMERGENCY OT NEAR CASUALTY	DIATHERMY NOT WORKING	Vignesh. D.	checked and found that earthplate problem,replaced new earthplate now working good.	AssetNo :16000791	Narayanan.R. - Operation Theatre	09/06/2022
Comp. Dt. : 10/06/2022								
Status : Completed								

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
972	22060375	SPECIALITY OT	2 NO'S DIATHERMY BIPOLAR CABLE NOT WORKING	Sridhar. K.	replaced the foot switch,bipolar forceps with cable and patient plate	AssetNo :16000791	Palaniraja. G. - Operation Theatre	18/06/2022
Comp. Dt. : 14/06/2022 Status : Completed								
973	22060519	SPECIALITY OT	REMOTE TABLE NOT WORKING	Sridhar. K.	checked and found that table tilt not working, refixed the control cable,now working good.	AssetNo :16000511	Palaniraja. G. - Operation Theatre	14/06/2022
974	22060529	SPECIALITY OT	"G" MONITOR B P CUFF NOT WORKING	Sridhar. K.	CHECKED AND FOUND THE BP CUFF ISSUE. REPLACED THE NEW CUFF WORKING GOOD		Palaniraja. G. - Operation Theatre	01/07/2022
Comp. Dt. : 15/06/2022 Status : Completed								
975	22060541	ophthal ot	NEED TO CHECK OPHTHAL CATER BOX	Sridhar. K.	checked and found that foot switch problem.the problem is rectified.		Pavadharani. S. - Operation Theatre	18/06/2022
976	22060579	OG OT	NEED TO CHANGE LIGHT SOURCE LIGHT	Sridhar. K.	replaced the light source lamb now it's working good		Ramamoorthy.T.K - Operation Theatre	17/06/2022
Comp. Dt. : 16/06/2022 Status : Completed								
977	22060629	SPECIALITY OT	ECG CABLE NOT WORKING	Sridhar. K.	ECG CABLE ISSUE RECOMMENED TO PURCHASE NEW ONE		Devanathan. S. - Operation Theatre	17/06/2022
Comp. Dt. : 17/06/2022 Status : Completed								
978	22060638	OG OT	NEED TO CHECK LIGHT SOURCE	Sridhar. K.	recomplaint		Ramamoorthy.T.K - Operation Theatre	17/06/2022
Comp. Dt. : 27/06/2022 Status : Completed								
979	22060979	New OT	NEED TO REFIX SCREW FOR WORKING ELEMENT MACHINE	Gurumoorthy. G.	refix the srew		Jagatheeswaran. G. - Operation Theatre	27/06/2022
Comp. Dt. : 28/06/2022 Status : Completed								
980	22060997	Main OT	DIATHERMI MACHINE NOT WORKING	Sridhar. K.	checked and found fuse problem.replaced the fuse		Sendhil Kumar. C. - Operation Theatre	25/07/2022
981	22061030	SPECIALITY OT	DIATHERMI MACHINE (2NOS) NOT WORKING	Sridhar. K.	checked and found that wire connection and connector problem.the problem is rectified		Apratha. S. - Operation Theatre	25/07/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 29/06/2022								
Status : Completed								
982	22061037	New OT	NEED TO CHECK LAPAROSCOPY CAMERA CABLE HEAD - LOOSE	Gurumoorthy. G.	cable loose connection issue. cable cleaned and fixed now it's working good		Jayapratha. S. - Operation Theatre	01/07/2022
983	22061043	ORTHO OT	BUR HAND PIECE & MANMAN REAMER HANDPIECE - NOT WORKING old 2nos	Sridhar. K.	outside company service(medifield) is completed.now working good.		Mahalakshmi. G. - Operation Theatre	17/12/2022
Comp. Dt. : 01/07/2022								
Status : Completed								
984	22070041	OG OT	LIGHT SOURCE LIGHT NOT WORKING	Gurumoorthy. G.	wire connection issue it rectified now it's working good		Ramamoorthy.T.K - Operation Theatre	02/07/2022
Comp. Dt. : 04/07/2022								
Status : Completed								
985	22070123	ORTHO OT	MAN MAN MACHINE GUN CONNULATED NOT WORKING	Sridhar. K.	checked and found the problem in man gun(1) company service now its working gate pass772	AssetNo :16001062	Mahalakshmi. G. - Operation Theatre	20/07/2022
Comp. Dt. : 07/07/2022								
Status : Completed								
986	22070283	ORTHO OT	BP CUFF NOT WORKING	Vignesh. D.	bulb changed now it's working good		Shankari. G. - Operation Theatre	07/07/2022
Comp. Dt. : 12/07/2022								
Status : Completed								
987	22070479	SPECIALITY OT	PULSE OXI METER MONITOR NOT WORKING	Gurumoorthy. G.	checked and found that spo2 probe loose connection problem.the problem is rectfied.now its working g		Kousalya. S. - Operation Theatre	14/07/2022
988	22070486	ORTHO OT	MULTIPARA MONITOR NOT WORKING	Sridhar. K.	REPLACE NIBP HOSE, CUFF, SPO2 PROBE NOW WORKING	AssetNo :16000040	Mahalakshmi. G. - Operation Theatre	12/07/2022
Comp. Dt. : 14/07/2022								
Status : Completed								
989	22070557	OG OT	A L M LIGHT HANDLE BROKE	Sridhar. K.	replaced the ot light handle washer its now working	AssetNo :16000478	Amudha. V. - Operation Theatre	14/07/2022
Comp. Dt. : 18/07/2022								
Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
990	22070653	ORTHO OT	C ARM 5 C NOT WORKING	Gurumoorthy. G.	checked and found that trolley cable loose connection problem.the problem is rectified		Mahalakshmi. G. - Operation Theatre	19/07/2022
991	22070658	SPECIALITY OT	DIATHERMY MACHINE NOT WORKING	Sridhar. K.	checked and found that patient plate connector problem.the problem is rectified		Jayapratha. S. - Operation Theatre	20/07/2022
Comp. Dt. : 19/07/2022 Status : Completed								
992	22070686	SPECIALITY OT	DIATHERMY MACHINE 2NOS NOT WORKING	Gurumoorthy. G.	checked and found that earth plate connection problem.the problem is rectified		Evangelin. S. - Operation Theatre	19/07/2022
Comp. Dt. : 20/07/2022 Status : Completed								
993	22070737	E C T WARD - IV FLOOR	NEED TO CHECK BOYLES APPARATUS	Gurumoorthy. G.	checked and found the leakage problem it's rectified now it's working good		Palaniraja. G. - Operation Theatre	21/07/2022
Comp. Dt. : 22/07/2022 Status : Completed								
994	22070827	SPECIALITY OT	BOYLES APPARATUS NOT WORKING	Gurumoorthy. G.	checked and found that bellows connection problem.the problem is rectified		Narayanan.R. - Operation Theatre	25/07/2022
Comp. Dt. : 25/07/2022 Status : Completed								
995	22070905	SPECIALITY OT	ANAESTHESIA WORKSTATION [GE] NOT WORKING	Gurumoorthy. G.	checked and found that flow sensor connection problem.the problem is rectified	AssetNo :16000122	Jayapratha. S. - Operation Theatre	27/07/2022
Comp. Dt. : 01/08/2022 Status : Completed								
996	22080009	Main OT	NEED TO CHECK DIATHERMY FOOT SWITCH - NOT WORKING	Gurumoorthy. G.	checked and found that wire connection problem.the problem is rectified.		Palaniraja. G. - Operation Theatre	05/08/2022
Comp. Dt. : 09/08/2022 Status : Completed								
997	22080296	CSSD	AUTOCLAVE MACHINE 2 NOS NOT WORKING	Vignesh. D.	checked and found that coil defective.replaced the new coil.	AssetNo:16000122	Samamoorthy.T.K - Operation Theatre	23/08/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
998	22080336	SPECIALITY OT	GLUCO METER NOT WORKING	Gurumoorthy. G.	BATTERY ADJUSTMENT NOW ITS WORKING GOOD		Sobiya. N. - Operation Theatre	10/08/2022
Comp. Dt. : 17/08/2022 Status : Completed								
999	22080535	SPECIALITY OT	BOYLES EQUIPMENT PROBLEM	Gurumoorthy. G.	checked and found that canister connection issue it's rectified now working good	AssetNo :16000151	Abarna. M. - Operation Theatre	01/09/2022
Comp. Dt. : 19/08/2022 Status : Completed								
1000	22080624	SURGERY OT	STERLIZER WATER LEAKAGE	Gurumoorthy. G.	electrical complaint		Ramachandiran. M. - Operation Theatre	01/09/2022
1001	22080642	ORTHO OT	MULTIPARA MONITOR NOT WORKING	Gurumoorthy. G.	checked and found that display problem.tyhe problem is rectified.		Bhuvaneswari. I. - Operation Theatre	02/01/2023
1002	22080643	ORTHO OT	PHILIPS MONITOR NOT WORKING	Gurumoorthy. G.	checked and found that NIBP module problem.the problem is rectified		Bhuvaneswari. I. - Operation Theatre	02/01/2023
Comp. Dt. : 23/08/2022 Status : Completed								
1003	22080764	SPECIALITY OT	DIA THERMY NOT WORKING	Gurumoorthy. G.	checked and found that bipolar cable problem.the problem is rectified		Deepa. I. - Operation Theatre	23/08/2022
Comp. Dt. : 26/08/2022 Status : Completed								
1004	22080865	SPECIALITY OT	NEED DIATHERMY MACHINE ACCESSORIES	Gurumoorthy. G.	checked and found that earth plate and foot switch problem.replaced the new foot switch and earth pl	AssetNo :16000266	Jayapratha. S. - Operation Theatre	29/08/2022
1005	22080921	SPECIALITY OT	PROBLEM IN RECOVERY MONITOR BP	Gurumoorthy. G.	checked and found the nibp connection issue it's rectified now it's working good		Narayanan.R. - Operation Theatre	01/09/2022
Comp. Dt. : 27/08/2022 Status : Completed								
1006	22080954	NEUROLOGY	SPO2 PROBE & MONITOR NOT WORKING - INTERCOM NO 1159	Gurumoorthy. G.	spo2 probe issue it's replaced now it's working good		Punitha. A. - Operation Theatre	01/09/2022
Comp. Dt. : 30/08/2022 Status : Completed								
1007	22081022	OG OT	BABY WARMER NOT WORKING	Gurumoorthy. G.	connection issue working good		Murugan. M. - Operation Theatre	01/09/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 01/09/2022 Status : Completed								
1008	22090004	OG OT	WARMER NOT WORKING	Vignesh. D.	checked and found the heating coil wire connection problem.the problem is rectified.		Amudha. V. - Operation Theatre	03/09/2022
Comp. Dt. : 02/09/2022 Status : Completed								
1009	22090073	Main OT	MANNAN MOTOR FOOT PETAL REPAIR	Gurumoorthy. G.	checked and found that foot switch srew connection problem.the problem is rectified.		Shankari. G. - Operation Theatre	03/09/2022
Comp. Dt. : 07/09/2022 Status : Completed								
1010	22090276	New OT	PROBLEM IN MONITOR CABLE IN UROLOGY OT	Gurumoorthy. G.	checked and founf that bnc cable problem.replaced the new cable		Ramachandiran. M. - Operation Theatre	08/09/2022
Comp. Dt. : 10/09/2022 Status : Completed								
1011	22090386	New OT	MULTIPARA MONITOR PULSE PROBE NOT WORKING [2 NOS]	Gurumoorthy. G.	SPO2 PROBE CHANGED NOW IT'S WORKING GOOD		Ramachandiran. M. - Operation Theatre	10/09/2022
Comp. Dt. : 19/09/2022 Status : Completed								
1012	22090747	OG OT	FUMIGATION MACHINE NOT WORKING	Gurumoorthy. G.	checked and found that filter problem.replaced the filter		Ranjani. V. - Operation Theatre	24/09/2022
Comp. Dt. : 27/09/2022 Status : Completed								
1013	22091074	EMERGENCY OT NEAR CASUALTY	NEED TO CHECK OT LIGHT NOT WORKING	Sridhar. K.	BUBL REPLACED NOW WORKING GOOD		Priyadarshini. B. - Operation Theatre	27/09/2022
Comp. Dt. : 03/10/2022 Status : Completed								
1014	22100014	NICU	WARMER NOT WORKING	Vignesh. D.	replace temp probe its now working		Sobiya. N. - Operation Theatre	03/10/2022
Comp. Dt. : 08/10/2022 Status : Completed								
1015	22100181	SPECIALITY OT	CO VAPORIZER NOT WORKING	Gurumoorthy. G.	checked and found that internal leakage issue.the problem is rectified.		Suyapratha. S. - Operation Theatre	31/10/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 14/10/2022 Status : Completed								
1016	22100476	SURGERY OT	NEED TO CHECK BIPOLAR CABLE - NOT WORKING	Gurumoorthy. G.	checked and found that cable conection problem.the problem is rectified		Anitha. R. - Operation Theatre	14/10/2022
Comp. Dt. : 25/10/2022 Status : Completed								
1017	22100776	SPECIALITY OT	MULTIPARA MONITOR GE ETCO2 NOT WORKING	Gurumoorthy. G.	checked and found that gas analyser module loose connection problem.the problem is rectified.		Narayanan.R. - Operation Theatre	26/10/2022
Comp. Dt. : 05/11/2022 Status : Completed								
1018	22110183	New OT	UROLOGY -TURB WORKINF ELEMENT SCREW REFIXING WORK NEED TO DO	Sridhar. K.	company serviced done now itsn working.		Ramachandiran. M. - Operation Theatre	28/11/2022
Comp. Dt. : 11/11/2022 Status : Completed								
1019	22110481	SPECIALITY OT	MULTIPARA MONITOR SPO2 PROBE NOT WORKING	Gurumoorthy. G.	checked and found that spo2 probe connection problem.the problem is rectified		Sobiya. N. - Operation Theatre	19/11/2022
Comp. Dt. : 14/11/2022 Status : Completed								
1020	22110497	OG OT	PROBLEM IN MONITOR - ECG	Gurumoorthy. G.	checked and found that ECG cable defective.replaced the new ecg cable	AssetNo :16000069	Avina. A. - Operation Theatre	15/11/2022
Comp. Dt. : 15/11/2022 Status : Completed								
1021	22110565	OG OT	PLANET 45 ECG CABLE NOT WORKING	Gurumoorthy. G.	checked and found that ecg cable defective.replaced the new ECG cable.	AssetNo :16000813	Ranjani. V. - Operation Theatre	15/11/2022
Comp. Dt. : 25/11/2022 Status : Completed								
1022	22111114	Main OT	BP APPARATUS NOT WORKING	Vignesh. D.	replaced the bladder		Shankari. G. - Operation Theatre	26/11/2022
Comp. Dt. : 28/11/2022								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
1023	22111162	CSSD	COMPRESSOR MOTOR PROBLEM	Gurumoorthy. G.	TUBE REPLACED WORKING		Ramamoorthy.T.K - Operation Theatre	01/12/2022
Comp. Dt. : 30/11/2022								
Status : Completed								
1024	22111258	Main OT	NEED TO CHANGE BOIL'S O2 TUBE - LEAKAGE	Sridhar. K.	checked and found that o2 leakage issue.replaced the hose clamp		Palaniraja. G. - Operation Theatre	30/11/2022
1025	22111294	OG OT	WARMER NOT WORKING	Gurumoorthy. G.	HEATING COIL CONNECTION ISSUE IT'S RECTIFIED NOW WORKING GOOD		Srivalli. G. - Operation Theatre	01/12/2022
Comp. Dt. : 02/12/2022								
Status : Completed								
1026	22120055	ORTHO OT	MANMAN ROPE 3NOS AND HAND PIECE-3NOS NOT WORKING	Gurumoorthy. G.	checked and found that rope-3nos and hand piece-3nos problem.the problem is rectified		Mahalakshmi. G. - Operation Theatre	02/01/2023
Comp. Dt. : 05/12/2022								
Status : Completed								
1027	22120205	OG OT	WARMER NOT WORKING	Gurumoorthy. G.	checked and found that coil wire conection problem.the problem is rectified.		Subashini. E. - Operation Theatre	07/12/2022
Comp. Dt. : 13/12/2022								
Status : Completed								
1028	22120606	SPECIALITY OT	MULTIPARA MONITOR PROBE NOT WORKING	Gurumoorthy. G.	checked and found that spo2 sensor is defective.replaced the new spo2 probe.	AssetNo :16000061	Jayapratha. S. - Operation Theatre	17/12/2022
Comp. Dt. : 14/12/2022								
Status : Completed								
1029	22120665	New OT	PROBLEM IN MANMAN DRILL GUN	Sridhar. K.	checked and found that drill issue.service completed		Shankari. G. - Operation Theatre	02/01/2023
Comp. Dt. : 15/12/2022								
Status : Completed								
1030	22120738	SPECIALITY OT	M R I MONITOR NOT WORKING	Gurumoorthy. G.	new spo2 probe replace working		Narayanan.R. - Operation Theatre	21/12/2022
Comp. Dt. : 19/12/2022								
Status : Completed								
1031	22120861	Biomedical	UROLOGY MACHINE PEDAL BROKEN	Gurumoorthy. G.	serviced now working		Ramachandiran. M. - Operation Theatre	21/12/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 20/12/2022 Status : Completed								
1032	22120922	Main OT	O2 LEAKAGE (1117)	Gurumoorthy. G.	REPLACED THE TUBE NOW WORKING GOOD		Palaniraja. G. - Operation Theatre	21/12/2022
Comp. Dt. : 27/12/2022 Status : Completed								
1033	22121226	EMERGENCY OT NEAR CASUALTY	RECORDING SYSTEM NOT WORKING	Gurumoorthy. G.	checked and found that recording software is not working.booted the software.now working good.		Hemalatha.G. - Operation Theatre	02/01/2023
Comp. Dt. : 03/01/2023 Status : Completed								
1034	23010068	New OT	MULTIPARA MONITER BP NOT WORKING	Gurumoorthy. G.	BP CUFF REPLACED NOW WORKING GOOD		Kousalya. S. - Operation Theatre	03/01/2023
Comp. Dt. : 04/01/2023 Status : Completed								
1035	23010134	New OT	LITHOTRIPSY MACHINE AIR LEAKAGE (UROLOGY OT)	Gurumoorthy. G.	key plug replaced now working	AssetNo :16000411	Kousalya. S. - Operation Theatre	04/01/2023
Comp. Dt. : 07/01/2023 Status : Completed								
1036	23010295	OG OT	NITROGEN PIPELINE PENTON NEED TO BE CHANGE	Gurumoorthy. G.	chenged to the N2 key plugs		Devanathan. S. - Operation Theatre	07/01/2023
Comp. Dt. : 13/01/2023 Status : Completed								
1037	23010576	SPECIALITY OT	VENTILATOR BOILS LEAKAGE - INTERCOM NO 1124	Gurumoorthy. G.	checked and found that canister connection problem.the problem is rectified.	AssetNo :16000121	Sobiya. N. - Operation Theatre	14/01/2023
Comp. Dt. : 23/01/2023 Status : Completed								
1038	23010827	OG OT	ANAESTHESIA MACHINE NOT WORKING	Gurumoorthy. G.	checked and found that o2 sensor cable loose connection problem.the problem is rectified.		Subashini. E. - Operation Theatre	23/01/2023
Comp. Dt. : 25/01/2023 Status : Completed								
1039	23010925	SPECIALITY OT	VENTILATOR BOILS NOT WORKING	Gurumoorthy. G.	o2 connection issue it's rectified now working		Narayanan.R. - Operation Theatre	25/01/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 31/01/2023 Status : Completed								
1040	23011113	EMERGENCY OT NEAR CASUALTY	MOVABLE LIGHT NOT WORKING	Gurumoorthy. G.	replaced the lamp		Punitha. A. - Operation Theatre	31/01/2023
Comp. Dt. : 03/02/2023 Status : Completed								
1041	23020102	New OT	GAS LEAKAGE IN SYSTRA LITHOTRIPSY MACHINE - NEED TO CHECK	Gurumoorthy. G.	checked and found that air hose connection problem.the problem is rectified		Punitha. A. - Operation Theatre	06/02/2023
Comp. Dt. : 13/02/2023 Status : Completed								
1042	23020500	Main OT	SURGERY TABLE NOT WORKING	Gurumoorthy. G.	serviced table working		Kuppan.E. - Operation Theatre	14/02/2023
Comp. Dt. : 14/02/2023 Status : Completed								
1043	23020552	SPECIALITY OT	STRYKER MACHINE NOT WORKING	Gurumoorthy. G.	company out serviced working		Jayapratha. S. - Operation Theatre	15/02/2023
Comp. Dt. : 20/02/2023 Status : Completed								
1044	23020776	New OT	O2 SENSOR PROBLEM IN BOILS	Gurumoorthy. G.	replace o2 sensor working		Narayanan.R. - Operation Theatre	21/02/2023
Comp. Dt. : 24/02/2023 Status : Completed								
1045	23020941	Male Psychiatry - Ward 405	LEAKAGE IN BOYLE'S APPARATUS	Gurumoorthy. G.	checked and found that hose damaged.replaced the new hose.		Narayanan.R. - Operation Theatre	27/02/2023
Comp. Dt. : 01/03/2023 Status : Completed								
1046	23030014	New OT	(11590 CRM MACHINE SCREEN NOT WORKING(ONE SIDE SCREEN)	Gurumoorthy. G.	checked and found that monitor power connection problem.the problem is rectified.		Punitha. A. - Operation Theatre	01/03/2023
Comp. Dt. : 06/03/2023 Status : Completed								
1047	23030242	EMERGENCY OT NEAR CASUALTY	NEED TO CHECK LARYNGOSCOPE MONITOR CABLE - PROBLEM	Gurumoorthy. G.	wire connection problem.		Hemalatha.G. - Operation Theatre	08/03/2023
Comp. Dt. : 20/03/2023 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1048	23030827	SURGERY OT	ULTRA SOUND MACHINE - CHARGING PROBLEM	Gurumoorthy. G.	checked and found that power supply PCB issue.the problem is rectified.	AssetNo :16000645	Revathi. M. - Operation Theatre	24/03/2023
Comp. Dt. : 22/03/2023 Status : Completed								
1049	23030926	SURGERY OT	MONITOR NOT WORKING IN RECOVERY ROOM - 2 NOS	Gurumoorthy. G.	spo2 probe issue.replaced the spo2 probe		Logesh. D. - Operation Theatre	25/03/2023
1050	23030927	SURGERY OT	DEFIBRILATOR NOT WORKING	Gurumoorthy. G.	checked and found that padle wire connection problem.the problem is rectified.		Logesh. D. - Operation Theatre	25/03/2023
1051	23030928	SURGERY OT	SUCTION NOT WORKING	Gurumoorthy. G.	wire connection problem.the problem is rectified.		Logesh. D. - Operation Theatre	25/03/2023
1052	23030929	SURGERY OT	C.AM MACHINE MEASUREMENT SCALE CUT PROBLEM	Gurumoorthy. G.	checked and found that monitor power connection problem.the problem is rectified		Logesh. D. - Operation Theatre	27/03/2023
1053	23030930	SURGERY OT	CAUTERY MACHINE PROBLEM	Gurumoorthy. G.	power adapter loose connection problem.the problem is rectified.		Logesh. D. - Operation Theatre	25/03/2023
Comp. Dt. : 03/04/2023 Status : Completed								
1054	23040079	ORTHO OT	MANMAN HAND DRILLING MACHINE NOT WORKING	Sridhar. K.	checked and found that bearing problem.the problem is rectified.		Mahalakshmi. G. - Operation Theatre	04/04/2023
Comp. Dt. : 17/04/2023 Status : Completed								
1055	23040526	New OT	DIATHERMY & SUCTION NOT WORKING	Gurumoorthy. G.	WIRE CONNECTION ISSUE RECTIFIED NOW WORKING,TUBING ISSUE IT'S ALSO RECTIFIED WORKING		Logesh. D. - Operation Theatre	18/04/2023
1056	23040527	New OT	MONITOR NOT WORKING	Gurumoorthy. G.	PROBE ISSUE IT'S RECTIFIED		Logesh. D. - Operation Theatre	18/04/2023
Comp. Dt. : 19/04/2023 Status : Completed								
1057	23040616	SPECIALITY OT	MICRO DEBULATOR NOT WORKING	Gurumoorthy. G.	checked and found that handpiece problem.the problem is rectified.		Hemalatha.G. - Operation Theatre	20/04/2023
Comp. Dt. : 24/04/2023 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1058	23040733	ORTHO OT	NEED TO CHECK - MANMNA MOTOR, DRILL, SAW & REAMER - NOT WORKING	Sridhar. K.	checked and found that rust issue.the problem is rectified.		Mahalakshmi. G. - Operation Theatre	02/05/2023
1059	23040761	UROLOGY	DIATHERMY NOT WORKING	Gurumoorthy. G.	foot switch connection problem.the problem is rectified.		Udhaya Kumar. C. - Operation Theatre	24/04/2023
1060	23040768	SPECIALITY OT	REAMER ATTACHMENT NOT WORKING	Gurumoorthy. G.	reamer attachment connection problem.the problem is rectified.		Gayathri. G. - Operation Theatre	24/04/2023
Comp. Dt. : 28/04/2023 Status : Completed								
1061	23040967	SPECIALITY OT	MANMAN MOTOR NOT WORKING	Gurumoorthy. G.	checked and found that screws is missing.replaced the new screws.		Sobiya. N. - Operation Theatre	02/05/2023
Comp. Dt. : 02/05/2023 Status : Completed								
1062	23050060	SPECIALITY OT	MONITOR 3 NOS NOT WORKING	Sridhar. K.	checked the monitors problem in spo2 probe and nibp cuff issue.replaced the spo2 probe and nibp cuff		Murugan. M. - Operation Theatre	03/05/2023
Comp. Dt. : 08/05/2023 Status : Completed								
1063	23050269	New OT	NEED TO CHECH FOCUS LIGHT 2 NOS NOT WORKING - UROLOGY OT - 109 [INTERCOM NO 1159]	Gurumoorthy. G.	replaced the lamp		Udhaya Kumar. C. - Operation Theatre	09/05/2023
Comp. Dt. : 09/05/2023 Status : Completed								
1064	23050392	MINOR OT NEAR ENDOSCOPY	FOCUS LIGHT NOT WORKING	Gurumoorthy. G.	replaced the lamp		Ramya. P. - OPD	10/05/2023
Comp. Dt. : 15/05/2023 Status : Completed								
1065	23050603	ORTHO OT	MANMAN * C ARM NOT WORKING	Gurumoorthy. G.	checked and found that power cable connection problem.the problem is rectified.		Parthiban. R. - Operation Theatre	17/05/2023
Comp. Dt. : 17/05/2023 Status : Completed								
1066	23050706	New OT	MONITOR NOT WORKING	Gurumoorthy. G.	checked and found that ecg cable problem.the problem is rectified.		Logesh. D. - Operation Theatre	17/05/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 23/05/2023 Status : Completed								
1067	23050941	UROLOGY	FLOW METER NOT WORKING - INTERCOM NO 1159	Gurumoorthy. G.	gas plant complaint		Tamilmozhi. M. - Operation Theatre	24/05/2023
Comp. Dt. : 31/05/2023 Status : Completed								
1068	23051242	SPECIALITY OT	PATIENT TABLE NOT WORKING	Gurumoorthy. G.	fuse issue.replaced the fuse		Sobiya. N. - Operation Theatre	31/05/2023
Comp. Dt. : 01/06/2023 Status : Completed								
1069	23060020	OG OT	MOTOR SUCTION NOT WORKING	Gurumoorthy. G.	checked and found that tube connection problem.the problem is rectified.		Preshma. S. - Operation Theatre	02/06/2023
Comp. Dt. : 05/06/2023 Status : Completed								
1070	23060163	New OT	SP O2 PROBE & SINGLE PARA METER NOT WORKING	Gurumoorthy. G.	spo2 probe connection problem.the problem is rectified.		Punitha. A. - Operation Theatre	06/06/2023
Comp. Dt. : 09/06/2023 Status : Completed								
1071	23060333	SPECIALITY OT	MULTIPARA MONITOR NOT WORKING IN RECOVERY ROOM	Gurumoorthy. G.	checked and found that display cable connection problem.the problem is rectified.		Sobiya. N. - Operation Theatre	15/06/2023
Comp. Dt. : 15/06/2023 Status : Completed								
1072	23060543	ORTHO OT	MUNMUN CABLE NOT WORKING	Gurumoorthy. G.	checked and found that cable internal damaged.need for purchase to new one		Parthiban. R. - Operation Theatre	19/06/2023
1073	23060565	SPECIALITY OT	1.G MONITOR ETCO2 CABLE NOT WORKING.2.SPO2 PROBENOT WORKING.3.BP CUFF ALSO NOT WORKING	Sridhar. K.	front claisic is need for purchcse to new one		Sobiya. N. - Operation Theatre	16/06/2023
Comp. Dt. : 19/06/2023 Status : Completed								
1074	23060677	ORTHO OT	NEED TO CHECK MANMAN MOTOR - NOT WORKING	Gurumoorthy. G.	checked and found that cable issue.the problem is rectified.		Parthiban. R. - Operation Theatre	21/06/2023

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 24/06/2023 Status : Completed								
1075	23060908	ORTHO OT	SUCTION NOT WORKING	Gokul. P. K.	genral serviced its now working		Shankari. G. - Operation Theatre	26/06/2023
Dept Name : Ophthalmology - Biomedical Comp. Dt. : 13/09/2022 Status : Completed								
1076	22090469	Ophthalmology - OPD	SPLIT LIGHT NOT WORKING	Sridhar. K.	checked and found that smps defective.replaced the smps.now working good.		Rajeswari.V. - Ophthalmology	12/10/2022
Dept Name : ORTHOPAEDICS - Biomedical Comp. Dt. : 15/06/2023 Status : Completed								
1077	23060552	Orthopaedics - OPD	BP APPARATUS NOT WORKING	Gokul. P. K.	badder and buib replaced		Manjula. P. - ORTHOPAEDICS	16/06/2023
Dept Name : P.H.C. - Tiruvonnainallur - Biomedical Comp. Dt. : 17/06/2022 Status : Completed								
1078	22060667	Thiruvonnainallur	CENTRIFUGE NOT WORKING	Sridhar. K.	replaced the carbon brush		Kanagasabai. D. - P.H.C. - Tiruvonnainallur	24/06/2022
Comp. Dt. : 18/07/2022 Status : Completed								
1079	22070638	Thiruvonnainallur	CENTRIFUGE NOT WORKING	Gurumoorthy. G.	replaced the carbon brush		Kanagasabai. D. - P.H.C. - Tiruvonnainallur	19/07/2022
Comp. Dt. : 21/09/2022 Status : Completed								
1080	22090849	Thiruvonnainallur	SUCTION APPARATUS NOT WORKING - T V NALLUR PHC	Vignesh. D.	checked and found that hose connection problem.rectified the hose connection		Kanagasabai. D. - P.H.C. - Tiruvonnainallur	24/09/2022
Comp. Dt. : 29/11/2022 Status : Completed								
1081	22111228	Thiruvonnainallur	BP APPARATUS NOT WORKING	Sridhar. K.	replace the dial		Kanagasabai. D. - P.H.C. - Tiruvonnainallur	29/11/2022
Comp. Dt. : 04/04/2023 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1082	23040137	Thiruvonnainallur	I F T MACHINE NOT WORKING	Sridhar. K.	wire connection problem.the problem is rectified.		Kanagasabai. D. - P.H.C. - Tiruvonnainallur	05/04/2023
Comp. Dt. : 15/04/2023 Status : Completed								
1083	23040458	Thiruvonnainallur	CENTRIFUGE NOT WORKING	Sridhar. K.	CARBON BRUSH REPLACED NOW WORKING		Kanagasabai. D. - P.H.C. - Tiruvonnainallur	18/04/2023
Comp. Dt. : 31/05/2023 Status : Completed								
1084	23051232	Thiruvonnainallur	PULSE OXI METER NOT WORKING	Gurumoorthy. G.	smps wire connection problem.replaced the probe		Kanagasabai. D. - P.H.C. - Tiruvonnainallur	31/05/2023
Comp. Dt. : 07/06/2023 Status : Completed								
1085	23060236	Thiruvonnainallur	B P APPARATUS [DIAL SIZE] 4NOS NOT WORKING	Gokul. P. K.	replaced the bladder and bulb with valve		Kanagasabai. D. - P.H.C. - Tiruvonnainallur	09/06/2023
Comp. Dt. : 21/06/2023 Status : Completed								
1086	23060792	P.H.C. - Tiruvonnainallur	B P APPARATUS NOT WORKING [4NOS]	Gokul. P. K.	replaced the bulb with valve and bladder.		Kanagasabai. D. - P.H.C. - Tiruvonnainallur	22/06/2023
Comp. Dt. : 23/06/2023 Status : Completed								
1087	23060894	P.H.C. - Tiruvonnainallur	DIATHERMY MACHINE NOT WORKING	Gurumoorthy. G.	checked and found that coil issue.connected the coil.		Kanagasabai. D. - P.H.C. - Tiruvonnainallur	11/07/2023
Dept Name : PAEDIATRICS - Biomedical Comp. Dt. : 24/02/2023 Status : Completed								
1088	23020922	Obstetrics - Ward 208	WEIGHT MACHINE NOT WORKING	Sridhar. K.	replaced the battery		KARIKALAN. A. - PAEDIATRICS	27/02/2023
Comp. Dt. : 24/04/2023 Status : Completed								
1089	23040775	Audiometry & Speech Therapy	BONE VIBRATOR NOT WORKING	Sridhar. K.	power connection problem.the problem is rectified.		Manju @ Brinda. V. - PAEDIATRICS	24/04/2023
Comp. Dt. : 02/05/2023 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1090	23050064	Audiometry & Speech Therapy	BONE VIBURATOR NOT WORKING - ENT OPD	Sridhar. K.	checked and found that bone vibrator is defective.need to purchase new one.		Manju @ Brinda. V. - PAEDIATRICS	03/05/2023
Comp. Dt. : 25/05/2023 Status : Completed								
1091	23050995	Paediatrics - OPD	WEIGHT MACHINE NOT WORKING	Sridhar. K.	checked and found that PCB issue.the problem is rectified.	AssetNo :16000675	Gayathri. D. - PAEDIATRICS	02/06/2023
Dept Name : Paediatrics Ward - Biomedical Comp. Dt. : 22/06/2022 Status : Completed								
1092	22060814	Paediatrics Ward	NEED TO REFIX LARYNGOSCOPY SCREW - WARD NO 309 & 310	Vignesh. D.	CHECKED AND FOUND THAT ISSUE. IT' NOT RECTIFIED NEED TO BE CONDEM		Chitra. P. - Paediatrics Ward	22/06/2022
Comp. Dt. : 08/07/2022 Status : Completed								
1093	22070300	Paediatrics - Ward 309	SPO2 MONITOR NOT WORKING	Sridhar. K.	smps power supply cable services its now working	AssetNo :16000784	Chitra. P. - Paediatrics Ward	09/07/2022
Comp. Dt. : 20/07/2022 Status : Completed								
1094	22070731	Paediatrics - Ward 309	BP APPARATUS NOT WORKING	Vignesh. D.	checked and serviced the dial now it's working good		Rajeswari. P. - Paediatrics Ward	20/07/2022
Comp. Dt. : 27/09/2022 Status : Completed								
1095	22091089	Paediatrics - Ward 309	NEBULIZER NOT WORKING	Sridhar. K.	genral services working		Chitra. P. - Paediatrics Ward	03/10/2022
Comp. Dt. : 26/10/2022 Status : Completed								
1096	22100804	Paediatrics - Ward 308	MONITOR WITH PAEDIATRIC PROBE AND ADULT PROBE NOT WORKING	Sridhar. K.	spo2 cable connector broken.replaced the spo2 cable connector		Chitra. P. - Paediatrics Ward	02/01/2023
Comp. Dt. : 10/11/2022 Status : Completed								
1097	22110438	DIALYSIS NEW UNIT IN 1ST FLOOR	MULTIPARA MONITOR SPO2 PROBE NOT WORKING	Sridhar. K.	spo2 replaced	AssetNo :1600053	Parameswari. S. - Paediatrics Ward	10/11/2022
Comp. Dt. : 16/11/2022								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
1098	22110694	Paediatrics - Ward 309	3 NO'S BP APPARATUS NOT WORKING	Sridhar. K.	replaced the bladder		Chitra. P. - Paediatrics Ward	19/11/2022
Comp. Dt. : 27/01/2023								
Status : Completed								
1099	23010945	Paediatrics - Ward 308	AMBU BAG WITH RESERVOIR DAMAGE - NEED TO CHANGE URGENT	Gurumoorthy. G.	checked and found that connection problem.the problem is rectified		Naveena. N. - Paediatrics Ward	28/01/2023
Comp. Dt. : 01/03/2023								
Status : Completed								
1100	23030045	Paediatrics Ward	BP CUFF [3NOS] NOT WORKING	Sridhar. K.	replaced the cuff		Chitra. P. - Paediatrics Ward	01/03/2023
Comp. Dt. : 11/03/2023								
Status : Completed								
1101	23030440	Female Medical - Ward 307	NEED TO CHECK WEIGHT MACHINE [PEADATRIC 307]	Vignesh. D.	replaced the battery		Chitra. P. - Paediatrics Ward	13/03/2023
Comp. Dt. : 22/05/2023								
Status : Completed								
1102	23050859	Female Medical - Ward 307	SUCTION APPARATUS NOT WORKING [PAEDIATRICS 307]	Vignesh. D.	tubing connection problem.the problem is rectified.		Kayalvizhi. G. - Paediatrics Ward	23/05/2023
Comp. Dt. : 30/05/2023								
Status : Completed								
1103	23051181	DIALYSIS NEW UNIT IN 1ST FLOOR	B P APPARATUS [DIAMIND] NOT WORKING	Gurumoorthy. G.	replaced the bulb with valve		Parameswari. S. - Paediatrics Ward	30/05/2023
Comp. Dt. : 03/06/2023								
Status : Completed								
1104	23060110	Paediatrics - Ward 308	SPO2 PROBE NOT WORKING	Sridhar. K.	spo2 probe replaced	AssetNo :16000784	Chitra. P. - Paediatrics Ward	03/06/2023
Dept Name : PATHOLOGY - Biomedical								
Comp. Dt. : 10/06/2023								
Status : Completed								
1105	23060373	DIALYSIS NEW UNIT IN 1ST FLOOR	N 1 MACHINE NOT WORKING	Sridhar. K.	checked and found that pressure regulator issue.adjusted the pressure value.the problem is rectified	AssetNo :16001036	Vimal. M. - PATHOLOGY	15/06/2023
Dept Name : Physiotherapy - Biomedical								
Comp. Dt. : 04/05/2022								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
1106	22050086	Physiotherapy	PROBLEM IN I F T MACHINE	Gurumoorthy. G.	checked and found problem in in intensity potentiometer loose contact so remove and service it probl		Ezhilan.K. - Physiotherapy	05/05/2022
Comp. Dt. : 09/08/2022								
Status : Completed								
1107	22080301	Physiotherapy	I F T MACHINE NOT WORKING	Sridhar. K.	SERVICES NOW ITS WORKING		Ezhilan.K. - Physiotherapy	09/08/2022
Comp. Dt. : 23/08/2022								
Status : Completed								
1108	22080760	PHYSIOTHERAPY ROOM IN 4TH FLOOR	PROBLEM IN I F T MACHINE	Gurumoorthy. G.	checked and found that earth plate connection problem.the problem is rectified.		Ezhilan.K. - Physiotherapy	23/08/2022
Comp. Dt. : 28/09/2022								
Status : Completed								
1109	22091130	Physiotherapy	TRACTION NOT WORKING	Gurumoorthy. G.	checked and found the internal board issue it's rectified now working good		Ezhilan.K. - Physiotherapy	05/10/2022
Comp. Dt. : 27/10/2022								
Status : Completed								
1110	22100853	Physiotherapy	TRACTION MACHINE NOT WORKING	Gurumoorthy. G.	checekd and found that cable connection problem.the problem is rectified		Ezhilan.K. - Physiotherapy	28/10/2022
Comp. Dt. : 15/11/2022								
Status : Completed								
1111	22110571	Physiotherapy	IFT MACHINE NOT WORKING	Vignesh. D.	checked and found that earth plate cable connection problem.the problem is rectified		Ezhilan.K. - Physiotherapy	19/11/2022
Comp. Dt. : 10/01/2023								
Status : Completed								
1112	23010380	Physiotherapy	STIMULATION MAHCINE PROBLEM	Gurumoorthy. G.	checked and found that earth plate connection problem.the problem is rectified.		Elakkiya. R. - Physiotherapy	10/01/2023
Comp. Dt. : 11/01/2023								
Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1113	23010494	Physiotherapy	IFT MACHINE PROBLEM	Gurumoorthy. G.	wire connection issue it's rectified now working good		Ezhilan.K. - Physiotherapy	11/01/2023
Comp. Dt. : 04/02/2023 Status : Completed								
1114	23020138	Physiotherapy	PROBLEM IN I F T INSTRUMENT	Gurumoorthy. G.	checked and found that power connection problem.the problem is rectified		Shyamala.P. - Physiotherapy	06/02/2023
Comp. Dt. : 24/03/2023 Status : Completed								
1115	23030998	PHYSIOTHERAPY ROOM IN 4TH FLOOR	LASER THERAPY SCANNER NOT WORKING	Gurumoorthy. G.	checked and found that fuse problem.the problem is rectified.		Ezhilan.K. - Physiotherapy	25/03/2023
Comp. Dt. : 26/05/2023 Status : Completed								
1116	23051035	Physiotherapy	I F T MACHINE NOT WORKING	Sridhar. K.	earthconnection problem.the problem is rectified.	AssetNo :16000403	Ezhilan.K. - Physiotherapy	31/05/2023
Comp. Dt. : 07/06/2023 Status : Completed								
1117	23060212	Physiotherapy	NEED TO CHECK INSTRUMENT - SHOCK PROBLEM - NEED URGENT SERVICE	Gurumoorthy. G.	Earth plate connection problem.the problem is rectified.		Shyamala.P. - Physiotherapy	09/06/2023
Dept Name : PICU & NICU - Biomedical Comp. Dt. : 12/05/2022 Status : Completed								
1118	22050429	NICU	WEIGHT MACHINE NOT WORKING	Vignesh. D.	checked and found that weight deviation problem,problem rectified now working good.		Parameswari. P. - PICU & NICU	18/05/2022
Comp. Dt. : 02/06/2022 Status : Completed								
1119	22060062	NICU	THEROMETER & SKIN PROBE NOT WORKING	Vignesh. D.	in thermometer replaced battery,skin probe replaced new one now working good.		Parameswari. P. - PICU & NICU	02/06/2022
Comp. Dt. : 03/06/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1120	22060148	NICU	WARMER NOT WORKING	Vignesh. D.	checked and refixed the cable now unit working good	AssetNo :16000350	Parameswari. P. - PICU & NICU	04/06/2022
	Comp. Dt. : 09/06/2022							
	Status : Completed							
1121	22060338	NICU	MULTIPARA MONITOR NOT WORKING	Vignesh. D.	checked and found the cable issue. it's replaced now it's working good	AssetNo :16000043	Sarumathi. A. - PICU & NICU	09/06/2022
	Comp. Dt. : 27/06/2022							
	Status : Completed							
1122	22060948	PICU	NEED TO CHECK MULTIPARA MONITOR - NOT WORKING	Vignesh. D.	checked and found problem in smps it's replaced now working good	AssetNo :16000074	Poovathal. K. - PICU & NICU	07/12/2022
	Comp. Dt. : 28/06/2022							
	Status : Completed							
1123	22061006	NICU	THERMOMETER NOT WORKING	Vignesh. D.	BATTERY CHANGED NOW IT'S WORKING GOOD		Gobiya. G. - PICU & NICU	28/06/2022
	Comp. Dt. : 30/06/2022							
	Status : Completed							
1124	22061123	PICU	NEED TO CHECK DIGITAL WEIGHT MACHINE - NOT WORKING	Vignesh. D.	wire loose connection issue it rectified now it's working good		Poovathal. K. - PICU & NICU	30/06/2022
	Comp. Dt. : 02/07/2022							
	Status : Completed							
1125	22070055	NICU	DEFIBRILLATOR PRINTER NOT WORKING	Vignesh. D.	checked and found the printer roller issue it' refixed now it's working good.	AssetNo :16000711	Gobiya. G. - PICU & NICU	02/07/2022
	Comp. Dt. : 04/07/2022							
	Status : Completed							
1126	22070109	PICU	ADULT WEIGHT MACHINE NOT WORKING	Vignesh. D.	general service done now working good		Poovathal. K. - PICU & NICU	04/07/2022
	Comp. Dt. : 05/07/2022							
	Status : Completed							
1127	22070169	NICU	MULTIPARA MONITOR NOT WORKING	Vignesh. D.	checked and found the spo2 probe issue. it's replaced now it's working good.	AssetNo :16000065	Arya. K. - PICU & NICU	06/07/2022
	Comp. Dt. : 22/08/2022							
	Status : Completed							


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1128	22080720	PICU	WEIGHT MACHINE NOT WORKING	Vignesh. D.	GENERAL SERVICE DONE NOW IT'S WORKING GOOD		Poovathal. K. - PICU & NICU	24/08/2022
Comp. Dt. : 02/09/2022 Status : Completed								
1129	22090066	PICU	WEIGHT MACHINE NOT WORKING	Vignesh. D.	checked and found the ac to dc adapter problem IT'S REPLACED NOW WORKING GOOD	AssetNo :16000673	Thirushayeni. A. - PICU & NICU	05/09/2022
Comp. Dt. : 10/09/2022 Status : Completed								
1130	22090391	PICU	MULTIPARA MONITOR PROBE NOT WORKING	Vignesh. D.	CHECKED AND FOUND THE SPO2 PROBE ISSUE IT'S REPLACED NOW WORKING GOOD		Umamaheswari. P. - PICU & NICU	10/09/2022
Comp. Dt. : 21/09/2022 Status : Completed								
1131	22090843	PICU	MULTIPARA MONITOR NOT WORKING	Vignesh. D.	REPLACED THE NEW SPO2 PROBE NOW WORKING GOOD.	AssetNo :16000073	Poovathal. K. - PICU & NICU	21/09/2022
Comp. Dt. : 31/10/2022 Status : Completed								
1132	22100987	PICU	WEIGHING MACHINE ERROR PROBLEM	Vignesh. D.	cable issue it's rectified now working good		Poovathal. K. - PICU & NICU	02/11/2022
Comp. Dt. : 14/11/2022 Status : Completed								
1133	22110515	NEW NICU & PICU-2ND FLOOR	IN PICU-VENTILATOR BACKUP PROBLEM	Vignesh. D.	checked and found the setting issue it's rectified now working good		Thirushayeni. A. - PICU & NICU	19/11/2022
Comp. Dt. : 26/11/2022 Status : Completed								
1134	22111146	NEW NICU & PICU-2ND FLOOR	PICU-WEIGHT MACHINE NOT WORKING	Vignesh. D.	wire loose connection and reset the machine now working good		Poovathal. K. - PICU & NICU	29/11/2022
1135	22111147	PICU	SPO2 PROBE NOT WORKING	Vignesh. D.	probe connection issue it's replaced now working good		Poovathal. K. - PICU & NICU	01/12/2022
1136	22111148	PICU	NEBULIZER NOT WORKING	Vignesh. D.	checked and found that wire connection problem.the problem is rectified.		Poovathal. K. - PICU & NICU	26/11/2022
Comp. Dt. : 01/12/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1137	22120011	NICU	NEED TO CHANGE WARMER LIGHT - NOT WORKING	Vignesh. D.	checked and found the bulb wire loose connection issue it;s rectified now working good		Parameswari. P. - PICU & NICU	07/12/2022
Comp. Dt. : 10/12/2022 Status : Completed								
1138	22120468	NICU	WARMER NOT WORKING	Gurumoorthy. G.	wire connection problem is rectified.		Parameswari. P. - PICU & NICU	15/12/2022
Comp. Dt. : 19/12/2022 Status : Completed								
1139	22120849	NICU	WARMER NOT WORKING - 2NOS	Vignesh. D.	CHECKED AND FOUND THE WIRE LOOSE CONNECTION ON MAIN BOARD. IT'S SERVICED NOW WORKING GOOD		Parameswari. P. - PICU & NICU	21/12/2022
Comp. Dt. : 22/12/2022 Status : Completed								
1140	22121013	NICU	LARYNGOSCOPE NOT WORKING	Vignesh. D.	replaced the bulb		Parameswari. P. - PICU & NICU	24/12/2022
Comp. Dt. : 28/12/2022 Status : Completed								
1141	22121301	NICU	VENTILATOR NOT WORKING	Vignesh. D.	checked and found that mode settings issue.the problem is rectified		Parameswari. P. - PICU & NICU	02/01/2023
Comp. Dt. : 31/12/2022 Status : Completed								
1142	22121398	NICU	MULTIPARA MONITOR SPO2 PROBE NOT WORKING	Vignesh. D.	checked and found that spo2 probbe loose connection problem		Poovathal. K. - PICU & NICU	02/01/2023
Comp. Dt. : 05/01/2023 Status : Completed								
1143	23010245	NEW NICU & PICU-2ND FLOOR	IN PICU-NEUMOTIC BP APPARATUS NOT WORKING	Vignesh. D.	bulb replaced now working good		Poovathal. K. - PICU & NICU	05/01/2023
Comp. Dt. : 09/01/2023 Status : Completed								
1144	23010345	NEW NICU & PICU-2ND FLOOR	IN PICU-MULTIPARA MONITOR NIBP CUFF NOT WORKING	Vignesh. D.	NIBP CUFF CHANGED NOW WORKING GOOD		Poovathal. K. - PICU & NICU	09/01/2023
1145	23010356	NEW NICU & PICU-2ND FLOOR	IN PICU-MULTIPARA MONITOR SCREEN NOT WORKING	Vignesh. D.	CONNECTION ISSUE IT'S RECTIFIED NOW WORKING GOOD		Poovathal. K. - PICU & NICU	09/01/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 11/01/2023 Status : Completed								
1146	23010487	NEW NICU & PICU-2ND FLOOR	IN PICU-2 NO'S MULTIPARA MONITOR NOT WORKING	Vignesh. D.	spo2 probe replaced now working good		Poovathal. K. - PICU & NICU	11/01/2023
Comp. Dt. : 19/01/2023 Status : Completed								
1147	23010656	NICU	WARMER NOT WORKING	Gurumoorthy. G.	checked and found that wire connection problem.the problem is rectified		Sarumathi. A. - PICU & NICU	20/01/2023
Comp. Dt. : 20/01/2023 Status : Completed								
1148	23010724	PICU	MULTIPARA MONITOR NIBB [2NOS] NOT WORKING	Vignesh. D.	checked and found that nibp connector issue.rectified the complaint.		Poovathal. K. - PICU & NICU	21/01/2023
Comp. Dt. : 25/02/2023 Status : Completed								
1149	23020975	PICU	HUMIDIFIER PROBLEM	Vignesh. D.	checked and found that power card loose connection issue.the problem is rectified.		Thirushayeni. A. - PICU & NICU	27/02/2023
Comp. Dt. : 01/03/2023 Status : Completed								
1150	23030001	PICU	MONITOR PROBE NOT WORKING	Sridhar. K.	replaced spo2 probe now working	AssetNo :16000070	Poovathal. K. - PICU & NICU	01/03/2023
Comp. Dt. : 02/03/2023 Status : Completed								
1151	23030103	PICU	MULTIPARA MONITOR SPO2 NOT WORKING	Vignesh. D.	spo2 module replaced now working good		Poovathal. K. - PICU & NICU	04/03/2023
Comp. Dt. : 06/03/2023 Status : Completed								
1152	23030240	PICU	WEIGHT MACHINE NOT WORKING	Sridhar. K.	replaced the battery		Poovathal. K. - PICU & NICU	08/03/2023
Comp. Dt. : 12/04/2023 Status : Completed								
1153	23040362	NICU	WARMER NOT WORKING	Vignesh. D.	CHECKED THE TEMPERATURE PROBE ISSUE IT'S REPLACED NOW WORKING GOOD		Hemalatha. A. - PICU & NICU	18/04/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 17/04/2023 Status : Completed								
1154	23040535	DENTAL OPD -2ND FLOOR	NEED TO CHECK COMPRESSOR - BURNED SMELL NEED URGENT SERVICE	Sridhar. K.	WIRE CONNECTION ISSUE IT'S WORKING		Ushamala. I. - PICU & NICU	18/04/2023
Comp. Dt. : 29/04/2023 Status : Completed								
1155	23040986	NICU	VENTILATOR NOT WORKING	Vignesh. D.	checked and found need to cassette cleaning.the problem is rectified.		Sameetha. S. - PICU & NICU	02/05/2023
Comp. Dt. : 24/05/2023 Status : Completed								
1156	23050972	NICU	VENTILATOR NOT WORKING	Sridhar. K.	checked and found that circuit loose connection problem.the problem is rectified.		Parameswari. P. - PICU & NICU	25/05/2023
Comp. Dt. : 05/06/2023 Status : Completed								
1157	23060143	NICU	GLUCO METER NOT WORKING	Gurumoorthy. G.	Replaced the battery		Parameswari. P. - PICU & NICU	06/06/2023
Comp. Dt. : 08/06/2023 Status : Completed								
1158	23060281	PICU	PROBLEM IN DEFIBRILLATOR PRINT	Gurumoorthy. G.	checked and found that printer paper connection problem.the problem is recitified.		Krishnaveni. S. - PICU & NICU	14/06/2023
Comp. Dt. : 16/06/2023 Status : Completed								
1159	23060572	DENTAL OPD -2ND FLOOR	COMPRESSOR AIR LEAKAGE PROBLEM	Sridhar. K.	AIR COMPRESSOR SERVICED NOW WORKING		Ushamala. I. - PICU & NICU	16/06/2023
Dept Name : POW & SICU - Biomedical Comp. Dt. : 10/05/2022 Status : Completed								
1160	22050362	SICU	STETHOSCOPE NOT WORKING	Gurumoorthy. G.	replaced the chest piece.		Praveena. E. - POW & SICU	11/05/2022
Comp. Dt. : 17/05/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1161	22050586	SICU	ECG MACHINE & SUCTION APPARATUS NOT WORKING	Vignesh. D.	checked and found that cable loose connection problem,problem rectified now working good.		Jamuna. K - POW & SICU	18/05/2022
Comp. Dt. : 30/05/2022 Status : Completed								
1162	22051095	POW & SICU	PULSEOXIMETER NOT WORKING.	Vignesh. D.	checked and found that internal spo2 cable loose connection problem,cable refixed now working good.	AssetNo :16000563	Jamuna. K - POW & SICU	01/06/2022
Comp. Dt. : 04/06/2022 Status : Completed								
1163	22060172	POW & SICU	INFUSION PUMP [2NOS] NOT WORKING	Vignesh. D.	checked and found problem in power cord loose contact so it remove and refix it problem rectified.	AssetNo :16000388	Jamuna. K - POW & SICU	04/06/2022
Comp. Dt. : 23/06/2022 Status : Completed								
1164	22060852	SICU	ECG MACHINE NOT WORKING .	Vignesh. D.	ecg laed reinsert now its working		Jamuna. K - POW & SICU	25/06/2022
Comp. Dt. : 01/07/2022 Status : Completed								
1165	22070029	POW & SICU	MOVABLE PULSE OXIMETER NOT WORKING	Vignesh. D.	checked and found the display issue.display cable replaced.	AssetNo :16000580	Jamuna. K - POW & SICU	02/01/2023
Comp. Dt. : 06/07/2022 Status : Completed								
1166	22070222	POW & SICU	X RAY MACHINE NOT WORKING	Vignesh. D.	checked and found the board side fuse problem it's replaced now it's working good	AssetNo :16000698	Jamuna. K - POW & SICU	07/07/2022
Comp. Dt. : 07/07/2022 Status : Completed								
1167	22070241	POW & SICU	MULTIPARA MONITOR NOT WORKING	Vignesh. D.	checked and found the cable loose connection issue it's refixed no0w working gopod	AssetNo :16000045	Arulmozhi. D. - POW & SICU	07/07/2022
Comp. Dt. : 11/07/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1168	22070436	POW & SICU	ECG MACHINE NOT WORKING	Vignesh. D.	checked and found the cable issue now it's working good		Jamuna. K - POW & SICU	11/07/2022
	Comp. Dt. : 15/07/2022							
	Status : Completed							
1169	22070604	POW & SICU	INFUSION PUMP NOT WORKING	Vignesh. D.	checked and found the cable loose connection issue it's rectified now it's working good		Kausalya. V. - POW & SICU	16/07/2022
	Comp. Dt. : 19/07/2022							
	Status : Completed							
1170	22070689	POW & SICU	NEED TO CHANGE X RAY INSIDE SMALL LIGHT	Vignesh. D.	checked and changed the bulb now it's working good	AssetNo :16000699	Valarmathy. K. - POW & SICU	20/07/2022
	Comp. Dt. : 26/07/2022							
	Status : Completed							
1171	22070957	SICU	BP APPARATUS NOT WORKING	Gurumoorthy. G.	checked and changed the bladder now it's working good		Aruldevi. S. - POW & SICU	26/07/2022
	Comp. Dt. : 17/08/2022							
	Status : Completed							
1172	22080531	POW & SICU	X-RAY MACHINE LIGHT NOT WORKING	Gurumoorthy. G.	checked and found the collimator adjustment issue it's removed and refixed now it's working good.fus	AssetNo :16000699	Jamuna. K - POW & SICU	19/08/2022
	Comp. Dt. : 14/09/2022							
	Status : Completed							
1173	22090518	POW & SICU	X RAY MACHINE NOT WORKING	Vignesh. D.	checked and found the board issue,the problem is rectified.		Jamuna. K - POW & SICU	02/01/2023
	Comp. Dt. : 29/09/2022							
	Status : Completed							
1174	22091165	POW & SICU	MULTIPARA MONITOR NOT WORKING	Vignesh. D.	checked and found the smps issue it's replaced from old now working unit now it's working good	AssetNo :16000045	Valarmathy. K. - POW & SICU	30/09/2022
	Comp. Dt. : 10/10/2022							
	Status : Completed							
1175	22100222	POW & SICU	MULTIPARA MONITOR PROBE NOT WORKING	Vignesh. D.	probe loose connection issue it's rectified now working good		Jamuna. K - POW & SICU	12/10/2022

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHAL KUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 29/10/2022 Status : Completed								
1176	22100950	POW & SICU	MULTIPARA MONITOR NOT WORKING	Vignesh. D.	checked and found the front panel issue it's changed now working good		Jamuna. K - POW & SICU	02/11/2022
Comp. Dt. : 08/11/2022 Status : Completed								
1177	22110288	POW & SICU	2 NO' MUTIPARA MONITOR NOT WORKING	Vignesh. D.	SMPS & DISPLAY ISSUE REPLACED FROM THE OLD NOT WORKING UNIT NOW WORKING GOOD		Pragadeesh. V. - POW & SICU	09/11/2022
Comp. Dt. : 10/11/2022 Status : Completed								
1178	22110380	SICU	VENTILATOR NOT WORKING	Vignesh. D.	flow senson issue replaced now working good		Jamuna. K - POW & SICU	27/12/2022
Comp. Dt. : 12/12/2022 Status : Completed								
1179	22120560	POW & SICU	DIFIBRILLATOR NOT WORKING	Gurumoorthy. G.	checked and found that ECG cable connection problem.the problem is rectified		Jamuna. K - POW & SICU	15/12/2022
Comp. Dt. : 13/12/2022 Status : Completed								
1180	22120578	SICU	MULTIPARA MONITOR NOT WORKING	Sridhar. K.	SPO2 REPLACED WORKING	AssetNo :16000906	Jamuna. K - POW & SICU	13/12/2022
1181	22120618	POW & SICU	ECG MACHINE NOT WORKING	Sridhar. K.	re complaint		Gunavathi. G. - POW & SICU	15/12/2022
Comp. Dt. : 14/12/2022 Status : Completed								
1182	22120622	POW & SICU	ECG MACHINE NOT WORKING	Sridhar. K.	SERVICED DONE NOW WORKING GOOD		Jamuna. K - POW & SICU	03/01/2023
Comp. Dt. : 15/12/2022 Status : Completed								
1183	22120710	POW & SICU	MULTIPARA MONITOR NOT WORKING	Sridhar. K.	checked and found that spo2 probe connection problem.the problem is rectified.		Jamuna. K - POW & SICU	17/12/2022
Comp. Dt. : 17/12/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1184	22120827	POW & SICU	2 NO'S MULTIPARA MONITOR NOT WORKING	Gurumoorthy. G.	CHECKED AND FOUND THE PROBE ISSUE IT'S REPLACED NOW WORKING GOOD		Jamuna. K - POW & SICU	21/12/2022
Comp. Dt. : 22/12/2022 Status : Completed								
1185	22120995	POW & SICU	NEED TO FIX ECG MACHINE WHEEL	Vignesh. D.	checked and found that ecg cable screws connection problem.the problem is rectified		Valarmathy. K. - POW & SICU	24/12/2022
1186	22121000	POW & SICU	X-RAY MACHINE NOT WORKING	Vignesh. D.	repeat complaint		Valarmathy. K. - POW & SICU	27/12/2022
Comp. Dt. : 27/01/2023 Status : Completed								
1187	23010964	POW & SICU	MULTIPARA MONITOR BP CUFF NOT WORKING	Sridhar. K.	checked and found that nibp cuff problem.replaced the new nibp cuff	AssetNo :16000060	Jamuna. K - POW & SICU	28/01/2023
Comp. Dt. : 28/01/2023 Status : Completed								
1188	23011006	POW & SICU	NEED TO CHANGE ECG MACHINE CABLE	Sridhar. K.	checked and found that ecg cable issue.replaced the new cable	AssetNo :16000864	Jamuna. K - POW & SICU	28/01/2023
Comp. Dt. : 31/01/2023 Status : Completed								
1189	23011122	POW & SICU	MULTIPARA MONITOR 2 NOS NOT WORKING	Gurumoorthy. G.	checked and found that cable connection problem.the problem is rectified.		Jamuna. K - POW & SICU	31/01/2023
Comp. Dt. : 23/02/2023 Status : Completed								
1190	23020895	POW & SICU	MULTIPARA MONITOR NOT WORKING	Sridhar. K.	checked and found that nibp issue.the problem is rectified.		Jamuna. K - POW & SICU	27/02/2023
Comp. Dt. : 01/03/2023 Status : Completed								
1191	23030029	POW & SICU	VENTILATOR NOT WORKING	Gurumoorthy. G.	checked and found that expiratory cassette issue.the cassette is cleaned.		Jamuna. K - POW & SICU	01/03/2023
Comp. Dt. : 02/03/2023 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1192	23030082	CT-ICU ROOM-NEAR ORTHO OT RECOVERY ROOM	X RAY MACHINE NOT WORKING	Gurumoorthy. G.	checked and found the power cable issue it's replaced now working good		Jamuna. K - POW & SICU	04/03/2023
		Comp. Dt. : 03/03/2023 Status : Completed						
1193	23030131	SICU	INFUSION PUMP NOT WORKING	Vignesh. D.	general service done working good		Praveena. E. - POW & SICU	04/03/2023
		Comp. Dt. : 21/03/2023 Status : Completed						
1194	23030854	POW & SICU	VENTILATOR NOT WORKING	Vignesh. D.	pre-check done working good	AssetNo :16000658	Gunavathi. G. - POW & SICU	21/03/2023
		Comp. Dt. : 27/03/2023 Status : Completed						
1195	23031129	SICU	MULTIPARA MONITOR [2 NOS] NOT WORKING	Vignesh. D.	checked the probe issue it's rectified now working good		Arunkumar. D. - POW & SICU	03/04/2023
		Comp. Dt. : 30/03/2023 Status : Completed						
1196	23031291	POW & SICU	MULTIPARA MONITOR [2NOS] NOT WORKING	Vignesh. D.	spos probe changed now working good		Pragadeesh. V. - POW & SICU	03/04/2023
		Comp. Dt. : 09/06/2023 Status : Completed						
1197	23060319	POW & SICU	VENTILATOR CASSETTE NOT WORKING	Gurumoorthy. G.	cleaned the cassette		Arunkumar. D. - POW & SICU	12/06/2023
1198	23060334	POW & SICU	B P CUFF NOT WORKING	Gurumoorthy. G.	replaced the cuff		Valarmathy. K. - POW & SICU	12/06/2023
		Dept Name : Power Laundry - Biomedical Comp. Dt. : 01/03/2023 Status : Completed						
1199	23030012	Power Laundry	WEIGHT MACHING NOT WORKING	Gurumoorthy. G.	checked and found that internal switch connection problem.the problem is rectified.		Manikandan.M - Power Laundry	01/03/2023
		Dept Name : Radio Diagnosis - Biomedical Comp. Dt. : 21/05/2022 Status : Completed						
1200	22050804	XRay	OLD C R SYSTEM NOT WORKING	Gurumoorthy. G.	checked and found that software problem so reinstall the software along with the company person prob		Manikandan.V. - Radio Diagnosis	24/05/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 30/05/2022 Status : Completed								
1201	22051094	MRI	HEAD COIL BROKEN	Gurumoorthy. G.	checked and found that head coil headrust damaged.it's reploaced now it's working good	AssetNo :16000460	Adilakshmi. T. - Radio Diagnosis	02/07/2022
Comp. Dt. : 27/07/2022 Status : Completed								
1202	22070999	XRay	NEED TO CHANGE PORTABLE X RAY MACHINE LIGHT FOR I C U - NOT WORKING	Gurumoorthy. G.	checked and found that x-ray light transformer wiring connection problem.the problem is rectified	AssetNo :16000697	Arunmuthu. M. - Radio Diagnosis	09/09/2022
Comp. Dt. : 06/09/2022 Status : Completed								
1203	22090245	SCAN - GROUND FLOOR - BLOOD BANK OPP	ULTRASOUND PHILIPS X 7 E PROBE NOT WORKING	Vignesh. D.	checked and found that trb board dust problem.dust cleaned in trb board.now working good.	AssetNo :16000716	Abirami. P. - Radio Diagnosis	09/09/2022
Comp. Dt. : 10/10/2022 Status : Completed								
1204	22100231	CT Scan	PROBLEM IN POWER INJECTOR	Gurumoorthy. G.	checked and found that pressure injector motor.the problem is rectified.		Adilakshmi. T. - Radio Diagnosis	02/01/2023
Comp. Dt. : 06/12/2022 Status : Completed								
1205	22120273	XRay	800MA X-RAY MACHINE NOT WORKING	Gurumoorthy. G.	checked and found that cable connection problem.the problem is rectified.		Manikandan.V. - Radio Diagnosis	24/12/2022
Comp. Dt. : 01/02/2023 Status : Completed								
1206	23020006	RADIOLOGY	OLD C R WORK STATION NOT WORKING	Gurumoorthy. G.	checked and found that OS issue.booted the OS.now working good.		Guru. A. - Radio Diagnosis	01/02/2023
Comp. Dt. : 13/02/2023 Status : Completed								
1207	23020496	XRay	X RAY PRINTER 3 NOS NOT WORKING	Gurumoorthy. G.	checked and found that rollback and drum issue.the problem is rectified.		Manikandan.V. - Radio Diagnosis	17/02/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 20/02/2023 Status : Completed								
1208	23020747	XRay	NEED TO CHANGE X RAY COLI MACHINE TUBE - CUT	Gurumoorthy. G.	checked and found that collimator adjusment problem.adjusted the collimator.now its working good.		Guru. A. - Radio Diagnosis	20/02/2023
Comp. Dt. : 24/04/2023 Status : Completed								
1209	23040736	XRay	800 ALLENGERS MACHINE NOT WORKING	Gurumoorthy. G.	checked and found that exposure switch problem.the problem is rectified.		Manikandan.V. - Radio Diagnosis	02/05/2023
Dept Name : RICU - Biomedical Comp. Dt. : 05/07/2022 Status : Completed								
1210	22070140	RICU	MULTIPARA MONITOR NOT WORKING	Vignesh. D.	checked and found the spo2 prob & nibp cuff issue it's replaced now it's working good	AssetNo :16000099	Tamililakkiya. K. - RICU	06/07/2022
Comp. Dt. : 23/07/2022 Status : Completed								
1211	22070878	RICU	ECG MACHINE NOT WORKING	Vignesh. D.	checked and found that ecg module replaced	AssetNo :16000295	Silambarasan. S. - RICU	02/01/2023
Comp. Dt. : 25/07/2022 Status : Completed								
1212	22070904	RICU	BP APPARATUS NOT WORKING	Vignesh. D.	CHECKED AND CHANGED THE BULB NOW IT'S WORKING GOOD		Tamililakkiya. K. - RICU	25/07/2022
Comp. Dt. : 17/08/2022 Status : Completed								
1213	22080510	RICU	SPO2 PROBE NOT WORKING	Vignesh. D.	checked and found that spo2 probe is defective.replaced the new spo2 probe.	AssetNo :16000079	Silambarasan. S. - RICU	18/08/2022
Comp. Dt. : 24/11/2022 Status : Completed								
1214	22111051	RICU	MULTIPARA MONITOR PROBE NOT WOKRING	Vignesh. D.	spo2 probe replaced now working good	AssetNo :16000079	Silambarasan. S. - RICU	29/11/2022
Comp. Dt. : 02/12/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1215	22120081	RICU	BI PAP MACHINE NOT WORKING	Vignesh. D.	CHECKED AND FOUND THE BOARD ISSUE .IT'S SERVICED NOW WORKING GOOD		Silambarasan. S. - RICU	21/12/2022
Comp. Dt. : 16/12/2022 Status : Completed								
1216	22120793	RICU	MULTIPARA MONITOR NOT WORKING	Gurumoorthy. G.	CHECKED AND FOUND THE PROBE ISSUE IT'S WORKING GOOD		Silambarasan. S. - RICU	21/12/2022
Comp. Dt. : 15/03/2023 Status : Completed								
1217	23030610	RICU	MONITOR PROBE NOT WORKING	Vignesh. D.	SPO2 PROBE ISSUE IT'S REPLACED NOW WORKING GOOD		Silambarasan. S. - RICU	15/03/2023
Comp. Dt. : 30/03/2023 Status : Completed								
1218	23031278	RICU	MONITOR SPO2 PROBE NOT WORKING	Vignesh. D.	spo2 probe changed now working		Silambarasan. S. - RICU	03/04/2023
Comp. Dt. : 01/04/2023 Status : Completed								
1219	23040017	RICU	MONITOR PROBE NOT WORKING	Vignesh. D.	spo2 probe connection problem.the problem is rectified.		Anitha. A. - RICU	04/04/2023
Comp. Dt. : 08/05/2023 Status : Completed								
1220	23050280	RICU	WALL MOUNTING SUCTION NOT WORKING	Vignesh. D.	GAS PLANT COMPLAINT		Tamililakkiya. K. - RICU	11/05/2023
Comp. Dt. : 16/05/2023 Status : Completed								
1221	23050630	RICU	DEFIBRILLATOR & MULTIPARA MONITOR NOT WORKING	Vignesh. D.	checked and found that paddle connection problem.the problem is rectified.		Tamililakkiya. K. - RICU	17/05/2023
Comp. Dt. : 19/05/2023 Status : Completed								
1222	23050782	RICU	B.P. APPARATUS NOT WORKING	Gurumoorthy. G.	replaced the bulb with valve		Tamililakkiya. K. - RICU	19/05/2023
Comp. Dt. : 24/05/2023 Status : Completed								
1223	23050943	RICU	SPO2 PROBE [2 NOS] NOT WORKING	Sridhar. K.	replaced the new spo2 probe		Silambarasan. S. - RICU	25/05/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 26/05/2023 Status : Completed								
1224	23051034	RICU	MULTIPARA SPO2 MONITOR PROBE [2 NOS] NOT WORKING	Sridhar. K.	spo2 probe replaced	AssetNo :16001151	Tamililakkiya. K. - RICU	26/05/2023
Comp. Dt. : 27/06/2023 Status : Completed								
1225	23060996	POW & SICU	MULTIPARA MONITOR NOT WORKING [3NOS]	Gurumoorthy. G.	checked and found that software board issue.replaced the software board.		Yuvarani. P. - RICU	28/06/2023
Dept Name : Special Ward - Biomedical Comp. Dt. : 23/05/2022 Status : Completed								
1226	22050838	Special Ward - A	BP APPARATUS NOT WORKING	Vignesh. D.	checked and found problem in bladder defective so it replaced with the new one problem rectified		Revathi. S. - Special Ward	23/05/2022
Comp. Dt. : 24/05/2022 Status : Completed								
1227	22050873	SPECIAL WARD---B	SUCTION NOT WORKING	Vignesh. D.	checked and found that tube connection problem.the problem is rectified.now its working good.		Reena. N. - Special Ward	25/05/2022
Comp. Dt. : 23/06/2022 Status : Completed								
1228	22060849	SPECIAL WARD - A1	BP APPARATUS NOT WORKING	Vignesh. D.	checked an dfound the bulb issue it's replaced now it's working good		Manjula. R. - Special Ward	24/06/2022
Comp. Dt. : 25/06/2022 Status : Completed								
1229	22060924	Female Surgery - Ward 205	PULSE OXI METER NOT WORKING	Sridhar. K.	AC-DC power supply cable damage, service its now working	AssetNo :16000719	Brindha. R. - Female Surgery	27/06/2022
Comp. Dt. : 02/08/2022 Status : Completed								
1230	22080098	SPECIAL WARD - A1	SP O2 MONITOR NOT WORKING	Sridhar. K.	SPO2 CABLE LOOS PROBLEM RECTIFIED ITS WORKING	AssetNo :1600719	Manjula. R. - Special	04/08/2022

Dr. KAGNE. R.N
DEAN
SRI MANAKULAVINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 05/08/2022 Status : Completed								
1231	22080213	SPECIAL WARD - A1	ECG MACHINE NOT WORKING	Sridhar. K.	checked and found that ecg cable connecting screws damaged and replaced the clamp electrode	AssetNo :16000744	Sivapriya. P. - Special Ward	06/08/2022
Comp. Dt. : 06/08/2022 Status : Completed								
1232	22080228	Special Ward - C	B P CUFF 2NOS NOT WORKING	Sridhar. K.	replace the cuff,badder its working		Prithika. V. - Special Ward	08/08/2022
Comp. Dt. : 09/08/2022 Status : Completed								
1233	22080316	Special Ward - A	NEED ALL BIOMEDICAL ITEMS GENERAL SERVICE FOR ALL ROOMS	Sridhar. K.	checked all equipment working good		Ezhilarasi. P. - Special Ward	09/08/2022
Comp. Dt. : 10/08/2022 Status : Completed								
1234	22080392	SPECIAL WARD - A1	ECG PRINTER MACHINE NOT WORKING	Sridhar. K.	ecg printer machine services now its working	AssetNo :16000744	Manjula. R. - Special Ward	11/08/2022
Comp. Dt. : 11/08/2022 Status : Completed								
1235	22080419	SPECIAL WARD - A1	BP APPARATUS NOT WORKING	Sridhar. K.	general service now its working good		Manjula. R. - Special Ward	11/08/2022
1236	22080423	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	ECG MACHINE NOT WORKING	Sridhar. K.	10 leads ecg cable replaced now its working good	AssetNo :16000283	Elakkiya. S. - Special Ward	12/08/2022
Comp. Dt. : 23/08/2022 Status : Completed								
1237	22080762	SPECIAL WARD - A1	BP APPARATUS NOT WORKING	Gurumoorthy. G.	replaced the bladder		Shalini. S. - Special Ward	23/08/2022
Comp. Dt. : 26/08/2022 Status : Completed								
1238	22080925	Paediatrics - OPD	BP APPARATUS NOT WORKING	Sridhar. K.	service now working		Manjula. R. - Special Ward	27/08/2022
Comp. Dt. : 01/09/2022 Status : Completed								
1239	22090033	SPECIAL WARD - A1	LARYNGOSCOPE BLADE LIGHT NOT WORKING	Sridhar. K.	services now working		Sivapriya. P. - Special Ward	02/09/2022
Comp. Dt. : 17/09/2022								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
1240	22090671	Special Ward - C	BP APPARATUS NOT WORKING	Gurumoorthy. G.	replaced the bladder		Dhatchayani.N. - Special Ward	24/09/2022
Comp. Dt. : 26/09/2022								
Status : Completed								
1241	22091009	SPECIAL WARD - A1	BP APPARATUS NOT WORKING	Gurumoorthy. G.	replaced the bulb with valve		Manjula. R. - Special Ward	26/09/2022
Comp. Dt. : 08/10/2022								
Status : Completed								
1242	22100187	SPECIAL WARD - A1	NEBULIZATION MACHINE NOT WORKING	Gurumoorthy. G.	checked and found that wire connection problem.the problem is rectified		Ragavi. P. - Special Ward	10/10/2022
Comp. Dt. : 13/10/2022								
Status : Completed								
1243	22100396	Special Ward - C	BP APPARATUS NOT WORKING	Gurumoorthy. G.	replaced the bulb with valve		Hemachandra. P. - Special Ward	14/10/2022
Comp. Dt. : 09/11/2022								
Status : Completed								
1244	22110338	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	CITYCENTER- ECG MACHINE NOT WORKING	Sridhar. K.	ECG MODULE CONNECTOR ISSUE IT'S RECTIFIED NOW WORKING GOOD	AssetNo :16000283	Bharathi. R. - Special Ward	09/11/2022
1245	22110340	CITY CENTER IN PONDY	ECG MACHINE NOT WORKING	Sridhar. K.	RE COMPLAINT		Reena. N. - Special Ward	09/11/2022
Comp. Dt. : 02/12/2022								
Status : Completed								
1246	22120078	SPECIAL WARD - A1	NEBULIZER MACHINE + ALBHA BED NOT WORKING	Sridhar. K.	checked and found that wire connection problem.the problem is rectified		Manjula. R. - Special Ward	05/12/2022
Comp. Dt. : 06/12/2022								
Status : Completed								
1247	22120241	SPECIAL WARD A1-FOURTH FLOOR	ALPHA BED MOTOR NOT WORKING	Sridhar. K.	checked and found that wire connection problem.the problem is rectified.		Ragavi. P. - Special Ward	13/12/2022
Comp. Dt. : 10/12/2022								
Status : Completed								
1248	22120465	PATHOLOGY	BP CUFF NOT WORKING	Sridhar. K.	serviced working		Puthika. V. - Special Ward	12/12/2022

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 12/12/2022 Status : Completed								
1249	22120533	SPECIAL WARD A1-FOURTH FLOOR	2 NO'S BP APPARATUS NOT WORKING	Gurumoorthy. G.	replaced the bulb with valve		Manjula. R. - Special Ward	13/12/2022
Comp. Dt. : 17/12/2022 Status : Completed								
1250	22120813	CITY CENTER IN PONDY	ECG MACHINE NOT WORKING	Sridhar. K.	key board serviced	AssetNo :16000283	Dhatchayani.N. - Special Ward	26/12/2022
Comp. Dt. : 26/12/2022 Status : Completed								
1251	22121142	Special Ward - C	BP APPARATUS NOT WORKING	Gurumoorthy. G.	bulb replaced now working good		Pushpa. U. - Special Ward	27/12/2022
Comp. Dt. : 30/12/2022 Status : Completed								
1252	22121345	Special Ward - C	SP O2 MONITOR NOT WORKING	Sridhar. K.	checked and found that spo2 cable connection problem.the problem is rectified		Hemachandra. P. - Special Ward	02/01/2023
Comp. Dt. : 11/01/2023 Status : Completed								
1253	23010452	SPECIAL WARD A1-FOURTH FLOOR	BP APPARATUS NOT WORKING	Gurumoorthy. G.	bulb replaced now working good		Manjula. R. - Special Ward	11/01/2023
Comp. Dt. : 31/01/2023 Status : Completed								
1254	23011108	SPECIAL WARD - A1	BP APPARATUS & MONITOR NOT WORKING	Sridhar. K.	replaced the bladder		Manjula. R. - Special Ward	31/01/2023
1255	23011125	SPECIAL WARD---B	NEED TO CHECK ECG MACHINE PRINTER	Gurumoorthy. G.	printer paper fixing problem.the problem is rectified		Hemachandra. P. - Special Ward	31/01/2023
Comp. Dt. : 20/02/2023 Status : Completed								
1256	23020751	Paediatrics - Ward 309	BP APPARATUS NOT WORKING	Gurumoorthy. G.	replaced the bulb with valve		Hemachandra. P. - Special Ward	20/02/2023
Comp. Dt. : 24/02/2023 Status : Completed								
1257	23020916	Special Ward - C	PRESSURE DISPLAY PROBLEM IN SUCTION APPARATUS	Gurumoorthy. G.	checked and found that shar loose connection problem.the problem is rectified.		Muthulakshmi. A. - Special Ward	27/02/2023
Comp. Dt. : 10/03/2023								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
1258	23030430	Paediatrics - Ward 309	BP APPARATUS NOT WORKING	Vignesh. D.	replaced the bladder		Abirami. G. - Special Ward	13/03/2023
Comp. Dt. : 16/03/2023								
Status : Completed								
1259	23030635	SPECIAL WARD - A1	FINGER PROBE NOT WORKING	Gurumoorthy. G.	replaced the battery		Manjula. R. - Special Ward	24/03/2023
Comp. Dt. : 23/03/2023								
Status : Completed								
1260	23030936	Paediatrics - Ward 310	BP CUFF NOT WORKING [FEMALE MEDICAL WARD 310]	Sridhar. K.	replaced the cuff		Hemachandra. P. - Special Ward	25/03/2023
1261	23030978	Paediatrics - Ward 310	SUCTION APPARATUS NOT WORKING	Sridhar. K.	wire connection problem.the problem is rectified.		Hemachandra. P. - Special Ward	25/03/2023
Comp. Dt. : 30/03/2023								
Status : Completed								
1262	23031294	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	ECG MACHINE NOT WORKING	Sridhar. K.	clamp changed now working		Pushpa. K. - Special Ward	03/04/2023
Comp. Dt. : 15/04/2023								
Status : Completed								
1263	23040447	Special Ward - A	B P APPARATUS NOT WORKING	Gurumoorthy. G.	BULP REPLACED NOW WORKING		Revathi. S. - Special Ward	18/04/2023
Comp. Dt. : 27/04/2023								
Status : Completed								
1264	23040893	SPECIAL WARD - A1	SUCTION APPARATUS NOT WORKING	Gurumoorthy. G.	wire connection problem.the problem is rectified.		Shalini. S. - Special Ward	02/05/2023
Comp. Dt. : 23/05/2023								
Status : Completed								
1265	23050919	SPECIAL WARD - A1	BP APPARATUS NOT WORKING	Gurumoorthy. G.	badder replaced		Manjula. R. - Special Ward	24/05/2023
Comp. Dt. : 16/06/2023								
Status : Completed								
1266	23060605	Paediatrics - Ward 309	NO.2 BP APPARATUS NOT WORKING	Sridhar. K.	BP APP SERVICED WORKING		Ezhilarasi. P. - Special Ward	16/06/2023
Comp. Dt. : 19/06/2023								
Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1267	23060686	SPECIAL WARD - A1	ECG MACHINE NOT WORKING	Sridhar. K.	checked and found that cable connection problem.the problem is rectified.		Manjula. R. - Special Ward	21/06/2023
Comp. Dt. : 20/06/2023 Status : Completed								
1268	23060720	SPECIAL WARD - A1	ECG MACHINE NOT WORKING	Sridhar. K.	checked and found that cable issue.replaced the cable.		Sivapriya. P. - Special Ward	21/06/2023
Dept Name : Surgical Oncology - Biomedical Comp. Dt. : 27/08/2022 Status : Completed								
1269	22080945	Oncology	PULSE OXI METER NOT WORKING	Gurumoorthy. G.	probe issue it's replaced now it's working good		Dhivya Bharathi. P. - Surgical Oncology	01/09/2022
Dept Name : TB & CHEST - Biomedical Comp. Dt. : 07/07/2022 Status : Completed								
1270	22070256	TB & Chest OPD	SPIROMETRY NOT WORKING	Gurumoorthy. G.	checked and found that USB connection problem.the problem is rectified.now its working good.		Kirubasankar. E. - TB & CHEST	14/07/2022
Comp. Dt. : 13/07/2022 Status : Completed								
1271	22070511	TB & CHEST	SPIROMETER NOT WORKING	Gurumoorthy. G.	checked and found that USB connector defective.replaced the USB connector	AssetNo :16000601	Kirubasankar. E. - TB & CHEST	17/08/2022
Dept Name : Thiruvannainallur - Biomedical Comp. Dt. : 31/03/2023 Status : Completed								
1272	23031355	Thiruvannainallur	B P APPARATUS 4 NOS NOT WORKING	Gurumoorthy. G.	bulb replaced now working good		Kanagasabai. D. - P.H.C. - Tiruvannainallur	03/04/2023
Dept Name : UHC Villupuram - Biomedical Comp. Dt. : 20/06/2023 Status : Completed								
1273	23060698	VILLUPURAM PHC	B P APPARATUS BROKEN	Gokul. P. K.	bulb with value replaced		Sankari. J. - UHC Villupuram	20/06/2023
Dept Name : Ward - Biomedical								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
		Comp. Dt. : 28/09/2022						
		Status : Completed						
1274	22091141	OG-OPD	SPOT LIGHT NOT WORKING	Gurumoorthy. G.	replaced the lamp		Bakkiam. A. - Ward	28/09/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.



Sri Manakula Vinayagar Medical College and Hospital

Complaint Status Report From 01-05-2022 To 30-06-2023

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
College Name :		MIT						
Work Type :		Complaint						
Dept Name :		Civil - Maintenance - Civil - Maintenance						
Comp. Dt. :		04/05/2022						
Status :		Completed						
1	22050100	Mit ladies hostel	BLOCK IN BASEMENT WASHING AREA	Sakthivel. E.	block remor		AROKIAMARY - MIT	05/05/2022
2	22050103	Mit ladies hostel	BLOCK IN III FLOOR REST ROOM	Thanuzkodi. E	block remover work		AROKIAMARY - MIT	05/05/2022
Comp. Dt. :		05/05/2022						
Status :		Completed						
3	22050129	JR Quarters	NEED TO CHANGE TAP FOR III & IV FLOOR RESTROOM	Arunagiri. V.	new tap fixing work		KIRTHIKA - MIT	05/05/2022
4	22050139	Mit ladies hostel	BLOCK IN BASEMENT , GROUND , & I & II FLOOR	Govindan. R.,Sakthivel. E.,Thanuzkodi. E	block remover		AROKIAMARY - MIT	05/05/2022
Comp. Dt. :		06/05/2022						
Status :		Completed						
5	22050179	JR Quarters	NEED TO REFIX RESTROOM HANGER FOR III FLOOR [2NOS]	Sellaveeran. M.	2Nos of hanger fixed, problem solved		KIRTHIKA - MIT	12/05/2022
Comp. Dt. :		09/05/2022						
Status :		Completed						
6	22050276*	Mit ladies hostel	REST ROOM BLOCK IN III & IV FLOOR & NEED TO CLEAN GROUND FLOOR REST ROOM [BEE NEST]	Rajendran. R.,Thanuzkodi. E,Sivaraja. M.	3rd and 4th floor - Toilet block removed and Honeycomb destroyed		AROKIAMARY - MIT	12/05/2022
7	22050297	MIT College	REST ROOM BLOCK AT "B & C" WING AT IV FLOOR	Rajendran. R.	block remover work		GUBERAN - MIT	09/05/2022
Comp. Dt. :		12/05/2022						
Status :		Completed						
8	22050407	MIT PRINCIPAL ROOM	WASHBASIN BLOCK(2233)	Thanuzkodi. E,Govindan. R.,Sakthivel. E.	Wash basin block removed, work completed		RAVI - MIT	12/05/2022
9	22050416	MIT College	4TH FLOOR C WING BOYS REST ROOM BLOCK	Rajendhiran. V.,Thanuzkodi. E,Govindan. R.	Toilet block removed, work completed		RAVI - MIT	12/05/2022
Comp. Dt. :		13/05/2022						
Status :		Completed						

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
10	22050486	MIT---PLACEMENT CELL	MD SIR ROOM-REST ROOM BLOCK-NEED SCAVENGER	Rajendran. R.	Block removed.		KAVITHA - MIT	16/05/2022
Comp. Dt. : 18/05/2022 Status : Completed								
11	22050670	MIT College	NEED PLUMBER HELP FOR FIXING PIPELINE & URINAL AT GROUND FLOOR MALE RESTROOM	Sellaveeran. M.,Santhosh Kumar. M.,Gopal. S.	New pipe line and urinal basin fixing work completed		RAVI - MIT	21/05/2022
12	22050671	Mit ladies hostel	REST ROOM BLOCK AT III FLOOR & NEED TO REMOVE BEE NEST ROOM NO 9	Rajendhiran. V.,Sakthivel. E.,Govindan. R.	Rest room block removed. Informed to sivaraja to clear the bee nest in room no.9		AROKIAMARY - MIT	20/05/2022
Comp. Dt. : 21/05/2022 Status : Completed								
13	22050798	MIT College	BLOCK IN FEMALE RESTROOM GROUND FLOOR "B" WING	Sakthivel. E.	Toilet block removed, work completed		KAVITHA - MIT	24/05/2022
Comp. Dt. : 24/05/2022 Status : Completed								
14	22050896	Mit ladies hostel	BLOCK IN III FLOOR REST ROOM	Rajendhiran. V.,Sakthivel. E.,Govindan. R.	Block removed in the rest room		AROKIAMARY - MIT	25/05/2022
15	22050898	MIT College	REST ROOM BLOCK AT I FLOOR "C" WING	Sakthivel. E.	Rest room block removed.		GUBERAN - MIT	25/05/2022
Comp. Dt. : 11/06/2022 Status : Completed								
16	22060423	Mit ladies hostel	BLOCK AT HAND WASH AREA AT GROUND FLOOR	Sakthivel. E.	block removed.		AROKIAMARY - MIT	13/06/2022
Comp. Dt. : 13/06/2022 Status : Completed								
17	22060482	MIT College	BLOCK IN I FLOOR MBA STAFF REST ROOM	Sakthivel. E.	Toilet block removed, work completed		GUBERAN - MIT	14/06/2022
Comp. Dt. : 14/06/2022 Status : Completed								
18	22060524	MIT College	NEED TO REMOVE BEE NEST AT NEW BUILDING	Sivaraja. M.	Honey comb destroyed, work completed		KAVITHA - MIT	17/06/2022
Comp. Dt. : 18/06/2022 Status : Completed								
19	22060687	MIT College	BLOCK IN MALE REST ROOM AT GROUND FLOOR "B" WING	Govindan. R.	Block removed.		KAVITHA - MIT	20/06/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 20/06/2022 Status : Completed								
20	22060699	MIT College	BLOCK IN MALE REST ROOM - III FLOOR "C" WING	Sakthivel. E.	Block removed.		RAVI - MIT	21/06/2022
Comp. Dt. : 22/06/2022 Status : Completed								
21	22060793	Mit ladies hostel	REST ROOM BLOCK AT III FLOOR	Govindan. R.	Block removed.		AROKIAMARY - MIT	24/06/2022
Comp. Dt. : 24/06/2022 Status : Completed								
22	22060894	MIT College	BLOCK IN MALE REST ROOM - III FLOOR "C" WING	Govindan. R., Sakthivel. E., Rajendran. R.	Block removed.		GUBERAN - MIT	25/06/2022
Comp. Dt. : 28/06/2022 Status : Completed								
23	22061024	MIT College	BLOCK IN MALE REST ROOM "B" WING GROUND FLOOR & III FLOOR	Govindan. R.	Toilet block removed, work completed		KAVITHA - MIT	30/06/2022
Comp. Dt. : 29/06/2022 Status : Completed								
24	22061044	Mit ladies hostel	BLOCK IN BASEMENT WASHING AREA	Govindan. R.	Washing area block removed, work completed		RAVI - MIT	30/06/2022
25	22061070	Mit boys hostel	NEED LABOURS 2 NOS FOR SHIFTING GRINDER TO WORKSHOP FOR REPAIRING WORK	Pandiaraj. V., Yuvaraj. M., Murali. K.	Grinder shifted to workshop for repairing work		BALA - MIT	01/07/2022
Comp. Dt. : 30/06/2022 Status : Completed								
26	22061121	MIT College	NEED CLEANING WORK FOR AURO WATER TANK	Raja. V.	RO water tank cleaning work done		RAVI - MIT	09/07/2022
Comp. Dt. : 01/07/2022 Status : Completed								
27	22070033	Mit ladies hostel	WASH BASIN BLOCK & NEED TO CHANGE TAP - WATER LEAKAGE AT IV FLOOR COMMON RESTROOM	Rajendhiran. V., Thanuzkodi. E., Govindan. R.	Block removed and New tap changed.		AROKIAMARY - MIT	09/07/2022
Comp. Dt. : 06/07/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
28	22070211	MIT College	BLOCK IN II FLOOR " C" WING FEMALE RESTROOM	Sakthivel. E.,Govindan. R.,Murugan. S.	Block removed.		KAVITHA - MIT	09/07/2022
Comp. Dt. : 07/07/2022 Status : Completed								
29	22070269	MIT College	BLOCK IN FEMALE RESTROOM AT GROUND FLOOR "C" WING	Rajendhiran. V.	Block removed		KAVITHA - MIT	09/07/2022
Comp. Dt. : 11/07/2022 Status : Completed								
30	22070408	Mit ladies hostel	NEED TO CHANGE HEATER TAP - WATER LEAKAGE AT I FLOOR RESTROOM	Anandharaj. M.,Udhaya Kumar. R.,Gopal. S.	CP tap changed.		AROKIAMARY - MIT	22/07/2022
31	22070409	Mit ladies hostel	BLOCK IN I FLOOR RESTROOM	Govindan. R.	Block removed		AROKIAMARY - MIT	12/07/2022
32	22070432	MIT College	BLOCK IN REST ROOM 2 NOS AT GROUND FLOOR	Sakthivel. E.,Govindan. R.,Thanuzkodi. E	Block removed		GUBERAN - MIT	12/07/2022
Comp. Dt. : 14/07/2022 Status : Completed								
33	22070546	Mit ladies hostel	NEED TO CHECK HEATER PIPE LINE - BLOCK - WATER NOT COMING AT I FLOOR COMMON REST ROOM	Rajendhiran. V.,Thanuzkodi. E.,Murugan. S.	New tap changed.		AROKIAMARY - MIT	22/07/2022
Comp. Dt. : 20/07/2022 Status : Completed								
34	22070733	Mit ladies hostel	REST ROOM BLOCK AT GROUND FLOOR - NEED URGENT SERVICE	Rajendhiran. V.,Govindan. R.,Murugan. S.	Toilet block removed,work completed		AROKIAMARY - MIT	20/07/2022
35	22070736	MIT MESS	BLOCK IN WASH BASIN	Thanuzkodi. E	Wash basin block removed, work completed		RAVI - MIT	20/07/2022
36	22070758	Mit ladies hostel	BLOCK IN II FLOOR	Govindan. R.	Block removed.		AROKIAMARY - MIT	22/07/2022
Comp. Dt. : 22/07/2022 Status : Completed								
37	22070849	Mit ladies hostel	BLOCK IN BASEMENT WASHING AREA	Sakthivel. E.	Block removed.		AROKIAMARY - MIT	26/07/2022
Comp. Dt. : 25/07/2022 Status : Completed								
38	22070896	Mit ladies hostel	RESTROOM BLOCK IN IV FLOOR	Govindan. R.	Block removed.		AROKIAMARY - MIT	26/07/2022
39	22070919	Mit ladies hostel	IV FLOOR [LEFTSIDE] REST ROOM BLOCK	Govindan. R.	Block removed.		AROKIAMARY - MIT	26/07/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 26/07/2022								
Status : Completed								
40	22070951	Mit ladies hostel	BLOCK IN REST ROOM AT III & IV FLOOR + NEED TO CHECK HEATER TAP - WATER NOT COMING IN III FLOOR RE	Sakthivel. E.	Block removed.		AROKIAMARY - MIT	27/07/2022
41	22070952	Mit ladies hostel	NEED TO CHANGE TAP - WATER LEAKAGE AT GROUND FLOOR RESTROOM & FLUSH KEY NOT WORKING IN III FLOOR RE	Santhosh Kumar. M.	Flush tank washer changed, tap changed, work completed		AROKIAMARY - MIT	01/08/2022
42	22070953	Mit ladies hostel	NEED TO CHECK ALL WALL FOR ROOM NO 64 - WATER LEAKAGE FROM THE WALL SIDE & NEED URGENT SERVICE	Santhosh Kumar. M.	In window side leakage problem, leakage arrested		AROKIAMARY - MIT	01/08/2022
Comp. Dt. : 29/07/2022								
Status : Completed								
43	22071063	Mit ladies hostel	BLOCK IN IV FLOOR RESTROOM	Sakthivel. E.	Block removed.		AROKIAMARY - MIT	30/07/2022
Comp. Dt. : 30/07/2022								
Status : Completed								
44	22071098	Mit ladies hostel	BLOCK IN I FLOOR REST ROOM	Sakthivel. E.	Toilet block removed, work completed		AROKIAMARY - MIT	01/08/2022
Comp. Dt. : 05/08/2022								
Status : Completed								
45	22080194	Mit ladies hostel	BLOCK IN BASEMENT WASHING AREA	Sakthivel. E.	Block removed.		AROKIAMARY - MIT	08/08/2022
Comp. Dt. : 19/08/2022								
Status : Completed								
46	22080635	MIT College	NEED LABOURS FOR SHIFTING PURPOSE(20 NO'S DESK SHIFTING WORK)	Pandiaraj. V.,Yuvaraj. M.,Murali. K.	Desk shifting work done.		bala - MIT	22/08/2022
Comp. Dt. : 22/08/2022								
Status : Completed								
47	22080698	MIT College	BLOCK IN GROUND FLOOR "B" WING EXAM CELL	Govindan. R.	block removed.		KAVITHA - MIT	23/08/2022
Comp. Dt. : 26/08/2022								
Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
48	22080918	MIT College	NEED LABOURS 4 NOS FOR DUEL DESK SHIFTING WORK FROM LADIES HOSTEL TO MIT COLLEGE I FLOOR	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	Dual desk Shiftng and exam hall arrangement work completed		BALA - MIT	01/09/2022
		Comp. Dt. : 14/09/2022 Status : Completed						
49	22090556	MIT College	BLOCK IN GROUND FLOOR "B " WING & III FLOOR "C" WING BOTH [MALE & FEMALE] RESTROOMS	Sakthivel. E.	block removed.		BALA - MIT	15/09/2022
		Comp. Dt. : 16/09/2022 Status : Completed						
50	22090633	MIT College	BLOCK IN COMMON MALE RESTROOM - III FLOOR "C" WING	Sakthivel. E.,Rajendhiran. V.,Thanuzkodi. E	block removed.		KAVITHA - MIT	19/09/2022
		Comp. Dt. : 21/09/2022 Status : Completed						
51	22090824	Mit ladies hostel	BLOCK IN GROUND & III FLOOR RESTROOM	Sakthivel. E.	Block removed.		AROKIAMARY - MIT	24/09/2022
		Comp. Dt. : 17/10/2022 Status : Completed						
52	22100530	Mit ladies hostel	NEED TO CHANGE HEATER PIPELINE TAP - WATER FLOW AT I FLOOR	Sellaveeran. M.	Connection tube changed.		AROKIAMARY - MIT	25/10/2022
53	22100532	Mit ladies hostel	NEED TO CHECK R O WATER LINE TAP - WATER NOT COMING	Sellaveeran. M.	New tap and Pipe line making work, work completed		AROKIAMARY - MIT	27/10/2022
54	22100535	MIT College	DUE TO DEATH OF RAT - BAD SMELL -NEED TO CLEAN II FLOOR "C" WING COOLER	Pandiaraj. V.,Anandharaj. M.,Azhagar. N.	Checked, no complaint		GUBERAN - MIT	27/10/2022
55	22100536	MIT College	RESTROOM BLOCK AT GROUND FLOOR "B" WING	Sakthivel. E.	Block removed.		GUBERAN - MIT	20/10/2022
		Comp. Dt. : 19/10/2022 Status : Completed						
56	22100641	Mit ladies hostel	3RD FLOOR BATHROOM BLOCK	Sakthivel. E.	Block removed.		AROKIAMARY - MIT	20/10/2022
		Comp. Dt. : 20/10/2022 Status : Completed						
57	22100682	MIT College	GENS TOILET BLOCKED IN GROUND FLOOR	Sakthivel. E.	BLOCK REMOVED.		GUBERAN - MIT	21/10/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 26/10/2022 Status : Completed								
58	22100820	MIT College	(2209) NEED MANPOWER-TABLE ARRANGEMENT WORK(1ST YEAR INDUCTION DAY)	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	Table arrangment work completed.		BALA - MIT	28/10/2022
Comp. Dt. : 28/10/2022 Status : Completed								
59	22100899	J.R Quateres	NEED MANPOWER FOR SHIFTING PURPOSE-60 NO'S COT NEED TO BE SHIFT FROM GROUND FLOOR TO 4TH FLOOR	Pandiaraj. V.,Yuvaraj. M.,Thulasi. V.	Cot shifting work completed		BALA - MIT	31/10/2022
Comp. Dt. : 31/10/2022 Status : Completed								
60	22101037	MIT College	3RD FLOOR LADIES REST ROOM BLOCK	Sakthivel. E.	Block removed.		RAVI - MIT	03/11/2022
Comp. Dt. : 04/11/2022 Status : Completed								
61	22110119	MIT College	NEED LABOURS FOR 10 NO'S DUAL DESK SHIFTING PURPOSE	Prakash. N.,Pandiaraj. V.,Yuvaraj. M.	Dual desk shifting work completed.		BALA - MIT	15/11/2022
Comp. Dt. : 17/11/2022 Status : Completed								
62	22110721	Mit boys hostel	URINAL BLOCK IN GROUND FLOOR,NEED SCAVENGER	Sakthivel. E.	Block removed.		RAVI - MIT	18/11/2022
63	22110722	MIT College	C WING-URINAL BLOCK IN GROUND FLOOR,NEED SCAVENGER	Sakthivel. E.	Block removed.		RAVI - MIT	18/11/2022
Comp. Dt. : 21/11/2022 Status : Completed								
64	22110861	MIT College	NEED 5 NO'S MANPOWER FOR SHIFTING WORK	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	Shifting work completed.		BALA - MIT	25/11/2022
65	22110878	MIT College	IN 3RD AND 4TH FLOOR-WATER NOT COMING IN REST ROOMS	Anandharaj. M.,Prakash. V.,Rajendran. R.	Due to power cut problem, motor switch on water filled in tank, problem solved		GUBERAN - MIT	24/11/2022
Comp. Dt. : 25/11/2022 Status : Completed								
66	22111084	MIT College	NEED MANPOWER TO SHIFT TABLE FROM MIT TO J.R QUARTERS	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	Table shifting work completed.		BALA - MIT	26/11/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 29/11/2022 Status : Completed								
67	22111207	JR Quarters	NEED PLUMBING WORK WORK FOR IV FLOOR	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	4th floor Flush tank refixed, Tap changed, 3rd floor- 3Nos of Flush tank washer changed and rework, Work completed.		GUBERAN - MIT	01/12/2022
68	22111208	Mit ladies hostel	NEED PLUMBING WORK FOR III FLOOR	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.			GUBERAN - MIT	06/12/2022
Comp. Dt. : 01/12/2022 Status : Completed								
69	22120021	JR Quarters	NEED LABOURS 4 NOS FOR COT SHIFTING WORK	Pandiaraj. V.,Yuvaraj. M.,Thulasi. V.	Cot shifting work completed		BALA - MIT	05/12/2022
Comp. Dt. : 02/12/2022 Status : Completed								
70	22120066	Mit ladies hostel	NEED TO REFIX WASH BASIN - I FLOOR RESTROOM	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	Wash basin refixed.		AROKIAMARY - MIT	06/12/2022
Comp. Dt. : 27/12/2022 Status : Completed								
71	22121195	Mit ladies hostel	GROUND FLOOR REST ROOM BLOCK	Sakthivel. E.	Block removed.		AROKIAMARY - MIT	28/12/2022
Comp. Dt. : 04/01/2023 Status : Completed								
72	23010144	MIT College	NEAR CANTEEN-GROUND FLOOR-TOILET BLOCKED	Sakthivel. E.,Govindan. R.,Kathirvelu. K.	Block removed.		RAVI - MIT	05/01/2023
Comp. Dt. : 09/01/2023 Status : Completed								
73	23010370	MIT College	IN 4TH FLOOR-C WING GENTS TOILET BLOCKED,NEED SCAVENGER	Prakash. V.,Rajendran. R.,Ramkumar. R.	block removed.		RAVI - MIT	12/01/2023
Comp. Dt. : 24/01/2023 Status : Completed								
74	23010857	MIT AUDITORIUM BACKSIDE	STP PIPE LINE BROKEN - WATER FLOW NEAT MIT BUS STOP NEED URGENT SERVICE	Rajendran. R.,Sankar. R,Abdul Azees. J.	STP line connection work done.	 Dr. KAGNE. R.N DEAN SRI MANAKULA VINAYAGAR MEDICAL COLLEGE & HOSPITAL KALITHEERTHALKUPPAM, PUDUCHERRY-605107.	BALA - MIT	25/01/2023

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 25/01/2023 Status : Completed								
75	23010921	MIT College	RESTROOM BLOCK IN IV FLOOR "C" WING	Sakthivel. E.,Govindan. R.,Kathirvelu. K.	Block removed.		GUBERAN - MIT	27/01/2023
Comp. Dt. : 27/01/2023 Status : Completed								
76	23010961	Mit ladies hostel	BLOCK IN DINING HALL - NEED URGENT SERVICE	Sakthivel. E.,Govindan. R.,Murugan. S.	Dining hall block removed, work completed		AROKIAMARY - MIT	27/01/2023
Comp. Dt. : 28/01/2023 Status : Completed								
77	23011016	Mit ladies hostel	NEED TO SPRAY TERMITE SPRAY NEAR RESTROOM & DOOR FRAME	Kannan. J.	Termite spraying work done.		AROKIAMARY - MIT	31/01/2023
Comp. Dt. : 30/01/2023 Status : Completed								
78	23011039	Mit ladies hostel	BLOCK IN I FLOOR RESTROOM	Sakthivel. E.	block removed.		AROKIAMARY - MIT	31/01/2023
79	23011053	MIT College	BLOCK - MALE RESTROOM AT I FLOOR "C" WING	Sakthivel. E.	block removed.		GUBERAN - MIT	31/01/2023
Comp. Dt. : 02/02/2023 Status : Completed								
80	23020062	Mit ladies hostel	BLOCK IN I FLOOR RESTROOM	Sakthivel. E.	Block removed		AROKIAMARY - MIT	03/02/2023
Comp. Dt. : 07/02/2023 Status : Completed								
81	23020224	Mit ladies hostel	BLOCK IN WASH BASIN & REST ROOM	Sakthivel. E.,Govindan. R.,Kathirvelu. K.	BLOCK REMOVED.		RAVI - MIT	08/02/2023
82	23020248	MIT College	MALE REST ROOM BLOCK AT GROUND FLOOR " B " WING SIDE	Sakthivel. E.,Govindan. R.,Kathirvelu. K.	BLOCK REMOVED.		KAVITHA - MIT	08/02/2023
Comp. Dt. : 08/02/2023 Status : Completed								
83	23020286	MIT College	WASH BASIN WATER BLOCK IN 1ST FLOOR A WING	Sakthivel. E.,Govindan. R.,Kathirvelu. K.	BLOCK REMOVED.		PARAMESHWARI - MIT	09/02/2023
84	23020305	Mit ladies hostel	3RD FLOOR REST ROOM BLOCK	Sakthivel. E.,Govindan. R.,Kathirvelu. K.	BLOCK REMOVED.		AROKIAMARY - MIT	09/02/2023
Comp. Dt. : 09/02/2023								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
85	23020354	MIT College	MESS-WASHING AREA WATER BLOCK	Sakthivel. E.,Govindan. R.,Kathirvelu. K.	BLOCK REMOVED.		RAVI - MIT	10/02/2023
Comp. Dt. : 14/02/2023								
Status : Completed								
86	23020547	Mit ladies hostel	REST ROOM BLOCK IN III FLOOR	Sakthivel. E.,Govindan. R.,Kathirvelu. K.	BLOCK REMOVED.		AROKIAMARY - MIT	15/02/2023
Comp. Dt. : 20/02/2023								
Status : Completed								
87	23020762	MIT College	NEED MAN POWER 4 NOS FOR EXAM HALL ARRANGEMENT WORK	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	EXAM HALL ARRANGMENT WORK DONE.		BALA - MIT	25/02/2023
Comp. Dt. : 21/02/2023								
Status : Completed								
88	23020806	Mit ladies hostel	BLOCK IN GROUND FLOOR RESTROOM	Sakthivel. E.,Govindan. R.,Kathirvelu. K.	BLOCK REMOVED.		AROKIAMARY - MIT	21/02/2023
Comp. Dt. : 06/03/2023								
Status : Completed								
89	23030232	MIT Auditorium	NEED MANPOWER 4 NOS FOR PLAIN TABLE SHIFTING WORK FROM MIT AUDITORIUM TO MIT COLLEGE	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	TABLE SHIFTED FROM MIT AUDITORIUM TO MIT COLLEGE		BALA - MIT	17/03/2023
Comp. Dt. : 07/03/2023								
Status : Completed								
90	23030280	MIT College	URINAL BLOCK AT IV FLOOR " B" WING	Sakthivel. E.,Govindan. R.,Kathirvelu. K.	URINAL BLOCK REMOVED.		RAVI - MIT	08/03/2023
Comp. Dt. : 14/03/2023								
Status : Completed								
91	23030529	Mit boys hostel	REST ROOM BLOCK IN ROOM NO 9	Sakthivel. E.,Govindan. R.,Kathirvelu. K.	BLOCK REMOVED		BALA - MIT	15/03/2023
Comp. Dt. : 15/03/2023								
Status : Completed								
92	23030602	Mit ladies hostel	BLOCK IN I & III FLOOR RESTROOM	Rajendhiran. V.,Thanuzkodi. E.,Murugan. S.	BLOCK REMOVED		AROKIAMARY - MIT	16/03/2023

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 16/03/2023 Status : Completed								
93	23030654	Mit boys hostel	BLOCK IN GROUND FLOOR RESTROOM	Sakthivel. E.,Govindan. R.,Kathirvelu. K.	BLOCK REMOVED.		RAVI - MIT	17/03/2023
Comp. Dt. : 17/03/2023 Status : Completed								
94	23030718	MIT College	BLOCK IN IV FLOOR MALE RESTROOM	Sakthivel. E.,Govindan. R.,Kathirvelu. K.	BLOCK REMOVED.		RAVI - MIT	18/03/2023
95	23030725	MIT College	BLOCK IN IV FLOOR " B" WING MALE RESTROOM	Sakthivel. E.,Govindan. R.,Kathirvelu. K.	BLOCK REMOVED.		GUBERAN - MIT	18/03/2023
Comp. Dt. : 27/03/2023 Status : Completed								
96	23031095	Mit ladies hostel	BLOCK IN III FLOOR & MESS WASH BASIN	Thanuzkodi. E	BLOCK REMOVED.		AROKIAMARY - MIT	27/03/2023
Comp. Dt. : 28/03/2023 Status : Completed								
97	23031174	Mit ladies hostel	WASH BASIN BLOCK AT GROUND FLOOR DINNING HALL	Kathirvelu. K.,Sakthivel. E.,Govindan. R.	BLOCK REMOVED.		RAVI - MIT	30/03/2023
Comp. Dt. : 04/04/2023 Status : Completed								
98	23040115	MIT College	BLOCK IN MALE RESTROOM AT IV FLOOR "B" WING	Sakthivel. E.,Govindan. R.,Kathirvelu. K.	BLOCK REMOVED.		GUBERAN - MIT	05/04/2023
Comp. Dt. : 11/04/2023 Status : Completed								
99	23040319	Mit ladies hostel	TAP BROKEN AT II FLOOR - WATER FLOW NEED URGENT SERVICE	Prakash. V.,Rajendran. R.,Ramkumar. R.	New PVC Tap changed, problem solved		AROKIAMARY - MIT	20/04/2023
Comp. Dt. : 24/04/2023 Status : Completed								
100	23040751	Mit ladies hostel	NEED TO REMOVE BEE NEST . BEES FLY AND COMING IN SIDE THE ROOMS	Sivaraja. M.	HONEY BEE DESTROYED.		AROKIAMARY - MIT	06/05/2023
Comp. Dt. : 02/05/2023 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
101	23050043	Mit ladies hostel	NEED TO CHANGE TAP - BROKEN WATER FLOW AT I FLOOR RESTROOM - NEED URGENT SERVICE	Prakash. V.,Rajendran. R.,Ramkumar. R.	TAP CHANGED.		AROKIAMARY - MIT	05/05/2023
102	23050052	Mit ladies hostel	BLOCK IN GROUND FLOOR NEAR MESS	Sakthivel. E.,Govindan. R.,Kathirvelu. K.	block removed.		AROKIAMARY - MIT	03/05/2023
Comp. Dt. : 08/05/2023 Status : Completed								
103	23050335	MIT College	BLOCK IN MALE REST ROOM AT I FLOOR " C" WING	Sakthivel. E.	BLOCK REMOVED.		RAVI - MIT	10/05/2023
104	23050336	MIT College	BLOCK IN MALE REST ROOM AT III FLOOR " B " WING	Sakthivel. E.	BLOCK REMOVED.		RAVI - MIT	10/05/2023
Comp. Dt. : 10/05/2023 Status : Completed								
105	23050402	MIT College	1 FLOOR BATHROOM BLOCK	Sakthivel. E.	BLOCK REMOVED.		GUBERAN - MIT	11/05/2023
Comp. Dt. : 11/05/2023 Status : Completed								
106	23050432	MIT College	BLOCK IN II FLOOR " C WING" MALE RESTROOM	Sakthivel. E.,Govindan. R.,Kathirvelu. K.	BLOCK REMOVED.		GUBERAN - MIT	12/05/2023
Comp. Dt. : 12/05/2023 Status : Completed								
107	23050505	MIT College	BLOCK IN IV FLOOR "C" WING RESTROOM	Sakthivel. E.,Govindan. R.,Kathirvelu. K.	BLOCK REMOVED.		GUBERAN - MIT	13/05/2023
Comp. Dt. : 13/05/2023 Status : Completed								
108	23050533	MIT College	BLOCK IN MALE RESTROOM AT II FLOOR "C" WING	Sakthivel. E.	BLOCK REMOVED.		GUBERAN - MIT	15/05/2023
109	23050545	MIT College	NEED MANPOWER 4NOS FOR CUPBOARD SHIFTING WORK [INTERCHANGE]	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	CUPBOARD SHIFTING WORK COMPLETED		BALA - MIT	25/05/2023
Comp. Dt. : 16/05/2023 Status : Completed								
110	23050648	Mit ladies hostel	BLOCK IN I & III FLOOR RESTROOM	Sakthivel. E.	BLOCK REMOVED.		AROKIAMARY - MIT	17/05/2023
Comp. Dt. : 06/06/2023 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
111	23060169	Mit ladies hostel	RESTROOM BLOCK IN IV FLOOR - NEED URGENT SERVICE	Sakthivel. E.,Govindan. R.,Gnanasegaran. K.	BLOCK REMOVED.		AROKIAMARY 9095237375 - MIT	06/06/2023
112	23060192	MIT College	BLOCK IN GROUND FLOOR "B" WING COMMON MALE RESTROOM	Sakthivel. E.,Govindan. R.,Kathirvelu. K.	BLOCK REMOVED.		GUBERAN - MIT	06/06/2023
113	23060207	MIT MESS	BLOCK IN GROUND FLOOR HAND WASHING AREA	Sakthivel. E.,Govindan. R.,Kathirvelu. K.	BLOCK REMOVED.		AROKIAMARY - MIT	06/06/2023
Comp. Dt. : 07/06/2023 Status : Completed								
114	23060217	Mit ladies hostel	NEED TO CHECK BACKSIDE WALL - BROKEN - WATER LEAKAGE AT IV FLOOR	Prakash. V.,Rajendran. R.,Ramkumar. R.	WORKSHOP COMPLAINTS		AROKIAMARY - MIT	10/06/2023
Comp. Dt. : 14/06/2023 Status : Completed								
115	23060519	MIT College	BLOCK IN GROUND FLOOR "B" WING RESTROOM [BOTH SIDE]	Rajendhiran. V.,Sakthivel. E.,Govindan. R.	BLOCK REMOVED.		GUBERAN - MIT	15/06/2023
Comp. Dt. : 26/06/2023 Status : Completed								
116	23060975	Mit ladies hostel	BLOCK IN I FLOOR RESTROOM	Sakthivel. E.,Govindan. R.,Kathirvelu. K.	Block removed.		AROKIAMARY - MIT	27/06/2023
Comp. Dt. : 28/06/2023 Status : Completed								
117	23061071	Mit ladies hostel	BLOCK IN I FLOOR RESTROOM [REPEAT]	Rajendhiran. V.,Thanuzkodi. E.,Murugan. S.	BLOCK REMOVED.		AROKIAMARY - MIT	30/06/2023
Work Type : Work Dept Name : Civil - Maintenance - Civil - Maintenance Comp. Dt. : 21/05/2022 Status : Completed								
118	22050800	MIT College	NEED LABOURS 6 NOS FOR EXAM HALL ARRANGEMENT WORK	Pandiaraj. V.,Yuvaraj. M.,Thulasi. V.	Exam hall arrangement work completed		BALA - MIT	25/05/2022
Comp. Dt. : 22/06/2022 Status : Completed								
119	22060787	MIT College	NEED LABOURS 4 NOS FOR DUEL DESK SHIFTING WORK FROM III FLOOR TO IV FLOOR	Pandiaraj. V.,Yuvaraj. M.,Murali. K.	Duel desk shifting work completed		BALA - MIT	24/06/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 20/07/2022 Status : Completed								
120	22070734	MIT College	NEED LABOURS 2 NOS FOR DUAL DESK SHIFTING WORK FROM I FLOOR TO GROUND FLOOR	Pandiaraj. V.,Yuvaraj. M.,Thulasi. V.	Dual desk shifting work done		BALA - MIT	26/07/2022
Comp. Dt. : 27/07/2022 Status : Completed								
121	22071029	MIT College	NEED LABOURS 3 NOS FOR DRAWING TABLE SHIFTING WORK FROM GROUND FLOOR TO III FLOOR DRAWING HALL	Prakash. N.,Pandiaraj. V.,Yuvaraj. M.	Shifting work done		BALA - MIT	03/08/2022
Comp. Dt. : 10/08/2022 Status : Completed								
122	22080362	MIT College	NEED LABOURS 3 NOS FOR SHIFTING DUAL DESK [15 NOS] FROM II & I FLOOR TO GROUND FLOOR	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	shifting work completed.		BALA - MIT	11/08/2022
Comp. Dt. : 06/09/2022 Status : Completed								
123	22090229	Mit ladies hostel	NEED LABOURS 4 NOS FOR SHIFTING [TABLES 40NOS] FORM MIT LADIES HOSTEL TO MIT COLLEGE I FLOOR	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	shifting work completed		BALA - MIT	10/09/2022
Comp. Dt. : 09/09/2022 Status : Completed								
124	22090376	MIT College	NEED LABOUR 8 NOS FOR NINENNING HALL	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	work completed.		BALA - MIT	10/09/2022
Comp. Dt. : 27/09/2022 Status : Completed								
125	22091076	MIT College	NEED LABOURS 4 NO'S FOR SHIFTING DUAL DESK FROM 2nd FLOOR TO 3rd FLOOR	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	Dual desk shifting work completed.		BALA - MIT	01/10/2022
Comp. Dt. : 14/10/2022 Status : Completed								
126	22100460	MIT College	NEED LABOUR 2 NOS FOR COT SHIFTING WORK FROM MIT III FLOOR TO MIT LADIES HOSTEL	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	Shifting work comopleter		BALA - MIT	15/10/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 24/01/2023 Status : Completed								
127	23010850	MIT College	NEED MANPOWER 4 NOS FOR EXAM HALL ARRANGEMENT	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	Exam hall arrangement work done.		BALA - MIT	24/01/2023
Comp. Dt. : 25/01/2023 Status : Completed								
128	23010902	MIT College	NEED MANPOWER 2 NOS FOR ELECTRICAL ITEMS SHIFTING WORK	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	Shifting work completed		BALA - MIT	28/01/2023
Comp. Dt. : 31/01/2023 Status : Completed								
129	23011115	JR Quarters	NEED MANPOWER 4 NOS FOR SHIFTING WORK [TABLE [4NOS] & CHAIRS [25 NOS] FROM JR QUARTERS TO MIT COLL	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	TABLES AND CHAIRS SHIFTED FROM JR QUARTERS TO MIT COLLEGE		BALA - MIT	16/02/2023
Comp. Dt. : 25/02/2023 Status : Completed								
130	23020971	MIT College	NEED MANPOWER 8 NOS FOR FUNCTION [NEED ON TODAY 25.02.2023 & TOMORROW 26.02.2023]	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	FUNCTION ARRANGEMENT WORK DONE.		BALA - MIT	03/03/2023
Comp. Dt. : 14/03/2023 Status : Completed								
131	23030522	MIT College	NEED MANPOWER 4 NOS FOR DESK ARRANGEMENT	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	DESK ARRANGEMENT WORK DONE.		BALA - MIT	17/03/2023
Comp. Dt. : 26/06/2023 Status : Completed								
132	23060971	MIT College	NEED MANPOWER 4 NOS FOR TABLE [30 NOS] SHIFTING WORK FROM III FLOOR TO GROUND FLOOR	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	TABLE SHIFTING WORK COMPLETED		BALA - MIT	04/07/2023

College Name : Others

Work Type : Complaint

Dept Name : Civil - Maintenance - Civil - Maintenance

Comp. Dt. : 12/05/2022

Status : Completed

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
133	22050432	Mit ladies hostel	IN GROUND FLOOR-BATHROOM BLOCK	Rajendhiran. V.,Thanuzkodi. E.,Govindan. R.	block remor work		AROKIYAMARY - Others	13/05/2022
Comp. Dt. : 10/06/2022 Status : Completed								
134	22060395	Mit ladies hostel	IN 2ND FLOOR-BATHROOM BLOCK IN ALL ROOMS-NEED SCAVENGER	Govindan. R.	Block removed		AROKIYAMARY - Others	11/06/2022
Comp. Dt. : 17/08/2022 Status : Completed								
135	22080524	J.R Quateres	IN 2ND FLOOR-RO WATER NOT WORKING	Azhagar. N.	RO water coming		THENDRAL - Others	22/08/2022
Comp. Dt. : 12/09/2022 Status : Completed								
136	22090460	Polytechnic college	NEED SERVICE TOWARDS CHAMBER OVERFLOW	Sivaraja. M.,Anandharaj. M.,Azhagar. N.	Block removed.		SANTHANAM - Others	22/09/2022
Comp. Dt. : 20/10/2022 Status : Completed								
137	22100694	B.ED COLLEGE	WATER PIPE LINE BROKEN NEAR STP	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	1.1/4" pipeline connection work done.		SEEMAN - Others	26/10/2022
Comp. Dt. : 26/10/2022 Status : Completed								
138	22100837	Mit ladies hostel	IN 4TH FLOOR TERROUS WATER TAP BROKEN-MASON WORK	Azhagar. N.	New PVC Tap changed, problem solved		AROKIYAMARY - Others	27/10/2022
Comp. Dt. : 02/11/2022 Status : Completed								
139	22110018	B.ED COLLEGE	IN 1ST FLOOR-MALE STAFF REST ROOM-WATER TAP BROKEN,LEAKAGING PROBLEM	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	Tap changed. Flush tank rework done.		SRIMAN - Others	08/11/2022
Comp. Dt. : 04/11/2022 Status : Completed								
140	22110147	B.ED COLLEGE	WATER TAP BROKEN,LEAKAGING PROBLEM	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	Tap changed.		SRIMAN - Others	08/11/2022
Comp. Dt. : 15/11/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
141	22110621	B.ED COLLEGE	IN 1ST FLOOR-STAFF TOILET BLOCKED,NEED SCAVENGER	Govindan. R.	Toilet block removed, work completed		sriman - Others	16/11/2022
	Comp. Dt. : 24/11/2022 Status : Completed							
142	22111029	B.ED COLLEGE	IN 1ST FLOOR-STAFF TOILET BLOCK,NEED SCAVENGER	Sakthivel. E.	Block removed.		SRIMAN - Others	24/11/2022
	Comp. Dt. : 28/11/2022 Status : Completed							
143	22111170	Mit ladies hostel	IN 3RD FLOOR-REST ROOM BLOCK	Sakthivel. E.	block removed.		AROKIYAMARY - Others	30/11/2022
	Comp. Dt. : 30/11/2022 Status : Completed							
144	22111287	Mit ladies hostel	1 ST FLOOR-TOILET BLOCKED,NEED SCAVENGER	Sakthivel. E.	Block removed		AROKIYAMARY - Others	30/11/2022
	Comp. Dt. : 29/12/2022 Status : Completed							
145	22121336	Mit ladies hostel	IN 2ND FLOOR-COMMON TOILET BLOCKED,NEED SCAVENGER-JR SIDE	Sakthivel. E.,Govindan. R.,Kathirvelu. K.	Block removed.		AROKIYAMARY - Others	30/12/2022
	Comp. Dt. : 04/01/2023 Status : Completed							
146	23010181	B.ED COLLEGE	IN PRINCIPAL ROOM-REST ROOM BLOCK,NEED SCAVENGER	Sakthivel. E.,Govindan. R.,Kathirvelu. K.	Block removed.		SRIMAN - Others	05/01/2023
	Comp. Dt. : 09/01/2023 Status : Completed							
147	23010353	B.ED COLLEGE	GENTS TOILET BLOCKED IN GROUND FLOOR-NEED SCAVENGER	Sakthivel. E.,Govindan. R.,Kathirvelu. K.	Block removed.		SRIMAN - Others	10/01/2023

College Name : SMVEC

Work Type : Complaint

Dept Name : Civil - Maintenance - Civil - Maintenance

Comp. Dt. : 13/06/2022

Status : Completed

148 22060448 VC HOUSE
NEED PLUMBING WORK AT
V C SIR HOUSE I FLOOR
NEED URGENT SERVICE

Sivaraja. M.

Pipe line dummy fixed.

PRAKASH - SMVEC

14/06/2022

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
College Name : SMVMCH Work Type : Complaint Dept Name : BIOCHEMISTRY - Civil - Maintenance Comp. Dt. : 16/12/2022 Status : Completed								
149	22120756	Biochemistry Lab-Hospital	RO WATER FILTER NEED TO BE CHANGE	Prakash. V.,Rajendran. R.,Ramkumar. R.	Carbon filter and sand filter changed, problem solved		Srinivasamurugan. V. - BIOCHEMISTRY	19/12/2022
Dept Name : BLOOD BANK - Civil - Maintenance Comp. Dt. : 20/10/2022 Status : Completed								
150	22100672	Blood Bank	NEEDED 2 MAN POWER	Pandiaraj. V.,Yuvaraj. M.,Murali. K.	Work completed.		Ganesh. V. - BLOOD BANK	21/10/2022
Dept Name : Canteen - Boys Hostel - Civil - Maintenance Comp. Dt. : 05/05/2022 Status : Completed								
151	22050141	Boys hostel P.H-III	IN ROOM NO.40 BATHROOM DRAINAGE BLOCK	Thanuzkodi. E.,Govindan. R.,Sakthivel. E.	block remor work		Sambasivam. K. - Canteen - Boys Hostel	05/05/2022
Comp. Dt. : 12/05/2022 Status : Completed								
152	22050413	Boys hostel Phase-II	4TH FLOOR COMMN REST ROOMBLOCK AND WASHBASIN ALSO BLOCK	Rajendhiran. V.,Thanuzkodi. E.,Govindan. R.	Wash basin and toilet block removed, work completed		Sambasivam. K. - Canteen - Boys Hostel	12/05/2022
Comp. Dt. : 14/05/2022 Status : Completed								
153	22050511	Boys hostel PH-I	ROOM NO 14 TOILET SEAT COVER TO BE CHANGED	Sellaveeran. M.	Seat cover changed.		Sambasivam. K. - Canteen - Boys Hostel	16/05/2022
Comp. Dt. : 04/08/2022 Status : Completed								
154	22080151	Boys hostel P.H-III	IN ROOMN NO.22,37,35 BATHROOM SHOWER PROBLEM	Udhaya Kumar. R.,Sellaveeran. M.,Anandharaj. M.	Healthb faucet 3nos. changed.		Sambasivam. K. - Canteen - Boys Hostel	18/08/2022
Comp. Dt. : 17/08/2022 Status : Completed								
155	22080515	Boys hostel P.H-III	IN ROOM NO.39 FLUISH NOT WORKING	Azhagar. N.	Flush tank rework.		Sambasivam. K. - Canteen - Boys Hostel	18/08/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
156	22080516	Boys hostel Phase-II	IN 3RD FLOOR COMMON TOILET URINAL BLOCK	Thanuzkodi. E	Urinal block removed.		Sambasivam. K. - Canteen - Boys Hostel	18/08/2022
Comp. Dt. : 18/08/2022 Status : Completed								
157	22080566	Boys hostel PH-I	IN ROOM NO.42 WASH BASIN DRAINAGE PIPE LEAKAGING PROBLEM	Anandharaj. M., Azhagar. N., Udhaya Kumar. R.	Wash basin drainage pipe line rework.		Sambasivam. K. - Canteen - Boys Hostel	22/08/2022
158	22080567	Boys hostel P.H-III	IN ROOM NO.23 MIXER TAP LEAKAGING PROBLEM IN BATHROOM	Anandharaj. M., Azhagar. N., Udhaya Kumar. R.	Mixer tap fixed.		Sambasivam. K. - Canteen - Boys Hostel	22/08/2022
159	22080592	Boys hostel PH-I	IN ROOM NO.28 BATHROOM SHOWER TAP PROBLEM	Anandharaj. M., Azhagar. N., Gopal. S.	Seat cover changed.		Sambasivam. K. - Canteen - Boys Hostel	22/08/2022
Comp. Dt. : 15/09/2022 Status : Completed								
160	22090589	BOYS HOSTEL - MIT	THIRD FLOOR COMMON BATHROOM BLOCK(MALE)	Sakthivel. E.	Block removed.		Sambasivam. K. - Canteen - Boys Hostel	19/09/2022
Comp. Dt. : 12/10/2022 Status : Completed								
161	22100347	Boys hostel	NEED TO CHECK HEATER - WATER LEAKAGE AT WASHING AREA	Prakash. V., Rajendran. R., Ramkumar. R.	Water heater hose connection work done.		Kesavaraj. P. - Canteen - Boys Hostel	12/10/2022
Comp. Dt. : 21/10/2022 Status : Completed								
162	22100738	Boys hostel P.H-III	IN ROOM NO.39 FLUSH NOT WORKING	Anandharaj. M., Azhagar. N., Sellaveeran. M.	Flush tank rework done.		Sambasivam. K. - Canteen - Boys Hostel	22/10/2022
Comp. Dt. : 27/10/2022 Status : Completed								
163	22100845	Mit boys hostel	REST ROOM BLOCK IN 3RD FLOOR	Sakthivel. E., Govindan. R., Thanuzkodi. E	Toilet block removed, work completed		Sambasivam. K. - Canteen - Boys Hostel	27/10/2022
164	22100866	Boys hostel P.H-III	IN ROOM NO.38 MIXER VALVE TAP WATER NOT COMING	Prakash. V., Rajendran. R., Sankar. V.	Wall mixer tap rework and refixed in properly, problem solved		Sambasivam. K. - Canteen - Boys Hostel	31/10/2022
Comp. Dt. : 31/10/2022 Status : Completed								
165	22101012	BOYS HOSTEL-DINING HALL	DRAINAGE BLOCK	Sakthivel. E.	Block removed.		Sambasivam. K. - Canteen - Boys Hostel	02/11/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
166	22101015	Boys hostel Phase-II	COMMON BATHROOM 2NOS-SHOWER NOT WORKING	Prakash. V.	Shower fixed at common toilet.		Sambasivam. K. - Canteen - Boys Hostel	15/11/2022
167	22101024	Boys hostel	KITCHIN WASHING AREA HOT WATER PIPE LINE DAMAGE.	Prakash. V.,Ramkumar. R.,Rajendran. R.	1/2" GI Pipe nipple and valve changed, work completed		Kesavaraj. P. - Canteen - Boys Hostel	15/11/2022
Comp. Dt. : 02/11/2022 Status : Completed								
168	22110032	Mit boys hostel	IN GROUND FLOOR-URINAL BLOCK,NEED SCAVENGER	Sakthivel. E.,Govindan. R.,Thanuzkodi. E	Block removed.		Sambasivam. K. - Canteen - Boys Hostel	03/11/2022
Comp. Dt. : 05/11/2022 Status : Completed								
169	22110180	Boys hostel PH-I	IN ROOM NO.19 SHOWER TAP REPAIR WORK AND ROOM NO.8 FLUSH NOT WORKING	Prakash. V.,Sankar. V.,Udhaya Kumar. R.	Float washer changed.		Sambasivam. K. - Canteen - Boys Hostel	10/11/2022
Comp. Dt. : 07/11/2022 Status : Completed								
170	22110208	Boys hostel	KITCHEN PIPE WATER LEAKEAGE	Prakash. V.,Ramkumar. R.,Rajendran. R.	1/2" GI Pipe nipple and valve changed, work completed		Anand. G. - Transport	15/11/2022
171	22110242	Boys hostel PH-I	IN ROOM NO.30 SHOWER TAP REPAIR WORK	Prakash. V.,Anandharaj. M.,Azhagar. N.	Shower tap rework done.		Sambasivam. K. - Canteen - Boys Hostel	10/11/2022
172	22110243	Boys hostel PH-I	IN ROOM NO.33 HAND SHOWER WATER LEAKAGING PROBLEM	Prakash. V.	Hand shower changed.		Sambasivam. K. - Canteen - Boys Hostel	10/11/2022
173	22110244	Boys hostel PH-I	IN ROOM NO.41 EWC SEAT COVER NEED TO BE CHNAGE	Prakash. V.,Sankar. V.,Azhagar. N.	EWC seat cover changed.		Sambasivam. K. - Canteen - Boys Hostel	10/11/2022
174	22110245	Boys hostel PH-I	IN ROOM NO.39 WASH BASIN SINK TAP REPAIR WORK	Prakash. V.,Anandharaj. M.,Azhagar. N.	Pillar cock changed.		Sambasivam. K. - Canteen - Boys Hostel	10/11/2022
175	22110246	Boys hostel PH-I	IN ROOM NO.39 FLUSH TANK REPAIR WORK	Prakash. V.,Anandharaj. M.,Azhagar. N.	Flush tank rework done.		Sambasivam. K. - Canteen - Boys Hostel	10/11/2022
176	22110247	Boys hostel PH-I	IN ROOM NO.41-SHOWER TAP REPAIR WORK	Prakash. V.,Sankar. V.,Anandharaj. M.	New PVC Shower changed, problem solved		Sambasivam. K. - Canteen - Boys Hostel	15/11/2022
Comp. Dt. : 08/11/2022 Status : Completed								
177	22110308	Boys hostel PH-I	FLUSH TANK WATER LEAKAGE IN ROOM NO. 39	Prakash. V.,Rajendran. R.,Ramkumar. R.	Flush tank washer changed and serviced, problem solved		Sambasivam. K. - Canteen - Boys Hostel	15/11/2022
178	22110309	Boys hostel PH-I	FLUSH TANK NOT WORKING ROOM NO.48	Prakash. V.,Ramkumar. R.,Rajendran. R.	Flush tank fullset rework, new PVC shower changed, problem solved		Sambasivam. K. - Canteen - Boys Hostel	15/11/2022

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHAL KUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 10/11/2022 Status : Completed								
179	22110423	BOY HOSTEL MESS	HOT WATER LINE USING FOR MESS IS NOT WORKING	Prakash. V.,Ramkumar. R.,Rajendran. R.	1/2" GI Pipe nipple and valve changed, work completed		Elumalai. M. - Canteen - Boys Hostel	15/11/2022
Comp. Dt. : 14/11/2022 Status : Completed								
180	22110489	MEDICAL COLLEGE -- -BOYS HOSTEL	WATER BLOCK IN KITCHEN	Sakthivel. E.	Block removed.		Mathubalan. M. - Canteen - Boys Hostel	15/11/2022
Comp. Dt. : 15/11/2022 Status : Completed								
181	22110613	Boys hostel PH-I	FLUSH NOT WORKING	Udhaya Kumar. R.	Flush tank rework done.		Sambasivam. K. - Canteen - Boys Hostel	16/11/2022
Comp. Dt. : 16/11/2022 Status : Completed								
182	22110664	Boys hostel P.H-III	IN ROOM NO.39 FLUSH TANK NOT WORKING	Prakash. V.	Flush tank rework done.		Sambasivam. K. - Canteen - Boys Hostel	17/11/2022
Comp. Dt. : 21/11/2022 Status : Completed								
183	22110856	Boys hostel PH-I	IN ROOM NO.8-FLUSH NOT WORKING	Arunagiri. V.	Flush tank rework.		Sambasivam. K. - Canteen - Boys Hostel	23/11/2022
Comp. Dt. : 22/11/2022 Status : Completed								
184	22110916	Mit boys hostel	URINAL BLOCK AT GROUND & IST FLOOR	Sakthivel. E.	block removed.		Sambasivam. K. - Canteen - Boys Hostel	22/11/2022
Comp. Dt. : 03/12/2022 Status : Completed								
185	22120120	Boys hostel PH-I	SHOWER NOT WORKING IN ROOM NO. 43	Prakash. V.	Shower rework done.		Sambasivam. K. - Canteen - Boys Hostel	06/12/2022
Comp. Dt. : 05/12/2022 Status : Completed								
186	22120177	Kitchen - Boys Hostel	IN VESSEL WASHING AREA-HOT WATER NOT COMING	Prakash. V.	Tap rework done.		Elumalai. M. - Canteen - Boys Hostel	12/12/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 06/12/2022 Status : Completed								
187	22120243	Boys hostel Phase-II	IN ROOM NO.56-TERMITE FORMED ON WALL	Kannan. V.	Termite chemical sprayed		Sambasivam. K. - Canteen - Boys Hostel	08/12/2022
Comp. Dt. : 14/12/2022 Status : Completed								
188	22120648	Mit boys hostel	COMMON RESTROOM BLOCK	Sakthivel. E.	block removed.		Sambasivam. K. - Canteen - Boys Hostel	14/12/2022
Comp. Dt. : 20/12/2022 Status : Completed								
189	22120935	Boys hostel PH-I	ROOM NO 8 WASH BASIN ANGLE BROKEN	Prakash. V.,Sankar. V.,Rajendran. R.	Wash basin clamp fixed.		Sambasivam. K. - Canteen - Boys Hostel	21/12/2022
Comp. Dt. : 21/12/2022 Status : Completed								
190	22120957	Mit boys hostel	CHAMBER BLOCK	Sakthivel. E.	Block removed.		Sambasivam. K. - Canteen - Boys Hostel	21/12/2022
Comp. Dt. : 26/12/2022 Status : Completed								
191	22121186	Boys hostel P.H-III	TAP WATER SLOW IN ROOM NO 35	Prakash. V.,Sankar. V.,Anandharaj. M.	metro Spindle changed		Sambasivam. K. - Canteen - Boys Hostel	28/12/2022
192	22121187	Boys hostel PH-I	WASH BASIN WATER SLOW IN ROOM NO 12	Gopal. S.	Wash basin tap rework done.		Sambasivam. K. - Canteen - Boys Hostel	06/01/2023
Comp. Dt. : 27/12/2022 Status : Completed								
193	22121237	Boys hostel PH-I	IN ROPOM NO.10-FLUSH TANK REPAIR WORK	Prakash. V.,Sankar. V.,Anandharaj. M.	Flush tank rework. Health faucet changed		Sambasivam. K. - Canteen - Boys Hostel	28/12/2022
194	22121238	Boys hostel Phase-II	IN 4TH FLOOR COMMON TOILET-SHOWER VALVE REPAIR WORK NEED TO DO	Prakash. V.,Sankar. V.,Rajendran. R.	Shower Valve changed.		Sambasivam. K. - Canteen - Boys Hostel	28/12/2022
Comp. Dt. : 07/01/2023 Status : Completed								
195	23010319	Boys hostel PH-I	IN ROOM NO.27-SHOWER TAP VALVE LOOSE CONNECTION	Sivaraja. M.,Santhosh Kumar. M.,Sankar. V.	PVC shower changed.		Sambasivam. K. - Canteen - Boys Hostel	23/01/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 10/01/2023 Status : Completed								
196	23010388	Mit boys hostel	BYSIDE-SEPTIC TANK OVERFLOW	Sakthivel. E.,Govindan. R.,Kathirvelu. K.	Chamber block removed.		Sambasivam. K. - Canteen - Boys Hostel	11/01/2023
Comp. Dt. : 11/01/2023 Status : Completed								
197	23010439	Boys hostel Phase-II	IN 4TH FLOOR -COMMON TOILET URINAL BLOCK	Sakthivel. E.,Govindan. R.,Kathirvelu. K.	block removed.		Sambasivam. K. - Canteen - Boys Hostel	12/01/2023
198	23010440	Boys hostel P.H-III	IN ROOM NO.9-WASH BASIN SINK TAP REPAIR WORK	Sivaraja. M.	Mixer tap rework done.		Sambasivam. K. - Canteen - Boys Hostel	14/01/2023
199	23010491	BOYS HOSTEL-DINING HALL	WATER COOLER WATER LEAKAGING PROBLEM	Sivaraja. M.,Santhosh Kumar. M.,Sankar. V.	Pipeline rework done.		Sambasivam. K. - Canteen - Boys Hostel	20/01/2023
Comp. Dt. : 12/01/2023 Status : Completed								
200	23010531	Boys hostel Phase-II	IN 3RD FLOOR COMMON TOILET BLOCK	Govindan. R.,Sakthivel. E.,Kathirvelu. K.	block removed.		Sambasivam. K. - Canteen - Boys Hostel	12/01/2023
Comp. Dt. : 21/03/2023 Status : Completed								
201	23030844	Boys hostel P.H-III	NEED TO CHANGE HEALTH FAUCET AT ROOM NO.11.	Ramkumar. R.	HEALTH FAUCET CHANGED.		Sambasivam. K. - Canteen - Boys Hostel	22/03/2023
Comp. Dt. : 28/03/2023 Status : Completed								
202	23031177	Boys hostel PH-I	NEED TO CHANGE FLUSH TANK BROKEN - ROOM NO 21	Prakash. V.,Rajendran. R.,Ramkumar. R.	NEW CLAMP FIXED.		Sambasivam. K. - Canteen - Boys Hostel	30/03/2023
Comp. Dt. : 15/06/2023 Status : Completed								
203	23060547	Boys hostel P.H-III	ROOM NO-21,WASHBASIN BLOCK	Sivaraja. M.,Sellaveeran. M.,Santhosh Kumar. M.	WASH BASIN BLOCK REMOVED.		Sambasivam. K. - Canteen - Boys Hostel	16/06/2023
Comp. Dt. : 16/06/2023 Status : Completed								
204	23060593	Boys hostel PH-I	ROOM NO-8,SHOWER NOT WORKING	Sivaraja. M.,Santhosh Kumar. M.,Gopal. S.	Shower fixed.		Sambasivam. K. - Canteen - Boys Hostel	19/06/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Dept Name : Canteen - Hospital - Civil - Maintenance Comp. Dt. : 16/03/2023 Status : Completed								
205	23030663	DIET DEPARMENT	SHIFTING WORK FROM 5 TH FLOOR TO 6 TH FLOOR NEED 4 LABOURS	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	SHIFTING WORK COMPLETED.		Suriyaprakash. R. J. - Canteen - Hospital	17/03/2023
Comp. Dt. : 18/04/2023 Status : Completed								
206	23040543	DIET DEPARMENT	NEED 5 LABOUR SHIFTING WORK	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	Rice bags shifting work completed		Suriyaprakash. R. J. - Canteen - Hospital	19/04/2023
Dept Name : Canteen-Girls Hostel - Civil - Maintenance Comp. Dt. : 12/05/2022 Status : Completed								
207	22050404	Ladies hostel Phase-I	(3045)MESS WASHING AREA ONE TAP PROBLEM	Sellaveeran. M.,Udhaya Kumar. R.,Gopal. S.	3/4" PVC Elbow and tap changed, problem solved		Revathy. N. - Canteen-Girls Hostel	12/05/2022
208	22050410	J.R Quateres	CENTRE WASHING AREA WATER BLOCK	Rajendhiran. V.,Thanuzkodi. E.,Govindan. R.	Washing area block removed, work completed		Virgin Mary - Canteen-Girls Hostel	12/05/2022
Comp. Dt. : 13/05/2022 Status : Completed								
209	22050466	Ladies hostel Phase-II	IN 1ST FLOOR-ROOM NO.38 COT SHIFTING WORK -NEED MANPOWER FOR SHIFTING PURPOSE	Senthil Kumar. R.,Yuvaraj. M.,Pandiaraj. V.	Cot shifting work completed		Malliga. K. - Canteen-Girls Hostel	25/05/2022
210	22050468	Ladies hostel Phase-II	IN 1ST FLOOR-COMMON BATHROOM SHOWER TAP LEAKAGING PROBLEM	Udhaya Kumar. R.	Shower tap rework.		Malliga. K. - Canteen-Girls Hostel	18/05/2022
Comp. Dt. : 25/05/2022 Status : Completed								
211	22050936	Ladies hostel Phase-I	NEED TO CHECK HAND SHOWER - WATER LEAKAGE AT ROOM NO 21	Sivaraja. M.,Udhaya Kumar. R.,Sellaveeran. M.	Old CP health faucet set 1No changed, problem solved		Revathy. N. - Canteen-Girls Hostel	25/05/2022
Comp. Dt. : 10/06/2022 Status : Completed								
212	22060368	JR Quarters	(3042) GROUND FLOOR BATHROOM TAP BROKEN.WATER LEAKAGE	Udhaya Kumar. R.,Azhagar. N.,Anandharaj. M.	New water tap fixed.		Virgin Mary - Canteen-Girls Hostel	13/06/2022
Comp. Dt. : 17/08/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
213	22080508	Ladies hostel Phase-I	IN ROOM NO.18 BATHROOM BLOCK,NEED SCAVENGER	Thanuzkodi. E	Block removed.		Revathy. N. - Canteen-Girls Hostel	18/08/2022
	Comp. Dt. : 19/08/2022							
	Status : Completed							
214	22080629	Hostel - Girls-II Phase	NEED TO CHANGE TAP IN 2ND FLOOR RESTROOM	Anandharaj. M.	Tap changed.		Malliga. K. - Canteen-Girls Hostel	23/08/2022
	Comp. Dt. : 15/09/2022							
	Status : Completed							
215	22090596	Ladies hostel Phase-II	FOURTH FLOOR JR ROOM FLUSH NOT WORKING	Anandharaj. M.	Flush tank fullset rework, tap fixed, problem solved		Malliga. K. - Canteen-Girls Hostel	16/09/2022
	Comp. Dt. : 06/10/2022							
	Status : Completed							
216	22100094	JR Quarters	WATER NOT COMING IN GROUND FLOOR WASH BASIN	Anandharaj. M.,Azhagar. N.,Udhaya Kumar. R.	New connection tube changed.		Virgin Mary - Canteen-Girls Hostel	07/10/2022
	Comp. Dt. : 12/10/2022							
	Status : Completed							
217	22100346	Ladies hostel Phase-II	NEED TO REFIX TAP-WATER LEAKAGE AND DAMAGE AT I,II FLOOR REST ROOM	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	All floor common rest room were checked. Tap rework done.		Malliga. K. - Canteen-Girls Hostel	13/10/2022
218	22100350	JR Quarters	NEED TO REMOVE BEE NEST AT ROOM NO 40	Sivaraja. M.	No honey comb is there. Wasp is just entering inside the room.		Virgin Mary - Canteen-Girls Hostel	17/10/2022
	Comp. Dt. : 31/10/2022							
	Status : Completed							
219	22100993	JR Quarters	ONE DOG DIED IN BASEMENT.CLEAR IT	Sakthivel. E.	Dog destroyed, work completed		Virgin Mary - Canteen-Girls Hostel	31/10/2022
	Comp. Dt. : 02/11/2022							
	Status : Completed							
220	22110016	Ladies hostel Phase-II	IN 1ST FLOOR-BATHROOM /WASH BASIN SINK BLOCK ,NEED SCAVENGER	Sakthivel. E.	Block removed.		Malliga. K. - Canteen-Girls Hostel	03/11/2022
	Comp. Dt. : 03/11/2022							
	Status : Completed							
221	22110077	Ladies hostel Phase-I	IN ALL ROOMS-WATER HEATER TAP WATER POURING SLOWLY	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	All floor water heater rework. Block out.		Revathy. N. - Canteen-Girls Hostel	08/11/2022
	Comp. Dt. : 07/11/2022							
	Status : Completed							


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
222	22110190	J.R Quateres	WASH BASIN TAP WATER LEAKAGE	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	Wash basin pillar cork changed.		Virgin Mary - Canteen-Girls Hostel	10/11/2022
Comp. Dt. : 08/11/2022 Status : Completed								
223	22110301	Ladies hostel Phase-II	1ST FLOOR SHOWER TAP WATER LEAKAGE	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	Shower cleaned and serviced, refixed in properly, work completed		Malliga. K. - Canteen-Girls Hostel	16/11/2022
Comp. Dt. : 09/11/2022 Status : Completed								
224	22110352	Ladies hostel Phase-I	IN BOLCONY AREA-UNWANTED GRASS NEED TO BE CLEAN	Pandiaraj. V.	Grass removed.		Revathy. N. - Canteen-Girls Hostel	15/11/2022
Comp. Dt. : 10/11/2022 Status : Completed								
225	22110430	Ladies hostel Phase-I	IN 2ND FLOOR COMMON TOILET-FLUSH NOT WORKING	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	Flush tank rework done,.		Malliga. K. - Canteen-Girls Hostel	14/11/2022
Comp. Dt. : 14/11/2022 Status : Completed								
226	22110512	Ladies hostel Phase-II	IN ROOM NO.99(4TH FLOOR)-WALL CEILING WATER LEAKAGING PROBLEM	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	Due to heavy rain ceiling water seepage problem, now dry the wall		Revathy. N. - Canteen-Girls Hostel	16/11/2022
227	22110519	J.R Quateres	IN GROUND FLOOR-TOILET BLOCK,NEED SCAVENGER	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	Block removed.		Virgin Mary - Canteen-Girls Hostel	15/11/2022
Comp. Dt. : 16/11/2022 Status : Completed								
228	22110648	Ladies hostel Phase-I	IN 1ST FLOOR-HEATER AREA -WASTAGE WATER BLOCK	Govindan. R.	Heater area block removed, work completed		Revathy. N. - Canteen-Girls Hostel	16/11/2022
229	22110656	J.R Quateres	IN 1ST FLOOR-COMMON TOILET-WATER TAP LEAKAGING IN 2ND ROOM	Sellaveeran. M.	New PVC long body tap 1No, short body tap 1No changed, problem solved		Virgin Mary - Canteen-Girls Hostel	16/11/2022
230	22110662	J.R Quateres	IN 3RD FLOOR-COMMON BATHROOM LEFT SIDE-TOILET BLOCKED,NEED SCAVENGER	Govindan. R.	Toilet block removed, work completed		Virgin Mary - Canteen-Girls Hostel	16/11/2022
Comp. Dt. : 23/11/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
231	22111019	Ladies hostel Phase-I	KITCHEN WATER TANK OUTLET PIPE DAMAGED	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	2" UPVC Tee, 2X1.1/2 bush, coupling changed, pipe line fully rework, work completed		Revathy. N. - Canteen-Girls Hostel	01/12/2022
Comp. Dt. : 03/12/2022 Status : Completed								
232	22120128	Ladies hostel Phase-I	WATER NOT COMING IN ROOM NO. 66, 67	Anandharaj. M.	Pipe line direct connection given. Concealed cork removed.		Revathy. N. - Canteen-Girls Hostel	06/12/2022
233	22120133	Ladies hostel Phase-II	GROUND FLOOR REST ROOM TAP LEAKAGE	Anandharaj. M.,Sellaveeran. M.,Udhaya Kumar. R.	tap changed.		Malliga. K. - Canteen-Girls Hostel	06/12/2022
Comp. Dt. : 05/12/2022 Status : Completed								
234	22120203	Ladies hostel Phase-I	IN ROOM NO.75-HAND SHOWER PROBLEM	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	Hand shower rework done.		Revathy. N. - Canteen-Girls Hostel	16/12/2022
Comp. Dt. : 12/12/2022 Status : Completed								
235	22120516	J.R Quateres	1 ST FLOOR COMMON TOILET BLOCKED, NEED SCAVENGER	Thanuzkodi. E.,Govindan. R.,Murugan. S.	block removed.		Virgin Mary - Canteen-Girls Hostel	14/12/2022
Comp. Dt. : 20/12/2022 Status : Completed								
236	22120896	Ladies hostel Phase-I	NEED LABOURS FOR BERO SHIFTING WORK (2 NOS)	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	shifting work completed.		Revathy. N. - Canteen-Girls Hostel	21/12/2022
Comp. Dt. : 21/12/2022 Status : Completed								
237	22120961*	Ladies hostel Phase-I	WATER NOT COMING IN FOURTH FLOOR	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	Pipe line changing work completed.		Revathy. N. - Canteen-Girls Hostel	07/01/2023
Comp. Dt. : 22/12/2022 Status : Completed								
238	22120997	J.R Quateres	GROUND FLOOR REST ROOM BLOCK	Sakthivel. E.,Govindan. R.,Murugan. S.	Block removed.		Virgin Mary - Canteen-Girls Hostel	23/12/2022
239	22120998	J.R Quateres	HEATER WATER LEAKAGE IN GROUND FLOOR REST ROOM	Sellaveeran. M.	Electrical dept complaint, inform to electrical dept		Virgin Mary - Canteen-Girls Hostel	23/12/2022
240	22121032	J.R Quateres	GROUND FLOOR REST ROOM FLUSH NOT WORKING	Sellaveeran. M.,Santhosh Kumar. M.,Gopal. S.	Flush tank fullset rework and washer changed, problem solved		Virgin Mary - Canteen-Girls Hostel	23/12/2022


Dr. KAGNE. R.N.
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 24/12/2022 Status : Completed								
241	22121111	Ladies hostel Phase-II	GROUND FLOOR REST ROOM TAP WATER LEAKAGE	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	Tap rework done		Malliga. K. - Canteen-Girls Hostel	24/12/2022
Comp. Dt. : 26/12/2022 Status : Completed								
242	22121164	J.R Quateres	TAP NOT WORKING IN 3RD FLOOR REST ROOM	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	Tap rework done		Virgin Mary - Canteen-Girls Hostel	28/12/2022
Comp. Dt. : 27/12/2022 Status : Completed								
243	22121201	J.R Quateres	IN GROUND FLOOR-COMMON BATHROOM-WESTERN TOILET PIPE BROKEN	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	new tap fixed.		Virgin Mary - Canteen-Girls Hostel	28/12/2022
Comp. Dt. : 02/01/2023 Status : Completed								
244	23010015	J.R Quateres	WATER COOLER TAP NEED TO BE CHANGE	Sellaveeran. M.	Tap changed.		Virgin Mary - Canteen-Girls Hostel	07/01/2023
245	23010034	Ladies hostel Phase-II	IN 1ST FLOOR-COMMON BATHROOM BLOCK,NEED SCAVENGER	Sakthivel. E.,Govindan. R.,Kathirvelu. K.	Block removed.		Virgin Mary - Canteen-Girls Hostel	05/01/2023
Comp. Dt. : 03/01/2023 Status : Completed								
246	23010067	JR Quarters	WARDEN REST ROOM BLOCK	Prakash. V.,Rajendran. R.,Ramkumar. R.	Block removed.		Virgin Mary - Canteen-Girls Hostel	05/01/2023
247	23010079	Ladies hostel Phase-II	IN 2ND FLOOR COMMON BATHROOM-WATER POURING SLOWLY FROM HEATER TAP	Prakash. V.,Rajendran. R.,Ramkumar. R.	Water heater tap rework done.		Malliga. K. - Canteen-Girls Hostel	05/01/2023
Comp. Dt. : 09/01/2023 Status : Completed								
248	23010354	Ladies hostel Phase-I	ROOM NO.9-IN BATHROOM WESTERN TOILET CONNECTION TUBE AND WASHER NEED TO BE CHANGE	Prakash. V.,Rajendran. R.,Ramkumar. R.	New Connection tube and Flush tank washer changed, problem solved		Revathy. N. - Canteen-Girls Hostel	12/01/2023
Comp. Dt. : 11/01/2023 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
249	23010443	J.R Quateres	IN 3RD FLOOR-COMMON BATHROOM-2 NO'S WATER TAP NEED TO BE CHANGE	Prakash. V.,Rajendran. R.,Ramkumar. R.	2Nos of New PVC tap changed, problem solved		Virgin Mary - Canteen-Girls Hostel	18/01/2023
		Comp. Dt. : 13/01/2023 Status : Completed						
250	23010552	J.R Quateres	BLOCK IN WASH BASIN (WARDEN ROOM)	Sakthivel. E.,Govindan. R.,Kathirvelu. K.	Block removed.		Virgin Mary - Canteen-Girls Hostel	14/01/2023
		Comp. Dt. : 27/01/2023 Status : Completed						
251	23010992	Ladies hostel Phase-I	IN ROOM NO.40-FLUSH TANK NOT WORKING	Prakash. V.,Rajendran. R.,Ramkumar. R.	flush tank rework done.		Revathy. N. - Canteen-Girls Hostel	31/01/2023
		Comp. Dt. : 08/02/2023 Status : Completed						
252	23020267	JR Quarters	GROUND FLOOR REST ROOM BLOCK	Sakthivel. E.	Toilet block removed, work completed		Virgin Mary - Canteen-Girls Hostel	08/02/2023
		Comp. Dt. : 09/02/2023 Status : Completed						
253	23020346	J.R Quateres	GROUND FLOOR REST ROOM BLOCK	Kathirvelu. K.,Sakthivel. E.,Govindan. R.	BLOCK REMOVED.		Virgin Mary - Canteen-Girls Hostel	10/02/2023
		Comp. Dt. : 15/02/2023 Status : Completed						
254	23020584	Ladies hostel Phase-II	3DR FLOOR WASHBASIN BLOCK	Sakthivel. E.,Govindan. R.,Kathirvelu. K.	BLOCK REMOVED.		Malliga. K. - Canteen-Girls Hostel	16/02/2023
		Comp. Dt. : 16/02/2023 Status : Completed						
255	23020628	Ladies hostel Phase-II	PORTICO PLANTS CUTTING WORK	Prakash. V.,Rajendran. R.,Ramkumar. R.	PLANTS CUTTING WORK DONE		Malliga. K. - Canteen-Girls Hostel	17/02/2023
		Comp. Dt. : 28/02/2023 Status : Completed						
256	23021076	Ladies hostel Phase-II	2ND FLOOR -ONE TAP BROKEN	Prakash. V.,Rajendran. R.,Ramkumar. R.	NEW TAP CHANGED.		Malliga. K. - Canteen-Girls Hostel	04/03/2023
257	23021086	Ladies hostel Phase-II	COMMON REST ROOM BLOCK	Sakthivel. E.	BLOCK REMOVED.		Malliga. K. - Canteen-Girls Hostel	01/03/2023
		Comp. Dt. : 20/03/2023 Status : Completed						


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
258	23030774	Ladies hostel Phase-II	NEED TO CHANGE TAP IN ROOM NO. 78	Prakash. V.,Rajendran. R.,Ramkumar. R.	TAP CHANGED.		Revathy. N. - Canteen-Girls Hostel	22/03/2023
Comp. Dt. : 13/05/2023 Status : Completed								
259	23050550	Ladies hostel Phase-II	NEED TO SPRAY " INSECT SPRAY " FOR III & IV FLOOR RESTROOM	Kannan. V.	INSECTICIDE SPRAYED.		Malliga. K. - Canteen-Girls Hostel	19/05/2023
Comp. Dt. : 15/06/2023 Status : Completed								
260	23060527	Ladies hostel Phase-II	ALL FLOOR VERANDA AND ALL FLOOR REST ROOM - -MOSQUITO CHEMICAL TO BE SPRAY	Govindan. R.	MOSQUITO REPELLANT SPRAYED IN ALL THE AREA		Malliga. K. - Canteen-Girls Hostel	17/06/2023
261	23060531	Ladies hostel Phase-I	(3045)-ROOM NO-7,WATER NOT COMING	Prakash. N.,Rajendran. R.,Ramkumar. R.	Water not in over head tank, motor switch on and fill the tank, problem solved		Revathy. N. - Canteen-Girls Hostel	22/06/2023
Comp. Dt. : 16/06/2023 Status : Completed								
262	23060587	Ladies hostel Phase-II	1ST FLOOR BATHROOM WATER BLOCK	Sakthivel. E.,Govindan. R.,Gnanasegaran. K.	BLOCK REMOVED.		Malliga. K. - Canteen-Girls Hostel	17/06/2023
263	23060589	JR Quarters	3RD FLOOE BATH ROOM BLOCK	Sakthivel. E.,Govindan. R.,Gnanasegaran. K.	BLOCK REMOVED.		Virgin Mary - Canteen-Girls Hostel	17/06/2023
Dept Name : Civil - Execution - Civil - Maintenance Comp. Dt. : 02/06/2022 Status : Completed								
264	22060077	ASSOCIATIVE PROFESSOR QUARTERS	Need 4 labours for clearing all the debris	Pandiaraj. V.,Yuvaraj. M.,Murali. K.	Debris cleaning work done.		Sasikala. P. - Civil - Execution	17/06/2022
Comp. Dt. : 13/10/2022 Status : Completed								
265	22100432	MIT College	Need to shift tables, AC, from robotics lab	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	Tables and A/C shifting work done.		Sasikala. P. - Civil - Execution	17/10/2022
Comp. Dt. : 04/01/2023 Status : Completed								
266	23010167	professor quarters	Need to recheck and change in all bathroom pipe lines at room no.9 & 10.	Prakash. V.,Rajendran. R.,Ramkumar. R.	2nos of bathroom pipe line fully checked, working condition good, no complaints		Sasikala. P. - Civil - Execution	12/01/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 14/03/2023 Status : Completed								
267	23030563	professor quarters	ROOM NO.6 - KITCHEN SINK TO BE CHANGED.	Prakash. V.,Rajendran. R.,Ramkumar. R.	KITCHEN SINK FIXED.		Sasikala. P. - Civil - Execution	22/03/2023
Dept Name : Civil - Maintenance - Civil - Maintenance Comp. Dt. : 08/11/2022 Status : Completed								
268	22110305	NEW STP	RAW WATER LINE (PVC) DAMAGE	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	PVC changed.		Ranganathan. K. - Civil - Maintenance	10/11/2022
Comp. Dt. : 21/12/2022 Status : Completed								
269	22120974	OLD STP PLANT	PIPE BROKEN - NEAR BOYS HOSTEL	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	Coupling changed, pipe line rework, problem solved		Murugan. T. - Civil - Maintenance	23/12/2022
Comp. Dt. : 05/01/2023 Status : Completed								
270	23010246	OLD STP PLANT	PIPE LINE MTA GOT DAMAGED	Prakash. V.,Rajendran. R.,Ramkumar. R.	4" motor inlet line work completed.		Jayaraman. M. - Civil - Maintenance	14/01/2023
Comp. Dt. : 06/01/2023 Status : Completed								
271	23010285	Ladies hostel Phase-I	REMOVE RING MAN PIPE	Prakash. V.,Rajendran. R.,Ramkumar. R.	Ring man pipe line removed.		Sankar. R - Civil - Maintenance	07/01/2023
Comp. Dt. : 30/01/2023 Status : Completed								
272	23011077	NEW STP	Need earth work and 3" pipe line connection.	Gopal. S.	3" running coupling fixed.		Ranganathan. K. - Civil - Maintenance	30/01/2023
Comp. Dt. : 07/02/2023 Status : Completed								
273	23020238	MIT MESS	WASH BASIN PIPE LINE BROKEN	Prakash. V.,Rajendran. R.,Ramkumar. R.	Wash basin water line rework, work completed		Kumar. V. - Civil - Maintenance	08/02/2023
Comp. Dt. : 10/02/2023 Status : Completed								
274	23020413	Boys hostel	NEED TO FIX STP LINE VALVE NEAR BOYS HOSTEL GARDEN	Prakash. V.,Rajendran. R.,Ramkumar. R.	STP LINE VALVE CHANGED.		Kumar. V. - Civil - Maintenance	17/02/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 31/05/2023 Status : Completed								
275	23051247	COMMERCIAL BLOCK	NEED TO CHANGE TAP AT GROUND FLOOR COMMERCIAL BLOCK	Anandharaj. M.	TAP CHANGED.		Gurunathan. V. - Civil - Maintenance	31/05/2023
Comp. Dt. : 20/06/2023 Status : Completed								
276	23060700	COMMERCIAL BLOCK	Water coming slowly in Ground floor canteen wash basin.	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	CP Angle valve fixed.		Vengatesan. V. - Civil - Maintenance	20/06/2023
Comp. Dt. : 22/06/2023 Status : Completed								
277	23060814	MIT MESS	BLOCK IN WASH BASIN DRAINAGE PIPELINE	Rajendhiran. V.,Thanuzkodi. E,Gnanasegaran. K.	Block removed		Murali. K. - Civil - Maintenance	23/06/2023
Dept Name : Clinical Department - Civil - Maintenance Comp. Dt. : 15/06/2023 Status : Completed								
278	23060539	CLINICAL DEPARTMENT IN 3RD FLOOR	RIGHT SIDE ROOM NO-4,WATER NOT COMING	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	VALVE LINE BLOCK REMOVED.		Selvi. A. - Clinical Department	16/06/2023
Dept Name : Director Office - Civil - Maintenance Comp. Dt. : 13/05/2022 Status : Completed								
279	22050478	A.P Quateres	IN ROOM NO.41 WATER TAP LEAKGING PROBLEM	Sellaveeran. M.	Water tap leakage arrest		Mani. A. - Director Office	20/05/2022
280	22050479	professor quarters	IN ROOM NO.1 WATER TAPM LEAKAGING PROBLEM	Gopal. S.	New tap changed.		Mani. A. - Director Office	14/05/2022
281	22050480	A.P Quateres	IN ROOM NO.24 WATER LEAKAGING FROM SIDE WALLS	Gopal. S.	Leak arrest. Problem rectified.		Mani. A. - Director Office	20/05/2022
Comp. Dt. : 14/05/2022 Status : Completed								
282	22050498	professor quarters	ROOM NO-4.WATER TAP PROBLEM	Arunagiri. V.,Anandharaj. M.,Azhagar. N.	New tap changed.		Mani. A. - Director Office	18/05/2022
Comp. Dt. : 04/08/2022 Status : Completed								
283	22080155	A.P Quateres	IN ROOM NO.49 WASHING AREA BLOCK	Govindan. R.	block removed.		Mani. A. - Director Office	09/08/2022

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 18/08/2022								
Status : Completed								
284	22080591	A.P Quateres	IN ROOM NO.42 KITCHEN TAP WATER LEAKAGING PROBLEM	Azhagar. N.,Anandharaj. M.,Sivaraja. M.	Tap rework done.		Mani. A. - Director Office	23/08/2022
Comp. Dt. : 19/08/2022								
Status : Completed								
285	22080638	A.P Quateres	IN ROOM NO.15 FLUSH NOT WORKING	Anandharaj. M.,Azhagar. N.,Gopal. S.	Flush tank rework.		Mani. A. - Director Office	22/08/2022
Comp. Dt. : 20/10/2022								
Status : Completed								
286	22100697	A.P Quateres	FLUSH TANK PROBLEM AT AP QUATERES 13	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	Flush tank rework done.		Mani. A. - Director Office	25/10/2022
Comp. Dt. : 28/10/2022								
Status : Completed								
287	22100905	A.P Quateres	IN ROOM NO.49 KITCHEN AREA BLOCK	Govindan. R.,Rajendhiran. V.,Murugan. S.	Block removed.		Mani. A. - Director Office	29/10/2022
288	22100935	A.P Quateres	IN ROOM NO.31 BATHROOM TAP AND CEAT COVER DAMAGED,NEED TO BE CHANGE	Santhosh Kumar. M.,Gopal. S.,Anandharaj. M.	Seat cover changed. PVC tap changed.		Mani. A. - Director Office	29/10/2022
Comp. Dt. : 31/10/2022								
Status : Completed								
289	22101030	A.P Quateres	BATHROOM TAP WATER LEAKAGE IN ROOM NO.7	Sellaveeran. M.,Udhaya Kumar. R.,Sivaraja. M.	Tap rework done.		Mani. A. - Director Office	08/11/2022
290	22101035	A.P Quateres	IN ROOM NOS,40 AND 28- -DERMIT PROBLEM	Kannan. V.	Termite spray sprayed at room no.28,40		Mani. A. - Director Office	08/11/2022
Comp. Dt. : 04/11/2022								
Status : Completed								
291	22110150	professor quarters	IN ROOM NO.2-EWC SHEET NEED TO BE CHANGE	Santhosh Kumar. M.,Gopal. S.,Anandharaj. M.	EWC seat cover changed.		Mani. A. - Director Office	08/11/2022
Comp. Dt. : 08/11/2022								
Status : Completed								
292	22110284	A.P Quateres	TAP WATER LEAKAGE IN ROOM 32	Anandharaj. M.	Room locked		Mani. A. - Director Office	08/11/2022
293	22110285	A.P Quateres	KITCHEN SINK LEAKAGE IN ROOM NO 51	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	Connection tube rework done.		Mani. A. - Director Office	08/11/2022

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 11/11/2022 Status : Completed								
294	22110486	Electrical Maintanance College	Needed 2 man power for shifting fire extinguisher	Prakash. N.	Fire extinguisher shifting work completed.		Prasanna.B. - Director Office	22/11/2022
Comp. Dt. : 16/11/2022 Status : Completed								
295	22110659	A.P Quateres	IN ROOM NO.28-TERMITE FORMING ON WALLS	Thanuzkodi. E	Termite chemical sprayed, problem solved		Mani. A. - Director Office	17/11/2022
Comp. Dt. : 21/11/2022 Status : Completed								
296	22110884	A.P Quateres	IN ROOM NO.18 -WATER HEATER FIIXING WORK NEED TO DO	Gopal. S.	Water heater fixed.		Mani. A. - Director Office	01/12/2022
Comp. Dt. : 25/11/2022 Status : Completed								
297	22111103	A.P Quateres	IN ROOM NO.15 AND 51-FLUSH TANK LINE LEAKAGING PROBLEM	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	2Nos of room - Flush tank fullset rework, washer changed, work completed		Mani. A. - Director Office	29/11/2022
298	22111104	A.P Quateres	IN ROOM NO.18-WATER HEATER FIXING WORK NEED TO DO	Anandharaj. M.,Azhagar. N.,Gopal. S.	Old water heater fixed, water line connection given work completed		Mani. A. - Director Office	01/12/2022
299	22111105	A.P Quateres	MAIN WATER PIPELINE LEAKAGING PROBLEM	Anandharaj. M.,Sellaveeran. M.,Udhaya Kumar. R.	motor changed, pipe line dummy fixed, problem solved		Mani. A. - Director Office	23/12/2022
Comp. Dt. : 26/11/2022 Status : Completed								
300	22111132	A.P Quateres	WASTAGE WATER PIPELINE BROKEN AT A.P QUARTERS BACKSIDE	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	Drainage line rework done.		Mani. A. - Director Office	16/12/2022
Comp. Dt. : 05/12/2022 Status : Completed								
301	22120198	ASSOCIATIVE PROFESSOR QUARTERS	IN ROOM NO.11-BALCONY FLOOR TILES AIR CRACK PLACES WATER LEAKAGING PROBLEM	Anandharaj. M.,Gopal. S.,Santhosh Kumar. M.	Civil Execution work.		Mani. A. - Director Office	16/12/2022
302	22120200	ASSOCIATIVE PROFESSOR QUARTERS	IN TERROUS -UNWANTED PLANTS NEED TO BE REMOVE	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	Unwanted plants removed.		Mani. A. - Director Office	09/12/2022
Comp. Dt. : 20/12/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
303	22120919	A.P Quateres	FLUSH TANK PROBLEM IN ROOM NO 15	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	Flush tank rework done.		Mani. A. - Director Office	20/12/2022
304	22120920	A.P Quateres	WASH BASIN PIPE LEAKAGE IN ROOM NO 23	Azhagar. N.,Udhaya Kumar. R.,Gopal. S.	Wash basin pipe line rework done.		Mani. A. - Director Office	20/12/2022
Comp. Dt. : 23/12/2022								
Status : Completed								
305	22121081	A.P Quateres	WASH BASIN TAP PROBLEM IN ROOM NO 36	Prakash. V.	Wash basin tap rework done.		Mani. A. - Director Office	24/12/2022
Comp. Dt. : 27/12/2022								
Status : Completed								
306	22121233	A.P Quateres	IN ROOM NO.45-EWC CEAT COVER DAMAGED AND TAP LEAKAGING PROBLEM	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	Seat cover, pillar cock, connection tube, angle valve changed.		Mani. A. - Director Office	28/12/2022
Comp. Dt. : 29/12/2022								
Status : Completed								
307	22121322	A.P Quateres	IN ROOM NO.10-FLUSH TANK NOT WORKING	Azhagar. N.	Flush tank fullset, EWC seat cover, angle cock, shower, 1.1/4" waste hose, connection tube 2Nos chan		Mani. A. - Director Office	02/01/2023
Comp. Dt. : 02/01/2023								
Status : Completed								
308	23010042	ASSOCIATIVE PROFESSOR QUARTERS	WASTAGE WATER PIPELINE LEAKAGING PROBLEM AT BACKSIDE	Prakash. V.,Rajendran. R.,Ramkumar. R.	Connectuion tube changed.		Mani. A. - Director Office	05/01/2023
309	23010043	A.P Quateres	IN ROOM NO.49-FLUSH TANK NOT WORKING	Prakash. V.,Abdul Azees. J.,Sankar. V.	Flush tank rework done.		Mani. A. - Director Office	07/01/2023
Comp. Dt. : 03/01/2023								
Status : Completed								
310	23010099	A.P Quateres	IN ROOM NO.49-FLUSH TANK PROBLEM	Prakash. V.,Rajendran. R.,Ramkumar. R.	Flush tank rework done.		Mani. A. - Director Office	05/01/2023
311	23010111	A.P Quateres	IN ROOM NO.43-EWC CEAT COVER GOT DAMAGED	Prakash. V.,Rajendran. R.,Ramkumar. R.	Seat cover changed.		Mani. A. - Director Office	05/01/2023
Comp. Dt. : 04/01/2023								
Status : Completed								
312	23010146	ASSOCIATIVE PROFESSOR QUARTERS	IN ROOM NO.4-WATER TAP LEAKAGING PROBLEM	Prakash. V.,Rajendran. R.,Ramkumar. R.	New Water heater pipe line fully changed, leakage arrested, work completed		Mani. A. - Director Office	18/01/2023

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHAL KUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
313	23010147	A.P Quateres	IN ROOM NO.43 WATER HETER PIPELINE FIXING WORK NEED TO DO	Prakash. V.,Rajendran. R.,Ramkumar. R.	New Water heater fixed, New Health faucet 2Nos changed, work completed		Mani. A. - Director Office	12/01/2023
Comp. Dt. : 10/01/2023 Status : Completed								
314	23010410	A.P Quateres	IN ROOM NO.13 WATER TAP AND FLOOR GRATING NEED TO BE CHANGE	Rajendran. R.,Ramkumar. R.,Arunagiri. V.	Flush tank leakage problem, washer changed, leakage arrested, grating refixed, problem solved		Mani. A. - Director Office	12/01/2023
Comp. Dt. : 09/02/2023 Status : Completed								
315	23020359	A.P Quateres	WASH BASIN TAP LEAKAGE IN ROOM NO. 43	Prakash. V.,Rajendran. R.,Ramkumar. R.	Wash basin tap spindle changed.		Mani. A. - Director Office	17/02/2023
316	23020360	A.P Quateres	DUCT SIDE PIPELINE LEAKAGE IN ROOM NO. 3	Prakash. V.,Rajendran. R.,Ramkumar. R.	TOILET INSIDE FLOOR TILES POINTING WORK DONE.		Mani. A. - Director Office	25/02/2023
Dept Name : ENT & Ophthal Ward - Civil - Maintenance Comp. Dt. : 18/04/2023 Status : Completed								
317	23040560	ENT WARD-407	WASH BASIN TAP WATER LEAKAGE	Sivaraja. M.,Santhosh Kumar. M.,Gopal. S.	New Tap changed, problem solved		Jayalakshmi. J. - ENT & Ophthal Ward	20/04/2023
Dept Name : Female Ortho Ward - Civil - Maintenance Comp. Dt. : 06/02/2023 Status : Completed								
318	23020198	Female Ortho - Ward 402	BLOCK IN SINK	Rajendhiran. V.,Thanuzkodi. E,Murugan. S.	BLOCK REMOVED		Dhansulakshmi. K. - Female Ortho Ward	07/02/2023
Dept Name : FORENSIC MEDICINE - Civil - Maintenance Comp. Dt. : 14/11/2022 Status : Completed								
319	22110528	professor quarters	IN ROOM NO.2 WASH BASIN SINK WATER LEAKAGING PROBLEM	Anandharaj. M.,Sellaveeran. M.,Sivaraja. M.	Waste water line changed, leakage arrested, problem solved		Mathavi. B. - FORENSIC MEDICINE	16/11/2022
Dept Name : Gas Power Plant - Civil - Maintenance Comp. Dt. : 15/11/2022 Status : Completed								
320	22110593	Gas Power Plant	NEED LABOURS FOR A4 SHEET BUNDLE SHIFTING WORK	Palanisamy. R.,Yuvaraj. M.,Thulasi. V.	A4 Paper bundle unloading and shifting work completed		Abi Mohan Ram.S. - Gas Power Plant	16/11/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 19/04/2023 Status : Completed								
321	23040614	PRESS	WATER PURIFIER NOT WORKING [BOTH HOT & COOL WATER NOT COMING]	Sivaraja. M.,Azhagar. N.,Udhaya Kumar. R.	BLOCK REMOVED.		Mahi Mohan Ram.S. - Gas Power Plant	22/04/2023
Dept Name : Guest House - Indian Bank - Civil - Maintenance Comp. Dt. : 18/08/2022 Status : Completed								
322	22080582	Guest House - Indian Bank	IN ROOM NO.205 REST ROOM-HEALTH FUCET WATER LEAKAGING PROBLEM	Prakash. V.,Rajendran. R.,Ramkumar. R.	Health faucet changed.		John. H. - Guest House - Indian Bank	30/08/2022
Comp. Dt. : 12/10/2022 Status : Completed								
323	22100331	Guest House - Indian Bank	ROOM NO 103, 203 WATER NOT COMING	Prakash. V.,Rajendran. R.,Ramkumar. R.	Air lock released. Flush tank rework done. 203, diverter rework done.		John. H. - Guest House - Indian Bank	13/10/2022
Comp. Dt. : 21/10/2022 Status : Completed								
324	22100718	Guest House - Indian Bank	REQUEST TO CHECK PLUMBING ISSUES IN ALL ROOMS	Prakash. V.,Rajendran. R.,Ramkumar. R.	All complaints done.		John. H. - Guest House - Indian Bank	22/10/2022
325	22100728	Guest House - Indian Bank	REQUEST TO CLEAN WATER TANK	Raja. V.	Tank cleaning work competed		John. H. - Guest House - Indian Bank	26/10/2022
Comp. Dt. : 27/10/2022 Status : Completed								
326	22100860	Guest House - Indian Bank	IN ALL 12 ROOMS -WASH BASIN SINK BLOCK	Ramkumar. R.	Sink Block removed.		John. H. - Guest House - Indian Bank	28/10/2022
Comp. Dt. : 17/11/2022 Status : Completed								
327	22110729	Guest House - Indian Bank	IN ROOM NO.202 WASH BASIN SINK BLOCK	Prakash. V.	Block removed.		John. H. - Guest House - Indian Bank	21/11/2022
328	22110730	Guest House - Indian Bank	IN ROOM NO.104 AND 201-HEALTH FUCET NEED TO BE CHANGE	Prakash. V.	Health faucet fixed.		John. H. - Guest House - Indian Bank	14/12/2022
329	22110731	Guest House - Indian Bank	IN ROOM NO.201-TOILET PLATE NEED TO BE CHANGE	Prakash. V.	Plumbing work completed.		John. H. - Guest House - Indian Bank	14/12/2022
Comp. Dt. : 26/12/2022 Status : Completed								
330	22121145	Guest House - Indian Bank	HEALTH FACE SET CHANGE IN ROOM NO 102	Prakash. V.	New CP health faucet changed, problem solved		John. H. - Guest House - Indian Bank	27/12/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 09/02/2023 Status : Completed								
331	23020344	Guest House - Indian Bank	ALL ROOM SINK BLOCK	Rajendhiran. V.,Thanuzkodi. E.,Murugan. S.	BLOCK REMOVED.		John. H. - Guest House - Indian Bank	11/02/2023
Comp. Dt. : 22/02/2023 Status : Completed								
332	23020869*	Guest House - Indian Bank	ROOM NO-205,TILES BROKEN AND 204,WASH BASIN BROKEN 2NOS.NEED TO REPLACE.AND 204,FLUSH TANK SET NEED	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	Wash basin fittings, Flush tank set changed, Tiles changed, work completed in all rooms		John. H. - Guest House - Indian Bank	06/04/2023
Dept Name : Gynac Ward - Civil - Maintenance Comp. Dt. : 11/05/2022 Status : Completed								
333	22050402	Gynac Ward	RESTROOM BLOCK IN 207 AND 208 WARD	Thanuzkodi. E.,Rajendran. R.,Govindan. R.	block removed in both the ward.		Sagunthaladevi. S. - Gynac Ward	12/05/2022
Dept Name : Hospital Infection Control - Civil - Maintenance Comp. Dt. : 28/12/2022 Status : Completed								
334	22121260	Male Ortho - Ward 404	water leaking	Prakash. V.,Rajendran. R.,Ramkumar. R.	Expansion joint problem. Sealant to be applied by civil execution department.		Mohana. M. - Hospital Infection Control	30/12/2022
Dept Name : Housekeeping - Civil - Maintenance Comp. Dt. : 18/08/2022 Status : Completed								
335	22080606	TEMPLATE AREA	DRAINAGE PIPE REMOVING WORK	Prakash. V.,Rajendran. R.,Ramkumar. R.	Waste hose changed.		Elangchezhiyan. R. - Housekeeping	30/08/2022
Comp. Dt. : 13/12/2022 Status : Completed								
336	22120594	OG-OPD	NEED TO CHANGE TAP - WATER LEAKAGE AT OG OPG OUTSIDE TAP	Prakash. V.	Tap rework done.		Elangchezhiyan. R. - Housekeeping	17/12/2022
Comp. Dt. : 10/05/2023 Status : Completed								
337	23050403	PATHOLOGY	ROOM NO 406 BATHROOM BLOCK	Sakthivel. E.	BLOCK REMOVED.		Elangchezhiyan. R. - Housekeeping	11/05/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Dept Name : ICCU - Civil - Maintenance Comp. Dt. : 10/01/2023 Status : Completed								
338	23010429	Mit ladies hostel	IN 2ND AND 3RD FLOOR-TOILET BLOCKED,NEED SCAVENGER	Sakthivel. E.,Govindan. R.,Kathirvelu. K.	block removed.		Ammu. R. - ICCU	11/01/2023
Dept Name : Library - Civil - Maintenance Comp. Dt. : 08/02/2023 Status : Completed								
339	23020298	medical college library 2nd floor	SCREEN FIXING WORK	Prakash. V.,Yuvaraj. M.,Senthil Kumar. R.	SCREEN FIXING WORK COMPLETED.		Elangovan.N. - Library	11/02/2023
Dept Name : Male Medical Ward - Civil - Maintenance Comp. Dt. : 20/02/2023 Status : Completed								
340	23020755	Male Medical - Ward 302	BLOCK IN RESTROOM	Rajendhiran. V.,Thanuzkodi. E.,Murugan. S.	BLOCK REMOVED.		Ramya. D. - Male Medical Ward	21/02/2023
Dept Name : Male Ortho Ward - Civil - Maintenance Comp. Dt. : 17/09/2022 Status : Completed								
341	22090678	Male Ortho - Ward 403	bathroom blocked (403,404)	Rajendhiran. V.,Sakthivel. E.,Murugan. S.	Ward 403, 404 - Toilet block removed, work completed		Rajasree. R. - Male Ortho Ward	17/09/2022
Comp. Dt. : 09/11/2022 Status : Completed								
342	22110349	Male Ortho - Ward 404	FLUSH TANK WATER LEAKAGING PROBLEM	Prakash. V.,Rajendran. R.,Ramkumar. R.	Flush tank fullset repaired and serviced, problem solved		Rajasree. R. - Male Ortho Ward	15/11/2022
Dept Name : Male Surgery - Civil - Maintenance Comp. Dt. : 16/03/2023 Status : Completed								
343	23030661	Male Surgery - Ward 201	BATHROOM TAP LEAKAGE AND HEATER CONTROL TAP NEED TO BE TIGHTENED	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	CP BIB COCK CHANGED.		Kanimozhi. N - Male Surgery	16/03/2023
Comp. Dt. : 26/05/2023 Status : Completed								
344	23051043	Female Surgery - Ward 206	NEED TO REFIX WASH BASIN	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	Wash basin refixed, tap rework, work completed		Raveena. K. - Male Surgery	30/05/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Dept Name : Marketing Team - Civil - Maintenance Comp. Dt. : 20/10/2022 Status : Completed								
345	22100663	SPECIAL WARD - A1	SINK BLOCKED IN ROOM NO 7	Rajendhiran. V.,Murugan. S.,Thanuzkodi. E	BLOCK REMOVED.		Shameena Begum. A. - Marketing Team	21/10/2022
Dept Name : Nephrology - Civil - Maintenance Comp. Dt. : 18/04/2023 Status : Completed								
346	23040569	DIALYSIS IN 2ND FLOOR	drainage smell coming clear it	Rajendhiran. V.,Thanuzkodi. E,Murugan. S.	Toilet block removed, work completed		Suganya. B. - Nephrology	20/04/2023
Dept Name : Nursing Office - Civil - Maintenance Comp. Dt. : 20/10/2022 Status : Completed								
347	22100670	CLINICAL DEPARTMENT IN 4th FLOOR	needed 2 man power	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	Shifting work completed		Tamilarasi.C. - Nursing Office	21/10/2022
348	22100675	NICU	NEEDED MAN POWER FOR SHIFTING WORK	Pandiaraj. V.,Senthil Kumar. R.,Yuvaraj. M.	Cot shifting work completed		Powlin.P. - Nursing Office	21/10/2022
Dept Name : OPD - Civil - Maintenance Comp. Dt. : 12/12/2022 Status : Completed								
349	22120561	CARDIOLOGY OPD	IN DOCTORS REST ROOM-FLUSH NOT WOKRING	Prakash. V.,Rajendran. R.,Ramkumar. R.	Flush tank rework done.		Radhika. R. - OPD	15/12/2022
Dept Name : Paediatrics Ward - Civil - Maintenance Comp. Dt. : 10/02/2023 Status : Completed								
350	23020410	Paediatrics - Ward 308	WATER NOT COMING IN REST ROOM	Azhagar. N.,Sellaveeran. M.,Udhaya Kumar. R.	VAVLE OPENED. WATER COMING		Rakesh Kumar. S. - Paediatrics Ward	11/02/2023
Dept Name : PHARMACOLOGY - Civil - Maintenance Comp. Dt. : 08/02/2023 Status : Completed								
351	23020293*	PHARMACOLOGY	MALE SIDE REST ROOM IWC BROKEN - NEED TO CHANGE IWC	Prakash. V.,Rajendran. R.,Ramkumar. R.	WHITE CEMENT PACKING WORK DONE AT EWC		Devanathan. S. - PHARMACOLOGY	17/02/2023

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Dept Name : Pharmacy - Civil - Maintenance Comp. Dt. : 10/05/2023 Status : Completed								
352	23050413	Pharmacy	TERMITES PROBLEM	Kannan. V.	Termite repellent sprayed.		Rameshkumar. R. - Pharmacy	16/05/2023
Dept Name : PHYSIOLOGY - Civil - Maintenance Comp. Dt. : 16/03/2023 Status : Completed								
353	23030664	PHYSIOLOGY-- -COLLEGE	SNAKE COMING INSIDE DEPT (BAMBOO BUSH NEED TO BE CLEARED)	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	SHIFTING WORK COMPLETED		Balasankar. P. - PHYSIOLOGY	20/03/2023
Dept Name : Physiotherapy - Civil - Maintenance Comp. Dt. : 18/04/2023 Status : Completed								
354	23040550	pysiotherapy	DRAINGE PUMP NOT WORKING	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	Drainage block removed, work completed		Ezhilan.K. - Physiotherapy	19/04/2023
Dept Name : POW & SICU - Civil - Maintenance Comp. Dt. : 24/04/2023 Status : Completed								
355	23040720	POW & SICU	FLUSH NOT WORKING	Anandharaj. M.,Sellaveeran. M.,Udhaya Kumar. R.	flush tank rework done.		Jamuna. K - POW & SICU	25/04/2023
Dept Name : Printing Press - Civil - Maintenance Comp. Dt. : 17/08/2022 Status : Completed								
356	22080534	TAMILNADU MOTOR	WATER LINE FROM TAMILNADU MOTOR TO HOSPITAL BUILDING WOULD BE BROKEN DUE TO SOME NEW BLOCK CONSTRUC	Prakash. V.,Ramkumar. R.,Rajendran. R.	Pipe line rework done		Shanmugam. R. - Printing Press	18/08/2022
Dept Name : Radio Diagnosis - Civil - Maintenance Comp. Dt. : 08/12/2022 Status : Completed								
357	22120374	RADIOLOGY	COMMON TOILET BLOCKED,NEED SCAVENGER	Rajendhiran. V.	block removed.		Abirami. P. - Radio Diagnosis	09/12/2022
Dept Name : RICU - Civil - Maintenance Comp. Dt. : 23/12/2022								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
358	22121074	SICU	WASH BASIN WATER LEAKAGE	Prakash. V.	Wash basin tap packed with teflon tape. Water leakage arrested.		Yuvarani. P. - RICU	24/12/2022
Dept Name : Security - SIS - Civil - Maintenance								
Comp. Dt. : 03/12/2022								
Status : Completed								
359	22120134	MEDICAL COLLEGE GROUND FLOOR	LADIES REST ROOM FLUSH TANK DAMAGE	Anandharaj. M.,Azhagar. N.,Gopal. S.	New flush tank changed.		Prabakaran. P. - Security - SIS	06/12/2022
360	22120135	MEDICAL COLLEGE GROUND FLOOR	NEED TO FIX GRATINGS IN LADIES RESTROOM	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	Gratings fixed.		Prabakaran. P. - Security - SIS	06/12/2022
Comp. Dt. : 13/02/2023								
Status : Completed								
361	23020474	COMMUNITY MEDICINE DEPT IN MEDICAL COLLEGE	BLOCK & FLUSH NOT WORKING IN HOD RESTROOM	Prakash. V.,Ramkumar. R.,Rajendran. R.	BLOCK REMOVED AND FLUSH TANK REWORK DONE		Elavazhagan. A. - Security - SIS	15/02/2023
Comp. Dt. : 10/05/2023								
Status : Completed								
362	23050398	Mit ladies hostel	3 FLOOR BATHROOM WATER NOT COME	Prakash. V.,Rajendran. R.,Ramkumar. R.	REPEATED COMPLAINT		Sarguna. D. - Security - SIS	12/05/2023
363	23050399	Mit ladies hostel	3 FLOOR BATHROOM WATER NOT COME	Prakash. V.,Rajendran. R.,Ramkumar. R.	Tank filled. problem rectified.		Sarguna. D. - Security - SIS	13/05/2023
Dept Name : Special Clinic - Office - Civil - Maintenance								
Comp. Dt. : 20/12/2022								
Status : Completed								
364	22120933	SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	REST ROOM FLUSH NOT WORKING	Prakash. V.,Rajendran. R.,Ramkumar. R.	Flush tank rework done.		Monica Sales. D. - Special Clinic - Office	21/12/2022
Dept Name : Special Ward - Civil - Maintenance								
Comp. Dt. : 19/07/2022								
Status : Completed								
365	22070721	Special Ward - C	BLOCK IN FEMALE SIDE RESTROOM	Rajendhiran. V.,Govindan. R.,Murugan. S.	Toilet block removed, work completed		Sangeetha. S. - Special Ward	20/07/2022
Comp. Dt. : 21/12/2022								
Status : Completed								
366	22120964	SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	FLUSH NOT WORKING	Prakash. V.,Rajendhiran. V.,Ramkumar. R.	Flush tank rework done.		Dhatchayani.N. - Special Ward	21/12/2022

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHAL KUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 28/12/2022 Status : Completed								
367	22121261	Special Ward - A	wash basion blocked	Rajendhiran. V.,Murugan. S.,Thanuzkodi. E	wash basin bloc removed.		Revathi. S. - Special Ward	28/12/2022
Comp. Dt. : 07/01/2023 Status : Completed								
368	23010322	SPECIAL WARD A1-FOURTH FLOOR	IN ROOM NO.2-WESTERN TOILET -FLUSH LEAKAGING PROBLEM	Anandharaj. M.,Azhagar. N.,Udhaya Kumar. R.	Flush tank rework done,.		Bharathi. R. - Special Ward	09/01/2023
Dept Name : Tailoring Department - Civil - Maintenance Comp. Dt. : 20/12/2022 Status : Completed								
369	22120936	Tailoring Department	NEEDED 6 MAN POWER FOR SHIFTING WORK	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	Shifting work completed		Ilayaraja.S. - Tailoring Department	23/12/2022
Dept Name : Transport - Civil - Maintenance Comp. Dt. : 20/05/2023 Status : Completed								
370	23050828	BUS SHED IN HOSPITAL CAMPUS	NEED TO CHANGE THE VALVE	Sellaveeran. M.	WRONG COMPLAINT		Prabu. T. - Transport	03/06/2023
Work Type : Work Dept Name : Clinical Department - Civil - Maintenance Comp. Dt. : 19/09/2022 Status : Completed								
371	22090741	CLINICAL DEPARTMENT IN 2ND FLOOR	NEED LABOURS 2 NOS FOR SHIFTING CHAIRS [3NOS] FOR REPAIRING WORK TO WORKSHOP	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	work completed.		Vidhyavathi. S. - Clinical Department	21/09/2022
Dept Name : Gas Power Plant - Civil - Maintenance Comp. Dt. : 25/02/2023 Status : Completed								
372	23020977	Printing Press	NEED MANPOWER 5 NOS	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	PAPER BUNDLES SHIFTING WORK DONE.		Mahi Mohan Ram.S. - Gas Power Plant	02/03/2023
Dept Name : PHYSIOLOGY - Civil - Maintenance Comp. Dt. : 06/02/2023 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
373	23020152	PHYSIOLOGY-- -COLLEGE	NEED MANPOWER 3 NOS FOR INSTRUMENT SHIFTING WORK	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	Machines shifting work completed		Jayanthi.A. - PHYSIOLOGY	07/02/2023
Dept Name : POW & SICU - Civil - Maintenance Comp. Dt. : 19/01/2023 Status : Completed								
374	23010652	POW & SICU	NEED LABOURS 2 NOS FOR SCREEN FIXING WORK	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	Screen fixing work completed		Valarmathy. K. - POW & SICU	21/01/2023
College Name : SMVMCH-COL Work Type : Complaint Dept Name : Administration - Civil - Maintenance Comp. Dt. : 01/03/2023 Status : Completed								
375	23030041	MEDICAL COLLEGE I FLOOR	BLOCK IN FEMALE RESTROOM	Sakthivel. E.,Govindan. R.,Kathirvelu. K.	BLOCK REMOVED.		Karthik. K. - Administration	02/03/2023
Dept Name : Air Condition Department - Civil - Maintenance Comp. Dt. : 20/03/2023 Status : Completed								
376	23030828	MEDICAL COLLEGE	NEED CHILLER BASE CLEANING WORK AT MEDICAL COLLEGE	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	DEBRIS CLEANING WORK DONE.		Panneer Selvam. P. - Air Condition Department	21/03/2023
Dept Name : ANATOMY - Civil - Maintenance Comp. Dt. : 04/08/2022 Status : Completed								
377	22080173	ANATOMY	NEED LABOURS FOR SHIFTING 21 NO'S STOOLS FROM WORKSHOP	Pandiaraj. V.,Prakash. N.,Senthil Kumar. R.	shifting work completed.		Mathivanan.B. - ANATOMY	11/08/2022
Comp. Dt. : 07/09/2022 Status : Completed								
378	22090260	ANATOMY	TAP BROKEN - WATER FLOW - NEED TO CHANGE TAP URGENT	Anandharaj. M.,Azhagar. N.,Udhaya Kumar. R.	Old pipe line replaced with new pipe line		Mathivanan.B. - ANATOMY	09/09/2022
Comp. Dt. : 11/10/2022 Status : Completed								
379	22100272	ANATOMY	NEED TO CHANGE WASH BASIN DRAINAGE HOSE AT HISTOLOGY LAB	Santhosh Kumar. M.	Connection tube changed.		Mathivanan.B. - ANATOMY	12/10/2022

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 22/10/2022								
Status : Completed								
380	22100751	ANATOMY	WATER WASHBASIN WATER DRAINAGE PROBLEM--AP SIR ROOM(2025)	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	Wash basin waste water pipe line cut, drianage pipe line block removed, rework the pipe line, proble		Mathivanan.B. - ANATOMY	27/10/2022
Comp. Dt. : 02/01/2023								
Status : Completed								
381	23010032	ANATOMY	WATER NOT COMING IN WASH BASIN SINK	Prakash. V.,Rajendran. R.,Ramkumar. R.	Valve opened.		Mathivanan.B. - ANATOMY	07/01/2023
Comp. Dt. : 09/01/2023								
Status : Completed								
382	23010361	ANATOMY	IN LECTURE HALL-WASH BASIN SINK DAMAGED	Prakash. V.,Rajendran. R.,Ramkumar. R.	New wash basin connection tube and waste hose changed, problem solved		Mathivanan.B. - ANATOMY	18/01/2023
Comp. Dt. : 09/03/2023								
Status : Completed								
383	23030367	ANATOMY	NEED TO CHANGE WASH BASIN DRAINAGE HOSE WATER LEAKAGE AT RESEARCH LAB	Prakash. V.,Rajendran. R.,Ramkumar. R.	New waste hose changed, problem solved		Mathivanan.B. - ANATOMY	13/03/2023
Comp. Dt. : 31/03/2023								
Status : Completed								
384	23031363	ANATOMY	BLOCK IN WASHBASIN - TUTOR ROOM	Sakthivel. E.	BLOCK REMOVED.		Mathivanan.B. - ANATOMY	01/04/2023
Comp. Dt. : 11/04/2023								
Status : Completed								
385	23040303	ANATOMY	NEED TO CHANGE DICTION HALL KODAVAR TANK OUT WATER TAP - DAMAGE & WATER LEAKAGE	Prakash. V.,Rajendran. R.,Ramkumar. R.	2.1/2" X 2" PVC bush changed, pipe line fully rework, work completed		Mathivanan.B. - ANATOMY	20/04/2023
Comp. Dt. : 17/05/2023								
Status : Completed								
386	23050695	ANATOMY	NEED TO REFIX FLUSH KEY FOR FEMALE RESTROOM	Prakash. V.,Rajendran. R.,Ramkumar. R.	FLUSH TANK REWORK DONE		Mathivanan.B. - ANATOMY	19/05/2023
Comp. Dt. : 29/05/2023								
Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
387	23051163	ANATOMY	NEED TO CHANGE WASH BASIN DRAINAGE HOSE - WATER LEAKAGE AT AP ROOM	Prakash. V.,Rajendran. R.,Manikandan. S.	DRAINAGE HOSE CHANGED.		Mathivanan.B. - ANATOMY	31/05/2023
Dept Name : BIOCHEMISTRY - Civil - Maintenance Comp. Dt. : 07/06/2022 Status : Completed								
388	22060234	BIOCHEMISTRY-- -COLLEGE	NEED TO CHANGE RESTROOM TAP - WATER LEAKAGE AT HOD ROOM	Gopal. S.	Restroom tap rework done.		Suganthi. P. - BIOCHEMISTRY	09/06/2022
Comp. Dt. : 27/07/2022 Status : Completed								
389	22071010	BIOCHEMISTRY-- -COLLEGE	NEED TO CHANGE WASH BASIN DRAINAGE HOSE - DAMAGE & WATER LEAKAGE AT STUDENT LAB	Prakash. V.,Rajendran. R.,Ramkumar. R.	Wash basin drainage hose rework		Suganthi. P. - BIOCHEMISTRY	09/08/2022
Comp. Dt. : 05/08/2022 Status : Completed								
390	22080197	BIOCHEMISTRY-- -COLLEGE	NEED TO CHECK SINK - WATER LEAKAGE AT STUDENT'S LAB	Anandharaj. M.,Azhagar. N.,Gopal. S.	Sink rework done.		Suganthi. P. - BIOCHEMISTRY	22/08/2022
Comp. Dt. : 08/09/2022 Status : Completed								
391	22090302	Central Research Lab	DUE TO DEATH OF RAT BAD SMELE COMING INSIDE THE LAB - NEED CLEANING WORK URGENTLY	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	Rat removed		Anusuya. J. - BIOCHEMISTRY	09/09/2022
Comp. Dt. : 10/10/2022 Status : Completed								
392	22100207	BIOCHEMISTRY-- -COLLEGE	NEED TO CHECK WALL - WATER LEAKAGE AT SUNSHADE SIDE AT HOD ROOM	Anandharaj. M.,Santhosh Kumar. M.,Gopal. S.	Sunshade block removed.		Suganthi. P. - BIOCHEMISTRY	11/10/2022
Comp. Dt. : 03/11/2022 Status : Completed								
393	22110110	BIOCHEMISTRY-- -COLLEGE	IN A.P ROOM-RAIN WATER LEAKAGING FROM SUNSIDE	Prakash. V.,Ramkumar. R.,Rajendran. R.	Sunshade cleaned, now problem solved		Suganthi. P. - BIOCHEMISTRY	08/11/2022
Comp. Dt. : 05/01/2023 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
394	23010213	BIOCHEMISTRY-- -COLLEGE	IN CR LAB-NEEDN LABOURS FOR MACHINE SHIFTING PURPOSE	Prakash. N.,Senthil Kumar. R.,Murali. K.	Machine shifting work completed		Anusuya. J. - BIOCHEMISTRY	05/01/2023
Comp. Dt. : 31/01/2023 Status : Completed								
395	23011128	BIOCHEMISTRY-- -COLLEGE	NEED TO CHANGE TAP - WATER LEAKAGE AT STUDENT LAB	Prakash. V.,Rajendran. R.,Ramkumar. R.	Tap 2Nos rework and serviced, problem solved		Suganthi. P. - BIOCHEMISTRY	02/02/2023
Comp. Dt. : 17/03/2023 Status : Completed								
396	23030721	BIOCHEMISTRY-- -COLLEGE	NEED LABOURS 3 NOS FOR BERO & CHAIR SHIFTING WORK FROM BIOCHEMISTRY TO WORKSHOP	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	BERO AND CHAIR SHIFTED FROM BIOCHEMISTRY TO WORKSHOP		Suganthi. P. - BIOCHEMISTRY	20/03/2023
Dept Name : Canteen - Boys Hostel - Civil - Maintenance Comp. Dt. : 12/09/2022 Status : Completed								
397	22090459	Boys hostel PH-I	IN ROOM NO. 43 FLUSH TANK NOT WORKING	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	Flush tank washer changed. Flush tank stand fixed.		Sambasivam. K. - Canteen - Boys Hostel	22/09/2022
Comp. Dt. : 08/10/2022 Status : Completed								
398	22100172	Boys hostel PH-I	FLUSH TANK REPAIR WORK IN ROOM NO.26	Prakash. V.	New flush tank changed.		Sambasivam. K. - Canteen - Boys Hostel	08/10/2022
399	22100173	Boys hostel P.H-III	SHOWER NOT WORKING	Prakash. V.,Gopal. S.,Santhosh Kumar. M.	Shower changed.		Sambasivam. K. - Canteen - Boys Hostel	10/10/2022
400	22100174	Boys hostel P.H-III	MIXER TAP WATER LEAKAGE IN ROOM NO. 1 AND 10	Anandharaj. M.	Mixture tap changed.		Sambasivam. K. - Canteen - Boys Hostel	10/11/2022
Dept Name : Canteen-Girls Hostel - Civil - Maintenance Comp. Dt. : 18/08/2022 Status : Completed								
401	22080605	TEMPLATE AREA	DRAINAGE PIPE REMOVING WORK	Lester. Rodgers	USER NAME CREATED WRONGLY		Elanchiyam. S. - Canteen-Girls Hostel	18/08/2022
Comp. Dt. : 12/06/2023 Status : Completed								
402	23060393	JR Quarters	BLOCK IN II FLOOR RESTROOM	Sakthivel. E.,Govindan. R.,Kathirvelu. K.	block removed.		Virgin Mary - Canteen-Girls Hostel	13/06/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Dept Name : COMMUNITY MEDICINE - Civil - Maintenance Comp. Dt. : 24/05/2022 Status : Completed								
403	22050861	COMMUNITY MEDICINE DEPT IN MEDICAL COLLEGE	NEED TO REFIX URINAL - CLAMP DAMAGE AT COMMON RESTROOM	Azhagar. N.,Anandharaj. M.,Sellaveeran. M.	Urinal clamp refixed, problem solved		Muthuvel. A. - COMMUNITY MEDICINE	24/05/2022
Comp. Dt. : 26/07/2022 Status : Completed								
404	22070935	COMMUNITY MEDICINE DEPT IN MEDICAL COLLEGE	NEED TO CHANGE FLUSH TANK - BROKED AND FALLED DOWN AT COMMON MALE RESTROOM	Azhagar. N.	Flush tank clamp fixed. Seat cover changed.		Muthuvel. A. - COMMUNITY MEDICINE	26/07/2022
Comp. Dt. : 03/09/2022 Status : Completed								
405	22090140	COMMUNITY MEDICINE DEPT IN MEDICAL COLLEGE	R O WATER NOT COMING	Anandharaj. M.,Azhagar. N.,Santhosh Kumar. M.	Problem rectified.		Rajesh. D. - COMMUNITY MEDICINE	06/09/2022
Comp. Dt. : 07/09/2022 Status : Completed								
406	22090282	COMMUNITY MEDICINE DEPT IN MEDICAL COLLEGE	FLUSH TANK BROKEN - WATER FLOW AT COMMON RESTROOM - NEED URGENT SERVICE	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	Flush tank rework.		Muthuvel. A. - COMMUNITY MEDICINE	09/09/2022
Comp. Dt. : 30/09/2022 Status : Completed								
407	22091227	MEDICAL COLLEGE -READING HALL IN GROUND FLOOR	NEED LABOURS 6 NOS FOR TABLE ARRANGEMENT WORK	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	Work Completed		Raghavendran. V. - COMMUNITY MEDICINE	07/10/2022
Comp. Dt. : 19/10/2022 Status : Completed								
408	22100631	MEDICAL COLLEGE -READING HALL IN GROUND FLOOR	NEED TO LABOURS-CHAIRS ARRENGEMENT WORK	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	Chairs arrangement work completed		Raghavendran. V. - COMMUNITY MEDICINE	20/10/2022
Comp. Dt. : 11/02/2023 Status : Completed								
409	23020442	COMMUNITY MEDICINE DEPT IN MEDICAL COLLEGE	NEED MANPOWER 2NOS FOR "S" TYPE CHAIR [6NOS] SHIFTING WORK FROM COMMUNITY MEDICINE DEPT IN MEDICAL	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	'S' TYPE CHAIR SHIFTING WORK COMPLETED.	 Dr. KAGNE. R.N. DEAN SRI MANAKULA VINAYAGAR MEDICAL COLLEGE & HOSPITAL KALITHEERTHALKUPPAM, PUDUCHERRY-605107.	Muthuvel. A. - COMMUNITY MEDICINE	16/02/2023

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 16/02/2023 Status : Completed								
410	23020645	COMMUNITY MEDICINE	RACK SHIFTING WORK-- -NEED MAN POWER	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	RACK SHIFTING WORK COMPLETED.		Muthuvel. A. - COMMUNITY MEDICINE	21/02/2023
Comp. Dt. : 21/02/2023 Status : Completed								
411	23020793	COMMUNITY MEDICINE DEPT IN MEDICAL COLLEGE	NEED TO REFIX DRESS STAND HOOK FOR COMMON MALE RESTROOM	Prakash. V.,Rajendran. R.,Ramkumar. R.	DRESS STAND HOOK REFIXED.		Muthuvel. A. - COMMUNITY MEDICINE	21/02/2023
Comp. Dt. : 12/04/2023 Status : Completed								
412	23040352	Thiruvannainallur	NEED REPAIRING & CLEANING WORK FOR WATER TANK - LEAKAGE IN MORETHAN 5 PLACES & FUNGUS FORMED - NEE	Rajendran. R.	WORK COMPLETED		Sunitha. P. - COMMUNITY MEDICINE	24/05/2023
Comp. Dt. : 13/06/2023 Status : Completed								
413	23060468	COMMUNITY MEDICINE DEPT IN MEDICAL COLLEGE	NEED TO CHECK MALE REST ROOM PIPE LINE AT OFFICE - LINE BROKEN - BLOCK	Rajendran. R.	BLOCK REMOVED.		Sunitha. P. - COMMUNITY MEDICINE	14/06/2023
414	23060469	COMMUNITY MEDICINE DEPT IN MEDICAL COLLEGE	NEED TO OPEN FEMALE RESTROOM	Prakash. V.,Rajendran. R.,Ramkumar. R.	Door locked. Informed to Muthuvel to break the lock.		Sunitha. P. - COMMUNITY MEDICINE	20/06/2023
Dept Name : Computer Department - Civil - Maintenance Comp. Dt. : 15/06/2022 Status : Completed								
415	22060582	DIGITAL LAB	DUE TO DEATH OF RAT AT FALSE CEILING , BAD SMELL IN DIGITAL LAB - TOWARDS CLEANING WORK NEED CIVIL	Rajendhiran. V.,Thanuzkodi. E,Govindan. R.	Inform to House keeping dept Supervisor Mr.Naresh, complaint rectified		Jayaraj. J. - Computer Department	28/06/2022
Comp. Dt. : 24/02/2023 Status : Completed								
416	23020917	DIGITAL LAB	NEED PIPELINE ADJUSTMENT - BACK SIDE OF DIGITAL LAB	Prakash. V.,Rajendran. R.,Ramkumar. R.	PIPE LINE REMOVED.		Prakash. P. - Computer Department	25/02/2023
Dept Name : Director Office - Civil - Maintenance Comp. Dt. : 12/05/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
417	22050419	COMMUNITY MEDICINE---OFFICE	(2398) ONE BERO SHIFTING WORK-NEED LABOURS	Pandiaraj. V.,Yuvaraj. M.,Thulasi. V.	Bero shifting work completed		Vijai. A. - COMMUNITY MEDICINE	14/05/2022
Comp. Dt. :		19/05/2022						
Status :		Completed						
418	22050689	Director Office	WATER NOT COMING IN DEAN SIR & DIRECTOR SIR REST ROOMS - NEED URGENT SERVICE	Arunagiri. V.	Health faucet and filter serviced		Karthikeyan. R. - Director Office	19/05/2022
Comp. Dt. :		18/06/2022						
Status :		Completed						
419	22060679	professor quarters	KITCHEN AREA BLOCK QUARTERS NO 2	Sakthivel. E.	Block removed.		Mani. A. - Director Office	18/06/2022
420	22060680	A.P Quateres	FLUSH TANK PROBLEM QUARTERS NO 51 & WALL MIXTURE TAP NEED TO BE CHANGE QUARTERS NO 39	Sivaraja. M.	Flush tank rework.		Mani. A. - Director Office	18/06/2022
421	22060681	A.P Quateres	NEED TO CHANGE WASHING AREA TAP - QUARTERS NO 3	Anandharaj. M.	New tap fixed.		Mani. A. - Director Office	20/06/2022
Comp. Dt. :		15/07/2022						
Status :		Completed						
422	22070605	MEDICAL COLLEGE I FLOOR	BLOCK IN I FLOOR MALE RESTROOM	Thanuzkodi. E.,Govindan. R.,Sakthivel. E.	Toilet block removed, work completed		Raman. P. - Director Office	16/07/2022
Comp. Dt. :		29/07/2022						
Status :		Completed						
423	22071078	MEDICAL COLLEGE I FLOOR	WASH BASIN BLOCK AT COMMON MALE RESTROOM	Sakthivel. E.,Rajendhiran. V.,Murugan. S.	Block removed.		Jayasridhar. K. - Director Office	30/07/2022
Comp. Dt. :		21/09/2022						
Status :		Completed						
424	22090832	MEDICAL COLLEGE I FLOOR	NEED TO CHANGE TAP - BROKEN - WATER FLOW AT I FLOOR COMMON RESTROOM - NEED URGENT SERVICE	Anandharaj. M.,Sellaveeran. M.,Udhaya Kumar. R.	Urinal pipe refixed.		Karthikeyan. R. - Director Office	22/09/2022
Comp. Dt. :		18/10/2022						
Status :		Completed						
425	22100612	A.P Quateres	IN ROOM NO. 28 BATHROOM TAP AND FLUSH TANK PROBLEM	Anandharaj. M.	Tap and flush rework, wall mixer tap spindle changed.		Mani. A. - Director Office	08/11/2022
426	22100613	A.P Quateres	TERMITE PROBLEM IN ROOM NO. 40	Sakthivel. E.	Termite chemical sprayed, problem solved		Mani. A. - Director Office	28/10/2022

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 26/10/2022 Status : Completed								
427	22100823	A.P Quateres	IN ROOM NO-51--KITCHEN TAP PROBLEM	Sellaveeran. M.	New PVC tap changed.		Mani. A. - Director Office	26/10/2022
Comp. Dt. : 05/12/2022 Status : Completed								
428	22120212	MEDICAL COLLEGE	IN SECURITY AREA-NEED LABOURS FOR SLAB RE-CLOSING WORK	Pandiaraj. V., Yuvaraj. M., Senthil Kumar. R.	Slab closed.		Prasanna.B. - Director Office	10/12/2022
Comp. Dt. : 20/03/2023 Status : Completed								
429	23030790	A.P Quateres	NEED WATER HEATER FIXING WORK - QUARTERS NO 45	Prakash. V., Rajendran. R., Ramkumar. R.	NEW WATER PIPELINE FIXED FOR HEATER		Mani. A. - Director Office	21/03/2023
Comp. Dt. : 28/03/2023 Status : Completed								
430	23031163	ASSOCIATIVE PROFESSOR QUARTERS	NEED TO CHECK KITCHEN PIPELINE - WATER LEAKAGE QUARTERS NO 19	Prakash. V., Rajendran. R., Ramkumar. R.	KITCHEN PIPELINE CONNECTION REWORK DONE.		Mani. A. - Director Office	03/04/2023
Comp. Dt. : 04/04/2023 Status : Completed								
431	23040120	professor quarters	NEED TO CHECK WATER HEATER PIPELINE - BROKEN - QUARTERS NO 3	Prakash. V., Rajendran. R., Ramkumar. R.	WORK COMPLETED.		Mani. A. - Director Office	06/05/2023
Comp. Dt. : 25/04/2023 Status : Completed								
432	23040829	ASSOCIATIVE PROFESSOR QUARTERS	NEED TO CHECK SINK & BALCONY TAP - DAMAGE WATER LEAKAGE AT QUARTERS NO 7 & 12	Prakash. V., Rajendran. R., Ramkumar. R.	SINK AND BALCONY PIPE LINE CONNECTION REWORK DONE.		Mani. A. - Director Office	28/04/2023
Comp. Dt. : 19/05/2023 Status : Completed								
433	23050814	A.P Quateres	NEED TO CHANGE TAP - QUARTERS NO 28	Prakash. V., Rajendran. R., Ramkumar. R.	TAP CHANGED.		Mani. A. - Director Office	26/05/2023
Comp. Dt. : 06/06/2023 Status : Completed								
434	23060208	MEDICAL COLLEGE I FLOOR	NEED NEW PIPELINE CONNECTION FOR FIXING COOLER	Prakash. V., Rajendran. R., Ramkumar. R.	COOLER PIPELINE CONNECTION FIXED.		Prasanna.B. - Director Office	10/06/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 21/06/2023 Status : Completed								
435	23060789	A.P Quateres	NEED TO FIX WASHING MACHINE WATER LINE CONNECTION FOR QUARTERS NO 13	Prakash. V.,Rajendran. R.,Ramkumar. R.	New washing machine and water heater line making and water line connection given, work completed		Mani. A. - Director Office	22/06/2023
436	23060790	professor quarters	NEED TO CHECK HAND SET - DAMAGE AT QUARTERS NO 6	Prakash. V.,Rajendran. R.,Ramkumar. R.	Health faucet changed.		Mani. A. - Director Office	22/06/2023
Dept Name : Electrical Maintenance - Civil - Maintenance Comp. Dt. : 04/01/2023 Status : Completed								
437	23010125	MEDICAL COLLEGE	IN GARDEN AREA-CABLE EARTHENING WORK DONE-SO SAND LEVELING WORK NEED TO DO	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	Sand levelling work completed.		Sathishkumar. R. - Electrical Maintenance	09/01/2023
Comp. Dt. : 27/05/2023 Status : Completed								
438	23051091	MEDICAL COLLEGE	NEED CIVIL TOUCHUP WORK AT CALL LAB	Murugavel	ELECTRICAL PIPELINE TOUCH UP WORK DONE.		Azhagappan. J. - Electrical Maintenance	31/05/2023
Dept Name : FORENSIC MEDICINE - Civil - Maintenance Comp. Dt. : 29/06/2022 Status : Completed								
439	22061081	Work Shop	NEED MAN POWER TOWARDS UNLOADING WORK FROM WORKSHOP TO III FLOOR FORENSIC MEDICINE	Pandiaraj. V.,Prakash. N.,Yuvaraj. M.	Machine Shifting work completed		Mathavi. B. - FORENSIC MEDICINE	01/07/2022
Comp. Dt. : 07/09/2022 Status : Completed								
440	22090263	FORENSIC MEDICINE (3RD FLOOR) IN COLLEGE	NEED TO CHECK PIPE LINE - WATER NOT COMING AT FACULTY ROOMS [2NOS]	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	Pipe line rework done.		Mathavi. B. - FORENSIC MEDICINE	09/09/2022
Comp. Dt. : 21/09/2022 Status : Completed								
441	22090820	FORENSIC MEDICINE (3RD FLOOR) IN COLLEGE	NEED TO CHECK PIPE LINE CONNECTION - TAP WATER NOT COMING IN DEAN SIR OFFICE	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	pipe line connection checked.		Mathavi. B. - FORENSIC MEDICINE	22/09/2022
Comp. Dt. : 17/10/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
442	22100512	FORENSIC MEDICINE (3RD FLOOR) IN COLLEGE	NEED MAN POWER 2NOS FOR TABLE ARRANGEMENT WORK	Pandiaraj. V.	Table arrangement work done.		Mathavi. B. - FORENSIC MEDICINE	18/10/2022
Comp. Dt. :		17/12/2022						
Status :		Completed						
443	22120829	FORENSIC MEDICINE (3RD FLOOR) IN COLLEGE	NEED LABOURS FOR BERO SHIFTING WORK ON MONDAY	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	Bero shifting work completed		Mathavi. B. - FORENSIC MEDICINE	19/12/2022
Comp. Dt. :		20/12/2022						
Status :		Completed						
444	22120878	COLLEGE BLOCK III FLOOR	NEED MAN POWER (NO.3) -CUPBOARD SHIFTING	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	Cupboard shifting work completed		Mathavi. B. - FORENSIC MEDICINE	20/12/2022
Comp. Dt. :		23/12/2022						
Status :		Completed						
445	22121069	FORENSIC MEDICINE	NEED 2 LABOURS FOR CHAIR ARRANGEMENT	Pandiaraj. V.,Yuvaraj. M.,Thulasi. V.	Work completed.		Mathavi. B. - FORENSIC MEDICINE	24/12/2022
Comp. Dt. :		09/02/2023						
Status :		Completed						
446	23020358	FORENSIC MEDICINE	NEED 2NO LABOURS FOR TABLE SHIFTING WORK	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	Table shifting work completed		Mathavi. B. - FORENSIC MEDICINE	11/02/2023
Comp. Dt. :		17/03/2023						
Status :		Completed						
447	23030706	FORENSIC MEDICINE	NEED MANPOWER 2 NOS FOR CHAIR SHIFTING WORK	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	CHAIR SHIFTING WORK DONE.		Mathavi. B. - FORENSIC MEDICINE	20/03/2023
Comp. Dt. :		09/05/2023						
Status :		Completed						
448	23050358	FORENSIC MEDICINE (3RD FLOOR) IN COLLEGE	NEED MANPOWER 2 NOS FOR UNLOADING UN WANTED WOODEN PIECES & WASTE GLASS	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	WORK COMPLETED		Ganga. G. - FORENSIC MEDICINE	13/05/2023
Comp. Dt. :		25/05/2023						
Status :		Completed						
449	23051011	FORENSIC MEDICINE (3RD FLOOR) IN COLLEGE	NEED MANPOWER 2 NOS FOR EXAM ARRANGEMENT WORK	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	work completed		Mathavi. B. - FORENSIC MEDICINE	31/05/2023
Comp. Dt. :		30/05/2023						
Status :		Completed						


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
450	23051201	FORENSIC MEDICINE (3RD FLOOR) IN COLLEGE	FLUSH NOT WORKING - [HOD ROOM]	Prakash. V.,Rajendran. R.,Ramkumar. R.	FLUSH TANK REWORK DONE.		Mathavi. B. - FORENSIC MEDICINE	31/05/2023
Dept Name : Library - Civil - Maintenance Comp. Dt. : 02/06/2022 Status : Completed								
451	22060090	medical college library 2nd floor	NEED TO CHECK CEILING SOIL FLOW IN ROOF CEILING	Sellaveeran. M.,Anandharaj. M.,Azhagar. N.	Informed to N. Murugan, Project Manager. Civil Execution Department.		Elangovan.N. - Library	09/06/2022
Comp. Dt. : 16/07/2022 Status : Completed								
452	22070618	medical college library 2nd floor	BLOCK IN MALE RESTROOM	Thanuzkodi. E	Toilet block removed, work completed		Elangovan.N. - Library	16/07/2022
Comp. Dt. : 28/09/2022 Status : Completed								
453	22091142	MEDICAL COLLEGE LIBRARY	DUE TO DEATH OF RAT - BAD SMELL COMING - NEED CLEANING WORK FOR GROUND FLOOR OWN BOOK READING HALL	Rajendhiran. V.,Govindan. R.,Sakthivel. E.	Rat removed at false ceiling by AC department		Elangovan.N. - Library	30/09/2022
Comp. Dt. : 08/10/2022 Status : Completed								
454	22100190	MEDICAL COLLEGE LIBRARY	TILES PACKING WORK IN 1ST FLOOR LIBRARY	Sankar. R	Not a plumbing complaint. Work shop complaint.		Elangovan.N. - Library	12/10/2022
Comp. Dt. : 07/02/2023 Status : Completed								
455	23020225	MEDICAL COLLEGE LIBRARY	DUE TO DEATH OF RAT - BAD SMELL - NEED CLEANING WORK AT GROUND FLOOR LIBRARY	Thanuzkodi. E.,Sakthivel. E.,Govindan. R.	Wrong complaint		Elangovan.N. - Library	08/02/2023
Comp. Dt. : 17/03/2023 Status : Completed								
456	23030680	medical college library 2nd floor	NEED TO CHANGE RESTROOM TAP - BROKEN WATER FLOW - NEED URGENT SERVICE	Prakash. V.,Rajendran. R.,Ramkumar. R.	TAP CHANGED.		Elangovan.N. - Library	17/03/2023
Comp. Dt. : 28/03/2023 Status : Completed								
457	23031219	medical college library 2nd floor	PROBLEM IN WATER COOLER	Prakash. V.,Rajendran. R.,Ramkumar. R.	WATER COOLER CONDEMNED		Elangovan.N. - Library	01/04/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
458	23031220	medical college library 2nd floor	NEED TO CHECK FLUSH & FLUSH TANK KEY - NOT WORKING & BLOCK	Prakash. V.,Rajendran. R.,Ramkumar. R.	FLUSH TANK REWORK DONE.	wfm	Elangovan.N. - Library	12/05/2023
Comp. Dt. : 26/05/2023 Status : Completed								
459	23051054	medical college library 2nd floor	WASH BASIN BLOCK - PROBLEM IN DRAINAGE HOSE	Sakthivel. E.,Gnanasegaran. K.,Govindan. R.	BLOCK REMOVED.		Elangovan.N. - Library	27/05/2023
Comp. Dt. : 26/06/2023 Status : Completed								
460	23060951	medical college library 2nd floor	NEED TO CHECK WASH BASIN TAP POINT - WATER LEAKAGE	Prakash. V.,Rajendran. R.,Ramkumar. R.	Wash basin water line piping work completedq		Elangovan.N. - Library	27/06/2023
Dept Name : MICROBIOLOGY - Civil - Maintenance Comp. Dt. : 11/05/2022 Status : Completed								
461	22050388	MICROBIOLOGY IN COLLEGE	DR ROOM WASH BASIN TAP WATER LEAKAGE (2053)	Rajendran. R.	Drainage line rework done		Mageswari. R. - MICROBIOLOGY	16/05/2022
Comp. Dt. : 18/06/2022 Status : Completed								
462	22060685	MICROBIOLOGY IN COLLEGE	NEED PLUMBER FOR REARRANGING SEAT COVER AT RESTROOM	Azhagar. N.	Seat cover changed		Gopal. R. - MICROBIOLOGY	20/06/2022
Comp. Dt. : 26/07/2022 Status : Completed								
463	22070980	MICROBIOLOGY IN COLLEGE	NEED PLUMBER WORK & HELP	Gopal. S.	6" pipe line removed.		Gopal. R. - MICROBIOLOGY	27/07/2022
Comp. Dt. : 27/07/2022 Status : Completed								
464	22071023	MICROBIOLOGY IN COLLEGE	NEED TO CHANGE WASH BASIN TAP - WATER LEAKAGE AT HOD SIR ROOM	Arunagiri. V.	Waste hose changed and tap rework.		Buvana. C. - MICROBIOLOGY	29/07/2022
Comp. Dt. : 26/08/2022 Status : Completed								
465	22080906	MICROBIOLOGY IN COLLEGE	NEED PLUMBER HELP	Gopal. S.,Santhosh Kumar. M.,Anandharaj. M.	6" line work done		Gopal. R. - MICROBIOLOGY	30/08/2022
Comp. Dt. : 01/09/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
466	22090010	MICROBIOLOGY IN COLLEGE	NEED PLUMBER HELP - WATER LEAKAGE IN PIPELINE	Santhosh Kumar. M.	WFM - Repeated complaint		Mageswari. R. - MICROBIOLOGY	10/09/2022
Comp. Dt. : 14/09/2022 Status : Completed								
467	22090551	MICROBIOLOGY IN COLLEGE	NEED TO CHANGE WASH BASIN TAP - DAMAGE & WATER LEAKAGE	Ramkumar. R.	Water line rework and new health faucet fixed.		Praveenkumar. S. - MICROBIOLOGY	22/09/2022
468	22090559	MICROBIOLOGY IN COLLEGE	NEED TO FIX EYE WASH INSTUMENT	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	New health faucet fixed.		Anandh. P. - MICROBIOLOGY	22/09/2022
Comp. Dt. : 14/10/2022 Status : Completed								
469	22100462	MICROBIOLOGY IN COLLEGE	NEED TO CHANGE WASH BASIN DRAINAGE HOSE - WATER LEAKAGE AT PCR LAB	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	Wash basin drainage cleaned and refixed. Wash basin rework done.		Sathiya. G. - MICROBIOLOGY	15/10/2022
Comp. Dt. : 17/10/2022 Status : Completed								
470	22100510	MICROBIOLOGY IN COLLEGE	NEED TO PROVIDE PIPE LINE CONNECTION FOR SINK AT PCR LAB	Anandharaj. M.,Azhagar. N.,Santhosh Kumar. M.	1.1/4" waste hose changed. LPipe lilne connection done.		Mageswari. R. - MICROBIOLOGY	18/10/2022
Comp. Dt. : 18/10/2022 Status : Completed								
471	22100566	MICROBIOLOGY IN COLLEGE	NEED TO CHANGE FLUSH TANK - BROKEN AT HOD SIR'S RESTROOM	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	No complaints		Buvana. C. - MICROBIOLOGY	22/10/2022
472	22100590	MICROBIOLOGY IN COLLEGE	NEED MANPOWER 4 NOS FOR INSTRUMENT SHIFTING WORK	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	Instrument shifting work completed		Gopal. R. - MICROBIOLOGY	21/10/2022
Comp. Dt. : 26/10/2022 Status : Completed								
473	22100828	MICROBIOLOGY IN COLLEGE	LADIES REST ROOM WATER PIPE HANDLE BROKEN.	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	Tap head and spindle rework, problem solved		Gopal. R. - MICROBIOLOGY	27/10/2022
Comp. Dt. : 03/01/2023 Status : Completed								
474	23010062	MICROBIOLOGY IN COLLEGE	REST ROOM TAP NOT WORKING	Prakash. V.,Rajendran. R.,Manikandan. S.	Tap head changed and serviced the tap, problem solved		Mageswari. R. - MICROBIOLOGY	12/01/2023
Comp. Dt. : 09/01/2023 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
475	23010363	MICROBIOLOGY IN COLLEGE	NEED MANPOWER FOR BERO SHIFTING WORK FROM WORKSHOP DEPT	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	Bero shifting work completed.		Gopal. R. - MICROBIOLOGY	13/01/2023
Comp. Dt. : 18/02/2023 Status : Completed								
476	23020731	MICROBIOLOGY IN COLLEGE	NEED PLUMBER HELP	Prakash. V.,Rajendran. R.,Ramkumar. R.	New Health faucet, towel rod, soap dish changed, work completed		Gopal. R. - MICROBIOLOGY	22/02/2023
Comp. Dt. : 27/03/2023 Status : Completed								
477	23031123	MICROBIOLOGY IN COLLEGE	NEED MANPOWER 2 NOS FOR SHIFTING CYLINDER FROM COLLEGE TO HOSPITAL	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	CYLINDER SHIFTING WORK COMPLETED		Gopal. R. - MICROBIOLOGY	31/03/2023
Comp. Dt. : 28/03/2023 Status : Completed								
478	23031182	MICROBIOLOGY IN COLLEGE	NEED MANPOWER 2NOS FOR INSTRUMENT SHIFTING WORK FROM MICROBIOLOGY IN COLLEGE TO GENERAL STORES	Thulasi. V.	INSTRUMENT SHIFTED FROM MICROBIOLOGY TO GENERAL STORES.		Mageswari. R. - MICROBIOLOGY	03/04/2023
Comp. Dt. : 27/04/2023 Status : Completed								
479	23040917	MICROBIOLOGY IN COLLEGE	SINK DAMAGE - WATER LEAKAGE AT WASHING AREA	Prakash. V.,Rajendran. R.,Ramkumar. R.	WASTE COUPLING CHANGED.		Mageswari. R. - MICROBIOLOGY	03/06/2023
Comp. Dt. : 28/04/2023 Status : Completed								
480	23040970	MICROBIOLOGY IN COLLEGE	NEED TO CHANGE TAP - WATER FLOW AT LAB - NEED URGENT SERVICE	Prakash. V.,Rajendran. R.,Ramkumar. R.	NEW TAP CHANGED.		Mageswari. R. - MICROBIOLOGY	07/06/2023
Comp. Dt. : 15/06/2023 Status : Completed								
481	23060568	MICROBIOLOGY IN COLLEGE	LAB SINK WATER LEAKAGE PROBLEM	Prakash. V.,Rajendran. R.,Ramkumar. R.	Waste coupling fixed. waiting for materials (Tap)		Thiruvallarselvi. K. - MICROBIOLOGY	20/07/2023
Comp. Dt. : 09/11/2022 Status : Completed								
Dept Name : MS Office - Civil - Maintenance								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
482	22110378	MEDICAL COLLEGE	IN SIMULATION CENTET-NEED 4 MANPOWER FOR TABLE SHIFTING AND ARRANGEMENTS WORK	Pandiaraj. V.,Prakash. N.,Yuvaraj. M.	Tables shifted and arrangement work done.		Elumalai. M. - MS Office	11/11/2022
Comp. Dt. : 17/03/2023 Status : Completed								
483	23030688	SKILL LAB - MEDICAL COLLEGE	NEED MANPOWER 2 NOS FOR T V SHIFTING WORK	Pandiaraj. V.,Thulasi. V.,Yuvaraj. M.	TV SHIFTING WORK DONE.		Elumalai. M. - MS Office	20/03/2023
Comp. Dt. : 25/03/2023 Status : Completed								
484	23031080	SKILL LAB - MEDICAL COLLEGE	NEED TO REMOVE BEE NEST	Sivaraja. M.	HONEY COMB DESTROYED.		Elumalai. M. - MS Office	05/04/2023
Dept Name : PATHOLOGY - Civil - Maintenance Comp. Dt. : 04/08/2022 Status : Completed								
485	22080182	PATHOLOGY IN COLLEGE	BLOCK IN RESTROOM	Govindan. R.	Block removed.		Kalaichelvi.M. - PATHOLOGY	08/08/2022
Comp. Dt. : 01/09/2022 Status : Completed								
486	22090051	PATHOLOGY IN COLLEGE	NEED LABOUR 4 NOS FOR TABLE SHIFTING WORK	Palanisamy. R.,Yuvaraja. K.,Thulasi. V.	Table shifting work completed		Sathia Rajesh. C. - PATHOLOGY	05/09/2022
Comp. Dt. : 03/09/2022 Status : Completed								
487	22090133	Work Shop	NEED LABOURS 2 NOS FOR TABLE SHIFTING WORK FROM WORKSHOP TO PATHOLOGY IN COLLEGE	Pandiaraj. V.,Senthil Kumar. R.,Yuvaraj. M.	Table shifting work completed		Sathia Rajesh. C. - PATHOLOGY	05/09/2022
Comp. Dt. : 07/10/2022 Status : Completed								
488	22100161	PATHOLOGY IN COLLEGE	NEED TO CHANGE TAP - WATER LEAKAGE	Sellaveeran. M.,Gopal. S.,Santhosh Kumar. M.	wash basin pillar cork and wash basin connection tube changed.		Kalaichelvi.M. - PATHOLOGY	11/10/2022
Comp. Dt. : 11/10/2022 Status : Completed								
489	22100285	PATHOLOGY IN COLLEGE	NEED TO CHANGE SINK DRAINAGE HOSE - WATER LEAKAGE	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	connection tube changing work done		havamani. K. - PATHOLOGY	11/10/2022


Dr. KAGNE. R.N
 DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 18/11/2022 Status : Completed								
490	22110798	PATHOLOGY IN COLLEGE	NEED TO CHANGE TAP FOR FLUSH AND RESTROOM TAP- WATER LEAKAGE	Sellaveeran. M.,Azhagar. N.,Santhosh Kumar. M.	flush tank rework done. connection tube changed.		Sathia Rajesh. C. - PATHOLOGY	06/12/2022
Comp. Dt. : 10/02/2023 Status : Completed								
491	23020402	PATHOLOGY IN COLLEGE	SINK WATER LEAKAGE IN FACULTY ROOM	Prakash. V.,Rajendran. R.,Ramkumar. R.	SINK BLOCK REMOVED.		Kalaichelvi.M. - PATHOLOGY	15/02/2023
Comp. Dt. : 17/04/2023 Status : Completed								
492	23040496	PATHOLOGY IN COLLEGE	BLOCK IN WASH BASIN	Murugan. S.	Wash basin block removed, work completed		Sathia Rajesh. C. - PATHOLOGY	20/04/2023
Comp. Dt. : 02/05/2023 Status : Completed								
493	23050058	PATHOLOGY IN COLLEGE	BLOCK IN WASH BASIN	Sakthivel. E.	block removed.		Sathia Rajesh. C. - PATHOLOGY	03/05/2023
Comp. Dt. : 02/06/2023 Status : Completed								
494	23060058	PATHOLOGY IN COLLEGE	NEED - WASH BASIN DISCONNECT	Prakash. V.,Rajendran. R.,Manikandan. S.	SINK REMOVED AND REFIXED		Sathia Rajesh. C. - PATHOLOGY	08/06/2023
Comp. Dt. : 08/06/2023 Status : Completed								
495	23060263	PATHOLOGY IN COLLEGE	NEED TO CHANGE WASH BASIN TAP - WATER LEAKAGE	Prakash. V.,Rajendran. R.,Ramkumar. R.	TAP CHANGED.		Kalaichelvi.M. - PATHOLOGY	08/06/2023
Comp. Dt. : 23/06/2023 Status : Completed								
496	23060886	PATHOLOGY IN COLLEGE	NEED TO CHANGE WASH BASIN TAP - WATER LEAKAGE	Prakash. V.,Rajendran. R.,Ramkumar. R.	cp angle valve changed.		Sathia Rajesh. C. - PATHOLOGY	27/06/2023
Dept Name : PHARMACOLOGY - Civil - Maintenance Comp. Dt. : 25/07/2022 Status : Completed								
497	22070912	PHARMACOLOGY	WASH BASIN BLOCK IN LAB	Sakthivel. E.	Block removed.		Devanathan. S. - PHARMACOLOGY	26/07/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 29/09/2022 Status : Completed								
498	22091163	MUESIUM (DERM DEPT)IN 4TH FLOOR	NEED LABOURS 2NOS FOR TABLE SHIFTING WORK FROM MUESIUM TO PHARMOCOLGY	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	Table shifting work completed.		Devanathan. S. - PHARMACOLOGY	07/10/2022
Comp. Dt. : 21/11/2022 Status : Completed								
499	22110890	Animal House	NEED MANPOWER FOR SHIFTING PURPOSE FROM PHARMOCOLGY	Prakash. N.,Pandiaraj. V.,Yuvaraj. M.	Shifting work completed.		Devanathan. S. - PHARMACOLOGY	25/11/2022
Comp. Dt. : 16/12/2022 Status : Completed								
500	22120791	PHARMACOLOGY	WATER NOT COMING	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	Tank filled.		Panchali. P. - PHARMACOLOGY	17/12/2022
Comp. Dt. : 03/02/2023 Status : Completed								
501	23020086	PHARMACOLOGY	NEED MANPOWER 3 NOS FOR LAB ARRANGEMENT WORK	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	Lab materials arrangement work completed		Devanathan. S. - PHARMACOLOGY	07/02/2023
Comp. Dt. : 19/04/2023 Status : Completed								
502	23040583	PHARMACOLOGY	BLOCK IN SINK	Govindan. R.	BLOCK REMOVED.		Nageswari. S. - PHARMACOLOGY	22/04/2023
Dept Name : PHYSIOLOGY - Civil - Maintenance Comp. Dt. : 09/05/2022 Status : Completed								
503	22050277	PHYSIOLOGY--COLLEGE	NEED TO CHECK WATER PIPE LINE CONNECTION - WATER FLOW LAB INSIDE - NEED URGENT SERVICE	Manikandan. S.	new washhouse fixing work		Balasankar. P. - PHYSIOLOGY	09/05/2022
Comp. Dt. : 24/05/2022 Status : Completed								
504	22050891	PHYSIOLOGY--COLLEGE	NEED TO CHANGE WASH BASIN - BROKENED	Anandharaj. M.	New Wash basin changed.		Shanthini. M. - BIOCHEMISTRY	25/05/2022
Comp. Dt. : 26/05/2022 Status : Completed								
505	22050998	PHYSIOLOGY--COLLEGE	NEED TO CHECK WASH BASIN - WATER LEAKAGE IN HOD ROOM	Azhagar. N.	1.1/4" Waste water line fully rework, New grating fixed, problem solved		Balasankar. P. - PHYSIOLOGY	26/05/2022

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHAL KUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 28/05/2022								
Status : Completed								
506	22051058	PHYSIOLOGY-- -COLLEGE	WASH BASIN LEAKAGE AT LAB SIDE	Udhaya Kumar. R.,Azhagar. N.,Santhosh Kumar. M.	1*1/2" waste water line broken. New water line work done.		Balasankar. P. - PHYSIOLOGY	31/05/2022
Comp. Dt. : 02/06/2022								
Status : Completed								
507	22060050	PHYSIOLOGY-- -COLLEGE	NEED TO CHANGE TAP - WATER LEAKAGE	Gopal. S.	Water leakage arrest.		Balasankar. P. - PHYSIOLOGY	07/06/2022
Comp. Dt. : 03/06/2022								
Status : Completed								
508	22060149	PHYSIOLOGY-- -COLLEGE	NEED TO CHECK PIPELINE - WATER BLOCK IN CLASS ROOM - NEED URGENT SERVICE	Azhagar. N.,Gopal. S.,Anandharaj. M.	Block removed. New 2" waste water line work done.		Shanthini. M. - BIOCHEMISTRY	07/06/2022
Comp. Dt. : 01/12/2022								
Status : Completed								
509	22120043	PHYSIOLOGY-- -COLLEGE	NEED TO CHANGE INDIAN BASIN - BROKEN	Anandharaj. M.,Azhagar. N.,Udhaya Kumar. R.	New IWC changed and mason work completed		Shanthini. M. - BIOCHEMISTRY	07/12/2022
Comp. Dt. : 27/12/2022								
Status : Completed								
510	22121198	PHYSIOLOGY-- -COLLEGE	REST ROOM SINK BROKEN	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	Sink connection tube rework done.		Balasankar. P. - PHYSIOLOGY	28/12/2022
Comp. Dt. : 28/01/2023								
Status : Completed								
511	23011029	PHYSIOLOGY-- -COLLEGE	SINK BROKEN - NEED TO CHANGE AT FACULTY ROOM	Prakash. V.	2Nos waste coupling changed, work completed		Shanthini. M. - BIOCHEMISTRY	02/02/2023
Comp. Dt. : 27/02/2023								
Status : Completed								
512	23021023	PHYSIOLOGY-- -COLLEGE	NEED TO CHANGE TAP - WATER LEAKAGE	Prakash. V.,Rajendran. R.,Ramkumar. R.	TAP CHANGED.		Gowri.V. - PHYSIOLOGY	02/03/2023
Comp. Dt. : 10/03/2023								
Status : Completed								
513	23030422	PHYSIOLOGY-- -COLLEGE	NEED TO REMOVE & CLEAN WASTE CEMENT MATERIALS AT FEMALE RESTROOM & CARITOR	Rajendhiran. V.,Tamilarasan. K.,Sakthivel. E.	Cleaning work completed		Balasankar. P. - PHYSIOLOGY	13/03/2023

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
514	23030432	PHYSIOLOGY-- -COLLEGE	NEED MANPOWER 4 NOS FOR SHIFTING WORK	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	SHIFTING WORK COMPLETED.		Balasankar. P. - PHYSIOLOGY	17/03/2023
Comp. Dt. : 25/03/2023 Status : Completed								
515	23031044	PHYSIOLOGY-- -COLLEGE	NEED TO CHECK AND CHANGE SINK - BROKEN	Prakash. V.,Rajendran. R.,Ramkumar. R.	SINK CHANGED.		Shanthini. M. - BIOCHEMISTRY	04/04/2023
Comp. Dt. : 01/04/2023 Status : Completed								
516	23040025	PHYSIOLOGY-- -COLLEGE	NEED TO CHANGE WASH BASIN - BROKEN - NEED URGENT SERVICE	Prakash. V.,Rajendran. R.,Ramkumar. R.	WASH BASIN FIXED.		Deepika. V. - PHYSIOLOGY	04/04/2023
Comp. Dt. : 12/04/2023 Status : Completed								
517	23040359	PHYSIOLOGY-- -COLLEGE	NEED TO CHANGE SINK - BROKEN AT TUTOR ROOM	Prakash. V.,Rajendran. R.,Ramkumar. R.	NEW SINK FIXED.		Balasankar. P. - PHYSIOLOGY	03/05/2023
Comp. Dt. : 25/04/2023 Status : Completed								
518	23040817	PHYSIOLOGY-- -COLLEGE	WATER LEAKAGE IN SUN SHADE	Prakash. V.,Rajendran. R.,Ramkumar. R.	CIVIL EXECUTION COMPLAINTS		Balasankar. P. - PHYSIOLOGY	28/04/2023
Comp. Dt. : 16/05/2023 Status : Completed								
519	23050633	PHYSIOLOGY-- -COLLEGE	NEED TO CHECK CEILING - WATER LEAKAGE	Prakash. V.,Rajendran. R.,Ramkumar. R.	WASH BASIN LEAKAGE. PIPE LINE CONNECTION REWORK DONE.		Gowri.V. - PHYSIOLOGY	19/05/2023
Comp. Dt. : 26/05/2023 Status : Completed								
520	23051053	PHYSIOLOGY-- -COLLEGE	BLOCK IN MALE RESTROOM	Sakthivel. E.	BLOCK REMOVED.		Balasankar. P. - PHYSIOLOGY	27/05/2023
Comp. Dt. : 23/06/2023 Status : Completed								
521	23060851	PHYSIOLOGY-- -COLLEGE	BLOCK IN WESTERN	Sakthivel. E.,Govindan. R.,Kathirvelu. K.	block removed		Balasankar. P. - PHYSIOLOGY	24/06/2023
Dept Name : Security - SIS - Civil - Maintenance Comp. Dt. : 07/05/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
522	22050239	MEDICAL COLLEGE GROUND FLOOR	R O WATER NOT COMING	Sankar. V.	RO water motor manually ON		Prabakaran. P. - Security - SIS	09/05/2022
	Comp. Dt. : 12/05/2022							
	Status : Completed							
523	22050434	MEDICAL COLLEGE III FLOOR	GENTS TOILET BLOCK-NEED SCAVENGER	Govindan. R.,Sakthivel. E.,Thanuzkodi. E	Block removed.		Elavazhagan. A. - Security - SIS	14/05/2022
	Comp. Dt. : 25/06/2022							
	Status : Completed							
524	22060915	MEDICAL COLLEGE GROUND FLOOR	BLOCK IN BOTH MALE & FEMALE RESTROOM	Sakthivel. E.	Block removed		Elavazhagan. A. - Security - SIS	27/06/2022
	Comp. Dt. : 09/07/2022							
	Status : Completed							
525	22070399	MEDICAL COLLEGE III FLOOR	BLOCK IN RESTROOM	Rajendhiran. V.	Block removed.		Nilavazhagan. K. - Security - SIS	11/07/2022
	Comp. Dt. : 11/07/2022							
	Status : Completed							
526	22070423	MEDICAL COLLEGE III FLOOR	BLOCK IN MALE RESTROOM	Thanuzkodi. E.,Govindan. R.,Sakthivel. E.	Block removed		Prabakaran. P. - Security - SIS	12/07/2022
	Comp. Dt. : 13/07/2022							
	Status : Completed							
527	22070499	MEDICAL COLLEGE I FLOOR	URINAL BLOCK PIPE LINE BROKEN - LEAKAGE AT MALE RESTROOM	Thanuzkodi. E.,Govindan. R.,Sakthivel. E.	Block removed		Prabakaran. P. - Security - SIS	14/07/2022
	Comp. Dt. : 21/07/2022							
	Status : Completed							
528	22070786	MEDICAL COLLEGE	MALE RESTROOM BLOCK IN GROUND & II FLOOR	Sakthivel. E.	Block removed.		Elavazhagan. A. - Security - SIS	26/07/2022
	Comp. Dt. : 29/07/2022							
	Status : Completed							
529	22071047	MEDICAL COLLEGE I FLOOR	BLOCK IN FEMALE RESTROOM	Govindan. R.	Block removed.		Prabakaran. P. - Security - SIS	30/07/2022
	Comp. Dt. : 10/08/2022							
	Status : Completed							
530	22080349	MEDICAL COLLEGE GROUND FLOOR	TAPS ARE CLOSED WITH VALVE- WATER NOT COMING AT COMMON FEMALE REST ROOM - NEED TO CHECK AND DO	Anandharaj. M.,Sellaveeran. M.,Udhaya Kumar. R.	New tap fixed.		Prabakaran. P. - Security - SIS	18/08/2022

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 02/09/2022 Status : Completed								
531	22090090	MEDICAL COLLEGE GROUND FLOOR	WATER LEAKAGE IN GROUND FLOOR REST ROOM AND NEED TO CHANGE PIPE	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	Wash basin tap changed and waste water pipe line fully rework, work completed		Elavazhagan. A. - Security - SIS	10/09/2022
Comp. Dt. : 16/09/2022 Status : Completed								
532	22090627	MEDICAL COLLEGE	BLOCK IN GROUND & I FLOOR COMMON REST ROOM	Govindan. R.	Ground floor and I Floor toilet block removed, work completed		Elavazhagan. A. - Security - SIS	17/09/2022
Comp. Dt. : 07/10/2022 Status : Completed								
533	22100137	MEDICAL COLLEGE III FLOOR	BLOCK IN FEMALE RESTROOM	Sakthivel. E.	Block removed.		Prabakaran. P. - Security - SIS	11/10/2022
Comp. Dt. : 08/10/2022 Status : Completed								
534	22100178	MEDICAL COLLEGE I FLOOR	GENTS REST ROOM BLOCK IN 1ST FLOOR	Sakthivel. E.	Block removed.		Prabakaran. P. - Security - SIS	11/10/2022
Comp. Dt. : 10/10/2022 Status : Completed								
535	22100212	MEDICAL COLLEGE I FLOOR	BLOCK IN MALE RESTROOM	Sakthivel. E.	Block removed.		Elavazhagan. A. - Security - SIS	11/10/2022
Comp. Dt. : 11/10/2022 Status : Completed								
536	22100273	MEDICAL COLLEGE III FLOOR	BLOCK IN MALE & FEMALE RESTROOM	Sakthivel. E.	Block removed.		Elavazhagan. A. - Security - SIS	11/10/2022
Comp. Dt. : 08/11/2022 Status : Completed								
537	22110293	MEDICAL COLLEGE	GROUND FLOOR BATHROOM BLOCK	Sakthivel. E.	Block removed.		Elavazhagan. A. - Security - SIS	10/11/2022
Comp. Dt. : 28/11/2022 Status : Completed								
538	22111185	MEDICAL COLLEGE I FLOOR	IN REST ROOM-WATER NOT COMING	Anandharaj. M.,Gopal. S.,Sellaveeran. M.	4th floor pipe line rework purpose valve closed, after finishing the work, valve opened, problem sol		Prabakaran. P. - Security - SIS	29/11/2022
Comp. Dt. : 26/12/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
539	22121172	MEDICAL COLLEGE	1ST FLOOR REST ROOM BLOCK	Sakthivel. E.	Block removed.		Prabakaran. P. - Security - SIS	27/12/2022
	Comp. Dt. : 03/01/2023							
	Status : Completed							
540	23010081	MEDICAL COLLEGE GROUND FLOOR	IN MALE TOILET-FLUSH TANK WATER LEAKAGING PROBLEM	Prakash. V.,Rajendran. R.,Ramkumar. R.	Flush tank rework done.		Elavazhagan. A. - Security - SIS	05/01/2023
	Comp. Dt. : 05/01/2023							
	Status : Completed							
541	23010225	MEDICAL COLLEGE GROUND FLOOR	MALE TOILET-FLUSH TANK NOT WORKING	Prakash. V.,Rajendran. R.,Ramkumar. R.	Flush tank rework done.		Elavazhagan. A. - Security - SIS	07/01/2023
	Comp. Dt. : 23/01/2023							
	Status : Completed							
542	23010833	MEDICAL COLLEGE I FLOOR	BLOCK - I FLOOR NEAR WASH BASIN	Sakthivel. E.,Govindan. R.,Murugan. S.	Block removed.		Prabakaran. P. - Security - SIS	23/01/2023
	Comp. Dt. : 04/05/2023							
	Status : Completed							
543	23050177	PHARMACOLOGY	NEED TO CHANGE TAP - WATER LEAKAGE AT II FLOOR PHARMACOLOGY	Prakash. V.,Rajendran. R.,Ramkumar. R.	TAP CHANGED.		Prabakaran. P. - Security - SIS	05/05/2023
	Comp. Dt. : 06/05/2023							
	Status : Completed							
544	23050245	MEDICAL COLLEGE GROUND FLOOR	NEED TO REFIX BUSH E W C FOR FEMEALE RESTROOM	Prakash. V.,Rajendran. R.,Ramkumar. R.	1.1/4" back bush changed, problem solved		Prabakaran. P. - Security - SIS	09/05/2023
	Comp. Dt. : 07/06/2023							
	Status : Completed							
545	23060231	MEDICAL COLLEGE I FLOOR	TAP WATER BLOCK AT I FLOOR RESTROOM NEAR	Sakthivel. E.	BLOCK REMOVED.		Pitchaimuthu. P. - Security - SIS	08/06/2023
	Comp. Dt. : 16/06/2023							
	Status : Completed							
546	23060610	MEDICAL COLLEGE I FLOOR	NEAR GENTS REST ROOM TAP WATER LEAKAGE PROBLEM	Prakash. V.,Rajendran. R.,Ramkumar. R.	Tap rework done		Prabakaran. P. - Security - SIS	20/06/2023
	Comp. Dt. : 17/06/2023							
	Status : Completed							
547	23060639	DISSERTION HALL IN MEDICAL COLLEGE	DRAINAGE WATER BLOCK - NEED URGENT SERVICE	Govindan. R.,Gnanasegaran. K.,Kathirvelu. K.	block removed.		Prabakaran. P. - Security - SIS	19/06/2023

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Dept Name : UHC Villupuram - Civil - Maintenance Comp. Dt. : 30/01/2023 Status : Completed								
548	23011034	ASSOCIATIVE PROFESSOR QUARTERS	NEED TO CHANGE RESTROOM TAP - DAMAGE - WATER LEAKAGE - QUARTERS NO B 11	Prakash. V.,Rajendran. R.,Ramkumar. R.	New tap spindle changed, problem solved		Asaithambi. R. - UHC Villupuram	02/02/2023
Dept Name : Ward - Civil - Maintenance Comp. Dt. : 02/06/2022 Status : Completed								
549	22060087	PHYSIOLOGY--COLLEGE	NEED TO CHANGE WASH BASIN TAP - WATER LEAKAGE	Udhaya Kumar. R.,Sellaveeran. M.,Azhagar. N.	2nos. of water basin changed.		Gowri.V. - PHYSIOLOGY	07/06/2022
Work Type : Work Dept Name : ANATOMY - Civil - Maintenance Comp. Dt. : 26/07/2022 Status : Completed								
550	22070978	ANATOMY	NEED LABOURS 5 NOS FOR SHIFTING STOOLS [30 NOS] FROM ANATOMY TO WORKSHOP	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	Stools shifting work completed		Mathivanan.B. - ANATOMY	01/08/2022
Dept Name : BIOCHEMISTRY - Civil - Maintenance Comp. Dt. : 10/05/2022 Status : Completed								
551	22050358	BIOCHEMISTRY	NEED LABOURS 4 NOS FOR CENTRIFUGE SHIFTING WORK FROM II FLOOR TO I FLOOR	Pandiaraj. V.,Yuvaraj. M.,Thulasi. V.	Machine shifting work completed		Anusuya. J. - BIOCHEMISTRY	14/05/2022
Comp. Dt. : 07/12/2022 Status : Completed								
552	22120322	BIOCHEMISTRY--COLLEGE	NEED LABOURS 2NOS FOR SHIFTING WORK	Pandiaraj. V.,Yuvaraj. M.,Thulasi. V.	Shifting work completed.		Suganthi. P. - BIOCHEMISTRY	09/12/2022
Comp. Dt. : 15/03/2023 Status : Completed								
553	23030622	BIOCHEMISTRY--COLLEGE	NEED MANPOWER 3 NOS FOR BERO SHIFTING WORK FROM BIOCHEMISTRY TO WORKSHOP	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	BERO SHIFTED FROM BIOCHEMISTRY TO WORKSHOP	 Dr. KAGNE. R.N DEAN SRI MANAKULA VINAYAGAR MEDICAL COLLEGE & HOSPITAL KALITHEERTHALKUPPAM, PUDUCHERRY-605107.	Suganthi. P. - BIOCHEMISTRY	20/03/2023

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Dept Name : COMMUNITY MEDICINE - Civil - Maintenance Comp. Dt. : 07/06/2022 Status : Completed								
554	22060235	MEDICAL COLLEGE GROUND FLOOR	NEED LABOURS 4 NOS FOR TABLE ARRANGEMENT WORK AT OWN BOOK READING HALL	Pandiaraj. V.,Murali. K.,Senthil Kumar. R.	Table arrangement work done		Rajesh. D. - COMMUNITY MEDICINE	07/06/2022
Comp. Dt. : 14/06/2022 Status : Completed								
555	22060516	MEDICAL COLLEGE GROUND FLOOR	NEED LABOURS 4 NOS FOR MEETING ARRANGEMENT WORK AT OWN BOOK READING HALL AT 14.06.2022 @ 2 P.M	Pandiaraj. V.,Yuvaraj. M.,Murali. K.	Meeting arrangement work done.		Rajesh. D. - COMMUNITY MEDICINE	17/06/2022
Comp. Dt. : 05/10/2022 Status : Completed								
556	22100052	MEDICAL COLLEGE I FLOOR	NEED LABOURS 6 NOS FOR TABLE ARRANGEMENT WORK FOR OWN BOOK READING HALL	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	Table arrangement work completed.		Raghavendran. V. - COMMUNITY MEDICINE	07/10/2022
Comp. Dt. : 10/10/2022 Status : Completed								
557	22100221	MEDICAL COLLEGE -READING HALL IN GROUND FLOOR	NEED LABOURS 4 NOS FOR TABLE ARRANGEMENT WORK	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	Table arrangement work done.		Raghavendran. V. - COMMUNITY MEDICINE	11/10/2022
Comp. Dt. : 05/01/2023 Status : Completed								
558	23010202	PHYSIOLOGY-- -COLLEGE	NEED LOBOURS 4 NO'S FOR BERO SHIFTING WORK	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	Bero shifting work completed		Raghavendran. V. - COMMUNITY MEDICINE	09/01/2023
Dept Name : Computer Department - Civil - Maintenance Comp. Dt. : 13/09/2022 Status : Completed								
559	22090486	DIGITAL LAB	NEED LABOUR 2 NOS FOR SHIFTING TABLE FROM DIGITAL LAB TO WORKSHOP	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	work completed.		Jayaraj. J. - Computer Department	15/09/2022
Comp. Dt. : 07/03/2023 Status : Completed								
560	23030249	MEDICAL COLLEGE LIBRARY	NEED LABOUR 1 NO FOR RACK REMOVING WORK	Pandiaraj. V.	RACK REMOVING WORK DONE.		Abdullah. R. - Computer Department	07/03/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Dept Name : Director Office - Civil - Maintenance Comp. Dt. : 14/09/2022 Status : Completed								
561	22090519	MEDICAL COLLEGE -READING HALL IN GROUND FLOOR	DUE TO WORKSHOP TO BE HELD ON 15.09.2022 - NEED MANPOWER [4 NOS] FOR READING HALL SEATING ARRANGE	Pandiaraj. V.,Senthil Kumar. R.,Yuvaraj. M.	Arrangement work done.		Vijai. A. - COMMUNITY MEDICINE	21/09/2022
Comp. Dt. : 03/05/2023 Status : Completed								
562	23050099	Lecture Hall IV	NEED MANPOWER 4 NOS FOR CHAIR ARRANGEMENT WORK FOR INSPECTION PURPOSE	Pandiaraj. V.,Yuvaraj. M.,Thulasi. V.	Chair arrangement work completed		Prasanna.B. - Director Office	04/05/2023
Comp. Dt. : 06/05/2023 Status : Completed								
563	23050228	Lecture Hall IV	NEED MANPOWER 4 NOS FOR CHAIR ARRANGEMENT WORK	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	CHAIR ARRANGEMENT WORK COMPLETED		Prasanna.B. - Director Office	13/05/2023
Dept Name : FORENSIC MEDICINE - Civil - Maintenance Comp. Dt. : 25/06/2022 Status : Completed								
564	22060914	FORENSIC MEDICINE (3RD FLOOR) IN COLLEGE	NEED LABOURS 2 NOS FOR SHIFTING WORK [CHAIRS & TROLLEYS FOR REPAIRING WORK] FROM FORENSIC MEDICINE	Pandiaraj. V.,Yuvaraj. M.,Murali. K.	Shifting work done		Mathavi. B. - FORENSIC MEDICINE	25/06/2022
Comp. Dt. : 20/02/2023 Status : Completed								
565	23020740	FORENSIC MEDICINE (3RD FLOOR) IN COLLEGE	NEED MANPOWER 2 NOS FOR SHIFTING WORK - NEED URGENT SERVICE	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	MATERIALS SHIFTING WORK DONE		Mathavi. B. - FORENSIC MEDICINE	21/02/2023
Comp. Dt. : 24/03/2023 Status : Completed								
566	23030988	FORENSIC MEDICINE (3RD FLOOR) IN COLLEGE	NEED MANPOWER 4 NOS FOR SHIFTING WORK LIBRARY CUPBOARD	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	CUPBOARD SHIFTING WORK COMPLETED		Mathavi. B. - FORENSIC MEDICINE	25/03/2023
Comp. Dt. : 05/04/2023 Status : Completed								
567	23040170	FORENSIC MEDICINE (3RD FLOOR) IN COLLEGE	NEED MANPOWER 2 NOS FOR CHAIR SHIFTING WORK	Pandiaraj. V.	CHAIR SHIFTING WORK		Mathavi. B. - FORENSIC MEDICINE	08/04/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 30/06/2023 Status : Completed								
568	23061106	FORENSIC MEDICINE (3RD FLOOR) IN COLLEGE	NEED MANPOWER 2 NOS FOR CHAIR ARRANGEMENT WORK	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	WORK COMPLETED		Mathavi. B. - FORENSIC MEDICINE	04/07/2023
Dept Name : Housekeeping - Civil - Maintenance Comp. Dt. : 19/04/2023 Status : Completed								
569	23040587	Main Gate	NEED MANPOWER 2NOS FOR BANNER FIXING WORK AT MAIN GATE - [NEED AT 3 P.M.]	Pandiaraj. V.,Yuvaraj. M.,Thulasi. V.	Banner fixing work completed		Elangchezhiyan. R. - Housekeeping	02/05/2023
Dept Name : Library - Civil - Maintenance Comp. Dt. : 20/04/2023 Status : Completed								
570	23040666	BASEMENT AUDITORIUM	NEED MANPOWER 4 NOS FOR CHAIR SHIFTING WORK FROM BASEMENT AUDITORIUM TO MEDICAL COLLEGE	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	Chair shifting work completed		Elangovan.N. - Library	02/05/2023
Dept Name : MICROBIOLOGY - Civil - Maintenance Comp. Dt. : 12/08/2022 Status : Completed								
571	22080429	MICROBIOLOGY IN COLLEGE	NEED LABOUR 2 NOS FOR UNLOADING "RECORD PAPERS " FROM MICROBIOLOGY TO STORE ROOM	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	Unloading work completed.		Buvana. C. - MICROBIOLOGY	18/08/2022
Comp. Dt. : 14/06/2023 Status : Completed								
572	23060518	MICROBIOLOGY IN COLLEGE	NEED LABOURS 2 NOS FOR SHIFTING FRIDGE [INTERNAL]	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	FRIDGE SHIFTING WORK COMPLETED		Gopal. R. - MICROBIOLOGY	04/07/2023
Dept Name : MS Office - Civil - Maintenance Comp. Dt. : 11/10/2022 Status : Completed								
573	22100277	SKILL LAB - MEDICAL COLLEGE	NEED LABOURS 4 NOS FOR FLOOR MAT REFIXING WORK	Pandiaraj. V.	Mat Refixing work completed	 Dr. KAGNE. R.N DEAN SRI MANAKULA VINAYAGAR MEDICAL COLLEGE & HOSPITAL KALITHEERTHALKUPPAM, PUDUCHERRY-605107.	Elumalai. M. - MS Office	13/10/2022
Comp. Dt. : 18/11/2022 Status : Completed								

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
574	22110777	SKILL LAB - MEDICAL COLLEGE	NEED LABOURS 2 NOS FOR TABLE SHIFTING WORK FROM HOSPITAL TO MEDICAL COLLEGE - [INTERCOM NO 2001]	Pandiaraj. V.,Yuvaraj. M.,Murali. K.	Table shifting work completed.		Elumalai. M. - MS Office	28/11/2022
Comp. Dt. : 20/03/2023 Status : Completed								
575	23030780	SKILL LAB - MEDICAL COLLEGE	NEED MANPOWER 4 NOS FOR TV SHIFTING WORK	Pandiaraj. V.,Yuvaraj. M.,Thulasi. V.	TV SHIFTING WORK COMPLETED		Jayasri. S. - Skill Lab	21/03/2023
Comp. Dt. : 30/06/2023 Status : Completed								
576	23061105	SKILL LAB - MEDICAL COLLEGE	NEED MANPOWER 4 NOS FOR MANNEQUIN SHIFTING WORK FROM NURSING COLLEGE TO SKILL LAB	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	MANNEQUIN SHIFTING WORK COMPLETED		Elumalai. M. - MS Office	04/07/2023
Dept Name : Nephrology - Civil - Maintenance Comp. Dt. : 30/05/2023 Status : Completed								
577	23051184	FORENSIC MEDICINE	NEED MANPOWER 2NOS FOR TABLE SHIFTING WORK	Pandiaraj. V.,Yuvaraj. M.,Thulasi. V.	work completed		Mathanraj. M. - Nephrology	31/05/2023
Dept Name : PATHOLOGY - Civil - Maintenance Comp. Dt. : 06/09/2022 Status : Completed								
578	22090205	Work Shop	NEED LABOURS 4NOS FOR SHIFTING TABLE FROM WORKSHOP TO PATHOLOGY IN COLLEGE	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	work completed.		Sathia Rajesh. C. - PATHOLOGY	10/09/2022
Comp. Dt. : 22/09/2022 Status : Completed								
579	22090905	PATHOLOGY IN COLLEGE	NEED MANPOWER 2NO FOR T V SHIFTING WORK FROM I FLOOR TO II FLOOR	Pandiaraj. V.,Yuvaraj. M.,Thulasi. V.	TV Shifting work completed		Sathia Rajesh. C. - PATHOLOGY	23/09/2022
Comp. Dt. : 24/03/2023 Status : Completed								
580	23031013	PATHOLOGY IN COLLEGE	NEED MANPOWER 2 NOS FOR BERO SHIFTING WORK	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	BERO SHIFTINGQWORK COMPLETES		Thavamani. K. - PATHOLOGY	25/03/2023
Dept Name : PHARMACOLOGY - Civil - Maintenance								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 11/02/2023 Status : Completed								
581	23020447	PHARMACOLOGY	NEED MANPOWER 4 NOS FOR INTERNAL SHIFTING WORK	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	INTERNAL SHIFTING WORK COMPLETED.		Devanathan. S. - PHARMACOLOGY	16/02/2023
Dept Name : PHYSIOLOGY - Civil - Maintenance Comp. Dt. : 08/09/2022 Status : Completed								
582	22090321	Work Shop	NEED LABOURS 2 NOS FOR CARRYING PLYWOOD SHEETS 2 NOS FROM WORKSHOP TO PHYSIOLOGY	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	work completed		Balasankar. P. - PHYSIOLOGY	10/09/2022
Comp. Dt. : 03/02/2023 Status : Completed								
583	23020105	PHYSIOLOGY--COLLEGE	NEED MANPOWER 3 NOS FOR SHIFTING WORK FROM PHYSIOLOGY TO FORENSIC MEDICINE	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	Machines shifting work completed		Jayanthi.A. - PHYSIOLOGY	07/02/2023
Comp. Dt. : 09/03/2023 Status : Completed								
584	23030352	PHYSIOLOGY--COLLEGE	NEED MANPOWER 2 NOS FOR ROOM CHANGING WORK [INSTRUCTIONS GIVEN BY DEAN SIR]	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	AS PER DEAN SIR INSTRUCTION ROOM CHANGING WORK DONE.		Shanthini. M. - BIOCHEMISTRY	17/03/2023
Comp. Dt. : 23/03/2023 Status : Completed								
585	23030946	PHYSIOLOGY--COLLEGE	NEED MANPOWER 5 NOS FOR BERO SHIFTING WORK	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	BERO SHIFTING WORK COMPLETED		Balasankar. P. - PHYSIOLOGY	25/03/2023

College Name : SMVMCH-HOS

Work Type : Complaint

Dept Name : Administration - Civil - Maintenance

Comp. Dt. : 04/05/2022

Status : Completed

586 22050082 AO Office
NEED TO CHANGE HAND SHOWER FOR REGISTRAR ROOM [DAMAGE - WATER LEAKAGE]

Prakash. V.
New health faucet changed.

Kanimozhi. D. - Administration

04/05/2022

Comp. Dt. : 18/05/2022

Status : Completed

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
587	22050680	Main Gate	NEED LABOURS 4 NOS FOR UNLOADING PAPER BUNDALS FROM GATE TO BASEMENT STORE	Pandiaraj. V.,Yuvaraj. M.,Thulasi. V.	Paper bundle unloading work completed		Motheeswarar. R.S. - Administration	21/05/2022
Comp. Dt. : 14/06/2022 Status : Completed								
588	22060500	AO Office	NEED TO REFIX HAND SHOWER FOR FEMALE STAFF REST ROOM	Arunagiri. V.	Health faucet fixed.		Kanimozhi. D. - Administration	23/06/2022
Comp. Dt. : 27/06/2022 Status : Completed								
589	22060968	AO Office	MALE RESTROOM BLOCK - NEED URGENT SERVICE	Rajendhiran. V.	Block removed.		Santhosh Raja. K. - Administration	28/06/2022
Comp. Dt. : 15/07/2022 Status : Completed								
590	22070602	General Stores[Linen]	NEED TO CHECK DUCT PIPE LINE - WATER LEAKAGE INSIDETHE STORE	Prakash. V.,Rajendran. R.,Manikandan. S.	Special clinic #100 - duct line block, so floor leakage problem, duct line fully rework, leakage arr		Motheeswarar. R.S. - Administration	16/07/2022
Comp. Dt. : 22/07/2022 Status : Completed								
591	22070829	AO Office	DUE TO HEAVY RAIN METAL RUBBY SHEET IN BACK SIDE OF AO OFFICE FELL DOWN NEED TO REFIX	Pandiaraj. V.,Thulasi. V.,Prakash. N.	Metal rubby sheet shifted.		Gomathy. K. - Administration	26/07/2022
Comp. Dt. : 03/08/2022 Status : Completed								
592	22080122	Chairman Office	WATER NOT COMING IN CONFERENCE HALL WASH BASIN TAP - NEED TO CHECK & CHANGE	Prakash. V.,Arunagiri. V.,Ramkumar. R.	Sink Elbow action pillar cock and hot & Cold tap filter cleaned and serviced, rework the tap, proble		Sadhasivam. K. - Administration	04/08/2022
Comp. Dt. : 17/08/2022 Status : Completed								
593	22080539	GENERAL STORE	NEED MANPOWER TO SHIFT EQUIPEMENT FROM MAIN ENTRANCE TO STORE	Pandiaraj. V.,Yuvaraj. M.,Thulasi. V.	shifting work done.		Manikandan. S. - Administration	23/08/2022
Comp. Dt. : 22/08/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
594	22080710	AO Office	SINK BLOCK - NEED URGENT SERVICE	Rajendhiran. V.,Thanuzkodi. E.,Murugan. S.	Block removed.		Kadhiravan. C. - Administration	23/08/2022
	Comp. Dt. : 23/08/2022							
	Status : Completed							
595	22080750	Paediatrics - OPD	NEED TO CHANGE R O DRINKING WATER TAP - WATER LEAKAGE	Prakash. V.,Rajendran. R.,Ramkumar. R.	Bush changed.		Arulkumaran. S. - Administration	24/08/2022
	Comp. Dt. : 06/09/2022							
	Status : Completed							
596	22090233	AO Office	BLOCK IN MALE RESTROOM	Rajendhiran. V.,Murugan. R.,Thanuzkodi. E	block removed.		Karthik. K. - Administration	07/09/2022
	Comp. Dt. : 12/10/2022							
	Status : Completed							
597	22100339	GENERAL STORE	2 NO'S LABOUR NEED FOR SHIFTING WORK	Pandiaraj. V.	Machine shifting work done.		Manikandan. S. - Administration	13/10/2022
	Comp. Dt. : 09/11/2022							
	Status : Completed							
598	22110354	GENERAL STORE	WATER LEAKAGING FROM WALL CEILING	Prakash. V.,Rajendran. R.,Ramkumar. R.	Water leakage arrested.		Manikandan. S. - Administration	10/11/2022
	Comp. Dt. : 15/11/2022							
	Status : Completed							
599	22110599	GENERAL STORE	NEED LABOURS FOR MEDICINE COVER SHIFTING PURPOSE(FROM NEAR FREE PHARMACY)	Pandiaraj. V.,Yuvaraj. M.,Thulasi. V.	Shifitng work completed		Manikandan. S. - Administration	16/11/2022
	Comp. Dt. : 01/12/2022							
	Status : Completed							
600	22120006	Chairman Office	WATER NOT COMING IN WASH BASIN AT V.C SIR OFFICE ROOM	Vengatesan. V.	tap filter rework done.		Sadhasivam. K. - Administration	05/12/2022
	Comp. Dt. : 16/12/2022							
	Status : Completed							
601	22120760	GENERAL STORE	NEED MANPOWER TO SHIFT MATERIALS FROM GASPLANT TO GENERAL STORE	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	Materials shifting work completed		Manikandan. S. - Administration	20/12/2022
	Comp. Dt. : 30/12/2022							


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
602	22121367	GENERAL STORE	NEED MANPOWER FOR MATERIALS SHIFT FROM MAIN GATE	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	Hospital materials shifting work completed		Manikandan. S. - Administration	31/12/2022
Comp. Dt. : 21/01/2023								
Status : Completed								
603	23010754	AO Office	URINAL BLOCK AT MALE RESTROOM	Rajendhiran. V.,Thanuzkodi. E,Murugan. S.	block removed.		Karthik. K. - Administration	21/01/2023
604	23010767	Main Lobby	NEED LABOURS 5 NOS FOR INSTRUMENT SHIFTING WORK FROM MAIN PORTIGO TO BASEMENT GENERAL STORES	Pandiaraj. V.,Yuvaraj. M.,Thulasi. V.	Machine shifting work completed		Motheeswarar. R.S. - Administration	21/01/2023
Comp. Dt. : 14/02/2023								
Status : Completed								
605	23020529	AO Office	FLUSH WATER NOT COMING - S A O SIR ROOM	Azhagar. N.,Udhaya Kumar. R.,Sivaraja. M.	FLUSH TANK REWORK DONE.		Gomathy. K. - Administration	15/02/2023
Comp. Dt. : 20/03/2023								
Status : Completed								
606	23030819	MEDICAL STORE IN BASEMENT	CEILING WALL & SIDE WALL WATER LEAKAGE IN MEDICAL STORES - NEED URGENT SERVICE	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	FIRE PIPELINE LEAKAGE.		Sathiyamoorthy. D. - Administration	22/03/2023
Comp. Dt. : 04/04/2023								
Status : Completed								
607	23040092	Main Lobby	NEED LABOURS 4 NOS FOR UNLOADING WORK [CHAIR] FROM MAIN LOBBY TO BASEMENT GENERAL STORES	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	CHAIRS UNLOADED FROM MAIN PORTICO TO BASEMENT GENERAL STORE		Arulkumaran. S. - Administration	04/04/2023
Comp. Dt. : 05/04/2023								
Status : Completed								
608	23040146	Main Lobby	NEED MANPOWER 2 NOS FOR UNLOADING WORK FROM MAIN LOBBY TO BASEMENT STORE	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	WORK COMPLETED		Motheeswarar. R.S. - Administration	05/04/2023
Comp. Dt. : 06/04/2023								
Status : Completed								
609	23040204	AO Office	NEED TO SPRAY " MASQUITO SPRAY " DAILY EVENING	Kannan. V.	MOSQUITO REPELLANT SPRAYED.		Thiravan. C. - Administration	15/04/2023

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHAL KUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 19/05/2023 Status : Completed								
610	23050810	AO Office	NEED SERVICE FOR WATER PURIFYER	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	AC COMPLAINT		Gomathy. K. - Administration	24/05/2023
Comp. Dt. : 28/06/2023 Status : Completed								
611	23061060	General Stores[Linen]	STORE INSIDE WALL - WATER LEAKAGE - NEED TO CHECK	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	Portico block removed. Water leakage problem rectified.		Motheeswarar. R.S. - Administration	30/06/2023
Dept Name : Air Condition Department - Civil - Maintenance Comp. Dt. : 20/05/2022 Status : Completed								
612	22050778	CHILLER IN HOSPITAL TERROUS	NEED A NEW PIPE LINE CONNECTION	Prakash. V.	1/2" valve changed, problem solved		Babu. D. - Air Condition Department	24/05/2022
Comp. Dt. : 23/08/2022 Status : Completed								
613	22080765	Casualty	NEED CLEANING & CUTTING UNWANTED TREES AT BACK SIDE OF EMERGENCY CASUALTY	Pandiaraj. V.	Unwanted trees were cut		Panneer Selvam. P. - Air Condition Department	03/09/2022
Comp. Dt. : 29/08/2022 Status : Completed								
614	22080965	AHU Room-1ST FLOOR	BLOCK - BACK SIDE OF A H U ROOM I FLOOR - NEED TO CLEAR	Govindan. R.,Thanuzkodi. E.,Rajendran. R.	4" pipe line rework, dummy fixed, work completed		Panneer Selvam. P. - Air Condition Department	05/09/2022
Comp. Dt. : 22/09/2022 Status : Completed								
615	22090899	General Medicine	DRAINAGE BLOCK - BACK SIDE OF MEDICINE OPD	Rajendhiran. V.,Murugan. S.,Thanuzkodi. E	block removed.		Thulasi Daran. R. - Air Condition Department	24/09/2022
Comp. Dt. : 21/10/2022 Status : Completed								
616	22100714	CHILDREN'S PLAY GROUND INSIDE HOSPITAL	WATER LEAKAGING FROM 2ND FLOOR CARDIOLOGY OPD INTO GROUND FLOOR	Prakash. V.,Rajendran. R.,Ramkumar. R.	A/C complaint. Not a plumbing complaint.		Panneer Selvam. P. - Air Condition Department	22/10/2022
Comp. Dt. : 06/01/2023 Status : Completed								
617	23010281	MEDICAL COLLEGE	CANTEEN WATER PIPE BROKEN	Prakash. V.,Rajendran. R.,Ramkumar. R.	Sump pipe line broken, 2" UPVC pipe line fully changed, work completed		Ramkumar. S. - Air Condition Department	18/01/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 21/01/2023 Status : Completed								
618	23010762	Female Casulaty	NEED TO CHECK DRAINAGE PIPELINE - WATER LEAKAGE AT BACK SIDE OF FEMALE CASULATY	Sivaraja. M.,Santhosh Kumar. M.,Udhaya Kumar. R.	2.1/2" PVC elbow broken, new elbow changed, work completed		Panneer Selvam. P. - Air Condition Department	21/01/2023
Comp. Dt. : 20/03/2023 Status : Completed								
619	23030798	CHILLER IN HOSPITAL TERROUS	NEED TO FIX A NEW VALVE FOR WATER PIPE LINE	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	valu chaning	den	Panneer Selvam. P. - Air Condition Department	10/04/2023
Dept Name : ANATOMY - Civil - Maintenance Comp. Dt. : 14/12/2022 Status : Completed								
620	22120650	ANATOMY	FLUSH NOT WORKING 2 NOS	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	Flush tank rework done.		Mathivanan.B. - ANATOMY	17/12/2022
Dept Name : BIOCHEMISTRY - Civil - Maintenance Comp. Dt. : 11/05/2022 Status : Completed								
621	22050384	Biochemistry Lab-Hospital	R O WATER TUBE FIXING WORK	Prakash. V.	New water hose changed.		Srinivasamurugan. V. - BIOCHEMISTRY	12/05/2022
Comp. Dt. : 16/05/2022 Status : Completed								
622	22050519	Blood Collection Centre	WATER LEAKAGE IN WASHING ROOM SINK	Prakash. V.	M seal fixing work done		Srinivasamurugan. V. - BIOCHEMISTRY	16/05/2022
Comp. Dt. : 20/05/2022 Status : Completed								
623	22050750	COMMON FEMALE TOILET NEAR BIOCHEMISTRY	WATER NOT COMING	Prakash. V.,Ramkumar. R.,Rajendran. R.	Tap and helath faucet filter cleaned and serviced, problem solved		Sangeetha. S. - BIOCHEMISTRY	21/05/2022
Comp. Dt. : 25/05/2022 Status : Completed								
624	22050959	COMMON MALE TOILET NEAR BIOCHEMISTRY	NEED TO CHECK WHERE WATER LEAKAGE - NEED URGENT SERVICE - BAD SMELL	Thanuzkodi. E.,Govindan. R.,Sakthivel. E.	Toilet block removed, work completed		Sathyamurugan. E. - BIOCHEMISTRY	25/05/2022
Comp. Dt. : 01/06/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
625	22060001	COMMON MALE TOILET NEAR BIOCHEMISTRY	FLUSH NOT WORKING	Arunagiri. V.,Prakash. V.,Rajendran. R.	Flush tank fullset rework and serviced, problem solved		Sathyamurugan. E. - BIOCHEMISTRY	01/06/2022
Comp. Dt. : 07/06/2022 Status : Completed								
626	22060262	BIOCHEMISTRY	NEED TO CHANGE DISTILLED WATER FILTER	Prakash. V.	Micron Filter and Carbon filter changed, problem solved		Srinivasamurugan. V. - BIOCHEMISTRY	08/06/2022
Comp. Dt. : 24/06/2022 Status : Completed								
627	22060868	Blood Collection Centre	NEED TO CHANGE SINK TAP - WATER LEAKAGE & TAP DAMAGE	Ramkumar. R.,Rajendran. R.,Prakash. V.	New sink tap rework.		Srinivasamurugan. V. - BIOCHEMISTRY	28/06/2022
Comp. Dt. : 30/06/2022 Status : Completed								
628	22061130	BIOCHEMISTRY	DISTILLED WATER PLANT LEAKAGE	Prakash. V.,Ramkumar. R.,Rajendran. R.	RO Water hose rework, work completed		Srinivasamurugan. V. - BIOCHEMISTRY	04/07/2022
Comp. Dt. : 16/07/2022 Status : Completed								
629	22070627	COMMON MALE TOILET NEAR BIOCHEMISTRY	BLOCK -	Rajendhiran. V.	Block removed		Srinivasamurugan. V. - BIOCHEMISTRY	18/07/2022
Comp. Dt. : 18/07/2022 Status : Completed								
630	22070681	BIOCHEMISTRY-- -COLLEGE	NEED TO CHANGE TAP - WATER LEAKAGE	Azhagar. N.,Anandharaj. M.,Sellaveeran. M.	1.1/4" Waste coupling, waste hose changed, work completed		Suganthi. P. - BIOCHEMISTRY	20/07/2022
Comp. Dt. : 02/08/2022 Status : Completed								
631	22080060	COMMON MALE TOILET NEAR BIOCHEMISTRY	BLOCK IN MALE RESTROOM	Rajendhiran. V.	Block removed.		Srinivasamurugan. V. - BIOCHEMISTRY	03/08/2022
632	22080072	BIOCHEMISTRY	NEED TO CHANGE SINK TAP - DAMAGE & WATER LEAKAGE AT WASHING ROOM	Prakash. V.	Spindle has been changed in elbow action tap		Srinivasamurugan. V. - BIOCHEMISTRY	03/08/2022
Comp. Dt. : 22/08/2022 Status : Completed								
633	22080708	COMMON MALE TOILET NEAR BIOCHEMISTRY	BLOCK AND BAD SMELL - NEED TO CHECK - NEED URGENT SERVICE	Rajendhiran. V.,Thanuzkodi. E.,Murugan. S.	Block removed.		Srinivasamurugan. V. BIOCHEMISTRY	23/08/2022
Comp. Dt. : 05/09/2022								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
634	22090198	BIOCHEMISTRY	NEED TO REPLACE DISTILLED WATER FILTER	Prakash. V.,Rajendran. R.,Ramkumar. R.	Sand filter and carbon filter changed, work completed		Srinivasamurugan. V. - BIOCHEMISTRY	09/09/2022
Comp. Dt. : 08/10/2022								
Status : Completed								
635	22100194	TOILET NEAR CLINICAL PATHOLOGY	REST ROOM BLOCK	Rajendhiran. V.,Thanuzkodi. E.,Murugan. S.	Block removed.		Sathyamurugan. E. - BIOCHEMISTRY	11/10/2022
Comp. Dt. : 17/10/2022								
Status : Completed								
636	22100511	COMMON MALE TOILET NEAR BIOCHEMISTRY	NEED TO REFIX FLUSH TANK - DAMAGE & BROKEN AT STAFF REST ROOM	Prakash. V.,Rajendran. R.,Ramkumar. R.	Flush tank refixed in the clamp		Srinivasamurugan. V. - BIOCHEMISTRY	19/10/2022
Comp. Dt. : 28/10/2022								
Status : Completed								
637	22100933	COMMON MALE TOILET NEAR BIOCHEMISTRY	TOILET BLOCKED,NEED SCAVENGER	Rajendhiran. V.,Thanuzkodi. E.,Murugan. S.	Block removed.		Sathyamurugan. E. - BIOCHEMISTRY	29/10/2022
Comp. Dt. : 29/10/2022								
Status : Completed								
638	22100957	COMMON TOILET NEAR BLOOD BANK	RESTROOM BLOCK NEAR MICROBIOLOGY LAB	Rajendhiran. V.	Block removed.		Srinivasamurugan. V. - BIOCHEMISTRY	31/10/2022
Comp. Dt. : 03/11/2022								
Status : Completed								
639	22110057	COMMON MALE TOILET NEAR BIOCHEMISTRY	RESTROOM BLOCK	Rajendhiran. V.,Murugan. S.,Thanuzkodi. E	Block removed.		Srinivasamurugan. V. - BIOCHEMISTRY	03/11/2022
640	22110060	Biochemistry Lab-Hospital	IN MALE REST ROOM- WESTERN TOILET FLUSH TANK PIPE DAMAGE	Prakash. V.,Rajendran. R.,Ramkumar. R.	Flush tank leakage arrested. Flush tank and health faucet rework done.		Srinivasamurugan. V. - BIOCHEMISTRY	09/11/2022
Comp. Dt. : 05/11/2022								
Status : Completed								
641	22110179	COMMON MALE TOILET NEAR BIOCHEMISTRY	TOILET BLOCKED,NEED SCAVENGER	Rajendhiran. V.,Thanuzkodi. E.,Murugan. S.	block removed.		Srinivasamurugan. V. - BIOCHEMISTRY	08/11/2022
Comp. Dt. : 26/11/2022								
Status : Completed								
642	22111129	Biochemistry Lab-Hospital	WATER NOT COMING ON LAB SIDE WING	Prakash. V.,Rajendran. R.,Ramkumar. R.	Uniqcore connstruction broken the pipe. New pipe connected.		Srinivasamurugan. V. - BIOCHEMISTRY	28/11/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 21/12/2022 Status : Completed								
643	22120951	COMMON FEMALE TOILET NEAR BIOCHEMISTRY	REST ROOM BLOCK	Thanuzkodi. E,Rajendhiran. V.,Murugan. S.	Block removed.		Nirmala.B. - BIOCHEMISTRY	21/12/2022
Comp. Dt. : 09/01/2023 Status : Completed								
644	23010338	COMMON FEMALE TOILET NEAR LAB SIDE	TOILET BLOCKED,NEED SCAVENGER	Rajendhiran. V.,Thanuzkodi. E,Murugan. S.	Block removed.		Srinivasamurugan. V. - BIOCHEMISTRY	10/01/2023
Comp. Dt. : 12/01/2023 Status : Completed								
645	23010520	COMMON MALE TOILET NEAR BIOCHEMISTRY	TOILET BLOCKED,NEED SCAVENGER	Rajendhiran. V.,Thanuzkodi. E,Murugan. S.	block removed.		Srinivasamurugan. V. - BIOCHEMISTRY	12/01/2023
Comp. Dt. : 18/01/2023 Status : Completed								
646	23010603	COMMON MALE TOILET NEAR BIOCHEMISTRY	BLOCK - NEED URGENT SERVICE	Rajendhiran. V.,Murugan. S.,Thanuzkodi. E	block removed.		Srinivasamurugan. V. - BIOCHEMISTRY	20/01/2023
Comp. Dt. : 21/03/2023 Status : Completed								
647	23030858	BIOCHEMISTRY	NEED TO REPLACE DISTILLED WATER FILTER	Sellaveeran. M.,Udhaya Kumar. R.,Santhosh Kumar. M.	DISTILLED WATER FILTER (3NOS.) CHANGED.		Srinivasamurugan. V. - BIOCHEMISTRY	23/03/2023
Comp. Dt. : 14/06/2023 Status : Completed								
648	23060510	COMMON FEMALE TOILET NEAR BIOCHEMISTRY	TAP BROKEN - WATER FLOW - NEED URGENT SERVICE	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	TAP CHANGED.		Srinivasamurugan. V. - BIOCHEMISTRY	15/06/2023
Comp. Dt. : 20/06/2023 Status : Completed								
649	23060697	BIOCHEMISTRY	NEED TO CHANGE DISTILLED WATER FILTER	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	Distilled water filter changed.		Srinivasamurugan. V. - BIOCHEMISTRY	22/06/2023
Comp. Dt. : 21/06/2023 Status : Completed								
650	23060738	COMMON MALE TOILET NEAR BIOCHEMISTRY	BLOCK - NEED URGENT SERVICE	Rajendhiran. V.,Murugan. S.,Thanuzkodi. E	Block removed.		Srinivasamurugan. V. - BIOCHEMISTRY	22/06/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 27/06/2023 Status : Completed								
651	23061026	BIOCHEMISTRY	PROBLEM IN EYE WASHER	Sivaraja. M.,Santhosh Kumar. M.,Gopal. S.	Eye washer block removed and serviced.		Srinivasamurugan. V. - BIOCHEMISTRY	30/06/2023
Dept Name : Biomedical - Civil - Maintenance Comp. Dt. : 25/04/2023 Status : Completed								
652	23040819	Biomedical	NEED MANPOWER 4 NOS FOR INSTRUMENT SHIFTING WORK FROM BIOMEDICAL TO BASEMENT GENERAL SOTRES	Pandiaraj. V.,Yuvaraj. M.,Thulasi. V.	Shifting work completed		Sridhar. K. - Biomedical	03/05/2023
Dept Name : BLOOD BANK - Civil - Maintenance Comp. Dt. : 03/06/2022 Status : Completed								
653	22060136	Mit ladies hostel	NEED TO REMOVE INSECT NEST FOR WINDOW SIDE [BACK SIDE OF ROOM NO 9] STAFF	Govindan. R.	Insect nest removed from the window side		Suhasini. K. - BLOOD BANK	04/06/2022
Comp. Dt. : 18/07/2022 Status : Completed								
654	22070672	Blood Bank	SINK DRAINAGE LEAK	Prakash. V.,Rajendran. R.,Ramkumar. R.	Sink block removed.		Ganesh. V. - BLOOD BANK	19/07/2022
Comp. Dt. : 25/07/2022 Status : Completed								
655	22070894	Blood Bank	BLOCK IN SINK	Rajendhiran. V.,Murugan. S.,Thanuzkodi. E	Block removed.		Thirumangai. S. - BLOOD BANK	26/07/2022
Comp. Dt. : 02/08/2022 Status : Completed								
656	22080076	Blood Bank	NEED TO CHANGE SINK TAP - WATER LEAKAGE	Prakash. V.	Spindle has been changed.		Kokilambal. U. - BLOOD BANK	03/08/2022
Comp. Dt. : 17/08/2022 Status : Completed								
657	22080518	Blood Bank	WASH BASIN SINK OUTLET PIPE LEAKAGING PROBLEM	Prakash. V.,Arunagiri. V.,Rajendran. R.	Pipe line rework done.		Ganesh. V. - BLOOD BANK	19/08/2022
Comp. Dt. : 08/02/2023								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
658	23020264	Blood Bank	WASH BASIN BLOCK	Rajendhiran. V.,Thanuzkodi. E,Murugan. S.	Wash basin block removed, work completed		Thirumangai. S. - BLOOD BANK	08/02/2023
Comp. Dt. : 14/02/2023								
Status : Completed								
659	23020521	Blood Bank	SINK BLOCK	Rajendhiran. V.,Thanuzkodi. E,Murugan. S.	SINK BLOCK REMOVED.		Thirumangai. S. - BLOOD BANK	15/02/2023
Comp. Dt. : 09/03/2023								
Status : Completed								
660	23030349	Blood Bank	BLOCK IN SINK	Rajendhiran. V.,Thanuzkodi. E,Murugan. S.	SINK BLOCK REMOVED		Lakshmi.K. - BLOOD BANK	10/03/2023
Comp. Dt. : 27/05/2023								
Status : Completed								
661	23051096	Blood Bank	NEED TO CHECK SINK - WATER LEAKAGE	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	BLOCK REMOVED.		Sivasankari.I. - BLOOD BANK	27/05/2023
Comp. Dt. : 16/06/2023								
Status : Completed								
662	23060592	Blood Bank	SINK WATER TAP PROBLEM	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	TAP CHANGED.		Sivasankari.I. - BLOOD BANK	17/06/2023
Dept Name : Canteen - Boys Hostel - Civil - Maintenance								
Comp. Dt. : 04/05/2022								
Status : Completed								
663	22050081	Boys hostel P,H-III	NEED TO CHECK & CHANGE HAND SHOWER BLOCK IN ROOM NO 26 & 20	Thanuzkodi. E	Block removed.		Sriram. TR. K. - Canteen - Boys Hostel	04/05/2022
Comp. Dt. : 06/05/2022								
Status : Completed								
664	22050180	Mit boys hostel	BLOCK IN MIT BOYS HOSTEL BACK SIDE CHAMBER	Thanuzkodi. E,Govindan. R.,Sakthivel. E.	Chamber block removed, work completed		Sambasivam. K. - Canteen - Boys Hostel	07/05/2022
665	22050211	Boys hostel PH-I	NEED TO CHECK WATER TANK - DAMAGE - WATER LEAKAGE - NEED URGENT SERVICE	Gurunathan. V.	Tank Welding work completed, leakage arrested, now problem solved		Sambasivam. K. - Canteen - Boys Hostel	01/06/2022
Comp. Dt. : 09/05/2022								
Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
666	22050296	Mit boys hostel	BLOCK IN GROUND FLOOR REST ROOM	Sakthivel. E.	block remover work		Sambasivam. K. - Canteen - Boys Hostel	09/05/2022
Comp. Dt. : 10/05/2022 Status : Completed								
667	22050333	Mit boys hostel	NEED TO CHECK WATER PIPE LINE LEAKAGE OPP TO MIT BOYS HOSTEL	Azhagar. N.	New water pipe line changed to 6" Y (1no) shoe (2no) coupling (3no.)		Sambasivam. K. - Canteen - Boys Hostel	20/05/2022
668	22050339	Boys hostel P.H-III	NEED TO CHECK MIXTURE TAP & FLUSH TANK - WATER LEAKAGE ROOM NO 10, 31 & 21	Anandharaj. M.	#10-Wall mixer tap spindle changed, #31- Flush tank syfon changed, #21- new Wall mixer tap changed,		Sambasivam. K. - Canteen - Boys Hostel	12/05/2022
669	22050340	Boys hostel PH-I	NEED TO CHECK FLUSH PIPELINE - WATER LEAKAGE AT ROOM NO 31	Anandharaj. M.	Flush tank syfon changed, problem solved		Sambasivam. K. - Canteen - Boys Hostel	11/05/2022
Comp. Dt. : 19/05/2022 Status : Completed								
670	22050709	Boys hostel P.H-III	NEED TO CHANGE MIXTURE TAP [WATER LEAKAGE] & WASH BASIN STAND [UNFIX & BROKEND] FOR ROOM NO 9	Anandharaj. M.	New wall mixer tap changed, wash basin stand refixed, problem solved		Sambasivam. K. - Canteen - Boys Hostel	24/05/2022
Comp. Dt. : 23/05/2022 Status : Completed								
671	22050823	Boys hostel PH-I	FLUSH NOT WORKING ROOM NO 36 & 37	Azhagar. N.	Flush tank washer changed, fullset rework and serviced, problem solved		Sambasivam. K. - Canteen - Boys Hostel	24/05/2022
Comp. Dt. : 25/05/2022 Status : Completed								
672	22050949	Boys hostel PH-I	FLUSH WATER LEAKAGE ROOM NO 38	Azhagar. N.	Flush tank fullset rework and serviced, problem solved		Sambasivam. K. - Canteen - Boys Hostel	25/05/2022
673	22050960	Boys hostel PH-I	FLUSH TANK WATER LEAKAGE - ROOM NO 29	Santhosh Kumar. M.	Flush tank washer changed and fullset rework and serviced, problem solved		Sambasivam. K. - Canteen - Boys Hostel	25/05/2022
Comp. Dt. : 26/05/2022 Status : Completed								
674	22051002	Boys hostel Phase-II	PIPELINE BROKEN - WATER FLOW - NEED TO CHECK - II FLOOR COMMON RESTROOM	Azhagar. N., Santhosh Kumar. M., Gopal. S.	Wall mixer tap spindle changed, work complete		Sambasivam. K. - Canteen - Boys Hostel	27/05/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 27/05/2022 Status : Completed								
675	22051014	Boys hostel PH-I	FLUSH NOT WORKING - ROOM NO 20	Gopal. S.	Flush tank washer changed and serviced, problem solved		Sambasivam. K. - Canteen - Boys Hostel	27/05/2022
676	22051015	Boys hostel P.H-III	NEED TO REFIX HANS SHOWER STAND FOR ROOM NO 33	Santhosh Kumar. M.	New Hand shower stand changed, problem solved		Sambasivam. K. - Canteen - Boys Hostel	27/05/2022
Comp. Dt. : 04/06/2022 Status : Completed								
677	22060170	BOYS HOSTEL-DINING HALL	BLOCK IN WASH BASIN [2 NOS] AT DINING HALL -II	Rajendhiran. V., Thanuzkodi. E., Govindan. R.	Block removed.		Sriram. TR. K. - Canteen - Boys Hostel	06/06/2022
Comp. Dt. : 07/06/2022 Status : Completed								
678	22060247	Boys hostel PH-I	NEED TO CHECK PIPELINE - WATER COMING DUST & SMELL IN WASHBASIN - ROOM NO 31 & WASHBASIN DAMAGE NEED	Anandharaj. M., Azhagar. N., Udhaya Kumar. R.	1.1/4" Water pipe line fully cleaned, tap air lock released and serviced, problem solved		Sambasivam. K. - Canteen - Boys Hostel	10/06/2022
Comp. Dt. : 09/06/2022 Status : Completed								
679	22060349	Boys hostel PH-I	DRAINAGE WATER PIPE LINE LEAKAGE IN WASH BASIN - ROOM NO 40	Gopal. S.	1.1/4" Water pipe line and flush tank fullset cleaned and serviced, problem solved		Sambasivam. K. - Canteen - Boys Hostel	10/06/2022
Comp. Dt. : 13/06/2022 Status : Completed								
680	22060447	Mit boys hostel	BLOCK IN TANK AT MIT BOYS HOSTEL SIDE - NEAR MIT BOYS HOSTEL	Thanuzkodi. E., Govindan. R., Sakthivel. E.	Block removed.		Sambasivam. K. - Canteen - Boys Hostel	13/06/2022
Comp. Dt. : 16/06/2022 Status : Completed								
681	22060617	Boys hostel PH-I	NEED TO CHANGE HAND SHOWER & SHOWER TAP - DAMAGE WATER NOT COMING - ROOM NO 47	Anandharaj. M., Sellaveeran. M., Azhagar. N.	1no. Health faucet, ankle wall, WC seat cover, pvc shower changed.		Sambasivam. K. - Canteen - Boys Hostel	18/06/2022
682	22060618	Boys hostel P.H-III	WATER COMING SLOW IN HEATER - PROBLEM - ROOM NO 48	Anandharaj. M., Azhagar. N., Gopal. S.	Water heater rework done.		Sambasivam. K. - Canteen - Boys Hostel	20/06/2022
Comp. Dt. : 17/06/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
683	22060651	Boys hostel P.H-III	NEED REPAIRING WORK FOR HAND SHOWER - ROOM NO 48	Gopal. S.,Azhagar. N.,Anandharaj. M.	Hand shower rework.		Sambasivam. K. - Canteen - Boys Hostel	18/06/2022
684	22060652	Boys hostel Phase-II	NEED TO CHECK URINALS [2NOS] AT IV FLOOR COMMON RESTROOM	Udhaya Kumar. R.,Azhagar. N.,Anandharaj. M.	Urinal line block removed and refixed in properly, problem solved		Sambasivam. K. - Canteen - Boys Hostel	30/06/2022
Comp. Dt. : 20/06/2022 Status : Completed								
685	22060713	Mit boys hostel	URINAL BLOCK AT COMMON REST ROOM	Govindan. R.	Block removed		Sambasivam. K. - Canteen - Boys Hostel	20/06/2022
Comp. Dt. : 22/06/2022 Status : Completed								
686	22060817	BOYS HOSTEL-DINING HALL	NEED TO CHANGE COOLER TAP AT DINING HALL - I - TAP BROKEN WATER LEAKAGE	Anandharaj. M.,Azhagar. N.,Udhaya Kumar. R.	New cooler tap fixed.		Sambasivam. K. - Canteen - Boys Hostel	25/06/2022
Comp. Dt. : 23/06/2022 Status : Completed								
687	22060841	Boys hostel Phase-II	NEED TO CHECK II & III FLOOR COMMON REST ROOM - WATER NOT COMING IN THE MORNING SESSION	Gopal. S.,Sellaveeran. M.,Udhaya Kumar. R.	Tank filled with water. Water coming.		Sambasivam. K. - Canteen - Boys Hostel	25/06/2022
Comp. Dt. : 25/06/2022 Status : Completed								
688	22060917	Boys hostel PH-I	NEED REPAIRING WORK FOR WASH BASIN & HAND SHOWER WATER LEAKAGE - ROOM NO 53 + DRAINAGE BLOCK ROOM NO	Anandharaj. M.,Azhagar. N.,Sakthivel. E.	Wash basin block removed, connection tube changed, health faucet rework, work completed		Sambasivam. K. - Canteen - Boys Hostel	30/06/2022
Comp. Dt. : 29/06/2022 Status : Completed								
689	22061080	Mit boys hostel	WATER BLOCK AT PLOTFORM OPPOSITE TO MIT COLLEGE & BOYS HOSTEL - THE GAP OF DRAINAGE PIPELINE NE	Sakthivel. E.	Block removed		Sambasivam. K. - Canteen - Boys Hostel	06/07/2022
Comp. Dt. : 02/07/2022 Status : Completed								
690	22070069	BOYS HOSTEL MESS	NEED NEW AURO WATER PIPE LINE CONNECTION FOR BOILER	Azhagar. N.	New 1" UPVC Pipe line connection given in RO water plant, work completed		Sambasivam. K. - Canteen - Boys Hostel	20/07/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 04/07/2022 Status : Completed								
691	22070120	Boys hostel P.H-III	FLUSH NOT WORKING & HAND SHOWER WATER LEAKAGE AT ROOM NO 39	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	Flush tank rework. Hand shower rework		Sambasivam. K. - Canteen - Boys Hostel	09/07/2022
Comp. Dt. : 14/07/2022 Status : Completed								
692	22070536	Boys hostel PH-I	FLUSH WATER LEAKAGE - ROOM NO 47	Azhagar. N.	Flush tank fullset cleaned and serviced, problem solved		Sambasivam. K. - Canteen - Boys Hostel	15/07/2022
Comp. Dt. : 15/07/2022 Status : Completed								
693	22070574	Mit boys hostel	NEED TO CHECK PIPE LINE CONNECTION - BROKE - WATER FLOW AT MIT COLLEGE OPP	Santhosh Kumar. M.	2.1/2" Pipe line fully rework, work completed		Sambasivam. K. - Canteen - Boys Hostel	20/07/2022
694	22070582	Mit boys hostel	I FLOOR COMMON RESTROOM TAP BROKE - WATER FLOW AT MIT BOYS HOSTEL	Sellaveeran. M.	New Tap changed, work completed		Sambasivam. K. - Canteen - Boys Hostel	20/07/2022
Comp. Dt. : 18/07/2022 Status : Completed								
695	22070680	Boys hostel PH-I	FLUSH WATER LEAKAGE - ROOM NO 21 & 24	Sivaraja. M.	Flush tank fullset rework and serviced, problem solved		Sambasivam. K. - Canteen - Boys Hostel	20/07/2022
Comp. Dt. : 21/07/2022 Status : Completed								
696	22070769	STAFF'S CANTEEN	NEED TO CHANGE WASH BASIN TAP - WATER LEAKAGE - NEED URGENT SERVICE	Prakash. V.,Rajendran. R.,Ramkumar. R.	Tap changed.		Kesavaraj. P. - Canteen - Boys Hostel	26/07/2022
Comp. Dt. : 23/07/2022 Status : Completed								
697	22070872	Boys hostel PH-I	WATER NOT COMING IN WASH BASIN TAP - SLOW PROBLEM IN ROOM NO 12	Anandharaj. M.	1.1/4" waste coupling changed for sink at kitchen.		Sambasivam. K. - Canteen - Boys Hostel	04/08/2022
Comp. Dt. : 26/07/2022 Status : Completed								
698	22070945	Boys hostel PH-I	NEED TO CHECK WASH BASIN & FLUSH TANK - WATER LEAKAGE - ROOM NO 24	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	Wash basin and flush tank rework done		Sambasivam. K. - Canteen - Boys Hostel	09/08/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 27/07/2022 Status : Completed								
699	22070993	Mit boys hostel	BLOCK IN RESTROOM - I FLOOR ROOM NO 6	Govindan. R.	Block removed.		Sambasivam. K. - Canteen - Boys Hostel	29/07/2022
700	22071041	Boys hostel PH-I	FLUSH TANK & WASH BASIN PIPE LINE LEAKAGE - NEED TO CHANGE FLUSH SET & HAND SET & WASH BASIN DR	Anandharaj. M.	Flush tank rework and wash basin pipe line rework		Sriram. TR. K. - Canteen - Boys Hostel	09/08/2022
Comp. Dt. : 29/07/2022 Status : Completed								
701	22071050	Boys hostel P.H-III	FLUSH NOT WORKING ROOM NO 8 & WATER LEAKAGE AT MIXTURE TAP ROOM NO 26	Anandharaj. M., Azhagar. N., Sellaveeran. M.	New mixture tap changed. Flush washer changing at room no.8		Sambasivam. K. - Canteen - Boys Hostel	04/08/2022
702	22071051	Boys hostel PH-I	WATER COMING SLOW - NEED TO CHECK TAP - ROOM NO 14	Anandharaj. M., Azhagar. N., Gopal. S.	Tap rework		Sambasivam. K. - Canteen - Boys Hostel	04/08/2022
Comp. Dt. : 02/08/2022 Status : Completed								
703	22080067	Boys hostel PH-I	NEED TO REFIX WASH BASIN - BOLT DAMANGE- FALL DOWN DANGER POSITION AT ROOM NO 51 & HAND SHOWER FO	Gopal. S.	Fixed with new fisher bolt. Hand shower rework.		Sambasivam. K. - Canteen - Boys Hostel	04/08/2022
704	22080069	Mit boys hostel	URINAL BLOCK AT GROUND FLOOR COMMON RESTROOM	Sakthivel. E., Murugan. S., Thanuzkodi. E	Block removed.		Sambasivam. K. - Canteen - Boys Hostel	03/08/2022
Comp. Dt. : 03/08/2022 Status : Completed								
705	22080141	Boys hostel P.H-III	NEED TO CHECK PIPE LINE - WATER COMING SLOW IN WASH BASIN & SHOWER- ROOM NO 49	Anandharaj. M., Gopal. S., Azhagar. N.	Pipe line rework done.		Sambasivam. K. - Canteen - Boys Hostel	04/08/2022
Comp. Dt. : 04/08/2022 Status : Completed								
706	22080150	Boys hostel P.H-III	IN ROOM NO.48 FLUSH TANK NOT WORKING	Anandharaj. M., Azhagar. N., Gopal. S.	Flush tank rework		Sambasivam. K. - Canteen - Boys Hostel	04/08/2022
Comp. Dt. : 08/08/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
707	22080263	Boys hostel PH-I	NEED TO CHECK WASH BASIN & HAND SHOWER - WATER NOT COMING & SLOW PROBLEM - ROOM NO16	Anandharaj. M.,Sellaveeran. M.,Gopal. S.	Wash basin tap rework and Hand shower rework.		Sambasivam. K. - Canteen - Boys Hostel	09/08/2022
708	22080264	Boys hostel P.H-III	NEED TO CHECK E W C WATER LEAKAGE AT III FLOOR COMMON RESTROOM	Anandharaj. M.,Gopal. S.,Udhaya Kumar. R.	Flush tank washer changed.		Sambasivam. K. - Canteen - Boys Hostel	09/08/2022
709	22080284	Boys hostel PH-I	NEED TO CHANGE AURO DRINKING WATER TAP - WATER LEAKAGE AT IV FLOOR	Azhagar. N.	New tap changed.		Sambasivam. K. - Canteen - Boys Hostel	09/08/2022
Comp. Dt. : 09/08/2022 Status : Completed								
710	22080310	Boys hostel PH-I	NEED TO CHECK FLUSH PIPE LINE DAMAGE AT ROOM NO 11	Azhagar. N.	Health faucet stand fixed and bush changed.		Sambasivam. K. - Canteen - Boys Hostel	09/08/2022
Comp. Dt. : 10/08/2022 Status : Completed								
711	22080371	Mit boys hostel	BLOCK IN GROUND FLOOR COMMON RESTROOM	Govindan. R.	Block removed.		Sambasivam. K. - Canteen - Boys Hostel	12/08/2022
712	22080389	Boys hostel P.H-III	WATER LEAKAGE AT WATER PIPELINE AT GROUND FLOOR	Anandharaj. M.,Azhagar. N.,Gopal. S.	Pipe line connection rework.		Sambasivam. K. - Canteen - Boys Hostel	18/08/2022
Comp. Dt. : 11/08/2022 Status : Completed								
713	22080400	Boys hostel PH-I	NEED REPAIRING WORK FOR HAND SET - ROOOM NO 28	Anandharaj. M.	Health faucet changed.		Sambasivam. K. - Canteen - Boys Hostel	18/08/2022
Comp. Dt. : 12/08/2022 Status : Completed								
714	22080444	Boys hostel PH-I	NEED TO CHANGE SEAT COVER - BROKEN AT ROOM NO 27	Anandharaj. M.,Azhagar. N.,Senthil Kumar. R.	Seat cover changed.		Sambasivam. K. - Canteen - Boys Hostel	18/08/2022
715	22080445	BOYS HOSTEL-DINING HALL	WATER COMING SLOW IN WASH BASIN - DINING HALL I & II	Sivaraja. M.,Gopal. S.,Santhosh Kumar. M.	Wash basin tap rework.		Sambasivam. K. - Canteen - Boys Hostel	18/08/2022
Comp. Dt. : 18/08/2022 Status : Completed								
716	22080557	Mit boys hostel	RESTROOM BLOCK IN GROUND FLOOR	Govindan. R.	Block removed.		Sambasivam. K. - Canteen - Boys Hostel	19/08/2022
Comp. Dt. : 20/08/2022								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
717	22080677	Boys hostel P,H-III	NEED TO CHANGE MIXTURE TAP & HAND SHOWER - WATER LEAKAGE AND DAMAGE - ROOM NO 41	Anandharaj. M.,Sivaraja. M.,Azhagar. N.	New wall mixture set and health faucet changed.		Sambasivam. K. - Canteen - Boys Hostel	23/08/2022
718	22080681	Mit boys hostel	BLOCK IN I FLOOR WASH BASIN	Sakthivel. E.	Block removed.		Sambasivam. K. - Canteen - Boys Hostel	22/08/2022
Comp. Dt. : 22/08/2022								
Status : Completed								
719	22080695	Boys hostel Phase-II	FLOAT BALL NOT WORKING IN GROUND FLOOR COOLER	Anandharaj. M.,Gopal. S.,Santhosh Kumar. M.	New float ball fixed.		Sambasivam. K. - Canteen - Boys Hostel	23/08/2022
Comp. Dt. : 25/08/2022								
Status : Completed								
720	22080833	Boys hostel PH-I	FLUSH NOT WORKING ROOM NO 11	Anandharaj. M.	Flush tank rework.		Mathubalan. M. - Canteen - Boys Hostel	30/08/2022
Comp. Dt. : 26/08/2022								
Status : Completed								
721	22080874	Boys hostel P,H-III	FLUSH NOT WORKING - ROOM NO 39	Anandharaj. M.,Azhagar. N.,Udhaya Kumar. R.	Flush tank rework		Sambasivam. K. - Canteen - Boys Hostel	30/08/2022
722	22080875	Boys hostel Phase-II	NEED TO SPRAY "TERMITE SPRAY" FOR ROOM NO 54	Kannan. V.	work completed.		Sambasivam. K. - Canteen - Boys Hostel	30/08/2022
Comp. Dt. : 30/08/2022								
Status : Completed								
723	22081023	Boys hostel PH-I	NEED TO CHANGE WASH BASIN DRAINAGE HOSE - DAMAGE AND WATER LEAKAGE AT ROOM NO 4	Santhosh Kumar. M.,Gopal. S.,Govindan. R.	Wash basin block removed, waste drainage pipe line fully rework, work completed		Sambasivam. K. - Canteen - Boys Hostel	01/09/2022
Comp. Dt. : 01/09/2022								
Status : Completed								
724	22090016	Boys hostel	WASH BASIN DRAINAGE HOSE BLOCK AT COMPUTER ROOM	Govindan. R.,Murugan. S.,Santhosh Kumar. M.	Wash basin block removed, drainage line fully rework, work completed		Anand. G. - Transport	01/09/2022
725	22090026	Boys hostel P,H-III	NEED TO SPRAY "PESTOMATIC CONTROLS" TOWARDS AVOID OF SNAKE ENTRY	Kannan. V.	pestomatic controls sprayed.		Sambasivam. K. - Canteen - Boys Hostel	09/09/2022

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
726	22090028	Mit boys hostel	BLOCK IN COMMON RESTROOM AT GROUND FLOOR	Thanuzkodi. E.,Govindan. R.,Murugan. S.	Toilet block removed, work completed		Sambasivam. K. - Canteen - Boys Hostel	01/09/2022
727	22090040	Boys hostel PH-I	NEED REPAIRING WORK FOR SHOWER SPRIN FOR ROOM NO 16	Santhosh Kumar. M.	3/4 mti upvc (2 nos.), 3/4' consiled cork (1 no.), 3/4.1/2' upvc elbow (1 no.) new pipe line work do		Sambasivam. K. - Canteen - Boys Hostel	24/09/2022
Comp. Dt. : 05/09/2022 Status : Completed								
728	22090172	BOYS HOSTEL MESS	NEED TO CHANGE TAP - WATER LEAKAGE IN KITCHEN	Sellaveeran. M.,Anandharaj. M.,Azhagar. N.	New tap changed.		Kesavaraj. P. - Canteen - Boys Hostel	09/09/2022
Comp. Dt. : 07/09/2022 Status : Completed								
729	22090266	Boys hostel PH-I	SHOWER PROBLEM - ROOM NO 27	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	flush tank rework.		Mathubalan. M. - Canteen - Boys Hostel	13/09/2022
Comp. Dt. : 08/09/2022 Status : Completed								
730	22090323	Mit boys hostel	BLOCK IN GROUND FLOOR RESTROOM	Sakthivel. E.	Toilet block removed, work completed		Sambasivam. K. - Canteen - Boys Hostel	09/09/2022
Comp. Dt. : 10/09/2022 Status : Completed								
731	22090395	Mit boys hostel	BLOCK IN I FLOOR RESTROOM	Sakthivel. E.	Toilet block removed, work completed		Sambasivam. K. - Canteen - Boys Hostel	12/09/2022
732	22090418	Boys hostel PH-I	NEED REPAIRING WORK FOR FLUSH TANK - DAMAGE - ROOM NO 4	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	Flush tank rework, connection tube changed, work completed		Sambasivam. K. - Canteen - Boys Hostel	16/09/2022
Comp. Dt. : 13/09/2022 Status : Completed								
733	22090508	Boys hostel	NEED TO CHECK R O WATER - TASTE DIFFERENT to FEEL COMFORT AT BOYS HOSTEL	Anandharaj. M.,Azhagar. N.,Abdul Azees. J.	Memoran changed		Sambasivam. K. - Canteen - Boys Hostel	27/09/2022
Comp. Dt. : 14/09/2022 Status : Completed								
734	22090560	Boys hostel PH-I	FLUSH NOT WORKING ROOM NO 3	Sellaveeran. M.	Flush tank fullset rework and refixed, washer changed, New PVC tap, connection tube changed, work co		Sambasivam. K. - Canteen - Boys Hostel	16/09/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 17/09/2022 Status : Completed								
735	22090689	Boys hostel PH-I	FLUSH NOT WORKING - ROOM NO 8	Azhagar. N.	Flush tank rework.		Sambasivam. K. - Canteen - Boys Hostel	28/09/2022
Comp. Dt. : 22/09/2022 Status : Completed								
736	22090870	Mit boys hostel	URINAL BLOCK AT GROUND FLOOR COMMON RESTROOM	Sakthivel. E.	block removed.		Sambasivam. K. - Canteen - Boys Hostel	26/09/2022
737	22090871	Mit boys hostel	DUE TO TREE'S BRANCHES COMING INSIDE THE ROOM NEED TO CUT EXTENTION OF TREE BRANCH	Pandiaraj. V.,Prakash. N.,Senthil Kumar. R.	Garden complaints		Sambasivam. K. - Canteen - Boys Hostel	22/09/2022
Comp. Dt. : 24/09/2022 Status : Completed								
738	22090971	Boys hostel	NEED TO CHECK R O WATER PIPE LINE CONNECTION & TASTE	Sellaveeran. M.	Memoran changed.		Sambasivam. K. - Canteen - Boys Hostel	27/09/2022
Comp. Dt. : 26/09/2022 Status : Completed								
739	22090989	Boys hostel PH-I	FLUSH NOT WORKING - ROOM NO 7	Anandharaj. M.,Prakash. V.,Azhagar. N.	Flush tank rework.		Mathubalan. M. - Canteen - Boys Hostel	28/09/2022
Comp. Dt. : 29/09/2022 Status : Completed								
740	22091156	Boys hostel PH-I	FLUSH WATER LEAKAGE - ROOM NO - 24	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	flush tank rework done.		Sambasivam. K. - Canteen - Boys Hostel	30/09/2022
Comp. Dt. : 05/10/2022 Status : Completed								
741	22100068	Boys hostel	NEED TO CHECK KITCHEN BOILER WATER PIPE LINE - WATER LEAKAGE	Prakash. V.,Rajendran. R.,Ramkumar. R.	New water pipe line changed.		Anand. G. - Transport	13/10/2022
Comp. Dt. : 07/10/2022 Status : Completed								
742	22100151	Boys hostel P,H-III	NEED TO CHECK WATER TAP PIPELINE - WATER COMING SLOW - ROOM NO 31	Anandharaj. M.	Water tap pipeline rework done.	 Dr. KAGNE. R.N DEAN SRI MANAKULA VINAYAGAR MEDICAL COLLEGE & HOSPITAL KALITHEERTHALKUPPAM, PUDUCHERRY-605107.	Sambasivam. K. - Canteen - Boys Hostel	08/10/2022

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 11/10/2022								
Status : Completed								
743	22100282	Boys hostel PH-I	NEED TO CHECK SHOWER - WATER LEAKAGE & PROBLEM - ROOM NO 27	Rajendran. R.,Ramkumar. R.,Prakash. V.	Shower rework done		Sambasivam. K. - Canteen - Boys Hostel	12/10/2022
Comp. Dt. : 13/10/2022								
Status : Completed								
744	22100399	Boys hostel PH-I	NEED TO CHECK REST ROOM HAND SET - WATER LEAKAGE - ROOM NO 11	Prakash. V.,Rajendran. R.,Ramkumar. R.	work should be done by company		Sambasivam. K. - Canteen - Boys Hostel	13/10/2022
Comp. Dt. : 17/10/2022								
Status : Completed								
745	22100518	Mit boys hostel	BLOCK AT I FLOOR COMMON RESTROOM	Sakthivel. E.,Thanuzkodi. E,Govindan. R.	Block removed.		Sambasivam. K. - Canteen - Boys Hostel	18/10/2022
Comp. Dt. : 19/10/2022								
Status : Completed								
746	22100643	Mit boys hostel	3RD FLOOR BATH ROOM BLOCK	Sakthivel. E.	Block removed.		Sambasivam. K. - Canteen - Boys Hostel	20/10/2022
Comp. Dt. : 29/10/2022								
Status : Completed								
747	22100960	Boys hostel	FLUSH NOT WORKING IN RESTROOM NEAR COMPUTER ROOM	Prakash. V.	Flush tank full set rework, work completed		Anand. G. - Transport	31/10/2022
Comp. Dt. : 03/11/2022								
Status : Completed								
748	22110097	Boys hostel PH-I	IN ROOM NO.30 EWC WATER LEAKAGING PROBLEM	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	EWC pipe bend changed.		Sambasivam. K. - Canteen - Boys Hostel	10/11/2022
Comp. Dt. : 21/11/2022								
Status : Completed								
749	22110860	Boys hostel Phase-II	IN 2ND FLOOR-COMMON TOILET BLOCKED,NEED SCAVENGER	Sakthivel. E.	Block removed.		Sambasivam. K. - Canteen - Boys Hostel	22/11/2022
Comp. Dt. : 24/11/2022								
Status : Completed								
750	22111041	Boys hostel Phase-II	IN ROOM NO.8 AND 41 FLUSH TANK NOT WORKING IN REST ROOM	Prakash. V.	Flush tank rework done.		Sambasivam. K. - Canteen - Boys Hostel	05/12/2022

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
751	22111222	Boys hostel P.H-III	NEED TO CHANGE WASH BASIN TAP WATER LEAKAGE AT ROOM NO 8	Anandharaj. M.	tap changed.		Sambasivam. K. - Canteen - Boys Hostel	05/12/2022
752	22111250	Boys hostel P.H-III	IN ROOM NO.2-BATHROOM DRAINAGE BLOCK,NEED SCAVENGER	Sakthivel. E.	block removed.		Sambasivam. K. - Canteen - Boys Hostel	30/11/2022
Comp. Dt. : 30/11/2022								
Status : Completed								
753	22111268	Boys hostel P.H-III	NEED REPAIRING WORK FOR FLUSH TANK AT ROOM NO. 11	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	Flush tank rework done.		Sambasivam. K. - Canteen - Boys Hostel	05/12/2022
754	22111269	Boys hostel PH-I	NEED TO CHECK HAND SHOWER AT ROOM NO.27	Sankar. V.,Anandharaj. M.,Azhagar. N.	Hand shower rework done.		Sambasivam. K. - Canteen - Boys Hostel	06/12/2022
Comp. Dt. : 05/12/2022								
Status : Completed								
755	22120157	Mit boys hostel	BLOCK IN III FLOOR RESTROOM	Sakthivel. E.	Block removed.		Sambasivam. K. - Canteen - Boys Hostel	05/12/2022
756	22120163	Boys hostel P.H-III	RESTROOM DRAINAGE BLOCK ROOM NO 2 - NEED URGENT SERVICE	Rajendhiran. V.,Sakthivel. E.,Murugan. S.	Block removed.		Sambasivam. K. - Canteen - Boys Hostel	05/12/2022
Comp. Dt. : 06/12/2022								
Status : Completed								
757	22120240	Boys hostel PH-I	IN ROOM NO.21-FLUSH TANK PIPELINE WATER LEAKAGING PROBLEM	Prakash. V.,Sankar. V.,Arunagiri. V.	Flush tank rework.		Sambasivam. K. - Canteen - Boys Hostel	12/12/2022
758	22120242	Boys hostel PH-I	WATER COOLER BACKSIDE -WATER PIPELINE LEAKAGING PROBLEM	Arunagiri. V.	Leakage arrest. Tighten the valve.		Sambasivam. K. - Canteen - Boys Hostel	12/12/2022
Comp. Dt. : 09/12/2022								
Status : Completed								
759	22120419	Boys hostel P.H-III	NEED TO CHECK HAND SET FOR ROOM NO 11	Prakash. V.,Sankar. R.,Anandharaj. M.	Health faucet changed.		Sambasivam. K. - Canteen - Boys Hostel	15/12/2022
760	22120420	Boys hostel PH-I	OUTSIDE PIPE LINE WATER LEAKAGE - ROOM NO 13 WINDOW SIDE	Prakash. V.,Sankar. V.,Udhaya Kumar. R.	Pipe line rework done.		Sambasivam. K. - Canteen - Boys Hostel	17/12/2022
Comp. Dt. : 13/12/2022								
Status : Completed								
761	22120591	Boys hostel PH-I	DRAINAGE BLOCK AT II FLOOR HEATER PIT & HAND SHOWER NOT WORKING ROOM NO 20	Thanuzkodi. E	block removed		Sambasivam. K. - Canteen - Boys Hostel	14/12/2022

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 15/12/2022								
Status : Completed								
762	22120718	Boys hostel Phase-II	NEED TO REFIXING W E C SEAT COVER FOR II FLOOR COMMON REST ROOM	Prakash. V.,Sankar. R.,Abdul Azees. J.	Seat cover changed.		Sambasivam. K. - Canteen - Boys Hostel	17/12/2022
763	22120724	Boys hostel P.H-III	NEED TO CHECK MIXTURE TAP - WATER LEAKAGE FOR ROOM NO 40	Prakash. V.,Sankar. R.,Abdul Azees. J.	Mixture tap rework done.		Sambasivam. K. - Canteen - Boys Hostel	17/12/2022
764	22120729	Mit boys hostel	BLOCK IN GROUND FLOOR	Sakthivel. E.	block removed.		Sambasivam. K. - Canteen - Boys Hostel	16/12/2022
Comp. Dt. : 18/01/2023								
Status : Completed								
765	23010642	Mit boys hostel	URINAL BLOCK & HOSE DAMAGE NEED TO CHANGE - GROUND FLOOR COMMON RESTROOM	Sakthivel. E.,Govindan. R.,Kathirvelu. K.	Block removed.		Sambasivam. K. - Canteen - Boys Hostel	21/01/2023
Comp. Dt. : 20/01/2023								
Status : Completed								
766	23010736	Boys hostel	NEED TO CHECK KITCHEN HEATER PIPELINE	Santhosh Kumar. M.,Sivaraja. M.,Sankar. V.	Connection tube changed.		Elumalai. M. - Canteen - Boys Hostel	23/01/2023
Comp. Dt. : 23/01/2023								
Status : Completed								
767	23010823	BOYS HOSTEL-DINING HALL	NEED TO CHANGE WATER COOLER TAP - WATER LEAKAGE - NEED URGENT SERVICE	Prakash. V.,Rajendran. R.,Ramkumar. R.	WATER COOLER TAPN (2NOS) CHANGED.		Sambasivam. K. - Canteen - Boys Hostel	24/02/2023
768	23010835	Mit boys hostel	BLOCK AT ROOM NO 7	Sakthivel. E.,Govindan. R.,Murugan. S.	Block removed.		Sambasivam. K. - Canteen - Boys Hostel	23/01/2023
Comp. Dt. : 24/01/2023								
Status : Completed								
769	23010875	Boys hostel PH-I	NEED REPAIRING WORK FOR FLUSH TANK ROOM NO34	Sankar. R.,Sivaraja. M.,Gopal. S.	Flush tank rework done.		Sambasivam. K. - Canteen - Boys Hostel	25/01/2023
770	23010876	Boys hostel P.H-III	NEED TO CHECK HEATER PIPELINE - WATER NOT COMING - ROOM NO 41	Sivaraja. M.,Gopal. S.,Santhosh Kumar. M.	Heater pipe line rework done.		Sambasivam. K. - Canteen - Boys Hostel	25/01/2023
771	23010877	Boys hostel PH-I	NEED TO CHECK II FLOOR COOLER WATER TAP - WATER LEAKAGE	Rajendran. R.,Sankar. V.,Gopal. S.	SPINDLE CHANGED.		Sambasivam. K. - Canteen - Boys Hostel	30/01/2023
772	23010878	Boys hostel PH-I	FLOOR TRAP WATER LEAKAGE OUTER SIDE WALL ROOM NO 41	Santhosh Kumar. M.,Sankar. V.,Sivaraja. M.	Flush tank rework done.		Sambasivam. K. - Canteen - Boys Hostel	25/01/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 27/01/2023 Status : Completed								
773	23010980*	Mit boys hostel	BLOCK IN III FLOOR COMMON RESTROOM	Sakthivel. E.,Govindan. R.,Murugan. S.	Rest room block removed, work completed		Sambasivam. K. - Canteen - Boys Hostel	28/01/2023
Comp. Dt. : 28/01/2023 Status : Completed								
774	23011015	Boys hostel PH-I	FLUSH WATER LEAKAGE - ROOM NO 5	Sivaraja. M.,Santhosh Kumar. M.,Sankar. V.	FLUSH TANK REWORK DONE.		Sambasivam. K. - Canteen - Boys Hostel	30/01/2023
775	23011023	BOYS HOSTEL-DINING HALL	BLOCK IN WASH BASIN 2 NOS	Sakthivel. E.,Govindan. R.,Kathirvelu. K.	Block removed.		Sambasivam. K. - Canteen - Boys Hostel	28/01/2023
Comp. Dt. : 06/02/2023 Status : Completed								
776	23020163	Boys hostel PH-I	BLOCK IN WASH BASIN DRAINAGE HOSE - NEED TO CHANGE ROOM NO 47	Sakthivel. E.,Govindan. R.,Kathirvelu. K.	BLOCK REMOVED.		Sambasivam. K. - Canteen - Boys Hostel	07/02/2023
Comp. Dt. : 11/02/2023 Status : Completed								
777	23020429	Boys hostel PH-I	NEED TO CHECK II FLOOR WATER HEATER SPINDLE - PROBLEM	Azhagar. N.,Sellaveeran. M.,Udhaya Kumar. R.	SPINDLE CHANGED		Sambasivam. K. - Canteen - Boys Hostel	17/02/2023
Comp. Dt. : 13/02/2023 Status : Completed								
778	23020459	Boys hostel PH-I	FLUSH WATE LEAKAGE -ROOM O 47 & FLUSH & SHOWER SPINDLE REPAIRING WORK FOR ROOM NO 27	Sivaraja. M.	SPINDLE CHANGED.		Sambasivam. K. - Canteen - Boys Hostel	17/02/2023
Comp. Dt. : 20/02/2023 Status : Completed								
779	23020765	Mit boys hostel	BLOCK IN III FLOOR COMMON RESTROOM	Sakthivel. E.,Govindan. R.,Kathirvelu. K.	BLOCK REMOVED.		Sambasivam. K. - Canteen - Boys Hostel	21/02/2023
780	23020773	Boys hostel PH-I	RESTROOM CEILING WATER LEAKAGE - ROOM NO 30	Sivaraja. M.	CIVIL COMPLAINT.... FORWARDED TO PROJECT MANAGER.		Mathubalan. M. - Canteen - Boys Hostel	22/02/2023
781	23020774	Boys hostel P.H-III	NEED TO CHECK HEATER WATER PIPELINE WATER NOT COMING - ROOM NO 41	Sivaraja. M.	HEATER WATER PIPE LINE REWORK DONE		Mathubalan. M. - Canteen - Boys Hostel	22/02/2023
Comp. Dt. : 21/02/2023								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
782	23020804	Mit boys hostel	BLOCK IN MALE COMMON RESTROOM - I FLOOR	Sakthivel. E.,Govindan. R.,Kathirvelu. K.	BLOCK REMOVED.		Sambasivam. K. - Canteen - Boys Hostel	21/02/2023
Comp. Dt. : 24/02/2023								
Status : Completed								
783	23020931	Boys hostel PH-I	BLOCK IN WASH BASIN - ROOM NO 36	Sakthivel. E.,Govindan. R.,Kathirvelu. K.	BLOCK REMOVED.		Sambasivam. K. - Canteen - Boys Hostel	25/02/2023
Comp. Dt. : 27/02/2023								
Status : Completed								
784	23021018	Boys hostel P.H-III	WASH BASIN BLOCK FOR ROOM NO 33	Sakthivel. E.,Govindan. R.,Kathirvelu. K.	BLOCK REMOVED.		Sambasivam. K. - Canteen - Boys Hostel	28/02/2023
785	23021021	Mit boys hostel	BLOCK IN GROUND FLOOR COMMON RESTROOM	Sakthivel. E.,Govindan. R.,Kathirvelu. K.	BLOCK REMOVED.		Sambasivam. K. - Canteen - Boys Hostel	28/02/2023
Comp. Dt. : 02/03/2023								
Status : Completed								
786	23030069	Boys hostel PH-I	URINAL BLOCK AT II FLOOR COMMON RESTROOM	Sakthivel. E.,Govindan. R.,Kathirvelu. K.	URINAL BLOCK REMOVED.		Sambasivam. K. - Canteen - Boys Hostel	03/03/2023
Comp. Dt. : 03/03/2023								
Status : Completed								
787	23030127	Mit boys hostel	RESTROOM BLOCK AT GROUND FLOOR	Sakthivel. E.,Govindan. R.,Kathirvelu. K.	BLOCK REMOVED.		Sambasivam. K. - Canteen - Boys Hostel	04/03/2023
Comp. Dt. : 04/03/2023								
Status : Completed								
788	23030185	BOYS HOSTEL MESS	BLOCK - HAND WASH AREA	Sakthivel. E.,Govindan. R.,Kathirvelu. K.	BLOCK REMOVED.		Mathubalan. M. - Canteen - Boys Hostel	06/03/2023
Comp. Dt. : 07/03/2023								
Status : Completed								
789	23030278	Boys hostel P.H-III	BLOCK IN WASH BASIN DRAINAGE HOSE ROOM NO 43	Sakthivel. E.,Govindan. R.,Kathirvelu. K.	BLOCK REMOVED.		Sambasivam. K. - Canteen - Boys Hostel	08/03/2023
Comp. Dt. : 09/03/2023								
Status : Completed								
790	23030369	Boys hostel P.H-III	NEED TO CHANGE WASH BASIN DRAINAGE HOSE - DAMAGE ROOM NO 43	Sivaraja. M.,Santhosh Kumar. M.,Gopal. S.	1.1/4" waste line changed.		Sambasivam. K. - Canteen - Boys Hostel	13/03/2023

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHAL KUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 13/03/2023 Status : Completed								
791	23030485	Mit boys hostel	RESTROOM BLOCK AT GROUND & III FLOOR	Sakthivel. E.,Govindan. R.,Kathirvelu. K.	BLOCK REMOVED.		Sambasivam. K. - Canteen - Boys Hostel	14/03/2023
Comp. Dt. : 14/03/2023 Status : Completed								
792	23030543	Boys hostel PH-I	NEED TO CHANGE WASH BASIN DRAINAGE HOSE - BLOCK - ROOM NO12	Sellaveeran. M.,Udhaya Kumar. R.,Sivaraja. M.	BLOCK REMOVED		Sambasivam. K. - Canteen - Boys Hostel	15/03/2023
793	23030554	Mit boys hostel	RESTROOM BLOCK - II FLOOR ROOM NO 9	Sakthivel. E.	BLOCK REMOVED		Sambasivam. K. - Canteen - Boys Hostel	15/03/2023
Comp. Dt. : 15/03/2023 Status : Completed								
794	23030597	Boys hostel P.H-III	NEED REPAIRING WORK FOR HAND SHOWER ROOM NO 38	Sivaraja. M.,Sellaveeran. M.,Gopal. S.	Health faucet changed.		Sambasivam. K. - Canteen - Boys Hostel	21/03/2023
Comp. Dt. : 16/03/2023 Status : Completed								
795	23030648	Boys hostel PH-I	NEED REPAIRING WORK FOR SEAT COVER [BROKEN] & SHOWER [WATER NOT COMING] ROOM NO 26	Sivaraja. M.,Santhosh Kumar. M.,Gopal. S.	SEAT COVER CHANGED.		Sambasivam. K. - Canteen - Boys Hostel	18/03/2023
Comp. Dt. : 21/03/2023 Status : Completed								
796	23030857	Boys hostel Phase-II	URINAL BLOCK AT IV FLOOR COMMON RESTROOM	Sakthivel. E.,Govindan. R.,Kathirvelu. K.	URINAL BLOCK REMOVED.		Sambasivam. K. - Canteen - Boys Hostel	22/03/2023
Comp. Dt. : 29/03/2023 Status : Completed								
797	23031272	Boys hostel PH-I	NEED TO CHECK WASH BASIN DRAINAGE HOSE - BLOCK IN DINING HALL	Prakash. V.,Rajendran. R.,Ramkumar. R.	BLOCK REMOVED.		Mathubalan. M. - Canteen - Boys Hostel	03/04/2023
Comp. Dt. : 03/04/2023 Status : Completed								
798	23040053	BOYS HOSTEL-DINING HALL	NEED TO CHANGE WATER COOLER TAP - DAMAGE LEAKAGE AT DINING HALL NO - 1	Sivaraja. M.,Santhosh Kumar. M.,Gopal. S.	WATER COOLER TAP CHANGED.		Sambasivam. K. - Canteen - Boys Hostel	26/04/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
799	23040080	Boys hostel P.H-III	FLUSH NOT WORKING ROOMNO 5	Sivaraja. M.,Sellaveeran. M.,Gopal. S.	FLUSH TANK REWORK DONE.		Sambasivam. K. - Canteen - Boys Hostel	05/04/2023
800	23040081	Boys hostel P.H-III	BLOCK IN RESTROOM DRAINAGE - ROOM NO 10	Sakthivel. E.	BLOCK REMOVED.		Sambasivam. K. - Canteen - Boys Hostel	04/04/2023
Comp. Dt. : 06/04/2023 Status : Completed								
801	23040188	Boys hostel PH-I	BLOCK NEAR WATER COOLER DRAINAGE	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	BLOCK REMOVED.		Sambasivam. K. - Canteen - Boys Hostel	08/04/2023
Comp. Dt. : 08/04/2023 Status : Completed								
802	23040235	Boys hostel PH-I	NEED TO CHECK WATER PIPELINE - WATER COMING SLOW IN WASHBASIN ROOM 36	Sivaraja. M.	Tap air lock released, problem solved		Sambasivam. K. - Canteen - Boys Hostel	20/04/2023
803	23040236	Boys hostel P.H-III	SHOWER NOT WORKING - ROOM NO 21	Sivaraja. M.,Santhosh Kumar. M.,Gopal. S.	SHOWER CHANGED.		Sambasivam. K. - Canteen - Boys Hostel	06/05/2023
804	23040251	CANTEEN-COMMERCIAL COMPLEX	R O WATER COMING SLOW - NEED TO CHECK	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	Tap rework, problem solved		Elumalai. M. - Canteen - Boys Hostel	19/04/2023
Comp. Dt. : 11/04/2023 Status : Completed								
805	23040320	Mit boys hostel	BLOCK IN GROUND FLOOR RESTROOM - WATER COMING OUTSIDE ROAD	Sakthivel. E.,Govindan. R.,Thanuzkodi. E	BLOCK REMOVED.		Sambasivam. K. - Canteen - Boys Hostel	13/04/2023
806	23040321	Mit boys hostel	NEED CLEANING & CUTTING UNWANTED TREES & GRASS IN & AROUND BOYS HOSTER	Pandiaraj. V.	GARDEN COMPLAINTS		Sambasivam. K. - Canteen - Boys Hostel	28/04/2023
Comp. Dt. : 13/04/2023 Status : Completed								
807	23040403	Boys hostel P.H-III	NEED TO CHECK R O WATER PIPELINE - WATER COMING SLOW IN III FLOOR WATER COOLER	Sivaraja. M.,Santhosh Kumar. M.,Gopal. S.	RO Water line rework, work completed		Sambasivam. K. - Canteen - Boys Hostel	20/04/2023
808	23040404	Boys hostel PH-I	NEED TAP REPAIRING WORK FOR ROOM NO 25 - WATER FLOW NEED URGENT SERVICE	Ramkumar. R.,Sivaraja. M.,Sellaveeran. M.	Tap changed, problem solved		Sambasivam. K. - Canteen - Boys Hostel	20/04/2023
809	23040405	Boys hostel Phase-II	NEED TAP REPAIRING WORK FOR II FLOOR COMMON REST ROOM - WATER FLOW NEED URGENT SERVICE	Sivaraja. M.,Santhosh Kumar. M.,Gopal. S.	New Tap changed, problem solved		Sambasivam. K. - Canteen - Boys Hostel	20/04/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 17/04/2023 Status : Completed								
810	23040529	Boys hostel PH-I	NEED REPAIRING WORK FOR SHOWER GATE VALVE - ROOM NO 27	Sivaraja. M.,Santhosh Kumar. M.,Gopal. S.	NEW SHOWER CHANGED AND CONCEALED FIXED.		Sambasivam. K. - Canteen - Boys Hostel	19/05/2023
Comp. Dt. : 19/04/2023 Status : Completed								
811	23040608	BOYS HOSTEL-DINING HALL	NEED TO CHECK WASH BASIN WATER PIPE LINE - WATER COMING SLOW - 3 NOS AT DINNING HALL NO 2	Udhaya Kumar. R.	FILTER BLOCK REMOVED.		Sambasivam. K. - Canteen - Boys Hostel	28/04/2023
Comp. Dt. : 24/04/2023 Status : Completed								
812	23040767	Boys hostel P.H-III	SHOWER NOT WORKING ROOM NO 9	Sivaraja. M.,Sellaveeran. M.,Santhosh Kumar. M.	SHOWER CHANGED.		Sambasivam. K. - Canteen - Boys Hostel	06/05/2023
Comp. Dt. : 27/04/2023 Status : Completed								
813	23040915	Boys hostel P.H-III	IN ROOM NO 9 - NEED TO CHANGE FLUSH , WASH BASIN . HAND SHOWER , & TAP FOR RESTROOM [ALL DAMA	Sivaraja. M.,Santhosh Kumar. M.,Ramkumar. R.	FLUSH TANK, WASH BASIN, HEALTH FAUCET AND TAP CHANGED.		Sambasivam. K. - Canteen - Boys Hostel	06/05/2023
Comp. Dt. : 28/04/2023 Status : Completed								
814	23040975	Boys hostel PH-I	RESTROOM DRAINAGE BLOCK AT ROOM NO 3	Sakthivel. E.,Govindan. R.,Kathirvelu. K.	BLOCK REMOVED.		Sambasivam. K. - Canteen - Boys Hostel	03/05/2023
Comp. Dt. : 08/05/2023 Status : Completed								
815	23050289	BOYS HOSTEL MESS	WATER NOT COMING - PROBLEM IN KITCHEN AREA , STEAM BOILER	Sellaveeran. M.,Sivaraja. M.,Santhosh Kumar. M.	WATER LINE AIR LOCK RELEASED.		Kesavaraj. P. - Canteen - Boys Hostel	10/05/2023
Comp. Dt. : 11/05/2023 Status : Completed								
816	23050442	Boys hostel P.H-III	WATER LEAKAGE NEED TO CHECK ROOM NO 10 [WASH BASIN] & E WC ROOM NO 5	Sivaraja. M.,Gopal. S.,Sellaveeran. M.	Wash basin waste hose changed.		Sambasivam. K. - Canteen - Boys Hostel	16/05/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
817	23050578	Mit boys hostel	BLOCK IN I FLOOR COMMON RESTROOM	Sakthivel. E.	block removed		Sambasivam. K. - Canteen - Boys Hostel	16/05/2023
Comp. Dt. : 19/05/2023								
Status : Completed								
818	23050784	Boys hostel P.H-III	NEED REPAIRING WORK FOR WASH BASIN ROOM NO 34	Sivaraja. M.,Santhosh Kumar. M.,Gopal. S.	Wash basin changed in room no.02,03,34,41. pvc pillar cock, connection tube, waste hose, waste coupl		Sambasivam. K. - Canteen - Boys Hostel	13/06/2023
819	23050785	Boys hostel PH-I	NEED TO CHANGE COOLER TAP- BROKEN AT II FLOOR	Sivaraja. M.,Sellaveeran. M.,Santhosh Kumar. M.	COOLER TAP CHANGED.		Sambasivam. K. - Canteen - Boys Hostel	01/06/2023
Comp. Dt. : 22/05/2023								
Status : Completed								
820	23050852	BOYS HOSTEL MESS	WATER NOT COMING IN BOILER	Udhaya Kumar. R.	WORK COMPLETED		Elumalai. M. - Canteen - Boys Hostel	24/05/2023
Comp. Dt. : 24/05/2023								
Status : Completed								
821	23050947	Boys hostel P.H-III	NEED TO SPRAY " TERMITE SPRAY" FOR CUPBOARD - ROOM NO 43 & 44	Kannan. V.	TERMITE REPELLANT SPRAYED.		Sambasivam. K. - Canteen - Boys Hostel	25/05/2023
Comp. Dt. : 29/05/2023								
Status : Completed								
822	23051151	Boys hostel PH-I	NEED TO CHANGE COOLER TAP - WATER LEAKAGE AT II FLOOR	Sivaraja. M.,Santhosh Kumar. M.,Gopal. S.	COOLER TAP CHANGED.		Sambasivam. K. - Canteen - Boys Hostel	03/06/2023
Comp. Dt. : 03/06/2023								
Status : Completed								
823	23060103	Boys hostel	WASH BASIN BLOCK AT DINNING HALL II - NEED URGENT SERVICE	Sivaraja. M.,Santhosh Kumar. M.,Gopal. S.	BLOCK REMOVED.		Sambasivam. K. - Canteen - Boys Hostel	03/06/2023
Comp. Dt. : 05/06/2023								
Status : Completed								
824	23060152	Boys hostel	PROBELM - RO WATER NOT COMING - EVERY MONDAY PROBLEM	Santhosh Kumar. M.,Azhagar. N.,Sellaveeran. M.	BREAKER TRIP. ELECTRICAL PROBLEM.		Sambasivam. K. - Canteen - Boys Hostel	06/06/2023
Comp. Dt. : 07/06/2023								
Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
825	23060239	Boys hostel	FLUSH NOT WORKING	Sivaraja. M.,Sankar. R.,Sellaveeran. M.	FLUSH TANK REWORK DONE.		Elumalai. M. - Canteen - Boys Hostel	08/06/2023
Comp. Dt. : 08/06/2023 Status : Completed								
826	23060282	Boys hostel PH-I	NEED TO CHANGE DRINKING WATER TAP - DAMAGE WATER LEAKAGE AT II FLOOR	Santhosh Kumar. M.,Sellaveeran. M.,Azhagar. N.	PVC TAP CHANGED.		Sambasivam. K. - Canteen - Boys Hostel	08/06/2023
827	23060283	Boys hostel Phase-II	WATER LEAKAGE AT WATER COOLER TANK AT II FLOOR	Sivaraja. M.,Santhosh Kumar. M.,Sellaveeran. M.	TAP AND FLOAT VALVE REWORK DONE.		Sambasivam. K. - Canteen - Boys Hostel	10/06/2023
Comp. Dt. : 12/06/2023 Status : Completed								
828	23060406	Boys hostel Phase-II	URINAL BLOCK AT III FLOOR COMMON RESTROOM	Sakthivel. E.,Govindan. R.,Thanuzkodi. E	block removed		Sambasivam. K. - Canteen - Boys Hostel	13/06/2023
Comp. Dt. : 21/06/2023 Status : Completed								
829	23060766	Boys hostel PH-I	FLUSH TANK NOT WORKING ROOM NO 12	Sivaraja. M.,Santhosh Kumar. M.,Sellaveeran. M.	Flush tank rework done		Sambasivam. K. - Canteen - Boys Hostel	23/06/2023
830	23060767	Boys hostel P.H-III	NEED TO SPRAY "INSECT SPRAY " ROOM NO 32 - NEED URGENT SERVICE	Sivaraja. M.,Santhosh Kumar. M.,Sellaveeran. M.	Mosquito repellent sprayed.		Sambasivam. K. - Canteen - Boys Hostel	22/06/2023
Dept Name : Canteen - Hospital - Civil - Maintenance Comp. Dt. : 11/05/2022 Status : Completed								
831	22050368	DIET DEPARMENT	NEED TO 5 NOS MAN POWER FOR SHIFTING RICE IN GROUND FLOOR TO FIFTH FLOOR	Pandiaraj. V.,Yuvaraj. M.,Thulasi. V.	Rice bag shifting work completed		Shaik Haja Mohideen. S.M. - Canteen - Hospital	11/05/2022
Comp. Dt. : 03/09/2022 Status : Completed								
832	22090114	DIET DEPARMENT	NEED LABOURS 5 NOS FOR SHIFTING OIL TINS & RICE , WHEET BAGS FROM V FLOOR TO VI FLOOR STORE ROOM	Prakash. N.,Pandiaraj. V.,Yuvaraj. M.	Rice bags shifted to 5th floor		Suriyaprakash. R. J. - Canteen - Hospital	03/09/2022
Comp. Dt. : 08/09/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
833	22090296	OPTICAL SHOP NEAR OPHTHAL OPD	NEED LABOUR 6 NOS FOR RICE BAGS [56NOS] SHIFTING WORK FROM NEAR OPTICAL SHOP TO V FLOOR DIET DEPT	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	56 Nos Rice bags shifting work completed		Suriyaprakash. R. J. - Canteen - Hospital	09/09/2022
Comp. Dt. : 19/09/2022 Status : Completed								
834	22090699	DIET DEPARMENT	NEED LABOURS 4NOS FOR UNLOADING RICE BAGS FROM V FLOOR TO VI FLOOR STORE ROOM	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	Bags shifted to terrace		Suriyaprakash. R. J. - Canteen - Hospital	19/09/2022
Comp. Dt. : 22/09/2022 Status : Completed								
835	22090863	DIET DEPARMENT	NEED TO CHECK WASH BASIN DRAINAGE HOSE - DAMAGE & WATER LEAKAGE	Prakash. V.,Rajendran. R.,Ramkumar. R.	Waste hose changed.		Sankar. M. - Canteen - Hospital	22/09/2022
Comp. Dt. : 28/10/2022 Status : Completed								
836	22100923	DIET DEPARMENT	NEED MANPOWER TO SHIFT RICE BUNDLE TO TERROUS(NEAR OPTHAL OPD)	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	Rice bag shifting work completed.		Suriyaprakash. R. J. - Canteen - Hospital	29/10/2022
Comp. Dt. : 03/11/2022 Status : Completed								
837	22110062	DIET DEPARMENT	NEED FOUR LABOURS FOR SHIFTING PURPOSE	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	Rice bags shifting work completed.		Suriyaprakash. R. J. - Canteen - Hospital	04/11/2022
Comp. Dt. : 10/11/2022 Status : Completed								
838	22110384	DIET DEPARMENT	NEED 4 MANPOWER TO SHIFT RICE BUNDLE TO TERROUS	Prakash. N.,Pandiaraj. V.,Yuvaraj. M.	Rice bags shifted to terrace		Suriyaprakash. R. J. - Canteen - Hospital	11/11/2022
Comp. Dt. : 18/11/2022 Status : Completed								
839	22110756	DIET DEPARMENT	NEED LABOURS 2 NOS FOR [WHEET BAG - 6 NOS] SHIFTING WORK FROM NEAR OPTHAL SHOP TO V FLOOR STORE ROOM	Pandiaraj. V.	Shifitng work completed		Suriyaprakash. R. J. - Canteen - Hospital	18/11/2022
Comp. Dt. : 21/11/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
840	22110845	DIET DEPARMENT	RAT PROBLEM IN STORE ROOM	Pandiaraj. V.	Rat problem rectified.		Suriyaprakash. R. J. - Canteen - Hospital	23/11/2022
841	22110893	DIET DEPARMENT	NEED LABOURS FOR SHIFTING WORK	Pandiaraj. V.,Prakash. N.,Murali. K.	Shifting work completed.		Suriyaprakash. R. J. - Canteen - Hospital	25/11/2022
Comp. Dt. : 28/11/2022 Status : Completed								
842	22111159	DIET DEPARMENT	NEED LABOURS FOR SHIFTING 30 NO'S RICE BUNDLE FROM OPHTHAL OPD TO TERROUS	Prakash. N.,Pandiaraj. V.,Yuvaraj. M.	Rice bag shifting work completed.		Suriyaprakash. R. J. - Canteen - Hospital	28/11/2022
Comp. Dt. : 05/12/2022 Status : Completed								
843	22120147	OPTICAL SHOP NEAR OPHTHAL OPD	NEED MANPOWER 5 NOS FOR SHIFTING RICE BAGS 14 NOS FROM OPTICAL SHOP NEAR OPHTHAL OPD TO VI FLOOR DIE	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	Rice bag shifting work completed from Ground floor H Wing to Terrace V Floor Hospital canteen		Suriyaprakash. R. J. - Canteen - Hospital	05/12/2022
Comp. Dt. : 09/12/2022 Status : Completed								
844	22120399	DIET DEPARMENT	NEED LABOURS 5 NOS FOR UNLOADING WORK - FROM V FLOOR TO VI FLOOR	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	Unloading work completed.		Suriyaprakash. R. J. - Canteen - Hospital	10/12/2022
Comp. Dt. : 16/12/2022 Status : Completed								
845	22120740	DIET DEPARMENT	NEED MANPOWER 5 NOS FOR UNLOADING RICE BAGS FROM 5TH FLOOR TO 6TH FLOOR STORE ROOM	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	Rice bags unloading and shifting work completed		Suriyaprakash. R. J. - Canteen - Hospital	19/12/2022
Comp. Dt. : 23/12/2022 Status : Completed								
846	22121056	DIET DEPARMENT	NEED 4 LABOURS FOR WHEAT BAG SHIFTING WORK	Pandiaraj. V.,Yuvaraj. M.,Thulasi. V.	Rice bag shifting work completed		Suriyaprakash. R. J. - Canteen - Hospital	23/12/2022
Comp. Dt. : 18/01/2023 Status : Completed								
847	23010601	DIET DEPARMENT	NEED LABOURS 4 NOS FOR UNLOADING RICE BAGS FROM 5 FLOOR TO 6 FLOOR	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	Rice bags shifting work done.		Suriyaprakash. R. J. - Canteen - Hospital	20/01/2023
Comp. Dt. : 25/01/2023								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
848	23010896	DIET DEPARMENT	NEED MANPOWER 4 NOS FOR KITCHEN ITEM SHIFTING WORK FROM 5 TO 6 FLOOR	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	Shifting work completed		Suriyaprakash. R. J. - Canteen - Hospital	27/01/2023
Comp. Dt. : 08/02/2023								
Status : Completed								
849	23020263	DIET DEPARMENT	NEED LABOURS FOR RICE BAG AND TIN SHIFTING WORK - 4 NOS	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	Rice bag Shifting work completed		Suriyaprakash. R. J. - Canteen - Hospital	08/02/2023
Comp. Dt. : 14/02/2023								
Status : Completed								
850	23020536	DIET DEPARMENT	NEED LABOURS 5 NOS FOR RICE BAG SHIFTING WORK FROM OPHTHAL SHOP NEAR TO VI FLOOR STORE ROOM	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	RICE BAG SHIFTING WORK COMPLETED.		Suriyaprakash. R. J. - Canteen - Hospital	16/02/2023
Comp. Dt. : 22/02/2023								
Status : Completed								
851	23020875	DIET DEPARMENT	(1441) 55 RICE BAGS SHIFTING WORK (GROUND FLOOR TO 5TH FLOOR)	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	RICE BAGS SHIFTING WORK DONE.		Suriyaprakash. R. J. - Canteen - Hospital	24/02/2023
Comp. Dt. : 13/03/2023								
Status : Completed								
852	23030473	OPTICAL SHOP NEAR OPHTHAL OPD	NEED MANPOWER 4 NOS FOR SHIFTING RICE BAGS FROM OPTICAL SHOP NEAR TO V TH FLOOR	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	RICE BAGS SHIFTED		Suriyaprakash. R. J. - Canteen - Hospital	17/03/2023
Comp. Dt. : 14/03/2023								
Status : Completed								
853	23030516	DIET DEPARMENT	NEED MANPOWER 4 NOS FOR SHIFTING RICE BAGS FROM V FLOOR TO IV FLOOR STORE ROOM	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	RICE BAGS SHIFTING WORK COMPLETED.		Suriyaprakash. R. J. - Canteen - Hospital	17/03/2023
Comp. Dt. : 05/04/2023								
Status : Completed								
854	23040140	DIET DEPARMENT	NEED MANPOWER 5 NOS FOR UNLOADING WORK FROM V FLOOR TO VI FLOOR STORE ROOM	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	WORK COMPLETED		Suriyaprakash. R. J. - Canteen - Hospital	05/04/2023
Comp. Dt. : 22/04/2023								
Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
855	23040689	DIET DEPARMENT	NEED MANPOWER 6 NOS FOR UNLOADING WORK FROM V FLOOR TO VI FLOOR	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	Rice bag shifting work completed		Suriyaprakash. R. J. - Canteen - Hospital	02/05/2023
Comp. Dt. : 23/05/2023 Status : Completed								
856	23050905	DIET DEPARMENT	NEED TO REFIX FLUSH KEY - BROKEN	Anandharaj. M.,Azhar. N.,Sellaveeran. M.	FLUSH KEY FIXED.		Suriyaprakash. R. J. - Canteen - Hospital	24/05/2023
Comp. Dt. : 02/06/2023 Status : Completed								
857	23060054	DIET DEPARMENT	NEED MANPOWER 5 NOS FOR UNLOADING WORK FROM GROUND FLOOR TO VI FLOOR	Pandiaraj. V.,Yuvaraj. M.,Thulasi. V.	UNLOADING WORK COMPLETED.		Suriyaprakash. R. J. - Canteen - Hospital	02/06/2023
Dept Name : Canteen-Girls Hostel - Civil - Maintenance Comp. Dt. : 02/05/2022 Status : Completed								
858	22050009	Ladies hostel Phase-I	NEED TO FIX NEW HAND SHOWER FOR ROOM NO 50	Azhagar. N.	New 2 in 1 tap and health faucet changed		Revathy. N. - Canteen-Girls Hostel	02/05/2022
859	22050034	JR Quarters	BLOCK AT BASEMENT WASHING AREA	Rajendhiran. V.,Thanuzkodi. E.,Govindan. R.	Washing area block removed, work completed		Virgin Mary - Canteen-Girls Hostel	02/05/2022
Comp. Dt. : 04/05/2022 Status : Completed								
860	22050098	Ladies hostel Phase-I	NEED TO CHECK WATER NOT COMING IN WASH BASIN- ROOM NO12 + FLUSH WATER LEAKAGE - ROOM NO 7 &16 + RE	Sellaveeran. M.,Anandharaj. M.,Arunagiri. V.	flas rework		Revathy. N. - Canteen-Girls Hostel	05/05/2022
Comp. Dt. : 07/05/2022 Status : Completed								
861	22050229	Ladies hostel Phase-II	WASH BASIN OUTLET WATER LEAKAGE AT III FLOOR REST ROOM	Sellaveeran. M.	Wash basin waste water outlet line fully rework, waste coupling, waste hose and connection tueb chan		Malliga. K. - Canteen-Girls Hostel	07/05/2022
Comp. Dt. : 09/05/2022 Status : Completed								
862	22050273	Ladies hostel Phase-II	REST ROOM BLOCK AT I & II FLOOR	Rajendhiran. V.	block remor work		Malliga. K. - Canteen-Girls Hostel	10/05/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
863	22050283	JR Quarters	NEED TO REFIX FLUSH TANK FULL SET - BROKEND & DAMAGE AT WARDEN ROOM	Sellaveeran. M.	New washer and tap changed.		Virgin Mary - Canteen-Girls Hostel	09/05/2022
864	22050298	JR Quarters	DRAINAGE OVERFLOW	Sakthivel. E., Thanuzkodi. E., Govindan. R.	Drainage block removed, work completed		Virgin Mary - Canteen-Girls Hostel	10/05/2022
Comp. Dt. : 16/05/2022 Status : Completed								
865	22050530	JR Quarters	NEED LABOURS 2 NOS FOR COT SHIFTING WORK FROM GROUND FLOOR TO I FLOOR	Pandiaraj. V., Yuvaraj. M., Senthil Kumar. R.	cot shifting work done		Virgin Mary - Canteen-Girls Hostel	17/05/2022
866	22050555	Ladies hostel Phase-II	NEED TO CHANGE RESTROOM TAP - WATER LEAKAGE - ROOM NO 11 & HAND SHOWER FOR ROOM NO 15	Anandharaj. M.	Tap and Hand shower changed.		Revathy. N. - Canteen-Girls Hostel	16/05/2022
Comp. Dt. : 17/05/2022 Status : Completed								
867	22050630	Ladies hostel Phase-I	NEED TO CHANGE TAP - WATER LEAKAGE IN WASHING AREA	Anandharaj. M., Sellaveeran. M., Udhaya Kumar. R.	Old water heater fixed with scrub		Revathy. N. - Canteen-Girls Hostel	20/05/2022
Comp. Dt. : 18/05/2022 Status : Completed								
868	22050651	Ladies hostel Phase-II	WATER NOT COMING IN I FLOOR WASH BASIN & BLOCK IN III FLOOR REST ROOM	Sakthivel. E.	Wash basin rework. Block removed in 3rd floor restroom		Malliga. K. - Canteen-Girls Hostel	20/05/2022
Comp. Dt. : 19/05/2022 Status : Completed								
869	22050725	LADIES HOSTEL MESS	DRAINAGE BLOCK - NEED URGENT SERVICE	Sakthivel. E.	Block removed.		Revathy. N. - Canteen-Girls Hostel	20/05/2022
Comp. Dt. : 20/05/2022 Status : Completed								
870	22050767	Ladies hostel Phase-II	DRAINAGE PIPELINE DAMAGE WATER LEAKAGE AT PHASE II BACKSIDE	Anandharaj. M.	1.1/2" drainage pipe line rework, problem solved		Malliga. K. - Canteen-Girls Hostel	24/05/2022
Comp. Dt. : 21/05/2022 Status : Completed								
871	22050790	JR Quarters	REST ROOM BLOCK IN GROUND FLOOR	Govindan. R.	Toilet block removed, work completed		Virgin Mary - Canteen-Girls Hostel	21/05/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 23/05/2022 Status : Completed								
872	22050819	Ladies hostel Phase-I	NEED TO REFIX HAND SHOWER , SEAT COVER & HANGER FOR ROOM NO 9	Anandharaj. M.	ew Handshower and seat cover fixed, problem solved		Revathy. N. - Canteen-Girls Hostel	24/05/2022
Comp. Dt. : 24/05/2022 Status : Completed								
873	22050859	JR Quarters	BLOCK IN WASH BASIN - GROUND FLOOR RESTROON OPPOSITE	Rajendhiran. V.	Block removed in the wash basin		Virgin Mary - Canteen-Girls Hostel	25/05/2022
874	22050864	Ladies hostel Phase-II	DRAINAGE BLOCK AT BACK SIDE OF LADIES HOSTEL PHASE II	Thanuzkodi. E.,Govindan. R.,Sakthivel. E.	block removed in the drainage.		Malliga. K. - Canteen-Girls Hostel	25/05/2022
875	22050897	Ladies hostel Phase-II	DRINKING WATER PIPE LINE BROKENED - WATER FLOW - NEED URGENT SERVICE	Anandharaj. M.,Sellaveeran. M.,Azhagar. N.	Water pipe line rework, problem solved		Malliga. K. - Canteen-Girls Hostel	25/05/2022
876	22050900	Ladies hostel Phase-II	NEED TO REFIX SOAP DISH FOR IV FLOOR RESTROOM	Azhagar. N.	6Nos of new soap dish fixed, work completed		Malliga. K. - Canteen-Girls Hostel	10/06/2022
Comp. Dt. : 25/05/2022 Status : Completed								
877	22050926	LADIES HOSTEL MESS	NEED TO CHANGE TAP FOR TEA CANE [3 NOS]	Sivaraja. M.	New tap fixed.		Revathy. N. - Canteen-Girls Hostel	04/06/2022
Comp. Dt. : 26/05/2022 Status : Completed								
878	22050980	Ladies hostel Phase-I	DUE TO INSECT PROBLEM NEED TO SPRAY PEST SPRAY FOR BACK SIDE OF ROOM NO 9	Kannan. V.	Insecticide sprayed.		Revathy. N. - Canteen-Girls Hostel	28/05/2022
Comp. Dt. : 28/05/2022 Status : Completed								
879	22051039	Ladies hostel Phase-I	BLOCK IN RESTROOM - ROOM NO 19 & CHANGE HAND SHOWER FOR ROOM NO 55	Govindan. R.	Block removed in room no.19 and New health faucet changed in room no.55		Revathy. N. - Canteen-Girls Hostel	31/05/2022
880	22051062	Ladies hostel Phase-I	NEED TO CHANGE WASH BASIN - BROKENED- ROOM NO 21	Sellaveeran. M.	New wash basin fitting work done.		Revathy. N. - Canteen-Girls Hostel	31/05/2022
Comp. Dt. : 30/05/2022 Status : Completed								
881	22051083	Ladies hostel Phase-I	BLOCK IN RESTROOM - ROOM NO 20	Govindan. R.	Block removed		Revathy. N. - Canteen-Girls Hostel	31/05/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
882	22051096	JR Quarters	NEED TO CHANGE WASHBASIN TAP - LOOSE - [II FLOOR RESTROOM SIDE NO 1]	Azhagar. N.	Tap spindle changed, problem solved		Malliga. K. - Canteen-Girls Hostel	01/06/2022
Comp. Dt. : 01/06/2022 Status : Completed								
883	22060021	JR Quarters	BLOCK IN GROUND FLOOR RESTROOM	Thanuzkodi. E	Toilet block removed, work completed		Virgin Mary - Canteen-Girls Hostel	01/06/2022
Comp. Dt. : 04/06/2022 Status : Completed								
884	22060152	Ladies hostel Phase-I	WESTERN BASIN WATER LEAKAGE - NEED TO CHECK	Udhaya Kumar. R.	Door locked, Key not available		Revathy. N. - Canteen-Girls Hostel	08/06/2022
Comp. Dt. : 13/06/2022 Status : Completed								
885	22060460	Ladies hostel Phase-I	NEED TO CHANGE SEATCOVER FOR ROOM NO 52	Sellaveeran. M.	Seat cover changed.		Revathy. N. - Canteen-Girls Hostel	17/06/2022
Comp. Dt. : 14/06/2022 Status : Completed								
886	22060505	JR Quarters	RESTROOM BLOCK IN II FLOOR & NEED TO REFIX TAP FOR III FLOOR REST ROOM	Sakthivel. E.	Toilet block removed, work completed		Virgin Mary - Canteen-Girls Hostel	16/06/2022
Comp. Dt. : 15/06/2022 Status : Completed								
887	22060553	Ladies hostel Phase-II	NEED TO SPRAY INSECT SPRAY FOR ALL FLOOR ALL RESTROOM	Rajendran. R.	Termite sprayed in all floors		Malliga. K. - Canteen-Girls Hostel	18/06/2022
Comp. Dt. : 16/06/2022 Status : Completed								
888	22060626*	Ladies hostel Phase-I	BLOCK IN RESTROOM - ROOM NO 45	Gopal. S.,Sellaveeran. M.,Azhagar. N.	block removed.		Revathy. N. - Canteen-Girls Hostel	17/06/2022
Comp. Dt. : 17/06/2022 Status : Completed								
889	22060655	Ladies hostel Phase-I	BLOCK IN GROUND FLOOR HEATER WATER TANK	Sakthivel. E.	Block removed.		Revathy. N. - Canteen-Girls Hostel	18/06/2022
Comp. Dt. : 20/06/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
890	22060700	LADIES HOSTEL MESS	BOILER OUTLET VALVE BROKEN - NEED TO CHANGE	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	New 1*1/4 outlet valve fixed.		Revathy. N. - Canteen-Girls Hostel	25/06/2022
891	22060726	Ladies hostel Phase-I	NEED TO CHECK PIPE LINE CONNECTION - WASH BASIN TAP & RESTROOM TAP WATER NOT COMING IN ROOM NO 29	Anandharaj. M.	Pipe line connection rework. Wash basin tap and restroom tap rework		Revathy. N. - Canteen-Girls Hostel	25/06/2022
892	22060729	Ladies hostel Phase-I	WASH BASIN WATER NOT COMING IN WARDEN ROOM	Udhaya Kumar. R.	Wash basin rework done		Revathy. N. - Canteen-Girls Hostel	25/06/2022
Comp. Dt. : 21/06/2022 Status : Completed								
893	22060767	JR Quarters	FLUSH WATER LEAKAGE IN I FLOOR COMMON REST ROOM	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	Flush tnak washer changed, work completed		Virgin Mary - Canteen-Girls Hostel	30/06/2022
Comp. Dt. : 22/06/2022 Status : Completed								
894	22060782	Ladies hostel Phase-I	BLOCK IN REST ROOM - ROOM NO 10	Govindan. R.,Thanuzkodi. E,Rajendhiran. V.	Block removed.		Revathy. N. - Canteen-Girls Hostel	24/06/2022
Comp. Dt. : 23/06/2022 Status : Completed								
895	22060822	JR Quarters	NEED LABOURS 3 NOS FOR COT SHIFTING WORK FROM BASEMENT TO I FLOOR	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	COT shifting work completed.		Virgin Mary - Canteen-Girls Hostel	24/06/2022
896	22060827	JR Quarters	NEED LABOURS 4 NOS FOR TABLE SHIFTING WORK FROM JR TO WORKSHOP	Pandiaraj. V.,Yuvaraj. M.,Murali. K.	Table shifting work completed.		Virgin Mary - Canteen-Girls Hostel	24/06/2022
Comp. Dt. : 24/06/2022 Status : Completed								
897	22060870	Ladies hostel Phase-I	NEED TO CHANGE SEAT COVER FOR ROOM NO 52	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	Seat cover changed.		Revathy. N. - Canteen-Girls Hostel	25/06/2022
898	22060892	Ladies hostel Phase-II	DUE TO ENTER OF HONEY BEE & SNAKE , NEED TO "SPRAY" FROM IV FLOOR TO ENTRANCE & BASEMENT	Kannan. V.	Borate, Mosquito chemical sprayed, work completed		Malliga. K. - Canteen-Girls Hostel	30/06/2022
899	22060893	Ladies hostel Phase-II	BLOCK IN IV FLOOR RESTROOM	Govindan. R.	block removed		Malliga. K. - Canteen-Girls Hostel	25/06/2022
Comp. Dt. : 25/06/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
900	22060909	Ladies hostel Phase-II	RESTROOM BLOCK - NEED TO REFIX OUTLET WATER FILTER FOR ROOM NO 10 & 49	Rajendhiran. V.	Block removed.		Malliga. K. - Canteen-Girls Hostel	25/06/2022
Comp. Dt. : 27/06/2022 Status : Completed								
901	22060945	Ladies hostel Phase-II	BLOCK IN II FLOOR REST ROOM	Govindan. R.	Block removed.		Malliga. K. - Canteen-Girls Hostel	28/06/2022
Comp. Dt. : 29/06/2022 Status : Completed								
902	22061065*	Ladies hostel Phase-II	NEED TO DESTROY HONEY COMB FOR AT LADIES HOSTEL IV FLOOR STUDY HALL AND MEDICAL COLLEGE OUTER SIDE	Sivaraja. M.	2Nos of Honey comb destroyed, work completed		Malliga. K. - Canteen-Girls Hostel	30/06/2022
Comp. Dt. : 02/07/2022 Status : Completed								
903	22070061	Ladies hostel Phase-I	BLOCK IN REST ROOM - ROOM NO 25	Sakthivel. E.	Toilet block removed, work completed		Revathy. N. - Canteen-Girls Hostel	04/07/2022
Comp. Dt. : 04/07/2022 Status : Completed								
904	22070112	Ladies hostel Phase-II	NEED TO FIX TOWEL STAND FOR IV FLOOR	Anandharaj. M.	Towel stand fixed, problem solved		Malliga. K. - Canteen-Girls Hostel	05/07/2022
Comp. Dt. : 05/07/2022 Status : Completed								
905	22070137	Ladies hostel Phase-I	BLOCK IN REST ROOM - ROOM NO 25	Sakthivel. E.	Toilet block removed, work completed		Revathy. N. - Canteen-Girls Hostel	06/07/2022
Comp. Dt. : 06/07/2022 Status : Completed								
906	22070192	Ladies hostel Phase-II	NEED TO FIX SOAP STAND 2 NOS FOR III FLOOR RESTROOM	Rajendran. R.	2nos. soap stand and towel rod fixing work		Malliga. K. - Canteen-Girls Hostel	09/07/2022
Comp. Dt. : 11/07/2022 Status : Completed								
907	22070418	JR Quarters	need to check water pipe line connection - water not coming	Sellaveeran. M.	3/4" UPVC pipe line fully rework, problem solved		Malliga. K. - Canteen-Girls Hostel	15/07/2022
Comp. Dt. : 12/07/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
908	22070474	JR Quarters	WASH BASIN BLOCK AT GROUND & I FLOOR	Rajendran. R.,Govindan. R.,Sakthivel. E.	Toilet block removed, work completed		Virgin Mary - Canteen-Girls Hostel	13/07/2022
	Comp. Dt. : 13/07/2022							
	Status : Completed							
909	22070492	JR Quarters	WATER NOT COMING IN WASH BASIN - GROUND FLOOR & I FLOOR	Udhaya Kumar. R.	3/4" UPVC pipe line fully rework, problem solved		Virgin Mary - Canteen-Girls Hostel	15/07/2022
	Comp. Dt. : 19/07/2022							
	Status : Completed							
910	22070708	Ladies hostel Phase-II	WASH BASIN DRAINAGE WATER LEAKAGE AT I FLOOR	Sellaveeran. M.	Waste coupling replaced with new one.		Malliga. K. - Canteen-Girls Hostel	03/08/2022
	Comp. Dt. : 21/07/2022							
	Status : Completed							
911	22070782	Ladies hostel Phase-II	BLOCK IN IV FLOOR RESTROOM	Sakthivel. E.	Block removed.		Malliga. K. - Canteen-Girls Hostel	22/07/2022
	Comp. Dt. : 22/07/2022							
	Status : Completed							
912	22070842	JR Quarters	NEED TO CHANGE TAP FOR I FLOOR COOLER - LEAKAGE	Anandharaj. M.,Santhosh Kumar. M.,Sellaveeran. M.	tAP REWORK		Virgin Mary - Canteen-Girls Hostel	26/07/2022
913	22070846	JR Quarters	BLOCK INGROUND FLOOR WASHING AREA	Sakthivel. E.	Block removed.		Virgin Mary - Canteen-Girls Hostel	26/07/2022
	Comp. Dt. : 23/07/2022							
	Status : Completed							
914	22070874	Ladies hostel Phase-II	WATER NOT COMING IN IV FLOOR RESTROOM - NEED TO CHANGE TAP	Sellaveeran. M.,Udhaya Kumar. R.,Anandharaj. M.	Tap changed.		Malliga. K. - Canteen-Girls Hostel	26/07/2022
	Comp. Dt. : 25/07/2022							
	Status : Completed							
915	22070902	JR Quarters	BLOCK IN IV FLOOR RESTROOM & WATERNOT COMING IN WASH BASIN AT I & GROUND FLOOR	Govindan. R.	Block removed.		Virgin Mary - Canteen-Girls Hostel	26/07/2022
	Comp. Dt. : 26/07/2022							
	Status : Completed							
916	22070943	JR Quarters	BLOCK IN IV FLOOR RESTROOM	Govindan. R.	Block removed.		Virgin Mary - Canteen-Girls Hostel	27/07/2022
	Comp. Dt. : 01/08/2022							
	Status : Completed							


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
917	22080014	JR Quarters	NEED TO FIX TAP FOR COOLER	Santhosh Kumar. M.	Cooler tap changed, Toilet - Tap and flush tank washer changed, work completed		Virgin Mary - Canteen-Girls Hostel	01/08/2022
918	22080018	Ladies hostel Phase-I	FLUSH NOT WORKING - ROOM NO 21	Santhosh Kumar. M.	Flush tank fullset rework and refixed in properly, work completed		Revathy. N. - Canteen-Girls Hostel	01/08/2022
919	22080033	Ladies hostel Phase-II	DRAINAGE WATER LEAKAGE AT BACKSIDE OF HOSTEL & WASH BASIN TAP WATER LEAKAGE AT III FLOOR RESTROOM	Sellaveeran. M.	1.1/4" waste coupling changed.		Malliga. K. - Canteen-Girls Hostel	04/08/2022
Comp. Dt. : 02/08/2022 Status : Completed								
920	22080081	Ladies hostel Phase-II	BLOCK IN 3 FLOOR REST ROOM	Sakthivel. E., Thanuzkodi. E., Murugan. S.	Block removed.		Malliga. K. - Canteen-Girls Hostel	03/08/2022
Comp. Dt. : 04/08/2022 Status : Completed								
921	22080162	Ladies hostel Phase-I	IN ROOM NO.23 AND 40 FLUSH NOT WORKING	Anandharaj. M., Azhagar. N., Sellaveeran. M.	Flush tank rework done		Revathy. N. - Canteen-Girls Hostel	09/08/2022
Comp. Dt. : 08/08/2022 Status : Completed								
922	22080251	Ladies hostel Phase-I	NEED TO REFIX WASH BASIN AT ROOM NO 17 [DAMAGE & UNFIXING]	Anandharaj. M., Sellaveeran. M., Udhaya Kumar. R.	Key is not available.		Revathy. N. - Canteen-Girls Hostel	23/08/2022
Comp. Dt. : 10/08/2022 Status : Completed								
923	22080361	LADIES HOSTEL MESS	CEILING WATER LEAKAGE	Anandharaj. M., Azhagar. N., Sellaveeran. M.	3/4" pipe changed.		Revathy. N. - Canteen-Girls Hostel	23/08/2022
924	22080374	JR Quarters	WESTERN - WATER LEAKAGE IN GROUND FLOOR COMMON REST ROOM	Anandharaj. M., Azhagar. N., Sellaveeran. M.	Pipe line rework done.		Virgin Mary - Canteen-Girls Hostel	22/08/2022
Comp. Dt. : 12/08/2022 Status : Completed								
925	22080427	JR Quarters	NEED TO CHANGE TAP FOR I & II FLOOR COOLER	Anandharaj. M.	Cooler tap rework.		Virgin Mary - Canteen-Girls Hostel	18/08/2022
Comp. Dt. : 13/08/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
926	22080475	JR Quarters	BLOCK IN III FLOOR RESTROOM	Sakthivel. E.	Block removed.		Virgin Mary - Canteen-Girls Hostel	18/08/2022
		Comp. Dt. : 17/08/2022 Status : Completed						
927	22080526	Ladies hostel Phase-II	IN GARDENING AREA-WATER PIPE LEAKAGING PROBLEM	Azhagar. N.	leakage arrested.		Malliga. K. - Canteen-Girls Hostel	23/08/2022
		Comp. Dt. : 23/08/2022 Status : Completed						
928	22080752	Ladies hostel Phase-I	NEED TO CHECK III FLOOR HEATER - WATER COMING SLOW	Anandharaj. M., Sellaveeran. M., Udhaya Kumar. R.	Tap changed.		Revathy. N. - Canteen-Girls Hostel	30/08/2022
		Comp. Dt. : 26/08/2022 Status : Completed						
929	22080897	JR Quarters	DRINKING WATER NOT COMING AT GROUND FLOOR	Anandharaj. M., Azhagar. N., Udhaya Kumar. R.	Water coming		Virgin Mary - Canteen-Girls Hostel	29/08/2022
		Comp. Dt. : 27/08/2022 Status : Completed						
930	22080937	Ladies hostel Phase-II	NEED TO CUT & CLEAN UNWANTED TREES & BRANCES AT PHASE I SIDE	Gopal. S.	garden complaints		Malliga. K. - Canteen-Girls Hostel	09/09/2022
		Comp. Dt. : 03/09/2022 Status : Completed						
931	22090116	JR Quarters	NEED CLEANING WORK & CUTTING UNWANTED GRASS & TREES FOR IN AND AROUND JR QUARTERS	Anandharaj. M.	Garden complaints.		Virgin Mary - Canteen-Girls Hostel	06/09/2022
		Comp. Dt. : 05/09/2022 Status : Completed						
932	22090179	JR Quarters	BLOCK IN GROUND FLOOR RESTROOM	Sakthivel. E.	block removed.		Virgin Mary - Canteen-Girls Hostel	07/09/2022
933	22090196	Ladies hostel Phase-II	BLOCK IN GROUND FLOOR RESTROOM	Sakthivel. E.	Block removed.		Malliga. K. - Canteen-Girls Hostel	07/09/2022
		Comp. Dt. : 06/09/2022 Status : Completed						
934	22090232	JR Quarters	NEED TO CHANGE WASH BASIN DRAINAGE HOSE AT GROUND FLOOR RESTROOM	Anandharaj. M., Udhaya Kumar. R., Santhosh Kumar. M.	Block removed.		Virgin Mary - Canteen-Girls Hostel	09/09/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 07/09/2022								
Status : Completed								
935	22090269	Ladies hostel Phase-I	RESTROOM BLOCK AT I & II FLOOR	Sakthivel. E.	Restroom block removed.		Malliga. K. - Canteen-Girls Hostel	08/09/2022
936	22090290	Ladies hostel Phase-II	NEED TO SPRAY " INSECT SPRAY" FOR ALL FLOOR ALL RESTROOMS	Sakthivel. E.	insecticide sprayed.		Malliga. K. - Canteen-Girls Hostel	09/09/2022
Comp. Dt. : 08/09/2022								
Status : Completed								
937	22090306	JR Quarters	NEED TO CHANGE WASH BASIN DRAINAGE HOSE - DAMAGE & WATER LEAKAGE AT GROUND & I FLOOR REST ROOM	Santhosh Kumar. M., Sellaveeran. M., Udhaya Kumar. R.	Wash basin connection tube changed.		Virgin Mary - Canteen-Girls Hostel	09/09/2022
938	22090331	JR Quarters	BLOCK IN GROUND FLOOR RESTROOM	Govindan. R.	Toilet block removed, work completed		Virgin Mary - Canteen-Girls Hostel	09/09/2022
Comp. Dt. : 09/09/2022								
Status : Completed								
939	22090365	JR Quarters	NEED TO REFIX TAP VALVE FOR II FLOOR HEATER	Anandharaj. M.	Non return valve to be change, inform to electrical department		Virgin Mary - Canteen-Girls Hostel	12/09/2022
Comp. Dt. : 10/09/2022								
Status : Completed								
940	22090393	JR Quarters	NEED TO CHANGE TAP 3 NOS FOR GROUND & FIRST FLOOR	Anandharaj. M., Sellaveeran. M., Udhaya Kumar. R.	New 3Nos of PVC Tap changed in Ground and I Floor, problem solved		Virgin Mary - Canteen-Girls Hostel	12/09/2022
941	22090400	Ladies hostel Phase-II	BLOCK IN III FLOOR RESTROOM	Sakthivel. E.	Toilet block removed, work completed		Malliga. K. - Canteen-Girls Hostel	12/09/2022
Comp. Dt. : 12/09/2022								
Status : Completed								
942	22090425	Ladies hostel Phase-I	BLOCK IN ROOM NO 18	Sakthivel. E.	block removed.		Revathy. N. - Canteen-Girls Hostel	15/09/2022
Comp. Dt. : 16/09/2022								
Status : Completed								
943	22090640	JR Quarters	NEED TO CHECK & CHANGE TAP & FLUSH KEY - WATER LEAKAGE AT I FLOOR COMMON RESTROOM	Udhaya Kumar. R.	Wash basin pillar cork rework and cooler tap fixed. Flush tank rework.		Virgin Mary - Canteen-Girls Hostel	24/09/2022
Comp. Dt. : 19/09/2022								
Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
944	22090725*	Ladies hostel Phase-I	FLUSH TANK DAMAGE & WATER NOT COMING ROOM NO 58	Anandharaj. M., Azhagar. N., Sellaveeran. M.	Flush tank rework done		Revathy. N. - Canteen-Girls Hostel	21/09/2022
Comp. Dt. : 20/09/2022 Status : Completed								
945	22090760	JR Quarters	NEED TO CHECK FLUSH - WATER LEAKAGE AT I FLOOR RESTROOM & FIX TAP FOR GROUND FLOOR RESTROOM	Azhagar. N., Santhosh Kumar. M., Sellaveeran. M.	Flush tank washer fixed.		Virgin Mary - Canteen-Girls Hostel	22/09/2022
946	22090782	JR Quarters	BLOCK IN GROUND FLOOR RESTROOM	Sakthivel. E.	block removed.		Virgin Mary - Canteen-Girls Hostel	21/09/2022
947	22090790	JR Quarters	BLOCK IN BASEMENT WASHING AREA	Sakthivel. E.	Block removed.		Virgin Mary - Canteen-Girls Hostel	21/09/2022
Comp. Dt. : 23/09/2022 Status : Completed								
948	22090921	JR Quarters	WATER NOT COMING IN WASH BASIN & FLUSH TANK WATER LEAKAGE AT I FLOOR RESTROOM	Udhaya Kumar. R.	Pillar cork rework. Flush tank washer changed.		Virgin Mary - Canteen-Girls Hostel	23/09/2022
Comp. Dt. : 24/09/2022 Status : Completed								
949	22090964	JR Quarters	BLOCK IN GROUND FLOOR WASH BASIN	Sakthivel. E.	Block removed.		Virgin Mary - Canteen-Girls Hostel	27/09/2022
950	22090982	Ladies hostel Phase-I	RESTROOM BLOCK - ROOM NO 20	Sakthivel. E.	block removed.		Revathy. N. - Canteen-Girls Hostel	26/09/2022
Comp. Dt. : 26/09/2022 Status : Completed								
951	22091012	Ladies hostel Phase-I	NEED LABOURS 2 NOS FOR SHIFTING OLD COOLERS FROM LADIES HOSTEL PHASE I TO AC DEPARTMENT	Pandiaraj. V., Yuvaraj. M., Senthil Kumar. R.	Shifting work completed.		Revathy. N. - Canteen-Girls Hostel	01/10/2022
Comp. Dt. : 27/09/2022 Status : Completed								
952	22091060	JR Quarters	BLOCK IN GROUND FLOOR RESTROOM	Sakthivel. E.	Block removed.		Virgin Mary - Canteen-Girls Hostel	28/09/2022
953	22091063	Ladies hostel Phase-I	BLOCK IN RESTROOM - ROOM NO 20	Sakthivel. E.	Block removed.		Revathy. N. - Canteen-Girls Hostel	28/09/2022
954	22091064	Ladies hostel Phase-I	BLOCK IN RESTROOM - ROOM NO 20	Sakthivel. E.	Block removed.		Revathy. N. - Canteen-Girls Hostel	28/09/2022
Comp. Dt. : 28/09/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
955	22091100	JR Quarters	RESTROOM BLOCK AT III & GROUND FLOOR	Sakthivel. E.	Block removed		Virgin Mary - Canteen-Girls Hostel	30/09/2022
	Comp. Dt. : 29/09/2022							
	Status : Completed							
956	22091171	Ladies hostel Phase-I	NEED TO CHECK PIPE LINE CONNECTION - WATER NOT COMING IN HEATER AT I, II & III FLOOR	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	Electrical complaints.		Revathy. N. - Canteen-Girls Hostel	06/10/2022
	Comp. Dt. : 30/09/2022							
	Status : Completed							
957	22091199	Ladies hostel Phase-I	NEED TO CHANGE FLUSH TANK - WATER LEAKAGE - DAMAGE & BROKEN - ROOM NO 1	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	Flush tank rework		Revathy. N. - Canteen-Girls Hostel	30/09/2022
	Comp. Dt. : 05/10/2022							
	Status : Completed							
958	22100038	JR Quarters	NEED TO REMOVE AND CLEANING WORK FOR BEEHIVE - ROOMNO 37	Sivaraja. M.	Honey comb destroyed.		Virgin Mary - Canteen-Girls Hostel	11/10/2022
959	22100039	JR Quarters	BLOCK - III FLOOR RESTROOM	Sakthivel. E.	Block removed.		Virgin Mary - Canteen-Girls Hostel	07/10/2022
	Comp. Dt. : 10/10/2022							
	Status : Completed							
960	22100211	Ladies hostel Phase-I	NEED TO CHANGE TAP & WASH BASIN DRAINAGE HOSE - WATER LEAKAGE AT GROUND FLOOR MESS	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	cp tap changed.		Revathy. N. - Canteen-Girls Hostel	11/10/2022
	Comp. Dt. : 12/10/2022							
	Status : Completed							
961	22100343	Ladies hostel Phase-II	NEED TO BE CHANGE 3RD FLOOR FLUSH TANK IN COMMON BATHROOM	Anandharaj. M.	Flush tank washer changed. Flush tank rework done.		Malliga. K. - Canteen-Girls Hostel	13/10/2022
	Comp. Dt. : 13/10/2022							
	Status : Completed							
962	22100380	JR Quarters	NEED TO CHANGE HEATER TAP - WATER LEAKAGE AT I FLOOR RESTROOM	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	New CP tap fixed.		Virgin Mary - Canteen-Girls Hostel	17/10/2022
963	22100404	Ladies hostel Phase-I	NEED TO REFIX KITCHEN BOILER VALVE - DAMAGE - LEAKAGE - NEED URGENT SERVICE	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	complaint to be done by company person.		Revathy. N. - Canteen-Girls Hostel	27/10/2022
	Comp. Dt. : 15/10/2022							
	Status : Completed							


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
964	22100487	Ladies hostel Phase-I	NEED TO CHANGE TAP FOR I FLOOR COOLER - WATER LEAKAGE	Anandharaj. M.	X nipple changed. No water leakage		Revathy. N. - Canteen-Girls Hostel	15/10/2022
965	22100488	LADIES HOSTEL MESS	NEED TO CHANGE WASH BASIN DRAINAGE HOSE - DAMAGE WATER LEAKAGE	Sellaveeran. M.,Udhaya Kumar. R.,Anandharaj. M.	Wash basin drainage cleaned and refixed. Wash basin block removed.		Revathy. N. - Canteen-Girls Hostel	15/10/2022
Comp. Dt. : 17/10/2022 Status : Completed								
966	22100537	JR Quarters	NEED TO CHECK WALL - WATER LEAKAGE WALL DAMAGE AT II FLOOR	Udhaya Kumar. R.	Wall cutting work, extention Nipple 4Nos, PVC tap 3Nos changed, leakage arrested, problem solved		Virgin Mary - Canteen-Girls Hostel	28/10/2022
967	22100546	Ladies hostel Phase-I	WASH BASIN BLOCK AT MESS	Sakthivel. E.	Block removed.		Revathy. N. - Canteen-Girls Hostel	18/10/2022
Comp. Dt. : 18/10/2022 Status : Completed								
968	22100568	JR Quarters	NEED TO CHANGE FLUSH TANK - BROKEN AT I FLOOR REST ROOM	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	broken Flush tank removed		Virgin Mary - Canteen-Girls Hostel	18/10/2022
969	22100585	Ladies hostel Phase-II	BLOCK IN II FLOOR RESTROOM	Sakthivel. E.	Block removed		Malliga. K. - Canteen-Girls Hostel	18/10/2022
Comp. Dt. : 26/10/2022 Status : Completed								
970	22100799	J.R Quateres	GROUND FLOOR REST ROOM BLOCK	Sakthivel. E.	Block removed.		Virgin Mary - Canteen-Girls Hostel	27/10/2022
Comp. Dt. : 27/10/2022 Status : Completed								
971	22100870	Ladies hostel Phase-II	IN GROUND FLOOR-WATER TAP LEAKAGING PROBLEM	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	New tap fixed.		Malliga. K. - Canteen-Girls Hostel	08/11/2022
Comp. Dt. : 08/11/2022 Status : Completed								
972	22110302	Ladies hostel Phase-II	GROUND FLOOR BATHROOM WASH BASIN TAP BROKEN	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	Pillar cock changed.		Malliga. K. - Canteen-Girls Hostel	14/11/2022
Comp. Dt. : 15/11/2022 Status : Completed								
973	22110581	Ladies hostel Phase-I	IN ROOM NO.56 FLUSH NOT WORKING	Udhaya Kumar. R.	Flush tank fullset rework, washer changed, work completed		Revathy. N. - Canteen-Girls Hostel	16/11/2022
Comp. Dt. : 24/11/2022								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
974	22111068	Ladies hostel Phase-I	IN ROOM NO.58 WESTERN TOILET CEAT COVER NEED TO BE CHANGE	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	New EWC Seat cover changed, problem solved		Revathy. N. - Canteen-Girls Hostel	29/11/2022
Comp. Dt. : 28/11/2022								
Status : Completed								
975	22111198	Ladies hostel Phase-II	IN 3RD FLOOR-REST ROOM BLOCK,NEED SCAVENGER	Sakthivel. E.	block removed.		Malliga. K. - Canteen-Girls Hostel	30/11/2022
Comp. Dt. : 01/12/2022								
Status : Completed								
976	22120013	Ladies hostel Phase-II	NEED TO CHANGE REST ROOM TAP- WATER LEAKAGE AT II FLOOR COMMON RESTROOM	Sellaveeran. M.,Azhagar. N.,Udhaya Kumar. R.	Tao changed. Flush tank rework done. New washer fixed.		Malliga. K. - Canteen-Girls Hostel	06/12/2022
Comp. Dt. : 02/12/2022								
Status : Completed								
977	22120064	Ladies hostel Phase-II	NEED TO CHANGE TAP - WATER LEAKAGE AT GROUND FLOOR RESTROOM + REFIX SHOWER FOR I & II FLOOR COMMON RE	Anandharaj. M.,Azhagar. N.,Gopal. S.	Tap changed, Shower refix at 1st floor and 2nd floor restroom		Malliga. K. - Canteen-Girls Hostel	06/12/2022
Comp. Dt. : 05/12/2022								
Status : Completed								
978	22120156	Ladies hostel Phase-I	WATER NOT COMING - NEED TO CHECK PIPELINE ROOM NO 75 & 76	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	Block removed at #75. #76- Consealed cock rework, direct line connection given, problem solved		Revathy. N. - Canteen-Girls Hostel	07/12/2022
Comp. Dt. : 13/12/2022								
Status : Completed								
979	22120584	Ladies hostel Phase-II	BLOCK - I FLOOR RESTROOM	Sakthivel. E.	Block removed.		Malliga. K. - Canteen-Girls Hostel	14/12/2022
980	22120597	Ladies hostel Phase-I	NEED TO CHANGE REST ROOM TAP - WATER LEAKAGE AT ROOM NO 69	Sellaveeran. M.	New tap fixed.		Revathy. N. - Canteen-Girls Hostel	16/12/2022
Comp. Dt. : 14/12/2022								
Status : Completed								
981	22120623	Ladies hostel Phase-II	BLOCK IN II FLOOR RESTROOM	Sakthivel. E.	block removed.		Malliga. K. - Canteen-Girls Hostel	14/12/2022
Comp. Dt. : 15/12/2022								
Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
982	22120708	JR Quarters	HOT WATER NOT COMING IN GROUND FLOOR WATER PURIFIER	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	Hot water line rework done.		Virgin Mary - Canteen-Girls Hostel	17/12/2022
Comp. Dt. : 16/12/2022 Status : Completed								
983	22120780	Ladies hostel Phase-I	NEED TO CHANGE RESTROOM TAP - DAMAGE WATER LEALAGE - ROOM NO 67	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	New pillar cock fixed.		Revathy. N. - Canteen-Girls Hostel	17/12/2022
Comp. Dt. : 28/12/2022 Status : Completed								
984	22121279	J.R Quateres	3RD FLOOR RESTROOM BLOCK	Sakthivel. E.	Block removed.		Virgin Mary - Canteen-Girls Hostel	28/12/2022
Comp. Dt. : 02/01/2023 Status : Completed								
985	23010010	Ladies hostel Phase-I	in room no.36-flush not working-water not coming	Sellaveeran. M.	Flush tank washer and float washer changed, problem solved		Revathy. N. - Canteen-Girls Hostel	02/01/2023
986	23010035	Ladies hostel Phase-II	DRINKING WATER TAP NEED TO BE CHANGE IN COOLER	Prakash. V.,Rajendran. R.,Ramkumar. R.	2 nos. tap changed.		Virgin Mary - Canteen-Girls Hostel	07/01/2023
Comp. Dt. : 10/01/2023 Status : Completed								
987	23010420	Ladies hostel Phase-I	IN MESS-WASH BASIN SINK BLOCK	Sakthivel. E.,Govindan. R.,Kathirvelu. K.	Sink block removed.		Revathy. N. - Canteen-Girls Hostel	11/01/2023
Comp. Dt. : 13/01/2023 Status : Completed								
988	23010577	Ladies hostel Phase-I	NEED TO CHNAGE WASTE COUPLING FOR 1ST FLOOR COMMON REST ROOM	Prakash. V.,Ramkumar. R.,Arunagiri. V.	New waste coupling changed, problem solved		Revathy. N. - Canteen-Girls Hostel	18/01/2023
Comp. Dt. : 18/01/2023 Status : Completed								
989	23010616	JR Quarters	NEED TO CHECK HEATER HOSE FOR GROUND FLOOR RESTROOM - DAMAGE	Prakash. V.,Ramkumar. R.,Rajendran. R.	CP connection tube changed, problem solved		Virgin Mary - Canteen-Girls Hostel	20/01/2023
Comp. Dt. : 20/01/2023 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
990	23010706	Ladies hostel Phase-I	NEED TO CHANGE WASH BASIN DRAINAGE HOSE - DAMAGE FOR ROOM NO 75	Prakash. V.,Rajendran. R.,Ramkumar. R.	Connection tube changed, problem solved		Revathy. N. - Canteen-Girls Hostel	21/01/2023
Comp. Dt. : 23/01/2023 Status : Completed								
991	23010807	Ladies hostel Phase-II	NEED TO CHANGE COOLER TAP - WATER LEAKAGE	Prakash. V.,Rajendran. R.,Abdul Azees. J.	Tap changed.		Malliga. K. - Canteen-Girls Hostel	24/01/2023
992	23010812	Ladies hostel Phase-I	NEED TO CHANGE COOLER TAP AT MESS - BROKEN	Prakash. V.	Tap changed.		Revathy. N. - Canteen-Girls Hostel	24/01/2023
Comp. Dt. : 24/01/2023 Status : Completed								
993	23010854	Ladies hostel Phase-II	NEED TO REFIX TOWELSTAND FOR III FLOOR RESTROOM	Rajendran. R.,Abdul Azees. J.,Sankar. V.	Towel stand fixed.		Malliga. K. - Canteen-Girls Hostel	25/01/2023
Comp. Dt. : 30/01/2023 Status : Completed								
994	23011042	Ladies hostel Phase-II	NEED TO CHECK HEATER - WATER PIPE LINE CONNECTION - WATER LEAKAGE AT III FLOOR COMMON RESTROOM	Prakash. V.,Rajendran. R.,Ramkumar. R.	water heater connection tube changed.		Malliga. K. - Canteen-Girls Hostel	30/01/2023
995	23011044	Ladies hostel Phase-II	NEED SAND LEVELING WORK FOR COOLER DRAINAGE WATER AREA	Prakash. V.,Rajendran. R.,Ramkumar. R.	Need to raise the chamber..... Complained to Civil Execution		Malliga. K. - Canteen-Girls Hostel	08/02/2023
Comp. Dt. : 31/01/2023 Status : Completed								
996	23011102	Ladies hostel Phase-II	NEED TO REFIX COOLER VALVE - WATER LEAKAGE AT IV FLOOR	Prakash. V.,Rajendran. R.,Ramkumar. R.	New Cooler tap changed, work completed		Malliga. K. - Canteen-Girls Hostel	02/02/2023
Comp. Dt. : 04/02/2023 Status : Completed								
997	23020125	JR Quarters	NEED TO CHANGE TAP FOR I FLOOR RESTROOM - WATER LEAKAGE	Prakash. V.,Rajendran. R.,Ramkumar. R.	New PVC Tap changed, problem solved		Virgin Mary - Canteen-Girls Hostel	07/02/2023
Comp. Dt. : 06/02/2023 Status : Completed								
998	23020184	Ladies hostel Phase-II	BLOCK IN 1ST FLOOR RESTROOM	Sakthivel. E.,Govindan. R.,Kathirvelu. K.	BLOCK REMOVED.		Malliga. K. - Canteen-Girls Hostel	07/02/2023
Comp. Dt. : 08/02/2023 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
999	23020266	Ladies hostel Phase-II	WATER LEAKAGE IN HEATER - 2ND FLOOR REST ROOM	Prakash. V.,Rajendran. R.,Ramkumar. R.	Electrical complaint, msg inform to electrical dept		Malliga. K. - Canteen-Girls Hostel	08/02/2023
	Comp. Dt. : 13/02/2023							
	Status : Completed							
1000	23020481	Ladies hostel Phase-II	NEED CLEANING & CUTTING UNWANTED TREES AT ENTRANCE - NEED URGENT SERVICE	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	GARDEN COMPLAINT		Malliga. K. - Canteen-Girls Hostel	16/02/2023
	Comp. Dt. : 14/02/2023							
	Status : Completed							
1001	23020553	Ladies hostel Phase-II	BLOCK IN GROUND FLOOR COMMON RESTROOM	Sakthivel. E.,Govindan. R.,Kathirvelu. K.	BLOCK REMOVED.		Malliga. K. - Canteen-Girls Hostel	15/02/2023
	Comp. Dt. : 23/02/2023							
	Status : Completed							
1002	23020905	Ladies hostel Phase-II	BLOCK IN III FLOOR REST ROOM	Sakthivel. E.,Govindan. R.,Kathirvelu. K.	BLOCK REMOVED.		Malliga. K. - Canteen-Girls Hostel	24/02/2023
1003	23020907	JR Quarters	NEED TO CHANGE TAP - WATER LEAKAGE AT II , III & IV FLOOR RESTROOM	Prakash. V.,Rajendran. R.,Ramkumar. R.	NIPPLE FIXED.		Virgin Mary - Canteen-Girls Hostel	25/02/2023
	Comp. Dt. : 25/02/2023							
	Status : Completed							
1004	23020969	Ladies hostel Phase-II	FLUSH NOT WORKING IN WARDEN ROOM	Prakash. V.,Rajendran. R.,Ramkumar. R.	FLUSH TANK REWORK DONE.		Malliga. K. - Canteen-Girls Hostel	27/02/2023
	Comp. Dt. : 27/02/2023							
	Status : Completed							
1005	23021008	Ladies hostel Phase-II	NEED TO SPRAY " BOARDED POWDER" FOR SNAKE	Thanuzkodi. E	PHORATE POWDER SPRAYING WORK COMPLETED.		Malliga. K. - Canteen-Girls Hostel	02/03/2023
	Comp. Dt. : 01/03/2023							
	Status : Completed							
1006	23030037	Ladies hostel Phase-II	NEED TO REFIX COOLER TAP VALVE - WATER LEAKAGE	Prakash. V.,Rajendran. R.,Ramkumar. R.	FLOAT VALVE REFIXING WORK COMPLETED.		Malliga. K. - Canteen-Girls Hostel	04/03/2023
	Comp. Dt. : 10/03/2023							
	Status : Completed							
1007	23030404	Ladies hostel Phase-II	WATER NOT COMING IN IV FLOOR WASH BASIN	Prakash. V.,Rajendran. R.,Ramkumar. R.	WASH BASIN PILLAR COCK REWORK DONE.		Malliga. K. - Canteen-Girls Hostel	10/03/2023

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1008	23030407	Ladies hostel Phase-II	RESTROOM BLOCK IN GROUND & III FLOOR	Sakthivel. E.,Govindan. R.,Kathirvelu. K.	BLOCK REMOVED.		Malliga. K. - Canteen-Girls Hostel	10/03/2023
Comp. Dt. : 11/03/2023 Status : Completed								
1009	23030466	Ladies hostel Phase-II	NEED TO CHECK COOLER - WATER PIPELINE CONNECTION - DISCONNECT	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	Cooler pipe line disconnect, work completed		Malliga. K. - Canteen-Girls Hostel	16/03/2023
Comp. Dt. : 13/03/2023 Status : Completed								
1010	23030492	Ladies hostel Phase-II	BLOCK IN GROUND FLOOR RESTROOM	Sakthivel. E.,Govindan. R.,Kathirvelu. K.	BLOCK REMOVED.		Malliga. K. - Canteen-Girls Hostel	14/03/2023
Comp. Dt. : 14/03/2023 Status : Completed								
1011	23030565	JR Quarters	NEED TO CHANGE COOLER TAP - DAMAGE WATER LEAKAGE AT I FLOOR	Prakash. V.,Rajendran. R.,Ramkumar. R.	COOLER TAP CONNECTION WORK DONE.		Virgin Mary - Canteen-Girls Hostel	16/03/2023
Comp. Dt. : 17/03/2023 Status : Completed								
1012	23030699	Ladies hostel Phase-II	FLUSH NOT WORKING - I FLOOR COMMON RESTROOM	Prakash. V.,Rajendran. R.,Ramkumar. R.	FLUSH TANK REWORK DONE.		Malliga. K. - Canteen-Girls Hostel	22/03/2023
Comp. Dt. : 20/03/2023 Status : Completed								
1013	23030797	Ladies hostel Phase-II	DUE TO PROBLEM OF SNAKE NEED TO SPRAY PHORATE POWDER AT ENTRANCE	Kannan. V.	PHORATE POWDER SPRAYED		Malliga. K. - Canteen-Girls Hostel	25/03/2023
Comp. Dt. : 25/03/2023 Status : Completed								
1014	23031058	Ladies hostel Phase-I	RESTROOM BLOCK - ROOM NO 45	Sakthivel. E.	BLOCK REMOVED.		Revathy. N. - Canteen-Girls Hostel	25/03/2023
Comp. Dt. : 27/03/2023 Status : Completed								
1015	23031115	Ladies hostel Phase-I	NEED TO CLOSE REST ROOM DRAINAGE HOLE WITH WHITE CEMENT	Prakash. V.,Rajendran. R.,Ramkumar. R.	WORK COMPLETED		Revathy. N. - Canteen-Girls Hostel	03/04/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1016	23031127	Ladies hostel Phase-II	NEED TO SPRAY " MOSQUITO SPRAY" IN AND AROUND & ALL FLOOR CARITORS AT LADIES HOSTEL	Govindan. R.	MOSQUITO REPELLANT SPRAYED.		Malliga. K. - Canteen-Girls Hostel	30/03/2023
Comp. Dt. : 28/03/2023 Status : Completed								
1017	23031155	JR Quarters	REST ROOM BLOCK IN I FLOOR	Sakthivel. E.,Govindan. R.,Kathirvelu. K.	BLOCK REMOVED.		Virgin Mary - Canteen-Girls Hostel	29/03/2023
1018	23031213	Ladies hostel Phase-I	FLUSH NOT WORKING - ROOM NO 20	Prakash. V.,Rajendran. R.,Ramkumar. R.	FLUSH TANK REWORK DONE.		Revathy. N. - Canteen-Girls Hostel	01/04/2023
Comp. Dt. : 30/03/2023 Status : Completed								
1019	23031285	JR Quarters	NEED TO REFIX RESTROOM DRAINAGE FILLTER FOR GROUND FLOOR RESTROOM	Prakash. V.,Rajendran. R.,Ramkumar. R.	PIPELINE BLOCK REMOVED. DRAINAGE FILTER CHANGED.		Virgin Mary - Canteen-Girls Hostel	03/04/2023
1020	23031305	Ladies hostel Phase-II	BLOCK IN GROUND FLOOR COMMON RESTROOM	Sakthivel. E.,Govindan. R.,Kathirvelu. K.	block removed.		Malliga. K. - Canteen-Girls Hostel	31/03/2023
1021	23031306	Ladies hostel Phase-II	NEED TO CHECK WATER PIPE LINE CONNECTION - WATER COMING SLOW AT GROUND FLOOR COMMON RESTROOM	Prakash. V.,Rajendran. R.,Ramkumar. R.	2.1/2" 4 LENGTH, CONNECTION WORK DONE		Malliga. K. - Canteen-Girls Hostel	01/04/2023
Comp. Dt. : 31/03/2023 Status : Completed								
1022	23031342	Ladies hostel Phase-II	NEED TO CHECK WATER PIPELINE - WATER NOT COMING IN IV FLOOR RESTROOM TAP	Prakash. V.,Rajendran. R.,Arunagiri. V.	WATER FILLED IN TANK. WATER COMING.		Malliga. K. - Canteen-Girls Hostel	04/04/2023
1023	23031345	JR Quarters	BLOCK IN WASH BASIN - WARDEN ROOM	Sakthivel. E.,Govindan. R.,Kathirvelu. K.	BLOCK REMOVED.		Virgin Mary - Canteen-Girls Hostel	01/04/2023
Comp. Dt. : 03/04/2023 Status : Completed								
1024	23040044	JR Quarters	NEED TO CHANGE I FLOOR COOLER TAP - WATER LEAKAGE	Prakash. V.,Rajendran. R.,Ramkumar. R.	COOLER TAP REWORK DONE		Virgin Mary - Canteen-Girls Hostel	08/04/2023
1025	23040056	Ladies hostel Phase-I	FLUSH NOT WORKING - ROOM NO 13	Prakash. V.,Rajendran. R.,Ramkumar. R.	FLUSH TANK REWORK DONE.		Revathy. N. - Canteen-Girls Hostel	08/04/2023
Comp. Dt. : 04/04/2023 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1026	23040131	Ladies hostel Phase-I	FLUSH TANK & HAND SHOWER NOT WORKING ROOM NO 17	Prakash. V.,Rajendran. R.,Ramkumar. R.	FLUSH TANK REWORK AND HEALTH FAUCET BLOCK REMOVED.		Revathy. N. - Canteen-Girls Hostel	08/04/2023
Comp. Dt. : 06/04/2023 Status : Completed								
1027	23040182	Ladies hostel Phase-II	BLOCK IN GROUND FLOOR RESTROOM	Rajendhiran. V.	BLOCK REMOVED.		Malliga. K. - Canteen-Girls Hostel	08/04/2023
1028	23040183	Ladies hostel Phase-II	HOT WATER NOT COMING IN PURIFIER - NEED TO CHECK	Prakash. V.,Rajendran. R.,Ramkumar. R.	VALVE OPENED. PROBLEM RECTIFIED.		Malliga. K. - Canteen-Girls Hostel	08/04/2023
Comp. Dt. : 08/04/2023 Status : Completed								
1029	23040225	JR Quarters	RESTROOM BLOCK IN III FLOOR	Sakthivel. E.,Govindan. R.,Kathirvelu. K.	BLOCK REMOVED.		Virgin Mary - Canteen-Girls Hostel	08/04/2023
Comp. Dt. : 10/04/2023 Status : Completed								
1030	23040260	JR Quarters	BLOCK IN III FLOOR RESTROOM	Govindan. R.,Sakthivel. E.,Kathirvelu. K.	BLOCK REMOVED.		Virgin Mary - Canteen-Girls Hostel	13/04/2023
Comp. Dt. : 11/04/2023 Status : Completed								
1031	23040305	Ladies hostel Phase-II	BLOCK IN GROUND FLOOR RESTROOM	Sakthivel. E.,Govindan. R.,Kathirvelu. K.	BLOCK REMOVED.		Malliga. K. - Canteen-Girls Hostel	13/04/2023
1032	23040309	Ladies hostel Phase-II	NEED TO SPRAY INSECT SPRAY AT III FLOOR CARITOR	Kannan. V.	MOSQUITO REPELLANT SPRAYED.		Malliga. K. - Canteen-Girls Hostel	15/04/2023
Comp. Dt. : 17/04/2023 Status : Completed								
1033	23040501	Ladies hostel Phase-II	FLUSH TANK BROKEN NEED TO CHANGE AT III FLOOR REST ROOM	Prakash. V.	Flush tank full set rework, work completed		Malliga. K. - Canteen-Girls Hostel	20/04/2023
1034	23040510	Ladies hostel Phase-II	NEED TO GROUND FLOOR DUCT DOOR DRAINAGE LINE - WATER LEAKAGE	Prakash. V.,Rajendran. R.,Ramkumar. R.	ROOM NO.58, DUCT DOOR LEAKAGE ARREST DONE.		Revathy. N. - Canteen-Girls Hostel	17/04/2023
Comp. Dt. : 20/04/2023 Status : Completed								
1035	23040641	Ladies hostel Phase-I	FLUSH NOT WORKING & BLOCK IN RESTROOM - ROOM NO 41	Prakash. V.	FLUSH TANK REWORK DONE.		Revathy. N. - Canteen-Girls Hostel	22/04/2023
1036	23040655	JR Quarters	COLD WATER NOT COMING IN IV FLOOR WATER PURIFIER	Prakash. V.,Rajendran. R.,Ramkumar. R.	FLOAT VALVE WASHER CHANGED.		Virgin Mary - Canteen-Girls Hostel	24/04/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 26/04/2023								
Status : Completed								
1037	23040845	JR Quarters	NEED TO FIX A NEW SOAP STAND FOR I FLOOR RESTROOM	Prakash. V.,Rajendran. R.,Ramkumar. R.	New Soap stand 1No fixed, problem solved		Virgin Mary - Canteen-Girls Hostel	09/05/2023
1038	23040865	JR Quarters	TAP BROKEN AT BASEMENT WASHING AREA - NEED TO CHANGE TAP - WATER FLOW NEED URGENT SERVICE	Prakash. V.,Rajendran. R.,Ramkumar. R.	TAP CHANGED.		Virgin Mary - Canteen-Girls Hostel	28/04/2023
1039	23040873	Ladies hostel Phase-I	HAND SHOWER NOT WORKING - ROOM NO 30	Prakash. V.,Rajendran. R.,Ramkumar. R.	HEALTH FAUCET CHANGED.		Revathy. N. - Canteen-Girls Hostel	05/05/2023
Comp. Dt. : 29/04/2023								
Status : Completed								
1040	23041001	Ladies hostel Phase-II	NEED TO CHANGE TAP - WATER LEAKAGE AT III FLOOR & IV FLOOR SHOWER TAP	Prakash. V.,Rajendran. R.,Ramkumar. R.	concealed cock changed		Malliga. K. - Canteen-Girls Hostel	16/05/2023
Comp. Dt. : 02/05/2023								
Status : Completed								
1041	23050032	JR Quarters	NEED TO CHECK SHOWER - WATER NOT COMING & REFIX SOAP STAND FOR I FLOOR RESTROOM	Prakash. V.,Rajendran. R.,Ramkumar. R.	SOAP STAND REFIXED. SHOWER PIPELINE LINE CONNECTION REWORK DONE.		Virgin Mary - Canteen-Girls Hostel	03/05/2023
Comp. Dt. : 04/05/2023								
Status : Completed								
1042	23050151	Ladies hostel Phase-I	NEED TO CHANGE SHOWER - DAMAGE - ROOM NO 37	Prakash. V.,Rajendran. R.,Ramkumar. R.	New PVC Shower changed, problem solved		Revathy. N. - Canteen-Girls Hostel	09/05/2023
1043	23050165	JR Quarters	NEED TO CHECK COOLER NEAR SIDE WALL - WATER LEAKAGE AT I FLOOR	Prakash. V.,Rajendran. R.,Ramkumar. R.	WORK SHOP COMPLAINT.		Virgin Mary - Canteen-Girls Hostel	05/05/2023
Comp. Dt. : 08/05/2023								
Status : Completed								
1044	23050277	Ladies hostel Phase-I	NEED TO CHANGE SHOWER - WATER NOT COMING - ROOM NO 37	Prakash. V.,Rajendran. R.,Ramkumar. R.	New PVC Shower changed, problem solved		Revathy. N. - Canteen-Girls Hostel	09/05/2023
Comp. Dt. : 11/05/2023								
Status : Completed								
1045	23050441	Ladies hostel Phase-II	BLOCK IN GROUND FLOOR RESTROOM	Sakthivel. E.,Govindan. R.,Kathirvelu. K.	BLOCK REMOVED.		Malliga. K. - Canteen-Girls Hostel	12/05/2023

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 13/05/2023 Status : Completed								
1046	23050528	JR Quarters	NEED TO CHANGE WESTERN SEAT COVER - BROKEN AT WARDEN ROOM	Prakash. V.,Rajendran. R.,Ramkumar. R.	SEAT COVER CHANGED.		Virgin Mary - Canteen-Girls Hostel	15/05/2023
Comp. Dt. : 15/05/2023 Status : Completed								
1047	23050582	Ladies hostel Phase-II	NEED TO CHECK HEATER PIPELINE - WATER COMING SLOW AT GROUND FLOOR	Prakash. V.,Rajendran. R.,Ramkumar. R.	TAP REWORK DONE		Malliga. K. - Canteen-Girls Hostel	19/05/2023
Comp. Dt. : 16/05/2023 Status : Completed								
1048	23050637	Ladies hostel Phase-II	BLOCK IN RESTROOM [WARDEN ROOM]	Sakthivel. E.	BLOCK REMOVED.		Malliga. K. - Canteen-Girls Hostel	16/05/2023
1049	23050647	Ladies hostel Phase-II	NEED CEMENT WORK FOR I FLOOR EAST SIDE	Murugavel	Plastering work completed		Malliga. K. - Canteen-Girls Hostel	22/05/2023
1050	23050652	Ladies hostel Phase-I	NEED TO CHECK AND CHANGE TAPS , SHOWER, FLUSH , FLUSH KEY FOR ROOM NO 4	Prakash. V.	TAP, SHOWER, FLUSH, FLUSH KEY CHANGED.		Revathy. N. - Canteen-Girls Hostel	16/05/2023
Comp. Dt. : 17/05/2023 Status : Completed								
1051	23050686	Ladies hostel Phase-II	DRAINAGE BLOCK AT GROUND FLOOR	Sakthivel. E.	block removed		Malliga. K. - Canteen-Girls Hostel	18/05/2023
1052	23050688	Ladies hostel Phase-II	NEED TO REMOVE BEE NEST - INSIDE ROOM NO 5	Sivaraja. M.	HONEY COMB DESTROYED.		Malliga. K. - Canteen-Girls Hostel	19/05/2023
1053	23050720	JR Quarters	BLOCK IN III FLOOR	Sakthivel. E.,Gnanasegaran. K.,Govindan. R.	BLOCK REMOVED		Virgin Mary - Canteen-Girls Hostel	18/05/2023
Comp. Dt. : 19/05/2023 Status : Completed								
1054	23050809	JR Quarters	NEED MANPOWER 3 NOS FOR SHIFTING DOORS [6NOS] TO WORKSHOP	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	work completed		Virgin Mary - Canteen-Girls Hostel	31/05/2023
Comp. Dt. : 20/05/2023 Status : Completed								
1055	23050846	Ladies hostel Phase-I	NEED TO REFIX WASH BASIN -DAMAGE AND FALL DOWN AT I FLOOR DINNING ROOM	Prakash. V.,Rajendran. R.,Ramkumar. R.	WASH BASIN REFIXED.		Revathy. N. - Canteen-Girls Hostel	26/05/2023
Comp. Dt. : 22/05/2023								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
1056	23050875	Ladies hostel Phase-II	NEED TO SPRAY " INCEST SPRAY" AT III FLOOR RESTROOM & CARITOR	Kannan. V.	WORK COMPLETED		Malliga. K. - Canteen-Girls Hostel	01/06/2023
Comp. Dt. : 23/05/2023								
Status : Completed								
1057	23050906	JR Quarters	REST ROOM BLOCK IN IV FLOOR	Sakthivel. E.	block removed.		Virgin Mary - Canteen-Girls Hostel	24/05/2023
Comp. Dt. : 26/05/2023								
Status : Completed								
1058	23051051	JR Quarters	BLOCK AT ENTRANCE	Sakthivel. E.,Govindan. R.,Kathirvelu. K.	BLOCK REMOVED.		Virgin Mary - Canteen-Girls Hostel	27/05/2023
Comp. Dt. : 29/05/2023								
Status : Completed								
1059	23051137	Ladies hostel Phase-II	NEED TO CHECK SHOWER - WATER LEAKAGE AT II FLOOR	Prakash. V.,Rajendran. R.,Ramkumar. R.	Shower cleaned and rework, problem solved		Malliga. K. - Canteen-Girls Hostel	30/05/2023
1060	23051157	JR Quarters	NEED TO CHANGE TAP - WATER LEAKAGE AT IV FLOOR RESTROOM	Prakash. V.,Ramkumar. R.,Arunagiri. V.	TAP CHANGED.		Virgin Mary - Canteen-Girls Hostel	01/06/2023
Comp. Dt. : 30/05/2023								
Status : Completed								
1061	23051179	Ladies hostel Phase-I	FLUSH NOT WORKING - ROOM NO 48	Prakash. V.,Arunagiri. V.,Abdul Azees. J.	flush tank washer changed.		Revathy. N. - Canteen-Girls Hostel	01/06/2023
Comp. Dt. : 31/05/2023								
Status : Completed								
1062	23051229	Ladies hostel Phase-II	NEED CEMENT WORK FOR II FLOOR RESTROOM	Murugavel	WORK COMPLETED		Malliga. K. - Canteen-Girls Hostel	01/06/2023
1063	23051237	JR Quarters	BLOCK IN II FLOOR RESTROOM [BOTH SIDE]	Sakthivel. E.	block removed		Virgin Mary - Canteen-Girls Hostel	31/05/2023
Comp. Dt. : 02/06/2023								
Status : Completed								
1064	23060074	JR Quarters	BLOCK IN IV FLOOR RESTROOM	Rajendhiran. V.,Thanuzkodi. E.,Murugan. S.	BLOCK REMOVED.		Virgin Mary - Canteen-Girls Hostel	03/06/2023
Comp. Dt. : 03/06/2023								
Status : Completed								
1065	23060095	Ladies hostel Phase-I	FLUSH NOT WORKING - ROOM NO 55	Prakash. V.,Rajendran. R.,Ramkumar. R.	flush tank rework done.		Revathy. N. - Canteen-Girls Hostel	05/06/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 05/06/2023 Status : Completed								
1066	23060124	JR Quarters	NEED TO CHECK SHOWER NOT WORKING AT I FLOOR RESTROOM [BOTH SIDES]	Prakash. V.,Rajendran. R.,Ramkumar. R.	SHOWER CHANGED		Virgin Mary - Canteen-Girls Hostel	08/06/2023
1067	23060125	JR Quarters	NEED TO CHANGE W E C SEAT COVER - BROKEN AT WARDEN ROOM	Rajendran. R.,Ramkumar. R.,Arunagiri. V.	SEAT COVER CHANGED.		Virgin Mary - Canteen-Girls Hostel	07/06/2023
Comp. Dt. : 14/06/2023 Status : Completed								
1068	23060481	Ladies hostel Phase-II	WATER NOT COMING IN SHOWER - IV FLOOR RESTROOM	Prakash. V.,Rajendran. R.,Ramkumar. R.	Co;nceaied cock chanfged.		Malliga. K. - Canteen-Girls Hostel	20/06/2023
1069	23060515	JR Quarters	NEED TO REFIX TAP FOR [CLOSED PIPELINE] GROUND FLOOR COMMON RESTROOM	Prakash. V.,Rajendran. R.,Ramkumar. R.	TAP CHANGED.		Virgin Mary - Canteen-Girls Hostel	16/06/2023
Comp. Dt. : 17/06/2023 Status : Completed								
1070	23060626	JR Quarters	BLOCK IN I FLOOR	Sakthivel. E.	block removed.		Virgin Mary - Canteen-Girls Hostel	19/06/2023
Comp. Dt. : 19/06/2023 Status : Completed								
1071	23060652	JR Quarters	BLOCK IN I FLOOR RESTROOM	Sakthivel. E.,Govindan. R.,Kathirvelu. K.	block removed.		Virgin Mary - Canteen-Girls Hostel	20/06/2023
1072	23060662	Ladies hostel Phase-II	BLOCK IN RESTROOM AT GROUND FLOOR [WARDEN ROOM] & NEED TO CHECK BACKSIDE DRANAGE PIPELINE	Sakthivel. E.,Govindan. R.,Gnanasegaran. K.	block removed.		Malliga. K. - Canteen-Girls Hostel	20/06/2023
1073	23060664	Ladies hostel Phase-II	BLOCK & NEED TO CHANGE TAP WATER LEAKAGE IN III FLOOR RESTROOM	Sakthivel. E.,Govindan. R.,Kathirvelu. K.	block removed.		Malliga. K. - Canteen-Girls Hostel	20/06/2023
Comp. Dt. : 22/06/2023 Status : Completed								
1074	23060803	Ladies hostel Phase-I	NEED TO CHECK HEATER WATER PIPELINE AT III FLOOR	Prakash. V.,Rajendran. R.,Ramkumar. R.	Heater water piping work completed.		Revathy. N. - Canteen-Girls Hostel	26/06/2023
1075	23060821	Ladies hostel Phase-II	BLOCK & WATER LEAKAGE AT WALL SIDE - GROUND FLOOR COMMON RESTROOM	Sakthivel. E.,Govindan. R.,Kathirvelu. K.	Block removed.		Malliga. K. - Canteen-Girls Hostel	23/06/2023
Comp. Dt. : 23/06/2023								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
1076	23060873	Ladies hostel Phase-II	NEED TO CHANGE TAP - WATER LEAKAGE AT III FLOOR RESTROOM	Prakash. V.,Rajendran. R.,Ramkumar. R.	Tap changed.		Malliga. K. - Canteen-Girls Hostel	26/06/2023
Comp. Dt. : 26/06/2023								
Status : Completed								
1077	23060948	Ladies hostel Phase-II	BLOCK IN GROUND FLOOR RESTROOM	Sakthivel. E.,Govindan. R.,Kathirvelu. K.	Block removed.		Malliga. K. - Canteen-Girls Hostel	27/06/2023
1078	23060962	JR Quarters	NEED TO REFIX WASH BASIN - DAMAGE , BROKEN , TO BE FALL DOWN AT I FLOOR RESTROOM	Prakash. V.,Rajendran. R.,Ramkumar. R.	Wash basin changed.		Virgin Mary - Canteen-Girls Hostel	14/07/2023
Comp. Dt. : 30/06/2023								
Status : Completed								
1079	23061100	JR Quarters	SHOWER - WATER NOT COMING IN I FLOOR COMMON REST ROOM	Prakash. V.,Rajendran. R.,Ramkumar. R.	Shower changed.		Virgin Mary - Canteen-Girls Hostel	18/07/2023
Dept Name : CARDIOLOGY - Civil - Maintenance								
Comp. Dt. : 10/08/2022								
Status : Completed								
1080	22080386	Cath Lab	NEED TO CHANGE TAP - WATER LEAKAGE	Prakash. V.,Ramkumar. R.,Rajendran. R.	New spindle changed.		Padmapriya. D. - CARDIOLOGY	12/08/2022
Comp. Dt. : 26/12/2022								
Status : Completed								
1081	22121177	Cath Lab	NEED TO CHANGE TAP	Manikandan. S.,Arunagiri. V.,Abdul Azees. J.	Elbow action tap changed.		Lakshmanan. V. - CARDIOLOGY	27/12/2022
Comp. Dt. : 04/05/2023								
Status : Completed								
1082	23050132	ECG	NEED MANPOWER 3 NOS FOR ROOM SHIFTING WORK AT II FLOOR ECG ROOM	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	Shifting work completed		Priyanka. M. - CARDIOLOGY	04/05/2023
Comp. Dt. : 02/06/2023								
Status : Completed								
1083	23060060	Cath Lab	NEED TO REFIX DRESS HANGER STAND	Sivaraja. M.,Udhaya Kumar. R.,Gopal. S.	WORKSHOP COMPLAINT		Deva Arul Selva Sagayaraj. A. - CARDIOLOGY	03/06/2023
Comp. Dt. : 07/06/2023								

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
1084	23060225	Cath Lab	WATER NOT COMING NEED URGENT SERVICE	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	VALVE OPENED. PROBLEM RECTIFIED.		Lakshmanan. V. - CARDIOLOGY	08/06/2023
Dept Name : Cardiothoracic ICU - Civil - Maintenance								
Comp. Dt. : 07/05/2022								
Status : Completed								
1085	22050245	CT-ICU ROOM-NEAR ORTHO OT RECOVERY ROOM	NEED TO CHECK TAP - WATER LEAKAGE	Rajendhiran. V.	new elbow axian tap work		Sadham Husain. S. - Cardiothoracic ICU	09/05/2022
Comp. Dt. : 15/06/2022								
Status : Completed								
1086	22060578	CT-POST OPERATIVE WARD IN 4TH FLOOR	NEED TO CHANGE SINK TAP - WATER LEAKAGE	Arunagiri. V.,Manikandan. S.,Rajendran. R.	Waste hose leakage problem.		Gayathri. S. - Cardiothoracic POW	17/06/2022
Comp. Dt. : 08/11/2022								
Status : Completed								
1087	22110294	CT-ICU ROOM-NEAR ORTHO OT RECOVERY ROOM	BATHROOM BLOCK	Rajendhiran. V.,Murugan. S.,Thanuzkodi. E	Block removed.		Sangeetha. M. - Cardiothoracic ICU	09/11/2022
Comp. Dt. : 10/03/2023								
Status : Completed								
1088	23030418	CT-ICU ROOM-NEAR ORTHO OT RECOVERY ROOM	BLOCK IN REST ROOM	Rajendhiran. V.,Thanuzkodi. E,Murugan. S.	BLOCK REMOVED.		Sangeetha. M. - Cardiothoracic ICU	10/03/2023
Comp. Dt. : 04/05/2023								
Status : Completed								
1089	23050131	ORTHO OT	BLOCK IN RESTROOM	Rajendhiran. V.,Thanuzkodi. E,Murugan. S.	BLOCK REMOVED.		Sadham Husain. S. - Cardiothoracic ICU	05/05/2023
Comp. Dt. : 09/05/2023								
Status : Completed								
1090	23050345	CT POW -SPECIAL WARD B	NEED MANPOWER 1 NOM FOR FAN & AC CLEANNING WORK	Pandiaraj. V.	AC COMPLAINT		Rosaria Baska Rani - Cardiothoracic ICU	13/05/2023
Dept Name : Cardiothoracic POW - Civil - Maintenance								
Comp. Dt. : 03/08/2022								
Status : Completed								
1091	22080127	CT POW -SPECIAL WARD B	NEED TO CHANGE SEAT COVER - DAMAGE & BROKEN	Prakash. V.,Rajendran. R.,Ramkumar. R.	New EWC Seat cover changed, problem solved		lifer Mary. P. - Cardiothoracic POW	04/08/2022

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHAL KUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 17/09/2022 Status : Completed								
1092	22090682	SPECIAL WARD---B	NEED TO CHECK & CHANGE DAMAGED FLUSH TANKS , FLUSH KEY & HOSE CONNECTIONS FOR ALL ROOMS	Prakash. V.,Arunagiri. V.,Manikandan. S.	Flush tank rework.		Jenifer Mary. P. - Cardiothoracic POW	19/09/2022
Comp. Dt. : 03/12/2022 Status : Completed								
1093	22120115	CTVS	NEED LABOURS FOR SCREEN REMOVING WORK - 3 NOS - CTVS POW	Pandiaraj. V.	Screen removing work completed		Srimathi. V. - Cardiothoracic POW	05/12/2022
Comp. Dt. : 29/03/2023 Status : Completed								
1094	23031238	CT POW -SPECIAL WARD B	NEED MANPOWER 1NO FOR SCREEN REMOVING WORK	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	SCREEN REMOVING WORK COMPLETED		Praveena. M. - Cardiothoracic POW	31/03/2023
Dept Name : Cath Lab - Civil - Maintenance Comp. Dt. : 27/05/2022 Status : Completed								
1095	22051006	Cath Lab	PROBLEM IN AQUAGUARD PURIFIER WATER FILTER	Prakash. V.	Need support service		Muthukumaran. S. - Cath Lab	13/06/2022
Comp. Dt. : 17/08/2022 Status : Completed								
1096	22080487	Cath Lab	TAP BROKEN WATER LEAKAGE	Prakash. V.	Tap rework and spindle changed.		Muthukumaran. S. - Cath Lab	18/08/2022
Comp. Dt. : 23/12/2022 Status : Completed								
1097	22121042	Cath Lab	WASH BASIN WATER LEAKAGE	Prakash. V.,Rajendran. R.,Ramkumar. R.	White cement packing done.		Muthukumaran. S. - Cath Lab	23/12/2022
Dept Name : Civil - Execution - Civil - Maintenance Comp. Dt. : 26/05/2022 Status : Completed								
1098	22050996	Hospital	NEED TO ARREST WATER LEAKAGE AT IV FLOOR SPL.WARD , III FLOOR POST OPERATIVE & PAEDIATRICS OPD	Gurunathan. V.	Sealant applied in Expansion joint. water leakage arrest		Sasikala. P. - Civil - Execution	19/07/2022
Comp. Dt. : 30/05/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1099	22051106	DIRECTOR QUARTERS BACKSIDE	NEED TO CHANGE PIPE LINE CONNECTION - TANK OVERFLOW - WATER OVERFLOW	Udhaya Kumar. R.,Azhagar. N.,Santhosh Kumar. M.	1.1/4" PVC pipe line connection line changed, work completed		Sivamurugan. M - Civil - Execution	01/06/2022
Comp. Dt. : 08/09/2022 Status : Completed								
1100	22090329	DIRECTOR QUARTERS	Need to shift bricks to another place	Pandiaraj. V.,Yuvaraj. M.,Prakash. N.	work completed.		Sasikala. P. - Civil - Execution	10/09/2022
Comp. Dt. : 23/01/2023 Status : Completed								
1101	23010846	COMMERCIAL BLOCK	NEED TO CHECK SINK DRAINAGE HOSE - WATER LEAKAGE	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	Connection tube changed.		Surendhiran. R. - Civil - Execution	06/02/2023
Dept Name : Civil - Maintenance - Civil - Maintenance Comp. Dt. : 02/05/2022 Status : Completed								
1102	22050028	OLD STP PLANT	10HB PVC SUCTION LINE CONNECTION DAMAGE	Sellaveeran. M.	4" MTA and planch set changing work done		Ranganathan. K. - Civil - Maintenance	02/05/2022
1103	22050037	DIRECTOR HOME	NEED TO CHANGE WASH BASIN TAP - NEED URGENT SERVICE	Arunagiri. V.	New wash basin tap and water heater hose changed.		Arunagiri. V. - Civil - Maintenance	04/05/2022
Comp. Dt. : 20/05/2022 Status : Completed								
1104	22050742	ROAD- OUTSIDE GARDEN	NEED TO FIX NEW TAP VALVE 7 NOS FOR ROAD SIDE GARDEN	Anandharaj. M.,Sellaveeran. M.,Udhaya Kumar. R.	7Nos of valve changed, New pipe line 7 length changed, work completed		Kumar. V. - Civil - Maintenance	30/06/2022
Comp. Dt. : 06/06/2022 Status : Completed								
1105	22060216	MIT College	NEED TO FIX A NEW TAP FOR MIT COLLEGE BACK SIDE GARDEN	Anandharaj. M.,Udhaya Kumar. R.,Sellaveeran. M.	New tap fixed.		Kumar. V. - Civil - Maintenance	25/06/2022
Comp. Dt. : 24/06/2022 Status : Completed								
1106	22060872	NEW STP	TREATED WATER PUMP SUCTION LINE DAMAGE	Anandharaj. M.,Azhagar. N.,Gopal. S.	Suction line and treated water pipe line rework, 3/4" Valve, Pipe 2length, coupling, MTA changed, pr		Ranganathan. K. - Civil - Maintenance	30/06/2022
Comp. Dt. : 08/07/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1107	22070316	NEW STP	NEED TO REPLACE BASE PUMP FROM NEW STP TO ANIMAL HOUSE	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	Motor replaced in new place.		Ranganathan. K. - Civil - Maintenance	18/08/2022
Comp. Dt. : 15/07/2022 Status : Completed								
1108	22070611	OLD STP PLANT	NEED CUTTING WORK FOR PUMP BASE BOLT	Azhagar. N.,Sellaveeran. M.,Anandharaj. M.	Bolt cutting work completed		Ranganathan. K. - Civil - Maintenance	20/07/2022
Comp. Dt. : 17/08/2022 Status : Completed								
1109	22080540	COMMON TOILET NEAR BLOOD BANK	GENTS TOILET BLOCK,NEED SCAVENGER	Rajendhiran. V.	Block removed.		Santhosh Kumar. M. - Civil - Maintenance	18/08/2022
1110	22080541	COMMON TOILET NEAR OPHTAL OPD	LADIESTOILET BLOCK,NEED SCAVENGER	Rajendhiran. V.	Block removed.		Santhosh Kumar. M. - Civil - Maintenance	18/08/2022
Comp. Dt. : 20/09/2022 Status : Completed								
1111	22090793	MIT COLLEGE BACKSIDE	NEED SAND PIT 3 NOS & EXTENSION FOR PIPELINE FOR GARDEN WORK	Pandiaraj. V.	sand pit shifted.		Kumar. V. - Civil - Maintenance	22/09/2022
1112	22090794	DIRECTOR QUATERS	NEED PIPE LINE EXTENSION FOR GARDEN WORK	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	Garden pipe line extended		Kumar. V. - Civil - Maintenance	22/09/2022
1113	22090795	CAR PARKING AREA	NEED SAND PIT 2 NOS FOR GARDEN WORK AT DOCTOR'S CAR PARKING AREA	Prakash. N.,Senthil Kumar. R.,Murali. K.	Work completed.		Kumar. V. - Civil - Maintenance	24/09/2022
1114	22090796	VOLLEY BALL AND BADMITTON GROUND	STP PIPE LINE DAMAGE & BROKEN - WATER OVERFLOW NEED URGENT SERVICE - BACK SIDE OF VOLLEY BALL AND	Prakash. V.,Sankar. V.,Arunagiri. V.	3" pipe line fully rework, work completed		Kumar. V. - Civil - Maintenance	28/09/2022
Comp. Dt. : 26/09/2022 Status : Completed								
1115	22090993	NEW STP	SEWAGE PUMP SUCTION LINE DAMAGE	Prakash. V.,Anandharaj. M.,Sellaveeran. M.	Pipe line rework done.		Ranganathan. K. - Civil - Maintenance	11/10/2022
Comp. Dt. : 05/10/2022 Status : Completed								
1116	22100053	PUMP HOUSE	NEED TO CHECK STP LINE - DAMAGE & LEAKAGE AT PUMP HOUSE OPPOSITE	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	Stp pipe line rework done. Leakage arrest.		Kumar. V. - Civil - Maintenance	07/10/2022
Comp. Dt. : 11/10/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1117	22100284	VC sir Company	NEED PLUMBER 2 NOS	Udhaya Kumar. R.	New 2" MTA fixed.		Sankar. R - Civil - Maintenance	11/10/2022
1118	22100306	MIT College	NEED TO CHECK WATER PIPE LINE - BROKEN - WATER LEAKAGE AT MIT COLLEGE CANTEEN SIDE	Azhagar. N.	Water pipe line broken. Pipe line connection rework done.		Kumar. V. - Civil - Maintenance	18/10/2022
1119	22100307	PUMP HOUSE	NEED TO FIX A NEW WATER PIPE VALVE - OPPOSITE TO PUMP HOUSE	Prakash. V.,Rajendran. R.,Ramkumar. R.	Earth work going - Repeated complaint		Kumar. V. - Civil - Maintenance	13/10/2022
Comp. Dt. : 26/10/2022 Status : Completed								
1120	22100810	GARDEN	COLLEGE BACK SIDE (EAST) WATER PIPE CHANGE WORK	Prakash. V.,Rajendran. R.,Ramkumar. R.	Water pipe line changed.		Kumar. V. - Civil - Maintenance	03/11/2022
1121	22100811	TEMPLE [HOSPITAL]	NEED TO FIX ONE PIPE VALVE	Prakash. V.,Rajendran. R.,Ramkumar. R.	1" pipe valve rework done.		Kumar. V. - Civil - Maintenance	28/10/2022
Comp. Dt. : 10/11/2022 Status : Completed								
1122	22110393	Male Surgery - Ward 201	WATER LINE DAMAGE	Prakash. V.,Ramkumar. R.,Rajendran. R.	Connection tube changed.		Manikandan. S. - Civil - Maintenance	10/11/2022
1123	22110395	Male Surgery - Ward 201	EWG SEAT COVER NEED TO BE CHANGE	Rajendran. R.,Ramkumar. R.,Manikandan. S.	Seat cover changed.		Manikandan. S. - Civil - Maintenance	10/11/2022
1124	22110396	Male Surgery - Ward 201	HEALTHFUCET STAND DAMAGED	Manikandan. S.,Sankar. V.,Abdul Azees. J.	Health faucet changed.		Manikandan. S. - Civil - Maintenance	10/11/2022
1125	22110414	OLD STP PLANT	SEWAGE PUMP PVC LINE DAMAGED	Anandharaj. M.	PVC line fixed.		Ranganathan. K. - Civil - Maintenance	15/11/2022
1126	22110421	COMMON TOILET NEAR FREE PHARMACY	MALE TOILET BLOCKED,NEED SCAVENGER	Rajendhiran. V.,Murugan. S.,Thanuzkodi. E	Block removed.		Prakash. V. - Civil - Maintenance	11/11/2022
Comp. Dt. : 17/11/2022 Status : Completed								
1127	22110719	A- QUARTERS	WATER TANK LEAKAGING PROBLEM	Anandharaj. M.	1.1/2" MTA fixed.		Nagalingam. K. - Civil - Maintenance	18/11/2022
Comp. Dt. : 30/11/2022 Status : Completed								
1128	22111295	NEW STP	RAW WATER LINE DAMAGED	Anandharaj. M.	3/4" Pipe line rework, work completed		Ranganathan. K. - Civil - Maintenance	01/12/2022
Comp. Dt. : 06/12/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1129	22120271	NEW STP	TREATED WATER LINE(PUMP SUCTION LINE)GOT DAMAGED	Anandharaj. M.	New pipe line fixed.		Ranganathan. K. - Civil - Maintenance	12/12/2022
	Comp. Dt. : 09/12/2022							
	Status : Completed							
1130	22120427	NEW STP	TILLER WATER PUMP DELIVERY LINE DAMAGE	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	Pipe line rework done.		Ranganathan. K. - Civil - Maintenance	17/12/2022
	Comp. Dt. : 27/12/2022							
	Status : Completed							
1131	22121254	Male Surgery - Ward 201	Water heater pipe line leakage.	Sankar. V.,Arunagiri. V.,Prakash. V.	Quba spindle changed.		Gurunathan. V. - Civil - Maintenance	28/12/2022
	Comp. Dt. : 30/12/2022							
	Status : Completed							
1132	22121352	NEW STP	RAW WATER PIPELINE BROKEN,WATER LEAKAGING PROBLEM	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	Raw water pipeline connection work completed.		Murugan. T. - Civil - Maintenance	05/01/2023
	Comp. Dt. : 31/12/2022							
	Status : Completed							
1133	22121411	NEW STP	WATER PIPE BROKEN	Prakash. V.,Rajendran. R.,Ramkumar. R.	pipe line laying work completed.		Murugan. T. - Civil - Maintenance	05/01/2023
	Comp. Dt. : 02/01/2023							
	Status : Completed							
1134	23010052	NEW STP	WATER PIPELINE BROKEN AND LEAKAGING	Prakash. V.,Rajendran. R.,Ramkumar. R.	Water pipe line connection work completed.		Babu. D. - Civil - Maintenance	07/01/2023
1135	23010055	OLD STP PLANT	SEWAGE WATER LINE LEAKAGING PROBLEM	Prakash. V.,Rajendran. R.,Ramkumar. R.	STP water line connection work done.		Babu. D. - Civil - Maintenance	20/01/2023
	Comp. Dt. : 04/01/2023							
	Status : Completed							
1136	23010193	NEW STP	TREATED WATER PIPELINE DAMAGED(NEAR LAUNDRY AND WORKSHOP)	Prakash. V.,Rajendran. R.,Ramkumar. R.	Pipe line connection work completed (3/4" water pipe line)		Ranganathan. K. - Civil - Maintenance	09/01/2023
	Comp. Dt. : 13/01/2023							
	Status : Completed							
1137	23010569	MEDICAL COLLEGE	NEED TO CHANGE VALUE (3 NOS) FOR MEDICAL COLLEGE OPOSITE WATER FOUNDATION TANK	Prakash. V.,Rajendran. R.,Ramkumar. R.	3Nos of valve repaired and serviced, refixed in properly, problem solved		Kumar. V. - Civil - Maintenance	23/01/2023

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 21/01/2023 Status : Completed								
1138	23010775	professor quarters-DEAN SIR HOUSE	NEED TO CHANGE TAP VALVE - WATER LEAKAGE AT OPP TO DEAN SIR HOUSE	Prakash. V.	New hex nipple changed, valve refixed, problem solved		Kumar. V. - Civil - Maintenance	21/01/2023
Comp. Dt. : 27/01/2023 Status : Completed								
1139	23010989*	NEW STP	7.5 HP MOTOR SEAWAGE PUMP SUCTION LINE DAMAGE	Prakash. V.,Rajendran. R.,Ramkumar. R.	Suction pipe line connection work completed.		Ranganathan. K. - Civil - Maintenance	30/01/2023
Comp. Dt. : 07/02/2023 Status : Completed								
1140	23020239	TEMPLE [HOSPITAL]	NEED TO REFIX TAP VALVE	Manikandan. S.	New 1/2" and 1" Valve changed, water Pipe line connection given, work completed		Kumar. V. - Civil - Maintenance	08/02/2023
Comp. Dt. : 16/02/2023 Status : Completed								
1141	23020619	B-QUARTERS	MEDICAL COLLEGE SUMP-2 NOS INLET VALVE PROBLEM.NEED TO CHANGE	Prakash. V.,Rajendran. R.,Ramkumar. R.	INLET VALVE CHANGED.		Kannan. J. - Civil - Maintenance	04/03/2023
Comp. Dt. : 17/02/2023 Status : Completed								
1142	23020705	Polytechnic college	NEED PITS 2 NUMBERS S FOR WASTE SEGREGATION NEAR POLYTECHNIC COLLEGE	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	EARTH PIT 2NOS WORK DONE.		Kumar. V. - Civil - Maintenance	25/02/2023
Comp. Dt. : 22/02/2023 Status : Completed								
1143	23020871	NEW STP	TREATED WATER PUMP SECTION LINE DAMAGE(PVC)	Prakash. V.,Rajendran. R.,Ramkumar. R.	PVC SUCTION PIPE LINE CHANGED.		Ranganathan. K. - Civil - Maintenance	27/02/2023
Comp. Dt. : 23/02/2023 Status : Completed								
1144	23020891	Nursing College	NEED TO CHECK WATER PIPELINE - BROKEN WATER FLOW [OPP TO NURSING COLLEGE]	Prakash. V.,Rajendran. R.,Ramkumar. R.	WATER PIPELINE CONNECTION AND CEMENT PACKING WORK DONE.		Kumar. V. - Civil - Maintenance	25/02/2023
1145	23020892	Boys hostel	NEED TO FIX A NEW PIPE VALVE NEAR BOYS HOSTEL	Sivaraja. M.,Santhosh Kumar. M.,Sellaveeran. M.	NEW VALVE FIXED.		Kumar. V. - Civil - Maintenance	25/02/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 27/02/2023 Status : Completed								
1146	23021016	NEW STP	TREATED WATER PUMP DELIVERY LINE DAMAGE	Prakash. V.,Rajendran. R.,Ramkumar. R.	WATER PIPELINE REWORK DONE.		Ranganathan. K. - Civil - Maintenance	28/02/2023
Comp. Dt. : 07/03/2023 Status : Completed								
1147	23030295	NEW STP	SLUDGE PVC LINE DAMAGE	Prakash. V.,Rajendran. R.,Ramkumar. R.	SEWAGE LINE JOINING WORK COMPLETED.		Ranganathan. K. - Civil - Maintenance	08/03/2023
Comp. Dt. : 08/03/2023 Status : Completed								
1148	23030335	NEW STP	TREATED WATER PUMP SUCTION & DELIVERY LINE DAMAGE	Prakash. V.,Rajendran. R.,Ramkumar. R.	SUCTION LINE CONNECTION WORK DONE		Ranganathan. K. - Civil - Maintenance	10/03/2023
Comp. Dt. : 15/04/2023 Status : Completed								
1149	23040438	NEW STP	FILLTER BACK WASH PVC LINE DAMAGE	Prakash. V.,Rajendran. R.,Ramkumar. R.	filter back wash pvc line work completed		Ranganathan. K. - Civil - Maintenance	28/04/2023
Comp. Dt. : 05/06/2023 Status : Completed								
1150	23060134	Free Pharmacy	NEED TO CHANGE THE TAP AT MALE COMMON TOILET NEAR FREE PHARMACY	Sivaraja. M.,Santhosh Kumar. M.,Anandharaj. M.	TAP CHANGED.		Manikandan. S. - Civil - Maintenance	06/06/2023
Comp. Dt. : 08/06/2023 Status : Completed								
1151	23060269	NEW STP	SLUDGE LINE DAMAGE NEED TO FIX PVC VALVE	Prakash. V.,Rajendran. R.,Ramkumar. R.	PVC VALVE CHANGED.		Ranganathan. K. - Civil - Maintenance	08/06/2023
Comp. Dt. : 22/06/2023 Status : Completed								
1152	23060822	NEW STP	TREATED WATER DELIVERY VALVE DAMAGE	Prakash. V.,Rajendran. R.,Ramkumar. R.	New pvc piping work completed.		Ranganathan. K. - Civil - Maintenance	26/06/2023
Dept Name : Clinical Department - Civil - Maintenance Comp. Dt. : 06/05/2022 Status : Completed								
1153	22050209	CLINICAL DEPARTMENT IN 4th FLOOR	NEED TO CHECK WASH BASIN BROKENED - ROOM NO 4	Prakash. V.,Rajendran. R.,Manikandan. S.	New Wash basin changed water line connection given work completed		Vimal. P. - Clinical Department	07/05/2022

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1154	22050215	CLINICAL DEPARTMENT IN 4th FLOOR	NEED TO REFIX WASH BASIN - DAMAGE & BROKEN ROOM NO 3,4 &5	Prakash. V.	new washbasin room no 3.4.5.fixing work		Patchammal. K. - Clinical Department	13/05/2022
Comp. Dt. :		14/05/2022						
Status :		Completed						
1155	22050505	CLINICAL DEPARTMENT IN 2ND FLOOR	BERO SHIFTING WORK (2ND FLOOR TO 4TH FLOOR)	Pandiaraj. V.	Almerah shifting work done.		Bhuvana.M. - Clinical Department	16/05/2022
Comp. Dt. :		16/05/2022						
Status :		Completed						
1156	22050534	CLINICAL DEPARTMENT IN 4th FLOOR	FLUSH NOT WORKING ROOM NO 5 [RIGHT SIDE]	Prakash. V.	Flush tank rework.		Suguna. D. - Clinical Department	16/05/2022
Comp. Dt. :		31/05/2022						
Status :		Completed						
1157	22051129	CLINICAL DEPARTMENT IN 4th FLOOR	NEED TO REFIX RESTROOM OUTLET WATER FILTER - BROKENED & WATER BLOCK IN ROOM NO 3	Rajendhiran. V.,Thanuzkodi. E,Prakash. V.	Old grating damaged, removed the grating, new grating fixed and toilet block removed, work completed		Vimal. P. - Clinical Department	01/06/2022
Comp. Dt. :		22/08/2022						
Status :		Completed						
1158	22080726	CLINICAL DEPARTMENT IN 2ND FLOOR	NEED TO CHANGE TAP - WATER LEAKAGE - ROOM NO 7	Prakash. V.,Rajendran. R.,Ramkumar. R.	Connection tube and flush tank changed.		Vidhyavathi. S. - Clinical Department	24/08/2022
Comp. Dt. :		23/08/2022						
Status :		Completed						
1159	22080777	Surgery OPD	NEED TO STOP CEILING WATER DROP AT ROOM NO 52	Prakash. V.,Rajendran. R.,Ramkumar. R.	Water leakage occurs due to washing given at OG OT		Kheerthikaa. V. - Clinical Department	26/08/2022
Comp. Dt. :		26/08/2022						
Status :		Completed						
1160	22080892	CLINICAL DEPARTMENT IN 4th FLOOR	FLUSH & TAP WATER LEAKAGE AT ROOM NO 6	Prakash. V.,Rajendran. R.,Ramkumar. R.	flush tank rework.		Patchammal. K. - Clinical Department	30/08/2022
Comp. Dt. :		12/09/2022						
Status :		Completed						
1161	22090430	CLINICAL DEPARTMENT IN 2ND FLOOR	NEED TO CHECK WASH BASIN DRAINAGE HOSE AT ROOM NO 6 - WATER LEAKAGE	Prakash. V.,Rajendran. R.,Ramkumar. R.	Drainage hose rework.		Vidhyavathi. S. - Clinical Department	13/09/2022
Comp. Dt. :		04/11/2022						


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
1162	22110115	CLINICAL DEPARTMENT IN 4th FLOOR	IN ROOM NO.4 WASH BASIN SINK TAP WATER LEAKAGING PROBLEM	Prakash. V.,Rajendran. R.,Ramkumar. R.	Wash basin tap changed.		Bhuvana.M. - Clinical Department	05/11/2022
1163	22110124	CLINICAL DEPARTMENT IN 2ND FLOOR	IN ROOM NO.7 FLUSH NOT WORKING IN REST ROOM	Prakash. V.,Rajendran. R.,Ramkumar. R.	Flush tank rework done.		Vidhyavathi. S. - Clinical Department	05/11/2022
1164	22110138	CLINICAL DEPARTMENT IN 2ND FLOOR	RIGHT SIDE 4TH ROOM-WASH BASIN SINK TAP WATER POURING SLOWLY	Prakash. V.,Rajendran. R.,Arunagiri. V.	Angle valve rework done.		Kheerthikaa. V. - Clinical Department	05/11/2022
Comp. Dt. : 09/11/2022								
Status : Completed								
1165	22110363	CLINICAL DEPARTMENT IN 2ND FLOOR	IN ROOM NO.4 FLUSH TANK NOT FILLING WATER	Prakash. V.,Rajendran. R.,Ramkumar. R.	Flush tank fullset rework, work completed		Kheerthikaa. V. - Clinical Department	14/11/2022
Comp. Dt. : 23/11/2022								
Status : Completed								
1166	22110973	CLINICAL DEPARTMENT IN 3RD FLOOR	NEED TO REFIX DRAINAGE FILLTER - DAMAGE & BROKEN FOR ROOM NO 3 LEFT SIDE	Prakash. V.,Ramkumar. R.,Arunagiri. V.	Gratings fixed.		Balakrishnan. S. - BIOCHEMISTRY	26/11/2022
Comp. Dt. : 05/12/2022								
Status : Completed								
1167	22120192	CLINICAL DEPARTMENT IN 4th FLOOR	IN ENT DOCTOR ROOM-WATER TAP LEAKAGING IN REST ROOM	Prakash. V.,Rajendran. R.,Ramkumar. R.	tap changed.		Patchammal. K. - Clinical Department	06/12/2022
Comp. Dt. : 19/12/2022								
Status : Completed								
1168	22120862	CLINICAL DEPARTMENT IN 3RD FLOOR	PIPE BLOCK IN ROOM NO.7	Rajendhiran. V.,Murugan. S.,Thanuzkodi. E	Block removed.		Selvi. A. - Clinical Department	19/12/2022
Comp. Dt. : 03/01/2023								
Status : Completed								
1169	23010110	CLINICAL DEPARTMENT IN 4th FLOOR	IN OPHTHAL HOD ROOM NO.6-FLUSH TANK WATER LEAKAGING PROBLEM	Anandharaj. M.,Azhagar. N.,Ramkumar. R.	flush tank rework done.		Suguna. D. - Clinical Department	05/01/2023
Comp. Dt. : 10/01/2023								
Status : Completed								
1170	23010404	CLINICAL DEPARTMENT IN 4th FLOOR	IN ENT HOD ROOM NO.5-FLUSH TANK NOT WORKING	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	Flush tank rework done.		Patchammal. K. - Clinical Department	11/01/2023

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHAKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 11/01/2023 Status : Completed								
1171	23010501	CLINICAL DEPARTMENT IN 2ND FLOOR	IN 3RD ROOM-FLUSH NOT WORKING	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	Flush tank rework done		Kheerthikaa. V. - Clinical Department	13/01/2023
Comp. Dt. : 10/02/2023 Status : Completed								
1172	23020377	CLINICAL DEPARTMENT IN 4th FLOOR	(2610) BAD SMELL COMING IN ALL ROOMS	Azhagar. N.,Udhaya Kumar. R.,Santhosh Kumar. M.	BLOCK REMOVED.		Suguna. D. - Clinical Department	15/02/2023
Comp. Dt. : 13/02/2023 Status : Completed								
1173	23020488	CLINICAL DEPARTMENT IN 2ND FLOOR	NEED TO REFIX RESTROOM DRAINAGE FILLTER FOR ROOM NO 7	Azhagar. N.,Sellaveeran. M.,Udhaya Kumar. R.	GRATING REFIXED.		Bhuvana.M. - Clinical Department	15/02/2023
Comp. Dt. : 15/02/2023 Status : Completed								
1174	23020603	CLINICAL DEPARTMENT IN 4th FLOOR	FLUSH NOT WORKING - ROOM NO 3	Azhagar. N.,Sellaveeran. M.,Udhaya Kumar. R.	FLUSH TANK REWORK DONE		Vimal. P. - Clinical Department	16/02/2023
Comp. Dt. : 23/05/2023 Status : Completed								
1175	23050924	CLINICAL DEPARTMENT IN 3RD FLOOR	NEED TO CHANGE WASH BASIN DRAINAGE HOSE - DAMAGE AND WATER LEAKAGE AT ROOM NO 7	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	WASTE HOSE CLEANED AND REFIXED.		Bhuvana.M. - Clinical Department	25/05/2023
Comp. Dt. : 01/06/2023 Status : Completed								
1176	23060028	CLINICAL DEPARTMENT IN 2ND FLOOR	FLUSH WATER LEAKAGE - ROOM NO 8	Sivaraja. M.	Flush tank siphonic set changed, problem solved		Vidhyavathi. S. - Clinical Department	02/06/2023
Comp. Dt. : 13/06/2023 Status : Completed								
1177	23060458	CLINICAL DEPARTMENT IN 4th FLOOR	NEED TO CHANGE TAP - WATER LEAKAGE AT RESTROOM	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	PVC TAP CHANGED. FLUSH TANK REWORK DONE.		Patchammal. K. - Clinical Department	15/06/2023
Comp. Dt. : 27/06/2023 Status : Completed								
1178	23061030	CLINICAL DEPARTMENT IN 4th FLOOR	FLUSH NOT WORKING - ROOM NO 6	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	Flush tank service work done.		Patchammal. K. - Clinical Department	30/06/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 28/06/2023 Status : Completed								
1179	23061066	CLINICAL DEPARTMENT IN 2ND FLOOR	FLUSH WATER LEAKAGE - LEFT SIDE ROOM NO 4	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	Flush tank rework done.		Vijayalakshmi.N - Clinical Department	28/06/2023
Dept Name : CLINICAL PATHOLOGY - Civil - Maintenance Comp. Dt. : 14/06/2022 Status : Completed								
1180	22060488	Clinical Pathology	WATER NOT COMING	Prakash. V.,Rajendran. R.,Ramkumar. R.	Sink packing and 1.1/4 pipe line rework.		Gowri. S. - CLINICAL PATHOLOGY	14/06/2022
Comp. Dt. : 17/06/2022 Status : Completed								
1181	22060637	Clinical Pathology	BLOCK IN SINK	Rajendhiran. V.	Sink block removed, work completed		Reena. K. - CLINICAL PATHOLOGY	17/06/2022
Comp. Dt. : 18/06/2022 Status : Completed								
1182	22060690	Clinical Pathology	NEED TO CHECK SINK PIPE LINE - WATER LEAKAGE & SINK BLOCK	Prakash. V.,Rajendran. R.,Arunagiri. V.	Sink pipe line rework. Sink block removed.		Vinod Gnana Kumar. D. - CLINICAL PATHOLOGY	21/06/2022
Comp. Dt. : 30/07/2022 Status : Completed								
1183	22071091	Clinical Pathology	NEED LABOURS 2NOS FOR SHIFTING [UNWANTED RECORDS] FROM CLINICAL PATHOLOGY TO IV FLOOR	Pandiaraj. V.	shifting work done.		Vinod Gnana Kumar. D. - CLINICAL PATHOLOGY	03/08/2022
Comp. Dt. : 21/09/2022 Status : Completed								
1184	22090801	Clinical Pathology	NEED TO CHECK SINK - WATER LEAKAGE - SINK DAMAGE & BROKEN	Prakash. V.,Rajendran. R.,Ramkumar. R.	Health faucet fixed.		Vinod Gnana Kumar. D. - CLINICAL PATHOLOGY	22/09/2022
Comp. Dt. : 27/09/2022 Status : Completed								
1185	22091056	Clinical Pathology	NEED LABOURS 2 NOS FOR SHIFTING WORK	Pandiaraj. V.	shifting work completed		Vinod Gnana Kumar. D. - CLINICAL PATHOLOGY	01/10/2022
Comp. Dt. : 04/01/2023 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1186	23010140	Pathology Lab	NEED 2 LABOURS FOR SHIFTING PURPOSE	Palanisamy. R., Yuvaraj. M., Prakash. N.	Shifting work completed.		Vinod Gnana Kumar. D. - CLINICAL PATHOLOGY	04/01/2023
Comp. Dt. : 15/04/2023 Status : Completed								
1187	23040434	Clinical Pathology	BLOCK IN WASH BASIN	Rajendhiran. V., Thanuzkodi. E., Murugan. S.	BLOCK REMOVED.		Sivasakthi. D. - CLINICAL PATHOLOGY	16/04/2023
Comp. Dt. : 16/04/2023 Status : Completed								
1188	23040460	Clinical Pathology	BLOCK IN WASH BASIN	Rajendhiran. V., Thanuzkodi. E., Murugan. S.	WASH BASIN BLOCK REMOVED.		Vinothini. R. - CLINICAL PATHOLOGY	16/04/2023
Comp. Dt. : 12/06/2023 Status : Completed								
1189	23060401*	Clinical Pathology	NEED TO CHANGE WASH BASIN TAP - WATER LEAKAGE	Prakash. V., Rajendran. R., Ramkumar. R.	Elbow action tap changed.		Vinothini. R. - CLINICAL PATHOLOGY	03/07/2023
Dept Name : Computer Department - Civil - Maintenance Comp. Dt. : 26/10/2022 Status : Completed								
1190	22100798	MEDICAL COLLEGE	FIBRE CABLE SHIFTING WORK FROM COLLEGE TO EDP	Pandiaraj. V., Yuvaraj. M., Senthil Kumar. R.	Shifting work completed		Prakash. P. - Computer Department	27/10/2022
Comp. Dt. : 02/01/2023 Status : Completed								
1191	23010029	EDP IN UNDERGROUND	NEED LABOURS FOR MATERIAL SHIFTING PURPOSE	Pandiaraj. V., Yuvaraj. M., Senthil Kumar. R.	Shifting work completed.		Prakash. P. - Computer Department	04/01/2023
Comp. Dt. : 08/02/2023 Status : Completed								
1192	23020290	CAR PARKING AREA	NEED EARTH WORK	Pandiaraj. V., Yuvaraj. M., Senthil Kumar. R.	Earth work completed		Prakash. P. - Computer Department	11/02/2023
Comp. Dt. : 13/03/2023 Status : Completed								
1193	23030506	BASEMENT	DUE TO CLEANING MEDICINE DEMO ROOM - WATER LEAKAGE AT BASEMENT BEAM AND INSIDE EDP - NEED TO CHECK	Anandharaj. M., Azhagar. N., Sellaveeran. M.	EXPANSION JOINT PROBLEM.		Shafiullah. R. - Computer Department	14/03/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 23/03/2023 Status : Completed								
1194	23030960	EDP IN UNDERGROUND	NEED MANPOWER 5 NOS FOR SYSTEM SHIFTING WORK FROM EDP TO DIGITAL LAB	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	COMPUTER SHIFTINGWORK COMPLETED		Prakash. P. - Computer Department	25/03/2023
Comp. Dt. : 02/05/2023 Status : Completed								
1195	23050051	DIGITAL LAB	NEED TO CHECK FALSE CEILING - RAIN WATER LEAKAGE INSIDE THE LAB	Prakash. V.,Rajendran. R.,Ramkumar. R.	BLOCK REMOVED IN THE SUNSHADE		Madhubalan. S. - Computer Department	03/05/2023
Comp. Dt. : 17/06/2023 Status : Completed								
1196	23060634	Nursing Quarters	NEED A NEW PIT FOR CAMERA FIXING WORK	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	WORK COMPLETED		Prakash. P. - Computer Department	04/07/2023
Dept Name : COVID Control Room - Civil - Maintenance Comp. Dt. : 16/05/2022 Status : Completed								
1197	22050536	Casualty	FLUSH NOT WORKING	Prakash. V.	Flush tank rework		Kanimozhi. E. - EMERGENCY MEDICINE	17/05/2022
Dept Name : COVID Ward - Civil - Maintenance Comp. Dt. : 02/05/2022 Status : Completed								
1198	22050025	ENT WARD-407	NEED TO CHANGE WASH BASIN TAP FOR DOCTOR'S ROOM	Prakash. V.,Rajendran. R.,Arunagiri. V.	CP Elbow action pillar cock changed, problem solved		Jayalakshmi. J. - ENT & Ophthal Ward	02/05/2022
Comp. Dt. : 10/05/2022 Status : Completed								
1199	22050332	Female Ortho - Ward 401	BLOCK IN PATIENT REST ROOM	Rajendhiran. V.,Thanuzkodi. E.,Govindan. R.	block remover work		Girija. G. - Female Ortho Ward	11/05/2022
Comp. Dt. : 13/05/2022 Status : Completed								
1200	22050487	Male Ortho - Ward 404	WATER PIPE BROKEN.WATER LEAKAGE PROBLEM	Prakash. V.,Ramkumar. R.,Manikandan. S.	New pvc tap changed.		Divya. S. - Female Surgery	17/05/2022
Comp. Dt. : 16/05/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1201	22050523	Female Ortho - Ward 401	BLOCK IN PATIENT REST ROOM	Thanuzkodi. E	Block removed.		Girija. G. - Female Ortho Ward	19/05/2022
Comp. Dt. : 18/05/2022 Status : Completed								
1202	22050639	Female Ortho - Ward 402	FLUSH NOT WORKING IN DOCTOR'S ROOM	Prakash. N.	Flush tank cleaned and serviced, problem solved		Girija. G. - Female Ortho Ward	18/05/2022
Comp. Dt. : 15/06/2022 Status : Completed								
1203	22060569	ENT WARD-407	NEED TO CHANGE TAP - WATER LEAKAGE AT DOCTOR'S ROOM	Arunagiri. V.,Manikandan. S.,Rajendran. R.	Spindle changed. tap rework.		Jayalakshmi. J. - ENT & Ophthal Ward	17/06/2022
Comp. Dt. : 20/06/2022 Status : Completed								
1204	22060697	Female Ortho - Ward 401	BLOCK IN PATIENT REST ROOM	Rajendhiran. V.	Block removed.		Girija. G. - Female Ortho Ward	21/06/2022
Comp. Dt. : 12/07/2022 Status : Completed								
1205	22070450	Male Medical - Ward 303	WATER LEAKAGE IN WASH BASIN TAP	Prakash. V.,Rajendran. R.,Ramkumar. R.	Tap changed.		Karthikeyan. I. - Male Medical Ward	12/07/2022
Comp. Dt. : 18/07/2022 Status : Completed								
1206	22070645	ENT WARD-407	NEED TO CHANGE WASH BASIN TAP - WATER LEAKAGE	Prakash. V.,Rajendran. R.,Ramkumar. R.	Waste coupling, tap and waste line rework		Jayalakshmi. J. - ENT & Ophthal Ward	19/07/2022
Dept Name : CSSD - Civil - Maintenance Comp. Dt. : 17/06/2022 Status : Completed								
1207	22060659	CSSD	NEED TO CHECK DRAINAGE LEAKAGE AT GROUND FLOOR & BASEMENT CSSD UPPER SIDE - BAD SMELL -NEED URGENT	Prakash. V.,Rajendran. R.,Ramkumar. R.	Check the complaint area. Chamber block removed. Sludge removed.		Pazhanivel.S. - CSSD	23/06/2022
Comp. Dt. : 21/10/2022 Status : Completed								
1208	22100724	CSSD	TAP WATER NOT COMING	Ramkumar. R.	Hot water tap changed. Scrub tap changed.		Pazhanivel.S. - CSSD	22/10/2022
Comp. Dt. : 22/11/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1209	22110906	CSSD	WATER PIPE LINE LEAKAGE	Prakash. V.,Rajendran. R.,Ramkumar. R.	Leak arrest. Pipe line rework.		Vinnarasi. R - CSSD	01/12/2022
Comp. Dt. : 02/01/2023 Status : Completed								
1210	23010030	CSSD	WATER HEATER HOSE GOT DAMAGED	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	SS connection tube fixed.		Vinnarasi. R - CSSD	05/01/2023
Dept Name : Derm,Pulmo,Psych Ward - Civil - Maintenance Comp. Dt. : 05/05/2022 Status : Completed								
1211	22050122	TB AND CHEST WARD-405	NEED TO CHECK SINK - BLOCK & OUTLET WATER HOSE DEMAGE AT ECG ROOM	Prakash. V.,Manikandan. S.,Abdul Azees. J.	block remover work		Sarathkumar. R. - Derm,Pulmo,Psych Ward	05/05/2022
Comp. Dt. : 06/05/2022 Status : Completed								
1212	22050175	TB AND CHEST WARD-405	BLOCK IN MALE REST ROOM & SINK	Prakash. V.	Toilet and sink block removed, sink waste coupling changed, problem solved		Sarathkumar. R. - Derm,Pulmo,Psych Ward	07/05/2022
Comp. Dt. : 16/05/2022 Status : Completed								
1213	22050567	HOSPITAL IV FLOOR	R O WATER NOT COMING	Sankar. V.	Water Air lock. Problem solved.		Sarathkumar. R. - Derm,Pulmo,Psych Ward	17/05/2022
Comp. Dt. : 17/05/2022 Status : Completed								
1214	22050594	TB AND CHEST WARD-405	NEED TO CHECK SINK - WATER LEAKAGE & MALE RESTROOM URINAL - DAMAGE & LEAKAGE	Prakash. V.	Wash basin block removed. Urinal waste line rework.		Sarathkumar. R. - Derm,Pulmo,Psych Ward	17/05/2022
1215	22050617	TB AND CHEST WARD-405	BLOCK IN MALE REST ROOM	Thanuzkodi. E	Block removed.		Sarathkumar. R. - Derm,Pulmo,Psych Ward	17/05/2022
Comp. Dt. : 19/05/2022 Status : Completed								
1216	22050711	TB AND CHEST WARD-405	SINK BLOCK IN ECG ROOM	Govindan. R.	Sink block removed, work completed		Sarathkumar. R. - Derm,Pulmo,Psych Ward	20/05/2022
Comp. Dt. : 20/06/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1217	22060724	TB AND CHEST WARD-405	SINK BLOCK AT PATIENT RESTROOM	Rajendhiran. V.	Block removed		Bharathi. A - Derm,Pulmo,Psych Ward	20/06/2022
	Comp. Dt. : 21/06/2022							
	Status : Completed							
1218	22060738	TB AND CHEST WARD-405	SINK BLOCK - MALE SIDE	Rajendhiran. V.	Block removed		Sarathkumar. R. - Derm,Pulmo,Psych Ward	21/06/2022
	Comp. Dt. : 01/07/2022							
	Status : Completed							
1219	22070001	PSYCHIATRY WARD	SINK BLOCK	Prakash. V.	Block removed.		Sarathkumar. R. - Derm,Pulmo,Psych Ward	01/07/2022
	Comp. Dt. : 04/07/2022							
	Status : Completed							
1220	22070088	Male Ortho - Ward 404	NEED TO CHANGE TAP - BROKENED - WATER FLOW IN RESTROOM	Prakash. V.,Arunagiri. V.,Manikandan. S.	Dummy fixed, WFM - Tap		Manjula. P. - Male Ortho Ward	05/07/2022
1221	22070118	Female Ortho - Ward 402	WATER LEAKAGE IN TAP AT DOCTOR'S ROOM	Prakash. V.,Ramkumar. R.,Rajendran. R.	CP Tap spindle changed, problem solved		Sarathkumar. R. - Derm,Pulmo,Psych Ward	05/07/2022
	Comp. Dt. : 12/07/2022							
	Status : Completed							
1222	22070453	PSYCHIATRY WARD	NEED TO CHANGE RESTROOM TAP - BROKEN AT DOCTOR'S ROOM	Prakash. V.,Rajendran. R.,Ramkumar. R.	Tap rework done		Sarathkumar. R. - Derm,Pulmo,Psych Ward	12/07/2022
	Comp. Dt. : 14/07/2022							
	Status : Completed							
1223	22070540	PSYCHIATRY WARD	SINK BLOCK - WARD NO 405	Rajendhiran. V.	Block removed		Sarathkumar. R. - Derm,Pulmo,Psych Ward	14/07/2022
	Comp. Dt. : 16/07/2022							
	Status : Completed							
1224	22070620	PSYCHIATRY WARD	BLOCK IN SINK [2NOS] NEED URGENT SERVICE	Prakash. V.,Abdul Azees. J.,Rajendhiran. V.	Wash basin and toilet block removed, waste water outlet line fully rework, work completed		Sarathkumar. R. - Derm,Pulmo,Psych Ward	16/07/2022
	Comp. Dt. : 18/07/2022							
	Status : Completed							
1225	22070643	PSYCHIATRY WARD	NEED LABOURS 4 NOS FOR COT ARRANGEMENT WORK - WARD NO 405	Pandiaraj. V.,Yuvaraj. M.,Murali. K.	COT arrangement work done		Sarathkumar. R. - Derm,Pulmo,Psych Ward	19/07/2022

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHAL KUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 09/08/2022 Status : Completed								
1226	22080321	ENT WARD-407	BLOCK IN RESTROOM	Sakthivel. E.,Murugan. S.,Thanuzkodi. E	Toilet block removed, work completed		Dhivaneshwari. R. - Derm,Pulmo,Psych Ward	09/08/2022
Comp. Dt. : 22/08/2022 Status : Completed								
1227	22080721	Female Psychiatry - Ward 406	NEED TO CHANGE SINK DRAINAGE HOSE PIPELINE - DAMAGE WATER LEAKAGE	Prakash. V.,Arunagiri. V.,Rajendran. R.	Pipe line connection rework.		Sarathkumar. R. - Derm,Pulmo,Psych Ward	23/08/2022
Comp. Dt. : 01/09/2022 Status : Completed								
1228	22090043	PSYCHIATRY WARD	BLOCK IN FEMALE RESTROOM	Sakthivel. E.	Toilet block removed, work completed		Sarathkumar. R. - Derm,Pulmo,Psych Ward	01/09/2022
Comp. Dt. : 05/09/2022 Status : Completed								
1229	22090158	ENT WARD-407	NEED TO CHECK PIPELINE & TAP - WATER NOT COMING IN SINK	Prakash. V.,Rajendran. R.,Ramkumar. R.	In hospital terrace pipe line rework, work completed		Dhivaneshwari. R. - Derm,Pulmo,Psych Ward	07/09/2022
Comp. Dt. : 09/09/2022 Status : Completed								
1230	22090355	PSYCHIATRY WARD	BLOCK IN SINK & RESTROOM AT MALE SIDE	Rajendhiran. V.,Thanuzkodi. E,Murugan. S.	Toilet and sink block removed, work completed		Sarathkumar. R. - Derm,Pulmo,Psych Ward	09/09/2022
1231	22090377	PSYCHIATRY WARD	NEED TO FIX ELBOW TAP & TOWEL STAND FOR ECG ROOM	Prakash. V.,Rajendran. R.,Ramkumar. R.	Elbow action tap changed.		Sarathkumar. R. - Derm,Pulmo,Psych Ward	22/09/2022
Comp. Dt. : 14/09/2022 Status : Completed								
1232	22090540	PSYCHIATRY WARD	BLOCK IN RESTROOM	Rajendhiran. V.,Thanuzkodi. E,Murugan. S.	Block removed.		Sarathkumar. R. - Derm,Pulmo,Psych Ward	15/09/2022
Comp. Dt. : 15/09/2022 Status : Completed								
1233	22090582	PSYCHIATRY WARD	SINK BLOCK	Rajendran. R.	Sink and toilet block removed, work completed		Sarathkumar. R. - Derm,Pulmo,Psych Ward	16/09/2022
Comp. Dt. : 17/09/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1234	22090693	PSYCHIATRY WARD	BLOCK IN MALE RESTROOM	Rajendhiran. V.,Sakthivel. E.,Murugan. S.	Toilet block removed, work completed		Sarathkumar. R. - Derm,Pulmo,Psych Ward	17/09/2022
Comp. Dt. : 13/10/2022 Status : Completed								
1235	22100372	PSYCHIATRY WARD	MALE RESTROOM BLOCK - WARD NO 405	Rajendhiran. V.,Murugan. S.,Thanuzkodi. E	Block removed.		Sarathkumar. R. - Derm,Pulmo,Psych Ward	13/10/2022
Comp. Dt. : 31/10/2022 Status : Completed								
1236	22101017	TB AND CHEST WARD-405	REST ROOM BLOCK	Rajendhiran. V.	Block removed.		Sarathkumar. R. - Derm,Pulmo,Psych Ward	31/10/2022
Comp. Dt. : 08/11/2022 Status : Completed								
1237	22110316	PSYCHIATRY WARD	MALE SIDE RESTROOM BLOCK IN 405	Rajendhiran. V.,Murugan. S.,Thanuzkodi. E	Block removed.		Sarathkumar. R. - Derm,Pulmo,Psych Ward	09/11/2022
Comp. Dt. : 29/11/2022 Status : Completed								
1238	22111226	Male Psychiatry - Ward 405	BLOCK IN REST ROOM	Rajendhiran. V.,Murugan. S.,Thanuzkodi. E	block removed.		Sarathkumar. R. - Derm,Pulmo,Psych Ward	30/11/2022
Comp. Dt. : 01/12/2022 Status : Completed								
1239	22120044	Male Psychiatry - Ward 405	URINAL PIPE LINE DAMAGED - BROKEN NEED TO CHANGE	Manikandan. S.,Abdul Azees. J.,Sankar. V.	1.1/4" pipe line rework.		Sarathkumar. R. - Derm,Pulmo,Psych Ward	05/12/2022
Comp. Dt. : 06/12/2022 Status : Completed								
1240	22120237	TB AND CHEST WARD-405	FEMALE SIDE-TOILET BLOCKED,NEED SCAVENGER	Rajendhiran. V.,Murugan. S.,Thanuzkodi. E	block removed.		Sarathkumar. R. - Derm,Pulmo,Psych Ward	09/12/2022
Comp. Dt. : 10/12/2022 Status : Completed								
1241	22120452	PSYCHIATRY WARD	WATER NOT COMING - BOTH SIDE REST ROOMS	Prakash. V.,Rajendran. R.,Ramkumar. R.	Tank filled. Problem rectified.		Sarathkumar. R. - Derm,Pulmo,Psych Ward	12/12/2022
Comp. Dt. : 14/12/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1242	22120660	PSYCHIATRY WARD	BLOCK IN RESTROOM	Rajendhiran. V.	block removed		Sarathkumar. R. - Derm,Pulmo,Psych Ward	14/12/2022
Comp. Dt. : 21/12/2022 Status : Completed								
1243	22120989	TB AND CHEST WARD-405	PATIENTS RESTROOM BLOCK	Rajendhiran. V.	Block removed.		Saranya. M. - Derm,Pulmo,Psych Ward	23/12/2022
Comp. Dt. : 22/12/2022 Status : Completed								
1244	22121034	PSYCHIATRY WARD	FEMALE RESTROOM BLOCK	Rajendhiran. V.,Murugan. S.,Thanuzkodi. E	block removed.		Sarathkumar. R. - Derm,Pulmo,Psych Ward	23/12/2022
Comp. Dt. : 23/12/2022 Status : Completed								
1245	22121044	Male Psychiatry - Ward 405	PATIENT RESTROOM BLOCK	Rajendhiran. V.	Toilet block removed, work completed		Sarathkumar. R. - Derm,Pulmo,Psych Ward	23/12/2022
Comp. Dt. : 26/12/2022 Status : Completed								
1246	22121169	Male Psychiatry - Ward 405	REST ROOM BLOCK	Rajendhiran. V.,Murugan. S.,Thanuzkodi. E	Block removed.		Sarathkumar. R. - Derm,Pulmo,Psych Ward	27/12/2022
Comp. Dt. : 18/01/2023 Status : Completed								
1247	23010600	ENT WARD-407	NEED TO CHECK SINK - DAMAGE & BROKEN - WATER LEAKAGE - UNFIX	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	Wash basin changed.		Dhivaneshwari. R. - Derm,Pulmo,Psych Ward	20/01/2023
Comp. Dt. : 28/01/2023 Status : Completed								
1248	23011018	Male Psychiatry - Ward 405	SINK BLOCK - DE ADDITION ROOM	Rajendhiran. V.,Thanuzkodi. E,Murugan. S.	Block removed.		Sarathkumar. R. - Derm,Pulmo,Psych Ward	28/01/2023
Comp. Dt. : 06/02/2023 Status : Completed								
1249	23020196	Female Psychiatry - Ward 406	NEED TO REFIX ELBOW TAP FOR FEMALE RESTROOM - LOOSE	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	ELBOW ACTION TAP REWORK DONE.		Sarathkumar. R. - Derm,Pulmo,Psych Ward	07/02/2023
Comp. Dt. : 13/02/2023 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1250	23020467	PSYCHIATRY WARD	BLOCK IN RESTROOM	Rajendhiran. V.,Thanuzkodi. E,Murugan. R.	BLOCK REMOVED.		Preethi. R. - Derm,Pulmo,Psych Ward	14/02/2023
Comp. Dt. : 17/02/2023 Status : Completed								
1251	23020681	Male Psychiatry - Ward 405	NEED TO CHANGE RESTROOM TAP - BROKEN	Ramkumar. R.,Azhagar. N.,Sellaveeran. M.	TAP CHANGED.		Ashok Kumar. S. - Derm,Pulmo,Psych Ward	18/02/2023
Comp. Dt. : 07/03/2023 Status : Completed								
1252	23030297	ENT WARD-407	BLOCK IN RESTROOM	Rajendhiran. V.,Thanuzkodi. E,Murugan. S.	BLOCK REMOVED.		Dhivaneshwari. R. - Derm,Pulmo,Psych Ward	08/03/2023
Comp. Dt. : 16/03/2023 Status : Completed								
1253	23030643	ENT WARD-407	BLOCK IN RESTROOM	Rajendhiran. V.,Thanuzkodi. E,Murugan. S.	BLOCK REMOVED.		Dhivaneshwari. R. - Derm,Pulmo,Psych Ward	17/03/2023
Comp. Dt. : 19/04/2023 Status : Completed								
1254	23040573	ENT WARD-407	RESTROOM BLOCK	Rajendhiran. V.,Sakthivel. E.,Govindan. R.	Toilet block removed, work completed		Dhivaneshwari. R. - Derm,Pulmo,Psych Ward	20/04/2023
Comp. Dt. : 09/05/2023 Status : Completed								
1255	23050376	Male Psychiatry - Ward 405	URINAL LEAKAGE ATRESTROOM	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	URINAL BLOCK REMOVED.		Sarathkumar. R. - Derm,Pulmo,Psych Ward	11/05/2023
Comp. Dt. : 22/05/2023 Status : Completed								
1256	23050866	Female Psychiatry - Ward 406	BLOCK IN RESTROOM	Govindan. R.,Sakthivel. E.,Thanuzkodi. E	Toilet block removed, work completed		Prammadevan. P. - Derm,Pulmo,Psych Ward	22/05/2023
Comp. Dt. : 21/06/2023 Status : Completed								
1257	23060753	Male Psychiatry - Ward 405	NEED TO CHANGE ELBOW TAP FOR DE ADDICTION ROOM	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	Elbow action tap changed.		Sarathkumar. R. - Derm,Pulmo,Psych Ward	22/06/2023
Comp. Dt. : 28/06/2023 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1258	23061087	TB AND CHEST WARD-405	FLUSH WATER LEAKAGE - NEED TO CHECK	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	Flush tank rework done		Banupriya. R. - Derm,Pulmo,Psych Ward	04/07/2023
1259	23061088	TB AND CHEST WARD-405	PSYCHIATRY ROOM FLOOR WATER LEAKAGE - NEED TO CHECK	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	Expansion joint problem.		Banupriya. R. - Derm,Pulmo,Psych Ward	03/07/2023
Comp. Dt. : 30/06/2023 Status : Completed								
1260	23061102	Male Psychiatry - Ward 405	NEED TO REFIX WASH BASIN - DAMAGE AT COUNSELLING ROOM	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	WASH BASIN REFIXED.		Sarathkumar. R. - Derm,Pulmo,Psych Ward	06/07/2023
Dept Name : Dermatology & Vener. - Civil - Maintenance Comp. Dt. : 07/06/2022 Status : Completed								
1261	22060233	DERMATOLOGY OPD	BLOCK IN WASH BASIN	Rajendhiran. V.	Block removed.		Jayachandran. M. - Dermatology & Vener.	07/06/2022
Comp. Dt. : 11/07/2022 Status : Completed								
1262	22070419	DERMATOLOGY OPD	NEED TO CHECK WASH BASIN DRAINAGE PIPE LINE CONNECTION - WATER BLOCK ROOM NO 72	Prakash. V.	Block removed in room no.72.		Jayachandran. M. - Dermatology & Vener.	12/07/2022
Comp. Dt. : 22/07/2022 Status : Completed								
1263	22070841	DERMATOLOGY OPD	NEED TO CHANGE WASH BASIN TAP - WATER LEAKAGE	Prakash. V.,Ramkumar. R.,Rajendran. R.	Tap changed.		Jayachandran. M. - Dermatology & Vener.	26/07/2022
Comp. Dt. : 16/09/2022 Status : Completed								
1264	22090620	DERMATOLOGY OPD	NEED TO CHECK CEILING - WATER LEAKAGE [OPP TO ROOM NO 72]	Manikandan. S.,Arunagiri. V.,Sankar. V.	AC drain tray complaints.		Jayachandran. M. - Dermatology & Vener.	16/09/2022
Comp. Dt. : 26/10/2022 Status : Completed								
1265	22100840	DERMATOLOGY OPD	NEED MANPOWER FOR BANNER FIXING WORK	Pandiaraj. V.	Banner fixed		Jayachandran. M. - Dermatology & Vener.	27/10/2022
Dept Name : Dialysis - Civil - Maintenance Comp. Dt. : 24/05/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1266	22050854*	DIALYSIS NEW UNIT IN 1ST FLOOR	NEED TO CHANGE TAP - DAMAGE & WATER FLOW	Prakash. V.,Ramkumar. R.,Manikandan. S.	1/2 upvc dummy fixed.		Sumathira. C - Dialysis	01/07/2022
Comp. Dt. : 28/06/2022								
Status : Completed								
1267	22060994	DIALYSIS NEW UNIT IN 1ST FLOOR	NEED TO CHANGE SINK SILVER TAP - NOT CLOSING - WATER LEAKAGE	Prakash. V.,Manikandan. S.,Arunagiri. V.	CP Elbow action Tap rework and refixed in properly, problem solved		Sumathira. C - Dialysis	28/06/2022
Comp. Dt. : 14/07/2022								
Status : Completed								
1268	22070545	DIALYSIS NEW UNIT IN 1ST FLOOR	NEED TO CHANGE RESTROOM TAP - WATER LEAKAGE	Prakash. V.,Ramkumar. R.,Rajendran. R.	CP Tap spindle changed and serviced the tap, problem solved		Sumathira. C - Dialysis	16/07/2022
Comp. Dt. : 06/09/2022								
Status : Completed								
1269	22090237	DIALYSIS IN 2ND FLOOR	WATER NOT COMING IN POSITIVE SINK	Prakash. V.,Rajendran. R.,Ramkumar. R.	Valve opened. Water coming.		Arthi. A. - Dialysis	06/09/2022
Comp. Dt. : 26/11/2022								
Status : Completed								
1270	22111124	DIALYSIS NEW UNIT IN 1ST FLOOR	WASH BASIN SINK TAP LEAKAGING PROBLEM	Prakash. V.,Rajendran. R.,Ramkumar. R.	Leakage arrest. tap rework.		Sumithradevi. S - Dialysis	01/12/2022
Comp. Dt. : 15/12/2022								
Status : Completed								
1271	22120711	ICU	FLUSH KEY BROKEN - NEED TO CHANGE	Prakash. V.,Rajendran. R.,Ramkumar. R.	Flush tank rework done.		Piravinkumar. A. - Dialysis	17/12/2022
Comp. Dt. : 13/02/2023								
Status : Completed								
1272	23020476	RICU	FLUSH NOT WORKING & BLOCK IN RESTROOM	Rajendhiran. V.,Thanuzkodi. E.,Murugan. S.	BLOCK REMOVED AND FLUSH TANK REWORK DONE.		Piravinkumar. A. - Dialysis	14/02/2023
Comp. Dt. : 24/02/2023								
Status : Completed								
1273	23020923	Nephrology OPD	NEED TO CHANGE WASH BASIN TAP - BROKEN DAMAGE WATER LEAKAGE	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	WASH BASIN TAP REWORK DONE.		Sandhiya. C. - Dialysis	25/02/2023
Comp. Dt. : 11/04/2023								
Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1274	23040317	DIALYSIS IN 2ND FLOOR	NEED URGENT SERVICE - BAD SMELL IN ISOLATION ROOM	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	Toilet block removed, work completed		Monika. A. - Dialysis	19/04/2023
Comp. Dt. : 02/05/2023 Status : Completed								
1275	23050050	DIALYSIS NEW UNIT IN 1ST FLOOR	NEED TO CHANGE TAP - WATER LEAKAGE AT RESTROOM	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	TAP CHANGED.		Malathy. M. - Dialysis	06/05/2023
Comp. Dt. : 27/06/2023 Status : Completed								
1276	23061015	DIALYSIS NEW UNIT IN 1ST FLOOR	WATER NOT COMING IN RESTROOM	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	Valve opened and problem rectified.		Sumathira. C - Dialysis	28/06/2023
Comp. Dt. : 28/06/2023 Status : Completed								
1277	23061083	Male Ortho - Ward 404	WESTERN BASIN BROKEN - NEED REPAIRING WORK	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	Seat cover changed.		Caussalya. M. - Dialysis	03/07/2023
Dept Name : Director Office - Civil - Maintenance Comp. Dt. : 06/05/2022 Status : Completed								
1278	22050217	A.P Quateres	NEED TO FIX WASHING MACHINE FOR QUARTERS NO 20	Sellaveeran. M.	Washing machine new pipe water line connection given, work completed		Mani. A. - Director Office	07/05/2022
1279	22050218	ASSOCIATIVE PROFESSOR QUARTERS	EWC & OTHER PLUMBING WORK FOR QUARTERS NO 10	Rajendran. R.	New EWC fullset (health faucet, seat cover) changed, Flush tnak 2Nos changed, problem solved		Mani. A. - Director Office	11/05/2022
Comp. Dt. : 10/05/2022 Status : Completed								
1280	22050337	A.P Quateres	NEED TO CHECK REST ROOM TAP - WATER LEAKAGE QUARTERS NO 8 + CEILING LEAKAGE QUARTERS NO 29 & REST RO	Sellaveeran. M.	Water leakage arrest at room no.8 and room no. 29		Mani. A. - Director Office	20/05/2022
Comp. Dt. : 16/05/2022 Status : Completed								
1281	22050580	ASSOCIATIVE PROFESSOR QUARTERS	E W C SEAT COVER DAMAGE QUARTERS NO 2	Santhosh Kumar. M.	New seat cover changed.		Mani. A. - Director Office	16/05/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 31/05/2022								
Status : Completed								
1282	22051121	A.P Quateres	FLUSH NOT WORKING QUARTERS NO 31 & 34	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	Room No:31, 34 - Flush tank fullset serviced and rework, problem solved		Mani. A. - Director Office	01/06/2022
1283	22051122	professor quarters	NEED TO ATTEND PLUMBING FAULT AT QUARTERS NO 5	Udhaya Kumar. R.	Removed the water heater, handover to person		Mani. A. - Director Office	01/06/2022
Comp. Dt. : 02/06/2022								
Status : Completed								
1284	22060094	MEDICAL COLLEGE GROUND FLOOR	NEED PLUMBING WORK AT MALE RESTROOM	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	1*1/4 pvc Elbow broken. New *1/4 pvc Elbow fixed.		Prasanna.B. - Director Office	09/06/2022
Comp. Dt. : 13/06/2022								
Status : Completed								
1285	22060452	A.P Quateres	NEED HEATER FIXING WORK QUARTERS NO 23 & CHANGE REST ROOM TAP FOR QUARTERS 12	Anandharaj. M.	#23, 12- Water heater fixed, water line connection given, #12- Tap spindle changed and wall mixer se		Mani. A. - Director Office	17/06/2022
Comp. Dt. : 14/06/2022								
Status : Completed								
1286	22060517	A.P Quateres	NEED TO CHANGE MIXTURE TAP - PROBLEM QUARTERS NO 12 & 23	Anandharaj. M.	New Wall mixer tap set changed, problem solved		Mani. A. - Director Office	17/06/2022
Comp. Dt. : 25/06/2022								
Status : Completed								
1287	22060933	A.P Quateres	NEED WASTE MATERIAL SHIFTING WORK	Pandiaraj. V.,Yuvaraj. M.,Murali. K.	Waste materials shifted.		Mani. A. - Director Office	09/07/2022
Comp. Dt. : 29/06/2022								
Status : Completed								
1288	22061084	A.P Quateres	CEILING LEAKAGE AT QUARTERS NO 29	Sivaraja. M.,Sellaveeran. M.,Azhagar. N.	Room No:41- leakage complaint, rectification work going		Mani. A. - Director Office	05/07/2022
Comp. Dt. : 04/07/2022								
Status : Completed								
1289	22070102	ASSOCIATIVE PROFESSOR QUARTERS	NEED TO CHANGE WALL MIXTURE TAP - LEAKAGE - QUARTERS NO 9	Azhagar. N.	Wall mixture tap changed.		Mani. A. - Director Office	09/07/2022
1290	22070103	A.P Quateres	REST ROOM WALL LEAKAGE AT QUARTERS NO 41	Udhaya Kumar. R.	New pipe line changed.		Mani. A. - Director Office	09/07/2022

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 21/07/2022								
Status : Completed								
1291	22070809	A.P Quateres	BLOCK IN KITCHEN AREA QUARTERS NO 49	Govindan. R.	Block removed.		Mani. A. - Director Office	26/07/2022
1292	22070810	A.P Quateres	WATER LEAKAGE IN FLUSH TANK & TAP - QUARTERS NO 53	Anandharaj. M.	Washer changed. Flush tank rework		Mani. A. - Director Office	26/07/2022
Comp. Dt. : 29/07/2022								
Status : Completed								
1293	22071069	A.P Quateres	KITCHEN LINE BLOCK QUATERES NO 49 & TAP PROBLEM FOR QUARTERS NO 20 & 32	Sakthivel. E.	Block removed.		Mani. A. - Director Office	30/07/2022
Comp. Dt. : 03/08/2022								
Status : Completed								
1294	22080117	professor quarters	NEED TO CHANGE SEAT COVER FOR QUARTERS NO 8	Gopal. S.,Anandharaj. M.,Azhagar. N.	Seat cover changed.		Mani. A. - Director Office	04/08/2022
1295	22080118	A.P Quateres	NEED TO CHECK TAP LINE CONNECTION AT QUARTERS NO 6	Azhagar. N.,Gopal. S.,Sellaveeran. M.	Pipe line rework		Mani. A. - Director Office	04/08/2022
1296	22080124	A.P Quateres	NEED TO CHANGE TAP FOR RESTROOM & KITCHEN [PVC] - BROKEN AT QUARTERS NO 23	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	New tap fixed.		Mani. A. - Director Office	04/08/2022
Comp. Dt. : 09/08/2022								
Status : Completed								
1297	22080324	A.P Quateres	BLOCK IN KITCHEN AREA QUARTER NO 49	Sakthivel. E.	Block removed.		Mani. A. - Director Office	09/08/2022
1298	22080325	A.P Quateres	NEED TO FIX WASHING MACHINE PIPE LINE CONNECTION FOR QUARTERS NO 23	Arunagiri. V.	New pipe line connection given		Mani. A. - Director Office	18/08/2022
Comp. Dt. : 12/08/2022								
Status : Completed								
1299	22080459	ASSOCIATIVE PROFESSOR QUARTERS	NEED REPAIRING WORK FOR LIFT MACHINE ROOM FLOOR - DAMAGE AT ASSOCIATIVE PROFESSOR QUARTERS	Gopal. S.	Workshop complaint		Mani. A. - Director Office	18/08/2022
Comp. Dt. : 13/08/2022								
Status : Completed								
1300	22080472	A.P Quateres	BLOCK IN KITCHEN AREA QUARTERS NO 49	Sakthivel. E.	block removed work		Mani. A. - Director Office	17/08/2022

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 26/08/2022								
Status : Completed								
1301	22080879	ASSOCIATIVE PROFESSOR QUARTERS	KITCHEN AREA BLOCK QUARTERS NO 9 & FLUSH NOT WORKING QUARTER NO 6 & 9	Sakthivel. E.	Block removed.		Mani. A. - Director Office	30/08/2022
Comp. Dt. : 10/09/2022								
Status : Completed								
1302	22090408	ASSOCIATIVE PROFESSOR QUARTERS	NEED TO CHECK - MAIN G I WATER PIPE LINE - WATER LEAKAGE	Gopal. S.	3" G.I pipe nipple 3 no. fixed		Mani. A. - Director Office	13/09/2022
Comp. Dt. : 12/09/2022								
Status : Completed								
1303	22090436	A.P Quateres	NEED WASHING MACHINE FIXING WORK FOR QUARTERS NO 6	Arunagiri. V.	1.1/2' line extended.		Mani. A. - Director Office	22/09/2022
Comp. Dt. : 22/09/2022								
Status : Completed								
1304	22090903	A.P Quateres	NEED TO CHECK CEILING - WATER LEAKAGE AT QUARTERS NO 13 , 29 & 30	Azhagar. N.	Floor leakage.		Mani. A. - Director Office	30/09/2022
Comp. Dt. : 27/09/2022								
Status : Completed								
1305	22091077	A.P Quateres	NEED TO CHANGE RESTROOM TAP - QUARTERS NO 18 & 56	Anandharaj. M.	#18- PVC Tap changed, #56- New Wall mixer tap, health faucet, EWC Seat cover, Shower, Tap-2Nos chang		Mani. A. - Director Office	12/10/2022
Comp. Dt. : 07/10/2022								
Status : Completed								
1306	22100154	A.P Quateres	KITCHEN LINE BLOCK AT QUARTERS NO 49	Sakthivel. E.	Block removed.		Mani. A. - Director Office	11/10/2022
Comp. Dt. : 12/10/2022								
Status : Completed								
1307	22100355	professor quarters	NEED TO CHANGE FLUSH TANK - QUARTERS NO 4	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	Flush tank rework.		Mani. A. - Director Office	14/10/2022
1308	22100356	A.P Quateres	NEED REPAIRING WORKING FOR HAND SET - QUARTERS NO 6 & KITCHEN PIPE LINE BLOCK AT QUARTERS NO 49	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	Room no.49 flush tank rework done. Room no.6 hand shower block removed.		Mani. A. - Director Office	14/10/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 14/10/2022 Status : Completed								
1309	22100447	A.P Quateres	NEED TO CHANGE REST ROOM TAP & FLUSH TANK FOR QUARTERS NO 28	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	Tap and flush tank full set rework, work completed		Mani. A. - Director Office	27/10/2022
Comp. Dt. : 15/11/2022 Status : Completed								
1310	22110563	MEDICAL COLLEGE I FLOOR	IN REST ROOM-WASH BASIN SINK LEAKAGING PROBLEM	Govindan. R.	Bathroom and wash basin block removed, work completed		Karthikeyan. R. - Director Office	16/11/2022
Comp. Dt. : 16/11/2022 Status : Completed								
1311	22110660	A.P Quateres	IN ROOM NO.28 FLUSH NOT WORKING	Gopal. S.	New PVC Pillar cock, connection tube changed, Flush tank float and washer changed, work completed		Mani. A. - Director Office	16/11/2022
Comp. Dt. : 05/12/2022 Status : Completed								
1312	22120199	ASSOCIATIVE PROFESSOR QUARTERS	WASTAGE WATER PIPELINE LEAKAGING PROBLEM IN ROOM NO.11	Anandharaj. M.,Azhagar. N.,Gopal. S.	EWC seat cover changed. flush tank rework done.		Mani. A. - Director Office	06/12/2022
Comp. Dt. : 09/12/2022 Status : Completed								
1313	22120416	A.P Quateres	HOT WATER PIPELINE LEAKAGE QUARTERS NO 12 & REST ROOM WALL LEAKAGE QUARTERS NO 13	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	Water heater line rework done.		Mani. A. - Director Office	16/12/2022
1314	22120417	A.P Quateres	CHAMBER OVER FLOW - AP QUARTERS BACK SIDE	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	Chamber block removed. sledge removed.		Mani. A. - Director Office	16/12/2022
Comp. Dt. : 15/12/2022 Status : Completed								
1315	22120697	A.P Quateres	NEED TO CHECK WASH BASIN TAP - WATER LEAKAGE - QUARTERS NO 12	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	Hot water pipe line rework done.		Mani. A. - Director Office	16/12/2022
Comp. Dt. : 03/01/2023 Status : Completed								
1316	23010100	A.P Quateres	IN ROOM NO.31-KITCHEN TAP WATER LEAKAGING PROBLEM	Prakash. V.,Rajendran. R.,Ramkumar. R.	Tap rework done.		Mani. A. - Director Office	05/01/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 23/01/2023								
Status : Completed								
1317	23010845	MEDICAL COLLEGE I FLOOR	WASH BASIN BLOCK IN RESTROOM - MEDICAL COLLEGE I FLOOR - NEAR DIRECTOR OFFICE - NEED URGENT SERVI	Rajendhiran. V.,Sakthivel. E.,Govindan. R.	Block removed.		Vijayalakshmi. G. D. - Director Office	23/01/2023
Comp. Dt. : 07/02/2023								
Status : Completed								
1318	23020233	A.P Quateres	NEED TO CHANGE FLUSH TANK HOSE - PROBLEM QUARTER NO 47	Prakash. V.,Rajendran. R.,Ramkumar. R.	Flush tank refixed, washer changed, problem solved		Mani. A. - Director Office	07/02/2023
1319	23020234	ASSOCIATIVE PROFESSOR QUARTERS	NEED TO CHANGE WASH BASIN TAP - WATER LEAKAGE QUARTERS NO 9	Prakash. V.,Rajendran. R.,Ramkumar. R.	Wash basin waste hose, waste coupling and connection tube changed, problem solved		Mani. A. - Director Office	07/02/2023
1320	23020235	A.P Quateres	TERMITE PROBLEM - NEED TO SPRAY DERMITE FOR QUARERS NO 28 & 52	Kannan. V.	Termite chemical sprayed, work completed		Mani. A. - Director Office	08/02/2023
1321	23020236	A.P Quateres	TAP LINE LEAKAGE QUARTERS NO 13	Prakash. V.,Rajendran. R.,Ramkumar. R.	Tap spindle changed, problem solved		Mani. A. - Director Office	07/02/2023
Comp. Dt. : 10/02/2023								
Status : Completed								
1322	23020400	A.P Quateres	REST ROOM TAP WATER LEAKAGE IN ROOM NO. 45	Prakash. V.,Rajendran. R.,Ramkumar. R.	TAP REWORK DONE.		Mani. A. - Director Office	15/02/2023
Comp. Dt. : 04/03/2023								
Status : Completed								
1323	23030178	ASSOCIATIVE PROFESSOR QUARTERS	NEED TAP FIXING WORK FOR QUARTERS NO 4	Prakash. N.,Rajendran. R.,Ramkumar. R.	TAP CHANGED.		Mani. A. - Director Office	07/03/2023
Comp. Dt. : 06/03/2023								
Status : Completed								
1324	23030243	ASSOCIATIVE PROFESSOR QUARTERS	WATER HEATER PIPELINE LEAKAGE - QUARTERS NO 17	Prakash. V.,Rajendran. R.,Ramkumar. R.	UPVC PIPELINE REWORK DONE.		Mani. A. - Director Office	07/03/2023
1325	23030244	ASSOCIATIVE PROFESSOR QUARTERS	NEED TO CHANGE E W C SEAT - QUARTERS NO 7	Prakash. V.,Rajendran. R.,Ramkumar. R.	EWC REMOVED AND REFIXED.		Mani. A. - Director Office	07/03/2023
Comp. Dt. : 10/03/2023								
Status : Completed								
1326	23030426	A.P Quateres	NEED REPAIRING WORK FOR FLUSH TANK - QUARTERS NO 51	Prakash. V.,Rajendran. R.,Ramkumar. R.	FLUSH TANK REWORK DONE		Mani. A. - Director Office	13/03/2023

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 14/03/2023 Status : Completed								
1327	23030527	professor quarters	NEED TO CHANGE E W C - BROKEN AT QURARTERS NO 1	Prakash. V.,Rajendran. R.,Ramkumar. R.	NEW FLUSH TANK AND SEAT COVER CHANGED. EWC REPLACED WITH OLD EWC.		Mani. A. - Director Office	14/03/2023
1328	23030556	A.P Quateres	NEED TO CHANGE WATER HEATER TUBE - FAULT - QUARTERS NO 31	Prakash. V.,Rajendran. R.,Ramkumar. R.	CP CONNECTION TUBE CHANGED.		Mani. A. - Director Office	15/03/2023
1329	23030557	A.P Quateres	SINK WASTE COUPLING FAULT - QUARTERS NO 7	Prakash. V.,Rajendran. R.,Ramkumar. R.	WASTE COUPLING CHANGED.		Mani. A. - Director Office	15/03/2023
Comp. Dt. : 16/03/2023 Status : Completed								
1330	23030676	A.P Quateres	NEED TO ARREST ALL DUCT DOOR LEAKAGE	Prakash. V.,Rajendran. R.,Ramkumar. R.	DUCT DOOR LEAKAGE ARREST IS IMPOSSIBLE DUE TO INSUFFICIENT SPACE FOR SCAFFOLDING.		Mani. A. - Director Office	22/03/2023
Comp. Dt. : 17/03/2023 Status : Completed								
1331	23030704	ASSOCIATIVE PROFESSOR QUARTERS	BALCONY & SUNSHADE WALL CRACK - ALSO NEED TO BE REMOVE PLANTS FROM THE WALL & RECTIFY THE CRACK	Prakash. V.,Rajendran. R.,Ramkumar. R.	WALL CRACK WORK SHOULD BE DONE BY WORKSHOP. PLANTS REMOVED FROM THE WALL.		Mani. A. - Director Office	22/03/2023
1332	23030705	A.P Quateres	NEED TO REMOVE ALL FLOOR GRILL DUCT DOORS	Prakash. V.,Rajendran. R.,Ramkumar. R.	IT IS IMPOSSIBLE TO REMOVED GRILL DUCT DOORS AT ALL THE FLOORS		Mani. A. - Director Office	22/03/2023
Comp. Dt. : 21/03/2023 Status : Completed								
1333	23030859	A.P Quateres	FLUSH TANK DAMAGE NEED TO CHECK QUARTERS NO 47	Prakash. V.,Rajendran. R.,Ramkumar. R.	FLUSH TANK REWORK DONE.		Mani. A. - Director Office	22/03/2023
1334	23030860	A.P Quateres	KITCHEN TAP LINE PROBLEM QUARTERS NO 12	Prakash. V.,Rajendran. R.,Ramkumar. R.	KITCHEN TAP LINE CONNECTION REWORK DONE.		Mani. A. - Director Office	22/03/2023
Comp. Dt. : 22/03/2023 Status : Completed								
1335	23030925	A.P Quateres	NEED TO CHANGE MIXTURE TAP - WATER LEAKAGE QUARTERS NO 45	Prakash. V.,Rajendran. R.,Ramkumar. R.	Wall mixture tap changed.		Mani. A. - Director Office	04/07/2023
Comp. Dt. : 31/03/2023								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
1336	23031358	A.P Quateres	NEED TO CHECK TAP & FLUSH TANK WATER LEAKAGE QUARTERS NO 6,8 & 59	Prakash. V.,Rajendran. R.,Ramkumar. R.	Room no.6,59 work completed. Room no.8 key not available. wall mixer changed at room no.6		Mani. A. - Director Office	05/04/2023
Comp. Dt. : 11/04/2023								
Status : Completed								
1337	23040325	ASSOCIATIVE PROFESSOR QUARTERS	NEED TO FIX WASHING MACHINE - QUARTERS NO 7	Prakash. V.,Rajendran. R.,Ramkumar. R.	New washing machine connection given, water line connection given, work completed		Mani. A. - Director Office	20/04/2023
Comp. Dt. : 15/04/2023								
Status : Completed								
1338	23040453	ASSOCIATIVE PROFESSOR QUARTERS	NEED WASHING MACHINE FIXING WORK - QUARTERS NO 7	Prakash. V.,Rajendran. R.,Ramkumar. R.	WASHING MACHINE FIXING WORK COMPLETED		Mani. A. - Director Office	16/04/2023
1339	23040454*	A.P Quateres	NEED DUCT SIDE WALL PACKING WORK AT A P QUARTERS TERRACE	Murugavel	Wall packing work completed		Mani. A. - Director Office	20/04/2023
Comp. Dt. : 17/04/2023								
Status : Completed								
1340	23040522	professor quarters	NEED TO CHANGE E W C - BROKEN QUARTERS NO 4	Prakash. V.,Rajendran. R.,Ramkumar. R.	EWC CHANGED.		Mani. A. - Director Office	05/05/2023
Comp. Dt. : 25/04/2023								
Status : Completed								
1341	23040830	ASSOCIATIVE PROFESSOR QUARTERS	NEED WASHING MACHINE FIXING WORK QUARTERS NO 14	Prakash. V.,Rajendran. R.,Ramkumar. R.	WORK COMPLETED		Mani. A. - Director Office	28/04/2023
Comp. Dt. : 04/05/2023								
Status : Completed								
1342	23050140	ASSOCIATIVE PROFESSOR QUARTERS	SINK DRAINAGE PIPELINE LEAKAGE - QUARTERS NO 12	Prakash. V.,Rajendran. R.,Ramkumar. R.	SINK DRAINAGE PIPELINE REWORK DONE.		Mani. A. - Director Office	05/05/2023
Comp. Dt. : 08/05/2023								
Status : Completed								
1343	23050319	ASSOCIATIVE PROFESSOR QUARTERS	NEED WATER HEATER FIXING WORK FOR QUARTERS NO 7	Prakash. V.,Rajendran. R.,Ramkumar. R.	WATER HEATER FIXED. CONNECTION TUBE 2NOS FIXED.		Mani. A. - Director Office	12/05/2023
Comp. Dt. : 17/05/2023								
Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1344	23050713	A.P Quateres	BLOCK IN RESTROOM QUARTERS NO 19	Sakthivel. E.,Govindan. R.,Kathirvelu. K.	BLOCK REMOVED		Mani. A. - Director Office	18/05/2023
1345	23050714	professor quarters	FLUSH WATER LEAKAGE - QUARTERS NO 1	Prakash. V.,Rajendran. R.,Ramkumar. R.	FLUSH TANK WASHER CHANGED.		Mani. A. - Director Office	19/05/2023
1346	23050715	A.P Quateres	NEED TO CHANGE TAP WATER LEAKAGE - QUARTERS NO 29	Prakash. V.,Rajendran. R.,Ramkumar. R.	TAP REWORK DONE.		Mani. A. - Director Office	19/05/2023
Comp. Dt. : 19/05/2023 Status : Completed								
1347	23050812	A.P Quateres	FLUSH TANK DAMAGE - QUARTERS NO 10	Prakash. V.,Rajendran. R.,Ramkumar. R.	FLUSH TANK REWORK DONE.		Mani. A. - Director Office	26/05/2023
1348	23050813	ASSOCIATIVE PROFESSOR QUARTERS	FLUSH TANK LEAKAGE AT QUARTERS NO 6	Prakash. V.,Rajendran. R.,Ramkumar. R.	washer changed		Mani. A. - Director Office	23/05/2023
Comp. Dt. : 26/05/2023 Status : Completed								
1349	23051037	ASSOCIATIVE PROFESSOR QUARTERS	E W C BACK SIDE BUSH PROBLEM - QUARTERS NO 13	Prakash. V.,Rajendran. R.,Ramkumar. R.	BACK BUSH FIXED.		Mani. A. - Director Office	29/05/2023
1350	23051038	A.P Quateres	FLUSH TANK PROBLEM QUARTERS NO 51	Prakash. V.,Rajendran. R.,Ramkumar. R.	Flush tank rework, washer changed, problem solved		Mani. A. - Director Office	30/05/2023
Comp. Dt. : 30/05/2023 Status : Completed								
1351	23051205	A.P Quateres	NEED REPAIRING WORK FOR FLUSH TANK - QUARTERS NO 7	Prakash. V.,Rajendran. R.,Ramkumar. R.	flush tank rework done.		Mani. A. - Director Office	01/06/2023
1352	23051206	ASSOCIATIVE PROFESSOR QUARTERS	NEED REPAIRING WORK FOR WASHING MACHINE LINE & FLUSH LINE - QUARTERS NO 6	Prakash. V.,Rajendran. R.,Ramkumar. R.	WORK COMPLETED		Mani. A. - Director Office	15/06/2023
Comp. Dt. : 05/06/2023 Status : Completed								
1353	23060166	A.P Quateres	NEED TO CHANGE RESTROOM TAP - QUARTERS NO 43	Prakash. V.,Rajendran. R.,Ramkumar. R.	TAP CHANGED.		Mani. A. - Director Office	07/06/2023
Comp. Dt. : 10/06/2023 Status : Completed								
1354	23060363	A.P Quateres	NEED TO CHECK FLUSH TANK & SEAT COVER - DAMAGE & BROKEN - QUARTERS NO 3	Prakash. V.,Rajendran. R.,Ramkumar. R.	FLUSH TANK REWORK DONE AND SEAT COVER CHANGED.		Mani. A. - Director Office	15/06/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 19/06/2023								
Status : Completed								
1355	23060670	A.P Quateres	DUCT PIPELINE LEAKAGE	Prakash. V.,Rajendran. R.,Ramkumar. R.	1.1/2" water line fully rework, work completed		Mani. A. - Director Office	22/06/2023
1356	23060671	ASSOCIATIVE PROFESSOR QUARTERS	NEED TO CHANGE TAP - LEAKAGE QUARTERS NO 13	Prakash. V.,Rajendran. R.,Ramkumar. R.	Tap rework, problem solved		Mani. A. - Director Office	22/06/2023
1357	23060672	A.P Quateres	NEED TO CHANGE SEAT COVER & FLUSH TANK - DAMAGE & WATER LEAKAGE AT QUARTERS NO 1 & 2	Prakash. V.,Rajendran. R.,Ramkumar. R.	Work completed		Mani. A. - Director Office	14/07/2023
Comp. Dt. : 20/06/2023								
Status : Completed								
1358	23060692	MEDICAL COLLEGE I FLOOR	BLOCK IN I FLOOR FEMALE RESTROOM OPPOSITE WASH ROOM NEED URGENT SERVICE	Gnanasegaran. K.,Kathirvelu. K.,Sakthivel. E.	block removed.		Vijayalakshmi. G. D. - Director Office	20/06/2023
Comp. Dt. : 27/06/2023								
Status : Completed								
1359	23061007	A.P Quateres	NEED TO CHANGE RESTROOM TAP - WATER LEAKAGE - QUARTERS NO 41	Prakash. V.,Rajendran. R.,Ramkumar. R.	Flush tank rework done. Tap rework done.		Mani. A. - Director Office	27/06/2023
Dept Name : Dressing - Civil - Maintenance								
Comp. Dt. : 06/07/2022								
Status : Completed								
1360	22070219	Male Surgery - Ward 202	WATER LEAKAGE IN CEILING	Prakash. V.,Ramkumar. R.,Rajendran. R.	Expand joint fault. leakage occurs due to 3rd floor washing.		Dhachinamoorthy.R. - Dressing	07/07/2022
Comp. Dt. : 17/12/2022								
Status : Completed								
1361	22120800	CSSD	drainage block,need scavenger	Rajendhiran. V.,Murugan. S.,Thanuzkodi. E	block removed.		Vijayasethu. I. - Dressing	19/12/2022
Comp. Dt. : 02/01/2023								
Status : Completed								
1362	23010056	CSSD	DRAINAGE SMELL PROBLEM	Santhosh Kumar. M.,Gopal. S.,Anandharaj. M.	CSSD block removed.		Vijayasethu. I. - Dressing	05/01/2023
Comp. Dt. : 06/02/2023								
Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1363	23020179	Male Surgery - Ward 201	REST ROOM TAP BROKEN - WATER LEAKAGE	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	Tap changed.		Dhachinamoorthy.R. - Dressing	06/02/2023
Comp. Dt. : 03/03/2023 Status : Completed								
1364	23030128	Male Surgery - Ward 201	WATER NOT COMING IN RESTROOM	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	BLOCK REMOVED		Dhachinamoorthy.R. - Dressing	04/03/2023
Comp. Dt. : 16/03/2023 Status : Completed								
1365	23030637	Male Surgery - Ward 202	NEED TO CHANGE TAP 2NOS [WATER LEAKAGE] FOR DRESSING ROOM & WASH BASIN	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	ELBOW ACTION TAP 2NOS CHANGED.		Dhachinamoorthy.R. - Dressing	16/03/2023
Comp. Dt. : 08/04/2023 Status : Completed								
1366	23040219	Male Surgery - Ward 202	FLUSH KEY BROKEN - NEED REPAIRING WORK	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	FLUSH KEY REWORK DONE.		Dhachinamoorthy.R. - Dressing	08/04/2023
Comp. Dt. : 19/06/2023 Status : Completed								
1367	23060650	CSSD	NEED TO CHECK PIPELINE - BEND - WATER LEAKAGE	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	1/2" valve changed.		Shankar. A. - Dressing	10/07/2023
Comp. Dt. : 28/06/2023 Status : Completed								
1368	23061051	CSSD	NEED TO CHANGE MACHINE PIPELINE - LEAKAGE	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	Pipeline connection work done.		Shankar. A. - Dressing	10/07/2023
Dept Name : Electrical Maintenance - Civil - Maintenance Comp. Dt. : 23/07/2022 Status : Completed								
1369	22070863	Paediatrics - Ward 309	NEED TO ARREST CEILING LEAKAGE- WATER LEAKAGE AT FAN FIXING HOLE - DUE TO LEAKAGE OF WATER, FAN C	Prakash. V.,Rajendran. R.,Ramkumar. R.	Expansion joint problem.		Vaithianathan.M - Electrical Maintenance	26/07/2022
Comp. Dt. : 02/08/2022 Status : Completed								
1370	22080093	TRANSFORMER YARD	NEED TO CHANGE TAP - WATER LEAKAGE	Prakash. V.	1/2" Valve changed.		Shankinamoorthy. J - Electrical Maintenance	03/08/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 08/12/2022 Status : Completed								
1371	22120350	TRANSFORMER YARD	NEED TO CHECK PIPE LINE CONNECTION & TAP - WATER LEAKAGE	Prakash. V.	Pipe line connection work completed. Tap rework done.		Vaithianathan.M - Electrical Maintenance	19/12/2022
Comp. Dt. : 27/12/2022 Status : Completed								
1372	22121246	HOSPITAL TERROUS	WATER LINE LEAKAGING PROBLEM ABOVE FIRE PIPELINE-PIPELINE REAARANGEMENTS WORK NEED TO DO	Prakash. V.,Rajendran. R.,Ramkumar. R.	New 2" and 2.1/2" fire pipe line ring main changed, work completed		Vaithianathan.M - Electrical Maintenance	21/01/2023
Comp. Dt. : 14/03/2023 Status : Completed								
1373	23030560	TRANSFORMER YARD	TRANSFORMER YARD EXISTING WATER PIPELINE REALTERATION WORK	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	WATER PIPELINE ALTERATION WORK DONE		Vaithianathan.M - Electrical Maintenance	18/03/2023
Comp. Dt. : 23/05/2023 Status : Completed								
1374	23050937	HOSPITAL TERROUS	NEED TO CHECK CHANGE GRANITE AT HOSPITAL TERROUS - NEAR LIFT NEED URGENT SERVICE & EMERGENCY	Murugavel	WORKSHOP COMPLAINT		Angappan. A. - Electrical Maintenance	24/05/2023
Comp. Dt. : 27/05/2023 Status : Completed								
1375	23051090*	LIFT 3 -PATIENT LIFT	NEED CIVIL TOUCHUP WORK	Murugavel	ALL FLOOR LIFT-3 AREA TOUCH UP WORK DONE.,		Azhagappan. J. - Electrical Maintenance	29/05/2023
Comp. Dt. : 02/06/2023 Status : Completed								
1376	23060052	BASEMENT	WATER LEAKAGE AT WINDOW SIDE WALL - NEED TO CHECK AT BASEMENT ELECTRICAL MAINTENANCE	Sivaraja. M.	1.1/2 ELBOW CHANGED. PIPELINE CONNECTION CHANGED.		Babu. D. - Electrical Maintenance	03/06/2023
Dept Name : EMERGENCY MEDICINE - Civil - Maintenance Comp. Dt. : 08/07/2022 Status : Completed								
1377	22070312	Casualty	NEED TO FIX NEW WASH BASIN FOR DUTY DOCTOR'S ROOM	Prakash. V.,Rajendran. R.,Ramkumar. R.	New EWC set, wash basin gratings, fixed and 3/4 water line work done		Kanimozhi. E. - EMERGENCY MEDICINE	09/07/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1378	22070321	Female Casulaty	NEED TO PASTE BLOCK SHEET FOR DUTY DOCTOR'S ROOM DOOR MIRROR	Abdul Azees. J.	Informed to Moorthy arts		Kanimozhi. E. - EMERGENCY MEDICINE	24/08/2022
		Comp. Dt. : 09/07/2022 Status : Completed						
1379	22070372	ENT WARD-408	NEED TO CHANGE WASH BASIN TAP - BROKEN - WATER LEAKAGE AT WET LAB	Prakash. V.	Wash basin tap rework		Bhuvaneswari. M. - ENT & Ophthal Ward	12/07/2022
		Comp. Dt. : 11/07/2022 Status : Completed						
1380	22070428	Female Casulaty	WATER NOT WORKING AT P G ROOM	Prakash. V.	Valve closed for plumbing work purpose. Valve opened.		Rajipriya. K. - EMERGENCY MEDICINE	12/07/2022
1381	22070437	ENT WARD-407	BLOCK IN WASH BASIN	Govindan. R.	block removed		Bhuvaneswari. M. - ENT & Ophthal Ward	12/07/2022
		Comp. Dt. : 13/07/2022 Status : Completed						
1382	22070510	Casualty	NEED TO CHECK WATER PIPE LINE - WATER COMING SLOW IN DOCTOR'S ROOM	Prakash. V.,Rajendran. R.,Manikandan. S.	Pillar cock rework		Kanimozhi. E. - EMERGENCY MEDICINE	14/07/2022
		Comp. Dt. : 15/07/2022 Status : Completed						
1383	22070570	ENT WARD-407	NEED TO CHECK WASH BASIN DRAINAGE HOSE - WATER LEAKAGE	Prakash. V.,Rajendran. R.,Manikandan. S.	Wash basin waste water outlet line fully rework, JK White cement pointing work done		Bhuvaneswari. M. - ENT & Ophthal Ward	16/07/2022
		Comp. Dt. : 23/07/2022 Status : Completed						
1384	22070875	Casualty	NEED TO PASTE BLACK SHEET FOR DOCTOR'S ROOM & STOMACH WASH ROOM	Abdul Azees. J.	Informed to moorthy arts		Kanimozhi. E. - EMERGENCY MEDICINE	24/08/2022
		Comp. Dt. : 26/08/2022 Status : Completed						
1385	22080866	Casualty	WASH BASIN BLOCK IN PROCEDURE ROOM	Rajendhiran. V.,Murugan. S.,Thanuzkodi. E	Block removed.		Kanimozhi. E. - EMERGENCY MEDICINE	29/08/2022
		Comp. Dt. : 07/09/2022 Status : Completed						


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1386	22090292	Casualty	BLOCK IN RESTROOM	Murugan. S.	Block removed.		Jayalakshmi. J. - EMERGENCY MEDICINE	08/09/2022
Comp. Dt. : 10/09/2022 Status : Completed								
1387	22090397	Casualty	NEED TO CHECK FLUSH - WATER LEAKAGE & DAMAGE AT MAIN CASUALTY INSIDE RESTROOM	Prakash. V.,Rajendran. R.,Ramkumar. R.	Flush tank changed.		Rajipriya. K. - EMERGENCY MEDICINE	10/09/2022
Comp. Dt. : 22/10/2022 Status : Completed								
1388	22100757	Casualty	TAP WATER LEAKAGE PROBLEM	Prakash. V.,Rajendran. R.,Ramkumar. R.	Tap rework done.		Kanimozhi. E. - EMERGENCY MEDICINE	26/10/2022
Comp. Dt. : 31/10/2022 Status : Completed								
1389	22101008	Casualty	WASH BASIN WATER LEAKAGE PROBLEM	Rajendran. R.,Ramkumar. R.,Arunagiri. V.	Spindle changed.		Kanimozhi. E. - EMERGENCY MEDICINE	03/11/2022
Comp. Dt. : 03/11/2022 Status : Completed								
1390	22110092	CASUALATY COMMON BATHROOM	TOILET BLOCKED,NEED SCAVENGER	Rajendhiran. V.,Murugan. S.,Thanuzkodi. E	Block removed.		Kanimozhi. E. - EMERGENCY MEDICINE	03/11/2022
Comp. Dt. : 14/11/2022 Status : Completed								
1391	22110546	COMMON TOILET NEAR CASUALTY	MALE TOILET-URINAL PIPE BROKEN	Prakash. V.,Rajendran. R.,Ramkumar. R.	Urinal tube refixed.		Kanimozhi. E. - EMERGENCY MEDICINE	15/11/2022
Comp. Dt. : 21/11/2022 Status : Completed								
1392	22110838	CASUALATY COMMON BATHROOM	FLUSH NOT WORKING	Prakash. V.,Rajendran. R.,Ramkumar. R.	Flush tank fullset rework and serviced, problem solved		Kanimozhi. E. - EMERGENCY MEDICINE	21/11/2022
1393	22110839	CASUALATY COMMON BATHROOM	WESTERN TOILET LID BROKEN	Prakash. V.,Rajendran. R.,Ramkumar. R.	EWC seat cover refixed, problem solved		Kanimozhi. E. - EMERGENCY MEDICINE	24/11/2022
Comp. Dt. : 29/11/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1394	22111203	Casualty	NEED TO CHANGE WASH BASIN TAP - WATER LEAKAGE AT PG RESTROOM	Rajendran. R.,Arunagiri. V.,Manikandan. S.	New tap changed.		Kanimozhi. E. - EMERGENCY MEDICINE	01/12/2022
		Comp. Dt. : 12/12/2022 Status : Completed						
1395	22120531	Female Casulaty	BATHROOM BLOCKED,NEED SCAVENGER	Rajendhiran. V.,Murugan. S.,Thanuzkodi. E	Block removed.		Jayalakshmi. J. - EMERGENCY MEDICINE	12/12/2022
		Comp. Dt. : 23/12/2022 Status : Completed						
1396	22121073	MAIN CASUALTY	PATIENT REST ROOM BLOCK	Rajendhiran. V.	Toilet block removed, work completed		Devi. S - EMERGENCY MEDICINE	23/12/2022
		Comp. Dt. : 28/12/2022 Status : Completed						
1397	22121285	DOCTOR'S ROOM IN CASUALTY(ROOM NO.37)	WATER NOT COMING IN WASH BASIN SINK	Prakash. V.,Rajendran. R.,Ramkumar. R.	tap filter block removed and rework done.		Kanimozhi. E. - EMERGENCY MEDICINE	30/12/2022
		Comp. Dt. : 30/12/2022 Status : Completed						
1398	22121354	MAIN CASUALTY	WASH BASIN SINK LEAKAGING PROBLEM	Prakash. V.,Rajendran. R.,Ramkumar. R.	New Wash basin set fixed.		Kanimozhi. E. - EMERGENCY MEDICINE	02/01/2023
		Comp. Dt. : 09/01/2023 Status : Completed						
1399	23010365	DOCTOR'S ROOM IN CASUALTY(ROOM NO.37)	FLUSH NOT WORKING IN REST ROOM	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	Flush tank rework done.		Kanimozhi. E. - EMERGENCY MEDICINE	10/01/2023
		Comp. Dt. : 28/01/2023 Status : Completed						
1400	23011025	Casualty	WESTERN BASIN BROKEN - NEED TO CHANGE	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	Seat cover changed. flush tank changed.		Kanimozhi. E. - EMERGENCY MEDICINE	30/01/2023
		Comp. Dt. : 08/03/2023 Status : Completed						
1401	23030313	Male Surgery - Ward 201	BLOCK IN WASH BASIN	Rajendhiran. V.,Thanuzkodi. E,Murugan. S.	BLOCK REMOVED.		Kanimozhi. E. - EMERGENCY MEDICINE	09/03/2023
		Comp. Dt. : 17/03/2023 Status : Completed						


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1402	23030701	Casualty	NEED TO FIX HAND SHOWER FOR RECOVERY ROOM	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	TWO WAY TAP AND HEALTH FAUCET CHANGED.		Sowmiya. S. - EMERGENCY MEDICINE	22/03/2023
Comp. Dt. : 19/04/2023 Status : Completed								
1403	23040612	Casualty	NEED REPAIRING & CHANGE TAP - DAMAGE AT PRIORITY III	Sellaveeran. M.	TAP CHANGED.		Kanimozhi. E. - EMERGENCY MEDICINE	22/04/2023
Comp. Dt. : 02/06/2023 Status : Completed								
1404	23060050	Male Surgery - Ward 204	NEED TO CHANGE TAP WATER LEAKAGE	Sivaraja. M.	TAP BLOCK REMOVED.		Priyadharshini. K. - Gynac Ward	03/06/2023
Comp. Dt. : 15/06/2023 Status : Completed								
1405	23060556	Casualty	RECOVERY ROOM -- -WATER NOT COMING	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	PIPELINE CONNECTION REWORK DONE		Sasirekha. K. - EMERGENCY MEDICINE	16/06/2023
Comp. Dt. : 19/06/2023 Status : Completed								
1406	23060674	FEMALE CASUALTY BATHROOM	BLOCK	Gnanasegaran. K.,Murugan. S.,Thanuzkodi. E	Block removed		Sasirekha. K. - EMERGENCY MEDICINE	20/06/2023
Dept Name : Endoscopy - Civil - Maintenance Comp. Dt. : 21/03/2023 Status : Completed								
1407	23030884	Endoscopy	WATER NOT COMING	Udhaya Kumar. R.,Gopal. S.,Sankar. R	TAP FILTER BLOCK REMOVED.		Vijayalakshmi. G. - Endoscopy	23/03/2023
Dept Name : ENT & Ophthal Ward - Civil - Maintenance Comp. Dt. : 16/06/2022 Status : Completed								
1408	22060632	Male Ortho - Ward 404	REST ROOM BLOCK - NEED URGENT SERVICE	Rajendhiran. V.	Block removed.		Gayathri. R. - Male Ortho Ward	17/06/2022
Comp. Dt. : 08/08/2022 Status : Completed								
1409	22080291	ENT WARD-407	BLOCK IN PATIENT REST ROOM	Govindan. R.,Sakthivel. E.,Murugan. S.	Toilet block removed, work completed		Jayalakshmi. J. - ENT & Ophthal Ward	09/08/2022
Comp. Dt. : 30/08/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1410	22081016	Female Medical - Ward 305	WASH BASIN BROKEN	Prakash. V.,Arunagiri. V.,Rajendran. R.	Wash basin stand fixed		Bhuvaneswari. M. - ENT & Ophthal Ward	03/09/2022
	Comp. Dt. : 16/09/2022							
	Status : Completed							
1411	22090639	Female Medical - Ward 306	BLOCK IN WASH BASIN	Rajendhiran. V.,Murugan. S.,Thanuzkodi. E	Wash basin block removed, work completed		Bhuvaneswari. M. - ENT & Ophthal Ward	17/09/2022
	Comp. Dt. : 27/09/2022							
	Status : Completed							
1412	22091058	Female Medical - Ward 305	WASH BASIN BLOCK IN DEMO ROOM	Rajendhiran. V.,Murugan. S.,Thanuzkodi. E	Block removed.		Bhuvaneswari. M. - ENT & Ophthal Ward	28/09/2022
	Comp. Dt. : 13/10/2022							
	Status : Completed							
1413	22100425	ENT WARD-407	NEED TO REFIX DRAINAGE FILLER FOR DOCTOR'S REST ROOM	Rajendran. R.	Drainage filler refixed.		Jayalakshmi. J. - ENT & Ophthal Ward	17/10/2022
	Comp. Dt. : 31/10/2022							
	Status : Completed							
1414	22100991	Female Medical - Ward 305	WASH BASIN WATER LEAKAGE	Ramkumar. R.,Rajendran. R.,Arunagiri. V.	Quba spindle changed.		Bhuvaneswari. M. - ENT & Ophthal Ward	03/11/2022
	Comp. Dt. : 03/11/2022							
	Status : Completed							
1415	22110061	ENT WARD-408	FALSE CEILING WATER LEAKAGE	Prakash. V.,Rajendran. R.,Ramkumar. R.	Expansion joint problem due to heavy rain.		Jayalakshmi. J. - ENT & Ophthal Ward	04/11/2022
1416	22110075	ENT WARD-407	IN DOCTOR'S REST ROOM-FLUSH NOT WORKING	Prakash. V.,Ramkumar. R.,Arunagiri. V.	Flush tank fullset rework, work completed		Jayalakshmi. J. - ENT & Ophthal Ward	07/11/2022
	Comp. Dt. : 04/11/2022							
	Status : Completed							
1417	22110152	ENT WARD-407	IN DOCTOR'S ROOM-FLUSH NOT WORKING	Prakash. V.,Rajendran. R.,Ramkumar. R.	Flush tank washer changed, problem solved		Jayalakshmi. J. - ENT & Ophthal Ward	07/11/2022
	Comp. Dt. : 18/11/2022							
	Status : Completed							
1418	22110754	ENT WARD-407	NEED LABOURS 2 NOS FOR LABOUR COT SHIFTING WORK	Pandiaraj. V.	Cot shifting work completed.		Jayalakshmi. J. - ENT & Ophthal Ward	22/11/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 07/12/2022 Status : Completed								
1419	22120335	ENT WARD-407	NEED LABOURS 2 NO FOR LOCKER SHIFTING WORK FROM WORKSHOP	Pandiaraj. V.,Yuvaraj. M.,Thulasi. V.	locker shifting work completed.		Jayalakshmi. J. - ENT & Ophthal Ward	09/12/2022
Comp. Dt. : 08/12/2022 Status : Completed								
1420	22120369	ENT WARD-407	IN PATIENT BATHROOM-WATER NOT COMING	Prakash. V.	Tank filled. Problem rectified.		Jayalakshmi. J. - ENT & Ophthal Ward	12/12/2022
Comp. Dt. : 19/12/2022 Status : Completed								
1421	22120872	ENT WARD	NEED LABOURS FOR CART ARRANGEMENT	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	Cot arrangement work completed		Agila. V. - ENT & Ophthal Ward	20/12/2022
Comp. Dt. : 21/12/2022 Status : Completed								
1422	22120959	ENT WARD-408	PATIENT REST ROOM WASH BASIN BLOCK	Rajendhiran. V.,Thanuzkodi. E,Murugan. S.	Block removed.		Jayalakshmi. J. - ENT & Ophthal Ward	21/12/2022
Comp. Dt. : 23/12/2022 Status : Completed								
1423	22121066	ENT WARD-407	NEED 4 LABOURS FOR COT ARRANGEMENT	Senthil Kumar. R.,Murali. K.,Prakash. N.	Cot arrangement work completed		Jayalakshmi. J. - ENT & Ophthal Ward	23/12/2022
Comp. Dt. : 30/12/2022 Status : Completed								
1424	22121359	ENT WARD-408	NEED 4 NO'S MANPOWER FOR COT ARRANGEMENTS WORK	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	Cot arrangement work completed		Jayalakshmi. J. - ENT & Ophthal Ward	02/01/2023
Comp. Dt. : 04/01/2023 Status : Completed								
1425	23010189	ENT WARD-407	NEED LABOURS FOR SCREEN REFIXING WORK	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	Screen refixing work completed.		Jayalakshmi. J. - ENT & Ophthal Ward	09/01/2023
Comp. Dt. : 23/01/2023 Status : Completed								
1426	23010844	ENT WARD-407	RESTROOM BLOCK	Rajendhiran. V.,Murugan. S.,Thanuzkodi. E	Block removed.		Agila. V. - ENT & Ophthal Ward	23/01/2023
Comp. Dt. : 06/02/2023								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
1427	23020194	ENT WARD-407	NEED TO CHANGE WASH BASIN DRAINAGE HOSE - DAMAGE & WATER LEAKAGE AT PATIENT RESTROOM	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	WASTE HOSE CHANGED.		Samundeeswari. E. - ENT & Ophthal Ward	07/02/2023
Comp. Dt. : 09/02/2023								
Status : Completed								
1428	23020315	Female Medical - Ward 305	DOCTORS ROOM TAP WATER LEAKAGE (305 & 306)	Azhagar. N.,Sellaveeran. M.,Udhaya Kumar. R.	GURU LONG BODY TAP CHANGED.		Bhuvaneswari. M. - ENT & Ophthal Ward	10/02/2023
Comp. Dt. : 10/02/2023								
Status : Completed								
1429	23020394	ENT WARD-407	NEED 4 LABOURS FOR EXAM HALL ARRANGEMENT WORK	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	Exam hall arrangement work completed		Jayalakshmi. J. - ENT & Ophthal Ward	11/02/2023
Comp. Dt. : 03/03/2023								
Status : Completed								
1430	23030122	ENT WARD	NEED TO CHANG TAP - BROKEN WATER LEAKAGE - WARD NO 307 & 308	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	TAP CHANGED		Agila. V. - ENT & Ophthal Ward	04/03/2023
Comp. Dt. : 30/03/2023								
Status : Completed								
1431	23031280	Female Medical - Ward 305	PATIENT RESTROOM BLOCK	Rajendhiran. V.,Thanuzkodi. E.,Murugan. S.	BLOCK REMOVED.		Bhuvaneswari. M. - ENT & Ophthal Ward	30/03/2023
Comp. Dt. : 06/04/2023								
Status : Completed								
1432	23040206	ENT WARD-408	BLOCK IN RESTROOM	Rajendhiran. V.,Thanuzkodi. E.,Murugan. S.	BLOCK REMOVED.		Madhiveni. M. - ENT & Ophthal Ward	08/04/2023
Comp. Dt. : 29/05/2023								
Status : Completed								
1433	23051127	ENT WARD-407	BLOCK IN SINK	Rajendhiran. V.,Thanuzkodi. E.,Murugan. S.	BLOCK REMOVED.		Agila. V. - ENT & Ophthal Ward	29/05/2023
Comp. Dt. : 30/05/2023								
Status : Completed								
1434	23051168	Female Medical - Ward 305	NEED LABOURS 2 NOS FOR UNLOADING WORK TO WORKSHOP	Pandiaraj. V.,Yuvaraj. M.,Thulasi. V.	Shifting work completed		Bhuvaneswari. M. - ENT & Ophthal Ward	02/06/2023

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHAL KUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 27/06/2023 Status : Completed								
1435	23061025	Female Medical Ward	NEED TO CHECK CEILING FOR DOCTOR'S ROOM , PANTRY ROOM & EXAM ROOM - WATER LEAKAGE - NEED URGENT SER	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	Expansion joint water leakage.		Bhuvaneswari. M. - ENT & Ophthal Ward	28/06/2023
Dept Name : Female Medical Ward - Civil - Maintenance Comp. Dt. : 14/05/2022 Status : Completed								
1436	22050509	Female Medical - Ward 306	CEILING PIPELINE BROKEN(WATER LEAKAGE)	Prakash. V.	Water leakage due to floor washing. Problem solved.		Ramya. R. - Female Medical Ward	16/05/2022
Comp. Dt. : 14/09/2022 Status : Completed								
1437	22090554	Female Medical - Ward 306	SINK BLOCK	Rajendhiran. V.,Murugan. S.,Thanuzkodi. E	block removed.		Gomathy. G. - Female Medical Ward	15/09/2022
Comp. Dt. : 21/11/2022 Status : Completed								
1438	22110888	Female Medical - Ward 306	REQUETS TO CHECK ALL WATER TAP'SARE WORKING PROPERLY IN REST ROOM	Prakash. V.,Rajendran. R.,Ramkumar. R.	All are checked, No complaints		Vaitheeswari. A. - Female Medical Ward	24/11/2022
Comp. Dt. : 28/04/2023 Status : Completed								
1439	23040956	Female Medical - Ward 305	BLOCK IN RESTROOM	Rajendhiran. V.,Thanuzkodi. E,Murugan. S.	block removed.		Gomathy. G. - Female Medical Ward	03/05/2023
Comp. Dt. : 29/05/2023 Status : Completed								
1440	23051125	Male Medical - Ward 302	NEED TO CHECK HAND SHOWER IN DOCTOR'S ROOM RESTROOM	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	Health faucet changed, problem solved		Vaitheeswari. A. - Female Medical Ward	30/05/2023
Comp. Dt. : 30/05/2023 Status : Completed								
1441	23051197	Male Medical - Ward 302	NEED REPAIRING WORK FOR TAP - BROKEN WATER LEAKAGE AT PATIENT RESTROOM	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	PVC CHANGED.		Vaitheeswari. A. - Female Medical Ward	01/06/2023
Comp. Dt. : 15/06/2023 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1442	23060528	Female Medical - Ward 305	NEED MAN POWER FOR SCREEN ROD SHIFTING WORK(WORK SHOP TO FEMALE MEDICAL WARD-305)	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	Screen rod shifted from work shop to female medical ward 305		Gnanasoundari. G - Female Medical Ward	24/06/2023
Comp. Dt. : 26/06/2023 Status : Completed								
1443	23060960	Male Medical - Ward 302	BLOCK IN RESTROOM	Rajendhiran. V.,Thanuzkodi. E,Murugan. S.	Block removed.		Vaitheeswari. A. - Female Medical Ward	27/06/2023
Dept Name : Female Ortho Ward - Civil - Maintenance Comp. Dt. : 29/06/2022 Status : Completed								
1444	22061088	Male Ortho Ward	TAP BROKEN - WATER FLOW AT BOTH 403 & 404 - NEED URGENT SERVICE	Prakash. V.,Ramkumar. R.,Rajendran. R.	Wrong complaint, Urinal waste rework and refixed in properly, problem solved		Sandhiya. L. - Male Ortho Ward	30/06/2022
Comp. Dt. : 20/08/2022 Status : Completed								
1445	22080656	Female Ortho - Ward 402	NEED REPAIRING WORK FOR DOCTOR'S ROOM FLUSH - WATER LEAKAGE & FLUSH KEY NOT WORKING	Prakash. V.,Rajendran. R.,Ramkumar. R.	seat cover changed and flush tank rework done		Girija. G. - Female Ortho Ward	24/08/2022
Comp. Dt. : 29/08/2022 Status : Completed								
1446	22080967	Female Ortho - Ward 401	BLOCK IN PATIENT RESTROOM	Govindan. R.,Rajendran. R.,Thanuzkodi. E	Toilet block removed, work completed		Girija. G. - Female Ortho Ward	30/08/2022
1447	22080981	Female Ortho - Ward 401	FLUSH WATER LEAKAGE	Prakash. V.,Ramkumar. R.,Arunagiri. V.	Flush tank rework done.		Girija. G. - Female Ortho Ward	30/08/2022
Comp. Dt. : 05/09/2022 Status : Completed								
1448	22090192	Female Ortho - Ward 402	NEED TO REFIX SINK - DAMEGE BROKEN & UNFIX	Prakash. V.,Rajendran. R.,Ramkumar. R.	New sink stand fixed, now problem solved		Anbuselvi. P. - Female Ortho Ward	07/09/2022
Comp. Dt. : 30/09/2022 Status : Completed								
1449	22091233	Female Ortho - Ward 401	BLOCK IN PATIENT RESTROOM	Rajendhiran. V.,Murugan. S.,Thanuzkodi. E	Block removed.		Girija. G. - Female Ortho Ward	01/10/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 21/10/2022								
Status : Completed								
1450	22100715	Female Ortho - Ward 401	NEED MANPOWER TO SHIFT NURSES CABIN INTO ANOTHER PLACE	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	Workshop complaint.		Girija. G. - Female Ortho Ward	22/10/2022
1451	22100727	Female Ortho Ward	REST ROOM BLOCK-NEED SCAVENGER	Rajendhiran. V.	block removed.		Girija. G. - Female Ortho Ward	22/10/2022
1452	22100733	Female Ortho - Ward 402	IN DOCTOR'S ROOM-REST ROOM FLUSH NOT WORKING	Prakash. V.,Rajendran. R.,Ramkumar. R.	Flush tank rework.		Punithavathi. E. - Female Ortho Ward	22/10/2022
Comp. Dt. : 28/10/2022								
Status : Completed								
1453	22100926	Female Ortho - Ward 402	WASH BASIN SINK WATER POURING SLOWLY IN TREATMENT ROOM	Ramkumar. R.,Rajendran. R.,Manikandan. S.	Elbow action tap rework done.		Girija. G. - Female Ortho Ward	03/11/2022
Comp. Dt. : 07/11/2022								
Status : Completed								
1454	22110224	Female Ortho - Ward 402	PATIENT SIDE BATHROOM BLOCK(401-402)	Rajendhiran. V.,Thanuzkodi. E.,Murugan. S.	block removed.		Anbuselvi. P. - Female Ortho Ward	08/11/2022
Comp. Dt. : 10/12/2022								
Status : Completed								
1455	22120460	SPECIAL WARD - A1	WATER NOT COMING	Prakash. V.,Sankar. V.,Rajendran. R.	Tank filled. problem rectified.		Shabina Begum. S. - Female Ortho Ward	12/12/2022
Comp. Dt. : 24/12/2022								
Status : Completed								
1456	22121101	Female Ortho - Ward 402	NEED LABOURS FOR COT ARRANGEMENT	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	Cot arrangement work completed		Girija. G. - Female Ortho Ward	24/12/2022
Comp. Dt. : 27/12/2022								
Status : Completed								
1457	22121252	Female Ortho - Ward 402	NEED LABOURS FOR COT REARRANGEMENTS WORK IN WARD-EXAM OVER	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	Cot arrangement work done.		Girija. G. - Female Ortho Ward	28/12/2022
Comp. Dt. : 28/12/2022								
Status : Completed								
1458	22121297	Female Ortho - Ward 401	PATIENT REST ROOM BLOCK	Rajendhiran. V.,Thanuzkodi. E.,Murugan. S.	Block removed.		Anbuselvi. P. - Female Ortho Ward	29/12/2022
Comp. Dt. : 29/12/2022								
Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1459	22121311	Female Ortho - Ward 401	PATIENT REST ROOM BLOCK	Rajendhiran. V.,Murugan. S.,Thanuzkodi. E	Block removed.		Punithavathi. E. - Female Ortho Ward	29/12/2022
Comp. Dt. : 31/01/2023 Status : Completed								
1460	23011105	Female Ortho - Ward 401	BLOCK IN PATIENT RESTROOM	Rajendhiran. V.,Thanuzkodi. E,Govindan. R.	block removed.		Girija. G. - Female Ortho Ward	01/02/2023
Comp. Dt. : 18/02/2023 Status : Completed								
1461	23020724	Female Ortho - Ward 402	SINK BLOCK	Rajendhiran. V.,Thanuzkodi. E,Murugan. S.	BLOCK REMOVED		Punithavathi. E. - Female Ortho Ward	18/02/2023
Comp. Dt. : 22/02/2023 Status : Completed								
1462	23020879	Female Ortho - Ward 402	DR'S ROOM FLUSH NOT WORKING	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	FLUSH TANK REWORK DONE.		Dhansulakshmi. K. - Female Ortho Ward	24/02/2023
Comp. Dt. : 13/04/2023 Status : Completed								
1463	23040402	Female Ophthalmology - Ward 402	NEED TO CHANGE BROKE TAP -WATER FLOW AT PATIENT RESTROOM	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	New PVC Tap changed, problem solved		Girija. G. - Female Ortho Ward	19/04/2023
Comp. Dt. : 23/05/2023 Status : Completed								
1464	23050933	Female Ortho - Ward 402	NEED TO CHANGE WASH BASIN DRAINAGE HOSE [DAMAGE] AT PATIENT RESTROOM	Anandharaj. M.,Azhagar. N.,Sivaraja. M.	DRAINAGE HOSE REFIXED		Girija. G. - Female Ortho Ward	24/05/2023
Comp. Dt. : 29/05/2023 Status : Completed								
1465	23051107	Female Ortho - Ward 402	BLOCK IN WASH BASIN	Rajendhiran. V.,Thanuzkodi. E,Murugan. S.	BLOCK REMOVED.		Dhansulakshmi. K. - Female Ortho Ward	29/05/2023
1466	23051108	Female Ortho - Ward 401	BLOCK IN RESTROOM	Rajendhiran. V.,Thanuzkodi. E,Murugan. S.	BLOCK REMOVED.		Dhansulakshmi. K. - Female Ortho Ward	29/05/2023
Comp. Dt. : 02/06/2023 Status : Completed								
1467	23060053	Female Ortho - Ward 402	NEED MANPOWER 4 NOS FOR COT ARRANGEMENT WORK	Pandiaraj. V.,Yuvaraj. M.,Thulasi. V.	COT ARRANGEMENT WORK COMPLETED		Dhansulakshmi. K. - Female Ortho Ward	02/06/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 20/06/2023 Status : Completed								
1468	23060726	Female Ortho - Ward 402	NEED TO CHANGE WASH BASIN TAP - WATER LEAKAGE	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	Elbow action tap replaced.		Girija. G. - Female Ortho Ward	22/06/2023
Comp. Dt. : 28/06/2023 Status : Completed								
1469	23061039	Female Ortho - Ward 402	NEED TO CHANGE SINK TAP - WATER LEAKAGE & SINK BLOCK NEED URGENT SERVICE	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	Sink tap changed and block removed.		Dhansulakshmi. K. - Female Ortho Ward	01/07/2023
Dept Name : Female Surgery - Civil - Maintenance Comp. Dt. : 20/05/2022 Status : Completed								
1470	22050758	Female Surgery - Ward 205	NEED TO CHECK TAP - WATER LEAKAGE	Prakash. V.	new tap chaning work		Jayasree. S. - TB & Chest / Psychiatry	21/05/2022
Comp. Dt. : 06/07/2022 Status : Completed								
1471	22070215	Male Surgery - Ward 203	NEED TO CHECK CEILING - LEAKED WATER THROUGH THE CEILING , AFFECTING ELECTRICAL WIRES AROUND THE	Prakash. V.,Arunagiri. V.,Rajendran. R.	Expand joint fault. Water leakage due to washing work at 3rd floor		Ezhilarasi. E. - Male Surgery	07/07/2022
Comp. Dt. : 06/08/2022 Status : Completed								
1472	22080229	Male Surgery - Ward 203	BLOCK IN PATIENT RESTROOM	Rajendhiran. V.,Murugan. S.,Thanuzkodi. E	Block removed.		Vaidegi. S. - Female Surgery	09/08/2022
Comp. Dt. : 02/09/2022 Status : Completed								
1473	22090098	Male Surgery - Ward 204	DOCTORS RESTROOM FLUSH NOT WORKING	Prakash. V.,Rajendran. R.,Ramkumar. R.	flush tank rework done		Vinodhini. K. - Female Surgery	03/09/2022
Comp. Dt. : 06/09/2022 Status : Completed								
1474	22090236	Male Surgery - Ward 203	NEED TO CHECK HEATER PIPELINE - WATER LEAKAGE AT PATIENT RESTROOM	Prakash. V.,Rajendran. R.,Ramkumar. R.	CP Tap changed, problem solved		Vaidegi. S. - Female Surgery	09/09/2022
Comp. Dt. : 10/11/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1475	22110381	Male Surgery - Ward 201	PATIENT REST ROOM PIPE BROKEN - WATER LEAKAGE	Prakash. V.,Rajendran. R.,Ramkumar. R.	Pipe line connection done.		Vaidegi. S. - Female Surgery	10/11/2022
	Comp. Dt. : 02/01/2023							
	Status : Completed							
1476	23010039	Male Surgery - Ward 201	WATER NOT COMING IN PATIENT REST ROOM	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	Tap rework done.		Priyanka. V. - Female Surgery	02/01/2023
	Comp. Dt. : 25/01/2023							
	Status : Completed							
1477	23010938	Male Surgery - Ward 201	NEED TO CHECK WASH BASIN PIPELINE CONNECTION - WATER NOT COMING	Azhagar. N.,Anandharaj. M.,Sellaveeran. M.	Tap air lock released, serviced and refixed in properly, problem solved		Priyanka. V. - Female Surgery	27/01/2023
	Comp. Dt. : 28/01/2023							
	Status : Completed							
1478	23011031	Female Surgery - Ward 205	NEED MAN POWER 2 NOS FOR BERO SHIFTING WORK	Pandiaraj. V.,Yuvaraj. M.,Thulasi. V.	Bero shifting work completed		Vaidegi. S. - Female Surgery	07/02/2023
	Comp. Dt. : 20/03/2023							
	Status : Completed							
1479	23030785	Male Surgery - Ward 203	BLOCK IN WASH BASIN	Rajendhiran. V.,Thanuzkodi. E.,Murugan. R.	BLOCK REMOVED.		Priyanka. V. - Female Surgery	21/03/2023
	Comp. Dt. : 22/03/2023							
	Status : Completed							
1480	23030902	Male Surgery - Ward 204	BLOCK IN WASHBASIN & NEED TO CHANGE DRAINAGE HOSE - LEAKAGE	Rajendhiran. V.,Thanuzkodi. E.,Murugan. S.	BLOCK REMOVED.		Subashini. D. - Gynac Ward	23/03/2023
	Comp. Dt. : 25/03/2023							
	Status : Completed							
1481	23031048	Female Surgery - Ward 205	SINK DRAINAGE HOSE DAMAGE - WATER LEAKAGE AT PATIENT RESTROOM	Anandharaj. M.,Azhagar. N.,Sivaraja. M.	SINK DRAINAGE HOSE CHANGED.		Vaidegi. S. - Female Surgery	27/03/2023
	Comp. Dt. : 28/03/2023							
	Status : Completed							
1482	23031153	DENTAL OPD -2ND FLOOR	NEED TO CHECK DENTAL CHAIR PIPELINE - WATER LEAKAGE	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	1/2" SHOWER TAP VALVE FIXED.		Jayasree. S. - TB & Chest / Psychiatry	31/03/2023

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 01/06/2023 Status : Completed								
1483	23060001	Female Surgery - Ward 205	BEEES COMING INSIDE THE WARD , NEED TO REMOVE THE BEE NEST - NEED URGENT SERVICE	Sivaraja. M.	HONEY COMB DESTROYED.		Vaidegi. S. - Female Surgery	03/06/2023
Comp. Dt. : 16/06/2023 Status : Completed								
1484	23060606	ICU	WASHBASIN SINK WATER LEAKAGE PROBLEM	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	DRAINAGE HOSE REWORK DONE.		Brindha. R. - Female Surgery	17/06/2023
Dept Name : FORENSIC MEDICINE - Civil - Maintenance Comp. Dt. : 18/10/2022 Status : Completed								
1485	22100611	FORENSIC MEDICINE (3RD FLOOR) IN COLLEGE	SINK BROKEN	Anandharaj. M.	Wash basin fixed.		Mathavi. B. - FORENSIC MEDICINE	22/10/2022
Dept Name : Gas Power Plant - Civil - Maintenance Comp. Dt. : 14/06/2022 Status : Completed								
1486	22060526	Printing Press	NEED LABOUR 1 NO FOR UNLOADING MATERIAL FROM PUDUCHERRY	Pandiaraj. V.,Yuvaraj. M.,Murali. K.	materials unloaded.		Mahi Mohan Ram.S. - Gas Power Plant	17/06/2022
Comp. Dt. : 16/06/2022 Status : Completed								
1487	22060630	Gas Power Plant	NEED TO CHECK WASH BASIN TAP - WATER FORCE	Arunagiri. V.,Rajendran. R.,Prakash. V.	New pillar cock changed.		Mahi Mohan Ram.S. - Gas Power Plant	21/06/2022
Comp. Dt. : 07/07/2022 Status : Completed								
1488	22070277	Gas Power Plant	NEED VACUUM LINE TIGHT	Prakash. V.	Tighten the pipe line		Mahi Mohan Ram.S. - Gas Power Plant	12/07/2022
Comp. Dt. : 15/07/2022 Status : Completed								
1489	22070590	PRESS	NEED LABOURS 6 NOS FOR DISTRIBUTING RECORD NOTES FROM PRESS TO ALL OUR INSTITUTION [LABOUR NEED O	Pandiaraj. V.,Yuvaraj. M.,Prakash. N.	Record Note unloading and distribute work completed		Mahi Mohan Ram.S. - Gas Power Plant	20/07/2022
Comp. Dt. : 12/08/2022								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
1490	22080438	Printing Press	NEED LABOURS 4 NOS FOR UNLOADING PAPER BUNDAL FROM GROUND FLOOR PRESS TO I FLOOR	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	Paper bundle unloading and shifting work completed		Mahi Mohan Ram.S. - Gas Power Plant	17/08/2022
Comp. Dt. : 22/08/2022								
Status : Completed								
1491	22080688	LAUNDRY	PIPE LINE BROKEN - WATER OVERFLOW AT BACKSIDE OF LAUNDRY	Prakash. V.,Rajendran. R.,Ramkumar. R.	Dummy fixed.		Mahi Mohan Ram.S. - Gas Power Plant	23/08/2022
Comp. Dt. : 25/08/2022								
Status : Completed								
1492	22080857	NEW GAS PLANT	CEILING LEAKAGE - WATER DROPED HEAVY	Prakash. V.,Ramkumar. R.,Rajendran. R.	sunshade cleaning work done.		Mahi Mohan Ram.S. - Gas Power Plant	30/08/2022
Comp. Dt. : 18/10/2022								
Status : Completed								
1493	22100591	Printing Press	NEED MANPOWER 4 NOS FOR UNLOADING PAPER BUNDALS FROM PRESS GROUND FLOOR TO I FLOOR	Prakash. N.,Yuvaraj. M.,Senthil Kumar. R.	Paper unloading work completed.		Mahi Mohan Ram.S. - Gas Power Plant	20/10/2022
Comp. Dt. : 27/10/2022								
Status : Completed								
1494	22100842	Gas Power Plant	WATERLINE PIPE BROKEN IN LIQUID GAS PLANT	Prakash. V.,Rajendran. R.,Manikandan. S.	2.1/2" PVC Pipe line fully rework, work completed		Mahi Mohan Ram.S. - Gas Power Plant	27/10/2022
Comp. Dt. : 05/11/2022								
Status : Completed								
1495	22110182	Gas Power Plant	NEED LABOURS FOR SHIFTING PURPOSE	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	A4 Papber bundle unloading and shifting work completed on that day		Mahi Mohan Ram.S. - Gas Power Plant	08/11/2022
Comp. Dt. : 09/11/2022								
Status : Completed								
1496	22110355	Gas Power Plant	NEED LABOURS FOR SHIFTING PURPOSE	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	Materials shifting work completed.		Mahi Mohan Ram.S. - Gas Power Plant	11/11/2022
Comp. Dt. : 10/11/2022								
Status : Completed								
1497	22110407	Gas Power Plant	NEED 4 MANPOWER FOR PAPER BUNDLE SHIFTING WORK	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	Paper bundle unloading and shifting work completed		Mahi Mohan Ram.S. - Gas Power Plant	14/11/2022

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHAL KUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 17/11/2022 Status : Completed								
1498	22110707	Gas Power Plant	WASH BASIN SINK HOSE LEAKAGING PROBLEM	Prakash. V.	connection tube changed.		Mahi Mohan Ram.S. - Gas Power Plant	05/12/2022
Comp. Dt. : 23/11/2022 Status : Completed								
1499	22110982	Printing Press	NEED 5 NO'S MANPOWER FOR SHIFTING PURPOSE	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	Paper bundle unloading and shifting work completed		Mahi Mohan Ram.S. - Gas Power Plant	24/11/2022
Comp. Dt. : 16/12/2022 Status : Completed								
1500	22120787	Work Shop	WATER PIPELINE BROKEN - WATER FLOW - NEED TO CHANGE TAP - NEAR WORKSHOP NEED URGENT SERVICE	Prakash. V.,Rajendran. R.,Ramkumar. R.	tap changed.		Mahi Mohan Ram.S. - Gas Power Plant	20/12/2022
Comp. Dt. : 23/12/2022 Status : Completed								
1501	22121048	Printing Press	NEED 4 LABOURS TO GET A4 SHEET BUNDLE FROM PONDY	Pandiaraj. V.,Yuvaraj. M.,Thulasi. V.	A4 paper bundle unloading and shifting work completed		Mahi Mohan Ram.S. - Gas Power Plant	23/12/2022
1502	22121052	COW SHED	NEED TO SPRAY PESTICIDE MEDICINE	Rajendhiran. V.	Pesticide medicine sprayed.		Mahi Mohan Ram.S. - Gas Power Plant	24/12/2022
Comp. Dt. : 27/12/2022 Status : Completed								
1503	22121244	Printing Press	NEED 4 MEMBERS MANPOWER FOR PAPER BUNDLE SHIFTING WORK ON TOMORROW MORNING	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	A4 Paper bundle unloading and shifting work completed		Mahi Mohan Ram.S. - Gas Power Plant	30/12/2022
Comp. Dt. : 05/01/2023 Status : Completed								
1504	23010207	Printing Press	NEED LABOURS FOR PAPER BUNDLE SHIFTING WORK	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	Paper bundles shifting work completed.		Mahi Mohan Ram.S. - Gas Power Plant	09/01/2023
Comp. Dt. : 12/01/2023 Status : Completed								
1505	23010532	PRESS	SHIFTING WORK IN MAILAM COLLEGE (LABOUR 2NOS)	Prakash. N.,Pandiaraj. V.,Yuvaraj. M.	Shifting work completed.		Mahi Mohan Ram.S. - Gas Power Plant	14/01/2023
Comp. Dt. : 29/03/2023 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1506	23031230	Gas Power Plant	DUE TO FIX TELEPHONE CABLE NEED MANPOWER 1 NO	Santhosh Kumar. M.,Sivaraja. M.,Anandharaj. M.	WORK COMPLETED		Mahi Mohan Ram.S. - Gas Power Plant	03/04/2023
Comp. Dt. : 26/06/2023 Status : Completed								
1507	23060981	Gas Power Plant	BLOCK IN WASH BASIN	Raja. V.,Thanuzkodi. E,Gnanasegaran. K.	Block removed.		Mahi Mohan Ram.S. - Gas Power Plant	27/06/2023
Dept Name : Guest House - Indian Bank - Civil - Maintenance Comp. Dt. : 25/05/2022 Status : Completed								
1508	22050935	Guest House - Indian Bank	FLUSH TANK PROBLEM - ROOM NO 101, 105, 106 ,202 & 206	Prakash. V.,Ramkumar. R.,Arunagiri. V.	Flush tank and health faucet cleaned and serviced in 6 rooms, problem solved		John. H. - Guest House - Indian Bank	25/05/2022
Comp. Dt. : 03/06/2022 Status : Completed								
1509	22060115	Guest House - Indian Bank	NEED TO CHANGE HAND SHOWER FOR ROOM NO 201 & W C SEAT COVER FOR ROOM NO 101	Ramkumar. R.	#101 - EWC seat cover changed, #201 - Health faucet changed.		John. H. - Guest House - Indian Bank	24/06/2022
Comp. Dt. : 11/06/2022 Status : Completed								
1510	22060404	Guest House - Indian Bank	FLUSH NOT WORKING - ROOM NO 101 & 206	Arunagiri. V.	Flush tank rework.		John. H. - Guest House - Indian Bank	15/06/2022
Comp. Dt. : 14/06/2022 Status : Completed								
1511	22060513	Guest House - Indian Bank	WASH BASIN BLOCK AT STORE ROOM & FLUSH NOT WORKING ROOM NO 206	Rajendran. R.	flush tank rework.		John. H. - Guest House - Indian Bank	15/06/2022
Comp. Dt. : 28/06/2022 Status : Completed								
1512	22061015	Guest House - Indian Bank	NEED TO CHANGE HAND SET TAP - WATER LEAKAGE - ROOM NO 205	Prakash. V.	New health faucet changed, problem solved		John. H. - Guest House - Indian Bank	30/06/2022
Comp. Dt. : 29/06/2022 Status : Completed								
1513	22061060	Guest House - Indian Bank	FLUSH NOT WORKING - ROOM NO 103	Arunagiri. V.,Rajendran. R.,Ramkumar. R.	Flush tank rework		John. H. - Guest House - Indian Bank	01/07/2022
Comp. Dt. : 30/06/2022								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
1514	22061134	Guest House - Indian Bank	DUE TO FOREIGNERS VISIT - NEED TO CHECK ALL CIVIL MAINTENANCE RELATED ITEMS FOR ALL ROOMS	Rajendran. R.,Prakash. V.,Arunagiri. V.	All rooms checked and tap shower serviced.		John. H. - Guest House - Indian Bank	07/07/2022
Comp. Dt. : 14/07/2022								
Status : Completed								
1515	22070548	Guest House - Indian Bank	FLUSH NOT WORKING - ROOM NO 103	Prakash. V.,Rajendran. R.,Ramkumar. R.	Flush tank and water heater line fully rework, work completed		John. H. - Guest House - Indian Bank	16/07/2022
Comp. Dt. : 30/07/2022								
Status : Completed								
1516	22071111	Guest House - Indian Bank	WASH BASIN BLOCK AT ROOM NO 103	Rajendhiran. V.,Murugan. S.,Thanuzkodi. E	Wash basin block removed, 1.1/4" waste water pipe line fully rework, work completed		John. H. - Guest House - Indian Bank	01/08/2022
Comp. Dt. : 01/08/2022								
Status : Completed								
1517	22080027	Guest House - Indian Bank	NEED TO CUT THE ROOTS - DUE TO TREE ROOTS IN SIDE WALLS OF GUEST HOUSE- MADE DAMAGE	Arunagiri. V.	Block removed. Tree roots cleared. Tap rework done at both guest house and bank		John. H. - Guest House - Indian Bank	03/08/2022
Comp. Dt. : 11/08/2022								
Status : Completed								
1518	22080406	Guest House - Indian Bank	BLOCK IN SINK - ROOM NO 201	Rajendhiran. V.,Murugan. S.,Thanuzkodi. E	Block removed.		John. H. - Guest House - Indian Bank	12/08/2022
Comp. Dt. : 19/09/2022								
Status : Completed								
1519	22090754	Guest House - Indian Bank	NEED TO CHECK FLUSH TANK - WATER LEAKAGE AT STORE ROOM NEAR REST ROOM	Prakash. V.,Rajendran. R.,Ramkumar. R.	Flush tank rework		John. H. - Guest House - Indian Bank	22/09/2022
Comp. Dt. : 01/10/2022								
Status : Completed								
1520	22100004	Guest House - Indian Bank	WASH BASIN WATER LEAKAGE - ROOM NO 201	Prakash. V.,Rajendran. R.,Ramkumar. R.	Wash basin block removed. Tap rework done.		John. H. - Guest House - Indian Bank	05/10/2022
Comp. Dt. : 02/12/2022								
Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1521	22120089	Guest House - Indian Bank	NEED TO CHANGE WASH BASIN PIPE LINE - WATER LEAKAGE - ROOM NO. 101,103 & 204	Ramkumar. R.	Wash basin pipe line changed./		John. H. - Guest House - Indian Bank	17/12/2022
Comp. Dt. :		27/01/2023						
Status :		Completed						
1522	23010948	Guest House - Indian Bank	NEED WATER TANK CLEANING WORK	Kannan. J.	Tank cleaning work completed.		John. H. - Guest House - Indian Bank	27/01/2023
Comp. Dt. :		30/01/2023						
Status :		Completed						
1523	23011079	Guest House - Indian Bank	NEED TO FIX WATER TANK CLOSER	Anandharaj. M.	Work completed.		John. H. - Guest House - Indian Bank	03/02/2023
Comp. Dt. :		02/05/2023						
Status :		Completed						
1524	23050057	Guest House - Indian Bank	NEED TO CHECK SUNSHADE SIDE WALL - RAIN WATER LEAKAGE INSIDE THE ROOM - ROOM NO 101, 104 & 201,20	Gopal. S.,Sivaraja. M.,Santhosh Kumar. M.	Sunshade pipeline block removed.		John. H. - Guest House - Indian Bank	04/05/2023
Comp. Dt. :		13/05/2023						
Status :		Completed						
1525	23050554	Guest House - Indian Bank	NEED TO CHANGE SHOWER - LEAKAGE - ROOM NO 202	Anandharaj. M.,Azhagar. N.,Sivaraja. M.	DIVERTER REWORK DONE.		John. H. - Guest House - Indian Bank	18/05/2023
Comp. Dt. :		06/06/2023						
Status :		Completed						
1526	23060202	Guest House - Indian Bank	NEED TO REFIX HAND SET HANGER - BROKEN AT ROOM NO 103	Anandharaj. M.,Sivaraja. M.,Santhosh Kumar. M.	health faucet set changed.		John. H. - Guest House - Indian Bank	13/06/2023
Comp. Dt. :		13/06/2023						
Status :		Completed						
1527	23060461	Guest House - Indian Bank	NEED TO CHANGE SEAT COVER - DAMAGE - FOR ROOM NO 106	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	seat cover changed.		John. H. - Guest House - Indian Bank	20/06/2023
Dept Name :		Gynac Ward - Civil - Maintenance						
Comp. Dt. :		09/05/2022						
Status :		Completed						
1528	22050253	Labour Room	BLOCK IN WASH BASIN	Sakthivel. E.	block remover work		Kanimozhi. S. - Labour Ward	09/05/2022

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHAL KUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1529	22050266	Obstetrics - Ward 208	BLOCK IN REST ROOM	Rajendhiran. V.	block remover work		Sangeetha. J. - Gynac Ward	09/05/2022
	Comp. Dt. : 23/05/2022							
	Status : Completed							
1530	22050843	Labour Room	BLOCK IN WASH BASIN	Rajendhiran. V.,Thanuzkodi. E,Govindan. R.	Block removed in the wash basin		Kanimozhi. S. - Labour Ward	25/05/2022
	Comp. Dt. : 04/06/2022							
	Status : Completed							
1531	22060168	Obstetrics - Ward 207	NEED TO CHANGE TAP - BROKENED & WATER FLOW	Prakash. V.	New tap changed.		Ashwini. V. - Gynac Ward	06/06/2022
	Comp. Dt. : 13/06/2022							
	Status : Completed							
1532	22060473	Obstetrics - Ward 207	BLOCK IN RESTROOM	Rajendran. R.	Block removed.		Ashwini. V. - Gynac Ward	14/06/2022
	Comp. Dt. : 05/07/2022							
	Status : Completed							
1533	22070141	Labour Room	BLOCK IN WASH BASIN	Rajendhiran. V.,Thanuzkodi. E,Murugan. S.	Wash basin block removed, work completed		Kanimozhi. S. - Labour Ward	06/07/2022
	Comp. Dt. : 15/07/2022							
	Status : Completed							
1534	22070587	Obstetrics - Ward 207	BLOCK IN PATIENT RESTROOM	Rajendhiran. V.	Toilet block removed, work completed		Ashwini. V. - Gynac Ward	16/07/2022
	Comp. Dt. : 25/07/2022							
	Status : Completed							
1535	22070906	Obstetrics - Ward 207	BLOCK IN PATIENT REST ROOM	Rajendhiran. V.,Thanuzkodi. E,Murugan. S.	Block removed		Ramajayam. S. - Gynac Ward	26/07/2022
	Comp. Dt. : 04/08/2022							
	Status : Completed							
1536	22080163	Obstetrics - Ward 207	BATHROOM BLOCK,NEED SCAVENGER	Rajendhiran. V.,Murugan. S.,Thanuzkodi. E	Block removed.		Ashwini. V. - Gynac Ward	06/08/2022
	Comp. Dt. : 06/08/2022							
	Status : Completed							
1537	22080224	Obstetrics - Ward 208	BLOCK IN DOCTOR'S RESTROOM	Rajendhiran. V.,Murugan. S.,Thanuzkodi. E	Block removed.		Kalaivani. J. - Operation Theatre	06/08/2022

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 25/08/2022								
Status : Completed								
1538	22080842	Obstetrics - Ward 208	NEED TO CHECK CEILING - WATER FLOW IN CEILING - NEED URGENT SERVICE	Prakash. V.,Rajendran. R.,Ramkumar. R.	Water leakage arrest done		Divya. K. - Gynac Ward	30/08/2022
Comp. Dt. : 26/08/2022								
Status : Completed								
1539	22080887	Obstetrics - Ward 208	BLOCK IN RESTROOM	Rajendhiran. V.,Murugan. S.,Thanuzkodi. E	Block removed.		Ashwini. V. - Gynac Ward	29/08/2022
Comp. Dt. : 29/08/2022								
Status : Completed								
1540	22080999	Obstetrics - Ward 208	BLOCK IN PATIENT RESTROOM	Rajendhiran. V.,Thanuzkodi. E,Murugan. S.	Block removed.		Ashwini. V. - Gynac Ward	30/08/2022
Comp. Dt. : 02/09/2022								
Status : Completed								
1541	22090097	Obstetrics - Ward 207	NEED TO FIX WESTERN TOILET SEATER	Prakash. V.,Rajendran. R.,Ramkumar. R.	seat cover changed.		Sangeetha. J. - Gynac Ward	06/09/2022
Comp. Dt. : 14/09/2022								
Status : Completed								
1542	22090515	Obstetrics - Ward 208	NEED TO CHANGE WASH BASIN TAP - TAP DAMAGE - NOT CLOSING	Prakash. V.,Rajendran. R.,Ramkumar. R.	Tap rework, problem solved		Ashwini. V. - Gynac Ward	17/09/2022
1543	22090523	Obstetrics & Gynaecology	IN WASH BASIN WATER NOT COMING AT DOCTOR'S ROOM & PATIENT REST ROOM WARD NO 207 & 208 + BLOCK AT	Prakash. V.,Rajendran. R.,Ramkumar. R.	valve closed in terrace, OT inside tap changing purpose, after finishing the work valve opened, Bloc		Ashwini. V. - Gynac Ward	17/09/2022
Comp. Dt. : 17/09/2022								
Status : Completed								
1544	22090663	ENT WARD-407	REST ROOM BLOCK	Rajendhiran. V.,Sakthivel. E.,Murugan. S.	Toilet block removed, work completed		Saranya. S. - Gynac Ward	17/09/2022
Comp. Dt. : 31/10/2022								
Status : Completed								
1545	22100989	Gynaecology - Ward 209	BATHROOM BLOCK	Rajendhiran. V.,Murugan. S.,Thanuzkodi. E	Block removed.		Vishnupriya. V. - Gynac Ward	31/10/2022
1546	22101006	Obstetrics - Ward 207	NEED TO MAN POWER-BERO SHIFTING WORK	Pandiaraj. V.,Yuvaraj. M.,Murali. K.	Shifting work completed		Ashwini. V. - Gynac Ward	31/10/2022

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHAL KUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 18/11/2022 Status : Completed								
1547	22110768	Obstetrics - Ward 208	BLOCK IN PATIENT RESTROOM	Rajendhiran. V.,Murugan. S.,Thanuzkodi. E	Block removed.		Sangeetha. J. - Gynac Ward	21/11/2022
Comp. Dt. : 19/11/2022 Status : Completed								
1548	22110832	ICU	FLUSH NOT WORKING	Prakash. V.	Flush tank rework done.		Amsavalli. S. - Gynac Ward	23/11/2022
Comp. Dt. : 08/12/2022 Status : Completed								
1549	22120367	SPECIAL WARD -C IN FOURTH FLOOR	PATIENT BATHROOM-WATER NOT COMING	Prakash. V.	Tank filled. Problem rectified.		Ashwini. V. - Gynac Ward	12/12/2022
Comp. Dt. : 21/12/2022 Status : Completed								
1550	22120990	Female Ortho - Ward 401	WATER NOT COMING IN PATIENTS REST ROOM	Prakash. V.	Tap rework done.		Saranya. S. - Gynac Ward	23/12/2022
Comp. Dt. : 10/01/2023 Status : Completed								
1551	23010382	Obstetrics - Ward 208	TOILET BLOCKED,NEED SCAVENGER	Rajendhiran. V.,Thanuzkodi. E,Murugan. S.	Block removed.		Subasri. G. - Gynac Ward	10/01/2023
Comp. Dt. : 11/01/2023 Status : Completed								
1552	23010465	Female Surgery - Ward 205	TOILET BLOCKED,NEED SCAVENGER	Rajendhiran. V.,Thanuzkodi. E,Murugan. S.	block removed.		Amsavalli. S. - Gynac Ward	12/01/2023
Comp. Dt. : 14/01/2023 Status : Completed								
1553	23010586	Obstetrics - Ward 210	NEED TO CHECK HEATER PIPE LINE WATER NOT COMING	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	NRV fixed.		Divya. K. - Gynac Ward	20/01/2023
Comp. Dt. : 23/01/2023 Status : Completed								
1554	23010797	Obstetrics - Ward 207	NEED TO CHECK SINK TAP - NOT ABLE TO OPEN & WATER NOT COMING	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	Connection tube changed.Tap rework done.		Divya. K. - Gynac Ward	24/01/2023
Comp. Dt. : 31/01/2023								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
1555	23011116	Gynaecology - Ward 209	BLOCK IN PATIENT RESTROOM	Rajendhiran. V.,Thanuzkodi. E,Govindan. R.	Block removed.		Vishnupriya. V. - Gynac Ward	01/02/2023
Comp. Dt. : 03/02/2023								
Status : Completed								
1556	23020101	Obstetrics - Ward 207	RESTROOM BLOCK	Rajendhiran. V.	Block removed.		Sangeetha. J. - Gynac Ward	04/02/2023
Comp. Dt. : 14/02/2023								
Status : Completed								
1557	23020506	Obstetrics - Ward 208	WATER NOT COMING IN RESTROOM TAP - NEED TO CHECK PIPELINE	Azhagar. N.,Sellaveeran. M.,Udhaya Kumar. R.	TAP REWORK DONE		Vishnupriya. V. - Gynac Ward	15/02/2023
1558	23020540	Obstetrics - Ward 208	FLUSH NOT WORKING & BLOCK IN RESTROOM	Rajendhiran. V.,Thanuzkodi. E,Murugan. S.	FLUSH TANK REWORK DONE AND BLOCK REMOVED.		Subasri. G. - Gynac Ward	15/02/2023
Comp. Dt. : 27/02/2023								
Status : Completed								
1559	23021004	Obstetrics - Ward 207	RESTROOM BLOCK	Rajendhiran. V.,Thanuzkodi. E,Murugan. S.	BLOCK REMOVED.		Sangeetha. J. - Gynac Ward	28/02/2023
Comp. Dt. : 28/03/2023								
Status : Completed								
1560	23031198	Obstetrics - Ward 207	BLOCK IN RESTROOM	Rajendhiran. V.,Thanuzkodi. E,Murugan. S.	BLOCK REMOVED.		Sangeetha. J. - Gynac Ward	29/03/2023
Comp. Dt. : 19/04/2023								
Status : Completed								
1561	23040610	Obstetrics - Ward 207	RESTROOM BLOCK	Rajendhiran. V.,Sakthivel. E.,Govindan. R.	Toilet block removed, work completed		Sangeetha. J. - Gynac Ward	20/04/2023
Comp. Dt. : 26/04/2023								
Status : Completed								
1562	23040839	Obstetrics - Ward 208	BLOCK IN WESTERN	Rajendhiran. V.,Thanuzkodi. E,Murugan. S.	BLOCK REMOVED.		Divya. K. - Gynac Ward	26/04/2023
Comp. Dt. : 03/05/2023								
Status : Completed								
1563	23050075	Obstetrics - Ward 208	BLOCK IN RESTROOM - NEED URGENT SERVICE	Rajendhiran. V.,Thanuzkodi. E,Murugan. S.	block removed		Divya. K. - Gynac Ward	03/05/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 06/05/2023 Status : Completed								
1564	23050237	Obstetrics - Ward 207	NEED TO CHECK WESTERN - BLOCK & PROBLEM	Thanuzkodi. E,Rajendhiran. V.,Murugan. S.	block removed.		Subasri. G. - Gynac Ward	06/05/2023
Comp. Dt. : 09/06/2023 Status : Completed								
1565	23060326	Obstetrics - Ward 207	FLUSH NOT WORKING	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	Flush tank rework done.		Ashwini. V. - Gynac Ward	12/06/2023
Comp. Dt. : 12/06/2023 Status : Completed								
1566	23060415	Obstetrics - Ward 207	BLOCK IN RESTROOM	Rajendhiran. V.,Thanuzkodi. E,Murugan. S.	block removed.		Nanthini. M. - Gynac Ward	13/06/2023
Comp. Dt. : 16/06/2023 Status : Completed								
1567	23060611	Gynaecology - Ward 209	TREATMENT ROOM - -WATER NOT COMING	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	WORK COMPLETED		Vishnupriya. V. - Gynac Ward	17/06/2023
Dept Name : Hospital Infection Control - Civil - Maintenance Comp. Dt. : 31/10/2022 Status : Completed								
1568	22101019	Infection Control	NEED MAN POWER--SINK SHIFTING WOTRK(305 TO 403)	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	Shifting work completed		Mohana. M. - Hospital Infection Control	31/10/2022
Comp. Dt. : 09/11/2022 Status : Completed								
1569	22110333	Infection Control	NEED TO CHECK CEILING WATER LEAKAGE - 4TH FLOOR HOSPITAL INFECTION CONTROL DEPT	Prakash. V.,Rajendran. R.,Ramkumar. R.	Rain water leakage.		Mohana. M. - Hospital Infection Control	10/11/2022
Comp. Dt. : 14/11/2022 Status : Completed								
1570	22110525	HICC ROOM IN 4TH FLOOR-403	NEED TO FIX POSTER	Prakash. N.,Pandiaraj. V.,Yuvaraj. M.	Poster fixed, work complete		Mohana. M. - Hospital Infection Control	21/11/2022
Comp. Dt. : 10/06/2023 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1571	23060360	TB & Chest OPD	NEED TO CHECK DUCT DOOR ROOM AT TB CHEST OPD NEAR LIFT ROOM - BAD SMELL - NEED URGENT SERVICE	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	Phorate, mosquito repellent and termite repellent were removed from the duct area where they were st		Mohana. M. - Hospital Infection Control	10/06/2023
Dept Name : Housekeeping - Civil - Maintenance Comp. Dt. : 05/05/2022 Status : Completed								
1572	22050150	COMMON MALE TOILET NEAR BIOCHEMISTRY	REST ROOM BLOCK	Govindan. R.,Sakthivel. E.,Rajendhiran. V.	block remove work		Elangchezhiyan. R. - Housekeeping	05/05/2022
Comp. Dt. : 09/05/2022 Status : Completed								
1573	22050271	Obstetrics - Ward 207	BLOCK IN RESTROOM	Govindan. R.	block remover work		Balasubramaniyam. G. - Housekeeping	09/05/2022
1574	22050291	COMMON TOILET NEAR MEDICINE OPD	NEED TO REFIX TAP & FLUSH TANK [DAMAGE & BROKEN]FOR FEMELE REST ROOM -	Prakash. V.	flush tank rework		Elangchezhiyan. R. - Housekeeping	09/05/2022
Comp. Dt. : 10/05/2022 Status : Completed								
1575	22050350	COMMON MALE TOILET NEAR ORTHO OPD	REST ROOM BLOCK	Rajendhiran. V.,Thanuzkodi. E,Govindan. R.	block remover work		Elangchezhiyan. R. - Housekeeping	11/05/2022
Comp. Dt. : 16/05/2022 Status : Completed								
1576	22050578	COMMON TOILET NEAR MEDICINE OPD	URINAL BLOCK	Rajendran. R.	urinal block removed.		Elangchezhiyan. R. - Housekeeping	17/05/2022
Comp. Dt. : 18/05/2022 Status : Completed								
1577	22050665	Male Surgery - Ward 201	BLOCK IN REST ROOM	Thanuzkodi. E	Block removed.		Balasubramaniyam. G. - Housekeeping	19/05/2022
1578	22050666	COMMON TOILET NEAR FREE PHARMACY	BLOCK IN URINAL	Thanuzkodi. E	Block removed.		Balasubramaniyam. G. - Housekeeping	19/05/2022
Comp. Dt. : 24/05/2022 Status : Completed								
1579	22050867	COMMON TOILET NEAR OPHTAL OPD	REST ROOM BLOCK AT FEMALE REST ROOM NEAR OPHTAL OPD	Thanuzkodi. E	Block removed.		Elangchezhiyan. R. - Housekeeping	25/05/2022
1580	22050882	Casualty	URINAL BLOCK	Thanuzkodi. E	Urinal block removed		Elangchezhiyan. R. - Housekeeping	25/05/2022
Comp. Dt. : 30/05/2022								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
1581	22051103	COMMON FEMALE RESTROOM NEAR ORTHO OPD	NEED TO CHECK FLUSH TANK & TAP - LEAKAGE	Rajendran. R.,Arunagiri. V.,Ramkumar. R.	Flush tank fullset cleaned and serviced, probelm solved		Elangchezhiyan. R. - Housekeeping	01/06/2022
Comp. Dt. : 02/06/2022								
Status : Completed								
1582	22060078	Male Surgery - Ward 203	W EC SET DAMAGE & BROKENED - NEED TO REFIX	Prakash. N.,Ramkumar. R.,Rajendran. R.	Flush tank full service		Vengadesan. K. - Housekeeping	06/06/2022
Comp. Dt. : 07/06/2022								
Status : Completed								
1583	22060272	COMMON MALE TOILET NEAR ORTHO OPD	BLOCK IN MALE RESTROOM	Rajendhiran. V.	Block removed in male common toilet		Elangchezhiyan. R. - Housekeeping	07/06/2022
Comp. Dt. : 10/06/2022								
Status : Completed								
1584	22060372	COMMON TOILET NEAR FREE PHARMACY	LADIES REST ROOM BLOCK-NEED SCAVENGER	Thanuzkodi. E,Govindan. R.,Rajendhiran. V.	Block removed.		Elangchezhiyan. R. - Housekeeping	13/06/2022
1585	22060388	Female Surgery - Ward 207	BATHROOM BLOCK NEED SCAVENGER	Rajendhiran. V.	Block removed.		Balasubramaniyam. G. - Housekeeping	13/06/2022
Comp. Dt. : 13/06/2022								
Status : Completed								
1586	22060464	COMMON MALE TOILET NEAR BIOCHEMISTRY	BLOCK IN 2 RESTROOMS	Rajendhiran. V.,Thanuzkodi. E,Govindan. R.	Block removed.		Vengadesan. K. - Housekeeping	14/06/2022
Comp. Dt. : 16/06/2022								
Status : Completed								
1587	22060622	Special Ward - C	NEED TO CHECK WASH BASIN TAP - BROKEND AT 409	Arunagiri. V.,Rajendran. R.,Prakash. V.	Spindle changed and tap rework.		Ayyappan. K. - Housekeeping	17/06/2022
Comp. Dt. : 17/06/2022								
Status : Completed								
1588	22060666	COMMON MALE TOILET NEAR ORTHO OPD	BLOCK AT RESTROOM	Rajendhiran. V.	Block removed		Elangchezhiyan. R. - Housekeeping	18/06/2022
Comp. Dt. : 21/06/2022								
Status : Completed								
1589	22060749	Obstetrics - Ward 208	RESTROOM BLOCK	Rajendhiran. V.	block removed		Vengadesan. K. - Housekeeping	21/06/2022
1590	22060758	COMMON TOILET NEAR MEDICINE OPD	BLOCK IN REST ROOM	Rajendhiran. V.	Block removed.		Elangchezhiyan. R. - Housekeeping	21/06/2022
Comp. Dt. : 22/06/2022								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
1591	22060805	COMMON TOILET NEAR OPHTAL OPD	DRAINAGE HOSE DAMAGE IN WASH BASIN AT MALE RESTROOM	Prakash. V.,Rajendran. R.,Ramkumar. R.	Wash basin waste hose rework and refixed, problem solved		Elangchezhiyan. R. - Housekeeping	28/06/2022
Comp. Dt. : 27/06/2022								
Status : Completed								
1592	22060970	COMMON TOILET NEAR MEDICINE OPD	URINAL HOSE DAMAGE * LEAKAGE - NEED TO CHANGE AT MALE RESTROOM NEAR MEDICINE OPD	Prakash. V.,Ramkumar. R.,Rajendran. R.	Waste hose rework		Elangchezhiyan. R. - Housekeeping	27/06/2022
Comp. Dt. : 28/06/2022								
Status : Completed								
1593	22061009	Male Surgery - Ward 201	BLOCK IN WASH BASIN & HEATER NOT WORKING [CIVIL MAINTENANCE FAULT]	Sakthivel. E.,Rajendhiran. V.,Thanuzkodi. E	Wash bain block removed, Water heater connection tube changed.		Balasubramaniyam. G. - Housekeeping	01/07/2022
1594	22061011	Male Surgery - Ward 202	NEED TO CHANGE TAP - WATER FLOW - NEED URGENT SERVICE	Arunagiri. V.	Tap removed, dummy fixed		Balasubramaniyam. G. - Housekeeping	30/06/2022
1595	22061023	COMMON MALE TOILET NEAR ORTHO OPD	NEED TO CHANGE URINAL HOSE - DAMAGE & LEAKAGE -	Prakash. V.,Arunagiri. V.,Rajendran. R.	Urinal line block removed and hose refixed in properly, problem solved		Elangchezhiyan. R. - Housekeeping	30/06/2022
Comp. Dt. : 29/06/2022								
Status : Completed								
1596	22061042	COMMON TOILET NEAR MEDICINE OPD	BLOCK	Rajendhiran. V.	Toilet block removed, work completed		Elangchezhiyan. R. - Housekeeping	30/06/2022
Comp. Dt. : 01/07/2022								
Status : Completed								
1597	22070024	OG-OPD	BLOCK IN RESTROOM	Rajendhiran. V.	Block removed.		Elangchezhiyan. R. - Housekeeping	01/07/2022
1598	22070045	COMMON MALE TOILET NEAR ORTHO OPD	NEED TO CHECK URINAL BASIN HEAD - 3NOS - BROKEN	Prakash. V.,Rajendran. R.,Ramkumar. R.	Urinal basin head changed.		Elangchezhiyan. R. - Housekeeping	12/07/2022
1599	22070046	COMMON TOILET NEAR MEDICINE OPD	NEED TO CHECK URINAL BASIN HEAD - 1 NOS - BROKEN	Prakash. V.,Rajendran. R.,Ramkumar. R.	Urinal basin head changed.		Elangchezhiyan. R. - Housekeeping	12/07/2022
Comp. Dt. : 06/07/2022								
Status : Completed								
1600	22070204	Male Ortho - Ward 404	BLOCK IN WESTERN E W C	Rajendhiran. V.	Block removed		Naresh. R - Housekeeping	06/07/2022
1601	22070214	COMMON MALE TOILET NEAR BIOCHEMISTRY	WASH BASIN TAP - DAMAGE WATER LEAKAGE	Prakash. V.,Rajendran. R.,Ramkumar. R.	Wash basin rework		Elangchezhiyan. R. - Housekeeping	07/07/2022

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 07/07/2022								
Status : Completed								
1602	22070274	SPECIAL WARD---B	WASH BASIN BLOCK AT COMMON RESTROOM	Rajendhiran. V.	Block removed		Ayyappan. K. - Housekeeping	12/07/2022
1603	22070279	Dining Hall	WASH BASIN BLOCK AT PATIENT DINING HALL - GROUND FLOOR	Rajendhiran. V.	Block removed		Elangchezhiyan. R. - Housekeeping	12/07/2022
Comp. Dt. : 09/07/2022								
Status : Completed								
1604	22070359	ORTHO OT	NEED LABOURS 2 NOS FOR SHIFTING UNWANTED PLYWOOD SHEETS FROM ORTHO OT TO WORKSHOP	Pandiaraj. V.,Yuvaraj. M.,Thulasi. V.	Unwanted plywood sheets shifted to workshop		Elangchezhiyan. R. - Housekeeping	11/07/2022
1605	22070381	SPECIAL WARD---B	WASH BASIN BLOCK	Rajendhiran. V.	block removed		Ayyappan. K. - Housekeeping	11/07/2022
Comp. Dt. : 12/07/2022								
Status : Completed								
1606	22070468	COMMON FEMALE TOILET NEAR BIOCHEMISTRY	FLUSH WATER LEAKAGE	Prakash. V.,Rajendran. R.,Ramkumar. R.	Flush tank rework		Elangchezhiyan. R. - Housekeeping	14/07/2022
1607	22070481	COMMON MALE TOILET NEAR ORTHO OPD	BLOCK	Rajendhiran. V.	Toilet block removed, work completed		Elangchezhiyan. R. - Housekeeping	13/07/2022
Comp. Dt. : 19/07/2022								
Status : Completed								
1608	22070720	Male Surgery - Ward 203	NEED TO CHANGE TAP - BROKE - WATER FLOW - NEED URGENT SERVICE	Prakash. V.,Rajendran. R.,Manikandan. S.	New PVC Tap changed, problem solved		Balasubramaniam. G. - Housekeeping	20/07/2022
Comp. Dt. : 20/07/2022								
Status : Completed								
1609	22070757	COMMON MALE TOILET NEAR BIOCHEMISTRY	BLOCK - NEED URGENT SERVICE	Rajendhiran. V.,Govindan. R.,Sakthivel. E.	Block removed		Vengadesan. K. - Housekeeping	21/07/2022
1610	22070760	COMMON MALE TOILET NEAR ORTHO OPD	NEED TO EXTEND URINAL DRAINAGE HOSE - LEAKAGE & BLOCK	Rajendhiran. V.,Thanuzkodi. E.,Murugan. S.	1.1/2" pipe line rework		Elangchezhiyan. R. - Housekeeping	22/07/2022
Comp. Dt. : 21/07/2022								
Status : Completed								
1611	22070795	Obstetrics - Ward 208	BLOCK IN RESTROOM	Rajendhiran. V.,Thanuzkodi. E.,Murugan. S.	Block removed.		Balasubramaniam. G. - Housekeeping	22/07/2022
Comp. Dt. : 25/07/2022								
Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1612	22070927	Obstetrics - Ward 207	RESTROOM BLOCK	Rajendhiran. V.,Thanuzkodi. E,Murugan. S.	Block removed.		Vengadesan. K. - Housekeeping	26/07/2022
Comp. Dt. : 26/07/2022 Status : Completed								
1613	22070983	COMMON TOILET NEAR MEDICINE OPD	WASH BASIN TUBE DAMAGE - WATER LEAKAGE IN MALE RESTROOM	Prakash. V.,Rajendran. R.,Ramkumar. R.	Pillar cock changing work.		Elangchezhiyan. R. - Housekeeping	29/07/2022
Comp. Dt. : 27/07/2022 Status : Completed								
1614	22071018	Male Surgery - Ward 202	BLOCK AT RESTROOM	Rajendhiran. V.,Murugan. S.,Thanuzkodi. E	Block removed.		Balasubramaniam. G. - Housekeeping	29/07/2022
1615	22071028	XRay	RESTROOM BLOCK - NEED URGENT SERVICE	Rajendhiran. V.,Murugan. S.,Thanuzkodi. E	Block removed.		Elangchezhiyan. R. - Housekeeping	29/07/2022
Comp. Dt. : 29/07/2022 Status : Completed								
1616	22071043	COMMON TOILET NEAR MEDICINE OPD	BLOCK IN MALE REST ROOM	Rajendhiran. V.,Murugan. S.,Thanuzkodi. E	Block removed.		Elangchezhiyan. R. - Housekeeping	29/07/2022
Comp. Dt. : 02/08/2022 Status : Completed								
1617	22080074	COMMON MALE TOILET NEAR ORTHO OPD	URINAL HOSE DAMAGE & LEAKAGE NEED TO CHANGE	Prakash. V.,Rajendran. R.,Rajendhiran. V.	Block removed.		Elangchezhiyan. R. - Housekeeping	03/08/2022
1618	22080082	COMMON TOILET NEAR MEDICINE OPD	BLOCK IN MALE RESTROOM	Rajendhiran. V.	Block removed,.		Elangchezhiyan. R. - Housekeeping	03/08/2022
Comp. Dt. : 05/08/2022 Status : Completed								
1619	22080202	Male Ortho - Ward 403	NEED TO CHECK WASH BASIN TAP CONNECTOR VALVE - WATER LEAKAGE	Prakash. V.,Rajendran. R.,Ramkumar. R.	spindle and connection tube changed.		Indirani. S. - Housekeeping	06/08/2022
Comp. Dt. : 06/08/2022 Status : Completed								
1620	22080233	Male Surgery - Ward 203	BLOCK IN RESTROOM	Rajendhiran. V.,Murugan. S.,Thanuzkodi. E	Toilet block removed, work completed		Elangchezhiyan. R. - Housekeeping	09/08/2022
1621	22080238	Male Ortho - Ward 403	NEED TO REFIX URINAL HOSE - DAMAGE & BROKEN	Prakash. V.,Rajendran. R.,Ramkumar. R.	Spindle and connection tube changed.		Ayyappan. K. - Housekeeping	06/08/2022
Comp. Dt. : 08/08/2022								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
1622	22080281	Obstetrics - Ward 207	BLOCK IN DOCTOR'S REST ROOM - NEED URGENT SERVICE	Sakthivel. E.,Govindan. R.,Murugan. S.	Block removed		Vengadesan. K. - Housekeeping	09/08/2022
Comp. Dt. : 10/08/2022								
Status : Completed								
1623	22080383	Surgery OPD	WASH BASIN BLOCK AT OPD NO 72	Rajendhiran. V.,Murugan. S.,Thanuzkodi. E	Wash basin refixed.		Elangchezhiyan. R. - Housekeeping	12/08/2022
1624	22080384	Female Surgery - Ward 205	NEED TO CHECK DRAINAGE HOSE - BROKEN - INSIDE THE WARD - URGENT SERVICE NEED	Prakash. V.,Rajendran. R.,Ramkumar. R.	Waste hose changed, work completed		Elangchezhiyan. R. - Housekeeping	17/08/2022
Comp. Dt. : 12/08/2022								
Status : Completed								
1625	22080461	ICU	NEED TO CHANGE FILTER FOR DRINKING WATER PURIFIER	Prakash. V.,Ramkumar. R.,Rajendran. R.	Filter changed.		Vengadesan. K. - Housekeeping	19/08/2022
Comp. Dt. : 13/08/2022								
Status : Completed								
1626	22080480	COMMON TOILET NEAR MEDICINE OPD	BLOCK IN MALE & FEMALE RESTROOM	Rajendhiran. V.,Govindan. R.,Sakthivel. E.	Male and Female toilet block removed work, work completed		Balasubramaniyam. G. - Housekeeping	17/08/2022
Comp. Dt. : 19/08/2022								
Status : Completed								
1627	22080648	COMMON TOILET NEAR FREE PHARMACY	FEMALE SIDE-2 REST ROOMS-FLUSH TANK NOT WORKING	Prakash. V.,Rajendran. R.,Ramkumar. R.	Flush tank rework done.		Elangchezhiyan. R. - Housekeeping	24/08/2022
Comp. Dt. : 22/08/2022								
Status : Completed								
1628	22080715	Male Surgery - Ward 203	URINARY PIPELINE DAMAGE - NEED TO CHANGE	Prakash. V.,Rajendran. R.,Ramkumar. R.	1.1/4 urinal waste line rework		Balasubramaniyam. G. - Housekeeping	24/08/2022
Comp. Dt. : 23/08/2022								
Status : Completed								
1629	22080768	COMMON TOILET NEAR OPHTAL OPD	DUCT LEAKAGE AT COMMON MALE RESTROOM NEAR OPHTHAL OPD	Prakash. V.,Rajendran. R.,Ramkumar. R.	Block removed, Leakage arrest		Elangchezhiyan. R. - Housekeeping	29/08/2022
1630	22080769	OG-OPD	BLOCK IN WASH BASIN AT DEMO ROOM	Rajendhiran. V.,Murugan. S.,Thanuzkodi. E	Block removed.		Elangchezhiyan. R. - Housekeeping	24/08/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1631	22080775	COMMON TOILET NEAR MEDICINE OPD	URINAL BLOCK	Thanuzkodi. E, Murugan. S., Rajendhiran. V.	Urinal block removed.		Elangchezhiyan. R. - Housekeeping	24/08/2022
Comp. Dt. : 24/08/2022 Status : Completed								
1632	22080801	Male Surgery - Ward 204	BLOCK IN RESTROOM	Rajendhiran. V.	Block removed.		Balasubramaniam. G. - Housekeeping	26/08/2022
1633	22080802	Obstetrics - Ward 208	WATER NOT COMING IN WASH BASIN AT COMMON RESTROOM	Prakash. V., Rajendran. R., Arunagiri. V.	Wash basin rework done		Balasubramaniam. G. - Housekeeping	26/08/2022
1634	22080818	COMMON TOILET NEAR MEDICINE OPD	BLOCK IN FEMALE RESTROOM	Rajendhiran. V., Murugan. S., Thanuzkodi. E	Block removed.		Elangchezhiyan. R. - Housekeeping	26/08/2022
Comp. Dt. : 25/08/2022 Status : Completed								
1635	22080852	COMMON MALE TOILET NEAR BIOCHEMISTRY	BLOCK IN URINAL	Rajendhiran. V., Murugan. S., Thanuzkodi. E	Block removed.		Elangchezhiyan. R. - Housekeeping	26/08/2022
Comp. Dt. : 27/08/2022 Status : Completed								
1636	22080938	COMMON TOILET NEAR MEDICINE OPD	WASH BASIN BLOCK IN COMMON FEMALE TOILET NEAR MEDICINE OPD	Thanuzkodi. E, Govindan. R., Sakthivel. E.	Block removed.		Elangchezhiyan. R. - Housekeeping	30/08/2022
1637	22080951	COMMON TOILET NEAR MEDICINE OPD	BLOCK IN BOTH [MALE & FEMALE] RESTROOM	Rajendhiran. V., Thanuzkodi. E, Murugan. S.	Block removed.		Elangchezhiyan. R. - Housekeeping	30/08/2022
Comp. Dt. : 29/08/2022 Status : Completed								
1638	22080978	COMMON TOILET NEAR MEDICINE OPD	BLOCK IN BOTH MALE & FEMALE RESTROOM	Govindan. R., Thanuzkodi. E, Murugan. S.	Block removed,		Ayyappan. K. - Housekeeping	30/08/2022
1639	22080979	Blood Bank	WASH BASIN BLOCK	Rajendran. R., Govindan. R., Thanuzkodi. E	Wash basin block removed, work completed		Ayyappan. K. - Housekeeping	30/08/2022
Comp. Dt. : 30/08/2022 Status : Completed								
1640	22081029	COMMON TOILET NEAR MEDICINE OPD	BLOCK IN WASH BASIN AT FEMALE RESTROOM	Rajendhiran. V., Murugan. S., Thanuzkodi. E	Block removed.		Elangchezhiyan. R. - Housekeeping	30/08/2022
Comp. Dt. : 10/09/2022 Status : Completed								
1641	22090414	COMMON TOILET NEAR MEDICINE OPD	RESTROOM BLOCK	Rajendhiran. V., Murugan. S., Thanuzkodi. E	Block removed.		Elangchezhiyan. R. - Housekeeping	13/09/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 13/09/2022 Status : Completed								
1642	22090467	COMMON TOILET NEAR MEDICINE OPD	BLOCK IN MALE RESTROOM	Rajendhiran. V.,Murugan. S.,Thanuzkodi. E	block removed.		Elangchezhiyan. R. - Housekeeping	13/09/2022
Comp. Dt. : 14/09/2022 Status : Completed								
1643	22090536	COMMON TOILET NEAR MEDICINE OPD	BLOCK IN MALE RESTROOM	Rajendhiran. V.,Thanuzkodi. E,Murugan. S.	Block removed.		Elangchezhiyan. R. - Housekeeping	15/09/2022
Comp. Dt. : 19/09/2022 Status : Completed								
1644	22090712	Casualty	BLOCK IN MALE CASUALTY REST ROOM & NEED TO CHANGE FLUSH HOSE FOR FEMALE CASUALTY	Rajendhiran. V.,Murugan. S.,Thanuzkodi. E	Block removed.		Vengadesan. K. - Housekeeping	21/09/2022
1645	22090719	OG-OPD	FLUSH & FLUSH KEY DAMAGE AT DOCTOR'S RESTROOM	Prakash. V.,Rajendran. R.,Ramkumar. R.	Flush tank rework.		Vengadesan. K. - Housekeeping	21/09/2022
1646	22090736	Male Surgery - Ward 201	URINAL BLOCK	Rajendhiran. V.,Murugan. S.,Thanuzkodi. E	Urinal block removed.		Balasubramaniyam. G. - Housekeeping	21/09/2022
Comp. Dt. : 20/09/2022 Status : Completed								
1647	22090771*	Dining Hall	NEED DINNING HALL DRAINAGE TO BE CLOSED	Arunagiri. V.	Drainage water cleaned with motor.		Elangchezhiyan. R. - Housekeeping	26/09/2022
1648	22090778	Casualty	BLOCK IN MALE RESTROOM	Rajendhiran. V.,Murugan. S.,Thanuzkodi. E	block removed.		Elangchezhiyan. R. - Housekeeping	21/09/2022
1649	22090779	Male Ortho - Ward 403	NEED REPAIRING & CHANGE FLUSH FOR MALE REST ROOM - BROKEN	Rajendran. R.	Flush tank rework.		Vengadesan. K. - Housekeeping	21/09/2022
Comp. Dt. : 21/09/2022 Status : Completed								
1650	22090811	COMMON RESTROOM IN X RAY	NEED TO CHANGE URINAL HOSE - DAMAGE & UNFIX	Prakash. V.,Rajendran. R.,Ramkumar. R.	1.1/4" urinal line rework		Elangchezhiyan. R. - Housekeeping	22/09/2022
Comp. Dt. : 22/09/2022 Status : Completed								
1651	22090906	Paediatrics - OPD	NEED TO CHECK DRAINAGE PIPE LINE AT PAEDIATRIC OPD OUTSIDE - HOSE BROKEN - NEED URGENT SERVICE	Prakash. V.,Rajendran. R.,Ramkumar. R.	2.1/2 elbow changed.		Elangchezhiyan. R. - Housekeeping	24/09/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 27/09/2022								
Status : Completed								
1652	22091062	Obstetrics - Ward 208	NEED TO CHECK REST ROOM WASH BASIN - WATER NOT COMING	Rajendran. R.,Ramkumar. R.,Arunagiri. V.	Wash basin pillar cork rework.		Balasubramaniam. G. - Housekeeping	28/09/2022
Comp. Dt. : 08/10/2022								
Status : Completed								
1653	22100191	Male Surgery - Ward 201	REST ROOM BLOCK IN 201	Rajendhiran. V.,Murugan. S.,Thanuzkodi. E	Block removed.		Vengadesan. K. - Housekeeping	11/10/2022
1654	22100192	Male Surgery - Ward 202	WATER LEAKAGE IN RESTROOM	Prakash. V.,Rajendran. R.,Ramkumar. R.	Water leak arrested		Vengadesan. K. - Housekeeping	11/10/2022
Comp. Dt. : 13/10/2022								
Status : Completed								
1655	22100375	MIT Auditorium	BLOCK IN MALE REST ROOM -	Sakthivel. E.	block removed		Govindan. D. - Housekeeping	13/10/2022
Comp. Dt. : 15/10/2022								
Status : Completed								
1656	22100504	Male Surgery - Ward 202	REST ROOM BLOCK	Rajendhiran. V.,Murugan. S.,Thanuzkodi. E	Block removed.		Balasubramaniam. G. - Housekeeping	17/10/2022
1657	22100505	COMMON MALE TOILET NEAR ORTHO OPD	REST ROOM BLOCK	Rajendhiran. V.,Thanuzkodi. E,Murugan. S.	Block removed.		Balasubramaniam. G. - Housekeeping	17/10/2022
Comp. Dt. : 25/10/2022								
Status : Completed								
1658	22100774	COMMON TOILET NEAR MEDICINE OPD	URINE PIPE BROKEN IN MALE REST ROOM	Prakash. V.,Rajendran. R.,Ramkumar. R.	New pipe line hose changed.		Elangchezhiyan. R. - Housekeeping	27/10/2022
Comp. Dt. : 26/10/2022								
Status : Completed								
1659	22100825	Male Surgery - Ward 204	REST ROOM BLOCK	Rajendhiran. V.,Thanuzkodi. E,Murugan. S.	Block removed.		Balasubramaniam. G. - Housekeeping	27/10/2022
Comp. Dt. : 02/11/2022								
Status : Completed								
1660	22110009	COMMON MALE TOILET NEAR BIOCHEMISTRY	TOILET BLOCKED,NEED SCAVENGER	Rajendhiran. V.	Block removed.		Balasubramaniam. G. - Housekeeping	03/11/2022
1661	22110037	Male Surgery - Ward 204	IN TREATMENT ROOM-WASH BASIN SINK LEAKAGING PROBLEM	Arunagiri. V.,Abdul Azees. J.,Ramkumar. R.	Block removed.		Balasubramaniam. G. - Housekeeping	05/11/2022

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 03/11/2022								
Status : Completed								
1662	22110083	Male Surgery - Ward 201	COMMON TOILET BLOCKED,NEED SCAVENGER	Rajendhiran. V.,Murugan. S.,Thanuzkodi. E	block removed.		Balasubramaniyam. G. - Housekeeping	03/11/2022
1663	22110084	Male Surgery - Ward 203	IN COMMON BATHROOM-URINAL PIPE FITTING WORK	Prakash. V.,Rajendran. R.,Ramkumar. R.	urinal line waster water pipe line fully rework, work completed		Balasubramaniyam. G. - Housekeeping	07/11/2022
1664	22110093	Obstetrics - Ward 208	TOILET BLOCKED,NEED SCAVENGER	Rajendhiran. V.,Murugan. S.,Thanuzkodi. E	Toilet block removed, work completed		Balasubramaniyam. G. - Housekeeping	03/11/2022
Comp. Dt. : 04/11/2022								
Status : Completed								
1665	22110130	COMMON TOILET NEAR FREE PHARMACY	IN MALE BATHROOM-URIBAL BASIN TAP NEED TO BE FIX NEWLY	Prakash. V.,Rajendran. R.,Ramkumar. R.	Angle valve changed.		Elangchezhiyan. R. - Housekeeping	05/11/2022
1666	22110137	Male Surgery - Ward 201	TOILET BLOCKED ,NEED SCAVENGER	Rajendhiran. V.,Thanuzkodi. E,Murugan. S.	Block removed.		Balasubramaniyam. G. - Housekeeping	05/11/2022
Comp. Dt. : 09/11/2022								
Status : Completed								
1667	22110351	Obstetrics - Ward 208	BATHROOM BLOCK,NEED SCAVENGER	Rajendhiran. V.,Murugan. S.,Thanuzkodi. E	block removed.		Balasubramaniyam. G. - Housekeeping	10/11/2022
Comp. Dt. : 15/11/2022								
Status : Completed								
1668	22110574	New OT	URINAL LINE BLOCK IN REST ROOM	Rajendhiran. V.	Block removed.		Vengadesan. K. - Housekeeping	16/11/2022
1669	22110605	Male Surgery - Ward 201	TOILET BLOCKED,NEED SCAVENGER	Rajendhiran. V.	Block removed.		Balasubramaniyam. G. - Housekeeping	16/11/2022
1670	22110616	COMMON TOILET NEAR FREE PHARMACY	IN MALE TOILET-URINAL BLOCK	Rajendhiran. V.	Block removed.		Elangchezhiyan. R. - Housekeeping	16/11/2022
Comp. Dt. : 18/11/2022								
Status : Completed								
1671	22110755	COMMON TOILET NEAR MEDICINE OPD	URINAL BLOCK	Rajendhiran. V.,Murugan. S.,Thanuzkodi. E	Urinal block removed.		Elangchezhiyan. R. - Housekeeping	21/11/2022
Comp. Dt. : 19/11/2022								
Status : Completed								
1672	22110810	COMMON TOILET NEAR MEDICINE OPD	URINAL BLOCK	Rajendhiran. V.	Block removed.		Elangchezhiyan. R. - Housekeeping	21/11/2022
Comp. Dt. : 22/11/2022								
Status : Completed								

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1673	22110922	COMMON TOILET NEAR MEDICINE OPD	URINAL & WASH BASIN BLOCK AT MALE REST ROOM	Rajendhiran. V.,Murugan. S.,Thanuzkodi. E	block removed.		Elangchezhiyan. R. - Housekeeping	22/11/2022
1674	22110933	Labour Room	BLOCK AT WASH BASIN PIPE LINE	Rajendhiran. V.,Murugan. S.,Thanuzkodi. E	blocik removed.		Balasubramaniyam. G. - Housekeeping	22/11/2022
Comp. Dt. : 23/11/2022 Status : Completed								
1675	22110998	Male Surgery - Ward 204	TOILET BLOCKED,NEED SCAVENGER	Rajendhiran. V.,Murugan. S.,Thanuzkodi. E	Toilet block removed, work completed		Balasubramaniyam. G. - Housekeeping	24/11/2022
1676	22111018	COMMON MALE TOILET NEAR ORTHO OPD	URINAL HOSE LEAKAGING PROBLEM	Prakash. V.,Rajendran. R.,Ramkumar. R.	Connection tube changed.		Elangchezhiyan. R. - Housekeeping	26/11/2022
Comp. Dt. : 24/11/2022 Status : Completed								
1677	22111028	CT Scan	NEED 2 LABOURS FOR WOODEN BOX SHIFTING WORK	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	Wooden box shifting work completed.		Elangchezhiyan. R. - Housekeeping	25/11/2022
1678	22111057	Male Surgery - Ward 204	TOILET BLOCKED,NEED SCAVENGER	Rajendhiran. V.,Murugan. S.,Thanuzkodi. E	Block removed.		Balasubramaniyam. G. - Housekeeping	24/11/2022
Comp. Dt. : 26/11/2022 Status : Completed								
1679	22111141	COMMON MALE TOILET NEAR ORTHO OPD	URINAL BLOCK	Rajendhiran. V.,Murugan. R.,Thanuzkodi. E	Block removed.		Balasubramaniyam. G. - Housekeeping	28/11/2022
Comp. Dt. : 29/11/2022 Status : Completed								
1680	22111205	Main OT	NEED TO CHECK AND CHANGE WESTERN BASIN - DAMAGE & BROKEN AT I FLOOR MAIN OT	Abdul Azees. J.,Sankar. V.,Arunagiri. V.	New EWC and flush tank fixed.		Balasubramaniyam. G. - Housekeeping	01/12/2022
1681	22111255	COMMON TOILET NEAR MEDICINE OPD	IN FEMALE BATHROOM-NEW WATER TAP NEED TO BE FIX	Abdul Azees. J.,Sankar. V.,Rajendran. R.	New tap fixed.		Elangchezhiyan. R. - Housekeeping	05/12/2022
Comp. Dt. : 30/11/2022 Status : Completed								
1682	22111278	Male Surgery - Ward 204	FLUSH NOT WORKING AT COMMON RESTROOM	Rajendran. R.,Manikandan. S.,Sankar. V.	Flush tank rework done.		Balasubramaniyam. G. - Housekeeping	05/12/2022
Comp. Dt. : 02/12/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1683	22120071	Male Surgery - Ward 204	W.C. WATER LEAKAGE AT COMMON RESTROOM	Abdul Azees. J.,Manikandan. S.,Arunagiri. V.	Flush tank rework done.		Balasubramaniyam. G. - Housekeeping	05/12/2022
1684	22120086	Obstetrics - Ward 207	FLUSH WATER LEAKAGE - COMMON RESTROOM	Rajendran. R.,Abdul Azees. J.,Sankar. V.	Flush tank rework.		Balasubramaniyam. G. - Housekeeping	02/12/2022
1685	22120087	ICU	BLOCK IN RESTROOM	Rajendhiran. V.,Thanuzkodi. E,Murugan. S.	Block removed.		Balasubramaniyam. G. - Housekeeping	02/12/2022
1686	22120088	Main OT	BLOCK IN WASH BASIN	Murugan. S.,Thanuzkodi. E,Rajendhiran. V.	Block removed.		Balasubramaniyam. G. - Housekeeping	02/12/2022
Comp. Dt. : 05/12/2022 Status : Completed								
1687	22120175	Male Ortho - Ward 403	TOILET BLOCKED,NEED SCAVENGER	Rajendhiran. V.,Murugan. S.,Thanuzkodi. E	\Block removed.		Vengadesan. K. - Housekeeping	06/12/2022
1688	22120193	RADIOLOGY	COMMON BATHROOM BLOCK,NEED SCAVENGER	Rajendhiran. V.,Thanuzkodi. E,Murugan. S.	block removed.		Elangchezhiyan. R. - Housekeeping	06/12/2022
Comp. Dt. : 08/12/2022 Status : Completed								
1689	22120388	COMMON TOILET NEAR FREE PHARMACY	4 NO'S TAP NEED TO BE CHANGE	Prakash. V.,Ramkumar. R.,Rajendran. R.	Tap changed. (4nos.)		Ayyappan. K. - Housekeeping	12/12/2022
1690	22120390	PATIENT DINING AREA BACKSIDE OF RECEPTION	WASH BASIN SINK BLOCK	Rajendhiran. V.,Murugan. S.,Thanuzkodi. E	block removed.		Elangchezhiyan. R. - Housekeeping	09/12/2022
Comp. Dt. : 09/12/2022 Status : Completed								
1691	22120422	Reception	NEED REPAIRING WORK FOR RECEPTION MAIN GLASS DOOR STUCK	Gurunathan. V.	Work completed by complaint client.		Elangchezhiyan. R. - Housekeeping	12/12/2022
Comp. Dt. : 13/12/2022 Status : Completed								
1692	22120615	RICU	WATER LEAKAGE IN FLUSH TANK	Prakash. V.	flush tank rework done.		Elangchezhiyan. R. - Housekeeping	14/12/2022
Comp. Dt. : 16/12/2022 Status : Completed								
1693	22120792	Obstetrics - Ward 210	BLOCK IN COMMON RESTROOM	Rajendhiran. V.,Murugan. S.,Thanuzkodi. E	block removed.		Elangchezhiyan. R. - Housekeeping	19/12/2022
Comp. Dt. : 19/12/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1694	22120857	IVF ART CLINIC-INSIDE OF OG OPD(NO.68)	WASH BASIN WATER LEAKAGE IN DOCTORS ROOM	Arunagiri. V.,Prakash. N.,Rajendran. R.	Wash basin connection tube rework done.		Elangchezhiyan. R. - Housekeeping	19/12/2022
Comp. Dt. : 27/12/2022 Status : Completed								
1695	22121215	COMMON MALE TOILET NEAR BIOCHEMISTRY	TOILET BLOCKED,NEED SCAVENGER	Rajendhiran. V.,Thanuzkodi. E,Murugan. S.	Block removed.		Elangchezhiyan. R. - Housekeeping	27/12/2022
1696	22121249	COMMON TOILET NEAR OPHTAL OPD	FEMALE STAFF TOILET BLOCKED,NEED SCAVENGER	Rajendhiran. V.,Thanuzkodi. E,Murugan. S.	Block removed.		Elangchezhiyan. R. - Housekeeping	27/12/2022
1697	22121250	COMMON TOILET NEAR FREE PHARMACY	BATH MALE AND FEMALE COMMON TOILET BLOCKED,NEED SCAVENGER	Rajendhiran. V.,Thanuzkodi. E,Murugan. S.	Block removed.		Elangchezhiyan. R. - Housekeeping	27/12/2022
1698	22121251	GENERAL SURGERY OPD-55	LABOUR WASTAGES ARE GETTING DOWN THROUGH PIPELINE INTO SURGERY OPD-BACKSIDE LINE BLOCK	Rajendhiran. V.,Kathirvelu. K.,Thanuzkodi. E	BLOCK REMOVED.		Vengadesan. K. - Housekeeping	28/12/2022
Comp. Dt. : 30/12/2022 Status : Completed								
1699	22121373	COMMON MALE TOILET NEAR BIOCHEMISTRY	URINAL FITTING WORK AND TOILET BLOCKED,NEED SCAVENGER	Rajendhiran. V.,Murugan. S.,Thanuzkodi. E	Block removed.		Balasubramaniyam. G. - Housekeeping	31/12/2022
Comp. Dt. : 04/01/2023 Status : Completed								
1700	23010149	LADIES STAFF TOILET NEAR LAB	TOILET BLOCKED,NEED SCAVENGER	Sakthivel. E.	block removed.		Balasubramaniyam. G. - Housekeeping	05/01/2023
1701	23010150	COMMON TOILET NEAR FREE PHARMACY	IN MALE TOILET-URINAL PIPE DAMAGED	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	urinal pipe line connection refixed.		Balasubramaniyam. G. - Housekeeping	05/01/2023
1702	23010155	TB AND CHEST WARD-405	MALESIDE TOILET BLOCKED,NEED SCAVENGER	Rajendhiran. V.,Thanuzkodi. E,Murugan. S.	block removed.		Elangchezhiyan. R. - Housekeeping	05/01/2023
1703	23010165	Male Ortho - Ward 404	URINAL DRAINAGE PIPE LEAKAGING PROBLEM	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	Urinal drainage pipe refixing work.		Elangchezhiyan. R. - Housekeeping	05/01/2023
1704	23010166	HOSPITAL IV FLOOR	UNWANTED WOODEN PEICES NEED TO BE REMOVE FROM THERE-NEED LABOURS	Prakash. N.,Senthil Kumar. R.,Murali. K.	Unwanted wooden pieces removed.		Elangchezhiyan. R. - Housekeeping	09/01/2023
Comp. Dt. : 05/01/2023 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1705	23010232	Female Medical - Ward 306	IN PATIENT BATHROOM-FLUSH TANK BROKEN AND HANGING ,NEED TO RECTIFY IT SOON	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	Flush tank block rework done.		Vengadesan. K. - Housekeeping	06/01/2023
Comp. Dt. :		06/01/2023						
Status :		Completed						
1706	23010278	Male Medical - Ward 301	REST ROOM BLOCK	Rajendhiran. V.,Thanuzkodi. E.,Murugan. S.	Toilet block removed,work completed		Ayyappan. K. - Housekeeping	07/01/2023
Comp. Dt. :		09/01/2023						
Status :		Completed						
1707	23010333	TB AND CHEST WARD-405	IN PATIENT REST ROOM-URINE HOSE NEED TO BE REFIX	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	Urinal hose rework done.		Elangchezhiyan. R. - Housekeeping	10/01/2023
1708	23010340	COMMON MALE TOILET NEAR BIOCHEMISTRY	URINAL BLOCK,NEED SCAVENGER	Rajendhiran. V.,Murugan. S.,Thanuzkodi. E	Block removed.		Balasubramaniyam. G. - Housekeeping	10/01/2023
Comp. Dt. :		10/01/2023						
Status :		Completed						
1709	23010407	RADIOLOGY	IN COMMON TOILET-FLUSH OUT NOT WORKING	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	flush tank washer changed.		Balasubramaniyam. G. - Housekeeping	11/01/2023
Comp. Dt. :		13/01/2023						
Status :		Completed						
1710	23010564	Male Ortho - Ward 404	NEED TO REFIX URINAL HOSE	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	Urinal hose refixed.		Elangchezhiyan. R. - Housekeeping	20/01/2023
1711	23010579	GROUND FLOOR NEAR GENERAL MEDICINE OPD	MALE SIDE REST ROOM BLOCK	Rajendhiran. V.,Thanuzkodi. E.,Murugan. S.	Block removed.		Balasubramaniyam. G. - Housekeeping	14/01/2023
Comp. Dt. :		18/01/2023						
Status :		Completed						
1712	23010623	COMMON TOILET NEAR MEDICINE OPD	BLOCK IN MALE RESTROOM	Rajendhiran. V.,Thanuzkodi. E.,Murugan. S.	block removed.		Elangchezhiyan. R. - Housekeeping	20/01/2023
1713	23010624	COMMON MALE TOILET NEAR ORTHO OPD	URINAL BLOCK	Rajendhiran. V.,Thanuzkodi. E.,Murugan. S.	BLOCK REMOVED.		Elangchezhiyan. R. - Housekeeping	20/01/2023
Comp. Dt. :		20/01/2023						
Status :		Completed						
1714	23010717	COMMON TOILET NEAR MEDICINE OPD	NEED TO CHANGE TAP - DAMAGE AND WATER LEAKAGE AT FEMALE RESTROOM	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	Tap changed.		Ayyappan. K. - Housekeeping	21/01/2023

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHAL KUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 24/01/2023 Status : Completed								
1715	23010893	Dining Hall	SINK BLOCK - DRAINAGE HOSE DAMAGE - DINING HALL BACK SIDE OF RECEPTION	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	Block removed.		Balasubramaniyam. G. - Housekeeping	27/01/2023
Comp. Dt. : 25/01/2023 Status : Completed								
1716	23010920	Male Ortho Ward	NEED TO EXTEND URINAL HOSE PIPE LINE	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	Urinal line block removed and new pipeline connection work done		Elangchezhiyan. R. - Housekeeping	02/02/2023
Comp. Dt. : 30/01/2023 Status : Completed								
1717	23011060	XRay	RESTROOM BLOCK	Raja. V.,Thanuzkodi. E,Murugan. S.	Block removed.		Balasubramaniyam. G. - Housekeeping	30/01/2023
1718	23011061	XRay	NEED PIPE FITTING WORK AT BASEMENT RESTROOM	Anandharaj. M.	Clamp fixed.		Balasubramaniyam. G. - Housekeeping	01/02/2023
Comp. Dt. : 31/01/2023 Status : Completed								
1719	23011109	ENT WARD-407	BLOCK IN REST ROOM	Rajendhiran. V.,Thanuzkodi. E,Govindan. R.	Block removed.		Elangchezhiyan. R. - Housekeeping	01/02/2023
1720	23011112	COMMON TOILET NEAR MEDICINE OPD	BLOCK & NEED TO CHANDE SEAT COVER FOR MALE REST ROOM	Rajendhiran. V.,Thanuzkodi. E,Govindan. R.	block removed.		Balasubramaniyam. G. - Housekeeping	01/02/2023
Comp. Dt. : 04/02/2023 Status : Completed								
1721	23020144	COMMON TOILET NEAR MEDICINE OPD	NEED TO CHANGE SEAT COVER	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	Seat cover changed.		Balasubramaniyam. G. - Housekeeping	06/02/2023
Comp. Dt. : 06/02/2023 Status : Completed								
1722	23020156	Paediatrics - Ward 308	NEED TO CHANGE FLUSH - BROKEN	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	Flush tank rework done.		Vengadesan. K. - Housekeeping	06/02/2023
1723	23020192	Male Ortho - Ward 404	NEED TO REFIX URINAL HOSE - DAMAGE & BROKEN	Sivaraja. M.,Gopal. S.,Santhosh Kumar. M.	CONNECTION TUBE CHANGED.		Elangchezhiyan. R. - Housekeeping	07/02/2023
Comp. Dt. : 07/02/2023 Status : Completed								
1724	23020244	Dining Hall	SINK BLOCK AT RECEPTION BACKSIDE CANTEEN	Thanuzkodi. E,Murugan. S.,Rajendhiran. V.	BLOCK REMOVED.		Balasubramaniyam. G. - Housekeeping	08/02/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 08/02/2023 Status : Completed								
1725	23020296	Free Pharmacy	PLYWOOD DISPOSING WORK	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	PLYWOOD DISPOSAL WORK COMPLETED		Balasubramaniyam. G. - Housekeeping	11/02/2023
1726	23020311	Blood Bank	HEALTH FAUCET BROKEN IN STAFF SIDE REST ROOM	Azhagar. N.,Sellaveeran. M.,Udhaya Kumar. R.	HEALTH FAUCET CHANGED.		Balasubramaniyam. G. - Housekeeping	10/02/2023
Comp. Dt. : 09/02/2023 Status : Completed								
1727	23020349	Special Ward - C	WASH BASIN PIPE BROKEN	Azhagar. N.,Sellaveeran. M.,Udhaya Kumar. R.	WASH BASIN PIPE LINE CONNECTION REWORK DONE.		Elangchezhiyan. R. - Housekeeping	11/02/2023
Comp. Dt. : 10/02/2023 Status : Completed								
1728	23020370	Male Medical - Ward 303	REST ROOM TAP WATER LEAKAGE	Azhagar. N.,Udhaya Kumar. R.,Sivaraja. M.	PVC LONG BODY TAP CHANGED.		Elangchezhiyan. R. - Housekeeping	10/02/2023
1729	23020378	COMMON TOILET NEAR MEDICINE OPD	REST ROOM BLOCK	Rajendhiran. V.,Thanuzkodi. E,Murugan. S.	BLOCK REMOVED.		Balasubramaniyam. G. - Housekeeping	11/02/2023
Comp. Dt. : 11/02/2023 Status : Completed								
1730	23020446	Main OT	NEED TO REFIX WASH BASIN DRAINAGE HOSE - DAMAGE	Sivaraja. M.,Santhosh Kumar. M.,Gopal. S.	CONNECTION TUBE CHANGED.		Naresh. R - Housekeeping	13/02/2023
Comp. Dt. : 13/02/2023 Status : Completed								
1731	23020495	Female Psychiatry - Ward 406	RESTROOM BLOCK	Rajendhiran. V.,Thanuzkodi. E,Murugan. S.	BLOCK REMOVED		Elangchezhiyan. R. - Housekeeping	14/02/2023
Comp. Dt. : 14/02/2023 Status : Completed								
1732	23020531	Female Casulaty	FLUSH NOT WORKING	Santhosh Kumar. M.,Sivaraja. M.,Udhaya Kumar. R.	FLUSH TANK REWORK DONE		Ayyappan. K. - Housekeeping	15/02/2023
1733	23020559	Female Ortho - Ward 402	NEED TO REFIX WASH BASIN DRAINAGE HOSE PIPELINE - DAMAGE WATER LEAKAGE	Azhagar. N.,Sellaveeran. M.,Udhaya Kumar. R.	WASH BASIN WASTE HOSE REFIX.		Elangchezhiyan. R. - Housekeeping	17/02/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1734	23020560	Male Ortho - Ward 404	NEED TO CHECK URINAL WATER PIPELINE - WATER NOT COMING	Azhagar. N., Sellaveeran. M., Udhaya Kumar. R.	ANGLE VALVE CHANGED.		Elangchezhiyan. R. - Housekeeping	17/02/2023
Comp. Dt. : 16/02/2023 Status : Completed								
1735	23020643	Male Surgery - Ward 201	REST ROOM FLUSH TANK NOT WORKING	Azhagar. N., Sellaveeran. M., Udhaya Kumar. R.	FLUSH TANK REWORK AND NEW EWC FIXED.		Ayyappan. K. - Housekeeping	17/02/2023
Comp. Dt. : 20/02/2023 Status : Completed								
1736	23020760	COMMON TOILET NEAR MEDICINE OPD	WASH BASIN BLOCK	Rajendhiran. V., Thanuzkodi. E., Murugan. S.	BLOCK REMOVED.		Balasubramaniyam. G. - Housekeeping	21/02/2023
Comp. Dt. : 22/02/2023 Status : Completed								
1737	23020877	Female Ortho - Ward 402	REST ROOM BLOCK	Rajendhiran. V., Thanuzkodi. E., Murugan. S.	BLOCK REMOVED.		Ayyappan. K. - Housekeeping	24/02/2023
Comp. Dt. : 24/02/2023 Status : Completed								
1738	23020939	COMMON MALE TOILET NEAR ORTHO OPD	BLOCK IN COMMON RESTROOM	Rajendhiran. V., Thanuzkodi. E., Murugan. S.	BLOCK REMOVED		Balasubramaniyam. G. - Housekeeping	24/02/2023
Comp. Dt. : 25/02/2023 Status : Completed								
1739	23020978	Ophthalmology - OPD	NEED TO CHECK WATER PIPELINE AT HOD ROOM LEAKAGE	Azhagar. N., Anandharaj. M., Sellaveeran. M.	1.4" EWC BUSH CHANGED.		Balasubramaniyam. G. - Housekeeping	27/02/2023
1740	23020979	COMMON TOILET NEAR MEDICINE OPD	RESTROOM BLOCK	Rajendhiran. V., Thanuzkodi. E., Murugan. S.	BLOCK REMOVED.		Balasubramaniyam. G. - Housekeeping	27/02/2023
Comp. Dt. : 28/02/2023 Status : Completed								
1741	23021055	COMMON TOILET NEAR FREE PHARMACY	GENTS REST ROOM BLOCK	Rajendhiran. V., Murugan. S., Thanuzkodi. E.	BLOCK REMOVED.		Balasubramaniyam. G. - Housekeeping	01/03/2023
1742	23021077	Fourth Floor	NEED MAN POWER-PLYWOOD SCRAPS CLEANING WORK	Pandiaraj. V., Yuvaraj. M., Senthil Kumar. R.	PLYWOOD SCRAPS CLEANING WORK DONE.		Elangchezhiyan. R. - Housekeeping	03/03/2023
Comp. Dt. : 01/03/2023 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1743	23030016	COMMON TOILET NEAR MEDICINE OPD	URINAL BLOCK	Rajendhiran. V.,Thanuzkodi. E,Murugan. S.	URINAL BLOCK REMOVED.		Balasubramaniyam. G. - Housekeeping	02/03/2023
Comp. Dt. : 03/03/2023 Status : Completed								
1744	23030139	Male Ortho - Ward 404	RESTROOM BLOCK	Rajendhiran. V.,Thanuzkodi. E,Murugan. S.	BLOCK REMOVED.		Elangchezhiyan. R. - Housekeeping	04/03/2023
1745	23030140	Female Ophthalmology - Ward 408	NEED TO CHANGE TAP - DAMAGE WATER LEAKAGE	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	PVC TAP CHANGED		Elangchezhiyan. R. - Housekeeping	04/03/2023
Comp. Dt. : 06/03/2023 Status : Completed								
1746	23030234	Special Ward - C	CEILING WATER LEAKAGE	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	CIVIL EXECUTION COMPLAINT. NEED TO APPLY GROUT IN DIETRY DEPARTMENT AT TERRACE.		Elangchezhiyan. R. - Housekeeping	07/03/2023
Comp. Dt. : 09/03/2023 Status : Completed								
1747	23030355	COMMON TOILET NEAR MEDICINE OPD	FLUSH WATER NOT COMING AT MALE RESTROOM	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	FLUSH TANK REWORK DONE.		Balasubramaniyam. G. - Housekeeping	10/03/2023
Comp. Dt. : 11/03/2023 Status : Completed								
1748	23030468	COMMON TOILET NEAR MEDICINE OPD	WASH BASIN BLOCK IN FEMALE COMMON TOILET NEAR MEDICINE OPD	Rajendhiran. V.	BLOCK REMOVED.		Balasubramaniyam. G. - Housekeeping	13/03/2023
Comp. Dt. : 15/03/2023 Status : Completed								
1749	23030592	HOSPITAL III FLOOR	NEED TO SPRAY MUSQUITO REPELLANT IN ALL THE WARD AT 3RD FLOOR	Kannan. V.	MUSQUITO REPELLANT SPRAYED IN ALL THE WARD AT 3RD FLOOR		Vengadesan. K. - Housekeeping	25/03/2023
1750	23030595	COMMON TOILET NEAR MEDICINE OPD	BLOCK IN MALE RESTROOM	Rajendhiran. V.,Thanuzkodi. E,Murugan. S.	BLOCK REMOVED.		Balasubramaniyam. G. - Housekeeping	16/03/2023
Comp. Dt. : 16/03/2023 Status : Completed								
1751	23030667	COMMON MALE TOILET NEAR BIOCHEMISTRY	FLUSH NOT WORKING	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	FLUSH TANK REWORK DONE.		Balasubramaniyam. G. - Housekeeping	18/03/2023
Comp. Dt. : 21/03/2023								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
1752	23030846	Female surgery ward - 208	BLOCK IN RESTROOM	Rajendhiran. V.,Thanuzkodi. E,Murugan. S.	BLOCK REMOVED.		Ayyappan. K. - Housekeeping	22/03/2023
1753	23030861	Male Ortho - Ward 403	RESTOOM BLOCK	Rajendhiran. V.,Thanuzkodi. E,Murugan. S.	BLOCK REMOVED.		Vengadesan. K. - Housekeeping	22/03/2023
Comp. Dt. : 23/03/2023								
Status : Completed								
1754	23030938	TB & Chest OPD	CEILING WATER LEAKAGE IN 2 ROOMS	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	EXPANSION JOINT PROBLEM.		Elangchezhiyan. R. - Housekeeping	25/03/2023
1755	23030971	Male Medical - Ward 303	NEED MANPOWER 2 NOS FOR SHIFTING UNWANTED DOOR , FROM - WARD NO 303 BACKSIDE TO WORKSHOP	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	UNWANTED DOOR SHIFTED FROM 303 BACKSIDE TO WORKSHOP		Elangchezhiyan. R. - Housekeeping	25/03/2023
Comp. Dt. : 24/03/2023								
Status : Completed								
1756	23031005	COMMON TOILET NEAR MEDICINE OPD	WASH BASIN BLOCK IN FEMALE COMMON RESTROOM NEAR MEDICINE OPD	Rajendhiran. V.,Thanuzkodi. E,Murugan. S.	BLOCK REMOVED.		Elangchezhiyan. R. - Housekeeping	25/03/2023
Comp. Dt. : 27/03/2023								
Status : Completed								
1757	23031120	Special Ward - C	NEED TO CHANGE WASH BASIN DRAINAGE HOSE - DAMAGE - COMMON MALE RESTROOM	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	DRAINAGE HOSE CHANGED.		Elangchezhiyan. R. - Housekeeping	30/03/2023
1758	23031121	Male Ortho - Ward 404	NEED TO CHANGE URINAL DRAINAGE HOSE - DAMAGE - COMMON MALE RESTROOM	Sivaraja. M.,Santhosh Kumar. M.,Gopal. S.	WASTE HOSE CHANGED.		Elangchezhiyan. R. - Housekeeping	30/03/2023
Comp. Dt. : 28/03/2023								
Status : Completed								
1759	23031204	COMMON TOILET NEAR MEDICINE OPD	FLUSH KEY & TANK DAMAGE - NEED TO CHANGE AT FEMALE RESTROOM	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	FLUSH TANK REWORK DONE.		Balasubramaniyam. G. - Housekeeping	30/03/2023
1760	23031205	COMMON TOILET NEAR BLOOD BANK	FLUSH KEY & TANK DAMAGE - NEED TO CHANGE AT MALE RESTROOM	Anandharaj. M.,Udhaya Kumar. R.,Santhosh Kumar. M.	FLUSH TANK REWORK DONE.		Balasubramaniyam. G. - Housekeeping	30/03/2023
Comp. Dt. : 04/04/2023								
Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1761	23040109	Male Psychiatry - Ward 405	BLOCK IN RESTROOM	Rajendhiran. V.,Thanuzkodi. E,Murugan. S.	BLOCK REMOVED.		Elangchezhian. R. - Housekeeping	05/04/2023
	Comp. Dt. : 08/04/2023							
	Status : Completed							
1762	23040222	COMMON TOILET NEAR MEDICINE OPD	REST ROOM BLOCK	Rajendhiran. V.,Thanuzkodi. E,Murugan. S.	BLOCK REMOVED.		Vengadesan. K. - Housekeeping	08/04/2023
	Comp. Dt. : 10/04/2023							
	Status : Completed							
1763	23040280	BIOMEDICAL WASTAGE ROOM - BACKSIDE OF ORTHO OPD	NEED CEMENT WORK FOR WALL SIDE	Murugavel	WALL PLASTERING WORK COMPLETED		Balasubramaniyam. G. - Housekeeping	22/04/2023
	Comp. Dt. : 11/04/2023							
	Status : Completed							
1764	23040313	BIOMEDICAL WASTAGE ROOM - BACKSIDE OF ORTHO OPD	BLOCK - NEED TO CHECK WATER PIPELINE	Rajendhiran. V.,Thanuzkodi. E,Murugan. S.	BLOCK REMOVED.		Balasubramaniyam. G. - Housekeeping	13/04/2023
1765	23040345	Paediatrics - Ward 308	FLUSH TANK & KEY NOT WORKING	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	Flush tank key rework, problem solved		Vengadesan. K. - Housekeeping	20/04/2023
	Comp. Dt. : 15/04/2023							
	Status : Completed							
1766	23040455	COMMON TOILET NEAR MEDICINE OPD	BLOCK IN MALE RESTROOM	Rajendhiran. V.,Thanuzkodi. E,Murugan. S.	BLOCK REMOVED.		Balasubramaniyam. G. - Housekeeping	16/04/2023
	Comp. Dt. : 16/04/2023							
	Status : Completed							
1767	23040459	HOSPITAL III FLOOR	NEED TO REMOVE BEE NEST - BEE ARE FLYING AND BITE INSIDE THE WARD & RESTROOM	Sivaraja. M.	INFORMED TO PROJECT MANAGER. HONEY COMB TO BE DESTROYED BY PEST CONTROL		Vengadesan. K. - Housekeeping	28/04/2023
	Comp. Dt. : 02/05/2023							
	Status : Completed							
1768	23050049	BIOMEDICAL WASTAGE ROOM - BACKSIDE OF ORTHO OPD	BLOCK IN BIOMEDICAL WASTAGE ROOM - OUTSIDE	Rajendhiran. V.,Thanuzkodi. E,Murugan. S.	block removed.		Balasubramaniyam. G. - Housekeeping	03/05/2023
	Comp. Dt. : 03/05/2023							
	Status : Completed							
1769	23050102	Casualty	URINAL BLOCK	Rajendhiran. V.,Thanuzkodi. E,Murugan. S.	BLOCK REMOVED.		Elangchezhian. R. - Housekeeping	03/05/2023

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1770	23050103	Paediatrics - OPD	BLOCK IN FEMALE RESTROOM	Rajendhiran. V., Thanuzkodi. E., Murugan. S.	block removed.		Balasubramaniam. G. - Housekeeping	03/05/2023
Comp. Dt. : 06/05/2023		Status : Completed						
1771	23050256	Male Medical - Ward 303	NEED TO SPRAY MOSQUITO SPRAY AT 303 RESTROOM	Kannan. V.	MOSQUITO REPELLANT SPRAYED AT 303		Ayyappan. K. - Housekeeping	08/05/2023
Comp. Dt. : 08/05/2023		Status : Completed						
1772	23050311	OG-OPD	NEED TO RERIX DRAINAGE FILLTER AT RESTROOM	Anandharaj. M., Azhagar. N., Sellaveeran. M.	GRATING FIXED		Balasubramaniam. G. - Housekeeping	12/05/2023
1773	23050312	General Medicine - OPD	NEED TO RERIX DRAINAGE FILLTER AT RESTROOM	Anandharaj. M., Azhagar. N., Sellaveeran. M.	GRATING FIXED.		Balasubramaniam. G. - Housekeeping	11/05/2023
1774	23050313	Casualty	NEED TO RERIX DRAINAGE FILLTER AT RESTROOM	Anandharaj. M., Azhagar. N., Sellaveeran. M.	GRATING FIXED.		Balasubramaniam. G. - Housekeeping	11/05/2023
Comp. Dt. : 15/05/2023		Status : Completed						
1775	23050610	Male Surgery - Ward 203	URINAL BLOCK	Rajendhiran. V., Thanuzkodi. E., Murugan. S.	urinal block removed.		Balasubramaniam. G. - Housekeeping	16/05/2023
Comp. Dt. : 22/05/2023		Status : Completed						
1776	23050892	COMMON MALE TOILET NEAR ORTHO OPD	BLOCK IN MALE REST ROOM	Govindan. R., Sakthivel. E., Thanuzkodi. E	BLOCK REMOVED.		Vengadesan. K. - Housekeeping	23/05/2023
Comp. Dt. : 23/05/2023		Status : Completed						
1777	23050912	Male Surgery - Ward 203	URINAL BLOCK	Rajendhiran. V., Thanuzkodi. E., Murugan. S.	BLOCK REMOVED.		Ayyappan. K. - Housekeeping	24/05/2023
Comp. Dt. : 24/05/2023		Status : Completed						
1778	23050965	Obstetrics - Ward 208	BLOCK IN RESTROOM	Gnanasegaran. K.	BLOCK REMOVED.		Ayyappan. K. - Housekeeping	25/05/2023
Comp. Dt. : 26/05/2023		Status : Completed						
1779	23051047	Female Surgery - Ward 409	NEED TO REFIX WASH BASIN DRAINAGE HOSE - DAMAGE	Anandharaj. M., Azhagar. N., Sellaveeran. M.	WASH BASIN DRAINAGE HOSE		Elangchezhiyan. R. - Housekeeping	29/05/2023

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHAL KUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 27/05/2023								
Status : Completed								
1780	23051095	COMMON TOILET NEAR FREE PHARMACY	WASH BASIN BLOCK & FLUSH NOT WORKING AT FEMALE RESTROOM	Rajendhiran. V.,Thanuzkodi. E,Murugan. S.	FLUSH TANK REWORK DONE AND BLOCK REMOVED IN WASH BASIN		Ayyappan. K. - Housekeeping	29/05/2023
1781	23051102	Hospital	NEED TO REMOVE BEE NEST AT BACKSIDE OF FEMALE SURGERY 205 NEAR ARECANUT TREES	Sivaraja. M.	HONEY COMB DESTROYED.		Vengadesan. K. - Housekeeping	03/06/2023
Comp. Dt. : 29/05/2023								
Status : Completed								
1782	23051126	General Medicine - OPD	NEED TO CHANGE WASH BASIN DRAINAGE HOSE - WATER LEAKAGE - ROOM NO 17	Gopal. S.,Azhagar. N.,Anandharaj. M.	WASH BASIN REFIXED AND WASTE HOSE CHANGED		Balasubramaniyam. G. - Housekeeping	01/06/2023
1783	23051158	TB & Chest OPD	NEED TO CHECK WASH BASIN PIPE LINE - WATER NOT COMING	Anandharaj. M.,Gopal. S.,Santhosh Kumar. M.	valve opened. water coming		Balasubramaniyam. G. - Housekeeping	01/06/2023
Comp. Dt. : 31/05/2023								
Status : Completed								
1784	23051258	COMMON TOILET NEAR OPHTAL OPD	BLOCK IN FEMALE RESTROOM	Rajendhiran. V.,Thanuzkodi. E,Murugan. S.	block removed.		Vengadesan. K. - Housekeeping	31/05/2023
Comp. Dt. : 01/06/2023								
Status : Completed								
1785	23060015	Female Ortho - Ward 401	NEED MANPOWER 2 NOS FOR UNLOADING WASTE MATERIAL	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	block removed.		Elangchezhiyan. R. - Housekeeping	01/06/2023
1786	23060035	Female Ortho - Ward 401	BLOCK IN COMMON RESTROOM	Rajendhiran. V.,Thanuzkodi. E,Murugan. S.	BLOCK REMOVED.		Elangchezhiyan. R. - Housekeeping	01/06/2023
Comp. Dt. : 12/06/2023								
Status : Completed								
1787	23060416	ENT WARD-407	BLOCK IN DOCTOR'S REST ROOM	Rajendhiran. V.,Thanuzkodi. E,Murugan. S.	BLOCK REMOVED.		Elangchezhiyan. R. - Housekeeping	13/06/2023
Comp. Dt. : 14/06/2023								
Status : Completed								
1788	23060502	Male Psychiatry - Ward 405	URINAL DRAINAGE HOSE DAMAGE - LEAKAGE NEED TO CHANGE AT COMMON RESTROOM	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	WASTE HOSE REFIXED.		Elangchezhiyan. R. - Housekeeping	15/06/2023

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 16/06/2023 Status : Completed								
1789	23060597	CANTEEN - OPP TO SPECIAL CLINIC 100	SINK BLOCK	Rajendhiran. V.,Thanuzkodi. E,Murugan. S.	SINK BLOCK REMOVED.		Balasubramaniam. G. - Housekeeping	16/06/2023
Comp. Dt. : 19/06/2023 Status : Completed								
1790	23060675	Male Psychiatry - Ward 405	URINAL LEAKAGE	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	Urinal block removed.		Elangchezhiyan. R. - Housekeeping	20/06/2023
Comp. Dt. : 21/06/2023 Status : Completed								
1791	23060781	COMMON TOILET NEAR BLOOD BANK	BLOCK	Thanuzkodi. E,Murugan. S.,Gnanasegaran. K.	Block removed.		Balasubramaniam. G. - Housekeeping	22/06/2023
Comp. Dt. : 23/06/2023 Status : Completed								
1792	23060863	Male Ortho - Ward 404	NEED TO CHANGE HEATER TAP - WATER LEAKAGE	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	PVC tap changed.		Elangchezhiyan. R. - Housekeeping	24/06/2023
1793	23060865	Special Ward - C	NEED TO CHANGE WASH BASIN DRAINAGE HOSE - DAMAGE & WATER LEAKAGE	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	Waste hose refixed.		Elangchezhiyan. R. - Housekeeping	24/06/2023
1794	23060879	COMMON TOILET NEAR MEDICINE OPD	BLOCK AT MALE RESTROOM	Raja. V.,Thanuzkodi. E,Murugan. S.	Block removed.		Balasubramaniam. G. - Housekeeping	24/06/2023
Comp. Dt. : 26/06/2023 Status : Completed								
1795	23060980	Male Psychiatry - Ward 405	URINAL BLOCK	Raja. V.,Thanuzkodi. E,Gnanasegaran. K.	Block removed.		Elangchezhiyan. R. - Housekeeping	27/06/2023
Comp. Dt. : 28/06/2023 Status : Completed								
1796	23061044	Special Ward - C	BLOCK IN WASH BASIN	Thanuzkodi. E,Rajendhiran. V.,Murugan. S.	BLOCK REMOVED.		Elangchezhiyan. R. - Housekeeping	30/06/2023
1797	23061045	COMMON TOILET NEAR MEDICINE OPD	BLOCK IN MALE RESTROOM	Rajendhiran. V.,Thanuzkodi. E,Murugan. S.	block removed.		Vengadesan. K. - Housekeeping	28/06/2023
1798	23061069	SPECIAL WARD---B	NEED TO REFIX SEAT COVER FOR ROOM NO 22 & 23	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	Seat cover changed.		Elangchezhiyan. R. - Housekeeping	30/06/2023
Dept Name : ICCU - Civil - Maintenance Comp. Dt. : 16/05/2022								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
1799	22050566	Mit ladies hostel	NEED TO REMOVE BEE NEST AT GROUND FLOOR RESTROOM NEAR [STAFF SIDE]	Sivaraja. M.	Bee nest cleared.		Ammu. R. - ICCU	04/06/2022
Comp. Dt. : 23/05/2022								
Status : Completed								
1800	22050811	ICCU	WATER NOT COMING	Murugan. R.	water coming		Hemasri. M. - ICCU	23/05/2022
Comp. Dt. : 03/06/2022								
Status : Completed								
1801	22060098	ICCU	WATER NOT COMING	Prakash. V.,Arunagiri. V.,Ramkumar. R.	tap damage new tap ching work		Ammu. R. - ICCU	03/06/2022
Comp. Dt. : 11/07/2022								
Status : Completed								
1802	22070425	ICCU	NEED TO CHECK WASH BASIN TAP - WATER LEAKAGE	Prakash. V.	New tap changed.		Ammu. R. - ICCU	12/07/2022
Comp. Dt. : 15/07/2022								
Status : Completed								
1803	22070601	ICCU	NEED TO CHANGE HAND WASH SINK TAP - WATER LEAKAGE	Prakash. V.,Manikandan. S.,Rajendran. R.	New CP Elbow action tap changed, work completed		Ammu. R. - ICCU	16/07/2022
Comp. Dt. : 03/09/2022								
Status : Completed								
1804	22090139	Mit ladies hostel	NEED TO CHANGE RESTROOM TAP - WATER LEAKAGE AT GROUND FLOOR [STAFF SIDE]	Anandharaj. M.	New CP Tap changed, work completed		Ammu. R. - ICCU	16/09/2022
Comp. Dt. : 15/12/2022								
Status : Completed								
1805	22120704	Mit ladies hostel	BLOCK IN III FLOOR RESTROOM	Sakthivel. E.	block removed.		Ammu. R. - ICCU	16/12/2022
Comp. Dt. : 21/01/2023								
Status : Completed								
1806	23010783	ICCU	BLOCK IN DOCTOR'S RESTROOM	Sakthivel. E.,Rajendhiran. V.,Murugan. S.	Toilet block removed, work completed		Ammu. R. - ICCU	21/01/2023
Comp. Dt. : 02/02/2023								
Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1807	23020050*	ICCU	NEED TO CHANGE SINK DRAINAGE HOSE - WATER LEAKAGE	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	Connection tube changed. Old pillar cock changed.		Saradha. G. - ICCU	03/02/2023
Comp. Dt. : 25/02/2023 Status : Completed								
1808	23020989	ICCU	NEED TO CHANGE FILTER FOR WATER PURIFYER	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	WATER PURIFIER FILTER CHANGED.		Saradha. G. - ICCU	03/03/2023
Comp. Dt. : 02/03/2023 Status : Completed								
1809	23030055	Mit ladies hostel	NEED TO CHECK WATER PIPELINE CONNECTION - DAMAGE & BROKEN AT ENTRANCE - WATER FLOW NEED URGENT SERVI	Prakash. V.,Rajendran. R.,Ramkumar. R.	WATER PIPELILNE CONNECTION REWORK DONE.		Ammu. R. - ICCU	04/03/2023
Comp. Dt. : 21/03/2023 Status : Completed								
1810	23030869	ICCU	WATER PURIFIER BROKEN	Sellaveeran. M.,Udhaya Kumar. R.,Gopal. S.	INFORMED TO PURCHASE MANAGER AND PROJECT MANAGER.		Saradha. G. - ICCU	22/03/2023
Comp. Dt. : 23/03/2023 Status : Completed								
1811	23030949	ICCU	WATER LEAKAGE IN WATER PURIFIER	Sivaraja. M.,Gopal. S.,Santhosh Kumar. M.	WATER PURIFIER PIPELINE CONNECTION REWORK DONE.		Ammu. R. - ICCU	25/03/2023
1812	23030973	ICCU	NEED TO CHANGE RO WATER CARTRIDGE - WATER LEAKAGE	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	RO WATER WASHER (2NOS.) CHANGED.		Ammu. R. - ICCU	25/03/2023
Dept Name : ICU - Civil - Maintenance Comp. Dt. : 05/05/2022 Status : Completed								
1813	22050164	ICU	NEED TO REFIX DOCTOR'S ROOM SINK - DAMAGE & REFIX REST ROOM HANDLE STAND FOR NURSE'S RESTROOM	Prakash. V.	New Wash basin changed, water line connection given, Towel rod should be painted by workshop (inform		Latha. K. - ICU	12/05/2022
Comp. Dt. : 11/06/2022 Status : Completed								
1814	22060414	ICU	NEED TO CHANGE TAP - WATER LEAKAGE	Prakash. V.,Manikandan. S.,Rajendran. R.	CP Elbow action tap changed, problem solved		Latha. K. - ICU	13/06/2022
Comp. Dt. : 27/06/2022								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
1815	22060956	ICU	NEED TO CHANGE TAP - WATER FLOW - NEED URGENT SERVICE	Prakash. V.,Manikandan. S.,Ramkumar. R.	New elbow tap changed.		Latha. K. - ICU	27/06/2022
Comp. Dt. : 25/07/2022								
Status : Completed								
1816	22070892	ICU	WATER NOT COMING IN WASH BASIN	Prakash. V.,Rajendran. R.,Ramkumar. R.	Health faucet changed.		Regina Mary. S. - ICU	26/07/2022
Comp. Dt. : 16/09/2022								
Status : Completed								
1817	22090654	ICU	NEED TO CHECK FLUSH TANK WATER LEAKAGE	Prakash. V.,Arunagiri. V.,Sankar. V.	Flush tank fullset rework, Tap spindle need to changed		Jayabharathi. R. - ICU	21/09/2022
Comp. Dt. : 15/11/2022								
Status : Completed								
1818	22110568	ICU	IN STAFF TOILET-FLUSH TANK BROKEN	Prakash. V.	Flush tank fullset rework, work completed		Regina Mary. S. - ICU	15/11/2022
Comp. Dt. : 29/11/2022								
Status : Completed								
1819	22111248	PICU	NEED LABOURS FOR SHIFTING PURPOSE FROM WORKSHOP	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	Cot, Locker, table shifting work completed from workshop to New PICU & NICU - 2nd floor.		Uma Maheswari. A. - ICU	05/12/2022
Comp. Dt. : 30/11/2022								
Status : Completed								
1820	22111273	ICU	FLUSH TANK NOT WORKING	Abdul Azees. J.,Sankar. V.,Rajendran. R.	flush tank rework done.		Regina Mary. S. - ICU	05/12/2022
Comp. Dt. : 31/12/2022								
Status : Completed								
1821	22121401	ICU	PATIENT REST ROOM-FLUSH NOT WORKING	Anandharaj. M.,Sellaveeran. M.,Udhaya Kumar. R.	Flush tank rework done.		Regina Mary. S. - ICU	02/01/2023
Comp. Dt. : 14/01/2023								
Status : Completed								
1822	23010597	ICU	NEED TO CHECK FLUSH KEY - BROKEN AT PATIENT RESTROOM	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	Flush tank rework done.		Regina Mary. S. - ICU	20/01/2023
Comp. Dt. : 30/01/2023								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
1823	23011051	ICU	BLOCK IN PATIENT RESTROOM	Rajendhiran. V.	block lremoved.		Rajeshwari. P. - ICU	30/01/2023
Comp. Dt. : 11/03/2023								
Status : Completed								
1824	23030450	Female Surgery - Ward 206	FLUSH NOT WORKING AT DOCTOR'S REST ROOM	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	FLUSH TANK REWORK DONE		Suseela. R. - ICU	13/03/2023
Comp. Dt. : 12/04/2023								
Status : Completed								
1825	23040360	ICU	NEED TO CHANGE WASH BASIN DRAINAGE HOSE - WATER LEAKAGE	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	Waste hose changed, problem solved		Regina Mary. S. - ICU	19/04/2023
Comp. Dt. : 22/04/2023								
Status : Completed								
1826	23040695	ICU	PROBLEM IN FLUSH - NOT WORKING AT ICU STAFF RESTROOM	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	flush tank rework done.		Latha. K. - ICU	25/04/2023
Comp. Dt. : 04/05/2023								
Status : Completed								
1827	23050125	ICU	NEED TO CHECK WATER PIPELINE - LEAKAGE AT RESTROOM	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	water pipeline rework done.		Regina Mary. S. - ICU	06/05/2023
Comp. Dt. : 11/05/2023								
Status : Completed								
1828	23050433	ICU	NEED TO CHECK WATER PIPELINE - WATER LEAKAGE	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	WATER PIPELINE CONNECTION REWORK DONE		Regina Mary. S. - ICU	12/05/2023
Dept Name : Labour Ward - Civil - Maintenance								
Comp. Dt. : 10/05/2022								
Status : Completed								
1829	22050317	Labour Room	SINK BLOCK	Rajendran. R.	block removed.		Usharani. A. - Labour Ward	10/05/2022
Comp. Dt. : 01/06/2022								
Status : Completed								
1830	22060007	Labour Room	DRAINAGE LEAKAGE AT OT SIDE RESTROOM	Prakash. V.,Ramkumar. R.,Manikandan. S.	2.1/2" Pipe line connection changed, work completed		Brema. V. - Labour Ward	01/06/2022
Comp. Dt. : 07/06/2022								
Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1831	22060240	Labour Room	FLUSH KEY DAMAGE & BROKENED AT AP RESTROOM	Arunagiri. V.,Rajendran. R.,Prakash. V.	Flush tank fullset cleaned and serviced, problem solved		Sathiyavathi. S. - Labour Ward	08/06/2022
	Comp. Dt. : 09/06/2022							
	Status : Completed							
1832	22060323	Labour Room	BLOCK IN SINK	Thanuzkodi. E	block remover work		Santhiya. A. - Labour Ward	10/06/2022
	Comp. Dt. : 30/06/2022							
	Status : Completed							
1833	22061111	labour room -pow	PROBLEM IN WASH BASIN TAP - WATER LEAKAGE NEED TO CHANGE	Prakash. V.,Arunagiri. V.,Manikandan. S.	Flush tank fullset cleaned and serviced, problem solved		Priyanka. R. - Labour Ward	30/06/2022
1834	22061116	Labour Room	WATER LEAKAGE IN FLUSH PIPE LINE CONNECTION - STAFF REST ROOM	Prakash. V.,Arunagiri. V.,Manikandan. S.	Flush tank fullset cleaned and serviced, problem solved		Usharani. A. - Labour Ward	30/06/2022
	Comp. Dt. : 04/07/2022							
	Status : Completed							
1835	22070113	Labour Room	NEED TO CHECK DRAINAGE PIPE LINE - BAD SMELL	Prakash. V.,Rajendran. R.,Ramkumar. R.	Flush tank fullset cleaned and serviced, problem solved		Usharani. A. - Labour Ward	05/07/2022
	Comp. Dt. : 19/07/2022							
	Status : Completed							
1836	22070715	Labour Room	SINK BLOCK	Prakash. V.	Sink block removed, waste water line fully rework, work completed		Sathiyavathi. S. - Labour Ward	20/07/2022
	Comp. Dt. : 22/07/2022							
	Status : Completed							
1837	22070834	Labour Room	NEED TO CHANGE TAP - WATER LEAKAGE	Prakash. V.,Rajendran. R.,Ramkumar. R.	Elbow spindle changed.		Sathiyavathi. S. - Labour Ward	26/07/2022
	Comp. Dt. : 08/08/2022							
	Status : Completed							
1838	22080268	Labour Room	NEED TO CHECK ELBOW TAP - WATER LEAKAGE & SOUND PROBLEM	Ramkumar. R.,Rajendran. R.,Arunagiri. V.	CP elbow action Tap spindle changed, problem solved		Sathiyavathi. S. - Labour Ward	09/08/2022
	Comp. Dt. : 30/08/2022							
	Status : Completed							
1839	22081034	Labour Room	NEED TO CHECK WALL S/ JOINT WALL - WATER LEAKAGE - NEED URGENT SERVICE	Prakash. V.,Rajendran. R.,Ramkumar. R.	Rain water leakage.		Usharani. A. - Labour Ward	30/08/2022

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 01/09/2022 Status : Completed								
1840	22090009	Labour Room	NEED TO CHANGE WASH BASIN DRAINAGE HOSE - WATER LEAKAGE	Prakash. V.,Rajendran. R.,Ramkumar. R.	Drainage hose fixed		Aruldevi. M. - Labour Ward	03/09/2022
Comp. Dt. : 22/09/2022 Status : Completed								
1841	22090883	Labour Room	FLUSH NOT WORKING	Prakash. V.,Rajendran. R.,Ramkumar. R.	block removed.		Sathiyavathi. S. - Labour Ward	22/09/2022
Comp. Dt. : 27/09/2022 Status : Completed								
1842	22091035	Labour Room	BLOCK IN RESTROOM - NEED URGENT SERVICE	Rajendhiran. V.,Murugan. S.,Thanuzkodi. E	block removed.		Usharani. A. - Labour Ward	28/09/2022
Comp. Dt. : 20/10/2022 Status : Completed								
1843	22100664	Labour Room	WATER LEAKING FROM CEILING AT LABOR ROOM	Prakash. V.,Rajendran. R.,Ramkumar. R.	Water leakage due to washing in 2nd floor		Krishnadevi. D. - Labour Ward	22/10/2022
Comp. Dt. : 29/10/2022 Status : Completed								
1844	22100958	labour ot	STAFF RESTROOM BLOCK NEAR LABOUR OT	Rajendran. R.	Block removed.		Kirupavathy. S. - Labour Ward	31/10/2022
Comp. Dt. : 11/11/2022 Status : Completed								
1845	22110444	Labour Room	FLUSH NOT WORKING IN STAFF TOILET	Prakash. V.,Rajendran. R.,Ramkumar. R.	Flush tank rework		Usharani. A. - Labour Ward	11/11/2022
Comp. Dt. : 21/11/2022 Status : Completed								
1846	22110889	Labour Room	IN ANESTHETIC PG ROOM-FLUSH TANK LEAKAGING PROBLEM IN REST ROOM	Prakash. V.,Rajendran. R.,Ramkumar. R.	Flush tank fullset rework, work completed		Kirupavathy. S. - Labour Ward	24/11/2022
Comp. Dt. : 06/12/2022 Status : Completed								
1847	22120249	Obstetrics - Ward 208	NEED LABOURS FOR COT ARRANGEMENTS WORK	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	cot arrangement work completed.	 Dr. KAGNE. R.N DEAN SRI MANAKULA VINAYAGAR MEDICAL COLLEGE & HOSPITAL KALITHEERTHALKUPPAM, PUDUCHERRY-605107.	Kalaivani. B. - Labour Ward	09/12/2022
Comp. Dt. : 07/12/2022								

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
1848	22120288	OG OT	IN ANESTHETIC ROOM-WATER TAP CANNOT MOVE IN REST ROOM	Prakash. V.	Tap rework done.		Iyshwariya. M. - Labour Ward	12/12/2022
Comp. Dt. : 21/12/2022								
Status : Completed								
1849	22120975	Labour Room	DOCTORS REST ROOM HAND SHOWER REFIXING WORK	Prakash. V.,Ramkumar. R.,Rajendran. R.	Health faucet refixed.		Usharani. A. - Labour Ward	21/12/2022
Comp. Dt. : 13/01/2023								
Status : Completed								
1850	23010563	Labour Room	REST ROOM BLOCK	Rajendhiran. V.,Thanuzkodi. E,Murugan. S.	Block removed.		Sathiyavathi. S. - Labour Ward	14/01/2023
Comp. Dt. : 07/02/2023								
Status : Completed								
1851	23020226	Labour Room	SINK DRAINAGE WATER BLOCK	Rajendhiran. V.,Thanuzkodi. E,Murugan. S.	BLOCK REMOVED.		Sathiyavathi. S. - Labour Ward	08/02/2023
Comp. Dt. : 13/02/2023								
Status : Completed								
1852	23020455	Labour Room	BLOCK IN WASH BASIN	Rajendhiran. V.,Thanuzkodi. E,Murugan. S.	BLOCK REMOVED.		Krishnadevi. D. - Labour Ward	14/02/2023
Comp. Dt. : 18/02/2023								
Status : Completed								
1853	23020733	Labour Room	NEED TO CHANGE WASH BASIN DRAINAGE HOSE - WATER LEAKAGE	Sakthivel. E.	SCRUB BLOCK REMOVED.		Sathiyavathi. S. - Labour Ward	20/02/2023
Comp. Dt. : 14/03/2023								
Status : Completed								
1854	23030519	Labour Room	BLOCK IN WASH BASIN	Rajendhiran. V.,Thanuzkodi. E,Murugan. S.	BLOCK REMOVED.		Kanimozhi. S. - Labour Ward	15/03/2023
Comp. Dt. : 15/03/2023								
Status : Completed								
1855	23030593	Labour Room	SINK BLOCK	Rajendhiran. V.,Thanuzkodi. E,Murugan. S.	SINK BLOCK REMOVED.		Sathiyavathi. S. - Labour Ward	16/03/2023
Comp. Dt. : 18/03/2023								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
1856	23030750	Labour Room	BLOCK IN RESTROOM	Thanuzkodi. E.,Murugan. S.,Rajendhiran. V.	BLOCK REMOVED.		Kanimozhi. S. - Labour Ward	18/03/2023
Comp. Dt. : 20/03/2023								
Status : Completed								
1857	23030796	Labour Room	BLOCK IN PATIENT RESTROOM	Rajendhiran. V.,Thanuzkodi. E.,Murugan. S.	BLOCK REMOVED.		Krishnadevi. D. - Labour Ward	21/03/2023
Comp. Dt. : 17/04/2023								
Status : Completed								
1858	23040491	Labour Room	RESTROOM BLOCK - BAD SMELL - NEED TO CLEAR	Murugan. S.	Toilet block removed, work completed		Usharani. A. - Labour Ward	19/04/2023
1859	23040517	Labour Room	NEED TO CHECK & CHANGE WASH BASIN TAP & FLUSH TANK DAMAGE & BROKEN AT RESTROOM	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	Wash basin tap and flush tank rework and refixed in properly, work completed		Usharani. A. - Labour Ward	19/04/2023
Comp. Dt. : 22/04/2023								
Status : Completed								
1860	23040711	Labour Room	BLOCK IN WASH BASIN - STAFF RESTROOM	Rajendhiran. V.,Thanuzkodi. E.,Murugan. S.	BLOCK REMOVED.		Krishnadevi. D. - Labour Ward	24/04/2023
Comp. Dt. : 17/05/2023								
Status : Completed								
1861	23050692	Labour Room	BLOCK IN SINK - BAD SMELL	Sakthivel. E.	BLOCK REMOVED		Krishnadevi. D. - Labour Ward	18/05/2023
Comp. Dt. : 30/05/2023								
Status : Completed								
1862	23051175	Labour Room	NEED TO CHANGE WASH BASIN TAP - LEAKAGE	Udhaya Kumar. R.	elbow action pillar cock changed.		Krishnadevi. D. - Labour Ward	01/06/2023
Comp. Dt. : 26/06/2023								
Status : Completed								
1863	23060949	Female Medical - Ward 305	DUE TO WATER LEAKAGE FROM CEILING , ELECTRIC CABLES & SWITCH , PLUG POINTS SHOCK PROBLEM - N	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	Water leaked through the expansion joint. hence the electric shock occurs.		Lavanya. E. - Labour Ward	28/06/2023
Comp. Dt. : 27/06/2023								
Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1864	23061036	Labour Room	FLUSH WATER LEAKAGE AT DOCTOR'S ROOM	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	Flush tank rework done.		Sathiyavathi. S. - Labour Ward	30/06/2023
Dept Name : Male Medical Ward - Civil - Maintenance Comp. Dt. : 07/05/2022 Status : Completed								
1865	22050242	Male Medical - Ward 301	BLOCK IN RESTROOM	Govindan. R.,Sakthivel. E.,Thanuzkodi. E	Toilet block removed, work completed		Kanmani. R. - Male Medical Ward	07/05/2022
Comp. Dt. : 09/05/2022 Status : Completed								
1866	22050303	Male Medical - Ward 303	BLOCK IN REST ROOM	Govindan. R.	block remover		Vijayalakshmi. S. - Male Medical Ward	09/05/2022
Comp. Dt. : 14/05/2022 Status : Completed								
1867	22050510	Male Medical - Ward 301	BATHROOM BLOCK	Rajendran. R.	Block removed.		Yugapriya. M. - Male Medical Ward	17/05/2022
Comp. Dt. : 21/05/2022 Status : Completed								
1868	22050807	Male Medical - Ward 302	BLOCK IN RESTROOM	Govindan. R.	block remover work		Soniya Gandhi. A. - Male Medical Ward	23/05/2022
Comp. Dt. : 23/05/2022 Status : Completed								
1869	22050816	Male Medical - Ward 303	NEED REPAIRING WORK FOR RESTROOM CEILING - DAMANGE AND CEILING BROKENED AND FELL DOWN NEED URGENT S	Prakash. V.	Informed to workshop department.		Vijayalakshmi. S. - Male Medical Ward	25/05/2022
Comp. Dt. : 28/05/2022 Status : Completed								
1870	22051061	Male Medical - Ward 302	BLOCK IN REST ROOM	Sakthivel. E.	Block removed.		Soniya Gandhi. A. - Male Medical Ward	30/05/2022
Comp. Dt. : 05/07/2022 Status : Completed								
1871	22070153	Male Medical - Ward 302	REST ROOM BLOCK [AGAIN]	Rajendhiran. V.	Toilet block removed, work completed		Soniya Gandhi. A. - Male Medical Ward	06/07/2022
1872	22070154	Male Medical - Ward 302	NEED TO CHANGE PATIENT DRINKING WATER TAP - WATER LEAKAGE	Prakash. V.	New spindle changed.		Soniya Gandhi. A. - Male Medical Ward	07/07/2022
Comp. Dt. : 06/07/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1873	22070195	Male Medical - Ward 303	WASH BASIN BROKEN - NEED TO CHANGE AT DEMO ROOM	Prakash. V.,Arunagiri. V.,Gopal. S.	New wash basin fixed.		Vijayalakshmi. S. - Male Medical Ward	12/07/2022
	Comp. Dt. : 02/08/2022							
	Status : Completed							
1874	22080090	Male Medical - Ward 301	NEED TO CHECK RESTROOM TAP - WATER LEAKAGE	Prakash. V.	Spindle changed.		Soniya Gandhi. A. - Male Medical Ward	03/08/2022
	Comp. Dt. : 03/08/2022							
	Status : Completed							
1875	22080130	Male Medical - Ward 301	BLOCK IN RESTROOMS [BOTH SIDE]	Rajendhiran. V.,Murugan. S.,Thanuzkodi. E	Toilet block removed, work completed		Soniya Gandhi. A. - Male Medical Ward	04/08/2022
	Comp. Dt. : 04/08/2022							
	Status : Completed							
1876	22080165	Male Medical - Ward 301	BATHROOM BLOCK NEED SCAVENGER	Rajendhiran. V.,Murugan. S.,Thanuzkodi. E	block removed		Vijayalakshmi. S. - Male Medical Ward	06/08/2022
	Comp. Dt. : 05/08/2022							
	Status : Completed							
1877	22080190	Male Medical - Ward 301	BLOCK IN RESTROOM	Rajendhiran. V.,Murugan. S.,Thanuzkodi. E	Block removed.		Soniya Gandhi. A. - Male Medical Ward	06/08/2022
	Comp. Dt. : 09/08/2022							
	Status : Completed							
1878	22080326	Male Medical - Ward 302	BLOCK IN RESTROOM	Thanuzkodi. E,Murugan. S.,Govindan. R.	Toilet block removed, work completed		Soniya Gandhi. A. - Male Medical Ward	09/08/2022
	Comp. Dt. : 22/08/2022							
	Status : Completed							
1879	22080730	Male Medical - Ward 301	NEED TO REFIX WASH BASIN - UN FIX	Prakash. V.,Rajendran. R.,Ramkumar. R.	Wash basin refixed.		Soniya Gandhi. A. - Male Medical Ward	24/08/2022
	Comp. Dt. : 05/09/2022							
	Status : Completed							
1880	22090175	Male Medical - Ward 301	NEED TO REFIX SINK - DAMAGE & UNFIX	Prakash. V.,Rajendran. R.,Ramkumar. R.	Sink stand rework done.		Soniya Gandhi. A. - Male Medical Ward	08/09/2022
1881	22090187	Male Medical - Ward 302	FLUSH KEY NOT WORKING - WATER NOT COMING IN DOCTOR'S RESTROOM	Prakash. V.,Rajendran. R.,Ramkumar. R.	Flush tank rework.		Soniya Gandhi. A. - Male Medical Ward	06/09/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 14/09/2022								
Status : Completed								
1882	22090552	Male Medical - Ward 301	NEED TO CHANGE WASH BASIN DRAINAGE HOSE - WATER LEAKAGE	Prakash. V.,Rajendran. R.,Ramkumar. R.	Waste hose rework, work completed		Vijayalakshmi. S. - Male Medical Ward	17/09/2022
Comp. Dt. : 16/09/2022								
Status : Completed								
1883	22090622	TB AND CHEST WARD-405	BLOCK IN SINK	Sakthivel. E.	block remover work		Karthikeyan. I. - Male Medical Ward	16/09/2022
Comp. Dt. : 19/09/2022								
Status : Completed								
1884	22090742	Male Medical Ward	RESTROOM BLOCK IN 301 &302 BOTH SIDES	Rajendhiran. V.,Murugan. S.,Thanuzkodi. E	Block removed.		Geedhanjali. I - Male Medical Ward	21/09/2022
Comp. Dt. : 21/09/2022								
Status : Completed								
1885	22090848	Clinical Pathology	NEED TO CHECK SINK AGAIN WATER LEAKAGE & SINK UNFIX	Prakash. V.,Rajendran. R.,Ramkumar. R.	Health faucet fixed.		Vinothinee. B - Male Medical Ward	22/09/2022
Comp. Dt. : 22/09/2022								
Status : Completed								
1886	22090872	Male Medical - Ward 301	NEED TO CHANGE WASH BASIN DRAINAGE HOSE - DAMAGE & WATER LEAKAGE	Prakash. V.,Rajendran. R.,Ramkumar. R.	New Wash basin drainage hose changed. Block removed.		Soniya Gandhi. A. - Male Medical Ward	27/09/2022
Comp. Dt. : 26/10/2022								
Status : Completed								
1887	22100832	Male Medical - Ward 301	MMW 301 AND 302---REST ROOM BLOCK(1318)	Rajendhiran. V.,Thanuzkodi. E,Murugan. S.	Restroom block removed.		Soniya Gandhi. A. - Male Medical Ward	27/10/2022
Comp. Dt. : 23/11/2022								
Status : Completed								
1888	22110968	Male Medical - Ward 301	WASH BASIN BLOCK - WARD INSIDE	Rajendhiran. V.,Murugan. S.,Thanuzkodi. E	Wash basin block removed, work completed		Soniya Gandhi. A. - Male Medical Ward	24/11/2022
Comp. Dt. : 01/12/2022								
Status : Completed								
1889	22120002	Male Medical - Ward 301	NEED TO CHANGE PATIENT REST ROOM WASH BASIN TAP - DAMAGE & WATER LEAKAGE	Rajendran. R.,Manikandan. S.,Abdul Azees. J.	No way to change new tap... Only push tap should be used.		Soniya Gandhi. A. - Male Medical Ward	05/12/2022

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 16/12/2022 Status : Completed								
1890	22120755	Male Medical - Ward 303	IN DOCTOR'S ROOM-TOILET BLOCK	Rajendhiran. V.,Thanuzkodi. E,Murugan. S.	block removed.		Vijayalakshmi. S. - Male Medical Ward	19/12/2022
Comp. Dt. : 21/12/2022 Status : Completed								
1891	22120988	Male Medical - Ward 301	WATER NOT COMING IN PATIENTS REST ROOM	Prakash. V.	Valve closed for plumbing work. Problem rectified.		Geedhanjali. I - Male Medical Ward	23/12/2022
Comp. Dt. : 20/01/2023 Status : Completed								
1892	23010741	Male Medical - Ward 302	NEED TO CHANGE TAP - DAMAGE WATER LEAKAGE AT DOCTOR'S REST ROOM	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	New Elbow action tap changed, problem solved		Geedhanjali. I - Male Medical Ward	21/01/2023
Comp. Dt. : 23/01/2023 Status : Completed								
1893	23010805	Male Medical - Ward 301	NEED TO CHECK WASH BASIN WATER LEAKAGE AT PATIENT RESTROOM	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	It is impossible to fix tap in RO water.		Soniya Gandhi. A. - Male Medical Ward	24/01/2023
Comp. Dt. : 24/01/2023 Status : Completed								
1894	23010848	Male Medical - Ward 302	BLOCK IN REST ROOM	Rajendhiran. V.,Murugan. S.,Thanuzkodi. E	Block removed.		Deepa. S. - Male Medical Ward	24/01/2023
Comp. Dt. : 01/02/2023 Status : Completed								
1895	23020016	Male Medical Ward	BLOCK IN PATIENT RESTROOM BOTH 301 & 302	Rajendhiran. V.,Thanuzkodi. E,Murugan. S.	Block removed.		Karthikeyan. I. - Male Medical Ward	01/02/2023
Comp. Dt. : 17/02/2023 Status : Completed								
1896	23020667	Male Medical - Ward 301	BLOCK IN RESTROOM	Rajendhiran. V.,Thanuzkodi. E,Murugan. S.	BLOCK REMOVED.		Soniya Gandhi. A. - Male Medical Ward	18/02/2023
1897	23020701	Male Medical - Ward 301	BLOCK IN RESTROOM	Rajendhiran. V.,Thanuzkodi. E,Murugan. S.	BLOCK REMOVED.		Geedhanjali. I - Male Medical Ward	18/02/2023
Comp. Dt. : 03/03/2023 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1898	23030116	Male Medical - Ward 301	NEED TO CHANGE RESTROOM TAP - DAMAGE & BROKEN - WATER LEAKAGE	Anandharaj. M.,Azhagar. N.,Santhosh Kumar. M.	Tap changed		Geedhanjali. I - Male Medical Ward	04/03/2023
Comp. Dt. : 06/03/2023 Status : Completed								
1899	23030246	Male Medical - Ward 301	BLOCK IN WASH BASIN [PATIENT RESTROOM]	Rajendhiran. V.,Thirisangu. S.,Murugan. S.	BLOCK REMOVED.		Soniya Gandhi. A. - Male Medical Ward	07/03/2023
Comp. Dt. : 20/03/2023 Status : Completed								
1900	23030791	ASSOCIATIVE PROFESSOR QUARTERS	WATER HEATER PIPELINE FAULT - QUARTERS NO 13	Prakash. V.,Rajendran. R.,Ramkumar. R.	WATER HEATER PIPELINE CONNECTION LAID		Vijayalakshmi. S. - Male Medical Ward	24/03/2023
Comp. Dt. : 29/03/2023 Status : Completed								
1901	23031228	Male Medical - Ward 302	BLOCK IN RESTROOM	Rajendhiran. V.,Thanuzkodi. E.,Murugan. S.	BLOCK REMOVED.		Geedhanjali. I - Male Medical Ward	30/03/2023
Comp. Dt. : 04/04/2023 Status : Completed								
1902	23040086	Male Medical - Ward 302	BLOCK IN RESTROOM	Rajendhiran. V.,Thanuzkodi. E.,Murugan. S.	BLOCK REMOVED.		Kanmani. R. - Male Medical Ward	05/04/2023
Comp. Dt. : 06/04/2023 Status : Completed								
1903	23040177	Special Ward - C	BLOCK IN RESTROOM ROOM NO 409	Rajendran. R.,Thanuzkodi. E.,Murugan. S.	BLOCK REMOVED.		Nanthini. R. - Male Medical Ward	08/04/2023
1904	23040212	Male Medical - Ward 302	DUE TO BEE COMING INTO BACK SIDE OF WARD AFFECT OF PATIENT. NEED TO REMOVE HONEY BEE HIVE -	Sivaraja. M.	WORK COMPLETED.		Soniya Gandhi. A. - Male Medical Ward	13/04/2023
Comp. Dt. : 15/04/2023 Status : Completed								
1905	23040435	Male Medical - Ward 302	NEED TO CHANGE TAP - BROKEN - WESTERN TOILET TAP	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	New PVC Tap changed, problem solved		Soniya Gandhi. A. - Male Medical Ward	19/04/2023
Comp. Dt. : 03/05/2023 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1906	23050087	Male Medical - Ward 303	NEED TO CHANGE WASH BASIN - BROKEN AT DEMO ROOM	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	New wash basin changed, water line connection given, work completed		Vijayalakshmi. S. - Male Medical Ward	09/05/2023
Dept Name : Male Ortho Ward - Civil - Maintenance Comp. Dt. : 13/05/2022 Status : Completed								
1907	22050469	Male Ortho - Ward 404	WATER PIPE LEAKAGING PROBLEM IN PATIENTS BATHROOM...	Prakash. V.	water pipe line rework.		Rajasree. R. - Male Ortho Ward	19/05/2022
Comp. Dt. : 11/06/2022 Status : Completed								
1908	22060429	Male Ortho - Ward 404	BLOCK IN PATIENT REST ROOM	Rajendran. R.	Block removed.		Rajasree. R. - Male Ortho Ward	13/06/2022
Comp. Dt. : 17/06/2022 Status : Completed								
1909	22060656	Male Ortho Ward	PIPE LINE BROKEN & DAMAGE - WATER FLOW AT PATIENT RESTROOM - WARD NO 403 & 404	Prakash. V.,Rajendran. R.,Manikandan. S.	New EWC changed with new flush tank. New pvc ankle valve changed.		Rajasree. R. - Male Ortho Ward	23/06/2022
Comp. Dt. : 19/07/2022 Status : Completed								
1910	22070712	Female Ortho - Ward 401	RESTROOM BLOCK	Rajendhiran. V.,Govindan. R.,Murugan. S.	Toilet block removed,work completed		Anbuselvi. P. - Female Ortho Ward	20/07/2022
Comp. Dt. : 02/08/2022 Status : Completed								
1911	22080095	Male Ortho Ward	NEED TO CHANGE REST ROOM TAP - WATER LEAKAGE AT WARD NO 403 & 404	Prakash. V.	Spindle changed.		Rajasree. R. - Male Ortho Ward	03/08/2022
Comp. Dt. : 17/08/2022 Status : Completed								
1912	22080497	Male Ortho - Ward 403	DRINGING WATER LEAKAGING PROBLEM ON PATIENT'S BED SIDE	Prakash. V.,Arunagiri. V.,Rajendran. R.	Tap rework done.		Rajasree. R. - Male Ortho Ward	18/08/2022
Comp. Dt. : 20/08/2022 Status : Completed								
1913	22080654	Male Ortho - Ward 403	NEED TO CHANGE TAP - WATER LEAKAGE AT DRINKING WATER TAP	Prakash. V.,Arunagiri. V.,Rajendran. R.	Tap rework done.		Manjula. P. - Male Ortho Ward	23/08/2022
Comp. Dt. : 26/08/2022								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
1914	22080884	Male Ortho Ward	FLUSH NOT WORKING [BOTH SIDES]	Prakash. V.,Rajendran. R.,Ramkumar. R.	flush tank rework		Maheswari. J. - Male Ortho Ward	30/08/2022
1915	22080885	Male Ortho Ward	NEED TO SPRAY " INSECT SPRAY " FOR BOTH SIDE REST ROOMS	Kannan. V.	work completed.		Maheswari. J. - Male Ortho Ward	30/08/2022
Comp. Dt. : 13/09/2022								
Status : Completed								
1916	22090489	Male Ortho - Ward 403	NEED TO CHANGE TAP - WATER LEAKAGE IN RESTROOM	Prakash. V.,Rajendran. R.,Ramkumar. R.	Tap spindle changed, work completed		Jenit Jerlin. D. - Male Ortho Ward	17/09/2022
Comp. Dt. : 14/09/2022								
Status : Completed								
1917	22090563	Male Ortho - Ward 404	NEED TO CHECK SHOWER PIPELINE CONNECTION - WATER LEAKAGE	Prakash. V.,Rajendran. R.,Ramkumar. R.	Pipe line fully rework, work completed		Jenit Jerlin. D. - Male Ortho Ward	17/09/2022
Comp. Dt. : 15/09/2022								
Status : Completed								
1918	22090584	Male Ortho - Ward 403	BATHROOM BLOCK	Thanuzkodi. E	block removed		Manjula. P. - Male Ortho Ward	16/09/2022
Comp. Dt. : 30/09/2022								
Status : Completed								
1919	22091222	Male Ortho Ward	RESTROOM BLOCK - BOTH 403 & 404	Rajendhiran. V.,Murugan. S.,Thanuzkodi. E	Block removed.		Rajasree. R. - Male Ortho Ward	01/10/2022
Comp. Dt. : 18/10/2022								
Status : Completed								
1920	22100610	Male Ortho - Ward 403	DIET WALL TILES BROKEN	Prakash. V.,Rajendran. R.,Ramkumar. R.	Workshop complaint.		Rajasree. R. - Male Ortho Ward	19/10/2022
Comp. Dt. : 31/10/2022								
Status : Completed								
1921	22101013	Male Ortho - Ward 403	REST ROOM BLOCK	Rajendhiran. V.,Murugan. S.,Thanuzkodi. E	Block removed.		Rajasree. R. - Male Ortho Ward	31/10/2022
1922	22101014	Male Ortho - Ward 403	DR'S ROOM PEST PROBLEM	Kannan. V.	Block removed.		Rajasree. R. - Male Ortho Ward	03/11/2022
Comp. Dt. : 02/11/2022								
Status : Completed								

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1923	22110022	Male Ortho - Ward 404	WATER TAP OVERFLOWING IN REST ROOM	Ramkumar. R.,Arunagiri. V.,Manikandan. S.	Restroom block removed.		Gayathri. S. - Male Ortho Ward	04/11/2022
Comp. Dt. : 14/11/2022 Status : Completed								
1924	22110501	Male Ortho - Ward 404	NEED 4 NO'S MANPOWER FOR NURSES CABIN FIXING WORK	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	Nurses cabin shifting work completed		Rajasree. R. - Male Ortho Ward	15/11/2022
Comp. Dt. : 17/11/2022 Status : Completed								
1925	22110717	Male Surgery - Ward 204	TOILET BLOCKED,NEED SCAVENGER	Rajendhiran. V.,Thanuzkodi. E.,Murugan. S.	block removed		Vanitha. P. - Male Ortho Ward	18/11/2022
Comp. Dt. : 18/11/2022 Status : Completed								
1926	22110769	Male Ortho Ward	NEED LABOURS 4 NOS FOR SHIFTING WORK [DAMAGE NURSE'S CABIN] - TO WORKSHOP	Pandiaraj. V.,Yuvaraj. M.,Prakash. N.	Nurses cabin shifting work completed		Rajasree. R. - Male Ortho Ward	18/11/2022
1927	22110770	Male Ortho - Ward 404	NEED TO CHANGE ELBOW TAP FOR DOCTOR'S HAND WASH SINK	Prakash. V.,Rajendran. R.,Ramkumar. R.	Elbow action tap changed.		Rajasree. R. - Male Ortho Ward	05/12/2022
Comp. Dt. : 25/11/2022 Status : Completed								
1928	22111079	Male Ortho - Ward 403	WATER NOT COMING IN PATIENT REST ROOM	Prakash. V.,Rajendran. R.,Ramkumar. R.	Tap rework done.		Manjula. P. - Male Ortho Ward	01/12/2022
Comp. Dt. : 09/12/2022 Status : Completed								
1929	22120432	Female Surgery - Ward 205	NEED TO CHECK HEATER & HEATER PIPELINE - [PLUMBING PROBLEM]	Prakash. V.,Ramkumar. R.,Rajendran. R.	Heater pipe line connection rework done.		Vanitha. P. - Male Ortho Ward	17/12/2022
Comp. Dt. : 13/12/2022 Status : Completed								
1930	22120573	Male Ortho Ward	NEED TO CHANGE TAP - WATER LEAKAGE AT PATIENT RESTROOM WARD NO 403 & 404	Prakash. V.,Rajendran. R.,Ramkumar. R.	Tap changed.		Rajasree. R. - Male Ortho Ward	15/12/2022
Comp. Dt. : 11/01/2023 Status : Completed								
1931	23010455	Male Ortho - Ward 404	IN PATIENT BATHROOM-FLUSH NOT WORKING	Anandharaj. M.,Azahar. N.,Sellaveeran. M.	flush tank rework done. toilet line block removed.		Rajasree. R. - Male Ortho Ward	13/01/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 21/01/2023 Status : Completed								
1932	23010774	Male Ortho - Ward 404	WASH BASIN BLOCK AT TREATMENT ROOM	Rajendhiran. V.,Murugan. S.,Sakthivel. E.	Wash basin block removed, work completed		Gayathri. S. - Male Ortho Ward	21/01/2023
Comp. Dt. : 10/02/2023 Status : Completed								
1933	23020376	Male Ortho - Ward 403	WATER NOT COMING IN REST ROOM	Azhagar. N.,Udhaya Kumar. R.,Santhosh Kumar. M.	WATER COMING. VALVE OPENED		Manjula. P. - Male Ortho Ward	11/02/2023
Comp. Dt. : 15/02/2023 Status : Completed								
1934	23020602	Male Ortho - Ward 403	WATER NOT COMING IN RESTROOM	Azhagar. N.,Sellaveeran. M.,Udhaya Kumar. R.	URINAL PIPE REFIXED AND TAP BLOCK REMOVED		Manjula. P. - Male Ortho Ward	17/02/2023
Comp. Dt. : 06/03/2023 Status : Completed								
1935	23030197	Male Ortho Ward	PATIENT RESTROOM BLOCK AT 403 & 404 BOTH SIDES	Rajendhiran. V.,Thanuzkodi. E.,Murugan. S.	BLOCK REMOVED.		Rajasree. R. - Male Ortho Ward	07/03/2023
Comp. Dt. : 21/03/2023 Status : Completed								
1936	23030881	Male Ortho - Ward 403	WATER BLOCK IN PATIENT REST ROOM	Rajendhiran. V.,Thanuzkodi. E.,Murugan. S.	BLOCK REMOVED.		Maheswari. J. - Male Ortho Ward	22/03/2023
Comp. Dt. : 28/03/2023 Status : Completed								
1937	23031172	Male Ortho - Ward 403	RESTROOM BLOCK -	Rajendhiran. V.,Thanuzkodi. E.,Murugan. S.	BLOCK REMOVED.		Manikandan. V. - Male Ortho Ward	29/03/2023
Comp. Dt. : 30/05/2023 Status : Completed								
1938	23051194	Male Surgery - Ward 203	NEED MANPOWER 2 NOS FOR COT ARRANGEMENT WORK	Pandiaraj. V.,Yuvaraj. M.,Thulasi. V.	COT ARRANGEMENT WORK DONE.		Vanitha. P. - Male Ortho Ward	31/05/2023
Comp. Dt. : 03/06/2023 Status : Completed								
1939	23060097	Male Surgery - Ward 203	NEED TO CHANGE DRINKING WATER TAP - DAMAGE	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	NEW TAP CHANGED.		Vanitha. P. - Male Ortho Ward	05/06/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 20/06/2023 Status : Completed								
1940	23060715	Male Ortho - Ward 403	NEED TO SPRAY " INSECT SPRAY" FOR DOCTOR'S RESTROOM - INSECTS PROBLEM	Rajendhiran. V.	Insecticide sprayed.		Maheswari. J. - Male Ortho Ward	22/06/2023
1941	23060716	Male Ortho - Ward 404	FLUSH NOT WORKING AT PATIENT RESTROOM	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	Flush tank rework done		Maheswari. J. - Male Ortho Ward	22/06/2023
Comp. Dt. : 30/06/2023 Status : Completed								
1942	23061112	Male Ortho - Ward 404	NEED TO CHECK HEATER WATER PIPELINE - WATER STUCK	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	Tap changed.		Sandhiya. L. - Male Ortho Ward	03/07/2023
Dept Name : Male Surgery - Civil - Maintenance Comp. Dt. : 18/05/2022 Status : Completed								
1943	22050647	Female Surgery - Ward 206	NEED TO CHANGEWASHBASIN TAP - DAMAGE - WATER LEAKAGE	Prakash. N.,Manikandan. S.,Rajendran. R.	CP Elbow action tap changed, problem solved		Priyanka. V. - Female Surgery	18/05/2022
Comp. Dt. : 28/05/2022 Status : Completed								
1944	22051057	Female Surgery - Ward 206	SINK PIPELINE DAMAGE - WATER LEAKAGE IN PATIENT RESTROOM	Prakash. V.,Rajendran. R.,Ramkumar. R.	Toilet waste hose rework.		Vaidegi. S. - Female Surgery	30/05/2022
Comp. Dt. : 13/06/2022 Status : Completed								
1945	22060472	Male Surgery - Ward 201	BLOCK IN RESTROOM	Rajendran. R.	Block removed.		Girija. S. - Male Surgery	14/06/2022
Comp. Dt. : 27/06/2022 Status : Completed								
1946	22060974	Female Surgery - Ward 205	NEED TO CHANGE FLUSH KEY [DAMAGE & BROKENED]	Prakash. V.,Ramkumar. R.,Rajendran. R.	Flush key changed, flush tank fullset rework and serviced, problem solved		Subashini. D. - Gynac Ward	28/06/2022
Comp. Dt. : 01/07/2022 Status : Completed								
1947	22070019	Male Surgery - Ward 201	NEED TO PROVIDE A NEW WASH BASIN CONNECTION FOR DOCTOR'S SIDE	Prakash. V.,Rajendran. R.,Ramkumar. R.	WFM - expand join		Kanimozhi. N - Male Surgery	02/07/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 11/07/2022 Status : Completed								
1948	22070412	Male Surgery - Ward 201	BLOCK IN PATIENT RESTROOM	Rajendhiran. V.,Thanuzkodi. E.,Murugan. S.	Block removed		Kanimozhi. N - Male Surgery	12/07/2022
Comp. Dt. : 18/07/2022 Status : Completed								
1949	22070642	Male Surgery - Ward 204	RESTROOM BLOCK	Rajendhiran. V.,Murugan. S.,Thanuzkodi. E	Block removed.		Vaidegi. S. - Female Surgery	19/07/2022
Comp. Dt. : 26/07/2022 Status : Completed								
1950	22070977	Male Surgery - Ward 203	CEILING WALL LEAKAGE - NEED URGENT SERVICE	Prakash. V.,Rajendran. R.,Ramkumar. R.	Expansion joint problem. Water leakage due to washing in 3rd floor.		Sasikala. A. - Male Surgery	29/07/2022
Comp. Dt. : 30/07/2022 Status : Completed								
1951	22071103	Female Surgery - Ward 205	NEED TO CHECK PATIENT REST ROOM TAP - DAMAGE & WATER LEAKAGE	Prakash. V.,Arunagiri. V.,Rajendran. R.	Tap rework done		Sarmila. M. - Female Surgery	01/08/2022
Comp. Dt. : 09/08/2022 Status : Completed								
1952	22080318	Male Surgery - Ward 202	BLOCK IN REST ROOM	Thanuzkodi. E	Toilet block removed, work completed		Mounica. B. - Male Surgery	09/08/2022
1953	22080319	Male Surgery - Ward 201	BLOCK IN PATIENT REST ROOM	Thanuzkodi. E	Toilet block removed, work completed		Sugumari. M. - Male Surgery	09/08/2022
Comp. Dt. : 27/08/2022 Status : Completed								
1954	22080944	Male Surgery - Ward 201	WASH BASIN BLOCK	Govindan. R.	Wash basin block removed, work completed		Kanimozhi. N - Male Surgery	30/08/2022
Comp. Dt. : 08/09/2022 Status : Completed								
1955	22090317	Male Surgery - Ward 201	NEED TO CHANGE DRAINAGE HOSE FOR RESTROOM SINK - DAMAGE & WATER LEAKAGE	Prakash. V.,Rajendran. R.,Ramkumar. R.	CP connection tube changed, work completed		Sarmila. M. - Female Surgery	09/09/2022
Comp. Dt. : 26/09/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1956	22091023	Male Surgery - Ward 203	NEED TO CHECK CEILING - WATER LEAKAGE	Prakash. V.,Rajendran. R.,Ramkumar. R.	Expansion joint leakage due to washing given at 3rd floor C wing.		Mounica. B. - Male Surgery	27/09/2022
	Comp. Dt. : 13/10/2022 Status : Completed							
1957	22100406	Obstetrics - Ward 207	RESTROOM BLOCK	Rajendhiran. V.,Thanuzkodi. E.,Murugan. S.	Block removed		Sivasankari. T. - Male Surgery	13/10/2022
	Comp. Dt. : 15/10/2022 Status : Completed							
1958	22100500	Male Surgery - Ward 202	BLOCK IN PATIENT RESTROOM	Rajendhiran. V.,Murugan. S.,Thanuzkodi. E	Block removed.		Ananthi. S. - Male Surgery	17/10/2022
	Comp. Dt. : 17/10/2022 Status : Completed							
1959	22100523	Male Surgery - Ward 202	RESTROOM BLOCK	Rajendhiran. V.	Block removed.		Malathy. S - Male Surgery	18/10/2022
	Comp. Dt. : 29/10/2022 Status : Completed							
1960	22100965	Male Surgery - Ward 201	REST ROOM BLOCK	Rajendhiran. V.,Murugan. S.,Thanuzkodi. E	Block removed.		Girija. S. - Male Surgery	31/10/2022
	Comp. Dt. : 31/10/2022 Status : Completed							
1961	22101003	Male Surgery - Ward 201	MALE REST ROOM BLOCK	Rajendhiran. V.,Thanuzkodi. E.,Murugan. S.	Block removed.		Girija. S. - Male Surgery	02/11/2022
	Comp. Dt. : 02/11/2022 Status : Completed							
1962	22110015	Male Surgery - Ward 201	TOILET BLOCKED,NEED SCAVENGER	Rajendhiran. V.,Thanuzkodi. E.,Murugan. S.	Block removed.		Archana. G. - Male Surgery	03/11/2022
	Comp. Dt. : 03/11/2022 Status : Completed							
1963	22110105	Male Surgery - Ward 201	WATER HEATER PLUMBING LINE FAULT	Prakash. V.,Ramkumar. R.,Rajendran. R.	Connection tube changed.		Ananthi. S. - Male Surgery	05/11/2022
	Comp. Dt. : 11/11/2022 Status : Completed							


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1964	22110458	Male Surgery - Ward 202	FLUSH TANK BROKEN	Prakash. V.,Rajendran. R.,Ramkumar. R.	angle valve washer fixed.		Ananthi. S. - Male Surgery	18/11/2022
1965	22110460	Male Surgery - Ward 202	WATER HEATER PLUMBING FAULT	Prakash. V.,Rajendran. R.,Ramkumar. R.	Electrical department complaint.		Ananthi. S. - Male Surgery	11/11/2022
Comp. Dt. : 21/11/2022								
Status : Completed								
1966	22110871	Male Surgery - Ward 202	BLOCK IN PATIENT RESTROOM	Rajendhiran. V.,Murugan. S.,Thanuzkodi. E	Block removed.		Ananthi. S. - Male Surgery	22/11/2022
Comp. Dt. : 22/11/2022								
Status : Completed								
1967	22110907	Male Surgery - Ward 201	BLOCK IN PATIENT WASH BASIN	Rajendhiran. V.,Murugan. S.,Thanuzkodi. E	blocks removed.		Sugumari. M. - Male Surgery	22/11/2022
1968	22110908	Male Surgery - Ward 202	BLOCK - REST ROOM	Rajendhiran. V.,Murugan. S.,Thanuzkodi. E	block removed.		Sugumari. M. - Male Surgery	22/11/2022
Comp. Dt. : 23/11/2022								
Status : Completed								
1969	22111003	Male Surgery - Ward 202	WESTERN TOILET BASIN BROKEN	Prakash. V.,Rajendran. R.,Ramkumar. R.	New EWC and flush tank fixed.		Girija. S. - Male Surgery	01/12/2022
Comp. Dt. : 25/11/2022								
Status : Completed								
1970	22111077	Male Surgery - Ward 203	NEED LABOURS FOR COT ARRANGEMENTS WORK	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	COT arrangement work completed.		Ezhilarasi. E. - Male Surgery	26/11/2022
Comp. Dt. : 12/12/2022								
Status : Completed								
1971	22120550	Male Surgery - Ward 202	RAIN WATER LEAKAGING FROM WALL	Sakthivel. E.	Expansion joint problem.		Malathy. S - Male Surgery	14/12/2022
Comp. Dt. : 24/12/2022								
Status : Completed								
1972	22121102	Male Surgery - Ward 201	REST ROOM BLOCK	Rajendhiran. V.,Murugan. S.,Thanuzkodi. E	Block removed		Sarmila. M. - Female Surgery	24/12/2022
Comp. Dt. : 26/12/2022								
Status : Completed								
1973	22121155	Male Surgery - Ward 201	REST ROOM SINK BLOCK	Rajendhiran. V.	Block removed.		Sarmila. M. - Female Surgery	27/12/2022

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 13/01/2023 Status : Completed								
1974	23010561	Male Surgery - Ward 201	REST ROOM BLOCK	Rajendhiran. V.,Thanuzkodi. E.,Murugan. S.	Block removed.		Malathy. S - Male Surgery	14/01/2023
Comp. Dt. : 30/01/2023 Status : Completed								
1975	23011054	Male Surgery - Ward 201	SINK BLOCK AT PATIENT RESTROOM	Rajendhiran. V.	block removed.		Kanimozhi. N - Male Surgery	30/01/2023
Comp. Dt. : 02/02/2023 Status : Completed								
1976	23020041	Male Surgery - Ward 204	NEED TO CHECK TUBELIGHT SET - DAMAGED BY HONEY NEST	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	Honey comb destroyed.		Ezhilarasi. E. - Male Surgery	03/02/2023
Comp. Dt. : 28/02/2023 Status : Completed								
1977	23021071	Male Surgery - Ward 201	WASHBASIN WATER COMING PROBLEM	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	WATER LEAKAGE OCCURS IN ADDITIONAL. SO. WASH BASIN PIPE LINE VALVE CLOSED.		Malathy. S - Male Surgery	01/03/2023
Comp. Dt. : 03/03/2023 Status : Completed								
1978	23030144	Male Surgery - Ward 201	BLOCK IN RESTROOM	Rajendhiran. V.,Thanuzkodi. E.,Murugan. S.	BLOCK REMOVED.		Malathy. S - Male Surgery	04/03/2023
Comp. Dt. : 07/03/2023 Status : Completed								
1979	23030272	Male Surgery - Ward 202	BLOCK IN SINK	Rajendhiran. V.,Murugan. S.,Thanuzkodi. E	BLOCK REMOVED.		Sasikala. A. - Male Surgery	09/03/2023
Comp. Dt. : 17/03/2023 Status : Completed								
1980	23030700	Male Surgery - Ward 201	BLOCK IN PATIENT RESTROOM	Rajendhiran. V.,Thanuzkodi. E.,Murugan. S.	BLOCK REMOVED.		Sarmila. M. - Female Surgery	18/03/2023
Comp. Dt. : 04/04/2023 Status : Completed								
1981	23040096	Male Surgery - Ward 201	BLOCK IN RESTROOM	Rajendhiran. V.,Thanuzkodi. E.,Murugan. S.	BLOCK REMOVED.		Sasikala. A. - Male Surgery	05/04/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 16/05/2023 Status : Completed								
1982	23050624	Male Surgery - Ward 202	BLOCK IN WASH BASIN	Rajendhiran. V.,Thanuzkodi. E,Murugan. S.	block removed.		Kanimozhi. N - Male Surgery	16/05/2023
Comp. Dt. : 26/05/2023 Status : Completed								
1983	23051042	Female Surgery - Ward 205	BLOCK IN PATIENT RESTROOM	Thanuzkodi. E	BLOCK REMOVED.		Raveena. K. - Male Surgery	27/05/2023
Comp. Dt. : 29/05/2023 Status : Completed								
1984	23051119	Male Surgery - Ward 201	BLOCK IN RESTROOM SINK	Rajendhiran. V.,Thanuzkodi. E,Murugan. S.	BLOCK REMOVED.		Malathy. S - Male Surgery	29/05/2023
Comp. Dt. : 06/06/2023 Status : Completed								
1985	23060174	Male Surgery - Ward 201	BLOCK IN SINK	Rajendhiran. V.,Thanuzkodi. E,Murugan. S.	BLOCK REMOVED.		Sivasankari. T. - Male Surgery	06/06/2023
Comp. Dt. : 12/06/2023 Status : Completed								
1986	23060429	OG-OPD	NEED TO CHANGE SINK DRAINAGE HOSE - WATER LEAKAGE AT BIOPSY ROOM	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	WASTE HOSE CHANGED.		Mahalakshmi. L. - Male Surgery	14/06/2023
Dept Name : Marketing Team - Civil - Maintenance Comp. Dt. : 01/07/2022 Status : Completed								
1987	22070015	SPECIAL WARD---B	NEED TO CHANGE TAP - WATER LEAKAGE - ROOM NO B4-5-6	Prakash. V.,Rajendran. R.,Manikandan. S.	Flush tnak rework and serviced, problem solved		Prithivi. G. - Marketing Team	04/07/2022
Comp. Dt. : 08/07/2022 Status : Completed								
1988	22070305	SPECIAL WARD---B	NEED TO CHANGE WASHBASIN TAP - WATER LEAKAGE AT ROOM NO B7-B8	Prakash. V.,Rajendran. R.,Ramkumar. R.	CP Tap, Wall mixer tap, flush tank changed, work completed		Prithivi. G. - Marketing Team	13/07/2022
Comp. Dt. : 15/07/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1989	22070575	SPECIAL WARD---B	NEED TO CHECK RESTROOM TAP - WATER LEAKGE - ROOM NO B7- B8 - B 9	Prakash. V.,Rajendran. R.,Manikandan. S.	CP Tap rework and serviced, leakage arrested, problem solved		Prithivi. G. - Marketing Team	16/07/2022
		Comp. Dt. : 18/07/2022 Status : Completed						
1990	22070646	Special Ward - A	BLOCK IN WASH BASIN - ROOM NO 6	Rajendhiran. V.,Thanuzkodi. E,Murugan. S.	Wash basin block removed.		Prithivi. G. - Marketing Team	19/07/2022
		Comp. Dt. : 19/07/2022 Status : Completed						
1991	22070693	Special Ward - A	NEED TO CHANGE WASH BASIN TAP - WATER LEAKAGE AT ROOM NO 2	Prakash. V.,Rajendran. R.,Ramkumar. R.	WFM - CP Tap (Jaquar)		Dhanalakshmi. D. - Marketing Team	20/07/2022
		Comp. Dt. : 27/07/2022 Status : Completed						
1992	22070995	Special Ward - A	NEED TO CHANGE FLUSH TANK - BROKEN AND FALLED DOWN - ROOM NO 9	Prakash. V.,Rajendran. R.,Ramkumar. R.	Flush tank fullset rework and refixed, work completed		Dhanalakshmi. D. - Marketing Team	01/08/2022
		Comp. Dt. : 01/08/2022 Status : Completed						
1993	22080022	SPECIAL WARD---B	WASH BASIN DRAINAGE HOSE DAMAGE WATER LEAKAGE AT ROOM NO B1	Prakash. V.	Waste hose changed.		Shameena Begum. A. - Marketing Team	03/08/2022
		Comp. Dt. : 08/09/2022 Status : Completed						
1994	22090313	Special Ward - A	NEED TO REFIX SEAT COVER - DAMAGE & BROKEN AT ROOM NO 6	Prakash. V.,Rajendran. R.,Ramkumar. R.	EWC removed and refixed.		Vijayalakshmi. V. - Marketing Team	08/09/2022
		Comp. Dt. : 19/09/2022 Status : Completed						
1995	22090715	SPECIAL WARD---B	NEED TO REFIX WESTERN BASIN FOR B7-B8 - DAMAGE & UNFIX	Prakash. V.,Rajendran. R.,Ramkumar. R.	Western basin packing work done. refixed.		Gokulraj. K. - Marketing Team	24/09/2022
		Comp. Dt. : 19/10/2022 Status : Completed						
1996	22100622	SPECIAL WARD - A1	FLUSH TANK PROBLEM IN ROOM NO. 9	Rajendran. R.,Ramkumar. R.,Arunagiri. V.	Flush tank rework done.		Bhuvaneshwari. M. - Marketing Team	22/10/2022
		Comp. Dt. : 05/11/2022						


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
1997	22110161	CANTEEN - OPP TO SPECIAL CLINIC 100	WATER NOT COMING	Prakash. V.,Rajendran. R.,Ramkumar. R.	Tap rework and serviced, problem solved on that day		Prithivi. G. - Marketing Team	08/11/2022
Comp. Dt. : 19/12/2022								
Status : Completed								
1998	22120863	IVF ART CLINIC-INSIDE OF OG OPD(NO.68)	PATIENT COMMON RESTROOM HAND SHOWER LEAKAGE	Arunagiri. V.,Prakash. N.,Raja. V.	New health faucet changed.		Sathiya. M. - Marketing Team	19/12/2022
Comp. Dt. : 20/01/2023								
Status : Completed								
1999	23010738	COMMON TOILET NEAR FREE PHARMACY	FLASH TANK BROKED - WATER FLOW - NEED URGENT SERVICE AT COMMON FEMALE TOILET NEAR FREE PHARMACY	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	flush tank rework and tap changed.		Ramya. C. - Marketing Team	21/01/2023
Comp. Dt. : 11/02/2023								
Status : Completed								
2000	23020444	Special Ward - A	NEED TO CHANGE REST ROOM TAP - WATER LEAKAGE - ROOM NO 8	Sellaveeran. M.,Udhaya Kumar. R.,Gopal. S.	WALL MIXTURE GUR PSPINDLE CHANGED.		Vijayalakshmi. V. - Marketing Team	13/02/2023
Comp. Dt. : 02/03/2023								
Status : Completed								
2001	23030102	Special Ward - C	BLOCK IN RESTROOM - NEED URGENT SERVICE	Rajendhiran. V.,Thanuzkodi. E.,Murugan. S.	BLOCK REMOVED.		Vijayalakshmi. V. - Marketing Team	03/03/2023
Comp. Dt. : 03/03/2023								
Status : Completed								
2002	23030130	Special Ward - C	HEATER PIPELINE - PROBLEM - FEMALE SIDE	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	HEATER PIPELINE CONNECTION REWORK DONE		Vijayalakshmi. V. - Marketing Team	04/03/2023
Dept Name : Medical Records - Civil - Maintenance								
Comp. Dt. : 16/05/2022								
Status : Completed								
2003	22050520	Paediatrics - OPD	DRINKING WATER NOT COMING	Manikandan. S.	RO plant back wash work done. Drinking water is coming.		Pushparani. P - Ward	16/05/2022
Comp. Dt. : 09/12/2022								
Status : Completed								
2004	22120413	Obstetrics - Ward 208	REST ROOM BLOCK	Rajendhiran. V.,Murugan. S.,Thanuzkodi. E	block removed.		Veena. M. - Medical Records	10/12/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 06/04/2023 Status : Completed								
2005	23040191	Obstetrics - Ward 208	BLOCK IN RESTROOM	Rajendhiran. V.,Thanuzkodi. E.,Murugan. S.	BLOCK REMOVED.		Jerina. M. - Medical Records	08/04/2023
Comp. Dt. : 08/06/2023 Status : Completed								
2006	23060289	Obstetrics - Ward 208	PATIENT DRINKING WATER NOT COMING	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	AIR LOCK REMOVED.		Jerina. M. - Medical Records	08/06/2023
Dept Name : MICROBIOLOGY - Civil - Maintenance Comp. Dt. : 12/05/2022 Status : Completed								
2007	22050411	microbiology lab	ELIZA MACHINE SHIFTING WORK(COLLEGE LAB TO HOSPITAL LAB)--NEED LABOURS	Pandiaraj. V.,Yuvaraj. M.,Thulasi. V.	Machine shifting work completed		Karthik. S. - MICROBIOLOGY	14/05/2022
Comp. Dt. : 13/05/2022 Status : Completed								
2008	22050452	microbiology lab	WATER CONNECTION CUTTING WORK	Prakash. V.,Rajendran. R.,Arunagiri. V.	dummy fixing work		Karthik. S. - MICROBIOLOGY	13/05/2022
Comp. Dt. : 12/08/2022 Status : Completed								
2009	22080443	MICROBIOLOGY	NEED PIPE CITTING WORK	Anandharaj. M.,Azhagar. N.,Santhosh Kumar. M.	6"" PIPE LINE WORK DONE		Karthik. S. - MICROBIOLOGY	30/08/2022
Comp. Dt. : 25/08/2022 Status : Completed								
2010	22080823	MICROBIOLOGY	NEED MANPOWER 4 NOS	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	Mirror shifting work completed		Karthik. S. - MICROBIOLOGY	05/09/2022
Comp. Dt. : 01/09/2022 Status : Completed								
2011	22090038	MICROBIOLOGY IN COLLEGE	NEED PLUMBER HELP	Santhosh Kumar. M.	Work completed		Gopal. R. - MICROBIOLOGY	22/09/2022
Comp. Dt. : 23/09/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2012	22090920	MICROBIOLOGY	WATER NOT COMING - NEED URGENT SERVICE	Prakash. V.,Rajendran. R.,Ramkumar. R.	Air lock cleared.		Arunachalam. G. - MICROBIOLOGY	23/09/2022
2013	22090954	MICROBIOLOGY	WATER NOT COMING IN TAP	Ramkumar. R.,Rajendran. R.,Arunagiri. V.	Pipeline block removed.		Karthik. S. - MICROBIOLOGY	26/09/2022
Comp. Dt. : 12/10/2022 Status : Completed								
2014	22100309	microbiology opd lab	SINK BLOCK	Sakthivel. E.	BLOCK REMOVED.		Vinothini. V. - MICROBIOLOGY	13/10/2022
Comp. Dt. : 31/10/2022 Status : Completed								
2015	22100994	microbiology opd lab	(1006) -WSAHBASIN WATER LEAKAGE PROBLEM	Rajendran. R.,Prakash. V.,Ramkumar. R.	Spindle changed.		Vinothini. V. - MICROBIOLOGY	02/11/2022
Comp. Dt. : 05/12/2022 Status : Completed								
2016	22120182	microbiology opd lab	NEED MANPOWER 4 MEMBERS FOR BERO SHIFTING WORK FROM WORKSHOP	Pandiaraj. V.,Yuvaraj. M.,Thulasi. V.	Bero shifting work completed.		Karthik. S. - MICROBIOLOGY	09/12/2022
Comp. Dt. : 15/12/2022 Status : Completed								
2017	22120713	Work Shop	NEED MANPOWER 4 NOS FOR BERO SHIFTING WORK FROM SORKSHOP TO MICRO BIOLOGY	Pandiaraj. V.,Yuvaraj. M.,Murali. K.	Bero shifting work completed		Karthik. S. - MICROBIOLOGY	19/12/2022
Comp. Dt. : 18/02/2023 Status : Completed								
2018	23020714	MICROBIOLOGY	SINK BLOCK	Rajendhiran. V.,Thanuzkodi. E.,Murugan. S.	BLOCK REMOVED.		Vinothini. V. - MICROBIOLOGY	18/02/2023
Comp. Dt. : 21/02/2023 Status : Completed								
2019	23020788	MICROBIOLOGY	BLOCK IN SINK	Thanuzkodi. E.,Rajendhiran. V.,Murugan. S.	BLOCK REMOVED.		Suvedha. C. - MICROBIOLOGY	21/02/2023
Comp. Dt. : 17/03/2023 Status : Completed								
2020	23030681	MICROBIOLOGY	NEED MANPOWER 4 NOS FOR MACHINE SHIFTING WORK FROM MEDICAL COLLEGE TO HOSPITAL	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	MACHINE SHIFTING WORK COMPLETED.		Karthik. S. - MICROBIOLOGY	17/03/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 11/05/2023 Status : Completed								
2021	23050451	MICROBIOLOGY IN COLLEGE	NEED PLUMBER	Prakash. V.,Rajendran. R.,Ramkumar. R.	flush tank washer changed.		Gopal. R. - MICROBIOLOGY	13/05/2023
Comp. Dt. : 16/06/2023 Status : Completed								
2022	23060602	microbiology opd lab	TWO BOXS SHIFTING WORK (MICRO LAB TO COLLEGE LAB)	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	Box shifted from Hospital microbiology lab to College lab.		Karthik. S. - MICROBIOLOGY	24/06/2023
Comp. Dt. : 30/06/2023 Status : Completed								
2023	23061114	MICROBIOLOGY	WATER NOT COMING	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	POWER PROBLEM.		Aruljothi. S. - MICROBIOLOGY	01/07/2023
Dept Name : MS Office - Civil - Maintenance Comp. Dt. : 22/06/2022 Status : Completed								
2024	22060812	COMMERCIAL BLOCK	NEED TO CHANGE TAP - WATER LEAKAGE IN RESTROOM TAP	Prakash. V.,Ramkumar. R.,Abdul Azees. J.	Tap rework done		Sundarrajan. R. - MS Office	23/06/2022
Comp. Dt. : 12/07/2022 Status : Completed								
2025	22070462	SCAN - GROUND FLOOR - BLOOD BANK OPP	NEED LABOURS 3 NOS FOR SHIFTING 3 SEATER STEEL CHAIR FOR REPAIRING WORK FROM GROUND FLOOR SCAN TO	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	Chair arrangement work done		Sundarrajan. R. - MS Office	14/07/2022
Comp. Dt. : 25/07/2022 Status : Completed								
2026	22070922	Male Medical - Ward 304	NEED TO CLEAR GROWNUP UNWANTED TREE INSIDE WARD COMING THROUGH WINDOW - NEED CUTTING AND CLEANING	Prakash. V.,Rajendran. R.,Ramkumar. R.	Tree cut work done		Sundarrajan. R. - MS Office	27/07/2022
Comp. Dt. : 27/08/2022 Status : Completed								
2027	22080949	COMMON MALE TOILET NEAR ORTHO OPD	TAP DAMAGE - WATER LEAKAGE - NEED T CHANGE TAP	Prakash. V.,Rajendran. R.,Ramkumar. R.	pvc tap changed.		Sundarrajan. R. - MS	30/08/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 07/10/2022								
Status : Completed								
2028	22100129	Orthopaedics - OPD	EXPANSION JOINT CRACK AT CEILING WALL - NEED URGENT SERVICE	Prakash. V.,Rajendran. R.,Ramkumar. R.	Washing given at labour room.		Sundarrajan. R. - MS Office	08/10/2022
Comp. Dt. : 11/10/2022								
Status : Completed								
2029	22100293	Paediatrics - OPD	"E" WING BLCOK PAEDIATRICS OPD OUTSIDE BUILDING GROUND FLOOR " DRAINAGE PIPE BROKEN"	Rajendhiran. V.	Block removed		Sundarrajan. R. - MS Office	12/10/2022
Comp. Dt. : 02/11/2022								
Status : Completed								
2030	22110014	COMMON TOILET NEAR FREE PHARMACY	IN MALE SIDE REST ROOM-URINAL HEAD TAP NEED TO BE REFIX	Ramkumar. R.,Arunagiri. V.,Manikandan. S.	One pvc tap and two angle valve changed. Connection tube changed.		Sundarrajan. R. - MS Office	05/11/2022
Comp. Dt. : 02/12/2022								
Status : Completed								
2031	22120069	CHILDREN'S PARK	DRAINAGE PIPE LINE LEAKAGE	Rajendran. R.,Manikandan. S.,Arunagiri. V.	Need scaffolding work.		Sundarrajan. R. - MS Office	05/12/2022
Comp. Dt. : 07/12/2022								
Status : Completed								
2032	22120311	COMMON TOILET NEAR FREE PHARMACY	IN MALE TOILET-WATER TAP LEAKAGING PROBLEM	Prakash. V.	Tap rework done.		Sundarrajan. R. - MS Office	12/12/2022
Comp. Dt. : 11/02/2023								
Status : Completed								
2033	23020426	SKILL LAB - MEDICAL COLLEGE	NEED TO FIX TOWEL STAND	Prakash. V.,Rajendran. R.,Ramkumar. R.	New Towel stand fixed, work completed		Elumalai. M. - MS Office	17/02/2023
Comp. Dt. : 21/03/2023								
Status : Completed								
2034	23030849	Main Gate	NEED MANPOWER 4 NOS FOR SHIFTING " CMH SCHEME DISPLAY BOARD " FROM MAINGATE TO WORKSHOP	Pandiaraj. V.,Prakash. N.,Yuvaraj. M.	SIFTING WORK COMPLETED		Sundarrajan. R. - MS Office	25/03/2023
Comp. Dt. : 29/03/2023								
Status : Completed								

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2035	23031249	MS Office	NEED TO CHECK WATER PIPELINE - WATER COMING SLOW IN RESTROOM	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	ALL TAP SERVICED.		Hemavathi. P. - MS Office	30/03/2023
Comp. Dt. : 02/05/2023 Status : Completed								
2036	23050019	MS Office	NEED TO REFIT WASH BASIN - DAMAGE UNFIX AND FELL DOWN	Sivaraja. M.,Santhosh Kumar. M.,Gopal. S.	WASH BASIN REFIXED WITH FISHER BOLT		Hemavathi. P. - MS Office	03/05/2023
Comp. Dt. : 15/05/2023 Status : Completed								
2037	23050559	Dining Hall	NEED TO CHANGE WASH BASIN DRAINAGE HOSE - LEAKAGE	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	WASTE HOSE REWORK DONE AND BLOCK REMOVED.		Sundarrajan. R. - MS Office	16/05/2023
Dept Name : Nephrology - Civil - Maintenance Comp. Dt. : 06/05/2022 Status : Completed								
2038	22050213	DIALYSIS NEW UNIT IN 1ST FLOOR	BLOCK IN SINK	Prakash. V.	Sink block removed, work completed		Sangeetha. K. - Nephrology	07/05/2022
Comp. Dt. : 23/05/2022 Status : Completed								
2039	22050845	DIALYSIS NEW UNIT IN 1ST FLOOR	NEED DUMMY WATER	Prakash. V.,Ramkumar. R.,Manikandan. S.	WFM, Repeated complaint		Kamal. B. - Nephrology	25/05/2022
Comp. Dt. : 23/06/2022 Status : Completed								
2040	22060847	DIALYSIS IN 2ND FLOOR	NEED TO CHECK DRAINAGE PIPE LINE - LEAKAGE	Prakash. V.,Ramkumar. R.,Rajendran. R.	Wash basin sink waste hose changed, problem solved		Suganya. B. - Nephrology	28/06/2022
Comp. Dt. : 24/06/2022 Status : Completed								
2041	22060900	Casualty	NEED A NEW AERO WATER PIPE LINE CONNECTION NEED TO PROVIDE EMERGENCY DIALYSIS AT CASUALTY	Arunagiri. V.,Prakash. V.,Rajendran. R.	New 3/4" UPVC pipe line water line connection given in RO water line, work completed		Aathimoolam. R. - Nephrology	20/07/2022
Comp. Dt. : 04/07/2022 Status : Completed								
2042	22070107	DIALYSIS IN 2ND FLOOR	AURO WATER TAP DAMAGE NEED TO CHANGE	Prakash. V.	1.1/2" pipe line changed.		ivakumar. S. - Nephrology	12/07/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 09/07/2022 Status : Completed								
2043	22070380	DIALYSIS NEW UNIT IN 1ST FLOOR	DRAINAGE PIPE LINE LEAKAGE IN UNIT - NEED URGENT SERVICE	Prakash. V.,Arunagiri. V.,Gopal. S.	1.1/4" new pipe line changed		Aathimoolam. R. - Nephrology	12/07/2022
Comp. Dt. : 16/07/2022 Status : Completed								
2044	22070626	DIALYSIS NEW UNIT IN 1ST FLOOR	NEED TO CHANGE TAP - WATER LEAKAGE AT BY CORP ROOM	Prakash. V.,Rajendran. R.,Ramkumar. R.	New tap changed.		Kamal. B. - Nephrology	19/07/2022
Comp. Dt. : 19/07/2022 Status : Completed								
2045	22070699	DIALYSIS NEW UNIT IN 1ST FLOOR	NEED TO CHANGE ACID MOTOR PIPE LINE CONNECTION	Prakash. V.,Manikandan. S.,Arunagiri. V.	New Connection tube 2Nos changed, problem solved		Gopinath. P. - Nephrology	20/07/2022
Comp. Dt. : 12/08/2022 Status : Completed								
2046	22080437	DIALYSIS NEW UNIT IN 1ST FLOOR	RAW WATER NOT COMING	Prakash. V.,Arunagiri. V.,Ramkumar. R.	Valve closed in terrace after finishing work, valve opened, problem solved on that day		Sumathi. N. - Nephrology	17/08/2022
Comp. Dt. : 06/09/2022 Status : Completed								
2047	22090246	DIALYSIS IN 2ND FLOOR	BLOCK IN SINK	Rajendhiran. V.,Murugan. S.,Thanuzkodi. E	Block removed. Elbow action tap rework		Suriya. A. - Nephrology	06/09/2022
Comp. Dt. : 12/09/2022 Status : Completed								
2048	22090446	DIALYSIS NEW UNIT IN 1ST FLOOR	PROBLEM IN ACID MACHINE	Prakash. V.,Arunagiri. V.,Rajendran. R.	Machine removed.		Aathimoolam. R. - Nephrology	13/09/2022
2049	22090447	DIALYSIS NEW UNIT IN 1ST FLOOR	NEED TO REFIX PIPELINE CONNECTION - REMOVING	Prakash. V.,Rajendran. R.,Ramkumar. R.	Angle valve pillar cock changed.		Gnanasekaran. S. - Nephrology	21/09/2022
Comp. Dt. : 19/09/2022 Status : Completed								
2050	22090748	DIALYSIS NEW UNIT IN 1ST FLOOR	NEED TO CHECK DIALYSIS BICARB TAP - LEAKAGE	Prakash. V.,Rajendran. R.,Ramkumar. R.	elbow action pillar cork		Aathimoolam. R. - Nephrology	20/09/2022
Comp. Dt. : 23/09/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2051	22090944	DIALYSIS IN 2ND FLOOR	NEED TO CHANGE RESTROOM TAP - WATER LEAKAGE	Rajendran. R., Ramkumar. R., Abdul Azees. J.	Ankle valve removed. Dummy fixed.		Sivakumar. S. - Nephrology	24/09/2022
	Comp. Dt. : 20/10/2022 Status : Completed							
2052	22100701	DIALYSIS NEW UNIT IN 1ST FLOOR	TRAINAGE BLOCKED IN PATIENT REST ROOM	Rajendhiran. V., Thanuzkodi. E., Murugan. S.	BLOCK REMOVED.		Aathimoolam. R. - Nephrology	21/10/2022
	Comp. Dt. : 28/10/2022 Status : Completed							
2053	22100922	DIALYSIS IN 2ND FLOOR	RO MOTOR LEAKAGING PROBLEM	Ramkumar. R., Rajendran. R., Arunagiri. V.	Technician complaint.		Aathimoolam. R. - Nephrology	15/11/2022
	Comp. Dt. : 03/11/2022 Status : Completed							
2054	22110076	DIALYSIS NEW UNIT IN 1ST FLOOR	PATIENT TOILET BLOCKED, NEED SCAVENGER	Rajendhiran. V., Murugan. S., Thanuzkodi. E	Block removed.		Aathimoolam. R. - Nephrology	03/11/2022
	Comp. Dt. : 24/11/2022 Status : Completed							
2055	22111046	DIALYSIS IN 2ND FLOOR	RO MOTOR SOUND PROBLEM	Prakash. V., Rajendran. R., Ramkumar. R.	Need to service the motor. Technician complaint.		Karthik. A. - Nephrology	05/12/2022
	Comp. Dt. : 28/11/2022 Status : Completed							
2056	22111188	DIALYSIS IN 2ND FLOOR	WATER POURING SLOWLY IN WTARE TAP	Prakash. V., Rajendran. R., Ramkumar. R.	water line Block removed		Aathimoolam. R. - Nephrology	01/12/2022
	Comp. Dt. : 29/11/2022 Status : Completed							
2057	22111217	DIALYSIS IN 2ND FLOOR	NEED TO CHECK DRAINAGE PIPE LINE BAD SMELL	Abdul Azees. J., Sankar. V., Manikandan. S.	Block removed.		Suganya. B. - Nephrology	01/12/2022
	Comp. Dt. : 10/12/2022 Status : Completed							
2058	22120471	DIALYSIS NEW UNIT IN 1ST FLOOR	RAW WATER NOT COMING	Prakash. V., Rajendran. R., Sankar. V.	Water tank filled. Work completed		Kamal. B. - Nephrology	10/12/2022
2059	22120473	DIALYSIS IN 2ND FLOOR	RAW WATER NOT COMING - NEED URGENT SERVICE	Prakash. V., Rajendran. R., Ramkumar. R.	Tank filled. Problem rectified.		Neelavathi. T. - Nephrology	12/12/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 14/12/2022								
Status : Completed								
2060	22120631	DIALYSIS IN 2ND FLOOR	NEED TO CHANGE TAP - WATER LEAKAGE AT POSSITIVE WASHING AREA	Prakash. V.,Rajendran. R.,Ramkumar. R.	angle valve spindle changed.		Suganya. D. - Nephrology	15/12/2022
2061	22120632	DIALYSIS IN 2ND FLOOR	WATER COMING SLOW AT HAND WASH TAP NEED TO CHECK	Prakash. V.,Rajendran. R.,Ramkumar. R.	Angle valve spindle changed.		Suganya. D. - Nephrology	15/12/2022
Comp. Dt. : 16/12/2022								
Status : Completed								
2062	22120781	DIALYSIS IN 2ND FLOOR	NEED TO CHANGE TAP FOR WASHING AREA - WATER FLOW - NEED URGENT SERVICE	Prakash. V.,Rajendran. R.,Ramkumar. R.	New PVC Tap changed, work completed		Priyadarshini. A. - Nephrology	19/12/2022
Comp. Dt. : 28/12/2022								
Status : Completed								
2063	22121282	DIALYSIS IN 2ND FLOOR	IN REUSE ROOM-DRAINAGE SMELL PROBLEM,NEED TO CHECK WHETHER DRAINAGE BLOCKED	Rajendhiran. V.,Murugan. S.,Thanuzkodi. E	block removed		Suganya. B. - Nephrology	28/12/2022
Comp. Dt. : 11/01/2023								
Status : Completed								
2064	23010433	DIALYSIS IN 2ND FLOOR	MOTOR NOT WORKING	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	Electrical complaint.		Suganya. B. - Nephrology	20/01/2023
Comp. Dt. : 19/01/2023								
Status : Completed								
2065	23010647	DIALYSIS NEW UNIT IN 1ST FLOOR	REST ROOM BLOCK	Rajendhiran. V.,Thanuzkodi. E,Murugan. S.	Block removed.		Kamal. B. - Nephrology	19/01/2023
Comp. Dt. : 10/02/2023								
Status : Completed								
2066	23020379	Dialysis	1ST AND 2ND FLOOR RO BOOSTER MOTORS WATER LEAKAGE PROBLEM	Udhaya Kumar. R.,Azhagar. N.,Santhosh Kumar. M.	MOTOR DISMANTLEDAND REWORK DONE. REASSEMBLED AND REFIXED AGAIN.		Aathimoolam. R. - Nephrology	27/02/2023
Comp. Dt. : 16/03/2023								
Status : Completed								
2067	23030645	DIALYSIS NEW UNIT IN 1ST FLOOR	ACID MOTOR LEAKAGE	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	MOTOR DISMANTLED.		Aathimoolam. R. - Nephrology	18/03/2023

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHAKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 12/04/2023								
Status : Completed								
2068	23040365	DIALYSIS IN 2ND FLOOR	NEED TO REMOVE [REPAIR] R O RAW MOTOR & NEED TO FIX NEW RAW MOTOR - NEED URGENT SERVICE	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	Service 1HP motor fixed, water line connection given, work completed		Suganya. B. - Nephrology	19/04/2023
Comp. Dt. : 17/04/2023								
Status : Completed								
2069	23040538	DIALYSIS NEW UNIT IN 1ST FLOOR	W C BROKEN NEED TO CHANGE	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	EWC refixed, JK white cement pointing work done		Kamal. B. - Nephrology	19/04/2023
Comp. Dt. : 22/04/2023								
Status : Completed								
2070	23040687	DIALYSIS NEW UNIT IN 1ST FLOOR	NEED TO CHANGE WASH BASIN TAP - DAMAGE WATER LEAKAGE	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	pvc tap changed.		Kamal. B. - Nephrology	25/04/2023
Comp. Dt. : 26/04/2023								
Status : Completed								
2071	23040868	DIALYSIS NEW UNIT IN 1ST FLOOR	DRAINAGE BLOCK IN R O ROOM	Rajendhiran. V.,Thanuzkodi. E.,Murugan. S.	BLOCK REMOVED.		Kamal. B. - Nephrology	27/04/2023
Comp. Dt. : 02/05/2023								
Status : Completed								
2072	23050059	DIALYSIS IN 2ND FLOOR	NEED TO CHECK SIDE WALL - BROKEN	Murugavel	SWITCH BOARD PLASTERING WORK COMPLETED		Suganya. B. - Nephrology	05/05/2023
Comp. Dt. : 12/05/2023								
Status : Completed								
2073	23050488	DIALYSIS NEW UNIT IN 1ST FLOOR	NEED TO CHANGE SINK TAP - WATER LEAKAGE	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	SINK TAP CHANGED.		Aathimoolam. R. - Nephrology	13/05/2023
Comp. Dt. : 17/05/2023								
Status : Completed								
2074	23050719	DIALYSIS IN 2ND FLOOR	WATER NOT COMING - SLOW -NEED TI CHECK WASH BAI SN	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	WATER TANK FILLED.		Suganya. D. - Nephrology	18/05/2023
Comp. Dt. : 18/05/2023								
Status : Completed								
2075	23050767	DIALYSIS NEW UNIT IN 1ST FLOOR	DRAINAGE LEAKAGE	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	BLOCK REMOVED		Kamal. B. - Nephrology	19/05/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 19/05/2023 Status : Completed								
2076	23050802	DIALYSIS NEW UNIT IN 1ST FLOOR	WATER LEAKAGE AT REUSE ROOM	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	WATER LEAK ARREST		Kamal. B. - Nephrology	19/05/2023
Comp. Dt. : 22/05/2023 Status : Completed								
2077	23050879	DIALYSIS IN 2ND FLOOR	NEED TO CHECK DRAINAGE PIPE LINE - WATER LEAKAGE	Vengatesan. V.,Azhagar. N.,Santhosh Kumar. M.	Waste water pipe line fully rework, work completed		Suganya. B. - Nephrology	30/05/2023
Comp. Dt. : 25/05/2023 Status : Completed								
2078	23050998	DIALYSIS NEW UNIT IN 1ST FLOOR	NEED TO CHANGE TAP - WATER LEAKAGE	Sellaveeran. M.	SPINDLE CHANGED.		Kamal. B. - Nephrology	29/05/2023
Comp. Dt. : 31/05/2023 Status : Completed								
2079	23051257	DIALYSIS NEW UNIT IN 1ST FLOOR	NEED SERVICE FOR WATER PURIFYER - WATER COMING DUST	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	A/C department complaint		Suganya. D. - Nephrology	01/06/2023
Comp. Dt. : 26/06/2023 Status : Completed								
2080	23060982	DIALYSIS NEW UNIT IN 1ST FLOOR	ACID LEAKAGE	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	Work completed.		Kamal. B. - Nephrology	17/07/2023
Comp. Dt. : 27/06/2023 Status : Completed								
2081	23061010	DIALYSIS NEW UNIT IN 1ST FLOOR	RAW WATER NOT COMING	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	valve opened		Kamal. B. - Nephrology	28/06/2023
Comp. Dt. : 30/06/2023 Status : Completed								
2082	23061094	DIALYSIS NEW UNIT IN 1ST FLOOR	ACID MOTOR WATER LEAKAGE	Ramkumar. R.,Azhagar. N.,Sellaveeran. M.	Valve changed.		Neelavathi. T. - Nephrology	17/07/2023
Dept Name : NEUROLOGY - Civil - Maintenance Comp. Dt. : 23/11/2022 Status : Completed								
2083	22110975	EEG	WATER NOT COMING IN II FLOOR [LEFT SIDE]	Prakash. V.,Rajendran. R.,Ramkumar. R.	Tap air lock released and service the tap, problem solved		Vasuki. P. - NEUROLOGY	24/11/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Dept Name : Nursing Office - Civil - Maintenance Comp. Dt. : 29/06/2022 Status : Completed								
2084	22061036	New OT	NEED LABOURS 2NOS FOR SHIFTING UNWANTED WOODEN BOARDS & SHEETS TO WORKSHOP	Pandiaraj. V., Yuvaraj. M., Murali. K.	Unwanted materials shifted to workshop		Velangannie.N. - Nursing Office	01/07/2022
Comp. Dt. : 30/06/2022 Status : Completed								
2085	22061110	Nursing Office	DUE TO INSPECTION PURPOSE - NEED LABOURS 4 NOS FOR WARD ARRANGEMENT WORK - NEED FROM 01.07.2022 TO	Pandiaraj. V., Yuvaraj. M., Thulasi. V.	Ward arrangement work done		Greeta Guna Seelan - Nursing Office	01/07/2022
Comp. Dt. : 07/07/2022 Status : Completed								
2086	22070257	Paediatrics - Ward 308	WASH BASIN TAP LEAKAGE AT DEMO ROOM	Prakash. V., Rajendran. R., Arunagiri. V.	Elbow action tap rework		Devika.R - Nursing Office	12/07/2022
2087	22070264	Female Medical Ward	FLUSH WATER LEAKAGE AT WARD NO 307 & 308	Prakash. V., Rajendran. R., Arunagiri. V.	flush tank rework		Devika.R - Nursing Office	12/07/2022
Comp. Dt. : 09/07/2022 Status : Completed								
2088	22070360	SPECIALITY OT	NEED LABOURS 5NOS FOR COT ARRANGEMENT WORK	Pandiaraj. V., Yuvaraj. M., Thulasi. V.	Cot arrangement done		Rajalakshmi. N. - Nursing Office	11/07/2022
Comp. Dt. : 13/07/2022 Status : Completed								
2089	22070497	Nursing Office	DUE TO EXAM COT ARRANGEMENT WORK NEED LABOURS 8 NOS [TO MEET N.S MADAM TODAY 13.07.2022 AT 3.15	Pandiaraj. V., Yuvaraj. M., Thulasi. V.	Arrangement work done		Greeta Guna Seelan - Nursing Office	14/07/2022
Comp. Dt. : 15/07/2022 Status : Completed								
2090	22070577	Nursing Office	NEED LABOURS 2 NOS FOR COT SHIFTING WORK	Pandiaraj. V., Yuvaraj. M., Thulasi. V.	Cot shifting work completed	 Dr. KAGNE. R.N DEAN SRI MANAKULA VINAYAGAR MEDICAL COLLEGE & HOSPITAL KALITHEERTHAL KUPPAM, PUDUCHERRY-605107.	Greeta Guna Seelan - Nursing Office	16/07/2022
2091	22070592	Nursing Office	NEED LABOUR [1 NO] FOR "S" TYPE CHAIR SHIFTING WORK TO WORKSHOP	Pandiaraj. V.	Chair shifting work done		Papavathi. K. - Nursing Office	18/07/2022

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 18/07/2022 Status : Completed								
2092	22070673	Female Medical - Ward 307	NEED LABOURS 4 NOS FOR COT SHIFTING WORK - LABOUR NEED ON 19.07.2022 @ 9 A.M.	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	COT shifting work done		Kalaiaarasi. D. - Nursing Office	21/07/2022
Comp. Dt. : 05/08/2022 Status : Completed								
2093	22080188	Obstetrics - Ward 208	NEED LABOURS 2 NOS FOR SHIFTING BROKED DOOR FOR REPAIRING WORK TO WORKSHOP	Pandiaraj. V.,Yuvaraj. M.,Prakash. N.	shifting work completed.		Devika.R - Nursing Office	11/08/2022
Comp. Dt. : 24/09/2022 Status : Completed								
2094	22090973	Labour Room	NEED TO CHECK ECLAMPSIA ROOM AREA - BAD SMELL & SOME BLOCK - NEED CLEANING WORK	Rajendhiran. V.	Block removed and room fully washed		Devika.R - Nursing Office	27/09/2022
Comp. Dt. : 19/10/2022 Status : Completed								
2095	22100621	SPECIAL WARD - A1	CEILING WATER LEAKAGE	Prakash. V.,Rajendran. R.,Ramkumar. R.	Expansion joint problem.		Tamilarasi.C. - Nursing Office	22/10/2022
Comp. Dt. : 02/11/2022 Status : Completed								
2096	22110008	SPECIAL WARD -B IN FOURTH FLOOR	WASH BASIN SINK LEAKAGING PROBLEM	Ramkumar. R.,Arunagiri. V.,Manikandan. S.	Angle valve rework done.		Tamilarasi.C. - Nursing Office	04/11/2022
Comp. Dt. : 03/11/2022 Status : Completed								
2097	22110049	Male Surgery - Ward 201	WATER HEATER NOT WORKING-PLUMBING FAULT	Prakash. V.,Rajendran. R.,Ramkumar. R.	Connection tube changed.		Tessy Hillary Scurvilles - Nursing Office	05/11/2022
Comp. Dt. : 05/11/2022 Status : Completed								
2098	22110177	NEW NICU & PICU-2ND FLOOR	NEED 4 MEMBERS MANPOWER FOR SHIFTING PURPOSE	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	Cot shifting work done.		Powlin.P. - Nursing Office	08/11/2022
Comp. Dt. : 07/11/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2099	22110204	PICU & NICU	NEED 2 LABOURS FOR COT SHITING WORK FROM OLD NICU TO NEW NICU	Pandiaraj. V.	Cot shifted from 1st floor NICU to second floor NICU		Powlin.P. - Nursing Office	08/11/2022
	Comp. Dt. : 14/11/2022							
	Status : Completed							
2100	22110506	SPECIAL WARD -B IN FOURTH FLOOR	IN ROOM NO.20 WALL CEILING WATER LEAKAGING PROBLEM	Abdul Azees. J.	A/C pipe line leakage problem, inform to A/C dept		Tamilarasi.C. - Nursing Office	15/11/2022
	Comp. Dt. : 18/11/2022							
	Status : Completed							
2101	22110773	NICU	NEED TO FIX HOT & COLD WATER HEATER	Prakash. V.,Rajendran. R.,Ramkumar. R.	Connection tube changed.		Jenifer. S. - PICU & NICU	26/11/2022
	Comp. Dt. : 28/11/2022							
	Status : Completed							
2102	22111172	Male Surgery - Ward 201	WATER HEATER PIPELINE PROBLEM-NEED TO BE CHECK	Prakash. V.,Rajendran. R.,Ramkumar. R.	Water heater to be condemned.		Greeta Guna Seelan - Nursing Office	05/12/2022
	Comp. Dt. : 29/11/2022							
	Status : Completed							
2103	22111229	NICU	NEED MAN POWER 4NOS FOR SHIFTING COT 5NOS & PLYWOOD SHEETS TO WORK SHOP	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	Cot shifting and plywood shifting work done.		Powlin.P. - Nursing Office	01/12/2022
	Comp. Dt. : 09/12/2022							
	Status : Completed							
2104	22120409	Male Surgery - Ward 201	NEED TO CHECK HEATER PIPE LINE	Prakash. V.,Ramkumar. R.,Rajendran. R.	Electrical department complaint		Padma. A. - Nursing Office	12/12/2022
	Comp. Dt. : 21/12/2022							
	Status : Completed							
2105	22120953	Labour Room	PIPE LINE WATER LEAKAGE	Prakash. V.,Rajendran. R.,Ramkumar. R.	Pipe line connection rework done.		Ilambharat.K. - Nursing Office	21/12/2022
2106	22120984	Male Surgery - Ward 201	NEED TO FIX HEATER PIPE	Prakash. V.	Electrical complaint.		Devika.R - Nursing Office	23/12/2022
	Comp. Dt. : 23/12/2022							
	Status : Completed							
2107	22121090	Male Ortho - Ward 403	NEED 4 LABOURS FOR NURSES CABIN SHIFTING WORK	Pandiaraj. V.,Yuvaraj. M.,Thulasi. V.	Nurses cabin shifting work completed		Leena Grace. B. - Nursing Office	23/12/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 03/01/2023 Status : Completed								
2108	23010080	HOSPITAL IV FLOOR	NEAR LIFT-UNWANTED TABLE NEED TO BE REMOVE FROM THERE-NEED LABOURS	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	Work completed.		Ilambharat.K. - Nursing Office	09/01/2023
Comp. Dt. : 23/01/2023 Status : Completed								
2109	23010817	SPECIAL WARD---B	NEED TO REFIX FLUSH KEY FOR ALL RESTROOMS	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	Need letter from Ward Incharge through proper channel - Medical Superintendent.		Tamilarasi.C. - Nursing Office	24/01/2023
Comp. Dt. : 24/01/2023 Status : Completed								
2110	23010869	Labour Room	NEED MANPOWER 2NOS FOR BERO SHIFTING WORK	Yuvaraj. M.,Senthil Kumar. R.,Pandiaraj. V.	Bero shifting work done.		Devika.R - Nursing Office	24/01/2023
Comp. Dt. : 04/02/2023 Status : Completed								
2111	23020140	Female Medical - Ward 307	REST ROOM TAP BROKEN WATER FLOW - NEED URGENT SERVICE	Anandharaj. M.,Sivaraja. M.,Santhosh Kumar. M.	Tap changed.		Sudha.L. - Nursing Office	06/02/2023
Comp. Dt. : 06/02/2023 Status : Completed								
2112	23020149	Male Surgery - Ward 201	NEED REPAIRING WORK FOR FLUSH & KEY NOT WORKING	Anandharaj. M.,Azhagar. N.,Sankar. R	Flush tank rework done. Float washer changed.		Leena Grace. B. - Nursing Office	06/02/2023
Comp. Dt. : 10/02/2023 Status : Completed								
2113	23020387	Gynaecology - OPD	WASH BASIN TAP WATER LEAKAGE IN DOCTORS ROOM	Azhagar. N.,Udhaya Kumar. R.,Santhosh Kumar. M.	WASH BASIN TAP REWORK DONE.		Padma. A. - Nursing Office	11/02/2023
Comp. Dt. : 15/02/2023 Status : Completed								
2114	23020586	ICU - Ward 1	NEED MAN POWER--ONE NURSES STATION TABLE SHIFTING WORK(3DR FLOOR TO ICU)	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	Nurses cabin shifting work completed		Powlin.P. - Nursing Office	17/02/2023
Comp. Dt. : 16/02/2023 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2115	23020624	SPECIAL WARD---B	WATER TAP BROKEN	Azhagar. N.,Sellaveeran. M.,Udhaya Kumar. R.	TAP CHANGED		Tamilarasi.C. - Nursing Office	18/02/2023
Comp. Dt. : 03/03/2023 Status : Completed								
2116	23030124	SPECIAL WARD---B	NEED TO CHECK DRAINAGE PIPELINE - BAD SMELL - CHECK ALL RESTROOMS	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	HOUSEKEEPING COMPLAINT. WASHING GIVEN AT COMMON TOILET.		Tamilarasi.C. - Nursing Office	07/03/2023
Comp. Dt. : 15/03/2023 Status : Completed								
2117	23030618	DENTAL OPD -2ND FLOOR	NEED TO CHECK DENTAL CHAIR WATER PIPELINE - LEAKAGE	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	1/2 SHOWER TAP VALVE FIXED.		Sarala. V. - OPD	31/03/2023
Comp. Dt. : 17/03/2023 Status : Completed								
2118	23030679	ORTHO OT	BLOCK IN WASH BASIN	Rajendhiran. V.,Thanuzkodi. E,Murugan. S.	BLOCK REMOVED.		Devika.R - Nursing Office	18/03/2023
Comp. Dt. : 22/03/2023 Status : Completed								
2119	23030913	Main OT	WATER NOT COMING IN ALL OT'S	Gopal. S.,Sivaraja. M.,Santhosh Kumar. M.	VALVE CLOSED FOR WORKING IN CASUALTY RECOVERY ROOM. AFTER COMPLETING THE WORK VALVE OPENED.		Devika.R - Nursing Office	23/03/2023
Comp. Dt. : 29/03/2023 Status : Completed								
2120	23031233	TB & Chest OPD	NEED TO CHECK WATER PIPE LINE CONNECTION - WATER LEAKAGE FROM SURGERY OT	Udhaya Kumar. R.,Sellaveeran. M.,Anandharaj. M.	EXPANSION JOINT PROBLEM.		Padma. A. - Nursing Office	01/04/2023
Comp. Dt. : 30/03/2023 Status : Completed								
2121	23031289	Male Surgery - Ward 201	BLOCK IN PATIENT REST ROOM	Rajendhiran. V.,Thanuzkodi. E,Murugan. S.	block removed.		Kowsalya. G. - Male Surgery	31/03/2023
Comp. Dt. : 05/04/2023 Status : Completed								
2122	23040161	Special Ward - C	NEED TO REFIX W E C - DAMAGE & BROKED , WARD NO 409	Santhosh Kumar. M.,Gopal. S.,Sivaraja. M.	EWC refixed, problem solved		Tamilarasi.C. - Nursing Office	19/04/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 19/04/2023 Status : Completed								
2123	23040582	New OT	BLOCK IN RESTROOM & FLUSH NOT WORKING	Rajendhiran. V.,Sakthivel. E.,Sivaraja. M.	Flush tank float valve changed, toilet block removed, work completed		Devika.R - Nursing Office	20/04/2023
Comp. Dt. : 27/04/2023 Status : Completed								
2124	23040905	Nursing Office	NEED MANPOWER 4 NOS FOR ICU COT SHIFTING WORK	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	Cot shifting work completed		Tamilarasi.C. - Nursing Office	02/05/2023
Comp. Dt. : 02/05/2023 Status : Completed								
2125	23050001	PICU	WALL WATER LEAKAGE IN PICU DOCTOR'S ROOM - NEED URGENT SERVICE	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	water leakage due to heavy rain		Powlin.P. - Nursing Office	04/05/2023
Comp. Dt. : 25/05/2023 Status : Completed								
2126	23050993	Male Surgery - Ward 201	WATER NOT COMING AT REST ROOM	Anandharaj. M.	VALVE OPENED. PROBLEM RECTIFIED.		Kowsalya. G. - Male Surgery	25/05/2023
Dept Name : Nutrition & Dietetics - Civil - Maintenance Comp. Dt. : 16/05/2022 Status : Completed								
2127	22050515	Work Shop	NEED LABOURS 2 NOS FOR GRINDER SHIFTING WORK FROM WORKSHOP TO V FLOOR DIET DEPT	Yuvaraj. M.	grinder shifting work		Shanmugapriya. J. - Nutrition & Dietetics	16/05/2022
Comp. Dt. : 25/06/2022 Status : Completed								
2128	22060928	OPTICAL SHOP NEAR OPHTHAL OPD	NEED LABOURS 6 NOS FOR SHIFTING RICE BAGS NEAR OPHTHAL OPD TO V FLOOR STORE ROOM NEED URGENT SERVICE	Pandiaraj. V.,Yuvaraj. M.,Murali. K.	Rice bag shifting work done		Shanmugapriya. J. - Nutrition & Dietetics	25/06/2022
Comp. Dt. : 09/07/2022 Status : Completed								
2129	22070356	OPTICAL SHOP NEAR OPHTHAL OPD	NEED LABOURS 6 NOS FOR UNLOADING RICE BAGS [60 NOS] NEAR OPTICAL SHOP TO DIET DEPT STORE ROOM	Pandiaraj. V.,Yuvaraj. M.,Prakash. N.	rice bags shifted	 Dr. KAGNE. R.N DEAN SRI MANAKULA VINAYAGAR MEDICAL COLLEGE & HOSPITAL KALITHEERTHALKUPPAM, PUDUCHERRY-605107.	Shanmugapriya. J. - Nutrition & Dietetics	12/07/2022

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 22/08/2022								
Status : Completed								
2130	22080691	DIET DEPARMENT	NEED LABOURS [3NOS] FOR UNLOADING WORK FROM V FLOOR TO VI FLOOR	Pandiaraj. V.,Yuvaraj. M.,Murali. K.	Unloading work completed		Shanmugapriya. J. - Nutrition & Dietetics	24/08/2022
2131	22080705	DIET DEPARMENT	NEED TO CHANGE TAP - BROKEN AND WATER LEAKAGE AT V FLOOR	Prakash. V.,Rajendran. R.,Ramkumar. R.	Tap changed.		Rampriya. R. - Nutrition & Dietetics	23/08/2022
Comp. Dt. : 08/09/2022								
Status : Completed								
2132	22090303	HOSPITAL CANTEEN IN TERROUS	NEED TO SHIFT AIR PIPE FROM HOSPITAL CANTEEN TERROUS TO OUTSIDE	Prakash. V.,Rajendran. R.,Ramkumar. R.	Air pipe dummy fixed, problem solved		Shanmugapriya. J. - Nutrition & Dietetics	09/09/2022
Comp. Dt. : 21/09/2022								
Status : Completed								
2133	22090815*	DIET DEPARMENT	NEED TO EXTEND PIPE LINE CONNECTION FOR WASHING AREA AT V FLOOR	Prakash. V.,Rajendran. R.,Ramkumar. R.	4" 2.1/2' pipe line rework		Krishna Priya. E. - Nutrition & Dietetics	22/09/2022
Comp. Dt. : 12/10/2022								
Status : Completed								
2134	22100311	DIET DEPARMENT	WASH BASIN PIPE NEED TO BE EXTENED AT FIFTH FLOOR CANTEEN	Prakash. V.,Rajendran. R.,Ramkumar. R.	Work completed.		Shanmugapriya. J. - Nutrition & Dietetics	26/11/2022
Comp. Dt. : 24/11/2022								
Status : Completed								
2135	22111027	DIET DEPARMENT	IN TERROUS-WATERLINE NEED TO EXTERN LONG	Prakash. V.,Rajendran. R.,Ramkumar. R.	Water line extending work completed.		Shanmugapriya. J. - Nutrition & Dietetics	14/12/2022
Comp. Dt. : 12/12/2022								
Status : Completed								
2136	22120499	DIET DEPARMENT	TAP BROKEN IN DIET SETTING AREA	Prakash. V.,Rajendran. R.,Manikandan. S.	Tap fixed.		Rampriya. R. - Nutrition & Dietetics	12/12/2022
Comp. Dt. : 24/12/2022								
Status : Completed								
2137	22121100	DIET DEPARMENT	NEED 4 LABOURS FOR SHIFTING WORK (RICE BAG) - OPHTHAL OPD TO 6TH FLOOR	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	Rice bags shifted from ophthal opd to terrace dietician department.		Shanmugapriya. J. - Nutrition & Dietetics	24/12/2022
2138	22121132	DIET DEPARMENT	IN TERROUS-WASING AREA-SS LINE WATER LEAKAGING PROBLEM	Prakash. V.,Rajendran. R.,Ramkumar. R.	New CP tap changed, work completed		Shanmugapriya. J. - Nutrition & Dietetics	26/12/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 27/12/2022 Status : Completed								
2139	22121202	DIET DEPARMENT	IN REST ROOM-HEALATH FUCET LEAKAGING PROBLEM	Prakash. V.,Rajendran. R.,Ramkumar. R.	health faucet rework done.		Rampriya. R. - Nutrition & Dietetics	27/12/2022
2140	22121210	DIET DEPARMENT	IN WASHING AREA-TAP BROKEN AND IN KITCHEN-SS TAP WATER LEAKAGING PROBLEM	Prakash. V.,Rajendran. R.,Ramkumar. R.	quba spindle and metro spindle changed. New pvc tap changed.		Rampriya. R. - Nutrition & Dietetics	27/12/2022
Comp. Dt. : 07/01/2023 Status : Completed								
2141	23010309	DIET DEPARMENT	SS WATER TAP LEAKAGING PROBLEM	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	PVC tap fixed.		Shanmugapriya. J. - Nutrition & Dietetics	09/01/2023
Comp. Dt. : 12/01/2023 Status : Completed								
2142	23010525	DIET DEPARMENT	IN REST ROOM-WATER TAP LEAKAGING PROBLEM	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	Spindle changed.		Rampriya. R. - Nutrition & Dietetics	13/01/2023
Comp. Dt. : 23/01/2023 Status : Completed								
2143	23010839	DIET DEPARMENT	NEED TO CHANGE TAP - BROKEN AT WASHING AREA	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	Tap changed.		Krishna Priya. E. - Nutrition & Dietetics	24/01/2023
Comp. Dt. : 04/02/2023 Status : Completed								
2144	23020147	OPTICAL SHOP NEAR OPHTHAL OPD	NEED MANPOWER 4NOS FOR SHIFTING GROCERIES FROM OPTICAL SHOP NEAR OPHTHAL OPD TO VI FLOOR	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	Canteen items shifting work completed		Shanmugapriya. J. - Nutrition & Dietetics	07/02/2023
Comp. Dt. : 06/02/2023 Status : Completed								
2145	23020191	DIET DEPARMENT	BLOCK IN V FLOOR KITCHEN WASHING AREA	Rajendhiran. V.,Thanuzkodi. E.,Murugan. S.	BLOCK REMOVED.		Shanmugapriya. J. - Nutrition & Dietetics	07/02/2023
Comp. Dt. : 27/02/2023 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2146	23021040	DIET DEPARMENT	NEED TO CLOSE RESTROOM EXHAUST HOLE AT V FLOOR - BED SMELL & HOLE OPEN - NEED URGENT SERVICE	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	WORK SHOP COMPLAINT.		Shanmugapriya. J. - Nutrition & Dietetics	02/03/2023
Comp. Dt. : 11/03/2023 Status : Completed								
2147	23030443	DIET DEPARMENT	NEED TO CHANGE LITCHEN TAP - BROKEN - WATER FLOW - NEED URGENT SERVICE	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	PVC TAP CHANGED.		Vidhyashree. S. - Nutrition & Dietetics	11/03/2023
Comp. Dt. : 14/03/2023 Status : Completed								
2148	23030536	DIET DEPARMENT	NEED TO CHANGE WASHING AREA TAP - BROKEN - WATER LEAKAGE	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	NEW PVC TAP CHANGED.		Rampriya. R. - Nutrition & Dietetics	15/03/2023
Comp. Dt. : 17/03/2023 Status : Completed								
2149	23030685	DIET DEPARMENT	NEED TO CHANGE TAP WASHING AREA OUTSIDE TAP - DAMAGE WATER LEAKAGE	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	TAP CHANGED.		Vidhyashree. S. - Nutrition & Dietetics	17/03/2023
Comp. Dt. : 31/03/2023 Status : Completed								
2150	23031346	DIET DEPARMENT	NEED CLEANING AND CEMENT WORK FOR KITCHEN RICE FILTER AREA	Murugavel	BRICK WORK COMPLETED		Shanmugapriya. J. - Nutrition & Dietetics	04/04/2023
Comp. Dt. : 28/04/2023 Status : Completed								
2151	23040968	DIET DEPARMENT	NEED TO CHECK TOILET AIR EXTENTION - BAD SMELL AT VI FLOOR - NEED URGENT SERVICE	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	PIPE EXTENSION WORK DONE.		Shanmugapriya. J. - Nutrition & Dietetics	06/05/2023
Comp. Dt. : 29/04/2023 Status : Completed								
2152	23041004	Orthopaedics - OPD	NEED MANPOWER 6 NS FOR UNLOADING RICE BAGS FROM ORTHO OPD TO VI FLOOR AT 29.04.2023 12.30 P.M.	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	Rice bag shifting work completed		Shanmugapriya. J. - Nutrition & Dietetics	02/05/2023
Comp. Dt. : 02/05/2023								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
2153	23050005*	DIET DEPARMENT	V FLOOR - KITCHEN OUTSIDE CEILING BROKEN AND FALL DOWN - NEED URGENT SERVICE	Anandharaj. M.,Sellaveeran. M.,Udhaya Kumar. R.	SCAFFOLDING WORK DONE. CEILING PLASTERING WORK DONE		Shanmugapriya. J. - Nutrition & Dietetics	29/05/2023
Comp. Dt. : 04/05/2023								
Status : Completed								
2154	23050155*	DIET DEPARMENT	NEED CEMENT WORK FOR DIET SETTING , WASHING AREA WAY TROLLEY STAND PLACE	Murugavel	Chips concrete laying work completed		Shanmugapriya. J. - Nutrition & Dietetics	13/05/2023
Comp. Dt. : 22/05/2023								
Status : Completed								
2155	23050877	DIET DEPARMENT	NEED TO CHANGE KITCHEN TAP = WATER LEAKAGE	Gopal. S.,Santhosh Kumar. M.,Azhagar. N.	TAP CHANGED.		Shanmugapriya. J. - Nutrition & Dietetics	23/05/2023
Dept Name : OPD - Civil - Maintenance								
Comp. Dt. : 05/05/2022								
Status : Completed								
2156	22050155	Ophthalmology - OPD	REST ROOM BLOCK IN HOD SIR ROOM	Rajendran. R.	Flastank washar chaning		Seetha. R. - OPD	05/05/2022
Comp. Dt. : 06/05/2022								
Status : Completed								
2157	22050194	ENT OPD	WATER LEAKAGE IN HOD ROOM [RESTROOM]	Prakash. V.	Flush tank washer changed and serviced, problem solved		Ezhilarasi. M. - OPD	07/05/2022
Comp. Dt. : 07/05/2022								
Status : Completed								
2158	22050223	General Medicine - OPD	WATER NOT COMING IN SINK	Prakash. V.,Manikandan. S.,Arunagiri. V.	CP Elbow action pillar cock rework, problem solved		Sivaranjani. P. - OPD	07/05/2022
Comp. Dt. : 13/05/2022								
Status : Completed								
2159	22050476*	DENTAL OPD -2ND FLOOR	X-RAY STAND PIPE LEAAKGING PROBLEM	Prakash. V.,Ramkumar. R.,Sankar. V.	Painting work should be done by Workshop Department.		Kanakarani. R. - OPD	16/05/2022
Comp. Dt. : 16/05/2022								
Status : Completed								
2160	22050533	Orthopaedics - OPD	WATER LEAKAGE IN WASH BASIN AT DEMO ROOM	Arunagiri. V.	1*1/4" Waste line rework done.		Murgadevi. J - OPD	16/05/2022
Comp. Dt. : 17/05/2022								

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
2161	22050607	ENT OPD	FLUSH WATER LEAKAGE - NEED TO CHECK ROOM NO 70	Arunagiri. V.	Flush tank rework.		Ezhilarasi. M. - OPD	17/05/2022
Comp. Dt. : 21/05/2022								
Status : Completed								
2162	22050805	DENTAL OPD -2ND FLOOR	NEED TO CHANG WASH BASIN TAP - WATER LEAKAGE	Prakash. V.,Arunagiri. V.,Rajendran. R.	New Elbow action pillar cock changed		Lakshmi Devi. R. - OPD	25/05/2022
Comp. Dt. : 24/05/2022								
Status : Completed								
2163	22050884	COMMON TOILET NEAR OPHTAL OPD	MALE REST ROOM BLOCK	Thanuzkodi. E	Rest room block removed.		Kamala.D. - OPD	25/05/2022
Comp. Dt. : 28/05/2022								
Status : Completed								
2164	22051046	IVF ART CLINIC-INSIDE OF OG OPD(NO.68)	BLOCK IN RESTROOM [MADAM ROOM]	Thanuzkodi. E	Toilet block removed, work completed		Rajasekari. R. - OPD	31/05/2022
Comp. Dt. : 30/05/2022								
Status : Completed								
2165	22051097	Male Ortho - Ward 403	NEED TO CHANGE TAP - BROKEN - WATER LEAKAGE	Prakash. V.	New Urinal changed.		Vanitha. P. - Male Ortho Ward	31/05/2022
Comp. Dt. : 13/06/2022								
Status : Completed								
2166	22060437	ENT OPD	NEED TO CHECK WASH BASIN & TAP [DAMAGE & BROKEN] WATER LEAKAGE	Prakash. V.,Rajendran. R.,Arunagiri. V.	New wash basin and tap changed, water line connection given, problem solved		Ezhilarasi. M. - OPD	13/06/2022
Comp. Dt. : 15/06/2022								
Status : Completed								
2167	22060576	IVF ART CLINIC-INSIDE OF OG OPD(NO.68)	BLOCK IN RESTROOM	Rajendran. R.	Block removed.		Rajasekari. R. - OPD	17/06/2022
Comp. Dt. : 16/06/2022								
Status : Completed								
2168	22060610	UROLOGY--OPD	SINK BLOCK - II FLOOR OPD	Rajendhiran. V.	Block removed.		Lavanya. M. - OPD	17/06/2022
Comp. Dt. : 17/06/2022								
Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2169	22060635	IVF ART CLINIC-INSIDE OF OG OPD(NO.68)	BLOCK IN RESTROOM	Rajendhiran. V.	block removed.		Adhilakshmi. A. - OPD	17/06/2022
		Comp. Dt. : 20/06/2022 Status : Completed						
2170	22060725	COMMON TOILET NEAR FREE PHARMACY	BLOCK IN REST ROOM - COMMON TOILET NEAR FREE PHARMACY	Rajendhiran. V.	block removed		Ezhilarasi. M. - OPD	20/06/2022
		Comp. Dt. : 29/06/2022 Status : Completed						
2171	22061048	Paediatrics - OPD	NEED TO FIX NEW TOWEL STAND [3NOS] NEAR SINK	Prakash. V.,Arunagiri. V.,Manikandan. S.	New towel stand fixed.		Subashree. R. - OPD	12/07/2022
		Comp. Dt. : 04/07/2022 Status : Completed						
2172	22070092	OG-OPD	BLOCK IN RESTROOM	Rajendhiran. V.	Toilet block removed, work completed		Velangkanni. K. - OPD	05/07/2022
		Comp. Dt. : 05/07/2022 Status : Completed						
2173	22070160	DENTAL OPD -2ND FLOOR	NEED TO FIX NET FOR TAP - WATER COMING FORCE	Prakash. V.	Tap rework done		Lakshmi Devi. R. - OPD	07/07/2022
		Comp. Dt. : 06/07/2022 Status : Completed						
2174	22070190	ENT OPD	WASH BASIN SINK WATER LEAKAGE - ROOM NO 29	Prakash. V.,Arunagiri. V.,Ramkumar. R.	Flush tank rework and waste coupling rework		Ezhilarasi. M. - OPD	07/07/2022
2175	22070210	CARDIOLOGY OPD	WATER LEAKAGE IN FLUSH	Prakash. V.,Ramkumar. R.,Rajendran. R.	Flush tank rework		Radhika. R. - OPD	07/07/2022
		Comp. Dt. : 08/07/2022 Status : Completed						
2176	22070297	DENTAL OPD -2ND FLOOR	WASH BASIN BROKENED - NEED TO CHANGE	Prakash. V.,Arunagiri. V.,Rajendran. R.	Wash basin rework and refixed properly. Wrong complaint		Lakshmi Devi. R. - OPD	12/07/2022
2177	22070310	Nephrology OPD	BLOCK IN SINK	Rajendhiran. V.	Sink block removed.		Jenifer. K. - OPD	11/07/2022
		Comp. Dt. : 12/07/2022 Status : Completed						
2178	22070451	ONCOLOGY DEPT-2ND FLOOR-SPECIAL OPD	NEED TO CHANGE SINK OUTLET WATER HOSE - WATER LEAKAGE - OPD 216	Prakash. V.,Rajendran. R.,Ramkumar. R.	Waste hose changed. JK white pointing work		Tamilarasi. A. - OPD	14/07/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 19/07/2022 Status : Completed								
2179	22070704	General Medicine - OPD	BLOCK IN RESTROOM - ROOM NO 15	Rajendhiran. V.,Thanuzkodi. E,Govindan. R.	Toilet block removed, work completed		Bharathi.D. - OPD	20/07/2022
Comp. Dt. : 21/07/2022 Status : Completed								
2180	22070787	COMMON MALE TOILET NEAR ORTHO OPD	BLOCK IN MALE RESTROOM	Rajendhiran. V.,Thanuzkodi. E,Murugan. S.	Block removed.		Durgadevi. J - OPD	22/07/2022
2181	22070806	Work Shop	NEED LABOURS 2 NOS FOR SHIFTING RACK FROM WORKSHOP TO ENT OPD	Pandiaraj. V.,Yuvaraj. M.,Thulasi. V.	shifting work done		Ezhilarasi. M. - OPD	26/07/2022
Comp. Dt. : 23/07/2022 Status : Completed								
2182	22070868	DENTAL OPD -2ND FLOOR	NEED TO CHANGE TAP - BROKEN - WATER FLOW - NEED URGENT SERVICE	Prakash. V.,Rajendran. R.,Ramkumar. R.	Tap rework. Spindle changed.		Lakshmi Devi. R. - OPD	26/07/2022
Comp. Dt. : 30/07/2022 Status : Completed								
2183	22071092	General Medicine - OPD	NEED TO CHECK WALL SIDE PIPELINE - DAMAGE & WATER LEAKAGE - ROOM NO 15	Prakash. V.,Arunagiri. V.,Rajendran. R.	Wall and tiles fully binded.		Bharathi.D. - OPD	01/08/2022
Comp. Dt. : 17/08/2022 Status : Completed								
2184	22080496	DENTAL OPD -2ND FLOOR	WASH BASIN OUTLET PIPE WATER LEAKAGE	Prakash. V.	connection pipe changed.		Kanakarani. R. - OPD	24/08/2022
Comp. Dt. : 22/08/2022 Status : Completed								
2185	22080731	OG-OPD	BLOCK IN SINK AT DEMO ROOM	Rajendhiran. V.,Murugan. S.,Thanuzkodi. E	Block removed.		Velangkanni. K. - OPD	24/08/2022
Comp. Dt. : 24/08/2022 Status : Completed								
2186	22080816	TB & Chest OPD	CEILING WATER LEAKAGE IN DOCTOR'S ROOM - NEED TO CHECK	Prakash. V.,Ramkumar. R.,Rajendran. R.	water leakage due to wash at first floor		Jothi.R. - OPD	26/08/2022
Comp. Dt. : 26/08/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2187	22080924*	Paediatrics - OPD	BLOCK IN REST ROOM & NEED TO REFIX DRAINAGE FILTER FOR RESTROOM	Rajendhiran. V.,Thanuzkodi. E,Murugan. S.	Block removed and gratings fixed.		Subashree. R. - OPD	07/09/2022
	Comp. Dt. : 29/08/2022							
	Status : Completed							
2188	22081001	DENTAL OPD -2ND FLOOR	WASH BASIN BROKEN - NEED TO CHANGE	Prakash. V.,Rajendran. R.,Ramkumar. R.	sink tank fixed		Lakshmi Devi. R. - OPD	30/08/2022
	Comp. Dt. : 01/09/2022							
	Status : Completed							
2189	22090007	Paediatrics - OPD	NEED TO CHECK SINK PIPELINE - LINE DAMAGE - WATER LEAKAGE	Prakash. V.,Ramkumar. R.,Rajendran. R.	1.1/2" Waste water line fully rework, work completed		Subashree. R. - OPD	05/09/2022
	Comp. Dt. : 03/09/2022							
	Status : Completed							
2190	22090147	Work Shop	NEED LABOURS 2 NO FOR TABLE SHIFTING WORK FROM WORKSHOP TO DENTAL OPD	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	Table shifting work completed		Lakshmi Devi. R. - OPD	05/09/2022
	Comp. Dt. : 05/09/2022							
	Status : Completed							
2191	22090170	Nephrology OPD	NEED TO CHANGE TAP - WATER LEAKAGE	Arunagiri. V.,Manikandan. S.,Rajendran. R.	elbow action taprework		Jenifer. K. - OPD	06/09/2022
2192	22090197	Surgery OPD	CEILING WATER LEAKAGE	Prakash. V.,Rajendran. R.,Ramkumar. R.	Expansion joint problem.		Indhira. M. - OPD	06/09/2022
	Comp. Dt. : 06/09/2022							
	Status : Completed							
2193	22090222	TB & Chest OPD	NEED TO CHANGE TAP - WATER LEAKAGE AT DEMO ROOM	Prakash. V.,Rajendran. R.,Ramkumar. R.	Elbow action and connection tube rework		Jothi.R. - OPD	06/09/2022
	Comp. Dt. : 07/09/2022							
	Status : Completed							
2194	22090257	OG-OPD	WATER NOT COMING IN OPD	Prakash. V.,Rajendran. R.,Ramkumar. R.	Toilet room all tap rework, airlock released, problem solved		Velangkanni. K. - OPD	07/09/2022
	Comp. Dt. : 08/09/2022							
	Status : Completed							
2195	22090342	OG-OPD	FLUSH NOT WORKING - WATER NOT COMING - NEED TO CHECK	Prakash. V.,Rajendran. R.,Ramkumar. R.	Flush tank full set rework problem solved		Velangkanni. K. - OPD	09/09/2022

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 10/09/2022								
Status : Completed								
2196	22090415	IVF ART CLINIC-INSIDE OF OG OPD(NO.68)	NEED TO CHANGE TAP 3 NOS [DAMAGE & WATERLEAKAGE]	Prakash. V.,Rajendran. R.,Ramkumar. R.	Tap filter cleaned and refixed.		Rajasekari. R. - OPD	16/09/2022
Comp. Dt. : 15/09/2022								
Status : Completed								
2197	22090612	COMMON MALE TOILET NEAR ORTHO OPD	NEED TO CHECK TAP - BROKEN & WATER FLOW	Prakash. V.,Arunagiri. V.,Sankar. V.	New PVC tap changed, work completed		Durgadevi. J - OPD	17/09/2022
Comp. Dt. : 19/09/2022								
Status : Completed								
2198	22090738	Nephrology OPD	NEED TO CHANGE WASH BASIN TAP - NOT CLOSING PROPER	Prakash. V.,Rajendran. R.,Ramkumar. R.	Tap changed.		Jenifer. K. - OPD	21/09/2022
2199	22090739	IVF ART CLINIC-INSIDE OF OG OPD(NO.68)	CEILING WATER LEAKAGE - FUNGUS FORMED IN THE WALLS	Prakash. V.,Rajendran. R.,Ramkumar. R.	Water leakage arrested		Rajasekari. R. - OPD	22/09/2022
Comp. Dt. : 23/09/2022								
Status : Completed								
2200	22090911	Nephrology OPD	NEED TO CHANGE WASH BASIN DRAINAGE HOSE - BROKEN - WATER LEAKAGE AT PATIENT RESTROOM	Prakash. V.,Rajendran. R.,Ramkumar. R.	Wash basin packing work done. Waste hose and tap rework.		Jenifer. K. - OPD	24/09/2022
2201	22090914	Nephrology OPD	FLUSH NOT WORKING	Prakash. V.,Rajendran. R.,Ramkumar. R.	Flush tank rework		Jenifer. K. - OPD	24/09/2022
2202	22090924	ENT OPD	NEED TO CLOSE SEPTIC TANK(DRINAGE) BACK SIDE ENT NEAR CANTEEN	Prakash. V.,Rajendran. R.,Ramkumar. R.	Drainage removed with impeller motor pump		Ezhilarasi. M. - OPD	26/09/2022
Comp. Dt. : 26/09/2022								
Status : Completed								
2203	22091026	DENTAL OPD -2ND FLOOR	WATER LEAKAGE AT WASH BASIN TAP - NEED TO CHANGE	Manikandan. S.,Rajendran. R.,Ramkumar. R.	Wash basin tap rework.		Kanakarani. R. - OPD	27/09/2022
Comp. Dt. : 27/09/2022								
Status : Completed								
2204	22091049	Ophthalmology - OPD	NEED LABOUR 1 NO FOR SCREEN REMOVING WORK	Pandiaraj. V.	Screen removing work done.		Seetha. R. - OPD	28/09/2022
Comp. Dt. : 06/10/2022								
Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2205	22100097	DERMATOLOGY OPD	BLOCK IN WAS BASIN	Rajendhiran. V.,Thanuzkodi. E,Murugan. S.	block removed.		Indumathi. T. - OPD	07/10/2022
Comp. Dt. : 07/10/2022 Status : Completed								
2206	22100138	IVF ART CLINIC-INSIDE OF OG OPD(NO.68)	RESTROOM BLOCK - NEED URGENT SERVICE [DR. JAYASREE MADAM ROOM]	Rajendhiran. V.,Thanuzkodi. E,Murugan. S.	Block removed.		Rajasekari. R. - OPD	08/10/2022
Comp. Dt. : 11/10/2022 Status : Completed								
2207	22100276	COMMON TOILET NEAR MEDICINE OPD	BLOCK IN MALE RESTROOM	Rajendhiran. V.,Thanuzkodi. E,Murugan. S.	Block removed.		Kamala.D. - OPD	11/10/2022
Comp. Dt. : 12/10/2022 Status : Completed								
2208	22100338	Orthopaedics - OPD	WATER NOT COMING	Prakash. V.,Ramkumar. R.,Rajendran. R.	Valve opened. water coming		Durgadevi. J - OPD	13/10/2022
2209	22100361	DENTAL OPD -2ND FLOOR	NEED LABOURS 2 NOS FOR BERO SHIFTING WORK	Senthil Kumar. R.	Bero shifting work done.		Kanakarani. R. - OPD	13/10/2022
Comp. Dt. : 13/10/2022 Status : Completed								
2210	22100416	PUVATHERAPHY IN 2ND FLOOR	NEED TO FIX NEW TOWEL STAND NEAR HAND WASH	Prakash. V.,Arunagiri. V.,Manikandan. S.	Towel rod, towel ring and soap dish fixed.		Indumathi. T. - OPD	04/11/2022
Comp. Dt. : 14/10/2022 Status : Completed								
2211	22100435	Paediatrics - OPD	SINK DRAINAGE HOSE DAMAGE - WATER LEAKAGE NEED TO CHANGE	Prakash. V.,Rajendran. R.,Ramkumar. R.	Connection tube changed. waste hose changed.		Subashree. R. - OPD	15/10/2022
Comp. Dt. : 20/10/2022 Status : Completed								
2212	22100692	ENT OPD	WASBASIN TAB WATER LEAKAGE IN ROOM NO.29	Prakash. V.,Rajendran. R.,Ramkumar. R.	Elbow action pillar cock changed.		Ezhilarasi. M. - OPD	22/10/2022
Comp. Dt. : 27/10/2022 Status : Completed								
2213	22100848	IVF ART CLINIC-INSIDE OF OG OPD(NO.68)	PATIENT BATHROOM BACKSIDE WESTERN TOILET PIPE BROKEN	Prakash. V.	New Elbow action tap changed, flush tank full set rework, work completed		Rajasekari. R. - OPD	27/10/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 03/11/2022 Status : Completed								
2214	22110087	Paediatrics - OPD	TOILET BLOCK,NEED SCAVENGER	Rajendhiran. V.	block removed.		Subashree. R. - OPD	03/11/2022
Comp. Dt. : 09/11/2022 Status : Completed								
2215	22110336	Paediatrics - OPD	RESTROOM BLOCK	Rajendhiran. V.,Thanuzkodi. E,Murugan. S.	block removed.		Subashree. R. - OPD	10/11/2022
Comp. Dt. : 10/11/2022 Status : Completed								
2216	22110415	General Medicine - OPD	TERMITE FORMING ON WALLS	Kannan. V.	Termite spray sprayed.		Bharathi.D. - OPD	11/11/2022
Comp. Dt. : 21/11/2022 Status : Completed								
2217	22110843	General Medicine - OPD	IN ROOM NO.20-BAD SMELL FROM WASH BASIN SINK	Prakash. V.,Rajendran. R.,Rajendhiran. V.	Block removed at wash basin.		Bharathi.D. - OPD	26/11/2022
2218	22110891	COMMON MALE TOILET NEAR ORTHO OPD	TOILET BLOCKED,NEED SCAVENGER	Rajendhiran. V.,Murugan. S.,Thanuzkodi. E	Block removed.		Durgadevi. J - OPD	22/11/2022
Comp. Dt. : 24/11/2022 Status : Completed								
2219	22111066	OG-OPD	NEED LABOURS FOR FUNCTION ARRANGEMENTS WORK	Prakash. N.,Thulasi. V.,Senthil Kumar. R.	Function arrangement work completed.		Velangkanni. K. - OPD	25/11/2022
Comp. Dt. : 25/11/2022 Status : Completed								
2220	22111107	OG-OPD	NEED LABOURS FOR CHAIR REARRANGEMENTS WORK	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	Chair rearrangement work completed.		Velangkanni. K. - OPD	26/11/2022
Comp. Dt. : 30/11/2022 Status : Completed								
2221	22111284	DENTAL OPD -2ND FLOOR	NEED TO CHANGE TAP WATER LEAKAGE	Abdul Azees. J.,Sankar. V.,Manikandan. S.	pvc tap changed.		Priyadharshini. S. - OPD	05/12/2022
Comp. Dt. : 02/12/2022 Status : Completed								
2222	22120083	Nephrology OPD	NEED TO CHANGE WASH BASIN TAP - WATER LEAKAGE	Manikandan. S.,Arunagiri. V.,Rajendran. R.	Wash basin tap rework.		Jenifer. K. - OPD	02/12/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 03/12/2022 Status : Completed								
2223	22120119	New OT	WASH BASIN WATER BLOCK - UROLOGY OT	Rajendhiran. V.,Murugan. S.,Thanuzkodi. E	Block removed.		Banupriya. M. - Operation Theatre	05/12/2022
Comp. Dt. : 06/12/2022 Status : Completed								
2224	22120226	Paediatrics - OPD	WASH BASIN SINK NEED TO BE REFIX PROPERLY	Prakash. V.,Rajendran. R.,Sankar. V.	Wash basin rework.		Subashree. R. - OPD	06/12/2022
Comp. Dt. : 08/12/2022 Status : Completed								
2225	22120373	Surgery OPD	IN WHOLE WING-WATER NOT COMING	Prakash. V.	Tank filled. Problem rectified.		Indhira. M. - OPD	12/12/2022
Comp. Dt. : 12/12/2022 Status : Completed								
2226	22120507	New OT	UROLOGY OT - OT NO 8 - SCRUB AREA WATER TAP LEAKAGING	Prakash. V.	Tap rework done.		Banupriya. M. - Operation Theatre	12/12/2022
2227	22120508	New OT	UROLOGY OT MALE WAITING ROOM - NEAR O2 LINE WATER LEAKAGING, CHECK IMMEDIATELY	Prakash. V.	Connection tube changed.		Banupriya. M. - Operation Theatre	12/12/2022
2228	22120517	New OT	UROLOGY OT - DRAINAGE SMELL COMING	Prakash. V.,Rajendran. R.,Rajendhiran. V.	Block removed.		Banupriya. M. - Operation Theatre	12/12/2022
2229	22120557	NEW NICU & PICU-2ND FLOOR	NEED LABOURS FOR MATTRESS SHIFTING WORK TO PAEDIATRIC OPD	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	Mattress shifting work completed		Priyadharshini. S. - OPD	20/12/2022
Comp. Dt. : 15/12/2022 Status : Completed								
2230	22120689	IVF ART CLINIC-INSIDE OF OG OPD(NO.68)	FLUSH WATER LEAKAGE AT STAFF REST ROOM	Prakash. V.,Rajendran. R.,Ramkumar. R.	Flush tank fullset rework, washer changed, problem solved		Rajasekari. R. - OPD	19/12/2022
Comp. Dt. : 26/12/2022 Status : Completed								
2231	22121136	Ophthalmology - OPD	WASH BASIN WATER LEAKAGE IN ROOM NO 84	Ramkumar. R.,Abdul Azees. J.,Manikandan. S.	Wash basin waste line rework, flush tank fullset rework, work completed		Kamala.D. - OPD	26/12/2022
Comp. Dt. : 27/12/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2232	22121204	IVF ART CLINIC-INSIDE OF OG OPD(NO.68)	IN HOD MADAM ROOM-REST ROOM BLOCK,NEED SCAVENGER	Rajendhiran. V.,Thanuzkodi. E.,Murugan. S.	Block removed.		Rajasekari. R. - OPD	27/12/2022
	Comp. Dt. : 30/12/2022							
	Status : Completed							
2233	22121376	Paediatrics - OPD	DRINKING WATER TAP LEAKAGING PROBLEM	Prakash. V.,Rajendran. R.,Ramkumar. R.	CP long body tap fixed.		Subashree. R. - OPD	02/01/2023
	Comp. Dt. : 02/01/2023							
	Status : Completed							
2234	23010053	TB & Chest OPD	WATER TAP LOOSE CONNECTION IN WASH BASIN SINK	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	Wash basin tap tighten.		Jothi.R. - OPD	05/01/2023
	Comp. Dt. : 03/01/2023							
	Status : Completed							
2235	23010097	DENTAL OPD -2ND FLOOR	WATER NOT COMING IN WASH BASIN SINK TAP	Ramkumar. R.	Elbow action tap changed.		Priyadharshini. S. - OPD	05/01/2023
	Comp. Dt. : 04/01/2023							
	Status : Completed							
2236	23010124	IVF ART CLINIC-INSIDE OF OG OPD(NO.68)	IN PATIENT REST ROOM - RATS PROBLEM	Rajendhiran. V.	Housekeeping complaint.		Rajasekari. R. - OPD	06/01/2023
2237	23010153	GENERAL SURGERY OPD-55	IN ROOM NO.58-SINK WATER TAP LEAKAGING PROBLEM	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	Elbow action pillar cock changed.		Indhira. M. - OPD	05/01/2023
	Comp. Dt. : 05/01/2023							
	Status : Completed							
2238	23010230	DENTAL OPD -2ND FLOOR	DRAINAGE SMELL FROM WASH BASIN SINK	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	Wash basin sink block removed.		Lakshmi Devi. R. - OPD	06/01/2023
	Comp. Dt. : 10/01/2023							
	Status : Completed							
2239	23010394	Orthopaedics - OPD	NEED LABOURS FOR TABLE SHIFTING WORK	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	Table shifting work completed.		Durgadevi. J - OPD	13/01/2023
	Comp. Dt. : 14/01/2023							
	Status : Completed							
2240	23010599	Surgery OPD	NEED TO CHANGE TAP - DAMAGE - WATER LEAKAGE	Anandharaj. M.,Sivaraja. M.,Santhosh Kumar. M.	Tap rework done.		Indhira. M. - OPD	20/01/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 19/01/2023 Status : Completed								
2241	23010660	Surgery OPD	CLOSED WASH BASIN TAP CONNECTION NEED TO BE RECONNECT	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	Tap rework done.		Indhira. M. - OPD	20/01/2023
Comp. Dt. : 23/01/2023 Status : Completed								
2242	23010828	ENT OPD	NEED TO CHANGE WASH BASIN TAP - WATER LEAKAGE	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	Spindle changed.		Kamala.D. - OPD	24/01/2023
2243	23010837	Surgery OPD	RESTROOM BLOCK AT HOD ROOM	Rajendhiran. V.,Murugan. S.,Kathirvelu. K.	block removed.		Indhira. M. - OPD	23/01/2023
Comp. Dt. : 25/01/2023 Status : Completed								
2244	23010900	Orthopaedics - OPD	NEED MANPOWER 2NOS FOR TABLE SHIFTING WORK FROM WORKSHOP TO ORTHO OPD	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	Table shifting work completed		Durgadevi. J - OPD	28/01/2023
2245	23010908	ENT OPD	NEED TO CHECK DRAINAGE - BAD SMELL PROBLEM - AT HOD ROOM & ENT OPD SURROUNDING	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	Bad smell due to block in dining area.		Kamala.D. - OPD	27/01/2023
2246	23010934	DENTAL OPD -2ND FLOOR	NEED TO CHANGE WASH BASIN TAP - BROKEN - WATER LEAKAGE AT VIP ROOM	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	Tap rotate problem, tap repaired and serviced, refixed in properly, problem solved		Kanakarani. R. - OPD	27/01/2023
Comp. Dt. : 30/01/2023 Status : Completed								
2247	23011046	ENT OPD	DUE TO BAD SMELL PROBELM - NEED TO CLOSE SEPTIC TANK CLOSER AT BACKSIDE OF OPD	Rajendhiran. V.	Block removed		Ezhilarasi. M. - OPD	30/01/2023
2248	23011066	Orthopaedics - OPD	NEED MANPOWER 2NOS FOR TABLE SHIFTING WORK FROM OPD TO WORKSHOP	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	Tables shifting work done		Durgadevi. J - OPD	01/02/2023
Comp. Dt. : 02/02/2023 Status : Completed								
2249	23020047	COMMON TOILET NEAR OPHTAL OPD	BLOCK IN FEMALE RESTROOM	Rajendhiran. V.,Thanuzkodi. E.,Murugan. S.	Block removed.		Murugeshwari. V. - OPD	03/02/2023
Comp. Dt. : 04/02/2023 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2250	23020119	Work Shop	NEED MANPOWER 2NOS FOR TABLE SHIFTING WORK FROM WORKSHOP TO ORTHO OPD	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	Table shifting work completed		Durgadevi. J - OPD	07/02/2023
2251	23020127	General Medicine - OPD	NEED TO CHECK SINK DRAINAGE PIPELINE - BLOCK & BAD SMELL - ROOM NO 20	Murugan. S.	Block removed.		Bharathi.D. - OPD	06/02/2023
Comp. Dt. : 07/02/2023 Status : Completed								
2252	23020216	COMMON TOILET NEAR OPHTAL OPD	BLOCK IN FEMELE RESTROOM	Rajendhiran. V.,Thanuzkodi. E,Murugan. S.	BLOCK REMOVED.		Kamala.D. - OPD	08/02/2023
2253	23020228	IVF ART CLINIC-INSIDE OF OG OPD(NO.68)	RESTROOM BLOCK	Rajendhiran. V.	BLOCK REMOVED.		Rajasekari. R. - OPD	08/02/2023
Comp. Dt. : 08/02/2023 Status : Completed								
2254	23020302	GENERAL SURGERY OPD-55	DOCTORS RESTROOM BLOCK IN ROOM NO. 59	Rajendhiran. V.,Thanuzkodi. E,Murugan. S.	BLOCK REMOVED.		Indhira. M. - OPD	09/02/2023
Comp. Dt. : 10/02/2023 Status : Completed								
2255	23020390	OG-OPD	WASH BASIN TAP WATER LEAKAGE	Sivaraja. M.,Santhosh Kumar. M.,Gopal. S.	WASH BASIN TAP REWORK DONE		Velangkanni. K. - OPD	11/02/2023
Comp. Dt. : 13/02/2023 Status : Completed								
2256	23020494	COMMON MALE TOILET NEAR ORTHO OPD	NEED TO CHANGE RESTROOM TAP - BROKEN - WATER FLOW NEED URGENT SERVICE	Azhagar. N.,Sellaveeran. M.,Udhaya Kumar. R.	BLOCK REMOVED.		Durgadevi. J - OPD	15/02/2023
Comp. Dt. : 20/02/2023 Status : Completed								
2257	23020748	TB & Chest OPD	NEED CLEANING WORK [COBWEB]	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	HOUSE KEEPING COMPLAINT.....		Jothi.R. - OPD	21/02/2023
2258	23020759	PSYCHIATRY OPD	REST ROOM BLOCK & BAD SMELL - HOD ROOM RESTROOM	Rajendhiran. V.,Thanuzkodi. E,Murugan. S.	BLOCK REMOVED.		Kamala.D. - OPD	21/02/2023
Comp. Dt. : 22/02/2023 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2259	23020838	Orthopaedics - OPD	NEED MAN POWER--2NOS PATIENT STRUCTURE GOING TO WORKSHOP	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	STRUCTURE SHIFTED TO WORKSHOP		Durgadevi. J - OPD	22/02/2023
	Comp. Dt. : 23/02/2023							
	Status : Completed							
2260	23020911	OG-OPD	WATER NOT COMING	Azhagar. N.,Anandharaj. M.,Sellaveeran. M.	VALVE CLOSED AT TERRACE. VALVE OPENED.		Velangkanni. K. - OPD	24/02/2023
	Comp. Dt. : 24/02/2023							
	Status : Completed							
2261	23020936	PSYCHIATRY OPD	BLOCK IN WASH BASIN	Rajendhiran. V.,Murugan. S.,Thanuzkodi. E	BLOCK REMOVED		Kamala.D. - OPD	24/02/2023
	Comp. Dt. : 28/02/2023							
	Status : Completed							
2262	23021060	IVF ART CLINIC-INSIDE OF OG OPD(NO.68)	PATIENT REST ROOM BLOCK	Rajendhiran. V.,Thanuzkodi. E,Murugan. S.	BLOCK REMOVED.		Rajasekari. R. - OPD	01/03/2023
	Comp. Dt. : 02/03/2023							
	Status : Completed							
2263	23030093	DENTAL OPD -2ND FLOOR	NEED TO CHANGE TAP - DAMAGE - SPL CLINIC	Sivaraja. M.,Santhosh Kumar. M.,Anandharaj. M.	PILLAR COCK REWORK DONE.		Lakshmi Devi. R. - OPD	06/03/2023
	Comp. Dt. : 06/03/2023							
	Status : Completed							
2264	23030203	PSYCHIATRY OPD	BLOCK IN WASHBASIN - ROOM NO 75	Rajendhiran. V.,Thanuzkodi. E,Murugan. S.	BLOCK REMOVED.		Indumathi. T. - OPD	07/03/2023
	Comp. Dt. : 15/03/2023							
	Status : Completed							
2265	23030613	CTVS-ROOM NO.225 -2ND FLOOR	WASH BASIN DRAINAGE HOSE BLOCK	Rajendhiran. V.,Thanuzkodi. E,Murugan. S.	HOSE BLOCK REMOVED.		Suvitha. R. - OPD	16/03/2023
	Comp. Dt. : 17/03/2023							
	Status : Completed							
2266	23030694	Work Shop	NEED MANPOWER 3 NOS FOR SHIFTING [OPEN LOCKER] FROM WORKSHOP TO PAEDIATRIC OPD	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	OPEN LOCKER SHIFTED FROM WORKSHOP TO PAEDIATRIC OPD		Subashree. R. - OPD	17/03/2023
2267	23030711	Work Shop	NEED MANPOWER 2NOS FOR TABLE SHIFTING WORK	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	TABLE SHIFTING WORK DONE.		Durgadevi. J - OPD	20/03/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 24/03/2023 Status : Completed								
2268	23031014	Paediatrics - OPD	NEED LABOUR 1 NO FOR SCREEN REMOVING WORK	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	SCREEN REMOVING WORK COMPLETED		Subashree. R. - OPD	25/03/2023
Comp. Dt. : 27/03/2023 Status : Completed								
2269	23031118	Paediatrics - OPD	NEED LABOUR 1 NO FOR SCREEN REMOVING WORK	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	SCREEN REMOVING WORK COMPLETED		Subashree. R. - OPD	31/03/2023
Comp. Dt. : 28/03/2023 Status : Completed								
2270	23031144	OG-OPD	WATER LEAKAGE IN CEILING AT DOCTOR'S ROOM - NEED TO CHECK	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	EXPANSION JOINT PROBLEM		Velangkanni. K. - OPD	28/03/2023
Comp. Dt. : 30/03/2023 Status : Completed								
2271	23031297	COMMON TOILET NEAR OPHTAL OPD	RESTROOM TAP BROKEN	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	PVC TAP CHANGED.		Seetha. R. - OPD	31/03/2023
Comp. Dt. : 12/04/2023 Status : Completed								
2272	23040348	CTVS-ROOM NO.225 -2ND FLOOR	BLOCK IN WASH BASIN	Thanuzkodi. E.,Murugan. S.,Rajendhiran. V.	BLOCK REMOVED.		Suvitha. R. - OPD	13/04/2023
Comp. Dt. : 22/04/2023 Status : Completed								
2273	23040704	Surgery OPD	NEED TO CHANGE WASH BASIN DRAINAGE HOSE - WATER LEAKAGE	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	waste hose changed.		Indhira. M. - OPD	25/04/2023
Comp. Dt. : 26/04/2023 Status : Completed								
2274	23040863	Paediatrics - OPD	NEED TO CHANGE TAP - DAMAGE - WATER LEAKAGE AT VACCATION ROOM	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	PVC TAP CHANGED.		Subashree. R. - OPD	28/04/2023
2275	23040866	COMMON TOILET NEAR OPHTAL OPD	BLOCK INFEMALE RESTROOM - NEED URGENT SERVICE	Rajendhiran. V.,Thanuzkodi. E.,Murugan. S.	BLOCK REMOVED.		Kamala.D. - OPD	27/04/2023
Comp. Dt. : 28/04/2023 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2276	23040955	IVF ART CLINIC-INSIDE OF OG OPD(NO.68)	BLOCK IN PATIENT RESTROOM	Rajendhiran. V.,Thanuzkodi. E,Murugan. S.	block removed.		Nagalakshmi. M. - OPD	03/05/2023
		Comp. Dt. : 12/05/2023 Status : Completed						
2277	23050478	NEUROLOGY	NEED TO CHECK CEILING - WATER LEAKAGE	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	A/C DEPARTMENT COMPLAINT		Radhika. R. - OPD	13/05/2023
		Comp. Dt. : 06/06/2023 Status : Completed						
2278	23060179	RMO Office	WATER NOT COMING	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	WASH BASIN BLOCK REMOVED.		Jothi.R. - OPD	06/06/2023
2279	23060195	TB & Chest OPD	NEED TO CHECK TAP - WATER LEAKAGE	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	TAP CHANGED.		Jothi.R. - OPD	08/06/2023
		Comp. Dt. : 07/06/2023 Status : Completed						
2280	23060224	Ophthalmology - OPD	WASH BASIN & HAND WASH - WATER NOT COMING - FROM OPHTHAL OPD TO DERMO OPD	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	VALVE OPENED. PROBLEM RECTIFIED.		Kamala.D. - OPD	08/06/2023
		Comp. Dt. : 09/06/2023 Status : Completed						
2281	23060310	OG-OPD	R O WATER NOTCOMING	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	PIPE LINE CONNECTION REWORK DONE.		Velangkanni. K. - OPD	10/06/2023
		Comp. Dt. : 12/06/2023 Status : Completed						
2282	23060382	DRESSING ROOM NEAR SURGERY OPD	NEED MANPOWER 4 NOS FOR BERO SHIFTING WORK FOR REPAIRING WORK - FROM DRESSING OPD NO 53 TO WORKSHOP	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	BERO SHIFTING WORK COMPLETED		Badmasri. P. - OPD	15/06/2023
		Comp. Dt. : 13/06/2023 Status : Completed						
2283	23060460	OG-OPD	NEED TO CHANGE SINK TAP - WATER LEAKAGE	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	TAP REWORK DONE		Adhilakshmi. A. - OPD	14/06/2023
		Comp. Dt. : 19/06/2023 Status : Completed						


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2284	23060668	OG-OPD	FLUSH WATER LEAKAGE - NEED TO CHECK	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	flush tank rework done		Nagalakshmi. M. - OPD	20/06/2023
Comp. Dt. : 21/06/2023 Status : Completed								
2285	23060741	Orthopaedics - OPD	NEED TO CHECK WASH BASIN TAP - WATER NOT COMING - ROOM NO 66	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	pvc pillar cock tap changed.		Durgadevi. J - OPD	24/06/2023
2286	23060759	Gas Power Plant	NEED MANPOWER 3 NOS FOR SHIFTING CYLINDER FROM GAS PLANT TO IVF	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	Cylinder shifted from gas plant to IVF		Rajasekari. R. - OPD	28/06/2023
Comp. Dt. : 24/06/2023 Status : Completed								
2287	23060911	NEUROLOGY OPD-2ND FLOOR	DEILING - WATER LEAKAGE	Vengatesan. V.,Anandharaj. M.,Udhaya Kumar. R.	AC water draining through the expansion joint.		Radhika. R. - OPD	24/06/2023
Comp. Dt. : 26/06/2023 Status : Completed								
2288	23060937	NEUROLOGY OPD-2ND FLOOR	CEILING WATER LEAKAGE [AGAIN]	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	A/C line water leakage.		Radhika. R. - OPD	27/06/2023
Dept Name : Operation Theatre - Civil - Maintenance Comp. Dt. : 05/05/2022 Status : Completed								
2289	22050117	EMERGENCY OT NEAR CASUALTY	NEED TO CHANGE SINK TAP - WATER LEAKAGE & SINK OUTLET HOSE LEAKAGE	Prakash. V.,Manikandan. S.,Rajendran. R.	2/4 wast line rework		Hemalatha.G. - Operation Theatre	05/05/2022
Comp. Dt. : 09/05/2022 Status : Completed								
2290	22050268	OG OT	NEED TO CHANGE TAP - BROKEN AND DAMAGE	Prakash. V.,Ramkumar. R.,Manikandan. S.	elbow axin tap chaing work		Sathia. R. - Operation Theatre	09/05/2022
Comp. Dt. : 16/05/2022 Status : Completed								
2291	22050574	ORTHO OT	WASH BASIN OUTLET HOSE BLOCK	Rajendhiran. V.	Block removed.		Bhuvaneswari. I. - Operation Theatre	17/05/2022
Comp. Dt. : 17/05/2022 Status : Completed								
2292	22050616	OG OT	BLOCK IN WASH BASIN	Prakash. V.	Block removed		Amudha. V. - Operation Theatre	17/05/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 19/05/2022 Status : Completed								
2293	22050721	SPECIALITY OT	NEED CONNECTION WORK FOR HEATER AT DEMO ROOM	Ramkumar. R.,Prakash. V.,Rajendran. R.	Heater line connection given, problem solved		Sobiya. N. - Operation Theatre	21/05/2022
2294	22050728	New OT	BLOCK IN RESTROOM	Rajendran. R.	Toilet block removed, work completed		Shankari. G. - Operation Theatre	21/05/2022
Comp. Dt. : 14/06/2022 Status : Completed								
2295	22060486	Main OT	NEED TO CHECK SINK OUTLET WATER PIPE LINE - LEAKAGE AT WASHING AREA -2	Prakash. V.,Arunagiri. V.,Manikandan. S.	1.1/4" pipe line rework		Ayisha Bee. M. A. - Operation Theatre	14/06/2022
2296	22060498	Casualty	BLOCK IN SINK - ROOM NO 38 [DRESSING ROOM]	Rajendhiran. V.	Block removed.		Murugu. V. - Operation Theatre	14/06/2022
Comp. Dt. : 23/06/2022 Status : Completed								
2297	22060824	Casualty	SINK BLOCK ROOM NO 38	Govindan. R.,Rajendhiran. V.,Sakthivel. E.	Sink block removed.		Murugu. V. - Operation Theatre	24/06/2022
Comp. Dt. : 30/06/2022 Status : Completed								
2298	22061124	OG OT	TAP WATER NOT COMING	Prakash. V.,Arunagiri. V.,Manikandan. S.	Valve closed in terrace for tap changing purpose, after finishing work valve opened, problem solved		Ranjani. V. - Operation Theatre	30/06/2022
Comp. Dt. : 04/07/2022 Status : Completed								
2299	22070105	SPECIALITY OT	NEED TO PLACE " RED STTRICKER" FOR OT	Prakash. V.	Red sticker pasted		Sobiya. N. - Operation Theatre	07/07/2022
Comp. Dt. : 06/07/2022 Status : Completed								
2300	22070187	OG OT	NEED TO CHANGE FLUSH - BROKEND AND WATER LEAKAGE AT MALE	Prakash. V.,Ramkumar. R.,Arunagiri. V.	Flush tank rework done		Sasikala. S. - Operation Theatre	07/07/2022
Comp. Dt. : 14/07/2022 Status : Completed								
2301	22070556	OG OT	DRAINAGE HOSE DAMAGE & BROKE WATER OVERFLOW - NEED URGENT SERVICE	Prakash. V.,Ramkumar. R.,Rajendran. R.	1.1/4" waste coupling changed, work completed	 Dr. KAGNE. R.N DEAN SRI MANAKULA VINAYAGAR MEDICAL COLLEGE & HOSPITAL KALITHEERTHAL KUPPAM, PUDUCHERRY-605107.	Amudha. V. - Operation Theatre	16/07/2022

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
2302	22070749	SPECIALITY OT	WATER NOT COMING IN RECOVERY ROOM WASH BASIN	Prakash. V.,Rajendran. R.,Manikandan. S.	Water empty in water tank. Water filled in the tank		Jayapratha. S. - Operation Theatre	22/07/2022
Comp. Dt. : 25/07/2022								
Status : Completed								
2303	22070923	OG OT	SINK BLOCK - DRAINAGE HOSE DAMAGE & BROKEN -WATER LEAKAGE	Rajendhiran. V.,Thanuzkodi. E.,Murugan. S.	block removed.		Amudha. V. - Operation Theatre	26/07/2022
Comp. Dt. : 02/08/2022								
Status : Completed								
2304	22080054	ORTHO OT	NEED TO CHANGE TAP FOR SCRUB AREA - WATER LEAKAGE	Prakash. V.	Tap rework done.		Bhuvaneswari. I. - Operation Theatre	03/08/2022
Comp. Dt. : 06/08/2022								
Status : Completed								
2305	22080234	Main OT	NEED TO CHANGE TAP - SOUND & WATER LEAKAGE AT SCRUB AREA & RESTROOM	Prakash. V.,Rajendran. R.,Ramkumar. R.	New Tap changed, work completed		Shankari. G. - Operation Theatre	09/08/2022
Comp. Dt. : 09/08/2022								
Status : Completed								
2306	22080299	OG OT	NEED LABOURS 2 NOS FOR SHIFTING UNWANTED BROKENED DOOR GLASS FROM OG OT TO WORKSHOP	Pandiaraj. V.,Thulasi. V.,Prakash. N.	Shifting work completed		Amudha. V. - Operation Theatre	11/08/2022
Comp. Dt. : 18/08/2022								
Status : Completed								
2307	22080559	OG OT	PIPELINE WATER LEAKAGE	Prakash. V.,Rajendran. R.,Ramkumar. R.	Tap rework done		Subashini. E. - Operation Theatre	18/08/2022
Comp. Dt. : 19/08/2022								
Status : Completed								
2308	22080608	New OT	FLUSH NOT WORKING(BROKEN) IN DOCTORS RESTROOM	Prakash. V.,Rajendran. R.,Ramkumar. R.	flush tank rework		Udhaya Kumar. C. - Operation Theatre	24/08/2022
Comp. Dt. : 20/08/2022								
Status : Completed								
2309	22080658	ORTHO OT	NEED TO CHANGE TAP - TAP DAMAGE & WATER LEAKAGE	Prakash. V.,Rajendran. R.,Ramkumar. R.	Tap changed		Mukeshkannan. M. - Operation Theatre	26/08/2022

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHAL KUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 23/08/2022 Status : Completed								
2310	22080741	SURGERY OT	TAP BROKEN - NEED TO CHANGE TAP AT PATIENT WAITING ROOM WASHING AREA	Prakash. V.,Rajendran. R.,Ramkumar. R.	Wash basin rework done.		Ramachandiran. M. - Operation Theatre	24/08/2022
2311	22080751	SPECIALITY OT	BLOCK IN SINK AT FEMALE DRESS CHANGING ROOM	Rajendhiran. V.,Thanuzkodi. E.,Murugan. S.	Block removed.		Evangelin. S. - Operation Theatre	24/08/2022
Comp. Dt. : 24/08/2022 Status : Completed								
2312	22080800	SURGERY OT	NEED TO CHANGE TAP - WATER LEAKAGE AT PATIENT WAITING ROOM	Prakash. V.,Ramkumar. R.,Arunagiri. V.	tap changed.		Ramachandiran. M. - Operation Theatre	26/08/2022
Comp. Dt. : 08/09/2022 Status : Completed								
2313	22090310	ORTHO OT	NEED TO CHANGE TAP AT INSIDE OT - DAMAGE & NOT CLOSING PROPER	Prakash. V.,Rajendran. R.,Ramkumar. R.	elbow action tap fixed		Shankari. G. - Operation Theatre	22/09/2022
Comp. Dt. : 15/09/2022 Status : Completed								
2314	22090598	ORTHO OT	WATER POURING FASTLY IN TAP	Rajendran. R.,Arunagiri. V.,Prakash. V.	Angle valve rework and refixed in properly, problem solved		Mahalakshmi. G. - Operation Theatre	17/09/2022
Comp. Dt. : 16/09/2022 Status : Completed								
2315	22090658	Main OT	BLOCK IN SCRUB AREA	Rajendhiran. V.,Murugan. S.,Sakthivel. E.	Scrub area block removed, work completed		Shankari. G. - Operation Theatre	17/09/2022
Comp. Dt. : 17/09/2022 Status : Completed								
2316	22090666	ORTHO OT	AQUA GUARD NOT WORKING - OT NO 3	Prakash. V.	Informed to company.		Shankari. G. - Operation Theatre	19/09/2022
Comp. Dt. : 24/09/2022 Status : Completed								
2317	22090967	ORTHO OT	AQUAGUARD IN 3RD OT NOT WORKING	Arunagiri. V.	Old aquaguard removed. Quotation given to purchase new aquaguard		Mahalakshmi. G. - Operation Theatre	12/10/2022
Comp. Dt. : 30/09/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2318	22091196	Main OT	BLOCK IN SINK	Rajendhiran. V.,Murugan. S.,Thanuzkodi. E	Block removed.		Shankari. G. - Operation Theatre	01/10/2022
Comp. Dt. : 05/10/2022 Status : Completed								
2319	22100063	SURGERY OT	WASH BASIN WATER BLOCK	Rajendhiran. V.,Murugan. S.,Thanuzkodi. E	Block removed.		Jagatheeswaran. G. - Operation Theatre	07/10/2022
Comp. Dt. : 06/10/2022 Status : Completed								
2320	22100089	New OT	SINK BLOCK IN WASHING AREA	Rajendhiran. V.,Murugan. S.,Thanuzkodi. E	Block removed.		Kousalya. S. - Operation Theatre	07/10/2022
Comp. Dt. : 17/10/2022 Status : Completed								
2321	22100551	ORTHO OT	NEED TO CHECK AQUA GUARD - WATER NOT COMING & LEAKAGE	Prakash. V.,Rajendran. R.,Ramkumar. R.	Aqua guard refixed.		Mahalakshmi. G. - Operation Theatre	19/10/2022
Comp. Dt. : 02/11/2022 Status : Completed								
2322	22110029	Main OT	STAFF TOILET BLOCK,NEED SCAVENGER	Rajendhiran. V.,Thanuzkodi. E,Murugan. S.	Block removed.		Shankari. G. - Operation Theatre	03/11/2022
2323	22110040	EMERGENCY OT NEAR CASUALTY	WASH BASIN SINK LEAKAGING PROBLEM	Ramkumar. R.,Arunagiri. V.,Abdul Azees. J.	PVC connection tube changed.		Hemalatha.G. - Operation Theatre	04/11/2022
Comp. Dt. : 04/11/2022 Status : Completed								
2324	22110134	SPECIALITY OT	SIDE CORRIDOR WATER LEAKAGING PROBLEM	Manikandan. S.,Arunagiri. V.,Prakash. V.	Expansion joint water leakage due to heavy rain.		Jayapratha. S. - Operation Theatre	05/11/2022
Comp. Dt. : 05/11/2022 Status : Completed								
2325	22110173	Main OT	REST ROOM BLOCK,NEED SCAVENGER	Rajendhiran. V.,Thanuzkodi. E,Murugan. S.	blocks removed.		Ayisha Bee. M. A. - Operation Theatre	08/11/2022
Comp. Dt. : 22/11/2022 Status : Completed								
2326	22110930	ORTHO OT	FLUSH NOT WORKING AT MALE STAFF REST ROOM & DOCTOR'S ROOM	Prakash. V.,Rajendran. R.,Ramkumar. R.	Flush tank fullset rework, work completed		Mahalakshmi. G. - Operation Theatre	24/11/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 26/11/2022								
Status : Completed								
2327	22111154	SPECIALITY OT	WASH BASIN SINK TAP BROKEN IN STAFF ROOM	Prakash. V.,Rajendran. R.,Ramkumar. R.	Tap rework done.		Jayapratha. S. - Operation Theatre	01/12/2022
2328	22111155	SPECIALITY OT	IN PATINET WAITING REST ROOM-TAP FIXED CLAMP NEED TO BE REFIX	Prakash. V.,Rajendran. R.,Ramkumar. R.	Clamp fixed		Jayapratha. S. - Operation Theatre	01/12/2022
Comp. Dt. : 28/11/2022								
Status : Completed								
2329	22111191	ORTHO OT	URINAL BLOCK PATIENT RESTROOM	Rajendhiran. V.,Murugan. S.,Thanuzkodi. E	block removed.		Mahalakshmi. G. - Operation Theatre	30/11/2022
Comp. Dt. : 01/12/2022								
Status : Completed								
2330	22120040	SPECIALITY OT	SINK BLOCK	Rajendhiran. V.,Thanuzkodi. E,Murugan. S.	Sink block removed.		Anitha. R. - Operation Theatre	02/12/2022
Comp. Dt. : 06/12/2022								
Status : Completed								
2331	22120216	New OT	SINK BLOCK AT SCRUB AREA AT OT NO 7	Rajendhiran. V.,Thanuzkodi. E,Murugan. S.	2 nos. scrub block removed.		Kousalya. S. - Operation Theatre	06/12/2022
Comp. Dt. : 26/12/2022								
Status : Completed								
2332	22121140	OG OT	WATER LEAKAGE	Ramkumar. R.,Manikandan. S.,Arunagiri. V.	CP Elbow action tap changed, problem solved		Sathia. R. - Operation Theatre	26/12/2022
2333	22121141	OG OT	FLUSH NOT WORKING IN STAFF REST ROOM	Manikandan. S.,Arunagiri. V.,Sankar. V.	Flush tank fullset rework, work completed		Sathia. R. - Operation Theatre	26/12/2022
2334	22121189	Main OT	SINK WATER LEAKAGE	Prakash. V.,Rajendran. R.,Ramkumar. R.	Elbow action tap, flush tank, seat cover changed.		Malathi. M. - Operation Theatre	27/12/2022
Comp. Dt. : 20/01/2023								
Status : Completed								
2335	23010742	SPECIALITY OT	NEED TO CHECK FLUSH KEY BROKEN & SINK BLOCK AT FEMALE RESTROOM	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	Sink block removed and health faucet changed.		Saravanan. P. - Operation Theatre	21/01/2023
Comp. Dt. : 28/01/2023								
Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2336	23011030	ORTHO OT	NEED TO CHECK & CLEANING WORK - BAD SMELL	Santhosh Kumar. M.	Wash basin Block removed		Mahalakshmi. G. - Operation Theatre	30/01/2023
	Comp. Dt. : 06/02/2023							
	Status : Completed							
2337	23020201	ORTHO OT	SINK BLOCK - INSIDE MALE SIDE ROOM	Thanuzkodi. E	BLOCK REMOVED.		Mahalakshmi. G. - Operation Theatre	07/02/2023
	Comp. Dt. : 14/02/2023							
	Status : Completed							
2338	23020563	Main OT	RESTROOM WASH BASIN WATER LEAKAGE	Azhagar. N., Sellaveeran. M., Sivaraja. M.	WASH BASIN PILLAR COCK CHANGED.		Shankari. G. - Operation Theatre	24/02/2023
	Comp. Dt. : 15/02/2023							
	Status : Completed							
2339	23020604	SPECIALITY OT	NEED TO CHECK WALL - WATER LEAKAGE AT EMERGENCY OT INSIDE WALL	Azhagar. N., Sellaveeran. M., Udhaya Kumar. R.	EXPANSION JOINT PROBLEM		Harine. S. - Operation Theatre	17/02/2023
	Comp. Dt. : 20/02/2023							
	Status : Completed							
2340	23020766	UROLOGY	FLUSH NOT WORKING IN FEMALE DOCTOR'S RESTROOM - UROLOGY OT	Azhagar. N., Sellaveeran. M., Udhaya Kumar. R.	FLUSH TANK REWORK DONE.		Banupriya. M. - Operation Theatre	22/02/2023
	Comp. Dt. : 02/03/2023							
	Status : Completed							
2341	23030107	OG OT	NEED TO CHANGE TAP - WATER LEAKAGE AT FEMALE DOCTOR'S ROOM	Anandharaj. M., Azhagar. N., Sellaveeran. M.	EXPANSION JOINT LEAKAGE.		Ranjani. V. - Operation Theatre	03/03/2023
	Comp. Dt. : 11/03/2023							
	Status : Completed							
2342	23030446	New OT	NEED TO CHECK WATER PIPE LINE - WATER NOT COMING AT PATENT , FEMALE DOCTOR & MALE DOCTOR RESTROOMS	Anandharaj. M., Azhagar. N., Sellaveeran. M.	FLUSH TANK, HEALTH FAUCET REWORK DONE. TAP BLOCK REMOVED.		Punitha. A. - Operation Theatre	14/03/2023
	Comp. Dt. : 21/03/2023							
	Status : Completed							
2343	23030872	SPECIALITY OT	DUE TO RAT & COCKROACH PROBLEM NEED TO SPRAY INSECT SPRAY	Govindan. R.	INSECTICIDE SPRAYED.		Hemalatha. G. - Operation Theatre	25/03/2023

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 01/04/2023 Status : Completed								
2344	23040006	SPECIALITY OT	BLOCK IN DOCTOR'S REST ROOM - NEED URGENT SERVICE	Sakthivel. E.,Govindan. R.,Rajendhiran. V.	BLOCK REMOVED.		Anitha. R. - Operation Theatre	01/04/2023
Comp. Dt. : 04/04/2023 Status : Completed								
2345	23040112	OG OT	NEED TO CHECK & CHANGE HAND FLUSH AT DOCTOR'S ROOM - DAMAGE	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	New Health faucet changed, work completed		Manibharathi. S. - Operation Theatre	19/04/2023
Comp. Dt. : 11/04/2023 Status : Completed								
2346	23040329	SPECIALITY OT	FLUSH KEY NOT WORKING - WATER NOT COMING	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	Flush key and flush tank fullset rework, work completed		Anitha. R. - Operation Theatre	19/04/2023
Comp. Dt. : 17/04/2023 Status : Completed								
2347	23040528	New OT	FLUSH NOT WORKING [OT INSIDE RESTROOM]	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	Flush tank fullset rework, work completed		Logesh. D. - Operation Theatre	19/04/2023
Comp. Dt. : 02/05/2023 Status : Completed								
2348	23050024	ORTHO OT	NEED TO CHANGE TAP - BROKEN & WATER FLOW IN RESTROOM	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	TAP BLOCK REMOVED.		Logesh. M. - Operation Theatre	03/05/2023
Comp. Dt. : 22/05/2023 Status : Completed								
2349	23050890	OG OT	NEED TO CHANGE TAP - DAMAGE WATER LEAKAGE - [INSIDE OT]	Azhagar. N.	FLUSH TANK REWORK DONE.		Avina. A. - Operation Theatre	23/05/2023
Comp. Dt. : 27/05/2023 Status : Completed								
2350	23051087	New OT	FLUSH TANK WATER LEAKAGE AT HOD ROOM	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	FLUSH TANK REWORK DONE.		Punitha. A. - Operation Theatre	29/05/2023
Comp. Dt. : 01/06/2023 Status : Completed								
2351	23060025	New OT	FLUSH TANK ,KEY NOT WORKING AT DOCTOR'S REST ROOM	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	PSYPHONIC SET CHANGED.		uppan.E. - Operation Theatre	03/06/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 13/06/2023 Status : Completed								
2352	23060438	Main OT	Need to change the filters in all the Aqua Gaurd.	Sivaraja. M.,Santhosh Kumar. M.,Gopal. S.	Carbon and mica filters changed in three Aqua Gaurd.		Logesh. M. - Operation Theatre	16/06/2023
2353	23060453	New OT	R O [DRINKING WATER] NOT COMING	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	TANK WAS EMPTY DUE TO THE POWER SUPPLY		Punitha. A. - Operation Theatre	14/06/2023
Comp. Dt. : 23/06/2023 Status : Completed								
2354	23060854	ORTHO OT	FLUSH NOT WORKING - DOCTOR'S RESTROOM - NEED URGENT SERVICE	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	Flush tank rework done.		Mahalakshmi. G. - Operation Theatre	24/06/2023
Dept Name : ORTHOPAEDICS - Civil - Maintenance Comp. Dt. : 27/05/2022 Status : Completed								
2355	22051023	COMMON MALE TOILET NEAR ORTHO OPD	BLOCK IN MALE RESTROOM	Thanuzkodi. E	block remover		Manjula. P. - ORTHOPAEDICS	27/05/2022
Comp. Dt. : 04/08/2022 Status : Completed								
2356	22080176	Orthopaedics - OPD	NEED LABOURS FOR THINGS SHIFTING WORK	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	shifting work completed.		Manjula. P. - ORTHOPAEDICS	11/08/2022
Comp. Dt. : 04/01/2023 Status : Completed								
2357	23010186	Orthopaedics - OPD	NEED LABOURS FOR DOOR SHIFTING PURPOSE	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	Door shifting work completed.		Manjula. P. - ORTHOPAEDICS	06/01/2023
Dept Name : P.H.C. - Tiruvonnainallur - Civil - Maintenance Comp. Dt. : 05/05/2022 Status : Completed								
2358	22050162	Thiruvonnainallur	NEED PLUMBER HELP FOR FIXING URINAL & OTHER RAPAIRING WORK	Prakash. V.	Urinal block removed and all rooms were checked.		Kanagasabai. D. - P.H.C. - Tiruvonnainallur	09/05/2022
Comp. Dt. : 23/09/2022 Status : Completed								
2359	22090952	Thiruvonnainallur	URINAL BLOCK AND NEED PLUMBER HELP	Prakash. V.	All floor plumbing work completed.		Kanagasabai. D. - P.H.C. - Tiruvonnainallur	18/10/2022
Comp. Dt. : 02/02/2023 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2360	23020064	Thiruvannainallur	NEED TO CHANGE TAP 2 NOS & FLUSH 4 NOS - BROKEN & RESTROOM BLOCK NEED URGENT SERVICE	Prakash. V.,Rajendran. R.,Manikandan. S.	TAP (2NOS) AND FLUSH (4NOS) CHANGED. BLOCK REMOVED.		Kanagasabai. D. - P.H.C. - Tiruvannainallur	02/03/2023
Dept Name : PAEDIATRICS - Civil - Maintenance Comp. Dt. : 03/01/2023 Status : Completed								
2361	23010066	Paediatrics - OPD	AURO WATER BLOCK (PAEDIATRICS OPD BACKSIDE)	Anandharaj. M.,Sellaveeran. M.,Azhagar. N.	Block removed.....		Manju @ Brinda. V. - PAEDIATRICS	05/01/2023
Comp. Dt. : 06/01/2023 Status : Completed								
2362	23010268	Paediatrics - OPD	Need to fix grating at ladies toilet.	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	New Grating fixed at ladies toilet.		Manju @ Brinda. V. - PAEDIATRICS	06/01/2023
Comp. Dt. : 23/01/2023 Status : Completed								
2363	23010803	Paediatrics - OPD	NEED TO CHECK WINDOW SIDE WALL AT OPD - WATER LEAKAGE INSIDE THE OPD - NEED URGENT SERVICE	Anandharaj. M.	Water leakage from the new building construction. No anyother problem.		Manju @ Brinda. V. - PAEDIATRICS	24/01/2023
Comp. Dt. : 01/02/2023 Status : Completed								
2364	23020010	Paediatrics - OPD	SAND BLOCK IN R O WATER TANK - NEED TO CLEAR	Balam. B.,Agilan. P.,Rajendhiran. V.	Outlet pipeline block removed.		Manju @ Brinda. V. - PAEDIATRICS	02/02/2023
Dept Name : Paediatrics Ward - Civil - Maintenance Comp. Dt. : 28/06/2022 Status : Completed								
2365	22061032	Female Medical - Ward 305	NEED LABOURS 3 NOS FOR SHIFTING FRIDGE FROM GENERAL STORE TO FEMALE MEDICINE WARD INSIDE H I C C	Pandiaraj. V.,Yuvaraj. M.,Murali. K.	Fridge shifting work completed		Anitha. N. - Hospital Infection Control	01/07/2022
Comp. Dt. : 13/07/2022 Status : Completed								
2366	22070500	Paediatrics - Ward 309	BLOCK AT PATIENT RESTROOM & WASH BASIN	Thanuzkodi. E	Block removed		Chitra. P. - Paediatrics Ward	14/07/2022
Comp. Dt. : 21/07/2022								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
2367	22070802	Paediatrics - Ward 309	CEILING WATER LEAKAGE AT FAN CONNECTING WALL - NEED TO CHECK	Prakash. V.,Rajendran. R.,Ramkumar. R.	Expansion joint problem.		Naveena. N. - Paediatrics Ward	26/07/2022
Comp. Dt. : 27/09/2022								
Status : Completed								
2368	22091090	Paediatrics - Ward 309	NEED TO REFIX WASH BASIN ELBOW TAP AT DUTY DOCTOR'S ROOM	Rajendran. R.,Ramkumar. R.,Arunagiri. V.	Connection tube changed and elbow action tap rework.		Chitra. P. - Paediatrics Ward	28/09/2022
Comp. Dt. : 30/09/2022								
Status : Completed								
2369	22091211	Paediatrics - Ward 310	BLOCK IN RESTROOM	Rajendhiran. V.,Murugan. S.,Thanuzkodi. E	Block removed.		Chitra. P. - Paediatrics Ward	01/10/2022
Comp. Dt. : 03/11/2022								
Status : Completed								
2370	22110089	Paediatrics - Ward 309	TOILET BLOCKED,NEED SCAVENGER	Murugan. S.,Rajendhiran. V.,Thanuzkodi. E	Block removed.		Chitra. P. - Paediatrics Ward	03/11/2022
2371	22110090	Paediatrics - Ward 310	WASH BASIN SINK TAP BROKEN	Prakash. V.,Rajendran. R.,Ramkumar. R.	Wash basin pillar cock rework.		Chitra. P. - Paediatrics Ward	04/11/2022
Comp. Dt. : 09/11/2022								
Status : Completed								
2372	22110356	Paediatrics - Ward 310	WASH BASIN SINK TAP WATER LEAKAGING PROBLEM	Prakash. V.,Rajendran. R.,Ramkumar. R.	Tap rework done.		Naveena. N. - Paediatrics Ward	10/11/2022
2373	22110370	Paediatrics - Ward 309	WASH BASIN SINK HOSE LEAKAGING PROBLEM	Prakash. V.,Rajendran. R.,Ramkumar. R.	Wash basin waste water outlet line fully rework, work completed		Chitra. P. - Paediatrics Ward	14/11/2022
Comp. Dt. : 10/11/2022								
Status : Completed								
2374	22110410	Paediatrics - Ward 309	WASH BASIN SINK HOSE WATER LEAKAGING PROBLEM	Rajendran. R.,Manikandan. S.,Sankar. V.	Wash basin waste water outlet line fully rework, work completed		Naveena. N. - Paediatrics Ward	14/11/2022
Comp. Dt. : 18/11/2022								
Status : Completed								
2375	22110792	Paediatrics - Ward 308	NEED TO CHECK FLOOR - WATER LEAKAGE - NEED URGENT SERVICE	Prakash. V.,Rajendran. R.,Ramkumar. R.	Expansion joint water leakage		Chitra. P. - Paediatrics Ward	23/11/2022
Comp. Dt. : 19/11/2022								
Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2376	22110826	Paediatrics - Ward 308	NEED MANPOWER FOR COT ARRANGEMENTS WORK	Pandiaraj. V., Yuvaraj. M., Thulasi. V.	Cot arrangement work completed		Chitra. P. - Paediatrics Ward	21/11/2022
Comp. Dt. : 21/11/2022 Status : Completed								
2377	22110847	Paediatrics - Ward 308	NEED LABOURS 2 NO'S FOR SCREEN FIXING WORK IN 307 AND 308 WARD	Pandiaraj. V.	Screen fixing work completed.		Rajeswari. P. - Paediatrics Ward	22/11/2022
Comp. Dt. : 22/11/2022 Status : Completed								
2378	22110953	Paediatrics Ward	NEED LABOURS 4 NOS FOR WARD REARRANGEMENT WORK - WARD NO 307 & 308	Pandiaraj. V., Yuvaraj. M., Senthil Kumar. R.	Ward rearrangement work done.		Chitra. P. - Paediatrics Ward	25/11/2022
Comp. Dt. : 28/11/2022 Status : Completed								
2379	22111168	Paediatrics - Ward 308	NEED LABOURS 2 NO'S FOR SCREEN REMOVING WORK	Pandiaraj. V.	Screen removed.		Chitra. P. - Paediatrics Ward	01/12/2022
Comp. Dt. : 30/11/2022 Status : Completed								
2380	22111257	Female Medical - Ward 307	WATER LEAKAGE IN WASH BASIN DRAINAGE PIPE LINE & WASH BASIN - NEED TO CHECK & CHANGE AT PAEDOATRIC	Rajendran. R., Manikandan. S., Sankar. V.	Wash basin drain pipe line connection rework done.		Chitra. P. - Paediatrics Ward	01/12/2022
Comp. Dt. : 10/12/2022 Status : Completed								
2381	22120494	Paediatrics - Ward 308	TOILET BLOCKED, NEED SCAVENGER	Rajendhiran. V., Thanuzkodi. E., Murugan. S.	block removed.		Rajeswari. P. - Paediatrics Ward	12/12/2022
Comp. Dt. : 30/12/2022 Status : Completed								
2382	22121365	Paediatrics - Ward 308	TOILET BLOCKED, NEED SCAVENGER	Rajendhiran. V.	Block removed.		Rajeswari. P. - Paediatrics Ward	31/12/2022
Comp. Dt. : 03/01/2023 Status : Completed								
2383	23010091	Female Medical ward 307	WATER LEAKAGING FROM CEILING	Santhosh Kumar. M., Sivaraja. M., Azhagar. N.	Expansion joint problem.		Naveena. N. - Paediatrics Ward	05/01/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 04/01/2023 Status : Completed								
2384	23010190	Paediatrics - Ward 309	NEED LABOURS FOR SCREEN REFIXING WORK	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	Screen refixing work completed.		Chitra. P. - Paediatrics Ward	09/01/2023
Comp. Dt. : 06/02/2023 Status : Completed								
2385	23020177	Paediatrics Ward	RESTROOM WATER LEAKAGE - WARD NO. 307	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	WATER LEAK ARREST		Chitra. P. - Paediatrics Ward	07/02/2023
Comp. Dt. : 25/02/2023 Status : Completed								
2386	23020990	Paediatrics - Ward 308	RESTROOM BLOCK - WATER PIPELINE LEAKAGE	Rajendhiran. V.,Thanuzkodi. E,Murugan. S.	BLOCK REMOVED.		Naveena. N. - Paediatrics Ward	27/02/2023
Comp. Dt. : 01/03/2023 Status : Completed								
2387	23030008	Paediatrics - Ward 308	BLOCK IN RESTROOM	Rajendhiran. V.,Thanuzkodi. E,Murugan. R.	BLOCK REMOVED.		Kayalvizhi. G. - Paediatrics Ward	01/03/2023
Comp. Dt. : 26/05/2023 Status : Completed								
2388	23051070	Male Medical - Ward 302	NEED TO CHANGE TAP - BROKEN AT PATIENT REST ROOM	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	Tap rework and refixed in properly, problem solved		Sosilistha. C. - Paediatrics Ward	30/05/2023
Comp. Dt. : 30/05/2023 Status : Completed								
2389	23051170	Female Medical - Ward 307	FLUSH NOT WORKING AT PAEDIATRIC WARD NO 307 EXAM HALL	Sivaraja. M.,Udhaya Kumar. R.,Gopal. S.	BOTTOM WASHER CHANGED. FLUSH TANK REWORK DONE.		Chitra. P. - Paediatrics Ward	01/06/2023
Comp. Dt. : 13/06/2023 Status : Completed								
2390	23060451	Female Ortho - Ward 402	NEED TO CHANGE TAP - BROKEN AT RESTROOM & SINK BLOCK	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	WASH BASIN WASTE HOSE CHANGED.		Sivasankari. A. - Paediatrics Ward	14/06/2023
Comp. Dt. : 30/06/2023 Status : Completed								
2391	23061092	Female Medical - Ward 307	FLUSH WATER NON STOP - NEED TO CHECK - [PAEDIATRIC 307]	Azhagar. N.,Sellaveeran. M.,Udhaya Kumar. R.	Flush tank rework done and block removed.		Chitra. P. - Paediatrics Ward	30/06/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Dept Name : PATHOLOGY - Civil - Maintenance Comp. Dt. : 30/08/2022 Status : Completed								
2392	22081028	PATHOLOGY IN COLLEGE	NEED PLUMBER FOR PIPELINE ALTER WORK	Udhaya Kumar. R.	3/4" UPVC pipe line and 1.1/2" waste water pipe line fully changed for two nos of machines, work com		Sathia Rajesh. C. - PATHOLOGY	03/09/2022
Dept Name : PHARMACOLOGY - Civil - Maintenance Comp. Dt. : 24/09/2022 Status : Completed								
2393	22090972	Main Gate	NEED LABOURS 2 NOS FOR BANNER REMOVING WORK AT MAIN GATE ENTRANCE	Pandiaraj. V.	Banner removed.		Panchali. P. - PHARMACOLOGY	26/09/2022
Comp. Dt. : 27/09/2022 Status : Completed								
2394	22091050	PHARMACOLOGY	NEED LABOUR 1 NO FOR RACK SHIFTING WORK	Pandiaraj. V.	Rack shifting work completed.		Devanathan. S. - PHARMACOLOGY	01/10/2022
Comp. Dt. : 09/03/2023 Status : Completed								
2395	23030344	PHARMACOLOGY	BLOCK IN WASH BASIN	Sakthivel. E.,Govindan. R.,Kathirvelu. K.	WASH BASIN BLOCK REMOVED.		Kalidoss. T. - PHARMACOLOGY	10/03/2023
Dept Name : Pharmacy - Civil - Maintenance Comp. Dt. : 16/05/2022 Status : Completed								
2396	22050543	Pay Pharmacy	CEILING WATER LEAKAGE AT DINNING ROOM - NEED TO CHECK URGENT	Prakash. V.,Arunagiri. V.,Rajendran. R.	Soil waste line rework. 4" pvc elbow, door elbow changed.		Silambuselvan. P. - Pharmacy	19/05/2022
Comp. Dt. : 27/05/2022 Status : Completed								
2397	22051016	COMMON TOILET NEAR FREE PHARMACY	BLOCK IN MALE RESTROOM 2NOS	Rajendhiran. V.,Thanuzkodi. E.,Govindan. R.	block remover work		Thilagavathi. T. - Pharmacy	27/05/2022
Comp. Dt. : 23/07/2022 Status : Completed								
2398	22070866	Pay Pharmacy	NEED TO SPRAY " DERMITE SPRAY" FOR WALL SIDE DOOR	Kannan. V.	Termite spray sprayed		Silambuselvan. P. - Pharmacy	26/07/2022
Comp. Dt. : 30/11/2022								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
2399	22111276	COMMON TOILET NEAR FREE PHARMACY	FLUSH NOT WORKING	Manikandan. S.,Rajendran. R.,Sankar. V.	Flush tank rework done.		Jhansirani. T. - Pharmacy	05/12/2022
Comp. Dt. : 03/12/2022								
Status : Completed								
2400	22120131	COMMON TOILET NEAR MEDICINE OPD	TAP BROKEN AND WATER LEAKAGE	Prakash. V.,Rajendran. R.,Ramkumar. R.	Tap changed.		Thilagavathi. T. - Pharmacy	05/12/2022
Comp. Dt. : 13/02/2023								
Status : Completed								
2401	23020470	COMMON TOILET NEAR MEDICINE OPD	BLOCK IN BOTH MALE & FEMALE RESTROOM	Rajendhiran. V.,Thanuzkodi. E.,Murugan. S.	BLOCK REMOVED.		Thilagavathi. T. - Pharmacy	14/02/2023
Comp. Dt. : 11/03/2023								
Status : Completed								
2402	23030447	Pay Pharmacy	NEED TO SPRAY TERMITE SPRAY FOR CEILING WALL	Kannan. V.	TERMITE REPELLANT SPRAYED.		Silambuselvan. P. - Pharmacy	25/03/2023
Comp. Dt. : 04/04/2023								
Status : Completed								
2403	23040108	MEDICAL COLLEGE OPP FOUNTAIN	NEED TO CHANGE TAP - WATER LEAKAGE	Anandharaj. M.	VALVE CHANGED.		Thilagavathi. T. - Pharmacy	08/04/2023
Comp. Dt. : 12/04/2023								
Status : Completed								
2404	23040380	COMMON TOILET NEAR FREE PHARMACY	BLOCK IN BOTH [MALE & FEMALE] RESTROOM	Rajendhiran. V.,Thanuzkodi. E.,Murugan. S.	BLOCK REMOVED.		Jhansirani. T. - Pharmacy	13/04/2023
Comp. Dt. : 02/05/2023								
Status : Completed								
2405	23050018	MEDICAL STORE IN BASEMENT	CEILING WATER LEAKAGE - NEED TO CHECK INSIDE THE STORE	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	WATER LEAKAGE THROUGH THE VENTILATOR WINDOW.		Sheela. B. - Pharmacy	08/05/2023
Comp. Dt. : 06/05/2023								
Status : Completed								
2406	23050243	Pay Pharmacy	DUE TO TERMITES PROBLEM NEED TO SPRAY TERMITE SPRAY	Kannan. V.	TERMITE REPELLANT SPRAYED.		Silambuselvan. P. - Pharmacy	06/05/2023
Comp. Dt. : 17/05/2023								
Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2407	23050709	COMMON TOILET NEAR FREE PHARMACY	WATER NOT COMING	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	WATER TANK FILLED		Thilagavathi. T. - Pharmacy	18/05/2023
Comp. Dt. : 24/06/2023 Status : Completed								
2408	23060901	Pay Pharmacy	WATER LEAKAGE AT INSIDE CUPBOARD WALL - NEED TO CHECK URGERNTLY	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	AC water leakage.		Silambuselvan. P. - Pharmacy	26/06/2023
Dept Name : PHYSIOLOGY - Civil - Maintenance Comp. Dt. : 20/05/2022 Status : Completed								
2409	22050736	PHYSIOLOGY-- -COLLEGE	SINK & TAP DAMAGE - WATER LEAKAGE IN HOD ROOM - NEED URGENT SERVICE	Sellaveeran. M.,Udhaya Kumar. R.,Sivaraja. M.	New wash basin and waste coupling changed, water line connection given, work completed		Balasankar. P. - PHYSIOLOGY	25/05/2022
Comp. Dt. : 01/06/2022 Status : Completed								
2410	22060019	PHYSIOLOGY-- -COLLEGE	PIPE LINE & TAP LEAKAGE IN LAB	Sellaveeran. M.	New 2" waste water line work done. Water leakage arrested.		Balasankar. P. - PHYSIOLOGY	07/06/2022
Comp. Dt. : 11/07/2022 Status : Completed								
2411	22070424	ASSOCIATIVE PROFESSOR QUARTERS	NEED TO CHECK KITCHEN SINK DRAINAGE HOSE - WATER LEAKAGE - QUARTERS NO B 12	Sellaveeran. M.,Santhosh Kumar. M.,Azhagar. N.	New Waste hose changed, work completed		Deepika. V. - PHYSIOLOGY	20/07/2022
Comp. Dt. : 03/08/2022 Status : Completed								
2412	22080107	ASSOCIATIVE PROFESSOR QUARTERS	NEED TO CHECK WALL - WATER LEAKAGE AT QUARTERS NO B 12	Sellaveeran. M.	Pipe line rework		Deepika. V. - PHYSIOLOGY	03/08/2022
Dept Name : Physiotherapy - Civil - Maintenance Comp. Dt. : 10/05/2022 Status : Completed								
2413	22050359	Physiotherapy	WATER BLOCK MOTOR NOT WORKING	Prakash. V.,Arunagiri. V.,Rajendhiran. V.	Motor block removed, problem solved		Ezhilan.K. - Physiotherapy	11/05/2022
Comp. Dt. : 19/05/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2414	22050685	Physiotherapy	MOTOR WORKING , BUT - WATER BLOCK - NEED TO CHECK	Prakash. V.,Manikandan. S.,Sankar. V.	Block removed.		Ezhilan.K. - Physiotherapy	19/05/2022
Comp. Dt. : 25/05/2022 Status : Completed								
2415	22050933	Physiotherapy	DRAINAGE PUMPING MOTOR NOT WORKING - WATER BLOCK	Prakash. V.,Rajendran. R.,Manikandan. S.	Motor block removed and drianage block removed, work completed		Ezhilan.K. - Physiotherapy	25/05/2022
2416	22050940	Physiotherapy	NEED TO CHANGE WASH BASIN - DAMAGE & BROKENED	Prakash. V.,Rajendran. R.,Arunagiri. V.	new wash basin and waste coupling changed, water line connection given, work completed		Ezhilan.K. - Physiotherapy	26/05/2022
Comp. Dt. : 27/05/2022 Status : Completed								
2417	22051007	Physiotherapy	WATER LEAKAGE IN NEWLY FIXED WASHBASIN	Prakash. V.,Ramkumar. R.,Rajendran. R.	Wash basin connection tube and waste coupling changed, problem solved		Ezhilan.K. - Physiotherapy	27/05/2022
Comp. Dt. : 21/12/2022 Status : Completed								
2418	22120946	Physiotherapy	WASH BASIN PIPE WATER LEAKAGE	Prakash. V.,Rajendran. R.,Ramkumar. R.	Wash basin pipe line connection rework done.		Ezhilan.K. - Physiotherapy	21/12/2022
Comp. Dt. : 23/05/2023 Status : Completed								
2419	23050916	Physiotherapy	MOTOR NOT WORKING - WATER BLOCK	Rajendhiran. V.,Thanuzkodi. E,Murugan. S.	BLOCK REMOVED.		Ezhilan.K. - Physiotherapy	24/05/2023
Comp. Dt. : 07/06/2023 Status : Completed								
2420	23060245	Physiotherapy	MOTOR NOT WORKING - WATER BLOCK	Sivaraja. M.,Gopal. S.,Santhosh Kumar. M.	BLOCK REMOVED.		Ezhilan.K. - Physiotherapy	08/06/2023
Comp. Dt. : 12/06/2023 Status : Completed								
2421	23060411	Physiotherapy	BLOCK - MOTOR NOT WORKING	Rajendhiran. V.,Thanuzkodi. E,Murugan. S.	block removed		Ezhilan.K. - Physiotherapy	13/06/2023
Comp. Dt. : 13/06/2023 Status : Completed								
2422	23060447	Physiotherapy	BLOCK - MOTOR NOT WORKING	Rajendhiran. V.	BLOCK REMOVED.		Ezhilan.K. - Physiotherapy	14/06/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Dept Name : PICU & NICU - Civil - Maintenance Comp. Dt. : 05/05/2022 Status : Completed								
2423	22050133	NICU	NEED TO CHECK PURIFIER TAP - WATER LEAKAGE	Sankar. V.	purifier hose changed.		Parameswari. P. - PICU & NICU	19/05/2022
Comp. Dt. : 24/08/2022 Status : Completed								
2424	22080807	PICU	BLOCK IN WASH BASIN	Rajendhiran. V.	Block removed.		Poovathal. K. - PICU & NICU	26/08/2022
Comp. Dt. : 10/09/2022 Status : Completed								
2425	22090392	PICU	BLOCK IN RESTROOM SINK	Rajendhiran. V., Murugan. S., Thanuzkodi. E	Block removed.		Umamaheswari. P. - PICU & NICU	13/09/2022
Comp. Dt. : 08/11/2022 Status : Completed								
2426	22110291	PICU & NICU	NEED 2 LABOURS FOR TABLE SHIFTING WORK FROM OLD NICU TO NEW NICU	Pandiaraj. V.	Table shifted from 1st floor NICU PICU to 2nd floor NICU PICU.		Parameswari. P. - PICU & NICU	09/11/2022
Comp. Dt. : 15/11/2022 Status : Completed								
2427	22110632	NEW NICU & PICU-2ND FLOOR	IN DOCTOR'S ROOM-WATER NOT COMING	Prakash. V., Ramkumar. R., Rajendran. R.	Tap rework and serviced, refixed in properly, problem solved		Poovathal. K. - PICU & NICU	16/11/2022
Comp. Dt. : 18/11/2022 Status : Completed								
2428	22110766	NICU	WATER NOT WOMING IN RESTROOM HEATER	Prakash. V., Rajendran. R., Ramkumar. R.	Heater tap block removed and rework done.		Parameswari. P. - PICU & NICU	23/11/2022
Comp. Dt. : 23/11/2022 Status : Completed								
2429	22111013	NEW NICU & PICU-2ND FLOOR	NEED LABOURS 4 NO'S FOR SHIFTING PURPOSE	Pandiaraj. V., Yuvaraj. M., Senthil Kumar. R.	Materials Shifting work completed.		Poovathal. K. - PICU & NICU	26/11/2022
Comp. Dt. : 01/12/2022 Status : Completed								
2430	22120038	Work Shop	NEED MAN POWER 2 NOS FOR COT (6 NOS) SHIFTING WORK FROM WORKSHOP TO PICU	Pandiaraj. V., Yuvaraj. M., Prakash. N.	Cot, Locker, table shifting work completed from workshop to New PICU & NICU - 2nd floor.		Parameswari. P. - PICU & NICU	05/12/2022

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 13/12/2022 Status : Completed								
2431	22120574	PICU	NEED TO CHECK CEILING WALL - WATER LEAKAGE	Prakash. V.	Expansion joint problem.		Poovathal. K. - PICU & NICU	14/12/2022
Comp. Dt. : 15/12/2022 Status : Completed								
2432	22120730	NICU	BLOCK IN RESTROOM	Rajendhiran. V., Thanuzkodi. E., Murugan. S.	block removed.		Poovathal. K. - PICU & NICU	16/12/2022
Comp. Dt. : 17/12/2022 Status : Completed								
2433	22120799	NICU	WASH BASIN SINK BLOCK	Rajendhiran. V., Thanuzkodi. E., Murugan. S.	Block removed.		Parameswari. P. - PICU & NICU	19/12/2022
2434	22120818	NICU	TOILET BLOCKED, NEED SCAVENGER	Rajendhiran. V., Murugan. S., Thanuzkodi. E.	block removed.		Parameswari. P. - PICU & NICU	19/12/2022
Comp. Dt. : 22/12/2022 Status : Completed								
2435	22121005	NICU	WATER BLOCK IN REST ROOM	Sakthivel. E.	Block removed.		Poovathal. K. - PICU & NICU	23/12/2022
2436	22121014	NICU	DOCTORS RESTROOM BLOCK	Sakthivel. E.	Block removed.		Parameswari. P. - PICU & NICU	23/12/2022
Comp. Dt. : 20/02/2023 Status : Completed								
2437	23020775	PICU	WATER NOT COMING IN DOCTOR'S RESTROOM	Azhagar. N., Sellaveeran. M., Anandharaj. M.	TAP BLOCK REMOVED. HEALTH FAUCET REWORK DONE.		Poovathal. K. - PICU & NICU	22/02/2023
Comp. Dt. : 08/03/2023 Status : Completed								
2438	23030326	PICU	NEED TO PASTE WHITE STRICKER	Vengatesan. V.	INFORMED TO PROJECT MANAGER		Poovathal. K. - PICU & NICU	15/03/2023
Comp. Dt. : 20/04/2023 Status : Completed								
2439	23040637	DENTAL OPD -2ND FLOOR	NEED TO CHECK DENTAL CHAIR WATER PIPELINE - STUCK - NEED URGENT SERVICE	Sivaraja. M., Udhaya Kumar. R., Azhagar. N.	ANGLE COCK REWORK DONE.		Ushamala. I. - PICU & NICU	22/04/2023
Comp. Dt. : 29/04/2023 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2440	23040999	PICU	BLOCK IN RESTROOM	Rajendhiran. V., Thanuzkodi. E., Murugan. S.	block removed.		Vinodhini. V. - PICU & NICU	03/05/2023
Comp. Dt. : 15/06/2023 Status : Completed								
2441	23060564	PICU	(1271) -WATER LEALAGE PROBLEM	Anandharaj. M., Azhagar. N., Udhaya Kumar. R.	Water leakage through expansion due to water stag in 310		Poovathal. K. - PICU & NICU	16/06/2023
Dept Name : POW & SICU - Civil - Maintenance Comp. Dt. : 13/05/2022 Status : Completed								
2442	22050460	CT POW -SPECIAL WARD B	NEED LABOURS TO REMOVE WINDOW SCREEN	Prakash. N., Thanuzkodi. E., Rajendhiran. V.	screen fixing work		Praveena. E. - POW & SICU	13/05/2022
Comp. Dt. : 06/06/2022 Status : Completed								
2443	22060217	POW & SICU	NEED TO CHECK TAP - WATER LEAKAGE IN SINK TAP & RESTROOM TAP 3NOS	Prakash. V., Arunagiri. V., Ramkumar. R.	All tap rework and refixed in properly, now problem solved		Jamuna. K - POW & SICU	13/06/2022
Comp. Dt. : 20/06/2022 Status : Completed								
2444	22060733	POW & SICU	FLUSH NOT WORKING	Udhaya Kumar. R., Anandharaj. M., Azhagar. N.	Flush tank rework.		Pragadeesh. V. - POW & SICU	21/06/2022
Comp. Dt. : 05/07/2022 Status : Completed								
2445	22070177	SICU	NEED TO PASTE BLOCK SHEET FOR FRONT MAIN GLASS DOOR	Prakash. V.	Indormed to Moorty arts		Valarmathy. K. - POW & SICU	23/08/2022
Comp. Dt. : 08/07/2022 Status : Completed								
2446	22070352	POW & SICU	WALL CEILING DAMAGE - WATER LEAKAGE - NEED TO CHECK	Prakash. V., Arunagiri. V., Ramkumar. R.	Expand joint problem. Problem rectified.		Jamuna. K - POW & SICU	12/07/2022
Comp. Dt. : 20/07/2022 Status : Completed								
2447	22070738	POW & SICU	NEED LABOUR 1 NO FOR SCREEN ROD CLEANING WORK	Pandiaraj. V.	Rod cleaning work done		Valarmathy. K. - POW & SICU	21/07/2022
Comp. Dt. : 25/07/2022								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
2448	22070920	POW & SICU	REST ROOM BLOCK	Rajendhiran. V.,Thanuzkodi. E,Murugan. S.	Block removed.		Gayathri. K. - POW & SICU	26/07/2022
Comp. Dt. : 09/08/2022								
Status : Completed								
2449	22080293	POW & SICU	NEED TO CHANGE SINK TAP - WATER LEAKAGE - NEED URGENT SERVICE	Rajendran. R.,Ramkumar. R.,Prakash. V.	Tap 1No, Tap spindle 3Nos changed, work completed		Pragadeesh. V. - POW & SICU	09/08/2022
Comp. Dt. : 17/08/2022								
Status : Completed								
2450	22080523	POW & SICU	WATER LEAKAGING FROM FALSE CEILING	Prakash. V.	Waste hose changed.		Pragadeesh. V. - POW & SICU	18/08/2022
2451	22080554	POW & SICU	IN DOCTOR'S ROOM-WASH BASIN SINK WATE LEAKAGING PROBLEM	Prakash. V.,Rajendran. R.,Ramkumar. R.	Sink waste line connection provided.		Jamuna. K - POW & SICU	18/08/2022
Comp. Dt. : 26/08/2022								
Status : Completed								
2452	22080870	POW & SICU	NEED TO CHANGE RESTROOM TAP - BROKE - WATER LEAKAGE	Prakash. V.,Rajendran. R.,Ramkumar. R.	tap and flush tank rework.		Gayathri. K. - POW & SICU	30/08/2022
Comp. Dt. : 29/08/2022								
Status : Completed								
2453	22080960	POW & SICU	NEED LABOURS 2 NOS FOR SCREEN FIXING WORKING	Pandiaraj. V.,Yuvaraj. M.,Thulasi. V.	Screen fixing work completed		Jamuna. K - POW & SICU	01/09/2022
Comp. Dt. : 12/09/2022								
Status : Completed								
2454	22090438	POW & SICU	NEED TO FIX NAILS FOR ODONIL FIXING WORK FOR ALL RESTROOMS	Prakash. V.,Rajendran. R.,Ramkumar. R.	Steel nail fixed.		Jamuna. K - POW & SICU	17/09/2022
Comp. Dt. : 16/09/2022								
Status : Completed								
2455	22090647	POW & SICU	NEED TO CHANGE WASH BASIN DRAINAGE HOSE - BLOCK AT REST ROOM	Arunagiri. V.,Rajendran. R.,Sankar. V.	Wash basin waste hose changed, problem solved		Kausalya. V. - POW & SICU	17/09/2022
Comp. Dt. : 19/09/2022								
Status : Completed								
2456	22090730	POW & SICU	BLOCK IN SINK IN DOCTOR'S ROOM REST ROOM	Rajendhiran. V.,Murugan. S.,Thanuzkodi. E	block removed.		Prasanthini. S. - POW & SICU	21/09/2022

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 08/11/2022 Status : Completed								
2457	22110290	POW & SICU	BATHROOM WATER LEAKAGE	Rajendhiran. V.,Thanuzkodi. E.,Murugan. S.	New Cp Tap changed, problem solved		Pragadeesh. V. - POW & SICU	15/11/2022
Comp. Dt. : 15/11/2022 Status : Completed								
2458	22110604	POW & SICU	NEED LABOURS TO REMOVE BEDSIDE SCREEN FROM SCREEN ROD FOR WASHING	Senthil Kumar. R.	Screen removed, work completed		Jamuna. K - POW & SICU	21/11/2022
Comp. Dt. : 05/12/2022 Status : Completed								
2459	22120197	SICU	WATER TAP LEAKAGING PROBLEM	Prakash. V.,Rajendran. R.,Ramkumar. R.	Tap changed.		Jayapradha. J. - POW & SICU	06/12/2022
Comp. Dt. : 12/12/2022 Status : Completed								
2460	22120542	POW & SICU	WASH BASIN SINK BROKEN IN BATHROOM	Prakash. V.,Rajendran. R.,Ramkumar. R.	New Wash basin sink changed.		Jamuna. K - POW & SICU	17/12/2022
Comp. Dt. : 14/12/2022 Status : Completed								
2461	22120645	POW & SICU	NEED TO CHANGE WASH BASIN BROKEN & WATER LEAKAGE	Prakash. V.,Rajendran. R.,Ramkumar. R.	New wash basin changed.		Jamuna. K - POW & SICU	17/12/2022
Comp. Dt. : 29/12/2022 Status : Completed								
2462	22121312	POW & SICU	REST ROOM BLOCK	Thanuzkodi. E.,Murugan. R.,Rajendhiran. V.	block removed.		Jamuna. K - POW & SICU	29/12/2022
2463	22121335	POW & SICU	IN DOCTOR'S ROOM-WATER TAP NEED TO BE CHANGE	Prakash. V.,Rajendran. R.,Ramkumar. R.	New CP Tap changed, problem solved		Gunavathi. G. - POW & SICU	31/12/2022
Comp. Dt. : 03/01/2023 Status : Completed								
2464	23010089	SICU	WASH BASIN SINK WATER LEAKAGING PROBLEM	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	Connection tube rework done.		Jamuna. K - POW & SICU	05/01/2023
Comp. Dt. : 10/01/2023 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2465	23010403	SEPTIC ROOM(NEW) -IN 3RD FLOOR	TOILET BLOCKED,NEED SCAVENGER	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	block removed.		Valarmathy. K. - POW & SICU	11/01/2023
Comp. Dt. : 18/01/2023 Status : Completed								
2466	23010645	POW & SICU	NEED TO CHANGE WASH BASIN DRAINAGE HOSE - WATER LEAKAGE	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	Wash basin connection tube washer changed.		Jayapradha. J. - POW & SICU	20/01/2023
Comp. Dt. : 24/01/2023 Status : Completed								
2467	23010874	POW & SICU	NEED TO CHECK SINK DRAINAGE HOSE WATER LEAKAGE	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	Angle valve changed, problem solved		Jamuna. K - POW & SICU	27/01/2023
Comp. Dt. : 09/02/2023 Status : Completed								
2468	23020366	SICU	REST ROOM BLOCK	Rajendhiran. V.,Thanuzkodi. E,Murugan. S.	BLOCK REMOVED.		Lakshmi. R. - POW & SICU	10/02/2023
Comp. Dt. : 11/02/2023 Status : Completed								
2469	23020448	SICU	NEED LABOUR FOR COT SHIFTING WORK FROM GROUND FLOOR TO SICU	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	COT SHIFTED FROM GROUND FLOOR SICU		Lakshmi. R. - POW & SICU	16/02/2023
Comp. Dt. : 01/03/2023 Status : Completed								
2470	23030052	POW & SICU	CEILING WATER LEAKAGE	Anandharaj. M.	WATER LEAKAGE DUE TO EXPANSION JOINT.		Jamuna. K - POW & SICU	02/03/2023
Comp. Dt. : 09/03/2023 Status : Completed								
2471	23030348	POW & SICU	NEED MANPOWER 4NOS FOR COT ARRANGEMENT WORK	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	COT ARRANGEMENT WORK DONE.		Jamuna. K - POW & SICU	17/03/2023
Comp. Dt. : 14/03/2023 Status : Completed								
2472	23030555	POW & SICU	WATER NOT COMING IN RESTROOM [MALE SIDE]	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	WATER FILLED IN TANK. PROBLEM RECTIFIED.		Gunavathi. G. - POW & SICU	15/03/2023
Comp. Dt. : 28/03/2023 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2473	23031156	POW & SICU	WATER LEAKAGE AT CEILING	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	EXPANSION JOINT PROBLEM.		Jamuna. K - POW & SICU	28/03/2023
2474	23031157	POW & SICU	BLOCK IN HAND WASH SINK	Rajendhiran. V.	BLOCK REMOVED.		Jamuna. K - POW & SICU	29/03/2023
2475	23031185	POW & SICU	NEED TO CHANGE RESTROOM & WASH BASIN TAP - WATER LEAKAGE	Sivaraja. M.,Santhosh Kumar. M.,Gopal. S.	AQUA GUARD WATER PIPELINE REWORK DONE.		Pragadeesh. V. - POW & SICU	30/03/2023
Comp. Dt. : 05/04/2023 Status : Completed								
2476	23040172	POW & SICU	WATER NOT COMING IN FEMALE RESTROOM	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	VALVE OPENED. PROBLEM RECTIFIED.		Aruldevi. S. - POW & SICU	08/04/2023
Comp. Dt. : 16/04/2023 Status : Completed								
2477	23040464	POW & SICU	BLOCK AT REST ROOM	Rajendhiran. V.,Thanuzkodi. E.,Murugan. S.	Toilet block removed, work completed		Jamuna. K - POW & SICU	19/04/2023
Comp. Dt. : 19/04/2023 Status : Completed								
2478	23040605	POW & SICU	CEILING WATER LEAKAGE	Sivaraja. M.,Udhaya Kumar. R.,Sellaveeran. M.	EXPANSION JOINT PROBLEM.		Asha. A. - POW & SICU	22/04/2023
Comp. Dt. : 24/04/2023 Status : Completed								
2479	23040722	POW & SICU	NEED TO CHECK DRAINAGE PIPELINE - BLOCK AND BAD SMELL	Rajendhiran. V.,Thanuzkodi. E.,Murugan. S.	block removed.		Jamuna. K - POW & SICU	25/04/2023
Comp. Dt. : 08/05/2023 Status : Completed								
2480	23050334	POW & SICU	FLUSH NOT WORKING - NEED TO CHECK	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	FLUSH TANK REWORK DONE.		Asha. A. - POW & SICU	11/05/2023
Comp. Dt. : 09/05/2023 Status : Completed								
2481	23050382	POW & SICU	NEED TO CHECK SINK PIPE LINE - BROKEN	Sivaraja. M.,Santhosh Kumar. M.,Gopal. S.	WASTE COUPLING AND WASTE HOSE CHANGED.		Jamuna. K - POW & SICU	11/05/2023
Comp. Dt. : 16/05/2023 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2482	23050649	POW & SICU	FLUSH TANK BROKEN - NEED TO CHECK & CHANGE 2NOS	Anandharaj. M.,Azhagar. N.,Udhaya Kumar. R.	FLUSH TANK BEND CHANGED.		Jamuna. K - POW & SICU	17/05/2023
Comp. Dt. : 18/05/2023 Status : Completed								
2483	23050760	POW & SICU	CEILING WATER LEAKAGE AT FEMALE SIDE SICU	Azhagar. N.	AC DEPARTMENT COMPLAINT		Jamuna. K - POW & SICU	19/05/2023
Comp. Dt. : 20/06/2023 Status : Completed								
2484	23060718	POW & SICU	NEED TO SPRAY INSECT SPRAY FOR RESTROOM - INSECT PROBLEM	Rajendhiran. V.	Mosquito repellent sprayed.		Jamuna. K - POW & SICU	22/06/2023
2485	23060719	POW & SICU	NEED TO CHANGE FILLTER FOR RO WATER	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	Carbon and mica filter changed.		Jamuna. K - POW & SICU	22/06/2023
Comp. Dt. : 24/06/2023 Status : Completed								
2486	23060920	POW & SICU	FLUSH & TANK KEY DAMAGE AT SEPTIC ROOM	Anandharaj. M.,Sellaveeran. M.,Udhaya Kumar. R.	Flush tank rework done.		Jamuna. K - POW & SICU	26/06/2023
Dept Name : Power Laundry - Civil - Maintenance Comp. Dt. : 06/05/2022 Status : Completed								
2487	22050187	LAUNDRY	BLOCK IN SIDE TANK	Thanuzkodi. E,Govindan. R.,Sakthivel. E.	Laundry side chamber block removed, work completed		Punniamurthy. R - Power Laundry	07/05/2022
Comp. Dt. : 17/09/2022 Status : Completed								
2488	22090691	LAUNDRY	NEED TO CHECK NEW WASHING MACHINE - DAMAGE & WATER LEAKAGE	Prakash. V.,Rajendran. R.,Arunagiri. V.	Waste hose changed.		Manikandan.M - Power Laundry	19/09/2022
Comp. Dt. : 17/10/2022 Status : Completed								
2489	22100543	LAUNDRY	NEED CLEANING & UNWANTED TREES & GRASS CUTING WORK IN AND AROUND LAUNDARY	Kumar. V.	Garden complaints. informed to Kumar. V Garden supervisor		Punniamurthy. R - Power Laundry	22/10/2022
Comp. Dt. : 30/11/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2490	22111270	LAUNDRY	WATER NOT COMING	Rajendran. R.,Sankar. V.,Abdul Azees. J.	Pipe line changed.		Manikandan.M - Power Laundry	05/12/2022
Comp. Dt. : 24/01/2023 Status : Completed								
2491	23010889	LAUNDRY	WATER NOT COMING	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	Pipe line connection disconnected and new pipe line changed.		Punnamurthy. R - Power Laundry	25/01/2023
Comp. Dt. : 01/03/2023 Status : Completed								
2492	23030011	Power Laundry	NEW MACHINE WATER LEAKAGE PROBLEM	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	MACHINE UNION LEAKAGE ARREST.		Manikandan.M - Power Laundry	06/03/2023
Comp. Dt. : 11/03/2023 Status : Completed								
2493	23030470	PRESS	BLOCK IN REST ROOM NEAR PRESS	Rajendhiran. V.,Thanuzkodi. E,Murugan. S.	Toilet block removed, work completed		Manikandan.M - Power Laundry	13/03/2023
Comp. Dt. : 09/06/2023 Status : Completed								
2494	23060340	LAUNDRY	BLOCK IN RESTROOM	Rajendhiran. V.	BLOCK REMOVED.		Manikandan.M - Power Laundry	10/06/2023
Dept Name : Printing Press - Civil - Maintenance Comp. Dt. : 07/07/2022 Status : Completed								
2495	22070230	COW SHED	NEED TO REPLACE TAPS FROM PLASTIC TO BRASS - 10 NOS	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	New building construction in progress.		Shanmugam. R. - Printing Press	26/07/2022
Dept Name : Quality Department - Civil - Maintenance Comp. Dt. : 11/06/2022 Status : Completed								
2496	22060411	NAC OFFICE 4TH FLOOR	NEED TO CHANGE WASH BASIN TAP - DAMAGE - WATER LEAKAGE	Arunagiri. V.,Ramkumar. R.,Rajendran. R.	CP Elbow action tap rework, leakage arrested, problem solved		Suganthi. M. - Quality Department	13/06/2022
Comp. Dt. : 19/01/2023 Status : Completed								
2497	23010683	ENT WARD-407	NEED MANPOWER 2 NOS FOR CHAIR SHIFTING WORK [10NOS] FROM ENT WARD 407 TO OLD SKILL LAB	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	Chair shifting work completed.		Suganthi. M. - Quality Department	21/01/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 07/06/2023 Status : Completed								
2498	23060243	NABH OFFICE	NEED TO CHANGE TAP - BROKEN WATER LEAKAGE	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	PILLAR COCK CHANGED.		Suganthi. M. - Quality Department	08/06/2023
Dept Name : Radio Diagnosis - Civil - Maintenance Comp. Dt. : 25/06/2022 Status : Completed								
2499	22060907	XRay	SEPTIC TANK OVER FLOW - NEED URGENT SERVICE	Rajendran. R.,Prakash. V.,Arunagiri. V.	Block removed.		Manikandan.V. - Radio Diagnosis	25/06/2022
Comp. Dt. : 24/08/2022 Status : Completed								
2500	22080784	BASEMENT SCAN	FLUSH NOT WORKING	Prakash. V.,Rajendran. R.,Ramkumar. R.	Flush tank full set rework and serviced, problem solved		Abirami. P. - Radio Diagnosis	24/08/2022
Comp. Dt. : 04/11/2022 Status : Completed								
2501	22110127	RADIOLOGY	IN DARK ROOM-MOTOR NOT WORKING	Prakash. V.,Rajendran. R.,Ramkumar. R.	Motor serviced, problem solved		Manikandan. G. - Radio Diagnosis	07/11/2022
Comp. Dt. : 25/11/2022 Status : Completed								
2502	22111092	XRay	NEED LABOURS TO SHIFT UNWANTED BOXES FROM DEPARTMENT	Prakash. N.,Thulasi. V.,Pandiaraj. V.	Unwanted boxes shifted.		Manikandan.V. - Radio Diagnosis	26/11/2022
Comp. Dt. : 05/12/2022 Status : Completed								
2503	22120150	XRay	RESTROOM BLOCK	Rajendhiran. V.,Thanuzkodi. E.,Murugan. S.	Block removed.		Manikandan.V. - Radio Diagnosis	05/12/2022
Comp. Dt. : 26/12/2022 Status : Completed								
2504	22121174	RADIOLOGY	NEED TO FIX TAP IN DARK ROOM	Prakash. V.,Rajendran. R.,Manikandan. S.	Tap fixed.		Manikandan.V. - Radio Diagnosis	05/01/2023
Comp. Dt. : 31/12/2022 Status : Completed								
2505	22121393	RADIOLOGY	NEED LABOURS FOR MATERIAL SHIFTING FROM X-RAY TO WORKSHOP	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	Material shifting work completed		Abirami. P. - Radio Diagnosis	02/01/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 03/01/2023 Status : Completed								
2506	23010116	XRay	IN DARK ROOM-MOTOR NEED TO BE REFIX	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	Refixing work completed.		Manikandan. G. - Radio Diagnosis	05/01/2023
Comp. Dt. : 05/01/2023 Status : Completed								
2507	23010221	RADIOLOGY	STAFF TOILET BLOCKED,NEED SCAVENGER	Rajendhiran. V.	Block removed.		Malathi. N. - Radio Diagnosis	06/01/2023
Comp. Dt. : 19/01/2023 Status : Completed								
2508	23010674	XRay	NEED MAN POWER 2NOS FOR SHIFTING CHAIR FROM WORKSHOP TO X RAY DEPT	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	Chair shifting work completed.		Manikandan.V. - Radio Diagnosis	21/01/2023
Comp. Dt. : 07/03/2023 Status : Completed								
2509	23030293	XRay	MOTOR NOT WORKING WATER BLOCK AT C R ROOM	Rajendhiran. V.,Thanuzkodi. E,Murugan. S.	BLOCK REMOVED		Manikandan.V. - Radio Diagnosis	09/03/2023
Comp. Dt. : 18/03/2023 Status : Completed								
2510	23030739	XRay	MOTOR NOT WORKING - WATER BLOCK	Rajendhiran. V.,Thanuzkodi. E,Murugan. S.	MOTOR BLOCK RMEOVED.		Malathi. N. - Radio Diagnosis	18/03/2023
Comp. Dt. : 31/03/2023 Status : Completed								
2511	23031353	XRay	NEED TO SPRAY " MOSQUITO SPRAY'	Kannan. V.	MOSQUITO REPELLANT SPRAYED.		Manikandan.V. - Radio Diagnosis	15/04/2023
2512	23031354	RADIOLOGY	NEED TO SPRAY MOSQUITO REPELLANT IN BASEMENT FLOOR D WING.	Kannan. V.	MOSQUITO REPELLANT SPRAYED.		Manikandan.V. - Radio Diagnosis	15/04/2023
Comp. Dt. : 20/05/2023 Status : Completed								
2513	23050850	BASEMENT SCAN	NEED TO SPRAY " BEE SPRAY"	Sivaraja. M.	MOSQUITO REPELLANT SPRAYED.		Abirami. P. - Radio Diagnosis	25/05/2023
Comp. Dt. : 12/06/2023 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2514	23060431	SCAN - GROUND FLOOR - BLOOD BANK OPP	NEED TO CHANGE WASH BASIN TAP - WATER LEAKAGE	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	Wash basin elbow action spindle changed.		Kanimozhi. D. - Radio Diagnosis	13/06/2023
Comp. Dt. :		23/06/2023						
Status :		Completed						
2515	23060867	Ultra Sound	WASH BASIN WATER LEAKAGE AT GROUND FLOOR USG ROOM	Anandharaj. M.,Azhagar. N.,Sakthivel. E.	Wash basin elbow action tap removed and pillar tap changed.		Kanimozhi. D. - Radio Diagnosis	23/06/2023
Dept Name :		Reception - Civil - Maintenance						
Comp. Dt. :		21/01/2023						
Status :		Completed						
2516	23010751	Reception	NEED TO CHECK RECEPTION MAIN ENTRANCE GLASS DOOR - SENSOR NOT WORKING	Vengatesan. V.	Informed to Project Manger.		Ranjithkumar. P. - Reception	23/01/2023
Dept Name :		RICU - Civil - Maintenance						
Comp. Dt. :		28/05/2022						
Status :		Completed						
2517	22051036	RICU	NEED TO CHANGE TAP - WATER LEAKAGE	Prakash. V.,Ramkumar. R.,Manikandan. S.	New CP tap changed.		Tamililakkiya. K. - RICU	30/05/2022
Comp. Dt. :		18/07/2022						
Status :		Completed						
2518	22070634	RICU	BLOCK IN REST ROOM	Rajendhiran. V.,Thanuzkodi. E.,Murugan. S.	Block removed.		Tamililakkiya. K. - RICU	19/07/2022
Comp. Dt. :		26/07/2022						
Status :		Completed						
2519	22070955	RICU	BLOCK IN RESTROOM	Rajendhiran. V.,Thanuzkodi. E.,Murugan. S.	Block removed.		Silambarasan. S. - RICU	27/07/2022
Comp. Dt. :		15/12/2022						
Status :		Completed						
2520	22120672	RICU	NEED TO CHECK WATER PURIFIER - LEAKAGE	Prakash. V.,Rajendran. R.,Ramkumar. R.	Bold tighten using teflon. Water leakage arrest.		Silambarasan. S. - RICU	17/12/2022
Comp. Dt. :		18/01/2023						
Status :		Completed						
2521	23010626	RICU	NEED TO CHANGE WASH BASIN DRAINAGE HOSE - BLOCK	Rajendhiran. V.,Thanuzkodi. E.,Murugan. S.	Wash basin hose changed.		Nanthini. M. - RICU	21/01/2023

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 31/05/2023 Status : Completed								
2522	23051228	RICU	BLOCK IN RESTROOM	Rajendhiran. V., Thanuzkodi. E., Murugan. S.	block removed.		Abirami. J. - RICU	31/05/2023
Comp. Dt. : 15/06/2023 Status : Completed								
2523	23060562	RICU	WATER PURIFIER WATER LEAKAGE PROBLEM	Anandharaj. M., Azhagar. N., Sellaveeran. M.	WATER PURIFIER PIPE CONNECTION REWORK DONE		Sheela. B. - RICU	16/06/2023
Dept Name : Security - SIS - Civil - Maintenance Comp. Dt. : 06/05/2022 Status : Completed								
2524	22050182	MEDICAL COLLEGE I FLOOR	BLOCK IN WASH BASIN	Thanuzkodi. E., Govindan. R., Sakthivel. E.	Wash basin block removed, work completed		Prabakaran. P. - Security - SIS	07/05/2022
Comp. Dt. : 11/10/2022 Status : Completed								
2525	22100294	MEDICAL COLLEGE GROUND FLOOR	BLOCK IN GROUND FLOOR RESTROOM	Sakthivel. E.	Block removed.		Elavazhagan. A. - Security - SIS	12/10/2022
Comp. Dt. : 14/10/2022 Status : Completed								
2526	22100477	MEDICAL COLLEGE GROUND FLOOR	NEED TO CHANGE FLUSH TANK & HOSE - BROKEN - DAMAGE & BLOCK AT GROUND FLOOR RESTROOM	Udhaya Kumar. R., Gopal. S., Santhosh Kumar. M.	1.1/4 (1 no.) Bend and 1.1/4 back bush changed. Flush tank rework done.		Elavazhagan. A. - Security - SIS	15/10/2022
Comp. Dt. : 10/11/2022 Status : Completed								
2527	22110382	MEDICAL COLLEGE GROUND FLOOR	WASH BASIN BLOCK - NEAR LIBRARY	Sakthivel. E.	Block removed.		Elavazhagan. A. - Security - SIS	11/11/2022
Comp. Dt. : 24/11/2022 Status : Completed								
2528	22111040	MEDICAL COLLEGE TERROUS	WATERLINE BROKEN ,WATER LEAKAGING CONTINUOUSLY FROM YESTERDAY	Anandharaj. M., Azhagar. N., Sellaveeran. M.	Pipe line rework, water line dummy fixed, problem solved		Elavazhagan. A. - Security - SIS	29/11/2022
Comp. Dt. : 13/01/2023 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2529	23010567	MEDICAL COLLEGE	WATER PIPE LINE CONNECTION BROKEN NEED SERVICE - GROUND FLOOR OUTSIDE	Prakash. V.,Rajendran. R.,Ramkumar. R.	College outside canteen pipe line 2" pipe line fully changed, earth work completed		Prabakaran. P. - Security - SIS	18/01/2023
		Comp. Dt. : 13/02/2023 Status : Completed						
2530	23020473	MEDICAL COLLEGE III FLOOR	BLOCK & FLUSH NOT WORKING IN BOTH MALE & FEMALE RESTROOM	Prakash. V.,Rajendran. R.,Ramkumar. R.	BLOCK REMOVED AND FLUSH TANK REWORK DONE.		Elavazhagan. A. - Security - SIS	14/02/2023
		Comp. Dt. : 18/02/2023 Status : Completed						
2531	23020717	MEDICAL COLLEGE III FLOOR	BLOCK IN MALE RESTROOM	Sakthivel. E.,Govindan. R.,Kathirvelu. K.	BLOCK REMOVED.		Pitchaimuthu. P. - Security - SIS	18/02/2023
		Comp. Dt. : 30/03/2023 Status : Completed						
2532	23031281	MEDICAL COLLEGE III FLOOR	NEED TO REMOVE BEE NEST - III FLOOR SKILL LAB OPP	Sivaraja. M.	WORK COMPLETED.		Pitchaimuthu. P. - Security - SIS	05/04/2023
		Comp. Dt. : 08/04/2023 Status : Completed						
2533	23040247	MEDICAL COLLEGE GROUND FLOOR	NEED TO CHANGE TAP - WATER LEAKAGE FOR WASH BASIN & R O WATER	Prakash. V.,Rajendran. R.,Ramkumar. R.	PVC TAP CHANGED.		Prabakaran. P. - Security - SIS	08/04/2023
		Comp. Dt. : 25/04/2023 Status : Completed						
2534	23040796	Mit boys hostel	URINAL BLOCK AT I FLOOR	Sakthivel. E.,Govindan. R.,Kathirvelu. K.	BLOCK REMOVED.		Ganesan. R. - Security - SIS	26/04/2023
		Comp. Dt. : 10/06/2023 Status : Completed						
2535	23060365	PHYSIOLOGY--COLLEGE	WATER NOT COMING & BLOCK IN MALE RESTROOM	Sakthivel. E.,Govindan. R.,Kathirvelu. K.	BLOCK REMOVED.		Pitchaimuthu. P. - Security - SIS	15/06/2023
		Dept Name : Special Clinic - Civil - Maintenance Comp. Dt. : 21/09/2022 Status : Completed						


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2536	22090809	PATHOLOGY IN COLLEGE	NEED LABOURS 2 NOS FOR SHIFTING ROLLING CHAIR [3NOS] FROM PATHOLOGY IN COLLEGE TO SPECIAL CLINIC OFF	Senthil Kumar. R.	work completed.		Thamizhselvi. S. - Administration	22/09/2022
Comp. Dt. : 27/10/2022 Status : Completed								
2537	22100868	SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	BANNER FIXING WORK NEED TO DO	Pandiaraj. V.	Banner fixing work completed.		Rani. B. - Special Clinic - Office	29/10/2022
Comp. Dt. : 24/04/2023 Status : Completed								
2538	23040763	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	NEED TO CHECK WATER PIPELINE - WATER COMING SLOW IN WASHBASIN	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	TAP FILTER BLOCK REMOVED.		Ramya. A. V. - Special Clinic	26/04/2023
Comp. Dt. : 19/06/2023 Status : Completed								
2539	23060651	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	NEED TO CHECK WATER PIPELINE - IN WASH BASIN WATER COMING SLOW	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	Wash basin water line block removed.		Ramya. A. V. - Special Clinic	20/06/2023
Dept Name : Special Clinic - Dialysis - Civil - Maintenance Comp. Dt. : 24/02/2023 Status : Completed								
2540	23020944	DIALYSIS NEW UNIT IN 1ST FLOOR	NEED LABOURS FOR REMOVING WINDOW BLIND CURTAIN AT DIALYSIS'S RECEPTION	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	WORKSHOP COMPLAINT.		Swathika. K. - Special Clinic - Dialysis	25/02/2023
Dept Name : Special Clinic - Office - Civil - Maintenance Comp. Dt. : 16/11/2022 Status : Completed								
2541	22110684*	SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	RAIN WATER LEAKAGING THROUGH WALL CEILING	Vengatesan. V.	Water leakage due to water stagnation at sunshade. cleaned and cleared the sunshade, now problem sol		Thamizhselvi. S. - Administration	21/11/2022
Comp. Dt. : 02/12/2022 Status : Completed								
2542	22120058	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	RESTROOM BLOCK AT II FLOOR URGENT SERVICE	Rajendhiran. V.,Murugan. S.,Thanuzkodi. E	Block removed.		thilakshmi. K - Special Clinic - Office	02/12/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 02/01/2023 Status : Completed								
2543	23010008	SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	TOILET BLOCKED,NEED SCAVENGER	Thanuzkodi. E	Block removed.		Thamizhselvi. S. - Administration	02/01/2023
Comp. Dt. : 28/02/2023 Status : Completed								
2544	23021066	SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	NEED MAN POWER-ONE SYSTEM TABLE SHIFTING WORK(SPL WARD B TO SPL CLINIC OFFICE)	Murali. K.	SYSTEM TABLE SHIFTED FROM SPL WARD B TO SPL CLINIC OFFICE.		Thamizhselvi. S. - Administration	03/03/2023
Comp. Dt. : 09/05/2023 Status : Completed								
2545	23050353	SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	BLOCK IN RESTROOM	Rajendhiran. V.,Thanuzkodi. E,Murugan. S.	BLOCK REMOVED.		Rani. B. - Special Clinic - Office	10/05/2023
Comp. Dt. : 17/06/2023 Status : Completed								
2546	23060632*	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	NEED CEMENT WORK FOR DAMAGE FLOOR AT OPD - WATER LEAKAGE AT FLOOR	Murugavel	Grout powder applied in duct room and doctors room		Thamizhselvi. S. - Administration	26/06/2023
Dept Name : Special OPD - Civil - Maintenance Comp. Dt. : 04/03/2023 Status : Completed								
2547	23030168	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	WATER NOT COMING IN WASHBASIN	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	BLOCK REMOVED.		Saranya. S. - Clinical Department	04/03/2023
Dept Name : Special Ward - Civil - Maintenance Comp. Dt. : 04/05/2022 Status : Completed								
2548	22050094	SPECIAL WARD---B	BLOCK IN WASH BASIN - ROOM NO B24-26	Rajendhiran. V.	Block removed		Reena. N. - Special Ward	04/05/2022
2549	22050110	SPECIAL WARD - A1	WATER NOT COMING IN RESTROOM - ROOM NO 11	Prakash. V.	civill work going, water line temporarily closed, after finishing the work, valve opened		Manjula. R. - Special Ward	07/05/2022
Comp. Dt. : 06/05/2022 Status : Completed								
2550	22050176	Special Ward - A	NEED TO CHECK WASH BASIN TAP - WATERLEAKAGE IN ROOM NO 5	Prakash. V.	Tap rework, temporarily problem solved		Anulperunjothi. M. - Special Ward	07/05/2022

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHAL KUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 13/05/2022 Status : Completed								
2551	22050449	SPECIAL WARD---B	NEED LABOURS-WINDOW SCREENS FIXING WORK	Prakash. N.	screens fixing work		Ragavi. P. - Special Ward	13/05/2022
Comp. Dt. : 17/05/2022 Status : Completed								
2552	22050596*	Special Ward - A	NEED LABOUR 1 NO FOR SCREEN FIXING WORK	Pandiaraj. V.,Yuvaraj. M.,Thulasi. V.	Screen fixing work completed		Revathi. S. - Special Ward	21/05/2022
2553	22050612	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	NEED TO CHECK FLOOR - DRAINAGE WATER LEAKAGE AT SENTHIL SIR ROOM - NEED URGENT SERVICE	Ramkumar. R.	water seepage problem. will be cleared in 2days by itself		Elakkiya. S. - Special Ward	17/05/2022
Comp. Dt. : 20/05/2022 Status : Completed								
2554	22050741	SPECIAL WARD---B	NEED TO REFIX SOAP STAND & TOWEL HANGER FOR RESTROOM FOR ALL ROOMS	Prakash. V.,Rajendran. R.,Manikandan. S.	room no.22 tap rework		Reena. N. - Special Ward	21/05/2022
2555	22050762	Special Ward - C	NEED TO CHANGE WASH BASIN OUTLET WATER HOSE - FULLY DAMAGE & WATER LEAKAGE AT COMMON MALE RESTROOM	Prakash. V.,Manikandan. S.,Rajendran. R.	Water heater line hose changing work done		Sangeetha. S. - Special Ward	23/05/2022
Comp. Dt. : 24/05/2022 Status : Completed								
2556	22050913	Special Ward - A	FLUSH WATER LEAKAGE - ROOM NO 6	Arunagiri. V.	flush tank rework done.		Reena. N. - Special Ward	25/05/2022
2557	22050914	Special Ward - A	SINK BLOCK IN ROOM NO 1 & FLUSH TANK KEY BROKEN WATER LEAKAGE IN ROOM NO 6	Prakash. V.,Thanuzkodi. E.,Ramkumar. R.	Block removed at room no.1 and flush tank rework.		Revathi. S. - Special Ward	25/05/2022
2558	22050919	SPECIAL WARD - A1	NEED TO CHANGE ELBOW TAP AT TREATMENT ROOM & REST ROOM TAP [TIGHT PROBLEM] AT REST ROOM - ROOM NO	Prakash. V.	Treatment room and rest room tap and Elbow action tap rework, problem solved		Manjula. R. - Special Ward	25/05/2022
Comp. Dt. : 26/05/2022 Status : Completed								
2559	22050967	SPECIAL WARD - A1	WATER NOT COMING IN REST ROOM - ROOM NO 9	Arunagiri. V.,Prakash. V.,Manikandan. S.	Plumbing materials fully rework, airlock released, problem solved		Gayathiri. V. - Special Ward	26/05/2022
Comp. Dt. : 27/05/2022								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
2560	22051008	SPECIAL WARD - A1	NEED TO CLOSE FLOOR HOLE - WATER LEAKAGE - ROOM NO 3- NEED URGENT SERVICE	Rajendran. R.,Ramkumar. R.,Manikandan. S.	JK white cement pointing work done, work completed		Sivasankari. M. - Special Ward	27/05/2022
Comp. Dt. : 03/06/2022								
Status : Completed								
2561	22060105	Special Ward - A	BLOCK IN WASH BASIN - ROOM NOM 1	Rajendhiran. V.	wash basin block removed, work completed		Gayathiri. V. - Special Ward	04/06/2022
2562	22060108	Special Ward - C	WATER LEAKAGE IN WASH BASIN ROOM NO 2	Prakash. V.,Ramkumar. R.,Arunagiri. V.	Wash basin waste line fully rework and wash basin refixed in properly, tap rework, problem solved		Manjula. R. - Special Ward	04/06/2022
Comp. Dt. : 04/06/2022								
Status : Completed								
2563	22060159	Special Ward - A	BLOCK IN WASH BASIN - ROOM NO 1	Thanuzkodi. E	Wash basin block removed, work completed		Revathi. S. - Special Ward	04/06/2022
Comp. Dt. : 06/06/2022								
Status : Completed								
2564	22060178	SPECIAL WARD---B	NEED TO CHECK ALL CIVIL MAINTENANCE ITEMS FOR ALL ROOMS	Prakash. V.,Arunagiri. V.,Ramkumar. R.	All rooms checked.		Reena. N. - Special Ward	07/06/2022
Comp. Dt. : 07/06/2022								
Status : Completed								
2565	22060255	Special Ward - A	FLUSH NOT WORKING - WATER NOT COMING IN FLUSH ROOM NO 8	Prakash. V.	Flush tank fullset rework and serviced, problem solved		Manjula. R. - Special Ward	08/06/2022
Comp. Dt. : 13/06/2022								
Status : Completed								
2566	22060457	Special Ward - C	MALE SIDE RESTROOM BLOCK	Rajendhiran. V.	Block removed		Sangeetha. S. - Special Ward	14/06/2022
Comp. Dt. : 30/06/2022								
Status : Completed								
2567	22061094	Special Ward - A	NEED TO CHECK ALL CIVIL MAINTENANCE ITEMS FOR ALL ROOMS	Prakash. V.	All room toilet plumbing materials and fittings checked, All complaints rectified, problem solved		Bharathi. R. - Special Ward	30/06/2022
Comp. Dt. : 04/07/2022								
Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2568	22070095	SPECIAL WARD - A1	NEED TO CHECK ALL CIVIL MAINTENANCE ITEMS FOR ALL ROOMS	Prakash. V.,Rajendran. R.,Manikandan. S.	All room plumbing materials and fittings checked, #7- Wall mixer tap rework, #8- Flush tank fullset		Manjula. R. - Special Ward	05/07/2022
Comp. Dt. : 06/07/2022 Status : Completed								
2569	22070199	SPECIAL WARD---B	TAP WATER LEAKAGE AT RESTROOM - ROOM NO B4,B5 & B20	Prakash. V.,Arunagiri. V.,Manikandan. S.	New Wall mixer tap-4Nos, CP Tap-5Nos, Flush tank 2Nos Shower 4Nos changed, Grating 1No fixed work co		Reena. N. - Special Ward	13/07/2022
Comp. Dt. : 08/07/2022 Status : Completed								
2570	22070308	SPECIAL WARD---B	NEED TO CHECK CEILING - BROKEN AT NURSE,S CABIN	Prakash. V.,Rajendran. R.,Ramkumar. R.	False ceiling problem, inform to workshop dept, painting work to be done		Reena. N. - Special Ward	15/07/2022
2571	22070340	SPECIAL WARD---B	NEED TO CHANGE WASH BASIN TAP - WATER LEAKAGE AT ROOM B7 - B8	Prakash. V.,Rajendran. R.,Ramkumar. R.	Wash basin tap changed, Flush tank and CP Tap changed, work completed		Reena. N. - Special Ward	13/07/2022
2572	22070341	SPECIAL WARD - A1	FLUSH WATER LEAKAGE - ROOM NO 10	Arunagiri. V.	Flush tank rework		Manjula. R. - Special Ward	12/07/2022
Comp. Dt. : 12/07/2022 Status : Completed								
2573	22070459	SPECIAL WARD---B	NEED TO CHECK CEILING - WATER LEAKAGE IN ROOM NO 6	Prakash. V.,Rajendran. R.,Ramkumar. R.	Flase ceiling painting problem, inform to workshop dept, painting work to be done		Gayathiri. V. - Special Ward	15/07/2022
Comp. Dt. : 15/07/2022 Status : Completed								
2574	22070594	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	NEED URGENT SERVICE - DRAINAGE BLOCK - COMING INSIDE THE WARD	Rajendhiran. V.,Thanuzkodi. E,Govindan. R.	Duct pipe line fully block removed, rework the pipe line, problem solved		Elakkiya. S. - Special Ward	16/07/2022
Comp. Dt. : 19/07/2022 Status : Completed								
2575	22070719	SPECIAL WARD---B	NEED LABOURS 2 NOS FOR SCREEN REMOVING WORK	Pandiaraj. V.,Yuvaraj. M.,Thulasi. V.	Screen removing work done		Kaviya. M. - Special Ward	21/07/2022
Comp. Dt. : 22/07/2022 Status : Completed								
2576	22070818	SPECIAL WARD---B	NEED LABOURS 2NOS FOR SCREEN FIXING WORK	Pandiaraj. V.	Screen fixing work done		Kaviya. M. - Special Ward	26/07/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2577	22070820	Special Ward - C	NEED LABOURS 2 NOS FOR SCREEN FIXING WORK	Pandiaraj. V.	Screen fixing work done		Muthulakshmi. A. - Special Ward	26/07/2022
2578	22070840	Special Ward - A	WASH BASIN BLOCK - ROOM NO 6	Rajendhiran. V.,Murugan. S.,Thanuzkodi. E	Block removed.		Bharathi. R. - Special Ward	23/07/2022
Comp. Dt. : 25/07/2022 Status : Completed								
2579	22070918	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	WATER NOT COMING IN WASHBASIN [DR RAMYA MADAM ROOM]	Prakash. V.,Rajendran. R.,Ramkumar. R.	Wash basin tap rework.		Elakkiya. S. - Special Ward	26/07/2022
Comp. Dt. : 03/08/2022 Status : Completed								
2580	22080120	Special Ward - C	NEED TO CHANGE REST ROOM TAP - BROKEN AT MALE SIDE	Prakash. N.,Rajendran. R.,Ramkumar. R.	Tap changed.		Dhatchayani.N. - Special Ward	12/08/2022
Comp. Dt. : 04/08/2022 Status : Completed								
2581	22080170	SPECIAL WARD -C IN FOURTH FLOOR	NEED LABOURS FOR WINDOW SCREEN REFIXING WORK	Pandiaraj. V.,Yuvaraj. M.,Prakash. N.	Screen fixing work completed.		Vinidha. R. - Special Ward	11/08/2022
Comp. Dt. : 09/08/2022 Status : Completed								
2582	22080294	Special Ward - A	BLOCK IN WASH BASIN & RESTROOM - ROOM NO 9	Rajendhiran. V.,Murugan. S.,Thanuzkodi. E	Wash basin block removed.		Revathi. S. - Special Ward	09/08/2022
2583	22080314	Special Ward - A	NEED ALL CIVIL MAINTENANCE ITEMS GENERAL SERVICE FOR ALL ROOMS	Prakash. V.,Arunagiri. V.,Rajendran. R.	All rooms were checked.		Ezhilarasi. P. - Special Ward	12/08/2022
Comp. Dt. : 13/08/2022 Status : Completed								
2584	22080482	Special Ward - A	REST ROOM BLOCK IN ROOM NO 6	Rajendhiran. V.	Toilet block removed, work completed		Bharathi. R. - Special Ward	17/08/2022
Comp. Dt. : 17/08/2022 Status : Completed								
2585	22080495	Special Ward - A	IN ROOM NO:9 FLUSH NOT WORKING	Prakash. V.	Flush tank rework done.		Revathi. S. - Special Ward	18/08/2022
Comp. Dt. : 18/08/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2586	22080564	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	IN DOCTOR ROOM-DRAINAGE PIPE LEAKAGING PROBLEM	Prakash. V.,Rajendran. R.,Ramkumar. R.	Block removed.		Elakkiya. S. - Special Ward	18/08/2022
Comp. Dt. :		19/08/2022						
Status :		Completed						
2587	22080622	SPECIAL WARD A1-FOURTH FLOOR	WASH BASIN PIPELINE BLOCK IN ROOM NO. 8	Rajendhiran. V.,Thanuzkodi. E.,Murugan. S.	Block removed.		Manjula. R. - Special Ward	22/08/2022
Comp. Dt. :		22/08/2022						
Status :		Completed						
2588	22080736	SPECIAL WARD - A1	NEED CONNECTION WORK FOR HEATER ROOM NO 8	Prakash. V.,Rajendran. R.,Ramkumar. R.	connection wire rework.		Ahilandeswari. B. - Special Ward	23/08/2022
Comp. Dt. :		25/08/2022						
Status :		Completed						
2589	22080851	SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	NEED URGENT SERVICE - FALSE CEILING DAMAGE - WATER DROP IN SIDE THE OFFICE	Prakash. V.,Rajendran. R.,Ramkumar. R.	Expansion joint problem.		Elakkiya. S. - Special Ward	30/08/2022
Comp. Dt. :		29/08/2022						
Status :		Completed						
2590	22080995	Special Ward - C	BLOCK IN RESTROOM	Rajendhiran. V.,Thanuzkodi. E.,Murugan. S.	Block removed.		Pushpa. U. - Special Ward	30/08/2022
Comp. Dt. :		01/09/2022						
Status :		Completed						
2591	22090048	Special Ward - C	BLOCK IN FEMALE DOCTOR'S ROOM	Sakthivel. E.	Toilet block removed, work completed		Sangeetha. S. - Special Ward	03/09/2022
Comp. Dt. :		02/09/2022						
Status :		Completed						
2592	22090082	SPECIAL WARD - A1	PLUMBER AND MAINTAINANCE CHECKING WORK FOR ALL ROOMS	Prakash. V.,Ramkumar. R.,Rajendran. R.	All rooms were checked.		Manjula. R. - Special Ward	03/09/2022
2593	22090106	Special Ward - A	WESTERN TOILET PROBLEM IN ROOM NO.6	Prakash. V.,Rajendran. R.,Ramkumar. R.	Fixed with screw		Kowsalya. A. - Special Ward	03/09/2022
Comp. Dt. :		05/09/2022						
Status :		Completed						
2594	22090162	Special Ward - A	NEED TO CHECK ALL CIVIL MAINTENANCE ITEMS FOR ALL ROOMS	Prakash. V.,Rajendran. R.,Ramkumar. R.	General check up finished.		Bharathi. R. - Special Ward	06/09/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 06/09/2022								
Status : Completed								
2595	22090244	Special Ward - C	BLOCK IN DOCTOR'S REST ROOM [FEMALE SIDE]	Rajendhiran. V.,Murugan. S.,Thanuzkodi. E	block removed.		Dhatchayani.N. - Special Ward	07/09/2022
Comp. Dt. : 12/09/2022								
Status : Completed								
2596	22090420	Special Ward - A	NEED SERVICE FOR WATER COOLER [DRINKING WATER HEATER]	Prakash. V.,Rajendran. R.,Ramkumar. R.	AC department complaint.		Ezhilarasi. P. - Special Ward	16/09/2022
Comp. Dt. : 13/09/2022								
Status : Completed								
2597	22090506	SPECIAL WARD - A1	NEED TO CHEECK FLUSH KEY AND TANK AND SHOWER FOR ROOM NO 8 & 9	Prakash. N.,Rajendran. R.,Ramkumar. R.	Flush tank full set rework and refixed, problem solved		Manjula. R. - Special Ward	17/09/2022
Comp. Dt. : 23/09/2022								
Status : Completed								
2598	22090942	Special Ward - A	NEED TO CHECK TAP - WATER NOT COMING IN ROOM NO 7	Ramkumar. R.,Rajendran. R.,Arunagiri. V.	Water leakage arrested. Tap rework done.		Manjula. R. - Special Ward	26/09/2022
Comp. Dt. : 26/09/2022								
Status : Completed								
2599	22090992	Special Ward - A	WASH BASIN BLOCK - ROOM NO 6	Rajendhiran. V.,Thanuzkodi. E,Murugan. S.	wash basin Block removed		Bharathi. R. - Special Ward	27/09/2022
Comp. Dt. : 27/09/2022								
Status : Completed								
2600	22091068	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	WASH BASIN BLOCK	Rajendhiran. V.,Murugan. S.,Thanuzkodi. E	Block removed.		Sangeetha. C. - Special Ward	28/09/2022
Comp. Dt. : 29/09/2022								
Status : Completed								
2601	22091181	SPECIAL WARD---B	NEED TO CHANGE ELBOW ACTION TAP [5 NOS]	Rajendran. R.,Ramkumar. R.,Arunagiri. V.	5 nos. elbow action tap changed.		Reena. N. - Special Ward	30/09/2022
Comp. Dt. : 06/10/2022								
Status : Completed								
2602	22100103	SPECIAL WARD - A1	WATER NOT COMING - ROOM NO 1	Rajendran. R.,Ramkumar. R.,Arunagiri. V.	Wall mixture tap rework.		Lavi. P. - Special Ward	08/10/2022

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHAL KUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 10/10/2022		Status : Completed						
2603	22100224	Special Ward - C	BLOCK IN RESTROOM - ROOM NO 410	Rajendhiran. V.,Thanuzkodi. E.,Murugan. S.	Toilet block removed, work completed		Pushpa. K. - Special Ward	11/10/2022
Comp. Dt. : 11/10/2022		Status : Completed						
2604	22100266	SPECIAL WARD - A1	NEED TO REFIX HAND PIPE - DAMAGE AT ROOM NO 2	Rajendran. R.,Ramkumar. R.,Arunagiri. V.	Health faucet rework done.		Sivapriya. P. - Special Ward	03/11/2022
2605	22100274	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	WATER LEAKAGE - DRAINAGE ROOM TO Dr. SENTHIL SIR ROOM - NEED URGENT SERVICE	Prakash. V.,Rajendran. R.,Rajendhiran. V.	AC department complaints.		Elakkiya. S. - Special Ward	11/10/2022
Comp. Dt. : 13/10/2022		Status : Completed						
2606	22100407	SPECIAL WARD - A1	NEED LABOURS 2 NOS FOR COT SHIFTING WORK	Pandiaraj. V.	Cot shifting work done.		Manjula. R. - Special Ward	13/10/2022
2607	22100430	SPECIAL WARD - A1	NEED TO CHANGE FLUSH TANK - WATER LEAKAGE AT ROOM NO 8	Prakash. V.,Rajendran. R.,Ramkumar. R.	Flush tank rework done. Water leakage arrest.		Manjula. R. - Special Ward	17/10/2022
Comp. Dt. : 20/10/2022		Status : Completed						
2608	22100686	SPECIAL WARD - A1	COT SHITING ROOM NO:6 MAN POWER NEEDED	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	Cot shifting work completed		Manjula. R. - Special Ward	21/10/2022
Comp. Dt. : 31/10/2022		Status : Completed						
2609	22100992	Special Ward - C	MALE RESTROOM BLOCK	Rajendhiran. V.,Thanuzkodi. E.,Murugan. S.	Block removed.		Vinidha. R. - Special Ward	31/10/2022
2610	22101010	SPECIAL WARD---B	ROOM NO-(7,8 AND 9) WASH BASIN WATER LEAKAGE PROBLEM	Ramkumar. R.,Arunagiri. V.,Abdul Azees. J.	cp angle valve changed.		Ahilandeswari. B. - Special Ward	03/11/2022
2611	22101029	SPECIAL WARD - A1	WATER NOT COMING	Rajendran. R.,Ramkumar. R.,Arunagiri. V.	tank dry. Tank filled.		Sivapriya. P. - Special Ward	02/11/2022
Comp. Dt. : 05/11/2022		Status : Completed						
2612	22110174	SPECIAL WARD -C IN FOURTH FLOOR	BATHROOM BLOCK,NEED SCAVENGER	Rajendhiran. V.,Murugan. S.,Thanuzkodi. E	Block removed.		Kavipriya. P. - Special Ward	08/11/2022
Comp. Dt. : 07/11/2022								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
2613	22110196	Special Ward - C	BATHROOM BLOCK	Rajendhiran. V.	Block removed.		Ragavi. P. - Special Ward	08/11/2022
Comp. Dt. : 08/11/2022								
Status : Completed								
2614	22110267	SPECIAL WARD - A1	FLUSH NOT WORKING IN ROOM NO. 2, 8	Prakash. V.,Arunagiri. V.,Rajendran. R.	New Health faucet, EWC seat cover changed, Towel rod fixed, Flush tank fullset rework, work complete		Manjula. R. - Special Ward	08/11/2022
Comp. Dt. : 09/11/2022								
Status : Completed								
2615	22110360	SPECIAL WARD -C IN FOURTH FLOOR	NEED LABOURS FOR PATIENT COT MATTRESS SHIFTING WORK TO SPECIAL WARD A	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	Cot mattress shifting work done.		Sangeetha. S. - Special Ward	15/11/2022
Comp. Dt. : 14/11/2022								
Status : Completed								
2616	22110507	SPECIAL WARD A1-FOURTH FLOOR	IN ROOM NO.4-WESTERN TOILET EWC SHEET COVER NEED TO BE CHANGE	Prakash. V.,Ramkumar. R.,Rajendran. R.	EWC seat cover changed.		Manjula. R. - Special Ward	15/11/2022
Comp. Dt. : 15/11/2022								
Status : Completed								
2617	22110598	SPECIAL WARD A THIRD FLOOR	IN ROOM NO.1-SINK WATER TAP IS HARD TO OPEN	Prakash. V.,Ramkumar. R.,Abdul Azees. J.	Tap rework and refixed in properly, problem solved		Bharathi. D. - Special Ward	21/11/2022
Comp. Dt. : 17/11/2022								
Status : Completed								
2618	22110698	SPECIAL WARD A1-FOURTH FLOOR	IN ROOM NO.5 AND 2 -WATER NOT COMING IN REST ROOM	Prakash. V.,Rajendran. R.,Ramkumar. R.	#2-Water heater tap rework and refixed, #5- valve closed in Room No:2 tap rework purpose, after fini		Manjula. R. - Special Ward	21/11/2022
2619	22110735	SPECIAL WARD A1-FOURTH FLOOR	IN ROOM NO.4-WATER HEATER HOSE COLLAR NIPPLE DAMAGED	Prakash. V.	Water heater line fully rework and refixed in properly, problem solved		Manjula. R. - Special Ward	21/11/2022
Comp. Dt. : 19/11/2022								
Status : Completed								
2620	22110817	Special Ward - A	HEATER PROBLEM HOT WATER NOT COMING IN ROOM NO 5	Rajendran. R.	Hot water heater tap rework, dust cleaned, problem solved		Bharathi. R. - Special Ward	21/11/2022
Comp. Dt. : 22/11/2022								
Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2621	22110909	Special Ward - A	BLOCK IN WASH BASIN AT TREATMENT ROOM	Rajendhiran. V.,Murugan. S.,Thanuzkodi. E	block removed.		Bharathi. R. - Special Ward	22/11/2022
Comp. Dt. : 24/11/2022 Status : Completed								
2622	22111043	SPECIAL WARD -C IN FOURTH FLOOR	IN REST ROOM-FLUSH TANK PIPE LINE LEAKAGING PROBLEM	Prakash. V.,Rajendran. R.,Ramkumar. R.	Flush tank rework done.		Punitha. V. - City Centre - Pondicherry	26/11/2022
Comp. Dt. : 25/11/2022 Status : Completed								
2623	22111087	SPECIAL WARD A THIRD FLOOR	IN ROOM NO.2-WASH BASIN SINK WATER TAP BROKEN	Prakash. V.,Rajendran. R.,Ramkumar. R.	Wash basin sink tap fixed.		Bharathi. R. - Special Ward	05/12/2022
Comp. Dt. : 26/11/2022 Status : Completed								
2624	22111130	SPECIAL WARD A1-FOURTH FLOOR	IN ROOM NO.1-WASH BASIN SINK BLOCK	Rajendhiran. V.,Murugan. S.,Thanuzkodi. E	Block removed.		Punitha. V. - City Centre - Pondicherry	28/11/2022
Comp. Dt. : 29/11/2022 Status : Completed								
2625	22111234	SPECIAL WARD - A1	BLOCK IN REST ROOM - ROOM NO 6	Thanuzkodi. E,Murugan. S.,Rajendhiran. V.	block removed.		Manjula. R. - Special Ward	30/11/2022
Comp. Dt. : 02/12/2022 Status : Completed								
2626	22120050	Special Ward - C	RESTROOM BLOCK - FEMALE SIDE FORTH END	Rajendhiran. V.,Murugan. S.,Thanuzkodi. E	block removed.		Pushpa. U. - Special Ward	02/12/2022
Comp. Dt. : 05/12/2022 Status : Completed								
2627	22120188	SPECIAL WARD -B IN FOURTH FLOOR	NEED LABOURS FOR SCREEN REMOVING WORK	Murali. K.,Senthil Kumar. R.,Thulasi. V.	screen removing work completed.		Kaviya. M. - Special Ward	09/12/2022
2628	22120190	SPECIAL WARD -C IN FOURTH FLOOR	IN DOCTOR'S ROOM-WESTER TOILET CEAT COVER DAMAGED ,NEED TO CHANGE	Prakash. V.,Rajendran. R.,Ramkumar. R.	Seat cover changed.		Hemachandra. P. - Special Ward	15/12/2022
Comp. Dt. : 06/12/2022 Status : Completed								
2629	22120266	SPECIAL WARD -B IN FOURTH FLOOR	NEED LABOURS FOR SCREEEN FIXING WORK	Pandiaraj. V.,Yuvaraj. M.,Thulasi. V.	Screen fixing work completed.		Seena. N. - Special Ward	09/12/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 09/12/2022 Status : Completed								
2630	22120421	Special Ward - A	NEED TO CHANGE SINK TAP - WATER LEAKAGE - ROOM NO 2 & 5	Prakash. V.,Rajendran. R.,Ramkumar. R.	White cement packed. Water leakage arrest.		Bharathi. R. - Special Ward	12/12/2022
Comp. Dt. : 17/12/2022 Status : Completed								
2631	22120820	SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	TOILET BLOCKED,NEED SCAVENGER	Thanuzkodi. E,Rajendhiran. V.,Murugan. S.	block removed.		Dhatchayani.N. - Special Ward	19/12/2022
Comp. Dt. : 21/12/2022 Status : Completed								
2632	22120979	SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	NEED LABOURS FOR SHIFTING WORK FROM SPECIAL OFFICE TO RECEPTION	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	Shifting work completed		Dhatchayani.N. - Special Ward	23/12/2022
Comp. Dt. : 22/12/2022 Status : Completed								
2633	22121015	Special Ward - C	SCREEN REMOVING WORK	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	Screen removing work completed		Abirami. G. - Special Ward	23/12/2022
2634	22121029	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	WATER NOT COMING IN DOCTORS ROOM	Prakash. V.	Tap rework done		Elakkiya. S. - Special Ward	23/12/2022
Comp. Dt. : 24/12/2022 Status : Completed								
2635	22121115	SPECIAL WARD -C IN FOURTH FLOOR	NEED 2 MANPOWER FOR SCREEN REFIXING WORK	Yuvaraj. M.,Senthil Kumar. R.,Murali. K.	Screen fixing work completed.		Ramya. R. - Special Ward	24/12/2022
2636	22121120	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	DRAINAGE WATER LEAKAGING PROBLEM	Prakash. V.,Rajendran. R.,Ramkumar. R.	Water leakage due to block in 201. Problem rectified.		Elakkiya. S. - Special Ward	24/12/2022
Comp. Dt. : 26/12/2022 Status : Completed								
2637	22121138	Special Ward - C	NEED TO FIX SCREEN IN ROOM NO 410	Prakash. N.	Screen fixing work completed.		Pushpa. U. - Special Ward	26/12/2022
2638	22121191	Special Ward - C	SCREEN REMOVING WORK	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	Screen removing work completed.		Sangeetha. S. - Special Ward	27/12/2022
Comp. Dt. : 28/12/2022 Status : Completed								
2639	22121288	SPECIAL WARD A THIRD FLOOR	IN ROOM NO.7-HEALTH FUCET NOT WORKING	Prakash. V.,Rajendran. R.,Ramkumar. R.	Room No:3 - Health faucet serviced, problem solved		Kowsalya. A. - Special Ward	31/12/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 02/01/2023								
Status : Completed								
2640	23010005	SPECIAL WARD -C IN FOURTH FLOOR	NEED LABOURS FOR SCREEN REFIXING WORK	Prakash. N.,Thulasi. V.,Senthil Kumar. R.	Screen fixing work completed		Muthulakshmi. A. - Special Ward	02/01/2023
2641	23010006	SPECIAL WARD -C IN FOURTH FLOOR	PATINET REST ROOM BLOCK	Rajendhiran. V.,Thanuzkodi. E,Murugan. S.	Block removed.		Hemachandra. P. - Special Ward	02/01/2023
Comp. Dt. : 03/01/2023								
Status : Completed								
2642	23010060	SPECIAL WARD---B	REST ROOM FLUSH NOT WORKING IN ROOM NO B3	Anandharaj. M.,Sellaveeran. M.,Udhaya Kumar. R.	Flush tank rework.		Sangeetha. S. - Special Ward	05/01/2023
2643	23010087	SPECIAL WARD A THIRD FLOOR	IN ROOM NO.6 WASH BASIN SINK BLOCK	Rajendhiran. V.,Murugan. S.,Thanuzkodi. E	Block removed.		Bharathi. R. - Special Ward	04/01/2023
Comp. Dt. : 05/01/2023								
Status : Completed								
2644	23010199	Special Ward - A	WASH BASIN BLOCK - ROOM NO.3&6	Rajendhiran. V.,Thanuzkodi. E,Murugan. S.	Block removed.		Bharathi. R. - Special Ward	05/01/2023
2645	23010240	SPECIAL WARD -B IN FOURTH FLOOR	IN ROOM NO.3-TOILET BLOCKED,NEED SCAVENGER	Rajendhiran. V.,Murugan. S.,Thanuzkodi. E	Block removed.		Sangeetha. S. - Special Ward	06/01/2023
Comp. Dt. : 06/01/2023								
Status : Completed								
2646	23010282	Special Ward - A	SINK BLOCK--ROOM NO-2	Rajendhiran. V.,Thanuzkodi. E,Murugan. S.	Sink block removed, work completed		Kowsalya. A. - Special Ward	07/01/2023
Comp. Dt. : 09/01/2023								
Status : Completed								
2647	23010346	SPECIAL WARD A1-FOURTH FLOOR	IN TREATMENT ROOM-WATER NOT COMING IN WASH BASIN SINK	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	Wash basin sink tap rework done.		Sivapriya. P. - Special Ward	10/01/2023
Comp. Dt. : 18/01/2023								
Status : Completed								
2648	23010631	Special Ward - A	WATER NOT COMING IN FLUSH - ROOM NO 9	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	Flush tank rework done		Bharathi. R. - Special Ward	20/01/2023
Comp. Dt. : 25/01/2023								
Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2649	23010940	SPECIAL WARD - A1	NEED TO CHECK PIPE LINE - WATER NOT COMING ROOM NO 2	Anandharaj. M.,Santhosh Kumar. M.,Gopal. S.	Pipe line rework done.		Ragavi. P. - Special Ward	27/01/2023
Comp. Dt. : 27/01/2023 Status : Completed								
2650	23010946	Special Ward - A	NEED TO CHANGE RESTROOM TAP - WATER LEAKAGE - ROOM NO 4	Gopal. S.,Sivaraja. M.,Ramkumar. R.	2Nos of Guru spindle changed, problem solved		Bharathi. R. - Special Ward	28/01/2023
2651	23010956	SPECIAL WARD A1-FOURTH FLOOR	IN ROOM NO.8 AND 5 WATER POURING SLOWLY FROM WATER TAP IN BATHROOM	Sivaraja. M.	Tap filter block removed.		Ragavi. P. - Special Ward	28/01/2023
Comp. Dt. : 07/02/2023 Status : Completed								
2652	23020247	Special Ward - C	NEED TO CHECK FLUSH WATER - LEAKAGE AT DOCTOR'S ROOM	Azhagar. N.,Udhaya Kumar. R.,Gopal. S.	Flush tank washer changed, rework, work completed		Muthulakshmi. A. - Special Ward	08/02/2023
Comp. Dt. : 20/02/2023 Status : Completed								
2653	23020779	Special Ward - C	NEED TO CHECK FLUSH =WATER LEAKAGE AT DOCTOR'S REST ROOM	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	BLOCK REMOVED.		Muthulakshmi. A. - Special Ward	21/02/2023
Comp. Dt. : 21/02/2023 Status : Completed								
2654	23020792	SPECIAL WARD---B	NEED TO CHECK WATER PIPELINE - BLOCK - WATER NOT COMING - ROOM NO B4 - B5	Azhagar. N.,Sellaveeran. M.,Anandharaj. M.	BLOCK REMOVED.		Sangeetha. S. - Special Ward	21/02/2023
Comp. Dt. : 22/02/2023 Status : Completed								
2655	23020858	Paediatrics - Ward 309	WASHBASIN WATER LEAKAGE PROBLEM	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	WHITE CEMENT PACKING WORK DONE.		Hemachandra. P. - Special Ward	24/02/2023
Comp. Dt. : 02/03/2023 Status : Completed								
2656	23030109	Special Ward - C	SINK BROKEN - NEED TO CHANGE AT MALE SIDE	Sivaraja. M.,Gopal. S.,Azhagar. N.	TILES PROBLEM. CONNECTION TUBE CHANGED.		Abirami. G. - Special Ward	04/03/2023
Comp. Dt. : 03/03/2023 Status : Completed								
2657	23030135	SPECIAL WARD---B	BLOCK IN RESTROOM	Rajendhiran. V.,Murugan. S.,Thanuzkodi. E	BLOCK REMOVED.		Sangeetha. S. - Special Ward	04/03/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2658	23030141	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	WATER NOT COMING IN WASH BASIN	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	BLOCK REMOVED		Elakkiya. S. - Special Ward	04/03/2023
Comp. Dt. :		04/03/2023						
Status :		Completed						
2659	23030184	SPECIAL WARD - A1	NEED TO CHECK ALL CIVIL MAINTENANCE ITEMS AT ALL ROOMS	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	MATERIALS NOTED.		Manjula. R. - Special Ward	06/03/2023
Comp. Dt. :		14/03/2023						
Status :		Completed						
2660	23030545	Paediatrics - Ward 310	RESTROOM BLOCK	Rajendhiran. V.,Thanuzkodi. E.,Murugan. S.	BLOCK REMOVED.		Pushpa. U. - Special Ward	16/03/2023
2661	23030568	Special Ward - C	BLOCK IN RESTROOM	Rajendhiran. V.,Thanuzkodi. E.,Murugan. S.	BLOCK REMOVED.		Keerthana. N. - Special Ward	15/03/2023
Comp. Dt. :		15/03/2023						
Status :		Completed						
2662	23030578	SPECIAL WARD---B	NEED TO CHANGE WASH BASIN DRAINAGE HOSE - WATER LEAKAGE	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	WASH BASIN DRAINAGE HOSE CHANGED.		Jayabarathi. P. - Special Ward	17/03/2023
2663	23030590	Special Ward - C	BLOCK IN RESTROOM	Rajendhiran. V.,Murugan. S.,Thanuzkodi. E	BLOCK REMOVED.		Kavipriya. P. - Special Ward	16/03/2023
Comp. Dt. :		16/03/2023						
Status :		Completed						
2664	23030656	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	NEED MANPOWER 2 NOS FOR SCREEN REMOVING WORK	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	SCREEN REMOVING WORK DONE		Elakkiya. S. - Special Ward	17/03/2023
Comp. Dt. :		18/03/2023						
Status :		Completed						
2665	23030736	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	NEED TO CHECK DRAINAGE PIPELINE - WATER LEAKAGE AT DOCTOR'S ROOM - NEED URGENT SERVICE	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	ELBOW DOOR REFIXED.		Elakkiya. S. - Special Ward	21/03/2023
Comp. Dt. :		20/03/2023						
Status :		Completed						
2666	23030831	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	DRAINAGE LEAKAGE	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	1.1/2" and 2.1/2" elbow door rework done.		Elakkiya. S. - Special Ward	21/03/2023
Comp. Dt. :		22/03/2023						
Status :		Completed						


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2667	23030909	SPECIAL WARD - A1	NEED CEMENT WORK FOR CEILING WATER LEAKAGE AT NURSE'S CABIN & RESTROOM	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	ELECTRICAL AND WORKSHOP COMPLAINTS.		Ragavi. P. - Special Ward	23/03/2023
	Comp. Dt. : 29/03/2023							
	Status : Completed							
2668	23031271	SPECIAL WARD - A1	WATER NOT COMING - ROOM NO 7	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	TAP FILTER BLOCK REMOVED.		Manjula. R. - Special Ward	31/03/2023
	Comp. Dt. : 01/04/2023							
	Status : Completed							
2669	23040020	Special Ward - C	NEED TO CHANGE RESTROOM TAP - WATER LEAKAGE AT DOCTOR'S ROOM	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	TAP BLOCK REMOVED.		Muthulakshmi. A. - Special Ward	04/04/2023
	Comp. Dt. : 10/04/2023							
	Status : Completed							
2670	23040263	Special Ward - C	REST ROOM BLOCK - ROOM NO 410	Govindan. R.,Rajendhiran. V.,Sakthivel. E.	BLOCK REMOVED.		Muthulakshmi. A. - Special Ward	13/04/2023
	Comp. Dt. : 13/04/2023							
	Status : Completed							
2671	23040424	Special Ward - A	SINK BLOCK - NEED URGENTSERVICE	Rajendhiran. V.,Thanuzkodi. E.,Murugan. S.	BLOCK REMOVED.		Prithika. V. - Special Ward	15/04/2023
	Comp. Dt. : 19/04/2023							
	Status : Completed							
2672	23040596	Special Ward - C	BLOCK IN MALE RESTROOM	Rajendhiran. V.,Sakthivel. E.,Govindan. R.	Toilet block removed, work completed		Kavipriya. P. - Special Ward	20/04/2023
	Comp. Dt. : 20/04/2023							
	Status : Completed							
2673	23040631	SPECIAL WARD---B	NEED TO CHECK DRAINAGE HOSE FOR SINK WATER LEAKAGE - ROOM NO B11-B2-B3	Sivaraja. M.,Azhagar. N.,Udhaya Kumar. R.	DRAINAGE HOSE CHANGED.		Ahilandeswari. B. - Special Ward	22/04/2023
	Comp. Dt. : 25/04/2023							
	Status : Completed							
2674	23040808	SPECIAL WARD - A1	NEED TO CHANGE TAP 2NOS FOR SINK AND RESTROOM - WATER LEAKAGE AT ROOM NO 1	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	FLUSH TANK REFIXED.		Shalini. S. - Special Ward	28/04/2023

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 26/04/2023 Status : Completed								
2675	23040847	Paediatrics - Ward 310	FLUSH NOT WORKING	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	FLUSH TANK REWORK DONE.		Kaviya. M. - Special Ward	28/04/2023
Comp. Dt. : 27/04/2023 Status : Completed								
2676	23040887	Special Ward - A	BLOCK IN FLUSH OUT ROOM NO 4 - PATIENT STAYING - NEED URGENT SERVICE	Rajendhiran. V.,Thanuzkodi. E,Murugan. S.	BLOCK REMOVED.		Revathi. S. - Special Ward	28/04/2023
2677	23040926	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	NEED TO CHECK WASH BASIN NEAR WALL - WATER LEAKAGE AT Dr. RAMYA MADAM ROOM	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	WASH BASIN FILTER BLOCK REMOVED.		Elakkiya. S. - Special Ward	28/04/2023
Comp. Dt. : 28/04/2023 Status : Completed								
2678	23040969	SPECIAL WARD---B	NEED TO CHANGE WASH BASIN DRAINAGE HOSE - WATER LEAKAGE AT ROOM NO B1*B2 & B5-B6	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	WASTE HOSE CHANGED.		Sangeetha. S. - Special Ward	06/05/2023
2679	23040973	SPECIAL WARD - A1	WASH BASIN BLOCK AT ROOM NO 1	Thanuzkodi. E,Murugan. S.,Rajendhiran. V.	block removed.		Manjula. R. - Special Ward	03/05/2023
Comp. Dt. : 08/05/2023 Status : Completed								
2680	23050327	Special Ward - A	NEED TO CHANGE RESTROOM TAP - WATER LEAKAGE - ROOM NO 6	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	TAP FIXED.		Ragavi. P. - Special Ward	11/05/2023
2681	23050331	SPECIAL WARD---B	WATER NOT COMING ROOM NO B1-B2-B3	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	PIPELINE CONNECTION REWORK DONE.		Ahilandeswari. B. - Special Ward	10/05/2023
Comp. Dt. : 09/05/2023 Status : Completed								
2682	23050384	SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	BLOCK IN RESTROOM	Rajendhiran. V.,Thanuzkodi. E,Murugan. S.	BLOCK REMOVED.		Revathi. S. - Special Ward	10/05/2023
Comp. Dt. : 11/05/2023 Status : Completed								
2683	23050427	Special Ward - A	NEED TO CHECK SINK PIPELINE - HOT WATER COMING - DELUX ROOM NO 2	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	HOT WATER PIPELINE CONNECTION REWORK DONE.		Prithika. V. - Special Ward	12/05/2023
Comp. Dt. : 12/05/2023								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
2684	23050498	Special Ward - A	NEED TO CHANGE RESTROOM TAP - WATER LEAKAGE - ROOM NO 6	Anandharaj. M.,Azhagar. N.,Udhaya Kumar. R.	RESTROOM TAP CHANGED,.		Revathi. S. - Special Ward	13/05/2023
Comp. Dt. : 16/05/2023								
Status : Completed								
2685	23050627	SPECIAL WARD---B	FLUSH WATER LEAKAGE - NEED TO CHECK - ROOM NO B1- B2	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	FLUSH BEND CHANGED.		Sangeetha. S. - Special Ward	17/05/2023
Comp. Dt. : 17/05/2023								
Status : Completed								
2686	23050710	Special Ward - C	WATER NOT COMING	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	WATER TANK FILLED		Kavipriya. P. - Special Ward	18/05/2023
Comp. Dt. : 19/05/2023								
Status : Completed								
2687	23050807	SPECIAL WARD - A1	NEED TO CHECK WATER PIPELINE - LEAKAGE - ROOM NO 7	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	WATERN HEATER CONNECTION TUBE REWORK DONE.		Kaviya. M. - Special Ward	19/05/2023
Comp. Dt. : 24/05/2023								
Status : Completed								
2688	23050952	SPECIAL WARD - A1	BLOCK IN SINK	Gnanasegaran. K.	BLOCK REMOVED.		Shalini. S. - Special Ward	25/05/2023
Comp. Dt. : 30/05/2023								
Status : Completed								
2689	23051192	SPECIAL WARD - A1	NEED REPAIRING WORK FOR TAP - NOT WORKING AT ROOM NO 10	Sivaraja. M.	TAP REWORK DONE		Manjula. R. - Special Ward	01/06/2023
Comp. Dt. : 02/06/2023								
Status : Completed								
2690	23060079	Special Ward - A	FLUSH NOT WORKING ROOM NO 6, 9	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	FLUSH TANK REWORK DONE.		Bharathi. R. - Special Ward	03/06/2023
Comp. Dt. : 05/06/2023								
Status : Completed								
2691	23060116	Special Ward - A	BLOCK IN SINK ROOM NO 4	Rajendhiran. V.,Thanuzkodi. E.,Murugan. S.	block removed.		Prithika. V. - Special Ward	06/06/2023
2692	23060146	Special Ward - C	NEED MANPOWER 4 NOS FOR SCREEN REMOVING WORK [60 NOS] - WARD NO 409 & 410	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	Screen removing work completed		uthulakshmi. A. - Special Ward	09/06/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 15/06/2023 Status : Completed								
2693	23060561*	Paediatrics - Ward 309	REST ROOM WATER COMING OUT SIDE	Anandharaj. M.,Rajendhiran. V.,Thanuzkodi. E	Block removed in restroom		Ezhilarasi. P. - Special Ward	16/06/2023
Comp. Dt. : 17/06/2023 Status : Completed								
2694	23060641	Special Ward - C	NEED TO CHANGE TAP FOR DOCTOR'S ROOM RESTROOM - TAP WATER LEAKAGE , WATER COMING INSIDE PATIENT'S	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	wash basin tap rework done		Muthulakshmi. A. - Special Ward	20/06/2023
Comp. Dt. : 19/06/2023 Status : Completed								
2695	23060666	SPECIAL WARD - A1	NEED TO CHECK HEATER PIPELINE - WATER LEAKAGE - ROOM NO 11	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	Connection tube 2nos changed.		Manjula. R. - Special Ward	20/06/2023
Comp. Dt. : 22/06/2023 Status : Completed								
2696	23060805	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	NEED TO CHECK WASH BASIN NEAR FLOOR - WATER LEAKAGE AT DR. RAMYA MADAM'S ROOM	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	Wash basin elbow action tap removed and pillar tap changed.		Elakkiya. S. - Special Ward	23/06/2023
Comp. Dt. : 24/06/2023 Status : Completed								
2697	23060907	Special Ward - A	BLOCK IN WASH BASIN - ROOM NO 6	Thanuzkodi. E,Rajendhiran. V.,Murugan. S.	Block removed.		Revathi. S. - Special Ward	24/06/2023
Dept Name : Surgical Oncology - Civil - Maintenance Comp. Dt. : 05/06/2023 Status : Completed								
2698	23060132	ONCOLOGY DEPT-2ND FLOOR-SPECIAL OPD	WATER NOT COMING	Sivaraja. M.	VALVE OPENED. PROBLEM RECTIFIED.		Dhivya Bharathi. P. - Surgical Oncology	06/06/2023
Dept Name : Tailoring Department - Civil - Maintenance Comp. Dt. : 09/05/2022 Status : Completed								
2699	22050252	Pay Pharmacy	NEED LABOURS 3 NOS FOR SHIFTING TAILORING BUNDALS FROM PAY PHARMACY TO TAILING DEPT.	Pandiaraj. V.	shifting work		Ilayaraja.S. - Tailoring Department	09/05/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 29/06/2022 Status : Completed								
2700	22061049	Work Shop	NEED LABOURS 3 NOS FOR SHIFTING BERO FROM WORKSHOP TO TAILORING DEPARTMENT	Pandiaraj. V.,Yuvaraj. M.,Murali. K.	Shifting work has been done		Ilayaraja.S. - Tailoring Department	01/07/2022
Comp. Dt. : 05/07/2022 Status : Completed								
2701	22070129	LAUNDRY	NEED LABOURS 4 NOS FOR TAILORING MATERIALS SHIFTING WORK FROM LAUNDRY TO TAILORING DEPT I FLOOR	Pandiaraj. V.,Yuvaraj. M.,Prakash. N.	Materials shifting work done		Ilayaraja.S. - Tailoring Department	06/07/2022
Comp. Dt. : 02/11/2022 Status : Completed								
2702	22110012	Tailoring Department	TOILET BLOCKED,NEED SCAVENGER	Rajendhiran. V.,Murugan. S.,Thanuzkodi. E	Block removed.		Ilayaraja.S. - Tailoring Department	03/11/2022
Comp. Dt. : 17/11/2022 Status : Completed								
2703	22110696	Tailoring Department	NEED 6 NO'S MANPOWER FOR SHIFTING PURPOSE	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	Cloth material bundle shifting work completed		Ilayaraja.S. - Tailoring Department	18/11/2022
Dept Name : TB & CHEST - Civil - Maintenance Comp. Dt. : 29/08/2022 Status : Completed								
2704	22080966	TB & Chest OPD	WATER LEAKAGE IN CEILING - NEED URGENT SERVICE	Prakash. V.,Ramkumar. R.,Sankar. V.	surgery opd toilet leakage.		Kirubasankar. E. - TB & CHEST	30/08/2022
Dept Name : Transport - Civil - Maintenance Comp. Dt. : 24/06/2022 Status : Completed								
2705	22060873	NURSING COLLEGE OPP BUS STAND	NEED TO CHECK PIPE LINE - BROKING & WATER FLOW - NEED URGENT SERVICE	Sellaveeran. M.,Udhaya Kumar. R.,Santhosh Kumar. M.	3/4" PVC pipe line fully rework, Pipe 2length and elbow changed, work completed		Sasikumar. P. - Transport	30/06/2022
Comp. Dt. : 27/07/2022 Status : Completed								
2706	22071008	COMMERCIAL BLOCK	DRAINAGE OVERFLOW - NEED URGENT SERVICE	Thanuzkodi. E.,Govindan. R.,Murugan. S.	Block removed.		Man.T. - Transport	29/07/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 01/08/2022 Status : Completed								
2707	22080046	COMMERCIAL BLOCK	FLUSH - DAMAGE & NOT WORKING - WATER LEAKAGE AT COMMERCIAL BLOCK READING ROOM	Govindan. R., Sakthivel. E., Thanuzkodi. E	Chamber block removed		Balasundaram. C. - Transport	03/08/2022
Comp. Dt. : 03/08/2022 Status : Completed								
2708	22080143	COMMERCIAL BLOCK	Water leakage in the chamber near commercial block	Rajendhiran. V., Murugan. S., Thanuzkodi. E	Block removed.		Karthikeyan. P. - Transport	06/08/2022
Comp. Dt. : 24/08/2022 Status : Completed								
2709	22080789	Work Shop	NEED TO FIX NEW TAP FOR HAND WASH PURPOSE	Prakash. V., Rajendran. R., Ramkumar. R.	3/4 water line rework.		Sasikumar. P. - Transport	30/08/2022
Comp. Dt. : 10/09/2022 Status : Completed								
2710	22090403	CAR PARKING AREA	NEED REPAIRING WORK FOR COMPRESSOR AT CAR SHED - BUS SERVICE AREA	Prakash. V., Rajendran. R., Ramkumar. R.	3/4" GI pipe line compressor water line make it, work completed		Sasikumar. P. - Transport	17/09/2022
Comp. Dt. : 27/01/2023 Status : Completed								
2711	23010958	WATER SERVICE	WATER SUMP CLEANING WORK NEED TO DO	Gurunathan. V., Govindan. R., Thanuzkodi. E	Sump cleaning work completed		Mohan. T. - Transport	03/02/2023
Comp. Dt. : 08/04/2023 Status : Completed								
2712	23040245	BIOMEDICAL WASTAGE ROOM - BACKSIDE OF ORTHO OPD	NEED TO CHECK WATER PIPELINE - LEAKAGE AT BIOMEDICAL WASTAGE ROOM - BAD SMELL & INSECTS PROBLEM	Anandharaj. M., Azhagar. N., Sellaveeran. M.	Toilet block removed, work completed		Kumar. R. - Transport	19/04/2023
Dept Name : UHC Villupuram - Civil - Maintenance Comp. Dt. : 23/06/2022 Status : Completed								
2713	22060853	ASSOCIATIVE PROFESSOR QUARTERS	NEED TO CHANGE REST ROOM TAP - WATER LEAKAGE - QUARTERS NO B 11	Prakash. V.	2 spindle changed.	 Dr. KAGNE. R.N DEAN SRI MANAKULA VINAYAGAR MEDICAL COLLEGE & HOSPITAL KALITHEERTHAL KUPPAM, PUDUCHERRY-605107.	Asaithambi. R. - UHC Villupuram	25/06/2022

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 12/07/2022								
Status : Completed								
2714	22070456	UHC Villupuram	NEED TO CHANGE TAP - WATER LEAKAGE	Rajendran. R.	New connection tube and tap rework		Rathinamala. A. - UHC Villupuram	19/07/2022
Comp. Dt. : 05/10/2022								
Status : Completed								
2715	22100069	UHC Villupuram	NEED TO CHANGE TAP - BROKEN & WATER FLOW - NEED URGENT SERVICE	Prakash. V.,Rajendran. R.,Ramkumar. R.	Tap changed.		Sankari. J. - UHC Villupuram	08/10/2022
Comp. Dt. : 17/04/2023								
Status : Completed								
2716	23040508	UHC Villupuram	NEED TO CHECK PIPE LINE - WATER LEAKAGE AT OUTSIDE PIPE	Rajendran. R.	Health faucet, wash basin outlet water line rework, problem solved		Rathinamala. A. - UHC Villupuram	19/04/2023
Comp. Dt. : 09/05/2023								
Status : Completed								
2717	23050369	UHC Villupuram	BLOCK IN WASH BASIN - NEED URGENT SERVICE	Rajendhiran. V.	BLOCK REMOVED.		Sankari. J. - UHC Villupuram	10/05/2023
Dept Name : Ward - Civil - Maintenance								
Comp. Dt. : 07/07/2022								
Status : Completed								
2718	22070289	RADIOLOGY	NEED LABOURS 2NOS FOR "S" TYPE CHAIR SHIFTING WORK FROM RADIOLOGY TO WORKSHOP	Pandiaraj. V.,Yuvaraj. M.,Murali. K.	chair shifting work done		Jerina Begum. P. - Ward	12/07/2022
Comp. Dt. : 27/09/2022								
Status : Completed								
2719	22091070	RADIOLOGY	BLOCK IIN RESTROOM	Rajendhiran. V.,Thanuzkodi. E,Murugan. S.	Block removed.		Jerina Begum. P. - Ward	28/09/2022
Comp. Dt. : 24/11/2022								
Status : Completed								
2720	22111042	RADIOLOGY	IN BASEMENT REST ROOM BLOCK,NEED SCAVENGER	Rajendhiran. V.,Murugan. S.,Thanuzkodi. E	Block removed.		Jerina Begum. P. - Ward	24/11/2022
Comp. Dt. : 02/12/2022								
Status : Completed								
2721	22120077	XRay	RESTROOM BLOCK (BASEMENT XRAY)	Murugan. S.,Thanuzkodi. E,Rajendhiran. V.	Block removed.		Jerina Begum. P. - Ward	02/12/2022

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 03/12/2022 Status : Completed								
2722	22120108	New OT	SINK BLOCK	Rajendhiran. V.,Thanuzkodi. E,Murugan. S.	block removed.		Sarala. P. - Ward	05/12/2022
Comp. Dt. : 08/02/2023 Status : Completed								
2723	23020300	RADIOLOGY	REST ROOM WATER BLOCK	Rajendhiran. V.,Thanuzkodi. E,Murugan. S.	BLOCK REMOVED.		Jerina Begum. P. - Ward	09/02/2023
Comp. Dt. : 24/03/2023 Status : Completed								
2724	23031009	BASEMENT	BLOCK IN RESTROOM	Rajendhiran. V.,Thanuzkodi. E,Murugan. S.	BLOCK REMOVED.		Jerina Begum. P. - Ward	25/03/2023
Comp. Dt. : 24/04/2023 Status : Completed								
2725	23040757	RADIOLOGY	BLOCK - BASEMENT RESTROOM	Rajendhiran. V.,Thanuzkodi. E,Murugan. S.	BLOCK REMOVED.		Jerina Begum. P. - Ward	26/04/2023
Comp. Dt. : 12/05/2023 Status : Completed								
2726	23050516	RADIOLOGY	BLOCK IN REST ROOM - ROOM NO 1	Rajendhiran. V.,Thanuzkodi. E,Murugan. S.	Toilet block removed, work completed		Jerina Begum. P. - Ward	13/05/2023
Comp. Dt. : 29/05/2023 Status : Completed								
2727	23051155	SPECIALITY OPD	WATER NOT COMING	Anandharaj. M.	WORK COMPLETED		Amudha Durairaj - Ward	31/05/2023
Comp. Dt. : 10/06/2023 Status : Completed								
2728	23060353	XRay	BLOCK IN WASH BASIN DRAINAGE HOSE - AT BASEMENT NEAR REST ROOM	Rajendhiran. V.,Thanuzkodi. E,Murugan. S.	block removed.		Jerina Begum. P. - Ward	10/06/2023
Dept Name : Work Shop - Civil - Maintenance Comp. Dt. : 04/05/2022 Status : Completed								
2729	22050072	Work Shop	NEED TO CHANGE TAP - WATER LEAKAGE	Prakash. V.,Rajendran. R.,Sankar. V.	New tap changed.		Ganesan. A. - Work Shop	04/05/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 07/06/2022 Status : Completed								
2730	22060280	Work Shop	NEED LABOURS 2 NOS FOR CUPBOARD SHIFTING WORK FROM WORKSHOP TO DENTAL OPD II FLOOR ON 08.06.2022 AT	Pandiaraj. V.,Murali. K.,Senthil Kumar. R.	cupboard shifting work done		Ganesan. A. - Work Shop	15/06/2022
Comp. Dt. : 24/06/2022 Status : Completed								
2731	22060880	Work Shop	NEED LABOURS 4 NOS FOR SHIFTING CUPBOARDS FROM WORKSHOP TO II FLOOR DENTAL OPD	Pandiaraj. V.,Yuvaraj. M.,Murali. K.	Cupboards shifted.		Ganesan. A. - Work Shop	25/06/2022
Comp. Dt. : 27/07/2022 Status : Completed								
2732	22071040	Work Shop	NEED LABOURS 2 NOS FOR SHIFTING CUPBOARD FROM WORKSHOP TO NEPROLOGY [NEED ON 28.07.2022 AT 9. A.M	Pandiaraj. V.,Yuvaraj. M.,Murali. K.	Cupboard shifting work completed		Ganesan. A. - Work Shop	01/08/2022
Comp. Dt. : 18/08/2022 Status : Completed								
2733	22080600	Female Medical - Ward 305	Wash basin clamp rusted, to be change	Pandiaraj. V.,Yuvaraj. M.,Murali. K.	Wash basin clamp fixed.		Ganesan. A. - Work Shop	03/09/2022
Comp. Dt. : 22/09/2022 Status : Completed								
2734	22090881	Work Shop	NEED NEW PIPELINE CONNECTION FROM TAMIL NADU BOARD TO WORKSHOP	Prakash. V.,Rajendran. R.,Ramkumar. R.	New pipe line connection given to Workshop from Tamil nadu bore water.		Ganesan. A. - Work Shop	27/10/2022
Comp. Dt. : 22/11/2022 Status : Completed								
2735	22110904	Female Medical Ward	NEED LABOURS 4 NOS FOR SHIFTING UNWANTED PLYWOOD SHEETS FROM WARD NO 305 & 306 TO WORKSHOP	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	Unwanted plywood sheets shifting work completed.		Ganesan. A. - Work Shop	25/11/2022
Comp. Dt. : 05/12/2022 Status : Completed								
2736	22120209	RADIOLOGY	NEED LABOURS FOR CHAIR SHIFTING WORK	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	chair shifting work completed.		Ganesan. A. - Work Shop	09/12/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 08/12/2022 Status : Completed								
2737	22120344	Work Shop	NEED LABOURS 4 NOS FOR MATERIAL SHIFTING WORK TO SPECIAL WARD B	Pandiaraj. V.,Yuvaraj. M.,Thulasi. V.	material shifting work done.		Ganesan. A. - Work Shop	09/12/2022
Comp. Dt. : 30/12/2022 Status : Completed								
2738	22121374	RADIOLOGY	NEED LABOURS FOR CUPBOARD SHIFTING WORK TO X-RAY	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	Cupboard shifted from workshop department to xray room		Ganesan. A. - Work Shop	02/01/2023
Comp. Dt. : 22/02/2023 Status : Completed								
2739	23020868	Work Shop	NEED MAN POWER --2 NOS OF CUPBOARD SHIFTING WORK. (WORKSHOP TO SPECIAL CLINIC 100)	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	CUPBOARDS SHIFTED FROM WORKSHOP TO SPECIAL CLINIC100		Ganesan. A. - Work Shop	25/02/2023
Comp. Dt. : 15/06/2023 Status : Completed								
2740	23060553	Polytechnic college	PIPE SHIFTING WORK(GROUND FLOOR TO 4TH FLOOR)--NEED MAN POWER(4 NOS)	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	Pipe shifted from ground floor to 4th floor		Ganesan. A. - Work Shop	24/06/2023
Comp. Dt. : 24/06/2023 Status : Completed								
2741	23060912	Work Shop	BLOCK IN WORKSHOP - NEED URGENT SERVICE	Thanuzkodi. E,Rajendhiran. V.,Murugan. R.	Block removed.		Ganesan. A. - Work Shop	26/06/2023
Work Type : Work Dept Name : Administration - Civil - Maintenance Comp. Dt. : 14/06/2022 Status : Completed								
2742	22060509	Main Lobby	NEED LABOURS 8 NOS FOR SHIFTING WORK STATION [2NOS] FROM MAIN PORTICO TO BASEMENT STORE	Pandiaraj. V.,Yuvaraj. M.,Murali. K.	Shifting work done		Motheeswarar. R.S. - Administration	17/06/2022
Comp. Dt. : 21/06/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2743	22060769	HOSPITAL ENTRANCE FRONT CORRIDOR	NEED LABOURS 4 NOS FOR UNLOADING WORK [FRIDGE 8 NOS] FROM HOSPITAL CARRIDOR TO BASEMENT STORES	Pandiaraj. V.,Yuvaraj. M.,Murali. K.	unloading work done from hospital corridor to basement stores.		Motheeswarar. R.S. - Administration	21/06/2022
Comp. Dt. : 28/06/2022 Status : Completed								
2744	22061019	Main Lobby	NEED LABOURS 5 NOS FOR SHIFTING WORK [MACHINE] AT MAIN PORTIGO TO BASEMENT GENERAL STORE	Pandiaraj. V.,Yuvaraj. M.,Thulasi. V.	Shifting work done		Motheeswarar. R.S. - Administration	01/07/2022
Comp. Dt. : 05/08/2022 Status : Completed								
2745	22080211	Main Lobby	NEED LABOURS 4 NOS FOR UNLOADING RECORD BOOK BUNDALS FROM MAIN PORTIGO TO BASEMENT STORE ROOM	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	unloading work completed.		Motheeswarar. R.S. - Administration	11/08/2022
Comp. Dt. : 13/08/2022 Status : Completed								
2746	22080479	Main Lobby	NEED LABOURS 4 NOS FOR UNLOADING STORE ITEMS FROM PARTICO TO BASEMENT STORES	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	Unloading work completed.		Motheeswarar. R.S. - Administration	18/08/2022
Comp. Dt. : 20/08/2022 Status : Completed								
2747	22080669	Main Lobby	NEED LABOURS 4 NOS FOR UNLOADING BUNDLES [34 NO] FROM MAIN PORTICO TO BASEMENT GENERAL STORES	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	Shifting work done.		Motheeswarar. R.S. - Administration	23/08/2022
Comp. Dt. : 09/09/2022 Status : Completed								
2748	22090375	General Stores[Linen]	NEED MAN POWER 4 NOS FOR MACHINE SHIFTING WORK FROM RECEPTION PORTICO TO GENERAL STORE	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	work completed.		Motheeswarar. R.S. - Administration	10/09/2022
Comp. Dt. : 29/09/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2749	22091168	Free Pharmacy	NEW CT MACHINE ARRIVE TODAY AT 2 P.M - NEED MANPOWER 10 NOS FOR UNLOADING MACHINE FROM PORTICO T	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	Unloading work completed.		Motheeswarar. R.S. - Administration	01/10/2022
Comp. Dt. : 09/12/2022 Status : Completed								
2750	22120449	Main Lobby	NEED MANPOWER 2 NOS FOR UNLOADING PAPER BUNDALS FROM MAIN LOBBY TO BASEMENT STORE ROOM	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	Paper bundals shifting work completed.		Arulkumaran. S. - Administration	10/12/2022
Comp. Dt. : 06/04/2023 Status : Completed								
2751	23040197	Main Lobby	NEED MANPOWER 4 NOS FOR UNLOADING WORK FROM MAIN PORTICO TO GENERAL STORE	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	UNLOADING WORK COMPLETED		Motheeswarar. R.S. - Administration	08/04/2023
Comp. Dt. : 24/06/2023 Status : Completed								
2752	23060926	Main Lobby	NEED MAN POWER 3 NUMBERS FOR UNLOADING BIO MEDICAL WASTE COVER FROM MAIN PORTIGO TO BASEMENT STORE	Yuvaraj. M.,Senthil Kumar. R.,Murali. K.	Biomedical waste cover shifted from main portigo to basement store.		Motheeswarar. R.S. - Administration	28/06/2023
Dept Name : Air Condition Department - Civil - Maintenance Comp. Dt. : 12/10/2022 Status : Completed								
2753	22100353	C' WING TERRACE - V FLOOR	NEED OF AIR CONTITION FIXING - NEED NEW WATER TANK AT TERRACE "C" WING SIDE	Prakash. V.,Rajendran. R.,Ramkumar. R.	Civil execution complaint		Saravanan. C. - Air Condition Department	12/10/2022
Dept Name : BIOCHEMISTRY - Civil - Maintenance Comp. Dt. : 12/04/2023 Status : Completed								
2754	23040356	BIOCHEMISTRY--COLLEGE	NEED MANPOWER 2NOS FOR BERO SHIFTING WORK - NEED URGENT	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	Bero shifting work completed		Suganthi. P. - BIOCHEMISTRY	20/04/2023
Dept Name : Biomedical - Civil - Maintenance Comp. Dt. : 17/05/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2755	22050636	Biomedical	NEED LABOURS 2NOS FOR SHIFTING WORK -	Sakthivel. E.,Pandiaraj. V.,Yuvaraj. M.	Biomedical materials and machines shifted		Premkumar. G. - Biomedical	18/05/2022
Comp. Dt. : 30/03/2023 Status : Completed								
2756	23031276	Biomedical	NEED LABOURS 2 NOS FOR SHIFTING INSTRUMENTS FROM BIOMEDICAL TO II FLOOR BIOMEDICAL STORE ROOM	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	Repeated complaint		Sridhar. K. - Biomedical	17/04/2023
Comp. Dt. : 03/04/2023 Status : Completed								
2757	23040061	Biomedical	NEED MANPOWER 2 NOS FOR INSTRUMENT SHIFTING WORK FROM BIOMEDICAL TO BIOMEDICAL STOREROOM	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	Shifting work completed		Sridhar. K. - Biomedical	19/04/2023
Dept Name : BLOOD BANK - Civil - Maintenance Comp. Dt. : 29/07/2022 Status : Completed								
2758	22071065	Blood Bank	NEED LABOURS 2 NOS FOR BOX SHIFTING WORK TO IV FLOOR [NEED ON 30.07.2022 @9 A.M.]	Pandiaraj. V.	box shifting work done		Ganesh. V. - BLOOD BANK	30/07/2022
Comp. Dt. : 09/08/2022 Status : Completed								
2759	22080295	Blood Bank	NEED LABOURS 2 NOS FOR SHIFTING RECORD BOXES FROM BLOOD BANK TO MRD	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	Record note shifting work completed		Ganesh. V. - BLOOD BANK	11/08/2022
Comp. Dt. : 16/09/2022 Status : Completed								
2760	22090656	Blood Bank	NEED LABOURS 2 NOS FOR BANNER FIXING WORK AT MAIN GATE ENTRANCE	Pandiaraj. V.	Baner fixed, work completed		Ganesh. V. - BLOOD BANK	17/09/2022
Comp. Dt. : 21/09/2022 Status : Completed								
2761	22090805	Blood Bank	NEED LABOURS 2 NOS FOR SHIFTING BOXES [RECORD] FROM BLOOD BANK TO MRD	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	boxes shifted.		Ganesh. V. - BLOOD BANK	22/09/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Dept Name : Canteen - Hospital - Civil - Maintenance Comp. Dt. : 19/05/2022 Status : Completed								
2762	22050683	DIET DEPARMENT	NEED LABOURS 5 NOS FOR SHIFTING RICE BAGS [50 NOS] FROM V FLOOR TO STORE ROOM	Thulasi. V.,Senthil Kumar. R.,Murali. K.	Rice bags shifted from ground floor to 5th floor terrace.		Shaik Haja Mohideen. S.M. - Canteen - Hospital	20/05/2022
Comp. Dt. : 23/05/2022 Status : Completed								
2763	22050813	DIET DEPARMENT	NEED LABOURS 5 NOS FOR UPLOADING WORK FROM V FLOOR TO STORE ROOM	Pandiaraj. V.,Yuvaraj. M.,Sakthivel. E.	uploading work done		Shaik Haja Mohideen. S.M. - Canteen - Hospital	25/05/2022
Comp. Dt. : 27/05/2022 Status : Completed								
2764	22051012	DIET DEPARMENT	NEED LABOURS 6 NOS FOR SHIFTING RICE BAGS FROM V FLOOR TO STORE ROOM	Yuvaraj. M.,Senthil Kumar. R.,Murali. K.	rice shifting work		Shaik Haja Mohideen. S.M. - Canteen - Hospital	27/05/2022
Comp. Dt. : 26/08/2022 Status : Completed								
2765	22080862	DIET DEPARMENT	NEED LABOURS 6 NOS FOR SHIFTING RICE BAGS [45 NOS] FROM NEAR OPTHAL OPD TO V FLOOR DIET	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	Work completed.		Suriyaprakash. R. J. - Canteen - Hospital	30/08/2022
Comp. Dt. : 15/09/2022 Status : Completed								
2766	22090615	DIET DEPARMENT	NEED LABOURS 3 NOS FOR UNLOADING DIET ITEMS FROM 5TH FLOOR TO STORE ROOM	Pandiaraj. V.,Prakash. N.,Yuvaraj. M.	work completed.		Suriyaprakash. R. J. - Canteen - Hospital	16/09/2022
Comp. Dt. : 26/09/2022 Status : Completed								
2767	22090991	OPTICAL SHOP NEAR OPTHAL OPD	NEED LABOURS 5 NOS FOR SHIFTING RICE BAGS FROM NEAR OPTHAL OPD TO VI FLOOR DIET STORE ROOM	Prakash. N.,Pandiaraj. V.,Yuvaraj. M.	Rice bags shifting work completed.		Suriyaprakash. R. J. - Canteen - Hospital	26/09/2022
Comp. Dt. : 06/10/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2768	22100121	DIET DEPARMENT	NEED LABOURS 5 NOS FOR UNLOADING RICE BAGS FROM 5 FLOOR TO 6 FLOOR	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	Rice bag shifting work completed.		Suriyaprakash. R. J. - Canteen - Hospital	07/10/2022
Comp. Dt. : 11/10/2022 Status : Completed								
2769	22100265	OPTICAL SHOP NEAR OPTHAL OPD	NEED LABOURS 6 NOS FOR UNLOADING RICE BAGS [40 NOS] - FROM OPTICAL SHOP TO 5 FLOOR DIET DEPT.	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	Rice bags shifting work completed.		Suriyaprakash. R. J. - Canteen - Hospital	11/10/2022
Comp. Dt. : 18/10/2022 Status : Completed								
2770	22100564	DIET DEPARMENT	NEED LABOUR 4 NOS FOR UNLOADING RICE BAGS FROM V FLOOR TO VI FLOOR STORE ROOM	Senthil Kumar. R.,Murali. K.,Prakash. N.	Rice bags unloading and shifting work completed		Suriyaprakash. R. J. - Canteen - Hospital	20/10/2022
Comp. Dt. : 15/12/2022 Status : Completed								
2771	22120674	OPTICAL SHOP NEAR OPTHAL OPD	NEED MANPOWER 6 NOS FOR UNLOADING RICE BAGS 60 NOS FROM OPTICAL SHOP NEAR OPTHAL OPD TO VI FLOOR DI	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	Rice bags shifting work done.		Suriyaprakash. R. J. - Canteen - Hospital	17/12/2022
Comp. Dt. : 05/01/2023 Status : Completed								
2772	23010204	DIET DEPARMENT	NEED LABOURS 5 NO'S FOR RICE BAGS SHIFTING WORK FROM 4 FLOOR TO 5 FLOOR	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	Rice bags shifting work completed.		Suriyaprakash. R. J. - Canteen - Hospital	06/01/2023
Comp. Dt. : 28/01/2023 Status : Completed								
2773	23010997	OPTICAL SHOP NEAR OPTHAL OPD	NEED MANPOWER 6 NOS FOR SHIFTING RICE BAGS 65 NOS FROM OPTICAL SHOP NEAR OPTHAL OPD TO DIET STORE V	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	Rice bags shifted to terrace		Suriyaprakash. R. J. - Canteen - Hospital	28/01/2023
Comp. Dt. : 17/02/2023 Status : Completed								
2774	23020661	DIET DEPARMENT	NEED MANPOWER 6 NOS FOR SHIFTING RICE BAGS FROM GROUND FLOOR OPTHAL SHOP NEAR TO V FLOOR DIET STORE	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	Rice bag shifting work completed		Suriyaprakash. R. J. - Canteen - Hospital	17/02/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 03/03/2023 Status : Completed								
2775	23030154	DIET DEPARMENT	NEED MANPOWER 3 NOS FOR UNLOADING WORK	Prakash. N.,Thulasi. V.,Senthil Kumar. R.	UNLOADING WORK COMPLETED.		Suriyaprakash. R. J. - Canteen - Hospital	04/03/2023
Comp. Dt. : 04/03/2023 Status : Completed								
2776	23030158	DIET DEPARMENT	NEED MANPOWER 5 NOS FOR SHIFTING WORK FROM V FLOOR TO VI FLOOR STORE ROOM	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	HIFTING WORK COMPLETED.		Suriyaprakash. R. J. - Canteen - Hospital	04/03/2023
Comp. Dt. : 07/03/2023 Status : Completed								
2777	23030247	DIET DEPARMENT	NEED MANPOWER 4 NOS FOR SHIFTING RICE BAGS FROM V FLOOR TO VI FLOOR STORE ROOM	Pandiaraj. V.,Yuvaraj. M.,Murali. K.	RICE BAGS SHIFTED FROM 5th FLOOR TO 6th FLOOR STORE ROOM		Suriyaprakash. R. J. - Canteen - Hospital	07/03/2023
Comp. Dt. : 24/03/2023 Status : Completed								
2778	23031010	DIET DEPARMENT	NEED MAN POWER 4 NOS FOR UNLOADING RICE BAGS FROM V FLOOR TO VI FLOOR STORE ROOM	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	RICE BAGS UNLOADING WORK COMPLETED		Suriyaprakash. R. J. - Canteen - Hospital	25/03/2023
Comp. Dt. : 28/03/2023 Status : Completed								
2779	23031143	OPTICAL SHOP NEAR OPHTHAL OPD	NEED MANPOWER 5 NOS FOR UNLOADING RICE BAGS FROM - NEAR OPTICAL SHOP TO VI FLOOR DIET STORE ROOM	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	Rice bags shifting work completed		Suriyaprakash. R. J. - Canteen - Hospital	28/03/2023
Comp. Dt. : 10/04/2023 Status : Completed								
2780	23040258	DIET DEPARMENT	NEED MANPOWER 3 NOS FOR UNLOADING RICE BAGS FROM V FLOOR TO VI FLOOR	Pandiaraj. V.,Murali. K.,Yuvaraj. M.	Rice bags shifting work completed		Suriyaprakash. R. J. - Canteen - Hospital	17/04/2023
Comp. Dt. : 12/04/2023 Status : Completed								
2781	23040381	Orthopaedics - OPD	NEED MANPOWER 6 NOS FOR UNLOADING RICE BAGS [60 NOS] FROM NEAR ORTHO OPD TO 6TH FLOOR	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	RICE BAGS UNLOADING WORK COMPLETED.		Suriyaprakash. R. J. - Canteen - Hospital	13/04/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 03/05/2023 Status : Completed								
2782	23050114	OPTICAL SHOP NEAR OPTHAL OPD	NEED MANPOWER 6 NOS FOR UNLOADING WORK FROM OPTICAL SHOP ENTRANCE TO VI FLOOR DIEET STORE ROOM ON	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	Rice bags shifting work completed		Suriyaprakash. R. J. - Canteen - Hospital	04/05/2023
Comp. Dt. : 16/05/2023 Status : Completed								
2783	23050622	DIET DEPARMENT	NEED MAN POWER 6 NOS FOR UNLOADING WORK FROM V FLOOR TO VI FLOOR	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	Unloading work completed		Suriyaprakash. R. J. - Canteen - Hospital	16/05/2023
Comp. Dt. : 19/05/2023 Status : Completed								
2784	23050779	HOSPITAL IV FLOOR	NEED MANPOWER 4 NOS FOR UNLOADING WORK FROM IV FLOOR TO IV FLOOR [WHEEL BAG 10 NOS]	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	WORK COMPLETED		Suriyaprakash. R. J. - Canteen - Hospital	19/05/2023
Comp. Dt. : 25/05/2023 Status : Completed								
2785	23050975	OPTICAL SHOP NEAR OPTHAL OPD	NEED MANPOWER 6 NOS FOR RICE BAGS [62NOS] UNLOADING WORK FROM OPTICAL SHOP NEAR OPTHAL OPD TO IV F	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	WORK COMPLETED		Suriyaprakash. R. J. - Canteen - Hospital	25/05/2023
Comp. Dt. : 19/06/2023 Status : Completed								
2786	23060645	DIET DEPARMENT	NEED MANPOWER 5 NOS FOR UNLOADING WORK FROM V FLOOR TO VI FLOOR STORE ROOM	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	Unloading work done from V floor to VI floor store room.		Suriyaprakash. R. J. - Canteen - Hospital	24/06/2023
Comp. Dt. : 22/06/2023 Status : Completed								
2787	23060837	DIET DEPARMENT	NEED MANPOWER 5 NOS FOR OIL TIN & RICE BAG UNLOADING WORK FROM V TO VI FLOOR STORE ROOM	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	Oil Tin & Rice bag unloaded from V floor to VI floor store room.		Suriyaprakash. R. J. - Canteen - Hospital	24/06/2023
Dept Name : Canteen-Girls Hostel - Civil - Maintenance Comp. Dt. : 02/05/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2788	22050045	JR Quarters	NEED LABOURS 2 NOS FOR COT SHIFTING WORK FROM GROUND FLOOR TO I FLOOR	Pandiaraj. V.,Yuvaraj. M.,Thulasi. V.	COT shifting work completed.		Virgin Mary - Canteen-Girls Hostel	04/05/2022
Comp. Dt. : 16/07/2022 Status : Completed								
2789	22070632	Ladies hostel Phase-I	NEED LABOURS [2 NOS] FOR SHIFTING WORK - [OLD GRINDER] SHIFT TO WORKSHOP	Murali. K.	Old grinder shifted		Revathy. N. - Canteen-Girls Hostel	18/07/2022
Comp. Dt. : 08/08/2022 Status : Completed								
2790	22080271	Ladies hostel Phase-I	NEED LABOURS 3 NOS FOR SHIFTING COT [20 NOS] FROM PHASE I TO PHASE II	Pandiaraj. V.	Cot shifting work completed		Malliga. K. - Canteen-Girls Hostel	09/08/2022
Comp. Dt. : 09/08/2022 Status : Completed								
2791	22080346	Ladies hostel Phase-II	NEED LABOURS 3 NOS FOR COT SHIFTING WORK FROM JR TO LADIES HOSTEL PHASE II	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	shifting work completed.		Malliga. K. - Canteen-Girls Hostel	11/08/2022
Comp. Dt. : 07/09/2022 Status : Completed								
2792	22090272	JR Quarters	NEED LABOURS 3 NOS FOR COT SHIFTING WORK FROM JR QUARTERS TO LADIES HOSTEL PHASE II	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	work completed.		Malliga. K. - Canteen-Girls Hostel	10/09/2022
Comp. Dt. : 12/09/2022 Status : Completed								
2793	22090424	JR Quarters	NEED LABOURS 3 NOS FOR SHIFTING WORK FOR UNWANTED DOOR 3NOS & COOLER 1 NO FROM JR TO WORKSHOP	Pandiaraj. V.,Yuvaraj. M.,Thulasi. V.	Work completed.		Virgin Mary - Canteen-Girls Hostel	21/09/2022
Comp. Dt. : 16/09/2022 Status : Completed								
2794	22090628	JR Quarters	NEED LABOURS 4 NOS FOR PAINTED COT SHIFTING WORK FROM GROUND FLOOR TO II FLOOR	Pandiaraj. V.,Prakash. N.,Yuvaraj. M.	Cot shifting work completed		Virgin Mary - Canteen-Girls Hostel	23/09/2022
Comp. Dt. : 17/09/2022								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
2795	22090669	JR Quarters	NEED LABOURS 4 NOS FOR COT SHIFTING WORK FROM GROUND FLOOR TO II FLOOR	Pandiaraj. V.,Yuvaraj. M.,Thulasi. V.	work completed.		Virgin Mary - Canteen-Girls Hostel	21/09/2022
Comp. Dt. : 31/10/2022								
Status : Completed								
2796	22101023	J.R Quateres	Need to be clean Honey bee nest - 2 Nos, very urgent	Sivaraja. M.	Honey comb 2Nos destroyed, work completed		Virgin Mary - Canteen-Girls Hostel	31/10/2022
Comp. Dt. : 02/03/2023								
Status : Completed								
2797	23030071	Ladies hostel Phase-II	NEED MANPOWER 4 NOS FOR OLD COOLER SHIFTING WORK	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	OLD COOLER SHIFTING WORK COMPLETED.		Malliga. K. - Canteen-Girls Hostel	17/03/2023
Dept Name : CARDIOLOGY - Civil - Maintenance								
Comp. Dt. : 18/07/2022								
Status : Completed								
2798	22070665	Female Surgery - Ward 205	NEED LABOURS [2 NOS] FOR COT [2 NOS] SHIFTING WORK FROM WARD NO 205 TO II FLOOR ECG ROOM	Pandiaraj. V.,Yuvaraj. M.,Prakash. N.	COT shifting work done		Priyanka. M. - CARDIOLOGY	21/07/2022
Comp. Dt. : 20/04/2023								
Status : Completed								
2799	23040667	CLINICAL DEPARTMENT IN 4th FLOOR	NEED MANPOWER 6 NOS FOR SHIFTING WORK [COT, PILLOW & TROLLEY] FROM CLINICAL DEPARTMENT IN 4th FLOOR	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	Cot, Pillow and trolley shifting work completed		Priyanka. M. - CARDIOLOGY	02/05/2023
Dept Name : Cardiothoracic ICU - Civil - Maintenance								
Comp. Dt. : 24/03/2023								
Status : Completed								
2800	23031018	CT POW -SPECIAL WARD B	NEED LABOUR 1 NO FOR SCREEN REMOVING WORK	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	SCREEN REMOVING WORK		Rosaria Baska Rani - Cardiothoracic ICU	25/03/2023
Dept Name : Cardiothoracic POW - Civil - Maintenance								
Comp. Dt. : 17/05/2022								
Status : Completed								
2801	22050608	CT-POST OPERATIVE WARD IN 4TH FLOOR	NEED LABOURS 2 NOS FOR SCREEN FIXING WORK	Sakthivel. E.	Screen fixing work completed		Jenifer Mary. P. - Cardiothoracic POW	18/05/2022

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 17/03/2023 Status : Completed								
2802	23030724	CT POW -SPECIAL WARD B	NEED MANPOWER 2NOS FOR SCREEN REMOVING WORK	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	SCREEN REMOVING WORK DONE.		Srimathi. V. - Cardiothoracic POW	20/03/2023
Dept Name : Cath Lab - Civil - Maintenance Comp. Dt. : 21/09/2022 Status : Completed								
2803	22090808	Cath Lab	NEED LABOURS 2 NOS FOR BANNER FIXING WORK AT MAIN GATE & OTHERPLACES	Pandiaraj. V.,Yuvaraj. M.,Murali. K.	banner fixing work completed		Muthukumaran. S. - Cath Lab	22/09/2022
Comp. Dt. : 22/09/2022 Status : Completed								
2804	22090860	Main Gate	NEED LABOURS 2 NOS FOR BANNER FIXING WORK AT MAIN ENTRANCE GATE & RECEPTION	Pandiaraj. V.	Banner fixing work.		Muthukumaran. S. - Cath Lab	22/09/2022
Comp. Dt. : 24/09/2022 Status : Completed								
2805	22090983	Cath Lab	NEED LABOURS 4 NOS FOR TABLE CHAIR ARRANGEMENT & BANNER FIXING WORK ON 26.09.2022 @ 8.30 A.M	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	Banner fixing work completed.		Muthukumaran. S. - Cath Lab	26/09/2022
Dept Name : Civil - Execution - Civil - Maintenance Comp. Dt. : 17/05/2022 Status : Completed								
2806	22050604	MIT College	NEED LABOURS 4 NOS FOR MATERIAL SHIFTING WORK FROM MIT SLAB ROOM TO POLYTECHNIC	Pandiaraj. V.,Yuvaraj. M.,Thulasi. V.	Shifting work completed		Sasikala. P. - Civil - Execution	21/05/2022
Comp. Dt. : 20/09/2022 Status : Completed								
2807	22090799	Nursing College	NEED HONEYCOMB DESTROYING WORK AT NURSING COLLEGE	Sivaraja. M.	Honey comb destroyed.		Murugan.N. - Civil - Execution	21/09/2022
Dept Name : Civil - Maintenance - Civil - Maintenance Comp. Dt. : 13/10/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2808	22100429	COMMERCIAL BLOCK	OSD sir Office room - wash basin block	Rajendran. R.	Wash basin block removed, work completed on that day		Gurunathan. V. - Civil - Maintenance	14/10/2022
Comp. Dt. : 23/12/2022 Status : Completed								
2809	22121050*	Ladies hostel Phase-I	Hostel front side tap broken, need to be change	Santhosh Kumar. M.	Dummy fixed.		Kumar. V. - Civil - Maintenance	02/01/2023
Dept Name : Clinical Department - Civil - Maintenance Comp. Dt. : 02/05/2022 Status : Completed								
2810	22050023	CLINICAL DEPARTMENT IN 2ND FLOOR	NEED LABOURS 3 NOS FOR CHAIR SHIFTING WORK [12 NOS] - FROM CLINICAL DEPT II FLOOR TO WORKSHOP	Pandiaraj. V.,Yuvaraj. M.,Thulasi. V.	Chair shifting work done		Vidhyavathi. S. - Clinical Department	02/05/2022
Comp. Dt. : 09/05/2022 Status : Completed								
2811	22050311	CLINICAL DEPARTMENT IN 2ND FLOOR	NEED LABOURS 4 NOS FOR SHIFTING BERO FROM GENERAL STORES TO II FLOOR CLINICAL DEPT	Pandiaraj. V.,Yuvaraj. M.,Thulasi. V.	Bero shifting work completed		Shuruthi. B. - Clinical Department	14/05/2022
Comp. Dt. : 21/05/2022 Status : Completed								
2812	22050788	CLINICAL DEPARTMENT IN 2ND FLOOR	NEED LABOURS 4 NOS FOR BERO SHIFTING WORK	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	Bero shifting work completed		Vidhyavathi. S. - Clinical Department	21/05/2022
Comp. Dt. : 05/07/2022 Status : Completed								
2813	22070127	MEDICAL COLLEGE	NEED LABOURS 3 NOS FOR BOOK READING HALL CHAIR ARRANGEMENT WORK	Pandiaraj. V.,Yuvaraj. M.,Thulasi. V.	Chair arrangement work completed		Parasuraman. R. - Medical Records	06/07/2022
Comp. Dt. : 23/02/2023 Status : Completed								
2814	23020894	General Medicine - OPD	NEED MANPOWER 2 NOS FOR BERO SHIFTING WORK	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	BERO SHIFTING WORK DONE		Selvi. A. - Clinical Department	25/02/2023
2815	23020898	CLINICAL DEPARTMENT IN 4th FLOOR	NEED MANPOWER 4 NOS FOR BERO [2NOS] SHIFTING WORK	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	BERO SHIFTING WORK DONE.		Bhuvana.M. - Clinical Department	25/02/2023
Comp. Dt. : 01/03/2023								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
2816	23030033	General Medicine - OPD	NEED MANPOWER 4NOS FOR BERO SHIFTING WORK FROM MEDICINE OPD TO I FLOOR ICU	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	BERO SHIFTING WORK COMPLETED.		Selvi. A. - Clinical Department	04/03/2023
Comp. Dt. : 09/03/2023								
Status : Completed								
2817	23030374	OG-OPD	NEED MANPOWER 4 NOS FOR CHAIR TABLE SHIFTING WORK	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	CHAIR TABLES SHIFTING WORK DONE.		Vimal. P. - Clinical Department	17/03/2023
Comp. Dt. : 06/06/2023								
Status : Completed								
2818	23060180	CLINICAL DEPARTMENT IN 2ND FLOOR	NEED MANPOWER 2 NOS FOR BERO SHIFTING [PLACE ADJUSTMENT] WORK	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	Bero shifting work completed		Vidhyavathi. S. - Clinical Department	09/06/2023
Dept Name : CLINICAL PATHOLOGY - Civil - Maintenance								
Comp. Dt. : 09/09/2022								
Status : Completed								
2819	22090371	Clinical Pathology	NEED MANPOWER 4NOS FOR SHIFTING INSTURMENT [2 WAY] FROM HOSPITAL TO MEDICAL COLLEGE	Pandiaraj. V.,Yuvaraj. M.,Prakash. N.	shifting work completed.		Vinod Gnana Kumar. D. - CLINICAL PATHOLOGY	10/09/2022
Comp. Dt. : 28/09/2022								
Status : Completed								
2820	22091133	Clinical Pathology	NEED LABOURS 2 NOS FOR INSTRUMENT SHIFTING WORK FROM HOSPITAL II FLOOR TO III FLOOR	Yuvaraj. M.,Thulasi. V.,Prakash. N.	Instrument shifting work completed.		Vinod Gnana Kumar. D. - CLINICAL PATHOLOGY	07/10/2022
Dept Name : Computer Department - Civil - Maintenance								
Comp. Dt. : 19/01/2023								
Status : Completed								
2821	23010662	EDP IN UNDERGROUND	NEED MAN POWER 3 NOS	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	Work completed.		Prakash. P. - Computer Department	21/01/2023
Dept Name : Director Office - Civil - Maintenance								
Comp. Dt. : 12/10/2022								
Status : Completed								
2822	22100357	A.P Quateres	NEED LABOURS 2 NOS FOR COT SHIFTING WORK	Pandiaraj. V.	cot shifting work completed		Mani. A. - Director Office	12/10/2022

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHAL KUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Dept Name : Electrical Maintenance - Civil - Maintenance Comp. Dt. : 15/11/2022 Status : Completed								
2823	22110620	SCAN - GROUND FLOOR - BLOOD BANK OPP	AT OUTER AREA-REQUEST TO PROVIDE NEW TAP CONNECTION FOR EARTHING PURPOSE	Prakash. V.,Ramkumar. R.,Rajendran. R.	New pipeline connection work done at D wing basement for electrical earthing purpose.		Azhagappan. J. - Electrical Maintenance	14/12/2022
Dept Name : EMERGENCY MEDICINE - Civil - Maintenance Comp. Dt. : 02/07/2022 Status : Completed								
2824	22070053	ENT WARD	DUE EXAMINATION HALL ARRANGEMENT WORK NEED LABOURS 4 NOS WARD NO 407 & 408	Pandiaraj. V.,Yuvaraj. M.,Murali. K.	Cot arrangment work completed		Bhuvaneswari. M. - ENT & Ophthal Ward	06/07/2022
Comp. Dt. : 23/09/2022 Status : Completed								
2825	22090948	Casualty	NEED LABOURS 4 NOS FOR COT ARRANGEMENT - NEED ON 24.09.2022 @ 9. A.M	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	Cot arrangement work completed.		Kanimozhi. E. - EMERGENCY MEDICINE	26/09/2022
Comp. Dt. : 14/02/2023 Status : Completed								
2826	23020541	Casualty	NEED LABOURS 5 NOS FOR COT SHIFTING WORK FROM CASUALTY TO IV FLOOR	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	COT SHIFTING WORK DONE		Kanimozhi. E. - EMERGENCY MEDICINE	15/02/2023
Dept Name : ENT & Ophthal Ward - Civil - Maintenance Comp. Dt. : 19/11/2022 Status : Completed								
2827	22110814	ENT WARD-408	NEED LABOURS 2NOS FOR COT SHIFTING WORK FROM WARD TO DEMO ROOM	Pandiaraj. V.,Yuvaraj. M.,Thulasi. V.	Cot shifting work completed.		Samundeeswari. E. - ENT & Ophthal Ward	25/11/2022
Comp. Dt. : 23/11/2022 Status : Completed								
2828	22110977	ENT WARD-407	NEED LABOURS 4 NOS FOR WARD RE ARRANGEMENT - AFTER COMPLITION OF EXAMINATION [2.P.M.]	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	COT arrangement work done.		Jayalakshmi. J. - ENT & Ophthal Ward	25/11/2022
Comp. Dt. : 13/01/2023 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2829	23010583	Female Medical - Ward 305	NEED LABOURS 2 NOS FOR BERO SHIFTING WORK	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	completed.		Bhuvaneswari. M. - ENT & Ophthal Ward	20/01/2023
Comp. Dt. : 13/02/2023 Status : Completed								
2830	23020475	ENT WARD-407	NEED MANPOWER 4 NS FOR EXAM HALL ARRANGEMENT WORK - NEED ON 14.02.2023 AT 8.30 A,M	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	HALL ARRANGEMENT WORK COMPELTED		Jayalakshmi. J. - ENT & Ophthal Ward	16/02/2023
Comp. Dt. : 20/02/2023 Status : Completed								
2831	23020735	ENT WARD	NEED MAN POWER 6 NOS FOR COT ARRANGEMENT WORK AT WARD NO 307 & 308	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	COT ARRANGEMENT WORK DONE		Agila. V. - ENT & Ophthal Ward	21/02/2023
Comp. Dt. : 21/02/2023 Status : Completed								
2832	23020780	Male Surgery - Ward 203	NEED MANPOWER 4 NOS FOR COT SHIFTING WORK	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	COT SHIFTING WORK COMPLETED.		Bhuvaneswari. M. - ENT & Ophthal Ward	21/02/2023
Comp. Dt. : 01/06/2023 Status : Completed								
2833	23060004	ENT WARD-407	NEED MANPOWER 4 NOS FOR COT SHIFTING WORK	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	Cot shifting work completed		Agila. V. - ENT & Ophthal Ward	01/06/2023
Comp. Dt. : 28/06/2023 Status : Completed								
2834	23061084	Female Medical - Ward 305	NEED MANPOWER 2NOS FOR SHIFTING WORK	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	WORK COMPLETED		Bhuvaneswari. M. - ENT & Ophthal Ward	04/07/2023
Dept Name : Female Medical Ward - Civil - Maintenance Comp. Dt. : 20/02/2023 Status : Completed								
2835	23020750	Paediatrics - Ward 309	NEED MANPOWER 2 NOS FOR SHIFTING OLD NURSE'S CABIN TO WORKSHOP	Thulasi. V.	OLD NURSE'S CABIN SHIFTING WORK COMPLETED.		Maniarasy. K. - Female Medical Ward	22/02/2023
Dept Name : Female Ortho Ward - Civil - Maintenance Comp. Dt. : 11/08/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2836	22080414	Female Ortho - Ward 402	NEED LABOUR 1 NO FOR SCREEN FIXING WORK	Pandiaraj. V.	Screen fixing work done.		Punitha. E. - Female Ortho Ward	12/08/2022
Comp. Dt. : 31/05/2023 Status : Completed								
2837	23051214	Female Ortho - Ward 402	NEED MANPOWER 3 NOS FOR COT ARRANGEMENT WORK	Pandiaraj. V., Yuvaraj. M., Senthil Kumar. R.	work completed		Girija. G. - Female Ortho Ward	31/05/2023
Dept Name : Female Surgery - Civil - Maintenance Comp. Dt. : 25/08/2022 Status : Completed								
2838	22080843	Male Surgery	NEED LABOUR 2 NOS FOR SCREEN FIXING WORK	Pandiaraj. V.	Screen fixed.		Vaidegi. S. - Female Surgery	03/09/2022
Comp. Dt. : 11/10/2022 Status : Completed								
2839	22100287	Male Surgery - Ward 203	NEED LABOURS 2 NOS FOR COT ARRANGEMENT WORK	Yuvaraj. M.	cot arrangement work done.		Vinodhini. K. - Female Surgery	12/10/2022
Dept Name : Gas Power Plant - Civil - Maintenance Comp. Dt. : 20/05/2022 Status : Completed								
2840	22050748	Printing Press	NEED LABOURS 4 NOS FOR UNLOADING PAPER BUNDLES FROM PRESS TO I FLOOR	Pandiaraj. V., Yuvaraj. M., Thulasi. V.	Paper bundle unloading and shifting work completed		Mahi Mohan Ram.S. - Gas Power Plant	21/05/2022
Comp. Dt. : 18/06/2022 Status : Completed								
2841	22060683	PRESS	NEED LABOURS 4 NOS FOR UNLOADING PAPER BUNDALS	Pandiaraj. V., Yuvaraj. M., Murali. K.	Paper bundles unloading work done.		Mahi Mohan Ram.S. - Gas Power Plant	20/06/2022
Comp. Dt. : 29/06/2022 Status : Completed								
2842	22061068	Printing Press	NEED LABOURS 5 NOS FOR UNLOADING PAPER BUNDALS FROM PRESS GROUND FLOOR TO I FLOOR	Prakash. N., Pandiaraj. V., Yuvaraj. M.	Paper bundals unloading work completed		Mahi Mohan Ram.S. - Gas Power Plant	01/07/2022
Comp. Dt. : 06/08/2022 Status : Completed								

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHAL KUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2843	22080231	Printing Press	NEED LABOOURS 4 NOS TOWRDS UNLOADING PAPER BUNDAL FROM PRESS GROUND FLOOR TO I FLOOR	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	Paper bundle unloading work completed		Mahi Mohan Ram.S. - Gas Power Plant	09/08/2022
Comp. Dt. :		20/09/2022						
Status :		Completed						
2844	22090798	Printing Press	NEED LABOURS 2NOS FOR UNLOADING PAPER BUNDALS FROM PRINTING PRESS TO I FLOOR	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	work compelted.		Mahi Mohan Ram.S. - Gas Power Plant	21/09/2022
Comp. Dt. :		22/09/2022						
Status :		Completed						
2845	22090892	Printing Press	A4 Paper box loading and unloading work	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	A4 paper unloading and shifting work completed		Mahi Mohan Ram.S. - Gas Power Plant	23/09/2022
Comp. Dt. :		23/09/2022						
Status :		Completed						
2846	22090941	Printing Press	NEED LABOURS 6 NOS FOR UNLOADING PAPER BUNDALS FROM GROUND FLOOR TO I FLOOR	Pandiaraj. V.,Yuvaraj. M.,Murali. K.	Paper bundles unloading work completed.		Mahi Mohan Ram.S. - Gas Power Plant	26/09/2022
Comp. Dt. :		14/10/2022						
Status :		Completed						
2847	22100455	Printing Press	NEED LABOURS 4 NOS FOR UNLOADING PAPER BUNDALS FROM GROUND FLOOR TO I FLOOR	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	Paper unloading and shifting work coompleted		Mahi Mohan Ram.S. - Gas Power Plant	14/10/2022
Comp. Dt. :		21/11/2022						
Status :		Completed						
2848	22110872	Printing Press	NEED LABOURS 4 NOS FOR UNLOADING PAPER BUNDALS	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	Paper bundle unloading and shifting work completed		Mahi Mohan Ram.S. - Gas Power Plant	24/11/2022
Comp. Dt. :		22/11/2022						
Status :		Completed						
2849	22110949	Printing Press	NEED LABOURS 4 NOS FOR UNLOADING PAPER BUNDALS	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	Paper bundle unloading and shifting work completed		Mahi Mohan Ram.S. - Gas Power Plant	24/11/2022
Comp. Dt. :		13/12/2022						
Status :		Completed						
2850	22120571	Gas Power Plant	NEED MANPOWER 4 NOS FOR UNLOADING COMPRESSURE	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	Compressor unloading work completed.		Mahi Mohan Ram.S. - Gas Power Plant	21/12/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 31/01/2023 Status : Completed								
2851	23011087	Printing Press	NEED MANPOWER 4 NOS FOR UNLOADING A4 SIZE PAPER BUNDALS FROM GROUND FLOOR TI TO I FLOOR	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	Paper unloading work completed.		Mahi Mohan Ram.S. - Gas Power Plant	01/02/2023
Comp. Dt. : 23/03/2023 Status : Completed								
2852	23030972	Printing Press	NEED MANPOWER 4 NOS FOR PAPER BUNDAL UNLOADING WORK ON 24.03.2023	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	PAPER BUNDLES SHIFTING WORK COMPLETED		Mahi Mohan Ram.S. - Gas Power Plant	25/03/2023
Comp. Dt. : 22/04/2023 Status : Completed								
2853	23040705	PRESS	NEED MANPOWER 2 NOS FOR UNLOADING LIBRARY BOOKS	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	Books unloading work completed		Mahi Mohan Ram.S. - Gas Power Plant	02/05/2023
Comp. Dt. : 25/04/2023 Status : Completed								
2854	23040803	PRESS	NEED MANPOWER 4 NOS FOR UNLOADING A4 SHEET BUNDALS FROM GROUND FLOOR TO I FLOOR ON 26.4.2023	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	A4 sheet bundles unloading and shifting work completed		Mahi Mohan Ram.S. - Gas Power Plant	02/05/2023
Comp. Dt. : 02/05/2023 Status : Completed								
2855	23050006	PRESS	NEED MANPOWER 3 NOS FOR UNLOADING PAPER BUNDAL FROM GROUND FLOOR TO I FLOOR	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	A4 Paper bundle shifting and unloading work completed		Mahi Mohan Ram.S. - Gas Power Plant	02/05/2023
Comp. Dt. : 04/05/2023 Status : Completed								
2856	23050126	Printing Press	NEED MANPOWER 4 NOS FOR UNLOADING PAPER BUNDAL FROM GROUND FLOOR TO I FLOOR	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	Paper bundle shifting work completed		Mahi Mohan Ram.S. - Gas Power Plant	04/05/2023
Comp. Dt. : 22/05/2023 Status : Completed								
2857	23050856	Printing Press	NEED MANPOWER 4 NOS FOR UNLOADING PAPER BUNDALS FROM GROUND FLOOR TO I FLOOR	Pandiaraj. V.,Yuvaraj. M.,Thulasi. V.	A4 paper unloading and shifting work completed		Mahi Mohan Ram.S. - Gas Power Plant	22/05/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 09/06/2023								
Status : Completed								
2858	23060321	Printing Press	NEED MANPOWER 5 NOS FOR PAPER BUNDAL UNLOADING WORK FROM GROUND FLOOR TO I FLOOR	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	PAPER BUNDLE SHIFTED FROM GROUND FLOOR TO 1ST FLOOR		Mahi Mohan Ram.S. - Gas Power Plant	10/06/2023
Comp. Dt. : 12/06/2023								
Status : Completed								
2859	23060426	PRESS	NEED MANPOWER 4 NOS FOR PAPER BUNDAL UNLOADING WORK FROM PRESS TO I FLOOR	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	PAPER BUNDLES UNLOADING WORK COMPLETED		Mahi Mohan Ram.S. - Gas Power Plant	15/06/2023
Comp. Dt. : 21/06/2023								
Status : Completed								
2860	23060793	Printing Press	NEED MANPOWER 5 NOS FOR PAPER BUNDAL UNLOADING WORK FROM GROUND FLOOR TO I FLOOR ON 22.06.2023 10 A.	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	Paper bundles shifting work completed		Mahi Mohan Ram.S. - Gas Power Plant	24/06/2023
Dept Name : Gynac Ward - Civil - Maintenance								
Comp. Dt. : 03/04/2023								
Status : Completed								
2861	23040037	Obstetrics - Ward 207	NEED MANPOWER 4NOS FOR COT ARRANGEMENT WORK	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	COT ARRANGEMENT WORK DONE.		Ashwini. V. - Gynac Ward	03/04/2023
Dept Name : Hospital Infection Control - Civil - Maintenance								
Comp. Dt. : 04/05/2023								
Status : Completed								
2862	23050163	BASEMENT AUDITORIUM	NEED MANPOWER 2 NOS FOR BANNER FIIXING WORK	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	Workshop complaint		Mohana. M. - Hospital Infection Control	04/05/2023
Dept Name : Housekeeping - Civil - Maintenance								
Comp. Dt. : 17/09/2022								
Status : Completed								
2863	22090665	Free Pharmacy	NEED LABOURS 2 NOS FOR SHIFTING PLYWOOD SHEETS FROM , NEAR FREE PHARMACY TO WORKSHOP	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	work completed.	 Dr. KAGNE. R.N DEAN SRI MANAKULA VINAYAGAR MEDICAL COLLEGE & HOSPITAL KALITHEERTHALKUPPAM, PUDUCHERRY-605107.	Elangchezhiyan. R. - Housekeeping	21/09/2022
Comp. Dt. : 23/09/2022								

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
2864	22090945	Biochemistry Lab-Hospital	NEED LABOURS 2 NOS FOR SHIFTING WOODEN PIECES FROM LAB SIDE TO WORKSHOP	Pandiaraj. V.	Work completed.		Elangchezhiyan. R. - Housekeeping	01/10/2022
Comp. Dt. : 14/10/2022								
Status : Completed								
2865	22100450	HOSPITAL III FLOOR	NEED LABOURS 2NOS FOR SHIFTING UNWANTED WOODEN PIECES - FROM III FLOOR[NEAR LIFT] TO WORKSHOP	Pandiaraj. V.	Wooden piece shifting work completed		Elangchezhiyan. R. - Housekeeping	15/10/2022
Comp. Dt. : 24/02/2023								
Status : Completed								
2866	23020943	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	NEED MANPOWER 4 NOS FOR SHIFTING GLASS DOOR FROM - NEAR SPL CLINIC 100 TO WORKSHOP	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	GLASS DOOR SHIFTING WORK COMPLETED.		Balasubramaniyam. G. - Housekeeping	01/03/2023
Comp. Dt. : 24/03/2023								
Status : Completed								
2867	23031024	Biochemistry Lab-Hospital	NEED LABOURS 2NOS FOR REMOVING UNWANTED THINGS FROM BACKSIDE OF BIOCHEMISTRY LAB STEPS	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	UNWANTED MATERIALS SHIFTING WORK COMPLETED		Vengadesan. K. - Housekeeping	25/03/2023
Comp. Dt. : 12/04/2023								
Status : Completed								
2868	23040369	HOSPITAL IV FLOOR	NEED MANPOWER 5 NOS FOR SHIFTING OLD UN WANTED NURSE'S CABIN FROM IV FLOOR TO WORKSHOP	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	Unwanted nurses cabin shifting work completed		Ayyappan. K. - Housekeeping	17/04/2023
Dept Name : ICCU - Civil - Maintenance								
Comp. Dt. : 09/06/2023								
Status : Completed								
2869	23060324	CSSD	NEED MANPOWER 2NOS FOR RACK SHIFTING WORK FROM CSSD TO ICCU	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	RACK 2NOS SHIFTED FROM CSSD TO ICCU		Ammu. R. - ICCU	10/06/2023
Dept Name : ICU - Civil - Maintenance								
Comp. Dt. : 14/06/2022								
Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2870	22060490	ICU	NEED LABOURS 2 NOS FOR BERO SHIFTING WORK	Pandiaraj. V.,Yuvaraj. M.,Murali. K.	Bearo shifting work done.		Latha. K. - ICU	17/06/2022
Comp. Dt. : 20/01/2023 Status : Completed								
2871	23010697	ICU	NEED MAN POWER 4 NOS FOR MOSQUITO NET SHIFTING WORK FROM WORKSHOP TO I FLOOR ICU	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	Mosquito net shifting work completed.		Regina Mary. S. - ICU	21/01/2023
Comp. Dt. : 21/01/2023 Status : Completed								
2872	23010761	ICU	NEED LABOURS 4 NOS FOR MOSQUITO NET SHIFTING WORK FROM ICU TO WORKSHOP	Palanisamy. R.,Yuvaraj. M.,Thulasi. V.	Mosquito net shifting work done fromt ICU to workshop.		Regina Mary. S. - ICU	21/01/2023
Comp. Dt. : 01/02/2023 Status : Completed								
2873	23020009	ICU	NEED MANPOWER 4 NOS FOR SHIFTING MOSQUITO STANDS FROM WORKSHOP TO ICU	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	Stand shifting work completed		Regina Mary. S. - ICU	07/02/2023
Comp. Dt. : 15/02/2023 Status : Completed								
2874	23020595	ICU	NEED LABOURS 4 NOS FOR SHIFTING "NURSE'S STATION" FROM IV FLOOR TO I FLOOR ICU EXTN	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	Nurses cabin shifting work completed		Latha. K. - ICU	17/02/2023
Comp. Dt. : 08/03/2023 Status : Completed								
2875	23030341	ICU	NEED MANPOWER 2 NOS FOR COT SHIFTING WORK FROM ICU TO POW & SICU	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	COT SHIFTED FROM ICU TO POW & SICU		Latha. K. - ICU	17/03/2023
Dept Name : Labour Ward - Civil - Maintenance Comp. Dt. : 02/05/2022 Status : Completed								
2876	22050017	Labour Room	NEED LABOURS 4 NOS FOR COT SHIFTING WORK - FROM LABOUR ROOM TO WORKSHOP	Pandiaraj. V.	All COT shifting work done		Sathiyavathi. S. - Labour Ward	02/05/2022
Dept Name : Male Medical Ward - Civil - Maintenance Comp. Dt. : 22/08/2022								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
2877	22080733	Male Medical - Ward 301	NEED LABOURS 3 NOS FOR SHIFTING REMOVED NURSE'S CABIN TO WORKSHOP FOR REPAIRING WORK	Pandiaraj. V.,Yuvaraj. M.,Murali. K.	Shifitng work completed		Soniya Gandhi. A. - Male Medical Ward	01/09/2022
Comp. Dt. : 28/03/2023								
Status : Completed								
2878	23031192	Male Medical - Ward 303	NEED MANPOWER 2NOS FOR COT SHIFTING WORK FROM WARD NO 307 TO 303	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	Cot shifting work completed		Vijayalakshmi. S. - Male Medical Ward	28/03/2023
Dept Name : Male Ortho Ward - Civil - Maintenance								
Comp. Dt. : 15/02/2023								
Status : Completed								
2879	23020580	Male Ortho - Ward 404	NEED MAN POWER 2 NOS FOR THINGS SHIFTING WORK	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	MATERIALS SHIFTING WORK COMPLETED.		Manjula. P. - Male Ortho Ward	16/02/2023
Comp. Dt. : 01/04/2023								
Status : Completed								
2880	23040015	Male Ortho - Ward 404	NEED LABOUR 1 NO FOR WINDOW CLEANING WORK	Pandiaraj. V.	WORK COMPLETED		Rajasree. R. - Male Ortho Ward	05/04/2023
Comp. Dt. : 03/04/2023								
Status : Completed								
2881	23040072	Male Surgery - Ward 203	NEED MANPOWER 2 NOS FOR COT ARRANGEMENT WORK	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	COT ARRANGEMENT WORK DONE.		Vanitha. P. - Male Ortho Ward	03/04/2023
Comp. Dt. : 08/04/2023								
Status : Completed								
2882	23040249	Male Surgery - Ward 203	NEED MAN POWER 2NOS FOR COT ARRANGEMENT WORK	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	Cot arrangement work completed		Vanitha. P. - Male Ortho Ward	19/04/2023
Comp. Dt. : 03/06/2023								
Status : Completed								
2883	23060083	Male Surgery - Ward 203	NEED MANPOWER 4 NOS FOR COT ARRANGEMENT WORK	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	COT ARRANGEMENT WORK COMPLETED		Vanitha. P. - Male Ortho Ward	03/06/2023
Dept Name : Male Surgery - Civil - Maintenance								
Comp. Dt. : 10/10/2022								
Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2884	22100253	Male Surgery - Ward 203	NEED LABOURS 4 NOS FOR COT ARRANGEMENT WORK [EXAM PURPOSE] NEED URGENT	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	Cot arrangement work done.		Sugumari. M. - Male Surgery	12/10/2022
Dept Name : Medical Records - Civil - Maintenance Comp. Dt. : 20/09/2022 Status : Completed								
2885	22090789	Medical Records	NEED VENTILATION GLASS CLEANING WORK	Pandiaraj. V.	house keeping complaints		Martin Prabu.V. - Medical Records	24/09/2022
Comp. Dt. : 13/01/2023 Status : Completed								
2886	23010558	Paediatrics - Ward 310	NEED LABOURS 2 NOS FOR TABLE SHIFTING WORK	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	Table shifting work completed		Deepa. S. - Medical Records	14/01/2023
Dept Name : MICROBIOLOGY - Civil - Maintenance Comp. Dt. : 18/05/2022 Status : Completed								
2887	22050661	MICROBIOLOGY IN COLLEGE	NEED LABOURS 4 NOS FOR INTERNAL SHIFTING WORK	Pandiaraj. V.,Yuvaraj. M.,Thulasi. V.	Machine shifting work completed		Buvana. C. - MICROBIOLOGY	25/05/2022
Comp. Dt. : 07/10/2022 Status : Completed								
2888	22100150	General Stores[Linen]	NEED LABOURS 4 NOS FOR UNLOADING BOXES FROM GENERAL STORE TO MICROBIOLOGY [HOSPITAL]	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	Boxes unloading work completed.		Karthik. S. - MICROBIOLOGY	08/10/2022
Comp. Dt. : 22/11/2022 Status : Completed								
2889	22110925	MICROBIOLOGY	NEED LABOURS 4NOS FOR STEEL BERO (2NOS) SHIFTING WORK FROM MICROBIOLOGY TO WORKSHOP	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	Steel bearo shifted from microbiology ton workshop.		Karthik. S. - MICROBIOLOGY	25/11/2022
Comp. Dt. : 29/11/2022 Status : Completed								
2890	22111200	MICROBIOLOGY	NEED LABOURS 8 NOS FOR SHIFTING MACHINE BOX FROM HOSPITAL MICROBIOLOGY TO COURIER PLACE AT RECEIPT	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	Machine shifting work completed		Vinothini. V. - MICROBIOLOGY	29/11/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 01/12/2022 Status : Completed								
2891	22120004	MICROBIOLOGY	NEED MAN POWER [3 NOS] FOR FIXING BANNERS NEAR BLOOD BANK	Pandiaraj. V.,Yuvaraj. M.,Thulasi. V.	baner fixing work completed		Anandh. P. - MICROBIOLOGY	05/12/2022
Dept Name : Nursing Office - Civil - Maintenance Comp. Dt. : 31/05/2022 Status : Completed								
2892	22051131	Obstetrics - Ward 208	NEED LABOURS 2 NOS FOR UNWANTED DOOR REMOVING WORK AT WARD NO 208	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	Door shifting work from Ward 208 to workshop, work completed		Padma. A. - Nursing Office	01/06/2022
Comp. Dt. : 08/06/2022 Status : Completed								
2893	22060315	SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	NEED LABOURS 2 NOS FOR UNLOADING UN WANTED THINGS FROM SPL CLINIC I FLOOR TO WORKSHOP SIDE	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	Shifting work done		Tamilarasi.C. - Nursing Office	17/06/2022
Comp. Dt. : 17/06/2022 Status : Completed								
2894	22060665	Nursing Office	NEED LABOURS 4 NOS FOR COT SHIFTING WORK [NEED ON 18.06.2022 @ 8.30 A.M]	Pandiaraj. V.,Yuvaraj. M.,Murali. K.	COT shifting work done		Greeta Guna Seelan - Nursing Office	20/06/2022
Comp. Dt. : 22/06/2022 Status : Completed								
2895	22060809	Nursing Office	NEED LABOURS 2 NOS FOR FRIDGE [2NOS] SHIFTING WORK FROM STORES TO OG OPD & I FLOOR	Pandiaraj. V.,Yuvaraj. M.,Murali. K.	refridgerator shifted to og opd		Greeta Guna Seelan - Nursing Office	24/06/2022
Comp. Dt. : 05/07/2022 Status : Completed								
2896	22070176	Nursing Office	NEED LABOURS 4 NOS FOR INSPECTION ARRANGEMENT WORK ON 06.07.2022 AT 8.30 A.M	Pandiaraj. V.,Yuvaraj. M.,Murali. K.	Cot arrangement work completed		Greeta Guna Seelan - Nursing Office	06/07/2022
Comp. Dt. : 09/07/2022 Status : Completed								
2897	22070377	Nursing Office	NEED MAN POWER 2 NOS AT 11 A.M. [TODAY]	Pandiaraj. V.,Yuvaraj. M.,Thulasi. V.	Man power given		Greeta Guna Seelan - Nursing Office	12/07/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 11/07/2022 Status : Completed								
2898	22070435	IVF ART CLINIC-INSIDE OF OG OPD(NO.68)	NEED LABOURS 3 NOS FOR FRIDGE SHIFTING WORK FROM IVF TO MALE MEDICAL WARD 301 DUE TO EXAMINATION GO	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	fridge shifting work done		Greeta Guna Seelan - Nursing Office	12/07/2022
Comp. Dt. : 19/07/2022 Status : Completed								
2899	22070724	Nursing Office	NEED LABOURS 6 NOS FOR COT ARRANGEMENT - NEED ON 20.07.2022 @ 9 A.M	Pandiaraj. V.,Yuvaraj. M.,Thulasi. V.	Cot arrangement work done		Greeta Guna Seelan - Nursing Office	21/07/2022
Comp. Dt. : 08/08/2022 Status : Completed								
2900	22080269	Obstetrics - Ward 208	NEED LABOURS 2 NOS FOR SHIFTING UNWANTED PLYWOOD DOORS FOR WARD NO 208 TO WORKSHOP	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	shifting work completed.		Devika.R - Nursing Office	11/08/2022
Comp. Dt. : 08/09/2022 Status : Completed								
2901	22090339	SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	NEED LABOURS 2 NOS FOR CLEANING & SHIFTING WORK ON 09.09.2022 @ 9.A.M	Pandiaraj. V.	shifting work completed.		Tamilarasi.C. - Nursing Office	10/09/2022
Comp. Dt. : 17/09/2022 Status : Completed								
2902	22090670	ANS DRESS CHANGING ROOM	NEED LABOURS 4NOS FOR COT SHIFTING WORK FROM ANS ROOM TO POST OPP	Pandiaraj. V.,Yuvaraj. M.,Thulasi. V.	work completed.		Devika.R - Nursing Office	21/09/2022
Comp. Dt. : 07/10/2022 Status : Completed								
2903	22100136	Gynaecology - Ward 209	NEED LABOURS 4 NOS FOR SHIFTING RACK & WARD ARRANGEMENT WORK AT WARD NO 209 & 210	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	Shifting work and ward arrangement work completed.		Powlin.P. - Nursing Office	08/10/2022
Comp. Dt. : 13/10/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2904	22100393	NICU	NEED MANPOWER [2NOS] FOR NEW WARD ARRANGEMENT WORK	Pandiaraj. V.	Arrangement work done.		Powlin.P. - Nursing Office	13/10/2022
Comp. Dt. : 02/02/2023 Status : Completed								
2905	23020068	Casualty	NEED MANPOWER 4 NOS FOR COT SHIFTING WORK FROM CASUALTY TO SPECIAL WARD B	Murali. K.,Kannan. V.,Thulasi. V.	8 Nos of Cot shifting work completed		Tamilarasi.C. - Nursing Office	03/02/2023
Comp. Dt. : 13/02/2023 Status : Completed								
2906	23020465	Male Surgery - Ward 203	NEED MANPOWER 4 NOS FOR COT SHIFTING WORK	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	COT SHIFTING WORK COMPELTED.		Leena Grace. B. - Nursing Office	16/02/2023
Comp. Dt. : 15/02/2023 Status : Completed								
2907	23020606	Female Medical - Ward 305	NEED MANPOWER 2 NOS FOR SHIFTING BROKEN NURSE'S STATION TO WORKSHOP	Thulasi. V.,Prakash. N.,Murali. K.	NURSE'S CABIN SHIFTED TO WORKSHOP		Sudha.L. - Nursing Office	16/02/2023
Comp. Dt. : 17/02/2023 Status : Completed								
2908	23020682	ICU	NEED MANPOWER 4NOS FOR COT SHIFTING WORK	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	Cot shifting work completed		Powlin.P. - Nursing Office	17/02/2023
Comp. Dt. : 20/02/2023 Status : Completed								
2909	23020736	Male Surgery - Ward 203	NEED MANPOWER 5 NOS FOR COT ARRANGEMENT WORK	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	COT ARRANGEMENT WORK DONE.		Rajalakshmi. N. - Nursing Office	21/02/2023
Comp. Dt. : 03/03/2023 Status : Completed								
2910	23030148	Female Ortho - Ward 401	NEED LABOURS 3 NOS FOR SHIFTING WASTE MATERIALS FROM WARD NO 401 TO WORKSHOP	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	WORK SHOP COMPLAINT.		Chandralekha. S. - Nursing Office	04/03/2023
Comp. Dt. : 06/03/2023 Status : Completed								
2911	23030230	ICU	NEED MANPOWER 3 NOS FOR RACK SHIFTING WORK	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	RACK SHIFTING WORK DONE.		Kalaiarasi. D. - Nursing Office	07/03/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 03/04/2023 Status : Completed								
2912	23040066	Paediatrics Ward	NEED MANPOWER 2 NOS FOR COT ARRANGEMENT & SHIFTING WORK TO WORKSHOP WARD NO 307 & 308	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	COT ARRANGEMENT WORK DONE. MUSQUITO STAND SHIFTED TO WORKSHOP		Powlin.P. - Nursing Office	03/04/2023
Comp. Dt. : 13/04/2023 Status : Completed								
2913	23040423	POW & SICU	NEED MANPOWER 2NOS FOR COT SHIFTING WORK FROM POW TO WARD NO 203	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	Cot shifting work completed		Leena Grace. B. - Nursing Office	19/04/2023
Comp. Dt. : 29/05/2023 Status : Completed								
2914	23051106	ENT WARD	NEED MANPOWER 4 NOS FOR EXAM COT ARRANGEMENT WORK WARD NO 407 & 408	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	work completed		Chandralekha. S. - Nursing Office	31/05/2023
Dept Name : Nutrition & Dietetics - Civil - Maintenance Comp. Dt. : 06/06/2022 Status : Completed								
2915	22060176	HOSPITAL CANTEEN IN TERROUS	NEED LABOURS 4NOS FOR UNLOADING WHEET BAGS [50 NOS] FROM TERROUS TO STORE ROOM	Yuvaraj. M.	Wheat bags shifted from terrace to store room.		Shanmugapriya. J. - Nutrition & Dietetics	06/06/2022
Comp. Dt. : 11/06/2022 Status : Completed								
2916	22060405	DIET DEPARMENT	NEED LABOURS 2 NOS FOR SHIFTING RICE BAGS [10NOS] FROM V FLOOR TO STORE ROOM	Pandiaraj. V.,Yuvaraj. M.,Murali. K.	Rice bags shifted to store room.		Shanmugapriya. J. - Nutrition & Dietetics	13/06/2022
Comp. Dt. : 20/06/2022 Status : Completed								
2917	22060693	DIET DEPARMENT	NEED LABOURS 4 NOS FOR UNLOADING RICE BAGS [50KGS] FROM V FLOOR TO STORE ROOM	Pandiaraj. V.	Rice bags shifted.		Shanmugapriya. J. - Nutrition & Dietetics	20/06/2022
Comp. Dt. : 05/07/2022 Status : Completed								

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2918	22070128	OPTICAL SHOP NEAR OPHTHAL OPD	NEED LABOURS 6 NOS FOR SHIFTING GRACERARY BUNDLES [30 NOS] FROM OPTICAL SHOP NEAR OPHTHAL OPD TO	Prakash. N.,Pandiaraj. V.,Yuvaraj. M.	Gorcery bundles and Rice bags shifting work completed		Shanmugapriya. J. - Nutrition & Dietetics	06/07/2022
Comp. Dt. : 19/07/2022 Status : Completed								
2919	22070684	OPTICAL SHOP NEAR OPHTHAL OPD	NEED LABOURS [4 NOS] FOR RICE BAGS UNLOADING WORK NEAR OPHTHAL SHOP TO V FLOOR STORE ROOM	Pandiaraj. V.,Yuvaraj. M.,Murali. K.	Rice bags shifted.		Shanmugapriya. J. - Nutrition & Dietetics	19/07/2022
Comp. Dt. : 25/07/2022 Status : Completed								
2920	22070881	OPTICAL SHOP NEAR OPHTHAL OPD	NEED LABOURS 4 NOS FOR SHIFTING RICE BAGS , FROM NEAR OPTICAL SHOP TO VI FLOOR DIET STORE ROOM	Pandiaraj. V.,Yuvaraj. M.,Murali. K.	Rice bag shifting work done		Shanmugapriya. J. - Nutrition & Dietetics	26/07/2022
Comp. Dt. : 03/08/2022 Status : Completed								
2921	22080131	DIET DEPARMENT	NEED LABOURS 3 NOS FOR SHIFTING WORK FROM V FLOOR TO VI FLOOR	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	shifting work completed		Shanmugapriya. J. - Nutrition & Dietetics	11/08/2022
Comp. Dt. : 17/06/2023 Status : Completed								
2922	23060616	DIET DEPARMENT	DUE TO FAILURE OF LIFT , NEED MANPOWER 8 NOS FOR FOOD DISTRIBUTION	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	WORK COMPLETED.		Shanmugapriya. J. - Nutrition & Dietetics	17/06/2023
Dept Name : OPD - Civil - Maintenance Comp. Dt. : 15/06/2022 Status : Completed								
2923	22060556	Paediatrics - OPD	NEED LABOURS 2 NO FOR TABLE ARRANGEMENT WORK	Senthil Kumar. R.	Table arrangement done		Subashree. R. - OPD	17/06/2022
Comp. Dt. : 23/06/2022 Status : Completed								
2924	22060843	Work Shop	NEED LABOURS 4 NOS FOR TABLE SHIFTING WORK FROM WORKSHOP TO NEPHROLOGY OPD	Pandiaraj. V.,Yuvaraj. M.,Murali. K.	Table shifted.		Jenifer. K. - OPD	24/06/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 01/07/2022								
Status : Completed								
2925	22070023	MINOR OT NEAR ENDOSCOPY	NEED LABOURS 2 NOS FOR SHIFTING WORK [PACKED BOX [2 NOS]]	Pandiaraj. V.,Yuvaraj. M.,Murali. K.	Shifting work completed		Sarala. P. - OPD	04/07/2022
Comp. Dt. : 22/07/2022								
Status : Completed								
2926	22070847	Work Shop	NEED LABOURS 2 NOS FOR SHIFTING STEEL STAND FROM WORKSHOP TO II FLOOR DENTAL OPD	Prakash. N.,Thulasi. V.,Pandiaraj. V.	Shifting work done		Lakshmi Devi. R. - OPD	26/07/2022
Comp. Dt. : 27/07/2022								
Status : Completed								
2927	22070996	DENTAL OPD -2ND FLOOR	NEED LABOURS 4 NOS FOR DENTAL CHAIR FIXING WORK	Pandiaraj. V.,Yuvaraj. M.,Prakash. N.	Chair fixing work done		Lakshmi Devi. R. - OPD	01/08/2022
Comp. Dt. : 02/08/2022								
Status : Completed								
2928	22080059	Orthopaedics - OPD	NEED LABOURS 2 NOS FOR BANNER FIXING WORK AT DEMO ROOM	Pandiaraj. V.,Yuvaraj. M.,Thulasi. V.	Banner fixing work completed.		Durgadevi. J - OPD	03/08/2022
Comp. Dt. : 04/08/2022								
Status : Completed								
2929	22080148	Orthopaedics - OPD	NEED LABOURS 2 NOS FOR BANNER FIXING WORK	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	Banner fixing completed.		Durgadevi. J - OPD	09/08/2022
Comp. Dt. : 18/10/2022								
Status : Completed								
2930	22100562	CT-POST OPERATIVE WARD IN 4TH FLOOR	NEED MANPOWER 2 NOS FOR SCREEN REMOVING WORK	Prakash. N.	Screen removing work completed		Jenifer. K. - OPD	21/10/2022
Comp. Dt. : 03/02/2023								
Status : Completed								
2931	23020107	IVF ART CLINIC-INSIDE OF OG OPD(NO.68)	NEED MANPOWER 1 NO FOR SHIFTING CYLINDER	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	Cylinder shifting work completed		Rajasekari. R. - OPD	07/02/2023
Comp. Dt. : 13/02/2023								
Status : Completed								
2932	23020485	Paediatrics - OPD	NEED MANPOWER 2NOS FOR SHIFTING WORK	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	MATERIALS SHIFTING WORK COMPLETED.		Subashree. R. - OPD	16/02/2023

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 01/03/2023 Status : Completed								
2933	23030005	Work Shop	NEED MANPOWER 4NOS FOR TABLE SHIFTING WORK FROM WORKSHOP TO ORTHO OPD	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	TABLE SHIFTED FROM WORKSHOP TO ORTHO OPD		Durgadevi. J - OPD	03/03/2023
Comp. Dt. : 06/03/2023 Status : Completed								
2934	23030194	Paediatrics - OPD	NEED MANPOWER 3 NOS FOR CHAIR ARRANGEMENT WORK AT OPP TO PADEIATRICS OPD	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	CHAIR ARRANGEMENT WORK DONE.		Velangkanni. K. - OPD	07/03/2023
2935	23030226	OG-OPD	NEED MANPOWER 3 NOS FOR CHAIR ARRANGEMENT WORK AT DEMO ROOM	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	CHAIR ARRANGEMENT WORK DONE AT DEMO ROOM		Velangkanni. K. - OPD	17/03/2023
Comp. Dt. : 07/03/2023 Status : Completed								
2936	23030279	Work Shop	NEED MANPOWER 4 NOS FOR BERO SHIFTING WORK FROM WORKSHOP TO TB CHEST OPD	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	BERO SHIFTING WORK COMPLETED		Jothi.R. - OPD	10/03/2023
2937	23030286	OG-OPD	NEED MANPOWER 2 NOS FOR BANNER FIXING WORK AT MAIN GATE	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	BANNER FIXING WORK DONE.		Velangkanni. K. - OPD	08/03/2023
Comp. Dt. : 10/03/2023 Status : Completed								
2938	23030385	Paediatrics - OPD	NEED MANPOWER 4 NOS FOR BERO SHIFTING WORK FROM PAEDIATRIC OPD TO OG OPD	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	BERO SHIFTED FROM PAEDIATRIC OPD TO OG OPD		Velangkanni. K. - OPD	17/03/2023
Comp. Dt. : 15/03/2023 Status : Completed								
2939	23030594	Paediatrics - OPD	NEED MANPOWER 3 NOS FOR BERO SHIFTING WORK FROM PAEDIATRICS OPD TO OG OPD	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	BERO SHIFTING WORK COMPLETED.		Subashree. R. - OPD	17/03/2023
Comp. Dt. : 22/03/2023 Status : Completed								
2940	23030915	Paediatrics - OPD	NEED MANPOWER 1 NO FOR SHIFTING THINGS FROM OPD TO WORKSHOP	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	SHIFTING WORK COMPLETED		Subashree. R. - OPD	25/03/2023
Comp. Dt. : 25/03/2023 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2941	23031086	Special Clinic	NEED LABOURS 2 NOS FOR TABLE SHIFTING WORK FROM SPECIAL OPD II FLOOR TO SURGERY OPD	Senthil Kumar. R.,Thulasi. V.,Murali. K.	TABLE SHIFTING WORK COMPLETED		Indhira. M. - OPD	31/03/2023
Comp. Dt. : 05/04/2023 Status : Completed								
2942	23040154	Orthopaedics - OPD	NEED MANPOWER 2 NOS FOR UNLOADING BUNDALS [UNWANTED FILES & RECORD] FROM ORTHO OPD TO V FLOOR	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	work completed		Durgadevi. J - OPD	05/04/2023
2943	23040164	Ophthalmology - OPD	NEED LABOURS 2 NOS FOR SHIFTING WORK [OLD RECORDS] FROM SPECIAL WARD "A" TO SPECIAL WARD "B"	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	OLD RECORDS SHIFTED FROM SPECIAL WARD A TO SPECIAL WARD B		Seetha. R. - OPD	08/04/2023
Comp. Dt. : 26/05/2023 Status : Completed								
2944	23051068	Paediatrics - OPD	NEED MANPOWER 2 NOS FOR BERO SHIFTING WORK TO WORKSHOP	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	work completed		Subashree. R. - OPD	31/05/2023
Comp. Dt. : 23/06/2023 Status : Completed								
2945	23060844	Dressing	NEED MANPOWER 4 NOS FOR BERO SHIFTING WORK FROM WORKSHOP TO DRESSING OPD - ROOM NO 53	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	Bero shifted from workshop to dressing opd		Badmasri. P. - OPD	28/06/2023
Dept Name : Ophthalmology - Civil - Maintenance Comp. Dt. : 24/08/2022 Status : Completed								
2946	22080819	Ophthalmology - OPD	NEED LABOURS 2 NOS FOR BANNER FIXING WORK ON 25.08.2022 @ 8.30 A.M.	Pandiaraj. V.	banner fixing work done		Rajeswari.V. - Ophthalmology	26/08/2022
Comp. Dt. : 13/09/2022 Status : Completed								
2947	22090470	Ophthalmology - OPD	NEED LABOURS 2 NOS FOR TABLE SHIFTING WORK FROM OPHTHAL OPD TO II FLOOR EYE BANK	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	work completed.		Rajeswari.V. - Ophthalmology	15/09/2022
Comp. Dt. : 14/10/2022								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
2948	22100436	Main Gate	NEED LABOURS 2 NOS FOR REMOVING BANNER AT MAIN GATE	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	Banner removed at main gate.		Rajeswari.V. - Ophthalmology	15/10/2022
Comp. Dt. : 22/03/2023								
Status : Completed								
2949	23030904	Ophthalmology	NEED MANPOWER 3 NOS FOR BANNER FIXING WORK AT MAINGATE & BASEMENT AUDITORIUM	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	BANNER SHIFTING WORK COMPLETED		Rajeswari.V. - Ophthalmology	25/03/2023
Dept Name : PAEDIATRICS - Civil - Maintenance								
Comp. Dt. : 07/07/2022								
Status : Completed								
2950	22070273	ENT OPD	NEED LABOURS 4 NOS FOR RACK SHIFTING WORK [FOR PAINTING WORK] FROM ENT OPD TO WORKSHOP	Prakash. N.,Senthil Kumar. R.,Pandiaraj. V.	Rack shifting work done		Manju @ Brinda. V. - PAEDIATRICS	11/07/2022
Dept Name : Paediatrics Ward - Civil - Maintenance								
Comp. Dt. : 02/12/2022								
Status : Completed								
2951	22120098	Paediatrics - Ward 308	NEED LABOURS 2 NOS FOR SCREEN REMOVING WORK	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	Screen removing work completed		Chitra. P. - Paediatrics Ward	05/12/2022
Comp. Dt. : 20/01/2023								
Status : Completed								
2952	23010732	Paediatrics - Ward 309	NEED 6NOS LABOUR FOR COT SHIFTING WORK	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	COT shifting work completed		Chitra. P. - Paediatrics Ward	21/01/2023
Comp. Dt. : 29/05/2023								
Status : Completed								
2953	23051112	Paediatrics Ward	NEED MANPOWER 4NOS FOR EXAM COT ARRANGEMENT & FIXING SCREEN CLOTH WARD NO 308 & 309	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	work completed		Chitra. P. - Paediatrics Ward	31/05/2023
Comp. Dt. : 03/06/2023								
Status : Completed								
2954	23060084	Female Medical - Ward 307	NEED MANPOWER 4NOS FOR COT ARRANGEMENT WORK [PAEDIATRICS 307]	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	COT ARRANGEMENT WORK COMPLETED		Chitra. P. - Paediatrics Ward	03/06/2023

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Dept Name : PHARMACOLOGY - Civil - Maintenance Comp. Dt. : 16/09/2022 Status : Completed								
2955	22090644	PHARMACOLOGY	DUE TO INSPECTION PURPOSE - NEED LABOUR 2 NO FOR AUTOCLAVE MACHINE SHIFTING WORK FROM PHARMACOLOGY	Palanisamy. R.,Yuvaraj. M.,Senthil Kumar. R.	work completed.		Panchali. P. - PHARMACOLOGY	22/09/2022
Dept Name : Physiotherapy - Civil - Maintenance Comp. Dt. : 08/08/2022 Status : Completed								
2956	22080285	Physiotherapy	NEED LABOURS 3 NOS FOR WINDOW GLASS CLEANNING WORK - NEED URGENT	Pandiaraj. V.,Yuvaraj. M.,Thulasi. V.	Window cleaning work		Ezhilan.K. - Physiotherapy	09/08/2022
Dept Name : PICU & NICU - Civil - Maintenance Comp. Dt. : 04/05/2023 Status : Completed								
2957	23050159	NICU	NEED MANPOWER 2NO FOR FRIDGE SHIFTING WORK	Pandiaraj. V.,Yuvaraj. M.,Thulasi. V.	Fridge shifting work completed		Parameswari. P. - PICU & NICU	04/05/2023
Comp. Dt. : 20/05/2023 Status : Completed								
2958	23050838	NICU	NEED MANPOWER 2 NOS FOR BERO SHIFTING WORK FROM NICU TO WORKSHOP FOR PAINTING WORK	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	work completed		Sasina. K. - PICU & NICU	31/05/2023
Comp. Dt. : 31/05/2023 Status : Completed								
2959	23051219	Work Shop	NEED MANPOWER 4 NOS FOR BERO [2NOS] SHIFTING WORK FROM WORKSHOP TO NICU	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	BERO (2NOS) SHIFTED FROM WORKSHOP TO NICU		Sameetha. S. - PICU & NICU	31/05/2023
2960	23051222	PICU	NEED MANPOWER 2 NOS FOR BERO [2NOS] SHIFTING WORK FROM PICU TO WORKSHOP	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	BERO (2NOS) SHIFTED FROM PICU TO WORKSHOP		Vinodhini. V. - PICU & NICU	31/05/2023
Comp. Dt. : 07/06/2023 Status : Completed								
2961	23060221	Work Shop	NEED MANPOWER 2 NOS FOR BERO SHIFTING WORK FROM WORKSHOP TO PICU	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	Bero shifting work completed		Prpriya. A. - PICU & NICU	09/06/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Dept Name : POW & SICU - Civil - Maintenance Comp. Dt. : 13/02/2023 Status : Completed								
2962	23020452	POW & SICU	NEED MANPOWER 4 NOS FOR COT ARRANGEMENT	Pandiaraj. V., Yuvaraj. M., Senthil Kumar. R.	COT ARRANGEMENT WORK COMPLETED.		Jamuna. K - POW & SICU	16/02/2023
Comp. Dt. : 21/02/2023 Status : Completed								
2963	23020815	POW & SICU	NEED MANPOWER 5 NOS FOR COT CLEANING WORK	Pandiaraj. V., Yuvaraj. M., Senthil Kumar. R.	SCREEN FIXING WORK COMPLETED.		Pragadeesh. V. - POW & SICU	22/02/2023
Dept Name : Quality Department - Civil - Maintenance Comp. Dt. : 15/06/2022 Status : Completed								
2964	22060591	NAC OFFICE 4TH FLOOR	NEED LABOURS 3 NOS FOR TABLE AND ROOM ARRANGEMENT WORK [DEAN SIR OFFICE]	Pandiaraj. V., Yuvaraj. M., Thulasi. V.	Table arrangement work done.		Suganthi. M. - Quality Department	17/06/2022
Dept Name : Radio Diagnosis - Civil - Maintenance Comp. Dt. : 22/06/2022 Status : Completed								
2965	22060791	RADIOLOGY	NEED LABOURS 4 NOS FOR SHIFTING WORK FROM BASEMENT TO IV FLOOR	Pandiaraj. V., Yuvaraj. M., Murali. K.	shifting work completed		Manikandan.V. - Radio Diagnosis	24/06/2022
Comp. Dt. : 11/10/2022 Status : Completed								
2966	22100271	XRay	NEED LABOURS 2 NOS FOR OLD RECORDS SHIFTING WORK FROM BASEMENT TO V FLOOR	Pandiaraj. V., Yuvaraj. M., Senthil Kumar. R.	Old Records shifting work completed		Manikandan.V. - Radio Diagnosis	14/10/2022
Comp. Dt. : 14/01/2023 Status : Completed								
2967	23010584	Work Shop	NEED LABOURS 2 NOS FOR TABLE SHIFTING WORK FROM WORKSHOP TO RADIOLOGY	Pandiaraj. V., Yuvaraj. M., Senthil Kumar. R.	Table shifting work completed		Manikandan.V. - Radio Diagnosis	14/01/2023
Comp. Dt. : 27/02/2023 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2968	23021007	Work Shop	NEED LABOURS 2 NOS FOR SHIFTING RACK FROM WORKSHOP TO X RAY	Pandiaraj. V., Yuvaraj. M., Senthil Kumar. R.	RACK SHIFTING WORK DONE FROM WORKSHOP TO XRAY		Manikandan.V. - Radio Diagnosis	01/03/2023
Comp. Dt. : 17/03/2023 Status : Completed								
2969	23030707	Work Shop	NEED MANPOWER 2 NOS FOR TABLE SHIFTING WORK FROM WORKSHOP TO X RAY	Pandiaraj. V., Yuvaraj. M., Senthil Kumar. R.	TABLE SHIFTING WORK DONE.		Manikandan.V. - Radio Diagnosis	20/03/2023
Dept Name : Special Clinic - Office - Civil - Maintenance Comp. Dt. : 14/01/2023 Status : Completed								
2970	23010594	Printing Press	NEED LABOURS 2 NO'S FOR SHIFTING PRINTED BOOKS (100 NO'S) FROM PRESS TO SPECIAL CLINIC 100 / I FLOO	Pandiaraj. V., Yuvaraj. M., Senthil Kumar. R.	Printed books shifted from press to special cilnic office.		Rani. B. - Special Clinic - Office	21/01/2023
Dept Name : Special Ward - Civil - Maintenance Comp. Dt. : 05/05/2022 Status : Completed								
2971	22050123	Special Ward - A	NEED LABOUR 1 NO FOR SCREEN REMOVING WORK	Murali. K.	SCREEN REMOVING		Bharathi. R. - Special Ward	05/05/2022
2972	22050161	Special Ward - A	NEED LABOUR 1 NO FOR SCREEN FIXING WORK	Prakash. N., Pandiaraj. V., Murali. K.	Screen fixing work		Bharathi. R. - Special Ward	05/05/2022
Comp. Dt. : 07/05/2022 Status : Completed								
2973	22050225	SPECIAL WARD---B	NEED LABOUR 2NOS FOR SCREEN REMOVING WORK	Pandiaraj. V.	2 nos. Screen removed.		Reena. N. - Special Ward	10/05/2022
Comp. Dt. : 06/07/2022 Status : Completed								
2974	22070224	Special Ward - A	NEED LABOURS 2 NOS FOR SCREEN FIXING WORK	Pandiaraj. V., Yuvaraj. M., Murali. K.	Screen fixed.		Bharathi. R. - Special Ward	07/07/2022
Comp. Dt. : 22/09/2022 Status : Completed								
2975	22090893	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	NEED LABOURS 2NOS FOR SHIFTING XEROX MACHINE FROM SPECIAL WARD 100 TO SPECIAL WARD C	Pandiaraj. V., Yuvaraj. M., Senthil Kumar. R.	Xerox machine shifting work completed		Elakkiya. S. - Special Ward	23/09/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 15/03/2023 Status : Completed								
2976	23030598	SPECIAL WARD---B	NEED MAN POWER 2 NOS FOR SHIFTING WORK	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	SHIFTING WORK DONE.		Sangeetha. S. - Special Ward	20/03/2023
Comp. Dt. : 17/03/2023 Status : Completed								
2977	23030709	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	NEED MANPOWER 2 NOS FOR SHIFTING WORK	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	SHIFTING WORK COMPLETED		Dhatchayani.N. - Special Ward	17/03/2023
Comp. Dt. : 17/04/2023 Status : Completed								
2978	23040514	Special Ward - A	NEED MANPOWER 2NOS FOR UNLOADING UNWANTED [FALSE CEILING] ITEMS FROM SPECIAL WARD "A" TO WORKSHOP	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	False ceiling shifting work completed		Revathi. S. - Special Ward	20/04/2023
Comp. Dt. : 02/05/2023 Status : Completed								
2979	23050023	Paediatrics - Ward 310	NEED LABOURS 2 NOS FOR SCREEN CLOTH FIXING WORK - FEMALE MEDICAL WARD 310	Palanisamy. R.,Yuvaraj. M.,Thulasi. V.	Screen fixing work completed		Hemachandra. P. - Special Ward	03/05/2023
Comp. Dt. : 12/06/2023 Status : Completed								
2980	23060385	Special Ward - C	NEED MANPOWER 2 NOS FOR SCREEN FIXING WORK	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	SCREEN FIXING WORK COMPLETED		Vinidha. R. - Special Ward	17/06/2023
Dept Name : Tailoring Department - Civil - Maintenance Comp. Dt. : 11/07/2022 Status : Completed								
2981	22070410	Tailoring Department	NEED LABOURS 4 NOS FOR COT SHIFTING WORK FROM TAILORING DEPARTMENT TO WORKSHOP	Prakash. N.,Pandiaraj. V.,Yuvaraj. M.	Cot shifting work done		Ilayaraja.S. - Tailoring Department	11/07/2022
Comp. Dt. : 18/10/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2982	22100558	LAUNDRY	NEED MAN POWER 4 NOS FOR SHIFTING TAILORING MATERIAL FROM - NEAR LAUNDRY TO TAILORING DEPT	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	Tailoring materials shifting work completed		Ilayaraja.S. - Tailoring Department	20/10/2022
Comp. Dt. : 24/03/2023 Status : Completed								
2983	23030987	LAUNDRY	NEED MANPOWER 3 NOS FOR UNLOADING WORK [TAILORING BUNDLE] FROM LAUNDRY TO TAILORING DEPT.	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	TAILORING BUNDLE SHIFTING WORK COMPLETED		Ilayaraja.S. - Tailoring Department	25/03/2023
Dept Name : TB & CHEST - Civil - Maintenance Comp. Dt. : 14/10/2022 Status : Completed								
2984	22100466	TB & Chest OPD	NEED LABOUR 2NO FOR BANNER FIXING WORK	Thulasi. V.	Banner fixing work completed		Vigneshwaran. S. - TB & CHEST	14/10/2022
Dept Name : Tele Exchange - Civil - Maintenance Comp. Dt. : 28/06/2023 Status : Completed								
2985	23061076	TELEPHONE DEPARTMENT IN EDP(UNDERGROUND)	NEED MANPOWER 2 NOS FOR CUPBOARD SHIFTING WORK FROM WORKSHOP TO TELEPHONE DEPARTMENT IN EDP(UNDERGRO	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	CUPBOARD SHIFTED FROM WORKSHOP TO TELEPHONE DEPARTMENT		Padmanaban. G. - Tele Exchange	04/07/2023
Dept Name : Transport - Civil - Maintenance Comp. Dt. : 21/02/2023 Status : Completed								
2986	23020829	COMMERCIAL BLOCK	NEED MANPOWER 3 NOS FOR GODOWN CLEANNING WORK NEED ON 22.02.2023 9.A.M	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	GODOWN CLEANING WORK COMPLETED.		Sasikumar. P. - Transport	25/02/2023
Dept Name : Work Shop - Civil - Maintenance Comp. Dt. : 02/05/2022 Status : Completed								
2987	22050043	Work Shop	NEED LABOURS 4 NOS FOR PLY WOOD SHEET SHIFTING WORK FROM WORKSHOP TO VC SIR COMPANY	Pandiaraj. V.,Yuvaraj. M.,Thulasi. V.	Plywood sheet were shifted to VC sir company		Ganesan. A. - Work Shop	02/05/2022
Comp. Dt. : 03/06/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2988	22060139	HOSPITAL IV FLOOR	NEED LABOURS 4 NOS FOR UNLOAD PLYWOOD SHEETS FROM IV FLOOR TO WORKSHOP	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	Plywood sheets unloaded to workshop by workshop labours.		Ganesan. A. - Work Shop	06/06/2022
Comp. Dt. : 14/06/2022 Status : Completed								
2989	22060530	Work Shop	NEED LABOURS 5 NOS ON 15.06.2022 @ 8 AM FOR V.C SIR COMPANY WORK - AS PER INSTRUCTIONS GIVEN B	Pandiaraj. V.,Yuvaraj. M.,Murali. K.	5 labours sent to vc sir company inspection work.		Ganesan. A. - Work Shop	17/06/2022
Comp. Dt. : 17/06/2022 Status : Completed								
2990	22060639	HOSPITAL IV FLOOR	NEED LABOURS 4 NOS FOR SHIFTING PLYWOOD SHEETS FROM IV FLOOR TO WORKSHOP	Pandiaraj. V.,Yuvaraj. M.,Murali. K.	Plywoods shifted from 4th floor to workshop		Ganesan. A. - Work Shop	21/06/2022
Comp. Dt. : 28/06/2022 Status : Completed								
2991	22061031	Work Shop	NEED LABOURS 2 NOS FOR SHIFTING BANNER FRAMES FROM WORKSHOP TO BASEMENT STORE	Pandiaraj. V.,Yuvaraj. M.,Murali. K.	Baner frames Shifting work completed		Ganesan. A. - Work Shop	01/07/2022
Comp. Dt. : 16/07/2022 Status : Completed								
2992	22070631	Work Shop	NEED LABOURS 3 NOS FOR PLYWOOD SHEETS SHIFTING WORK FROM WORKSHOP TO III FLOOR	Prakash. N.,Pandiaraj. V.,Yuvaraj. M.	Plywood sheets shifting work done		Ganesan. A. - Work Shop	18/07/2022
Comp. Dt. : 01/08/2022 Status : Completed								
2993	22080045	Work Shop	NEED LABOURS 4 NOS FOR CUPBOARD SHIFTING WORK FROM WORKSHOP TO MS OFFICE	Pandiaraj. V.,Yuvaraj. M.,Thulasi. V.	Shifting work done		Ganesan. A. - Work Shop	03/08/2022
Comp. Dt. : 18/01/2023 Status : Completed								
2994	23010630	PHARMACOLOGY	NEED LABOURS 4 NOS FOR ALUMINIUM PARTITION DOOR SHIFTING WORK FROM PHARMACOLOGY TO PHYSIOLOGY [	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	Aluminium partition door shifting work completed.		Ganesan. A. - Work Shop	21/01/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 11/02/2023								
Status : Completed								
2995	23020422	Hospital	NEED MANPOWER 4 NOS FOR SHIFTING PLYWOOD SHEETS FROM PHYSIOTHERAPY ROOM IN 4TH FLOOR & GROUND FLOOR	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	PLYWOOD SHEETS SHIFTED FROM 4TH FLOOR PHYSIOTHERAPY TO GROUND FLOOR		Ganesan. A. - Work Shop	16/02/2023
Comp. Dt. : 01/03/2023								
Status : Completed								
2996	23030004	Work Shop	NEED MANPOWER 2 NOS FOR CUPBOARD SHIFTING WORK FROM WORKSHOP TO SPL. CLINIC OFFICE I FLOOR	Pandiaraj. V.,Yuvaraj. M.,Thulasi. V.	CUPBOARD SHIFTING WORK DONE.		Ganesan. A. - Work Shop	03/03/2023
Comp. Dt. : 03/03/2023								
Status : Completed								
2997	23030153	Work Shop	NEED MANPOWER 4 NOS FOR SHIFTING WORK FROM WORKSHOP TO SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	MATERIALS SHIFTING WORK COMPLETED.		Ganesan. A. - Work Shop	04/03/2023
Comp. Dt. : 16/03/2023								
Status : Completed								
2998	23030670	Work Shop	NEED MANPOWER 4 NOS FOR SHIFTING WORK FROM WORKSHOP TO MICROBIOLOGY	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	MATERIALS SHIFTED FROM WORKSHOP TO MICROBIOLOGY		Ganesan. A. - Work Shop	17/03/2023
Comp. Dt. : 28/03/2023								
Status : Completed								
2999	23031175	HOSPITAL IV FLOOR	NEED MANPOWER 4 NOS FOR SHIFTING WASTE WOODEN PIECES FROM IV FLOOR TO WORKSHOP	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	WORK COMPLETED		Ganesan. A. - Work Shop	03/04/2023
Comp. Dt. : 10/06/2023								
Status : Completed								
3000	23060359	Work Shop	NEED MANPOWER 4 NOS FOR CUPBOARD SHIFTING WORK FROM WORKSHOP TO NEW NICU	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	CUPBOARD SHIFTED FROM WORKSHOP TO NICU		Ganesan. A. - Work Shop	15/06/2023

College Name : SMVNC
Work Type : Complaint


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Dept Name : Civil - Maintenance - Civil - Maintenance Comp. Dt. : 12/05/2022 Status : Completed								
3001	22050437*	Nursing College	HONEYBEE HIVE TO BE DESTROYED	Sivaraja. M.	Honeycomb destroyed, problem solved		RAJARAJESHWARI - SMVNC	10/06/2022
Comp. Dt. : 31/05/2022 Status : Completed								
3002	22051146	Nursing College	TAP BROKENED - WATER FLOW AT I FLOOR FEMALE REST ROOM - NEED URGENT SERVICE	Udhaya Kumar. R.	New PVC tap changed, problem solved		DHANDAPANI - SMVNC	01/06/2022
Comp. Dt. : 07/06/2022 Status : Completed								
3003	22060251	Nursing College	NEED TO CHANGE NEW COOLER TAP - WATER LEAKAGE & OVERFLOW AT III FLOOR	Udhaya Kumar. R.	Cooler tap rework and refixed in properly, problem solved		RAJARAJESWARI - SMVNC	08/06/2022
Comp. Dt. : 15/06/2022 Status : Completed								
3004	22060544	Nursing College	PIPE LINE BROKENED - WATER OVERFLOW - NEED TO CHANGE TAP 3/4" AND PIPE LINE AT OPP TO NURSING COLLEG	Anandharaj. M.	3/4" PVC pipe line fully rework, Tap changed, work completed		KIRUBA - SMVNC	17/06/2022
Comp. Dt. : 20/06/2022 Status : Completed								
3005	22060695	Nursing College	NEED TO CHECK MOTOR - NOT WORKING - WATER NOT COMING	Azhagar. N.,Anandharaj. M.,Sellaveeran. M.	Motor serviced. Water is coming.		RAJARAJESWARI - SMVNC	20/06/2022
Comp. Dt. : 27/06/2022 Status : Completed								
3006	22060976	Nursing College	NEED TO CHANGE MALE REST ROOM TAP AT I FLOOR - TAP BROKENED - WATER FLOW NEED URGENT SERVICE	Anandharaj. M.,Azhagar. N.,Santhosh Kumar. M.	PVC Tap changed, problem solved		JAYASEELAN - SMVNC	30/06/2022
Comp. Dt. : 30/06/2022 Status : Completed								
3007	22061098	Nursing College	NEED TO CHECK GROUND FLOOR COOLER - WATER OVER FLOW & BLOCK	Azhagar. N.,Anandharaj. M.,Sellaveeran. M.	Water cooler cold water line rework, work completed		DHANDAPANI - SMVNC	30/06/2022
Comp. Dt. : 09/07/2022								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
3008	22070370	Nursing College	BLOCK IN GROUND FLOOR REST ROOM	Thanuzkodi. E	Block removed.		DHANDAPANI - SMVNC	11/07/2022
Comp. Dt. : 11/07/2022								
Status : Completed								
3009	22070430	Nursing College	COOLER OVER FLOW - NEED TO CHECK TAP & BALL - AT GROUND FLOOR	Sellaveeran. M.	Water cooler float valve rework and refixed in properly, problem solved		DHANDAPANI - SMVNC	13/07/2022
Comp. Dt. : 13/07/2022								
Status : Completed								
3010	22070515	Nursing College	WATER NOT COMING IN RESTROOM	Udhaya Kumar. R.	3/4" UPVA pipe line fully rework, problem solved		RAJARAJESWARI - SMVNC	15/07/2022
Comp. Dt. : 13/08/2022								
Status : Completed								
3011	22080483	Nursing College	BLOCK IN II FLOOR RESTROOM	Thanuzkodi. E	Toilet block removed, work completed		DHANDAPANI - SMVNC	17/08/2022
Comp. Dt. : 25/08/2022								
Status : Completed								
3012	22080838	Nursing College	BLOCK IN GROUND FLOOR REST ROOM	Govindan. R.	Block removed.		DHANDAPANI - SMVNC	26/08/2022
Comp. Dt. : 27/08/2022								
Status : Completed								
3013	22080932	Nursing College	WATER NOT COMING IN NUTRITION LAB	Gopal. S.	Ground floor Pipe line work going so valve closed, after finishing the work valve closed, problem so		DHANDAPANI - SMVNC	30/08/2022
Comp. Dt. : 19/09/2022								
Status : Completed								
3014	22090708	Nursing College	NEED TO CHECK R O WATER PIPELINE - DAMAGED - WATER NOT COMING - NEED URGENT SERVICE	Anandharaj. M., Azhagar. N., Sellaveeran. M.	RO water pipeline rework done		RAJARAJESWARI 8838729121 - SMVNC	22/09/2022
Comp. Dt. : 11/10/2022								
Status : Completed								
3015	22100302	Nursing College	NEED TO CHANGE FLUSH TANK - DAMAGE & BROKEN AT I FLOOR RESTROOM	Azhagar. N.	Flush tank fullset changed, work completed		DHANDAPANI - SMVNC	12/10/2022
Comp. Dt. : 28/10/2022								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt	
Status : Completed									
3016	22100883	Nursing College	AURO WATER NOT COMING	Prakash. V.,Manikandan. S.,Sankar. V.	B.Ed pipe line broken, rework the pipe line, coupling changed, work completed		TAMILPULAVENDRAN - SMVNC	28/10/2022	
Comp. Dt. : 31/10/2022									
Status : Completed									
3017	22101001	Nursing College	REST ROOM WATER BLOCK(2400)	Sakthivel. E.	Block removed.		JAYASEELAN - SMVNC	02/11/2022	
Comp. Dt. : 14/11/2022									
Status : Completed									
3018	22110533	Nursing College	IN 1ST FLOOR-GENTS TOILET-WATER LINE BROKEN	Anandharaj. M.	Waste coupling 1No changed, problem solved		DHANDAPANI - SMVNC	16/11/2022	
Comp. Dt. : 15/11/2022									
Status : Completed									
3019	22110614	Nursing College	BACKSIDE BOREWELL TAP LINE BROKEN AND WATER LEAKAGING PROBLEM	Anandharaj. M.	Borewell area fully cleaned, pipe line refixed in properly, problem solved		DHANDAPANI - SMVNC	16/11/2022	
Comp. Dt. : 13/12/2022									
Status : Completed									
3020	22120603	Nursing College	FLUSH BROKED AT GROUND FLOOR STAFF REST ROOM	Azhagar. N.	Flush tank rework done.		DHANDAPANI - SMVNC	16/12/2022	
Comp. Dt. : 22/12/2022									
Status : Completed									
3021	22121028	Nursing College	3RD FLOOR REST ROOM WATER BLOCK	Murugan. S.	Block removed.		DHANDAPANI - SMVNC	23/12/2022	
Comp. Dt. : 27/12/2022									
Status : Completed									
3022	22121229	Nursing College	IN PRINCIPAL ROOM-HEALTH TANK BROKEN	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	Health faucet PVC fullset changed.		DHANDAPANI - SMVNC	28/12/2022	
Comp. Dt. : 12/01/2023									
Status : Completed									
3023	23010526	Nursing College	NEED LABOURS FOR TABLE SHIFTING WORK	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	Table shifting work completed	 Dr. KAGNE. R.N DEAN SRI MANAKULA VINAYAGAR MEDICAL COLLEGE & HOSPITAL KALITHEERTHALKUPPAM, PUDUCHERRY-605107.	DHANDAPANI - SMVNC	14/01/2023	
Comp. Dt. : 20/01/2023									
Status : Completed									

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
3024	23010709	Nursing College	NEED TO CHECK TAP 2NOS - DRINKING WATER NOT COMING	Prakash. V.,Rajendran. R.,Ramkumar. R.	No water in RO Tank, motor problem, motor serviced and fill the water in tank, problem solved on tha		DHANDAPANI - SMVNC	21/01/2023
Comp. Dt. : 21/01/2023 Status : Completed								
3025	23010752	Nursing College	NEED TO CHECK TAP - WATER LEAKAGE - NEAR GROUND FLOOR COOLER	Prakash. V.,Rajendran. R.,Ramkumar. R.	Angle valve serviced and refixed, spindle changed, problem solved		JAYASEELAN - SMVNC	21/01/2023
Comp. Dt. : 08/02/2023 Status : Completed								
3026	23020279	Nursing College	2ND AND 3RD FLOOR REST ROOM WATER LEAKAGE	Prakash. V.,Rajendran. R.,Ramkumar. R.	WORK SHOP COMPLAINT		RAJARAJESHWARI - SMVNC	10/02/2023
Comp. Dt. : 09/02/2023 Status : Completed								
3027	23020357	Nursing College	3RD FLOOR REST ROOM BLOCK	Sakthivel. E.,Thanuzkodi. E,Kathirvelu. K.	BLOCK REMOVED		DHANDAPANI - SMVNC	10/02/2023
Comp. Dt. : 21/02/2023 Status : Completed								
3028	23020790	Nursing College	NEED TO CHECK ALL FLOOR RESTROOM NEAR WALLS - WATER LEAKAGE	Prakash. V.,Rajendran. R.,Ramkumar. R.	WORK SHOP COMPLAINT. INFORMED TO GANESAN SIR		RAJARAJESWARI - SMVNC	21/02/2023
Comp. Dt. : 02/03/2023 Status : Completed								
3029	23030087	Nursing College	RO WATER NOT COMING	Prakash. V.,Rajendran. R.,Ramkumar. R.	WATER PIPELINE REWORK DONE BY COMPANY LABOURS		DHANDAPANI - SMVNC	04/03/2023
Comp. Dt. : 25/03/2023 Status : Completed								
3030	23031064	Nursing College	NEED TO SPRAY MOSQUITO SPRAY AT ALL FLOORS & IN & AROUND NURSING COLLEGE	Murugan. S.	MOSQUITO REPELLANT SPRAYED.		JAYASEELAN - SMVNC	25/03/2023
Comp. Dt. : 03/04/2023 Status : Completed								
3031	23040035	Nursing College	WATER NOT COMING - R O WATER MOTOR NOT WORKING	Prakash. V.,Rajendran. R.,Ramkumar. R.	ELECTRICAL COMPLAINT		DHANDAPANI - SMVNC	03/04/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 20/04/2023 Status : Completed								
3032	23040649	Nursing College	NEED TO CHANGE COOLER FLOAT BALL - NOT WORKING AT GROUND FLOOR	Prakash. V.,Rajendran. R.,Ramkumar. R.	FLOAT BALL CHANGED.		DHANDAPANI - SMVNC	22/04/2023
Comp. Dt. : 27/04/2023 Status : Completed								
3033	23040892	Nursing College	R O WATER NOT COMING IN III FLOOR	Prakash. V.,Rajendran. R.,Ramkumar. R.	RO WATER PIPELINE REWORK DONE.		DHANDAPANI - SMVNC	03/05/2023
Comp. Dt. : 04/05/2023 Status : Completed								
3034	23050135	Nursing College	NEED TO CHECK WATER PIPELINE - WATER LEAKAGE AT I & II FLOOR RESTROOM	Prakash. V.,Rajendran. R.,Ramkumar. R.	TAP CHANGED.		DHANDAPANI - SMVNC	06/05/2023
Comp. Dt. : 06/05/2023 Status : Completed								
3035	23050248	Nursing College	BLOCK IN SINK AT NUTRITION LAB	Sakthivel. E.	block removed.		JAYASEELAN - SMVNC	06/05/2023
Comp. Dt. : 25/05/2023 Status : Completed								
3036	23050989	Nursing College	NEED TO CHECK WASH BASIN PIPE LINE - WATER NOT COMING AT I FLOOR OBG LAB	Prakash. V.,Rajendran. R.,Ramkumar. R.	DRAINAGE HOSE CHANGED.		JAYASEELAN - SMVNC	26/05/2023
Comp. Dt. : 30/05/2023 Status : Completed								
3037	23051180	Nursing College	NEED TO CHANGE TAP - BROKEN AT I FLOOR FEMALE RESTROOM - WATER FLOW NEED URGENT SERVICE	Manikandan. S.,Rajendran. R.,Arunagiri. V.	PILLAR COCK CHANGED.		DHANDAPANI - SMVNC	01/06/2023
Comp. Dt. : 16/06/2023 Status : Completed								
3038	23060588	Nursing College	COOLER TAP NOT WORKING	Prakash. V.,Rajendran. R.,Ramkumar. R.	WATER COOLER TAP GURU SPINDLE CHANGED		DHANDAPANI - SMVNC	16/06/2023
Work Type : Work Dept Name : Civil - Maintenance - Civil - Maintenance								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 07/03/2023 Status : Completed								
3039	23030259	Nursing College	NEED MANPOWER 5 NOS FOR BENCH SHIFTING WORK	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	BENCH SHIFTING WORK COMPLETED.		RAJARAJESWARI - SMVNC	17/03/2023
College Name : SMVPT Work Type : Complaint Dept Name : Civil - Maintenance - Civil - Maintenance Comp. Dt. : 16/05/2022 Status : Completed								
3040	22050557	Polytechnic college	NEED TO CHANGE R O WATER TAP	Sankar. V.,Gopal. S.,Santhosh Kumar. M.	tap chaing work		SANTHANAM - SMVPT	16/05/2022
Comp. Dt. : 25/05/2022 Status : Completed								
3041	22050956	Polytechnic college	BLOCK IN CHAMBER OVERFLOW	Rajendhiran. V.,Govindan. R.,Sakthivel. E.	Drainage block removed, work completed		SANTHANAM - SMVPT	25/05/2022
Comp. Dt. : 26/05/2022 Status : Completed								
3042	22050994	Polytechnic college	PIPE LINE LEAKAGE AT FEMALE RESTROOM AT I & II FLOOR	Azhagar. N.	Broken pipe line replaced with new one.		SANTHANAM - SMVPT	28/05/2022
Comp. Dt. : 31/05/2022 Status : Completed								
3043	22051144	Polytechnic college	BLOCK IN II FLOOR MALE RESTROOM	Govindan. R.	Toilet block removed, work completed		SANTHANAM - SMVPT	01/06/2022
Comp. Dt. : 12/08/2022 Status : Completed								
3044	22080432	Polytechnic college	NEED TO CHANGE TAP - WATER LEAKAGE AT CHEMISTRY LAB	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	New tap changed.		SANTHANAM - SMVPT	18/08/2022
3045	22080457	Polytechnic college	CHAMBER OVERFLOW AT GROUND FLOOR	Thanuzkodi. E	Block removed.		SANTHANAM - SMVPT	18/08/2022
Comp. Dt. : 05/09/2022 Status : Completed								
3046	22090159	Polytechnic college	BLOCK IN I FLOOR RESTROOM	Sakthivel. E.	block removed,.		SANTHANAM - SMVPT	07/09/2022
Comp. Dt. : 09/09/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
3047	22090366	Polytechnic college	BLOCK IN II FLOOR MALE RESTROOM	Rajendhiran. V.	Block removed		SANTHANAM - SMVPT	10/09/2022
		Comp. Dt. : 17/09/2022 Status : Completed						
3048	22090673	Polytechnic college	CHAMBER OVERFLOW AT GROUND FLOOR	Murugan. S., Sakthivel. E., Govindan. R.	Block removed.		SANTHANAM - SMVPT	19/09/2022
		Comp. Dt. : 23/09/2022 Status : Completed						
3049	22090947	Polytechnic college	BLOCK IN II FLOOR COMON MALE RESTROOM	Sakthivel. E.	block removed.		SANTHANAM - SMVPT	26/09/2022
		Comp. Dt. : 21/10/2022 Status : Completed						
3050	22100716	Polytechnic college	IN STORE ROOM-REST ROOM BLOCK-NEED SCAVENGER	Sakthivel. E.	block removed.		SANTHANAM - SMVPT	22/10/2022
3051	22100737	Polytechnic college	IN GROUND FLOOR BATHROOM-URINAL BLOCK	Sakthivel. E.	block removed.		SANTHANAM - SMVPT	22/10/2022
		Comp. Dt. : 09/11/2022 Status : Completed						
3052	22110345	Polytechnic college	IN STORE ROOM -BATHROOM BLOCK-NEED SCAVENGER	Sakthivel. E.	Block removed.		SANTHANAM - SMVPT	10/11/2022
		Comp. Dt. : 14/11/2022 Status : Completed						
3053	22110531	Polytechnic college	IN GROUND FLOOR -TOILET-WATER TAP LEAKAGING PROBLEM	Prakash. V., Rajendran. R., Sankar. V.	Tap rework and refixed in properly, problem solved		SANTHANAM - SMVPT	16/11/2022
3054	22110532	Polytechnic college	WATER NOT COMING IN 3RD FLOOR-STAFF ROOM	Prakash. V.	Flush tank and tap rework and refixed in properly, work completed		SANTHANAM - SMVPT	16/11/2022
		Comp. Dt. : 18/11/2022 Status : Completed						
3055	22110796	Polytechnic college	BLOCK- II FLOOR COMMON RESTROOM	Govindan. R.	Block removed		SANTHANAM - SMVPT	21/11/2022
		Comp. Dt. : 14/12/2022 Status : Completed						
3056	22120636	Polytechnic college	BLOCK IN WORKSHOP RESTROOM	Sakthivel. E.	block removed		SANTHANAM - SMVPT	14/12/2022
		Comp. Dt. : 24/12/2022						


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
3057	22121127	Polytechnic college	NEW MOTOR RE-FIXING WORK NEED TO DO	Prakash. V.,Sankar. V.,Udhaya Kumar. R.	Motor refixing work completed.		SANTHANAM - SMVPT	24/12/2022
Comp. Dt. : 28/12/2022								
Status : Completed								
3058	22121299	Polytechnic college	GROUND FLOOR REST ROOM BLOCK	Rajendhiran. V.,Thanuzkodi. E,Murugan. S.	Block removed.		SANTHANAM - SMVPT	29/12/2022
Comp. Dt. : 04/01/2023								
Status : Completed								
3059	23010145	Polytechnic college	TANK NEW PIPELINE FIXING WORK	Ramkumar. R.,Sivaraja. M.,Santhosh Kumar. M.	New pipeline laying work completed.		SANTHANAM - SMVPT	06/01/2023
Comp. Dt. : 10/01/2023								
Status : Completed								
3060	23010422	Polytechnic college	IN WORK SHOP-REST ROOM-FLUSH LEAKAGING PROBLEM	Gopal. S.	Flush tank rework done.		SANTHANAM - SMVPT	11/01/2023
Comp. Dt. : 11/01/2023								
Status : Completed								
3061	23010472	Polytechnic college	IN GROUND FLOOR-TOILET BLOCKED,NEED SCAVENGER	Sakthivel. E.	block removed.		SANTHANAM - SMVPT	12/01/2023
Comp. Dt. : 12/01/2023								
Status : Completed								
3062	23010512	Polytechnic college	OLD MOTOR CONNECTION NEED TO GIVE	Sivaraja. M.,Santhosh Kumar. M.,Gopal. S.	Old motor connection given.		SANTHANAM - SMVPT	13/01/2023
Comp. Dt. : 25/01/2023								
Status : Completed								
3063	23010929	Polytechnic college	BLOCK - II FLOOR REST ROOM	Sakthivel. E.,Govindan. R.,Kathirvelu. K.	Block removed.		SANTHANAM - SMVPT	27/01/2023
Comp. Dt. : 30/01/2023								
Status : Completed								
3064	23011059	Polytechnic college	NEED TO CHANGE TAP - WATER LEAKAGE AT CHEMISTRY LAB	Sellaveeran. M.	New tap changed.		SANTHANAM - SMVPT	31/01/2023
Comp. Dt. : 31/01/2023								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
3065	23011120	Polytechnic college	NEED TO CHECK WATER PIPE LINE CONNECTION AT TERRACE - LINE BROKEN WATER FLOW	Sivaraja. M.,Santhosh Kumar. M.,Sankar. V.	PIPE LINE CONNECTION WORK COMPLETED.		SANTHANAM - SMVPT	07/02/2023
Comp. Dt. : 01/02/2023								
Status : Completed								
3066	23020015	B.ED COLLEGE	BLOCK IN I FLOOR STAFF RESTROOM	Sakthivel. E.,Govindan. R.,Kathirvelu. K.	Block removed.		SRIMAN - SMVPT	01/02/2023
Comp. Dt. : 03/02/2023								
Status : Completed								
3067	23020091	Polytechnic college	NEED TO CHECK RESTROOM PIPELINE BROKEN AT GROUND FLOOR	Sivaraja. M.,Gopal. S.,Santhosh Kumar. M.	PIPE LINE LAYING WORK COMPLETED.		SANTHANAM - SMVPT	07/02/2023
Comp. Dt. : 09/02/2023								
Status : Completed								
3068	23020331	Polytechnic college	TANK PIPE BROKEN	Sellaveeran. M.,Udhaya Kumar. R.,Sivaraja. M.	PIPE LINE CONNECTION COMPLETED		SANTHANAM - SMVPT	13/02/2023
Comp. Dt. : 16/02/2023								
Status : Completed								
3069	23020622	Polytechnic college	2ND FLOOR REST ROOM BLOCK	Sakthivel. E.,Govindan. R.,Kathirvelu. K.	BLOCK REMOVED.		SANTHANAM - SMVPT	16/02/2023
3070	23020623	Polytechnic college	CHEMISTRY LAB -WATER LEAKAGE PROBLEM	Sivaraja. M.,Sellaveeran. M.,Rajendran. R.	WASTE LINE REWORK DONE		SANTHANAM - SMVPT	17/02/2023
Comp. Dt. : 20/02/2023								
Status : Completed								
3071	23020769	Polytechnic college	BLOCK IN I FLOOR RESTROOM	Govindan. R.,Sakthivel. E.,Kathirvelu. K.	BLOCK REMOVED.		SANTHANAM - SMVPT	21/02/2023
Comp. Dt. : 21/02/2023								
Status : Completed								
3072	23020805	Polytechnic college	BLOCK IN GROUND FLOOR MALE RESROOM	Sakthivel. E.,Govindan. R.,Kathirvelu. K.	BLOCK REMOVED.		SANTHANAM - SMVPT	21/02/2023
Comp. Dt. : 24/02/2023								
Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
3073	23020945	Polytechnic college	NEED TO CHECK PIPELINE NEAR TANK - BROKEN WATER FLOW - NEED URGENT SERVICE	Sivaraja. M.,Santhosh Kumar. M.,Sellaveeran. M.	PIPE LINE LAYING WORK DONE.		SANTHANAM - SMVPT	25/02/2023
Comp. Dt. : 13/03/2023 Status : Completed								
3074	23030507	Polytechnic college	flush not working - ii floor staff room	Sivaraja. M.,Santhosh Kumar. M.,Sellaveeran. M.	FLUSH TANK REWORK DONE		SANTHANAM - SMVPT	15/03/2023
Comp. Dt. : 22/03/2023 Status : Completed								
3075	23030894	Polytechnic college	NEED TO CHECK WATER PIPELINE - BROKEN WATER FLOW AT I FLOOR - NEED URGENT SERVICE	Sivaraja. M.	WATER PIPELINE CONNECTION DONE,.		SANTHANAM - SMVPT	23/03/2023
Comp. Dt. : 24/03/2023 Status : Completed								
3076	23031002	Polytechnic college	NEED TO CHECK II FLOOR RESTROOM PIPELINE - BROKEN	Sivaraja. M.,Santhosh Kumar. M.,Gopal. S.	PIPELINE CONNECTION REWORK DONE.		SANTHANAM - SMVPT	25/03/2023
Comp. Dt. : 25/03/2023 Status : Completed								
3077	23031041	B.ED COLLEGE	NEED TO CHECK WATER PIPELINE CONNECTION - BROKEN AT GROUND FLOOR RESTROOM	Prakash. V.,Rajendran. R.,Ramkumar. R.	WORK COMPLETED.		SRIMAN - SMVPT	03/04/2023
Comp. Dt. : 01/04/2023 Status : Completed								
3078	23040012	Polytechnic college	NEED TO CHECK WATER PIPELINE - WATER NOT COMING IN PRINCIPAL OFFICE REST ROOM	Sivaraja. M.,Sellaveeran. M.,Gopal. S.	WATER PIPELINE CONNECTION REWORK DONE.		SANTHANAM - SMVPT	04/04/2023
Comp. Dt. : 10/04/2023 Status : Completed								
3079	23040277	Polytechnic college	BLOCK IN I FLOOR MALE RESTROOM	Rajendhiran. V.,Thanuzkodi. E.,Murugan. S.	BLOCK REMOVED.		SANTHANAM - SMVPT	13/04/2023
Comp. Dt. : 02/05/2023 Status : Completed								
3080	23050065*	Polytechnic college	NEED TO REMOVE BEE NEST AT III FLOOR CLASS ROOM NO 301	Sivaraja. M.	HONEY COMB DESTROYED.		SANTHANAM - SMVPT	24/05/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 08/05/2023 Status : Completed								
3081	23050297	Polytechnic college	BLOCK IN I FLOOR RESTROOM	Sakthivel. E.,Govindan. R.,Kathirvelu. K.	BLOCK REMOVED.		SANTHANAM - SMVPT	10/05/2023
Comp. Dt. : 11/05/2023 Status : Completed								
3082	23050462	Polytechnic college	NEED TO CHANGE WASH BASIN DRAINAGE HOSE FOR PHYSICS LAB	Anandharaj. M.,Sivaraja. M.,Gopal. S.	WASH BASIN DRAINAGE HOSE CHANGED.		SANTHANAM - SMVPT	13/05/2023
Comp. Dt. : 27/05/2023 Status : Completed								
3083	23051101	Polytechnic college	NEED MANPOWER 1 NO FOR CLEANING WORK	Pandiaraj. V.	HOUSEKEEPING COMPLAINT.		SANTHANAM - SMVPT	29/05/2023
Comp. Dt. : 03/06/2023 Status : Completed								
3084	23060102	Polytechnic college	BLOCK IN BACK SIDE CHAMBER	Sakthivel. E.,Govindan. R.,Gnanasegaran. K.	BLOCK REMOVED.		SANTHANAM - SMVPT	03/06/2023
Comp. Dt. : 15/06/2023 Status : Completed								
3085	23060554	Polytechnic college	PLAY GROUND WATER BLOCK	Sakthivel. E.,Govindan. R.,Kathirvelu. K.	BLOCK REMOVED		SANTHANAM - SMVPT	16/06/2023
Comp. Dt. : 20/06/2023 Status : Completed								
3086	23060722	Polytechnic college	NEED TO CHECK REST ROOM WALL - WATER LEAKAGE AT GROUND & II FLOOR COMMON RESTROOM	Sivaraja. M.,Santhosh Kumar. M.,Gopal. S.	Ground floor and 2nd floor restroom water pipeline connection rework done.		SANTHANAM - SMVPT	23/06/2023
Comp. Dt. : 22/06/2023 Status : Completed								
3087	23060827	Polytechnic college	NEED TO CHECK WATER PIPELINE - BROKEN AT COLLEGE BACKSIDE	Sivaraja. M.,Santhosh Kumar. M.,Sellaveeran. M.	Water pipeline connection rework done		SANTHANAM - SMVPT	23/06/2023

College Name : VCE
Work Type : Complaint
Dept Name : Civil - Maintenance - Civil - Maintenance
Comp. Dt. : 14/06/2022

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
3088	22060507	B.ED COLLEGE	NEED TO CHANGE TAP FOR GROUND & I FLOOR REST ROOM - DAMAGE & WATER LEAKAGE	Anandharaj. M.,Azhagar. N.,Sellaveeran. M.	4Nos of Health faucet, 9Nos of Pillar cock spindle, connection tube 4Nos, Tap 4Nos changed, work co		VENKATESAN - VCE	30/06/2022
Comp. Dt. : 06/10/2022								
Status : Completed								
3089	22100092	B.ED COLLEGE	WATER NOT COMING IN FIRST FLOOR ALL PLACES	Sellaveeran. M.,Udhaya Kumar. R.,Gopal. S.	complaint undertaken by unigcore constructions.		SRIMAN - VCE	07/10/2022
Comp. Dt. : 18/10/2022								
Status : Completed								
3090	22100597	B.ED COLLEGE	BLOCK IN I FLOOR MALE RESTROOM	Sakthivel. E.	Block removed		SRIMAN - VCE	18/10/2022
Comp. Dt. : 06/01/2023								
Status : Completed								
3091	23010266	Venkateswara College of Education	STAFF REST ROOM BLOCK	Sakthivel. E.,Govindan. R.,Kathirvelu. K.	Toilet block removed, work completed		SRIMAN - VCE	07/01/2023
Comp. Dt. : 20/01/2023								
Status : Completed								
3092	23010698	B.ED COLLEGE	R.O WATER NOT COMING	Prakash. V.,Rajendran. R.,Ramkumar. R.	Motor problem, motor repaired and serviced, now problem solved		SRIMAN - VCE	20/01/2023
Comp. Dt. : 27/01/2023								
Status : Completed								
3093	23010950	B.ED COLLEGE	NEED TO CHECK WATER PIPELINE CONNECTION - WATER NOT COMING IN I FLOOR	Prakash. V.,Rajendran. R.,Arunagiri. V.	Block removed. Pipe line connection rework done.		SRIMAN - VCE	31/01/2023
Comp. Dt. : 06/02/2023								
Status : Completed								
3094	23020189	B.ED COLLEGE	BLOCK IN I FLOOR STAFF ROOM	Sakthivel. E.,Rajendhiran. V.,Murugan. S.	BLOCK REMOVED.		SRIMAN - VCE	07/02/2023
Comp. Dt. : 20/02/2023								
Status : Completed								
3095	23020753	B.ED COLLEGE	NEED TO CHANGE DRINKING WATER TAP PIPE LINE - DAMAGE AT I FLOOR	Prakash. V.,Rajendran. R.,Ramkumar. R.	DRINKING WATER TAP PIPE LINE REWORK DONE.		SRIMAN - VCE	21/02/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 15/03/2023								
Status : Completed								
3096	23030611	B.ED COLLEGE	BLOCK IN GROUND & I FLOOR RESTROOM	Sakthivel. E.,Govindan. R.,Kathirvelu. K.	BLOCK REMOVED.		SRIMAN - VCE	16/03/2023
Comp. Dt. : 29/03/2023								
Status : Completed								
3097	23031242	B.ED COLLEGE	BLOCK IN I FLOOR RESTROOM	Sakthivel. E.,Govindan. R.,Kathirvelu. K.	BLOCK REMOVED.		SRIMAN - VCE	30/03/2023
Comp. Dt. : 11/04/2023								
Status : Completed								
3098	23040346	B.ED COLLEGE	BLOCK IN I FLOOR RESTROOM	Sakthivel. E.,Govindan. R.,Thanuzkodi. E	BLOCK REMOVED.		SRIMAN - VCE	13/04/2023
Comp. Dt. : 13/04/2023								
Status : Completed								
3099	23040415	B.ED COLLEGE	NEED TO CHECK WATER PIPE LINE BROKEN - WATER BLOCK AT COLLEGE ENTRANCE	Prakash. V.,Rajendran. R.,Ramkumar. R.	3/4" UPVC pipe line rework, work completed		SRIMAN - VCE	20/04/2023
Comp. Dt. : 24/04/2023								
Status : Completed								
3100	23040731	B.ED COLLEGE	R O WATER NOT COMING	Prakash. V.,Rajendran. R.,Ramkumar. R.	RO WATER PIPELINE REWORK DONE.		VENKATESAN - VCE	28/04/2023
Comp. Dt. : 27/04/2023								
Status : Completed								
3101	23040941	B.ED COLLEGE	RESTROOM BLOCK IN I FLOOR	Sakthivel. E.,Govindan. R.,Kathirvelu. K.	block removed.		VENKATESAN - VCE	28/04/2023
Comp. Dt. : 26/05/2023								
Status : Completed								
3102	23051025	B.ED COLLEGE	BLOCK IN GROUND FLOOR RESTROOM	Sakthivel. E.,Govindan. R.,Gnanasegaran. K.	BLOCK REMOVED.		VENKATESAN - VCE	27/05/2023

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.



Sri Manakula Vinayagar Medical College and Hospital

Complaint Status Report From 01-05-2022 To 30-06-2023

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
College Name : MIT								
Work Type : Complaint								
Dept Name : Civil - Execution - Civil - Execution								
Comp. Dt. : 25/08/2022								
Status : Completed								
1	22080859	Nursing Quarters	Need to clear all debris for dining hall pooja	Sasikala. P.	Debris cleaning work done.		sivagnanam - MIT	08/10/2022
2	22080860	Nursing Quarters	Need to clean all debris for dining hall pooja	Sasikala. P.	Debris cleaned.		Sivagnanam - MIT	08/10/2022
College Name : SMVMCH								
Work Type : Complaint								
Dept Name : Canteen - Boys Hostel - Civil - Execution								
Comp. Dt. : 22/02/2023								
Status : Completed								
3	23020840	Boys hostel PH-I	RESTROOM CEILING WATER LEAKAGE AT ROOM NO.30 (3RD FLOOR). TILES POINTING WORK SHOULD BE DONE.	Sasikala. P.	Tiles binding work completed		Mathubalan. M. - Canteen - Boys Hostel	20/07/2023
Comp. Dt. : 12/06/2023								
Status : Completed								
4	23060387	Boys hostel	Need touch up work at all floors in Boys Hostel Phase I, phase II & Phase III	Praveen Kumar. K.	All floors crack touch up work completed		Sambasivam. K. - Canteen - Boys Hostel	17/06/2023
Dept Name : Canteen-Girls Hostel - Civil - Execution								
Comp. Dt. : 12/05/2022								
Status : Completed								
5	22050420	J.R Quateres	HOLLOW BLOCK BRICKS DAMAGE	Sasikala. P.	Plastering work completed		Virgin Mary - Canteen-Girls Hostel	20/07/2023
Comp. Dt. : 19/12/2022								
Status : Completed								
6	22120853	J.R Quateres	ROAD DAMAGE WORK NEAR JR QUARTERS	Sasikala. P.	Work completed		Virgin Mary - Canteen-Girls Hostel	20/07/2023
Comp. Dt. : 08/02/2023								
Status : Completed								


Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
7	23020273	Ladies hostel Phase-II	NEED TO CHAMBER RAISING WORK	Sasikala. P.	Chamber raising work completed.		Malliga. K. - Canteen-Girls Hostel	20/07/2023
Dept Name : Civil - Execution - Civil - Execution Comp. Dt. : 09/05/2022 Status : Completed								
8	22050293	PICU & NICU	AC holes packing work	Praveen Kumar. K.	AC holes packing work completed		Praveen Kumar. K. - Civil - Execution	20/07/2023
Comp. Dt. : 12/05/2022 Status : Completed								
9	22050440	Reception	Need scaffolding work for portigo ceiling paint work.	Praveen Kumar. K.	Scaffolding work completed		Praveen Kumar. K. - Civil - Execution	20/07/2023
10	22050444	Reception	False ceiling painting work.	Praveen Kumar. K.	Painting work completed		Praveen Kumar. K. - Civil - Execution	12/05/2022
11	22050445	PICU & NICU	PICU area wall tile laying work.	Praveen Kumar. K.	Tiles laying work completed		Praveen Kumar. K. - Civil - Execution	20/07/2023
Comp. Dt. : 16/05/2022 Status : Completed								
12	22050573	ANATOMY	Need to lay tiles in the broken toilet area.	Sasikala. P.	Tiles laying work completed		Praveen Kumar. K. - Civil - Execution	20/07/2023
Comp. Dt. : 28/05/2022 Status : Completed								
13	22051066	Casualty	Need to apply sealant in windows	Sasikala. P.	Window sealant applied.		Sasikala. P. - Civil - Execution	20/07/2023
Comp. Dt. : 23/07/2022 Status : Completed								
14	22070877	Boys hostel Phase-II	Need scaffolding work for AC purpose	Sasikala. P.	Work completed		Sasikala. P. - Civil - Execution	20/07/2023
Comp. Dt. : 30/08/2022 Status : Completed								
15	22081047	A.P Quateres	Room no.12, Kitchen tiles to be laid	Sasikala. P.	Tiles laying work completed		Sasikala. P. - Civil - Execution	30/08/2022
Comp. Dt. : 30/09/2022 Status : Completed								
16	22091210	Boys hostel Phase-II	Need JCB and tractor brick jally rubbish loading and leveling work	Sasikala. P.	Brick jally rubbish loading and levelling work completed at medical college road from NH (damaged BT		Sasikala. P. - Civil - Execution	30/09/2022
Comp. Dt. : 23/11/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
17	22111001	Paediatrics - Ward 309	Need breaker to demolish the floor and wall tiles for expansion joint treatment.	Praveen Kumar. K.	Wall and floor demolished for expansion joint purpose.		Praveen Kumar. K. - Civil - Execution	23/11/2022
Comp. Dt. : 04/04/2023 Status : Completed								
18	23040138	professor quarters-DEAN SIR HOUSE	NEED BREAKER FOR DEMOLISHING THE FLOOR TILES AT WEST SIDE BALCONY	Sasikala. P.	FLOOR TILES DEMOLISHED AT WEST SIDE BALCONY		Sasikala. P. - Civil - Execution	04/04/2023
Comp. Dt. : 02/05/2023 Status : Completed								
19	23050015	Boys hostel	PRESSED TILE GROUTING WORK TO BE DONE AT BOYS HOSTEL I & III TERRACE	Praveen Kumar. K.	PRESSED TILE GROUTING WORK COMPLETED.		Praveen Kumar. K. - Civil - Execution	02/05/2023
Comp. Dt. : 03/06/2023 Status : Completed								
20	23060113	DIRECTOR QUATERS	NEED TO RAISE CHAMBER AT DIRECTOR QUARTERS	Praveen Kumar. K.	CHAMBER RAISING WORK COMPLETED		Praveen Kumar. K. - Civil - Execution	03/06/2023
Comp. Dt. : 12/06/2023 Status : Completed								
21	23060413	COMMERCIAL BLOCK	NEED PAINTING WORK AT PROJECT MANAGER ROOM	Praveen Kumar. K.	Painting work completed		Murugan.N. - Civil - Execution	04/09/2023
Dept Name : Civil - Maintenance - Civil - Execution Comp. Dt. : 09/05/2022 Status : Completed								
22	22050290	PICU & NICU	Toilet floor tiles laying work.	Praveen Kumar. K.	Floor tiles laid		Gurunathan. V. - Civil - Maintenance	20/07/2023
Comp. Dt. : 14/05/2022 Status : Completed								
23	22050508	MIT College	Need scaffolding work for 3rd floor toilet rework.	Praveen Kumar. K.	Scaffolding work completed		Sankar. R - Civil - Maintenance	20/07/2023
Comp. Dt. : 07/11/2022 Status : Completed								
24	22110220	Hospital	Need to raise chamber at pediatric opd backside.	Praveen Kumar. K.	Chamber raising work completed		Prakash. V. - Civil - Maintenance	20/07/2023
Comp. Dt. : 08/11/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
25	22110273	FOUNDER STATUE-NEAR MIT COLLEGE	Need to raise chamber	Sasikala. P.	Chamber raising work completed		Prakash. V. - Civil - Maintenance	20/07/2023
Comp. Dt. : 27/12/2022 Status : Completed								
26	22121200	NURSING HOSTEL	IN 2ND ,3RD ,4TH FLOOR COMMON TOILET FLOOR TILES BROKEN	Sasikala. P.	Work completed		Sankar. R - Civil - Maintenance	20/07/2023
Comp. Dt. : 21/01/2023 Status : Completed								
27	23010793	Boys hostel PH-I	Need scaffolding work upto 3rd floor - Cyclinder room south side.	Sasikala. P.	Scaffolding work completed		Gurunathan. V. - Civil - Maintenance	20/07/2023
Comp. Dt. : 17/06/2023 Status : Completed								
28	23060642	LADIES HOSTEL PHASE-1BACKSIDE	Need to raise the chamber	Praveen Kumar. K.	Chamber raising and plastering work completed		Sankar. R - Civil - Maintenance	17/06/2023
Dept Name : Director Office - Civil - Execution Comp. Dt. : 18/05/2023 Status : Completed								
29	23050753	professor quarters	NEED TO CHANGE GRANITE PIECE IN ALL FLOOR LIFT AREA	Sasikala. P.	Work completed		Mani. A. - Director Office	20/07/2023
Dept Name : Guest House - Indian Bank - Civil - Execution Comp. Dt. : 06/05/2023 Status : Completed								
30	23050259	Guest House - Indian Bank	NEED BREAKER FOR DEMOLISHING THE FLOOR TILES AT ROOM NO.204 AND 204 FOR FIXING WASH BASIN.	Murugan.N.	FLOOR TILES DEMOLISHING WORK COMPLETED.		John. H. - Guest House - Indian Bank	06/05/2023
College Name : SMVMCH-COL Work Type : Complaint Dept Name : Air Condition Department - Civil - Execution Comp. Dt. : 02/12/2022 Status : Completed								
31	22120060	PHARMACOLOGY	NEED SCAFFOLDING WORK AT NEAR MEDICAL COLLEGE PHARMACOLOGY	Praveen Kumar. K.	Scaffolding raised from ground floor to 3rd floor for A/C installation purpose.		Garavanan. C. - Air Condition Department	03/12/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Dept Name : BIOCHEMISTRY - Civil - Execution Comp. Dt. : 21/03/2023 Status : Completed								
32	23030863	BIOCHEMISTRY-- -COLLEGE	NEED REPAIRING WORK FOR OUTDOOR FRAME DAMAGE & CEILING WATER LEAKAGE WORK	Sasikala. P.	Work completed		Suganthi. P. - BIOCHEMISTRY	20/07/2023
33	23030865*	BIOCHEMISTRY-- -COLLEGE	NEED REPAINTING WORK FOR DOOR FRAME REPAIRING WORK PLACES [4NOS]	Sasikala. P.	Painting work done for door frame repaired area		Suganthi. P. - BIOCHEMISTRY	25/03/2023
34	23030866	BIOCHEMISTRY-- -COLLEGE	NEED REPAIRING & REFIX DOOR LOCK 4 NOS	Sasikala. P.	Work shop complaint		Suganthi. P. - BIOCHEMISTRY	20/07/2023
Dept Name : Civil - Execution - Civil - Execution Comp. Dt. : 18/07/2022 Status : Completed								
35	22070666	Hospital	G wing 2nd floor - Need scaffolding work for wall plastering	Sasikala. P.	Scaffolding work done		Sasikala. P. - Civil - Execution	18/07/2022
Comp. Dt. : 04/11/2022 Status : Completed								
36	22110126	MEDICAL COLLEGE	Need scaffolding work at backside near dissection hall.	Sasikala. P.	Scaffolding work done.		Sasikala. P. - Civil - Execution	04/11/2022
Dept Name : Civil - Maintenance - Civil - Execution Comp. Dt. : 08/12/2022 Status : Completed								
37	22120347	PHYSIOLOGY-- -COLLEGE	NEED TOUCHUP WORK FOR DAMAGED BROKEN TILES FOR PHYSIOLOGY RESTROOM AT GROUND FLOOR	Sasikala. P.	Tiles binding work completed		Sankar. R - Civil - Maintenance	20/07/2023
Comp. Dt. : 06/03/2023 Status : Completed								
38	23030229	PATHOLOGY IN COLLEGE	Existing damaged tiles to be replaced with new one.	Sasikala. P.	Existing damaged tiles demolished and new tiles laid.		Sankar. R - Civil - Maintenance	06/03/2023
Comp. Dt. : 23/06/2023 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
39	23060875	MEDICAL COLLEGE	DUE TO WATER LEAKAGE - NEED POINTING WORK AT MEDICAL COLLEGE I , II & III FLOOR	Praveen Kumar. K.	Binding and grouting work completed in west side Ladies and gents common toilet in all the three flo		Sankar. R - Civil - Maintenance	26/06/2023
Dept Name : Electrical Maintenance - Civil - Execution Comp. Dt. : 30/11/2022 Status : Completed								
40	22111290	MEDICAL COLLEGE	LINE GOT SHORT CIRCUIT,EARTHENING WORK NEED TO DO	Praveen Kumar. K.	Earth work completed		Vaithianathan.M - Electrical Maintenance	20/07/2023
Dept Name : FORENSIC MEDICINE - Civil - Execution Comp. Dt. : 06/04/2023 Status : Completed								
41	23040178	FORENSIC MEDICINE (3RD FLOOR) IN COLLEGE	NEED CEMENT TOUCHUP WORK FOR RESTROOM WALL	Sasikala. P.	Touch up plastering work completedq		Mathavi. B. - FORENSIC MEDICINE	20/07/2023
Dept Name : Library - Civil - Execution Comp. Dt. : 25/08/2022 Status : Completed								
42	22080855	MEDICAL COLLEGE I FLOOR	NEED TO REFIX WINDOW GLASS DOOR FRAME NEAR STEPS AT LIBRARY I FLOOR , RAIN WATER COMING INSIDE THE	Sasikala. P.	Window glass refixed.		Elangovan.N. - Library	20/07/2023
Dept Name : PHYSIOLOGY - Civil - Execution Comp. Dt. : 18/03/2023 Status : Completed								
43	23030757	PHYSIOLOGY-- -COLLEGE	NEED PAINTING WORK AT PHYSIOLOGY DEPT. MUSEUM ROOM	Sasikala. P.	PAINTING WORK COMPLETED		Deepika. V. - PHYSIOLOGY	25/03/2023
Work Type : Work Dept Name : Civil - Maintenance - Civil - Execution Comp. Dt. : 22/11/2022 Status : Completed								
44	22110954	MEDICAL COLLEGE 2ND FLOOR	NEED TO REFIX TILES FOR RESTROOM	Sasikala. P.	Floor tiles laying and binding work completed.		Sankar. R - Civil - Maintenance	25/11/2022
Dept Name : MICROBIOLOGY - Civil - Execution Comp. Dt. : 08/10/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
45	22100185	MICROBIOLOGY IN COLLEGE	Need Touchup work for marble - broken	Sasikala. P.	Work completed		Raffik Moideen. M. - SMV Allied Health Sciences	20/07/2023
College Name : SMVMCH-HOS Work Type : Complaint Dept Name : Administration - Civil - Execution Comp. Dt. : 27/12/2022 Status : Completed								
46	22121214	GENERAL STORE	RAINWATER LEAKAGING FROM CEILING	Praveen Kumar. K.	Work completed		Manikandan. S. - Administration	20/07/2023
Dept Name : Air Condition Department - Civil - Execution Comp. Dt. : 06/05/2022 Status : Completed								
47	22050174	CARDIOLOGY OPD	DUE TO AC FAULT - NEED SCAFFOLDING WORK FROM GROUND FLOOR TO III FLOOR BACK SIDE OF CARDIOLOGY	Praveen Kumar. K.	Scaffolding work completed		Babu. D. - Air Condition Department	20/07/2023
Comp. Dt. : 12/07/2022 Status : Completed								
48	22070476	Boys hostel Phase-II	NEED SCAFFOLDING WORK FOR FIXING NEW AC FOR ROOM NO 29	Sasikala. P.	Scaffolding work done		Babu. D. - Air Condition Department	21/07/2022
Comp. Dt. : 21/07/2022 Status : Completed								
49	22070779	CARDIOLOGY OPD	NEED SCAFFOLDING WORK FOR FIXING NEW AC AT II FLOOR CARDIOLOGY OPD	Sasikala. P.	Scaffolding work done		Babu. D. - Air Condition Department	21/07/2022
50	22070780	ALL WARD DEMO ROOM	NEED SCAFFOLDING WORK FOR FIXING NEW AC FOR ALL WARD DEMO ROOMS [5 NOS]	Praveen Kumar. K.	Scaffolding work completed		Babu. D. - Air Condition Department	20/07/2023
Comp. Dt. : 11/08/2022 Status : Completed								
51	22080398	V I P DENTAL CLINIC II FLOOR	NEED SCAFFOLDING WORK	Praveen Kumar. K.	Scaffolding work completed		Babu. D. - Air Condition Department	20/07/2023
Comp. Dt. : 18/08/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
52	22080588	THIRD FLOOR	B, D and G wing - Need scaffolding work for AC installation work at all demo rooms	Praveen Kumar. K.	Scaffolding work done.		Babu. D. - Air Condition Department	18/08/2022
Comp. Dt. : 12/10/2022 Status : Completed								
53	22100354	CT Scan	NEED OUTDOOR BED [2NOS] FOR AC - AT BACK SIDE OF CT SCAN	Praveen Kumar. K.	Outdoor bed 2nos. provided		Saravanan. C. - Air Condition Department	12/10/2022
54	22100369	HOSPITAL TERROUS	Need to provide water tank at terrace for AC purpose	Praveen Kumar. K.	Water tank provided.		Saravanan. C. - Air Condition Department	12/10/2022
Comp. Dt. : 26/10/2022 Status : Completed								
55	22100813	MIT COLLEGE BACKSIDE	SUBHOLDING WORK	Sasikala. P.	Scaffolding work completed		Panneer Selvam. P. - Air Condition Department	20/07/2023
Comp. Dt. : 04/04/2023 Status : Completed								
56	23040107	CARDIOLOGY OPD	NEED SCAFFOLDING WORK FROM BACKSIDE OF CARDIOLOGY [CHILDREN'S PARK]	Praveen Kumar. K.	Scaffolding work completed		Panneer Selvam. P. - Air Condition Department	20/07/2023
Comp. Dt. : 27/05/2023 Status : Completed								
57	23051077	CHILDREN'S PARK	NEED SCAFFOLDING WORK	Praveen Kumar. K.	Scaffolding work completed		Panneer Selvam. P. - Air Condition Department	20/07/2023
Comp. Dt. : 05/06/2023 Status : Completed								
58	23060140	CHILDREN'S PLAY GROUND INSIDE HOSPITAL	NEED SCAFFOLDING WORK FOR A/C SERVICE PURPOSE.	Sasikala. P.	SCAFFOLDING WORK RAISED UPTO 3RD FLOOR FOR THE AC SERVICE PURPOSE.		Elumalai. J. - Air Condition Department	05/06/2023
Dept Name : BIOCHEMISTRY - Civil - Execution Comp. Dt. : 21/03/2023 Status : Completed								
59	23030864	BIOCHEMISTRY--COLLEGE	SINK [WASH BASIN 3NOS] BROKEN NEED TO CHANGE	Praveen Kumar. K.	Civil Maintenance complaint		Suganthi. P. - BIOCHEMISTRY	20/07/2023
Dept Name : Canteen - Boys Hostel - Civil - Execution Comp. Dt. : 10/10/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
60	22100236	Boys hostel Phase-II	NEED CIVIL WORK FOR DAMAGED SUNSHADE WALL - WATER LEAKAGE & CEMENT CONCRETE PARTS FALLING DOWN F	Sasikala. P.	Repeated complaint		Sambasivam. K. - Canteen - Boys Hostel	20/07/2023
Comp. Dt. : 13/12/2022 Status : Completed								
61	22120592	Boys hostel	NEED REPAIRING WORK FOR WINDOW SUN SHADE - RAIN WATER LEAKAGE - ROOM NO 38,51 & 56 FOR HOYS HOSTEL P	Sasikala. P.	Work completed		Sambasivam. K. - Canteen - Boys Hostel	06/10/2023
Comp. Dt. : 11/03/2023 Status : Completed								
62	23030463	MIT MESS	NEED TO REARRANGE PAVER BLOCK - ENTRANCE MIT MESS	Sasikala. P.	Paver block refixed		Sambasivam. K. - Canteen - Boys Hostel	20/07/2023
Dept Name : Canteen-Girls Hostel - Civil - Execution Comp. Dt. : 21/09/2022 Status : Completed								
63	22090840*	LADIES HOSTEL- KITCHEN	Need to demolish and lay concrete in kitchen	Sasikala. P.	Cement concrete laid.		Revathy. N. - Canteen-Girls Hostel	08/10/2022
Dept Name : Civil - Execution - Civil - Execution Comp. Dt. : 24/05/2022 Status : Completed								
64	22050872	Casualty	NEED PAINTING WORK	Sasikala. P.	Painting work completed.		Sasikala. P. - Civil - Execution	28/05/2022
Comp. Dt. : 11/06/2022 Status : Completed								
65	22060415	PICU & NICU	Need scaffolding work in north side of NICU PICU for AC holes packing work.	Praveen Kumar. K.	Work completed		Praveen Kumar. K. - Civil - Execution	20/07/2023
Comp. Dt. : 18/06/2022 Status : Completed								
66	22060673*	Pulmonary Medicine	Need scaffolding work at 2nd floor G wing - outer side of pulmo opd for plumbing purpose	Praveen Kumar. K.	Scaffolding work done.		Praveen Kumar. K. - Civil - Execution	18/06/2022
Comp. Dt. : 30/06/2022 Status : Completed								
67	22061138	MEDICAL COLLEGE LIBRARY	Need to arrest water leakage in wall cracks	Sasikala. P.	Touchup work completed.		Sasikala. P. - Civil - Execution	30/06/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
68	22061140	MEDICAL COLLEGE	3rd floor - Existing damaged tiles to be replaced in skill lab	Sasikala. P.	New tiles replaced.		Sasikala. P. - Civil - Execution	30/06/2022
	Comp. Dt. : 09/07/2022 Status : Completed							
69	22070397	Casualty	Need to paint entrance false ceiling and recovery room for inspection work	Sasikala. P.	Paint work completed		Sasikala. P. - Civil - Execution	13/07/2022
	Comp. Dt. : 22/07/2022 Status : Completed							
70	22070839	PICU & NICU	Angle Fitting work	Praveen Kumar. K.	Angle fitting work done		Praveen Kumar. K. - Civil - Execution	22/07/2022
	Comp. Dt. : 06/09/2022 Status : Completed							
71	22090208	PICU & NICU	South side - Common toilet outer door - gas pipeline work	Praveen Kumar. K.	Scaffolding work done.		Praveen Kumar. K. - Civil - Execution	06/09/2022
72	22090226	PICU & NICU	Need scaffolding work for cleaning all the windows in NICU / PICU.	Praveen Kumar. K.	Scaffolding work completed.		Praveen Kumar. K. - Civil - Execution	06/09/2022
	Comp. Dt. : 19/09/2022 Status : Completed							
73	22090755	PICU & NICU	Need scaffolding for window cleaning and sealant applying work.	Praveen Kumar. K.	Scaffolding work done		Praveen Kumar. K. - Civil - Execution	19/09/2022
	Comp. Dt. : 24/09/2022 Status : Completed							
74	22090988	PICU & NICU	Need carpenter to fix the duct door in common toilet	Praveen Kumar. K.	Duct door provided.		Praveen Kumar. K. - Civil - Execution	24/09/2022
	Comp. Dt. : 30/09/2022 Status : Completed							
75	22091235	PICU & NICU	Need to lay floor tiles at common toilet at 2nd floor NICU / PICU	Praveen Kumar. K.	Floor tiles laying work completed.		Praveen Kumar. K. - Civil - Execution	30/09/2022
	Comp. Dt. : 10/10/2022 Status : Completed							
76	22100240	Boys hostel Phase-II	Need scaffolding for crack filling work in outer side.	Sasikala. P.	Scaffolding work done at front side of Boys hostel phase II		Murugan.N. - Civil - Execution	19/10/2022
77	22100241	Boys hostel Phase-II	Need to fill the crack with crack powder.	Sasikala. P.	Work completed		Murugan.N. - Civil - Execution	20/07/2023


Dr. KAGNE. R.N.
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 18/10/2022								
Status : Completed								
78	22100598	Hospital	Sealant to be applied at Main Portigo	Praveen Kumar. K.	Silicon sealant applying work completed.		Murugan.N. - Civil - Execution	25/10/2022
Comp. Dt. : 29/10/2022								
Status : Completed								
79	22100980	COMMERCIAL BLOCK	NEED TO PAINT AT DINING AREA - 1ST FLOOR COMMERCIAL BLOCK	Rajendiran. K.	Painting work completed		Praveen Kumar. K. - Civil - Execution	20/07/2023
80	22100981	COMMERCIAL BLOCK	NEED TO PAINT AT DINING AREA @ 1ST FLOOR STAFF CANTEEN	Praveen Kumar. K.	Scrubbing and touch up putty work completed.		Murugan.N. - Civil - Execution	20/07/2023
Comp. Dt. : 23/11/2022								
Status : Completed								
81	22111000	D-WING OUTER	Need scaffolding work for wall crack filling work.	Praveen Kumar. K.	Scaffolding work done for crack filling work.		Praveen Kumar. K. - Civil - Execution	23/11/2022
Comp. Dt. : 25/11/2022								
Status : Completed								
82	22111122	D-WING OUTER	Need scaffolding work at D wing outer for crack filling work at Specialty OT	Praveen Kumar. K.	Scaffolding work done at D wing east side upto 1st floor for crack filling work.		Praveen Kumar. K. - Civil - Execution	25/11/2022
Comp. Dt. : 06/12/2022								
Status : Completed								
83	22120264	professor quarters-DEAN SIR HOUSE	Need scaffolding upto Terrace for civil work.	Sasikala. P.	Scaffolding raised upto Terrace at south side for civil work.		Sasikala. P. - Civil - Execution	06/12/2022
Comp. Dt. : 20/12/2022								
Status : Completed								
84	22120918	PICU & NICU	Need to apply sealant in Additional ICU	Sivamurugan. M	Silicon sealant applied.		Sivamurugan. M - Civil - Execution	20/12/2022
Comp. Dt. : 24/12/2022								
Status : Completed								
85	22121133	BASEMENT	Room no.13 (X-ray 800 mA), existing floor tiles to be demolished and replaced with new tiles for ins	Praveen Kumar. K.	Floor breaking work completed.		Praveen Kumar. K. - Civil - Execution	04/01/2023
Comp. Dt. : 30/12/2022								
Status : Completed								
86	22121377	Main Gate	Need to paint at Maingate parapet wall.	Praveen Kumar. K.	Painting work completed		Sivamurugan. M - Civil - Execution	20/07/2023

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 02/01/2023 Status : Completed								
87	23010057	professor quarters	Need Scaffolding work at Professor Quarters backside for crack filling work.	Sasikala. P.	Scaffolding work at backside of proffessor quarters for crack filling work.		Rajendiran. K. - Civil - Execution	05/01/2023
88	23010058	HOSPITAL TERROUS	Need scaffolding at Terrace for fixing polycarbonate sheet.	Praveen Kumar. K.	Scaffolding work done at East side and central atrium		Praveen Kumar. K. - Civil - Execution	20/07/2023
Comp. Dt. : 28/01/2023 Status : Completed								
89	23011032	HOSPITAL TERROUS	Need crack filling work at Terrace columns.	Praveen Kumar. K.	Crack filling work done		Praveen Kumar. K. - Civil - Execution	20/07/2023
Comp. Dt. : 07/02/2023 Status : Completed								
90	23020250	HOSPITAL TERROUS	Need to apply metal paste at Atrium and glass to be cleaned.	Praveen Kumar. K.	Metal paste applied at West Atrium and glass cleaning work done.		Praveen Kumar. K. - Civil - Execution	07/02/2023
Comp. Dt. : 18/02/2023 Status : Completed								
91	23020723	HOSPITAL TERROUS	NEED TO APPLY SILICON SEALANT FOR ALL THE WINDOWS IN TERRACE	Praveen Kumar. K.	SILICON SEALANT APPLIED AT ALL THE WINDOWS IN TERRACE.		Praveen Kumar. K. - Civil - Execution	18/02/2023
Dept Name : Civil - Maintenance - Civil - Execution Comp. Dt. : 01/06/2022 Status : Completed								
92	22060035	Pulmonary Medicine	Need scaffolding for plumbing work in between F wing and G wing	Praveen Kumar. K.	Scaffolding work completed.		Prakash. V. - Civil - Maintenance	01/06/2022
Comp. Dt. : 01/08/2022 Status : Completed								
93	22080040	SPECIAL OPD	Need breaker for breaking chamber at Main portigo	Praveen Kumar. K.	Breaker work done		Sankar. R - Civil - Maintenance	01/08/2022
94	22080048	BOYS HOSTEL MESS	Need breaker for breaking chamber at boy's hostyel back side.	Sasikala. P.	Breaking work completed		Sankar. R - Civil - Maintenance	01/08/2022
Comp. Dt. : 05/08/2022 Status : Completed								
95	22080209	DIRECTOR QUATERS	Need to construct drainage chamber at North side of Director quarters	Sasikala. P.	Chamber construction work completed.		Sankar. R - Civil - Maintenance	20/08/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 08/08/2022 Status : Completed								
96	22080282	MEDICAL COLLEGE 2ND FLOOR	NEED BREAKER FOR BREAKING WORK AT II FLOOR COMMON RESTROOM	Sasikala. P.	Breaker work complaint		Sankar. R - Civil - Maintenance	20/07/2023
Comp. Dt. : 10/08/2022 Status : Completed								
97	22080353	Hospital	NEED TO RAISE CHAMBER - BACK SIDE OF I V F	Sasikala. P.	Chamber raising work completed		Gurunathan. V. - Civil - Maintenance	20/07/2023
Comp. Dt. : 14/09/2022 Status : Completed								
98	22090530	Animal House	Need to raise chamber at animal house	Sasikala. P.	Chamber raising work completed		Gurunathan. V. - Civil - Maintenance	20/07/2023
Comp. Dt. : 10/10/2022 Status : Completed								
99	22100242	Animal House	Need to raise the chamber level upto road level.	Sasikala. P.	Chamber raising work completed.		Gurunathan. V. - Civil - Maintenance	25/10/2022
Comp. Dt. : 07/11/2022 Status : Completed								
100	22110192	MEDICAL COLLEGE OPP FOUNTAIN	Need breaker work for laying pipeline at fountain area.	Murugan.N.	Breaking work done at fountain area for plumbing work.		Sivaraja. M. - Civil - Maintenance	07/11/2022
Comp. Dt. : 08/11/2022 Status : Completed								
101	22110271	HOSPITAL BACKSIDE-SUMP	Need to raise chamber at hospital backside near sump.	Praveen Kumar. K.	Chamber raising work completed		Prakash. V. - Civil - Maintenance	20/07/2023
Comp. Dt. : 06/01/2023 Status : Completed								
102	23010286*	Ladies hostel Phase-I	NEED MASION WORK(UPS PIPE)	Sasikala. P.	MATERIAL SHIFTING, BRICK WORK AND PLASTERING WORK COMPLETED.		Sankar. R - Civil - Maintenance	22/02/2023
Comp. Dt. : 07/02/2023 Status : Completed								
103	23020222	ASSOCIATIVE PROFESSOR QUARTERS	NEED TO REFIX TILES FOR QUARTERS NO 4 & 12	Sasikala. P.	Tiles laying work completed at room no.12. and Room no.4	 Dr. KAGNE. R.N DEAN SRI MANAKULA VINAYAGAR MEDICAL COLLEGE & HOSPITAL KALITHEERTHAL KUPPAM, PUDUCHERRY-605107.	Sankar. R - Civil - Maintenance	25/02/2023
Comp. Dt. : 08/04/2023								

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
104	23040257	MEDICAL COLLEGE	NEED BREAKER FOR DEMOLISHING THE PCC ROAD, BACK SIDE TO DISSECTION HALL	Praveen Kumar. K.	PCC ROAD DEMOLISHING WORK COMPLETED.		Sankar. R - Civil - Maintenance	08/04/2023
Comp. Dt. : 22/04/2023								
Status : Completed								
105	23040715	Surgery OPD	EXISTING CHAMBER LEVEL TO BE RAISED AT BACKSIDE OF SURGERY OPD	Sasikala. P.	Chamber raising work completed.		Gurunathan. V. - Civil - Maintenance	29/04/2023
Comp. Dt. : 23/06/2023								
Status : Completed								
106	23060876	JR Quarters	DUE TO WATER LEAKAGE - NEED POINTING WORK AT I , II & III FLOOR	Praveen Kumar. K.	All floor East and West side common toilet pointing work completed		Sankar. R - Civil - Maintenance	07/08/2023
Dept Name : Computer Department - Civil - Execution								
Comp. Dt. : 10/05/2022								
Status : Completed								
107	22050345	Nursing Office	NEED DIG HOLE FOR CAMERA FIXING WORK AT OPP TO NURSING COLLEGE	Sasikala. P.	Earth pit work completed		Prakash. P. - Computer Department	20/07/2023
Dept Name : Director Office - Civil - Execution								
Comp. Dt. : 23/06/2022								
Status : Completed								
108	22060837*	A.P Quateres	NEED TO FIX RESTROOM WALL TILES FOR QUARTERS NO 30	Sasikala. P.	Wall tiles laid at room no.30		Mani. A. - Director Office	01/07/2022
Comp. Dt. : 09/07/2022								
Status : Completed								
109	22070386	A.P Quateres	REST ROOM WALL TILLES BROEKN - NEED TOUCH UP WORK AT QUARTERS NO 41	Sasikala. P.	Wall tiles laying work done		Mani. A. - Director Office	18/07/2022
Comp. Dt. : 17/03/2023								
Status : Assigned								
110	23030703	A.P Quateres	WATER TANK OUTSIDE WALL CRACK - NEED TO BE RECTIFY	Sasikala. P.			Mani. A. - Director Office	
Comp. Dt. : 08/05/2023								
Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
111	23050317	A.P Quateres	WALL PLASTERING WORK NEED AT QUARTERS NO 25	Sasikala. P.	Wall plastering work done		Mani. A. - Director Office	04/11/2023
112	23050318	ASSOCIATIVE PROFESSOR QUARTERS	NEED CHAMBER BRICK WORK - QUARTERS BACK SIDE	Sasikala. P.	Chamber raising work completed		Mani. A. - Director Office	20/07/2023
Comp. Dt. : 10/06/2023 Status : Completed								
113	23060362	A.P Quateres	NEED PLASTERING WORK FOR QUARTERS NO 52, 53 & 56	Sasikala. P.	Plastering work completed		Mani. A. - Director Office	20/07/2023
Dept Name : Electrical Maintenance - Civil - Execution Comp. Dt. : 25/07/2022 Status : Completed								
114	22070928*	HOSPITAL CAMPUS	NEED ELECTRICAL EARTH WORK 6" INCHES EARTH BORING WORK FOR or NEED MANPOWER 2 NOS	Sasikala. P.	Earth work done.		Vaithianathan.M - Electrical Maintenance	05/08/2022
Comp. Dt. : 23/05/2023 Status : Completed								
115	23050938	HOSPITAL TERROUS	NEED TO CHECK CHANGE GRANITE AT HOSPITAL TERROUS - NEAR LIFT NEED URGENT SERVICE & EMERGENCY	Praveen Kumar. K.	Workl completed		Angappan. A. - Electrical Maintenance	20/07/2023
Dept Name : ENT & Ophthal Ward - Civil - Execution Comp. Dt. : 18/10/2022 Status : Completed								
116	22100582	ENT WARD-407	NEED TO CHECK TREATMENT ROOM DOOR NEAR WALL - DAMAGE & BROKEN	Praveen Kumar. K.	Work shop complaint		Jayalakshmi. J. - ENT & Ophthal Ward	20/07/2023
Dept Name : Housekeeping - Civil - Execution Comp. Dt. : 01/08/2022 Status : Completed								
117	22080002	Polytechnic college	NEED A PIT FOR POLYTECHNIC SOUTH SIDE	Sasikala. P.	Work completed on 07.8.2022		Naresh. R - Housekeeping	08/08/2022
Comp. Dt. : 22/11/2022 Status : Completed								
118	22110923	Reception	GLASS DOOR STUCK AT RECEPTION MAIN DOOR	Murugan.N.	Work completed		Elangchezhiyan. R. - Housekeeping	20/07/2023

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 06/02/2023 Status : Completed								
119	23020204	BIOMEDICAL WASTAGE ROOM - BACKSIDE OF ORTHO OPD	NEED REPAIRING WORK FOR BROKEND WALL	Praveen Kumar. K.	Work completed		Elangchezhiyan. R. - Housekeeping	20/07/2023
Dept Name : MS Office - Civil - Execution Comp. Dt. : 18/10/2022 Status : Completed								
120	22100586	HOSPITAL GROUND FLOOR H-WING	STAIRCASE MARBLES BROKEN AT MAIN PORTICO	Praveen Kumar. K.	Work completed		Sundarrajan. R. - MS Office	20/07/2023
Dept Name : Nursing Office - Civil - Execution Comp. Dt. : 02/03/2023 Status : Completed								
121	23030085	POW & SICU	NEED TO CHECK FALSE CEILING - WATER LEAKAGE - REPEAT COMPLAINT - NEED URGENT SERVICE	Praveen Kumar. K.	Expansion joint treatment should be done		Greeta Guna Seelan - Nursing Office	20/07/2023
Dept Name : OPD - Civil - Execution Comp. Dt. : 31/12/2022 Status : Completed								
122	22121395	IVF ART CLINIC-INSIDE OF OG OPD(NO.68)	IN SAMPLE COLLECTION ROOM-FALSE CEILING GOT DOWN	Praveen Kumar. K.	Work completed		Rajasekari. R. - OPD	20/07/2023
Dept Name : Operation Theatre - Civil - Execution Comp. Dt. : 31/05/2023 Status : Completed								
123	23051243	SPECIALITY OT	NEED TO CHANGE SCRUB AREA DOOR HANDLE - BROKEN	Praveen Kumar. K.	Work completed		Sobiya. N. - Operation Theatre	20/07/2023
Dept Name : Pharmacy - Civil - Execution Comp. Dt. : 14/05/2022 Status : Completed								
124	22050492	Pay Pharmacy	CEILING WATER LEAKAGE PROBLEM	Praveen Kumar. K.	Work completed		Selvan. A. - Pharmacy	20/07/2023
Dept Name : PICU & NICU - Civil - Execution Comp. Dt. : 06/06/2023 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
125	23060178	NICU	NEED REPAIRING WORK FOR DOOR - REPEAT COMPLAINT [NEW NICU]	Praveen Kumar. K.	Work completed		Sarumathi. A. - PICU & NICU	20/07/2023
Dept Name : Power Laundry - Civil - Execution Comp. Dt. : 27/07/2022 Status : Completed								
126	22071027	LAUNDRY	Need to construct ramp infront of laundry entrance	Sasikala. P.	Ramp construction work completed.		Manikandan.M - Power Laundry	04/08/2022
Dept Name : Printing Press - Civil - Execution Comp. Dt. : 17/12/2022 Status : Completed								
127	22120821	COW SHED	MOSQUITO KILLER SPRAY NEED TO USE	Praveen Kumar. K.	Civil maintenance complaint		Shanmugam. R. - Printing Press	20/07/2023
Dept Name : Special Ward - Civil - Execution Comp. Dt. : 24/11/2022 Status : Completed								
128	22111023	SPECIAL WARD A1-FOURTH FLOOR	FALSE CEILING NEED TO BE CLOSE NEAR NURSES CABIN	Praveen Kumar. K.	Work shop complaint		Manjula. R. - Special Ward	20/07/2023
Work Type : Work Dept Name : Air Condition Department - Civil - Execution Comp. Dt. : 11/06/2022 Status : Completed								
129	22060433	Ladies hostel Phase-I	NEED SCAFFOLDING WORK FROM GROUND FLOOR TO IV FLOOR TERRACE	Sasikala. P.	Scaffolding work completed.		Babu. D. - Air Condition Department	18/06/2022
Comp. Dt. : 12/07/2022 Status : Completed								
130	22070482	CHILDREN'S PARK	NEED SCAFFOLDING WORK FOR AC FIXING WORK AT CHILDREN'S PARK TO II FLOOR CARDIOLOGY OPD	Sasikala. P.	Scaffolding work done		Babu. D. - Air Condition Department	21/07/2022
Comp. Dt. : 12/08/2022 Status : Completed								
131	22080439	MIT Auditorium	NEED SCAFFOLDING WORK FOR AC FIXING AT BACK SIDE OF MECHANICAL BLOCK	Sasikala. P.	Scaffolding work completed		Babu. D. - Air Condition Department	20/07/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 21/09/2022 Status : Completed								
132	22090817	HOSPITAL G WING	NEED SCAFFOLDING WORK FROM GROUND FLOOR TO TERRACE , FOR AC FIXING WORK - FOR III FLOOR DEMO ROOM	Praveen Kumar. K.	Scaffolding work done		Babu. D. - Air Condition Department	23/09/2022
Comp. Dt. : 06/02/2023 Status : Completed								
133	23020162	CHILDREN'S PARK	NEED SCAFFOLDING WORK AT [CHILDREN'S PARK AREA] - BACKSIDE OF CHAIRMAN OFFICE	Praveen Kumar. K.	Work completed		Panneer Selvam. P. - Air Condition Department	20/07/2023
Comp. Dt. : 29/03/2023 Status : Completed								
134	23031248	Hospital	NEED SCAFFOLDING WORK AT HOSPITAL II FLOOR TO IV FLOOR [BACKSIDE OF AO OFFICE]	Praveen Kumar. K.	Work completed		Panneer Selvam. P. - Air Condition Department	20/07/2023
Dept Name : Civil - Execution - Civil - Execution Comp. Dt. : 14/06/2022 Status : Completed								
135	22060535	MEDICAL COLLEGE	NEED SCAFFOLDING WORK TO RECTIFY CROCK IN MEDICAL COLLEGE WEST SIDE	Sasikala. P.	Work completed		Sasikala. P. - Civil - Execution	20/07/2023
Comp. Dt. : 30/06/2022 Status : Completed								
136	22061126	Civil - Execution	NEED CIVIL LABOUR FOR CIVIL SKILL LAB ARRANGEMENT WORK AT SMVMCH III FLOOR	Sasikala. P.	Civil maintenance complaint		Praveen Kumar. K. - Civil - Execution	20/07/2023
Comp. Dt. : 22/05/2023 Status : Completed								
137	23050882	professor quarters	Room No:7 - Need to be fix Kadappa slap in bedroom	Sasikala. P.	Kadappa slab fixed.		Murugan.N. - Civil - Execution	20/07/2023
Dept Name : Civil - Maintenance - Civil - Execution Comp. Dt. : 01/06/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
138	22060042	Dialysis	Need breaker for Dialysis backside - I Floor (ceiling leakage problem)	Praveen Kumar. K.	Breaker work completed		Gurunathan. V. - Civil - Maintenance	20/07/2023
Comp. Dt. : 12/09/2022 Status : Completed								
139	22090464	Casualty	NEED TO BUILT A NEW CHAMBER AT CASUALTY SIDE	Sasikala. P.	Chamber constructing work completed.		Gurunathan. V. - Civil - Maintenance	21/09/2022
140	22090465	Nursing College	NEED TO BUILT A NEW CHAMBER AT NURSING COLLEGE SIDE	Sasikala. P.	chamber raising work completed		Gurunathan. V. - Civil - Maintenance	20/07/2023
Comp. Dt. : 05/10/2022 Status : Completed								
141	22100054	MEDICAL COLLEGE PUMP HOUSE	NEED SAND LEVELING WORK AT OPP TO PUMP HOUSE - MEDICAL COLLEGE RIGHT SIDE	Sasikala. P.	Work completed		Kumar. V. - Civil - Maintenance	20/07/2023

College Name : SMVNC

Work Type : Complaint

Dept Name : Civil - Execution - Civil - Execution

Comp. Dt. : 18/05/2022

Status : Completed

142	22050656	Nursing College	NEED TO FIX TILES FOR GROUND & III FLOOR COOLER CHAMBER	Sasikala. P.	Tile laying work completed		TAMILPULAVENDRAN - SMVNC	20/07/2023

College Name : SMVPT

Work Type : Complaint

Dept Name : Civil - Execution - Civil - Execution

Comp. Dt. : 27/06/2023

Status : Completed

143	23061034	Polytechnic college	NEED BREAKER WORK FOR DUCT STEEL DOOR AT GROUND FLOOR	Sasikala. P.	Breaker work completed		SANTHANAM - SMVPT	20/07/2023

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.



Sri Manakula Vinayagar Medical College and Hospital

Complaint Status Report From 01-05-2022 To 30-06-2023

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
College Name : MIT								
Work Type : Complaint								
Dept Name : Computer Department - Computer Department								
Comp. Dt. : 02/05/2022								
Status : Completed								
1	22050062	MIT College	Autocad need to install for project Manager system	Selvam. D.	autocad installed		BASKAR - MIT	02/05/2022
Comp. Dt. : 02/03/2023								
Status : Completed								
2	23030061	Mit ladies hostel	PROBLEM IN WI FI CONNECTION	Balachandar. A.	POWER MANAGER CHANGED		AROKIAMARY - MIT	04/03/2023
College Name : Others								
Work Type : Complaint								
Dept Name : Computer Department - Computer Department								
Comp. Dt. : 12/05/2022								
Status : Completed								
3	22050435	B.ED COLLEGE	CHNAGE PRINTER TONER	Jayaraj. J.	toner changed		SRIMAN - Others	13/05/2022
Comp. Dt. : 19/08/2022								
Status : Completed								
4	22080651	Indbazaar - Tnagar	KVMS pro software install	Prakash. P.	KVMPs pro configured		SELVAM - Others	20/08/2022
Comp. Dt. : 05/10/2022								
Status : Completed								
5	22100076	HERBAL HEALTHCARE COMPANY	SYSTEM NOT WORKING	Selvam. D.	SATA CABLE REFIXED WORKING FINE..		SUDHASANKAR - Others	06/10/2022
Comp. Dt. : 21/10/2022								
Status : Completed								
6	22100725	B.ED COLLEGE	SYSTEM NOT WORKING-2301	Jayaraj. J.	SYSTEM POWER CABLE REFIXED		VENKATESAN - Others	21/10/2022
Comp. Dt. : 03/11/2022								
Status : Completed								
7	22110067	B.ED COLLEGE	IN PRINCIPAL ROOM-SYSTEM NETWORK ISSUE	Selvam. D.	principal room network solved		SRIMAN - Others	04/11/2022

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 04/01/2023 Status : Completed								
8	23010136	B.ED COLLEGE	NEED TO CHANGE PRINTER TONER - (B.ED OFFICE ROOM)	Selvam. D.	88A toner changed		SRIMAN - Others	04/01/2023
Comp. Dt. : 25/02/2023 Status : Completed								
9	23020986	Nursing College	nitro pdf to be install	Balachandar. A.	nitro pdf installed		kiruba - Others	25/02/2023
Comp. Dt. : 18/03/2023 Status : Completed								
10	23030749	indnazar pondy	Printer not working	Selvam. D.	Teflon sleeve changed		Tamiloli - Others	18/03/2023
Comp. Dt. : 06/06/2023 Status : Completed								
11	23060196	indnazar pondy	SYSTEM HANGS	Selvam. D.	hard disk health issue so replaced 1tb hard disk changed		TAMILOLI - Others	06/06/2023
Comp. Dt. : 28/06/2023 Status : Completed								
12	23061043	UHC Villupuram	mouse not working	Shafiullah. R.	USB MOUSE CHANGED		asithambi - Others	28/06/2023

College Name : SMVMCH

Work Type : Complaint

Dept Name : Administration - Computer Department

Comp. Dt. : 10/06/2022

Status : Completed

13	22060382	AO Office	toner need to change	Selvam. D.	12A toner changed		Kanimozhi. D. - Administration	10/06/2022
14	22060383	AO Office	toner need to change	Selvam. D.	b201 toner changed		Gunavathi. S. - Administration	10/06/2022

Comp. Dt. : 24/06/2022

Status : Completed

15	22060877	OSD	system getting slow	Selvam. D.	NEW HARD DISK FIXING , 8 GB RAM UPGRADE PRINTER INSTALL AND FIXING PROBLEM SLOVED		Sugumaran. P. - Administration	24/06/2022

Comp. Dt. : 01/07/2022

Status : Completed

16	22070048	AO Office	speaker not working	Selvam. D.	NEW SPEAKER INSTALLED		Krishnasamy. K - Administration	02/07/2022

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
	Comp. Dt. :	21/07/2022						
	Status :	Completed						
17	22070813	Administration	MOUSE NOT WORKING	Murugavel.R	New usb mouse changed		Shyamala. R. - Administration	22/07/2022
	Comp. Dt. :	24/08/2022						
	Status :	Completed						
18	22080810	AO Office	system no power on	Balachandar. A.	smpls problem,new smpls changed		Karthikeyan.T. - Administration	25/08/2022
	Comp. Dt. :	07/09/2022						
	Status :	Completed						
19	22090289	AO Office	PROBLEM IN SYSTEM	Jayaraj. J.	WORKING FINE		Elumalai.K.A. - Administration	07/09/2022
	Comp. Dt. :	04/11/2022						
	Status :	Completed						
20	22110117	AO Office	Paper jam	Selvam. D.	Paper jam cleared		Gunavathi. S. - Administration	04/11/2022
	Comp. Dt. :	24/12/2022						
	Status :	Completed						
21	22121128	1st floor	SYSTEM AUTO SHUTDOWN PROBLEM	Jayaraj. J.	SYSTEM CPU FAN REPLACED		Shyamala. R. - Administration	24/12/2022
	Comp. Dt. :	06/01/2023						
	Status :	Completed						
22	23010277	AO Office	color printer not working	Shafiullah. R.	AIR LOCKED RELEASED WORKING FINE		Senthil Murugan.K. - Administration	09/01/2023
	Comp. Dt. :	28/01/2023						
	Status :	Completed						
23	23011019	AO Office	PRINTER PAPAER JAM	Selvam. D.	Setting done		Nitheeshkumar. D. - Administration	28/01/2023
	Comp. Dt. :	06/02/2023						
	Status :	Completed						
24	23020166	AO Office	BLACK INK NEED TO FILL	Selvam. D.	black ink filled		Muthukrishnan. S. - Administration	06/02/2023
	Comp. Dt. :	17/02/2023						
	Status :	Completed						
25	23020674	AO Office	Monitor not working	Balachandar. A.	New acer 22 inch monitor changed..		Roopa. S. - Administration	17/02/2023
26	23020690	AO Office	SYSTEM SLOW	Balachandar. A.	O/S INSTALLED		Nitheeshkumar. D. - Administration	17/02/2023

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 24/02/2023 Status : Completed								
27	23020940	AO Office	New system to be connect	Balachandar. A.	new system connected..		Senthil Murugan.K. - Administration	24/02/2023
28	23020957	AO Office	PRINTER PROBLEM	Jayaraj. J.	PRINTER HEAD CLEANED		Sankardevi. G. - Administration	24/02/2023
Comp. Dt. : 21/03/2023 Status : Completed								
29	23030848	AO Office	monitor not working	Balachandar. A.	new acer 21.5 monitor cahnged.		Kavitha. P. - Administration	22/03/2023
Comp. Dt. : 05/04/2023 Status : Completed								
30	23040169	AO Office	BROTHER TONER NEED TO CHANGE	Selvam. D.	BROTHER TONER CHANGED		Kanimozhi. D. - Administration	05/04/2023
Comp. Dt. : 04/05/2023 Status : Completed								
31	23050169	AO Office	printer problem	Selvam. D.	Carriage pully refixed		Muthukrishnan. S. - Administration	04/05/2023
Comp. Dt. : 03/06/2023 Status : Completed								
32	23060094	CASHCOUNTER IN RECEPTION	HRM SOFTWARE INSATLL IN AO OFFICE CASHIER ROOM	Raja.B	HRM SOFTWARE INSTALLED		Muthukrishnan. S. - Administration	03/06/2023
Comp. Dt. : 08/06/2023 Status : Completed								
33	23060301	AO Office	printer problem	Selvam. D.	BLACK INK FILLED		Senthil Murugan.K. - Administration	08/06/2023
34	23060302	AO Office	cash counter printer setting problem	Selvam. D.	PRINTER SETTING CHANGED		Muthukrishnan. S. - Administration	08/06/2023
Comp. Dt. : 09/06/2023 Status : Completed								
35	23060345	AO Office	bsnl bill web page not open	Raja.B	sonic wall locke released		Sankardevi. G. - Administration	09/06/2023
Comp. Dt. : 14/06/2023 Status : Completed								
36	23060507	AO Office	PRINTER PROBLEM	Balachandar. A.	INK FLUSH NOW WORKING		Senthil Murugan.K. - Administration	14/06/2023
Dept Name : Audit Wing - Computer Department Comp. Dt. : 11/05/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
37	22050401	AO Office	INTERNET NOT WORKING	Balachandar. A.	SETTINGS CHANGED..		Sadhasivam. A. - Audit Wing	11/05/2022
	Comp. Dt. : 27/06/2022							
	Status : Completed							
38	22060983	AO Office	keyboard hard to type	Selvam. D.	new USB Keyboard Changed		Hari Ram Singh. B. - Audit Wing	28/06/2022
	Dept Name : BIOCHEMISTRY - Computer Department							
	Comp. Dt. : 10/08/2022							
	Status : Completed							
39	22080390	Reception	counter 8 toner change	Selvam. D.	12a TONER CHANGED		Srinivasamurugan. V. - BIOCHEMISTRY	11/08/2022
	Comp. Dt. : 22/09/2022							
	Status : Completed							
40	22090876	Blood Collection Centre	NEED TO CHANGE BARCODE STRICKER	Shafiullah. R.	BARCODE STRICKER CHANGED		Srinivasamurugan. V. - BIOCHEMISTRY	22/09/2022
	Comp. Dt. : 19/10/2022							
	Status : Completed							
41	22100638	Biochemistry Lab-Hospital	12A TONER CHANGE	Shafiullah. R.	12A TONER CHANGED		Srinivasamurugan. V. - BIOCHEMISTRY	19/10/2022
	Comp. Dt. : 09/11/2022							
	Status : Completed							
42	22110325	Reception	Counter 6 mouse not working	Selvam. D.	New usb keyboard changed.		Srinivasamurugan. V. - BIOCHEMISTRY	09/11/2022
	Comp. Dt. : 28/12/2022							
	Status : Completed							
43	22121259	Blood Collection Centre	need bar code sticker	Selvam. D.	Revisit sticker changed		Srinivasamurugan. V. - BIOCHEMISTRY	28/12/2022
	Comp. Dt. : 02/02/2023							
	Status : Completed							
44	23020069	BIOCHEMISTRY-- -COLLEGE	System no power	Selvam. D.	smps changed		Asmathulla. S. - BIOCHEMISTRY	03/02/2023
	Comp. Dt. : 07/03/2023							
	Status : Completed							
45	23030285	BIOCHEMISTRY-- -COLLEGE	PRINTER GADGET PROBLEM	Madhubalan. S.	88A toner changed		Suganthi. P. - BIOCHEMISTRY	08/03/2023
	Comp. Dt. : 05/05/2023							
	Status : Completed							


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
46	23050186	Biochemistry Lab-Hospital	system not booting	Selvam. D.	Hard disk cable refixed		Srinivasamurugan. V. - BIOCHEMISTRY	05/05/2023
Comp. Dt. :		29/05/2023						
Status :		Completed						
47	23051159	Blood Collection Centre	NEED TO CHANGE BARE CODE STRICKER	Harikrishnan. R.	Revisit Sticker Changed.		Srinivasamurugan. V. - BIOCHEMISTRY	29/05/2023
Comp. Dt. :		01/06/2023						
Status :		Completed						
48	23060037	College - Biochemistry	windwos 10 update office system	Harikrishnan. R.	WINDOW 10 INSTALL MS OFFICE 16 INSTALLED		Kulkarni Sweta - BIOCHEMISTRY	01/06/2023
Dept Name :		Blood Collection Centre - Computer Department						
Comp. Dt. :		13/05/2022						
Status :		Completed						
49	22050483	Reception	COUNTER 8 SYSTEM PROBLEM	Jayaraj. J.	SYSTEM SETTING CHANGED		Sangeetha. P. - Blood Collection Centre	13/05/2022
Comp. Dt. :		02/09/2022						
Status :		Completed						
50	22090060	Reception	printer problem(lab report)	Selvam. D.	TONER REFIXED WORKING FINE		Kasthuribai. J. - Blood Collection Centre	02/09/2022
Comp. Dt. :		06/10/2022						
Status :		Completed						
51	22100124	Reception	counter 8 printer paper jam	Selvam. D.	Teflon sleeve replaced		Kasthuribai. J. - Blood Collection Centre	06/10/2022
Comp. Dt. :		07/06/2023						
Status :		Completed						
52	23060244	lab report issuing counter 8 in reception	PRINTER NOT WORKING	Shafiullah. R.	PRINTER SETUP REINSTALLED		Sangeetha. P. - Blood Collection Centre	07/06/2023
Dept Name :		Canteen - Boys Hostel - Computer Department						
Comp. Dt. :		07/11/2022						
Status :		Completed						
53	22110258	Boys hostel	SYSTEM SOFTWARE ISSUE	Balachandar. A.	NETWORK NOT RESOLVE,OS REINSTALLED.		Kesavaraj. P. - Canteen - Boys Hostel	08/11/2022
Comp. Dt. :		23/12/2022						
Status :		Completed						
54	22121071	Boys hostel	SOFTWARE PROBLEM	Selvam. D.	IP ADDRESS GIVEN WORKING		Kesavaraj. P. - Canteen - Boys Hostel	26/12/2022

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 24/12/2022 Status : Completed								
55	22121117	Boys hostel	SYSTEM NOT WORKING	Selvam. D.	DOUBLE ENTRY		Anand. G. - Transport	26/12/2022
Comp. Dt. : 04/03/2023 Status : Completed								
56	23030192	Boys hostel	MONITOR PROBLEM	Jayaraj. J.	MONITOR CHANGED		Sambasivam. K. - Canteen - Boys Hostel	04/03/2023
Comp. Dt. : 24/05/2023 Status : Completed								
57	23050963	BOY HOSTEL MESS	PRINTER NOT WORKING	Prakash. P.	12A TONER CHANGED		Elumalai. M. - Canteen - Boys Hostel	25/05/2023
Dept Name : Canteen - Hospital - Computer Department Comp. Dt. : 12/12/2022 Status : Completed								
58	22120532	DIET DEPARMENT	IN STORE -SYSTEM NOT WORKING	Jayaraj. J.	SYSTEM WORKING		Suriyaprakash. R. J. - Canteen - Hospital	12/12/2022
Dept Name : Canteen-Girls Hostel - Computer Department Comp. Dt. : 19/12/2022 Status : Completed								
59	22120837	JR Quarters	CAMERA NOT WORKING IN ENTRANCE	Valamburi. R.	IP CHANGED WORKING FINE		Virgin Mary - Canteen-Girls Hostel	24/12/2022
Dept Name : CARDIOLOGY - Computer Department Comp. Dt. : 22/07/2022 Status : Completed								
60	22070828	CARDIOLOGY OPD	system not working	Balachandar. A.	monitor power cable refixed		Ashida. T. S. - CARDIOLOGY	22/07/2022
Comp. Dt. : 10/09/2022 Status : Completed								
61	22090412	ECHO CARDIO GRAM	printer not work	Shafiullah. R.	POWER CABLE UNPLUGE AND FIX		Ramani Palanivel.P. - CARDIOLOGY	10/09/2022
Comp. Dt. : 19/10/2022 Status : Completed								
62	22100640	ECHO CARDIO GRAM	PRINTER CARTRIDGE REPLACE	Prakash. P.	INK REFILL COLOUR CARTRIDGE		Aarthi. A. - CARDIOLOGY	19/10/2022
Comp. Dt. : 13/01/2023 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
63	23010559	ECHO CARDIO GRAM	printer toner need to change	Selvam. D.	12A toner changed		Ramani Palanivel.P. - CARDIOLOGY	13/01/2023
64	23010560	TMT & Echo Department	Paper not pickup	Selvam. D.	pick roller changed.		Ramani Palanivel.P. - CARDIOLOGY	19/01/2023
Dept Name : Cardiothoracic POW - Computer Department Comp. Dt. : 08/03/2023 Status : Completed								
65	23030307	POW & SICU	printer problem	Selvam. D.	teflon sleeve and pressure roller changed		Sathiavani. A. - Cardiothoracic POW	08/03/2023
Dept Name : Civil - Execution - Computer Department Comp. Dt. : 19/08/2022 Status : Completed								
66	22080634	Civil - Execution	NEED NEW UPS	Balachandar. A.	lithium ups changed		Surendhiran. R. - Civil - Execution	29/09/2022
Comp. Dt. : 18/05/2023 Status : Completed								
67	23050740	Civil - Execution	Monitor black shadow problem	Balachandar. A.	New aoc 18.5 monitor installed		Murugan.N. - Civil - Execution	18/05/2023
68	23050742	Civil - Maintenance	Monitor black shadow problem	Balachandar. A.	COMPLIANT DOUBLE ENTRY		Murugan.N. - Civil - Execution	18/05/2023
69	23050743	Civil - Maintenance	MONITOR BLACK SHADOW PROBLEM	Balachandar. A.	New aoc 18.5 monitor installed		Murugan.N. - Civil - Execution	18/05/2023
Dept Name : Clinical Department - Computer Department Comp. Dt. : 26/05/2022 Status : Completed								
70	22050976	CLINICAL DEPARTMENT IN 2ND FLOOR	ups no backup	Balachandar. A.	lithium battery ups changed		Shuruthi. B. - Clinical Department	27/05/2022
Comp. Dt. : 28/06/2022 Status : Completed								
71	22060995	TB & Chest OPD	SYSTEM RESTAR PROBLEM	Murugavel.R	4 GB RAM INCREASED AND DRIVERS UPDATED PROBLEM SLOVED WORKING FINE		Vimal. P. - Clinical Department	28/06/2022
Comp. Dt. : 07/11/2022 Status : Completed								
72	22110198	CLINICAL DEPARTMENT IN 3RD FLOOR	NEED TO CHANGE PRINTER TONER	Balachandar. A.	PRINTER TONER CHANGED..		Manimegalai. M. - Clinical Department	07/11/2022
Comp. Dt. : 18/11/2022 Status : Completed								
73	22110795	CLINICAL DEPARTMENT IN 2ND FLOOR	surgery hod monitor no power on	Shafiullah. R.	acer 21' inch monitor changed		Kheerthikaa. V. - Clinical Department	18/11/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 25/02/2023 Status : Completed								
74	23020985	CLINICAL DEPARTMENT IN 4th FLOOR	New system to be install ophthal dept	Balachandar. A.	new system installed		Vijayalakshmi.N - Clinical Department	25/02/2023
Comp. Dt. : 07/03/2023 Status : Completed								
75	23030256	CLINICAL DEPARTMENT IN 4th FLOOR	system not booting	Balachandar. A.	domain refixed		Suguna. D. - Clinical Department	07/03/2023
Comp. Dt. : 21/03/2023 Status : Completed								
76	23030850	CLINICAL DEPARTMENT IN 3RD FLOOR	ups no backup	Balachandar. A.	ups changed..		Selvi. A. - Clinical Department	22/03/2023
Comp. Dt. : 22/03/2023 Status : Completed								
77	23030901	Paediatrics - OPD	system problem	Selvam. D.	NETWORK USB ADAPTER CHANGED		Manimegalai. M. - Clinical Department	22/03/2023
Comp. Dt. : 28/04/2023 Status : Completed								
78	23040960	CLINICAL DEPARTMENT IN 3RD FLOOR	monitor black shadow problem	Balachandar. A.	new aoc 18.5 monitor changed..		Manimegalai. M. - Clinical Department	29/04/2023
Comp. Dt. : 12/05/2023 Status : Completed								
79	23050518	CLINICAL DEPARTMENT IN 2ND FLOOR	NEED TO CHANGE TONER	Selvam. D.	88A toner changed		Saranya. S. - Clinical Department	12/05/2023
Comp. Dt. : 10/06/2023 Status : Completed								
80	23060358	CLINICAL DEPARTMENT IN 3RD FLOOR	system ms office problem and system slow	Balachandar. A.	os reinstalled and software installed		Sangeetha. C. - Clinical Department	12/06/2023
Dept Name : CLINICAL PATHOLOGY - Computer Department Comp. Dt. : 28/12/2022 Status : Completed								
81	22121257	PATHOLOGY IN COLLEGE	MED PLUS NOT WORKING IN ONE SYSTEM	Madhubalan. S.	system restarted		Vinod Gnana Kumar. D. - CLINICAL PATHOLOGY	29/12/2022
Dept Name : COMMUNITY MEDICINE - Computer Department Comp. Dt. : 20/08/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
82	22080657	COMMUNITY MEDICINE DEPT IN MEDICAL COLLEGE	system no power on	Balachandar. A.	NEW SMPS CHANGED		Kalai Selvan. G. - COMMUNITY MEDICINE	20/08/2022
Dept Name : Computer Department - Computer Department Comp. Dt. : 28/05/2022 Status : Completed								
83	22051065	DIGITAL LAB	DLAB 19 SYSTEM NO POWER ON	Jayaraj. J.	NEW SMPS CHANGED		Jayaraj. J. - Computer Department	30/05/2022
Comp. Dt. : 03/06/2022 Status : Completed								
84	22060141	Computer Department	SMS GET CHECKING MSG	Balachandar. A.	TESTING FINE		Balachandar. A. - Computer Department	03/06/2022
85	22060142	EDP IN UNDERGROUND	TESTING MSG SMS	Balachandar. A.	TESTING FINE		Murugavel.R - Computer Department	03/06/2022
86	22060143	EDP IN UNDERGROUND	TESTING MSG SMS	Shafiullah. R.	TESTING FINE		Balachandar. A. - Computer Department	03/06/2022
87	22060144	EDP IN UNDERGROUND	TESTING MSG SMS	Shafiullah. R.	TESTING FINE		Shafiullah. R. - Computer Department	03/06/2022
Comp. Dt. : 07/06/2022 Status : Completed								
88	22060237	DIGITAL LAB	System problem	Madhubalan. S.	NEW HDD CHANGED		Jayaraj. J. - Computer Department	07/06/2022
Comp. Dt. : 08/06/2022 Status : Completed								
89	22060322	DIGITAL LAB	system no power dlab 11	Shafiullah. R.	NEW SMPS CHANGED		Jayaraj. J. - Computer Department	08/06/2022
Comp. Dt. : 21/07/2022 Status : Completed								
90	22070785	BASEMENT	test	Murugavel.R	CHECKED PROBLEM SLOVED		Murugavel.R - Computer Department	21/07/2022
Comp. Dt. : 01/08/2022 Status : Completed								
91	22080011	GROUND FLOOR NEAR GENERAL MEDICINE OPD	Tube light interchange for face and finger print machine	Selvam. D.	WRONG COMPLIANT ENTER		Selvam. D. - Computer Department	01/08/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 01/09/2022								
Status : Completed								
92	22090018	Computer Department	test	Jayaraj. J.	for error checking		Valamburi. R. - Computer Department	01/09/2022
93	22090019	EDP IN UNDERGROUND	test	Jayaraj. J.	For error checking		Selvam. D. - Computer Department	01/09/2022
94	22090020	EDP IN UNDERGROUND	test	Selvam. D.	for error checking		Selvam. D. - Computer Department	01/09/2022
95	22090021	EDP IN UNDERGROUND	test	Jayaraj. J.	for error checking		Valamburi. R. - Computer Department	01/09/2022
Comp. Dt. : 07/10/2022								
Status : Completed								
96	22100134	Computer Department	system no power on	Balachandar. A.	H61 MOTHERBOARD CHANGED		Shafiullah. R. - Computer Department	07/10/2022
Comp. Dt. : 21/11/2022								
Status : Completed								
97	22110894	DIGITAL LAB	DLAB 23 MONITOR NO POWER ON	Selvam. D.	Repalced the monitor by Acer support service		Madhubalan. S. - Computer Department	01/12/2022
Comp. Dt. : 24/11/2022								
Status : Completed								
98	22111045	EDP IN UNDERGROUND	TEST	Balachandar. A.	test done working		Selvam. D. - Computer Department	25/11/2022
Comp. Dt. : 23/12/2022								
Status : Completed								
99	22121076	DIGITAL LAB	DIGITAL LAB 17 MONITOR WHITE SHADOW PROBLEM	Jayaraj. J.	NEW ACER MONITOR CHANGED		Madhubalan. S. - Computer Department	24/12/2022
100	22121077	DIGITAL LAB	DIGITAL LAB 07 MONITOR WHITE SHADOW PROBLEM	Jayaraj. J.	NEW ACER MONITOR CHANGED		Shafiullah. R. - Computer Department	24/12/2022
Comp. Dt. : 06/01/2023								
Status : Completed								
101	23010292	DIGITAL LAB	DIGITAL LAB 03 MONITOR WHITE SHADOW PROBLEM	Valamburi. R.	NEW ACER 22 INCH MONITOR CHANGED	 Dr. KAGNE. R.N DEAN SRI MANAKULA VINAYAGAR MEDICAL COLLEGE & HOSPITAL KALITHEERTHALKUPPAM, PUDUCHERRY-605107.	Madhubalan. S. - Computer Department	07/01/2023
102	23010293	DIGITAL LAB	DIGITAL LAB 04 MONITOR WHITE SHADOW PROBLEM	Shafiullah. R.	NEW ACER 22 INCH MONITOR CHANGED		Madhubalan. S. - Computer Department	07/01/2023

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 27/01/2023								
Status : Completed								
103	23010967	UROLOGY--OPD	ups no backup	Selvam. D.	one cell lithium battery changed		Selvam. D. - Computer Department	28/01/2023
Comp. Dt. : 03/02/2023								
Status : Completed								
104	23020079	DIGITAL LAB	No dosplay	Selvam. D.	New mother board replced		Jayaraj. J. - Computer Department	03/02/2023
Comp. Dt. : 25/02/2023								
Status : Completed								
105	23020993	DIGITAL LAB	Printer problem	Selvam. D.	Fuser assembly changed		Jayaraj. J. - Computer Department	27/02/2023
Comp. Dt. : 20/03/2023								
Status : Completed								
106	23030764	EDP IN UNDERGROUND	Server raid battery problem	Raja.B	Raid battery changed		Selvam. D. - Computer Department	20/03/2023
Comp. Dt. : 08/04/2023								
Status : Completed								
107	23040255	SPECIAL WARD---B	system problem	Selvam. D.	h310 mother board changed		Balachandar. A. - Computer Department	10/04/2023
Comp. Dt. : 12/05/2023								
Status : Completed								
108	23050495	AO Office	Ao Asst System Problem	Prakash. P.	POWER CABLE REFIXED		Prakash. P. - Computer Department	12/05/2023
Comp. Dt. : 18/05/2023								
Status : Completed								
109	23050757	Mymedical Shop - TPK	GUNDIY MY MEDICAL SHOP MS -OFFICE ACTIVATION	Shafiullah. R.	MS OFICCE ACTIVED		Raja.B - Computer Department	18/05/2023
Comp. Dt. : 25/05/2023								
Status : Completed								
110	23051003	DIRECTOR OFFICE-1ST FLOOR IN COLLEGE	KEYBOARD NOT WORKING	Jayaraj. J.	NEW USB KEYBOARD CHANGED		Jayaraj. J. - Computer Department	25/05/2023

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Dept Name : DENTAL - Computer Department Comp. Dt. : 29/06/2022 Status : Completed								
111	22061058	DENTAL OPD	ups no backup	Selvam. D.	multiple complaint raised		Ganesh.R. - DENTAL	29/06/2022
Comp. Dt. : 29/10/2022 Status : Completed								
112	22100953	CLINICAL DEPARTMENT IN 3RD FLOOR	NEW SYSTEM TO BE INSTALL TO EDITORIAL LAB CLERK	Balachandar. A.	NEW SYSTEM INSTALLED		Sanjay.P. - DENTAL	02/11/2022
Dept Name : Director Office - Computer Department Comp. Dt. : 22/10/2022 Status : Completed								
113	22100748	Dean Office	domain not login	Shafiullah. R.	domain reset		Gajalakshmi. R. - Director Office	22/10/2022
Comp. Dt. : 26/10/2022 Status : Completed								
114	22100839	Dean Office	O/S INSTALLED	Balachandar. A.	240 gb ssd added and os installed		Gajalakshmi. R. - Director Office	27/10/2022
Comp. Dt. : 02/02/2023 Status : Completed								
115	23020060	DEAN SIR	printer not working	Selvam. D.	default printer changed		Gajalakshmi. R. - Director Office	02/02/2023
Comp. Dt. : 21/03/2023 Status : Completed								
116	23030876	DEAN SIR	printer not working	Selvam. D.	Set as default done		Gajalakshmi. R. - Director Office	22/03/2023
Comp. Dt. : 09/05/2023 Status : Completed								
117	23050355	DIRECTOR OFFICE-1ST FLOOR IN COLLEGE	TONER CHANGE	Shafiullah. R.	12A TONER CHANGED		Vijayalakshmi. G. D. - Director Office	09/05/2023
Comp. Dt. : 03/06/2023 Status : Completed								
118	23060093	DIRECTOR OFFICE-1ST FLOOR IN COLLEGE	TONER CHANGE	Shafiullah. R.	12A TONER CHANGED		Vijayalakshmi. G. D. - Director Office	03/06/2023
Comp. Dt. : 06/06/2023 Status : Completed								
119	23060171	Dean Office	PRINTER PROBLEM	Selvam. D.	Engine controler pcb and paper sensor changed		Gajalakshmi. R. - Director Office	06/06/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 28/06/2023 Status : Completed								
120	23061061	Director Office	System slow	Balachandar. A.	Ram fixed. system working fine		Kalaiarasi. R. - Director Office	28/06/2023
Dept Name : Endoscopy - Computer Department Comp. Dt. : 02/09/2022 Status : Completed								
121	22090062	Endoscopy	computer not work	Selvam. D.	updates off and tested the system working fine		Vijayalakshmi. G. - Endoscopy	02/09/2022
Dept Name : Female Ortho Ward - Computer Department Comp. Dt. : 01/09/2022 Status : Completed								
122	22090037	Female Ortho - Ward 401	PRINTER NOT WORKING	Madhubalan. S.	SYSTEM RESTAT PRINTER WILL WORKING FINE		Girija. G. - Female Ortho Ward	01/09/2022
Comp. Dt. : 10/09/2022 Status : Completed								
123	22090411	Female Ortho - Ward 402	printer problem	Shafiullah. R.	TONER REFIXED		Girija. G. - Female Ortho Ward	10/09/2022
Dept Name : Female Surgery - Computer Department Comp. Dt. : 21/07/2022 Status : Completed								
124	22070791	Paediatrics - Ward 309	no power backup in ups	Jayaraj. J.	new ups Changed		Brindha. R. - Female Surgery	21/07/2022
Dept Name : FORENSIC MEDICINE - Computer Department Comp. Dt. : 19/12/2022 Status : Completed								
125	22120840	FORENSIC MEDICINE	SYSTEM SHIFTING WORK	Valamburi. R.	SYSTEM FIXED IN OTHER PLACE		Mathavi. B. - FORENSIC MEDICINE	19/12/2022
Dept Name : GENERAL MEDICINE - Computer Department Comp. Dt. : 24/06/2022 Status : Completed								
126	22060863	MS Office	System network not working..	Murugavel.R	PCI XPRESS CARD INSTALLED PROBLEM SLOVED		Girija.S. - General Medicine	24/06/2022
Comp. Dt. : 04/01/2023 Status : Completed								
127	23010182	General Medicine - OPD	system monitor line problem	Balachandar. A.	new acer 22 inch monitor changed		Deviyanarayanan. J. - General Medicine	05/01/2023

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 27/01/2023 Status : Completed								
128	23010977	General Medicine - OPD	UPS PROBLAM	Madhubalan. S.	NEW UPS CHANGED		Sathiyarayanan. J. - General Medicine	27/01/2023
Dept Name : Hospital Infection Control - Computer Department Comp. Dt. : 04/11/2022 Status : Completed								
129	22110112	HICC ROOM IN 4TH FLOOR-403	New system to be fix	Balachandar. A.	New system fixed and network given		Mohana. M. - Hospital Infection Control	04/11/2022
Dept Name : ICCU - Computer Department Comp. Dt. : 18/04/2023 Status : Completed								
130	23040551	ICCU	CHANGE TONER	Valamburi. R.	12A TONER CHANGED		Ammu. R. - ICCU	18/04/2023
Dept Name : Library - Computer Department Comp. Dt. : 19/12/2022 Status : Completed								
131	22120864	Library	PRINTER NOT WORKING - COLLEGE SIDE LIBRARY	Jayaraj. J.	SETTINGS CHANGED..		Lakshmi Gandhan.S. - Library	22/12/2022
Comp. Dt. : 25/05/2023 Status : Completed								
132	23051013	Library	INTERNET NOT WORK	Raja.B	BIO CHEMISTRY SWITCH RESTART		Elangovan.N. - Library	25/05/2023
Dept Name : Male Medical Ward - Computer Department Comp. Dt. : 02/09/2022 Status : Completed								
133	22090080	Male Medical - Ward 301	MONITOR NOT WORKING	Jayaraj. J.	monitor working fine		Soniya Gandhi. A. - Male Medical Ward	03/09/2022
Comp. Dt. : 11/02/2023 Status : Completed								
134	23020440	Male Medical - Ward 301	NEED TO CHANGE TONER	Harikrishnan. R.	12A toner changed		Kanmani. R. - Male Medical Ward	13/02/2023
Comp. Dt. : 08/03/2023 Status : Completed								
135	23030339	Male Medical - Ward 303	NEED TO REPALCE PRINTER FROM 304 TO 303	Jayaraj. J.	PRINTER REPLACED		Vijayalakshmi. S. - Male Medical Ward	09/03/2023
Dept Name : Male Ortho Ward - Computer Department								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 25/05/2023 Status : Completed								
136	23051001	Male Ortho - Ward 403	PRINTER - PAPER JAM	Shafiullah. R.	REINSTALL THE PRINTER DRIVER		Manjula. P. - Male Ortho Ward	25/05/2023
Dept Name : Male Surgery - Computer Department Comp. Dt. : 24/06/2022 Status : Completed								
137	22060876	CITY CENTER IN PONDY	ups not powering on	Selvam. D.	Lithium ups changed		Ilakkiya. J. - Male Surgery	25/06/2022
Comp. Dt. : 30/09/2022 Status : Completed								
138	22091205	Male Surgery - Ward 201	PRINTER NOT WORKING	Madhubalan. S.	PRINTER WORKING FINE		Sugumari. M. - Male Surgery	30/09/2022
Dept Name : Marketing Team - Computer Department Comp. Dt. : 17/09/2022 Status : Completed								
139	22090677	CUSTOMER CARE EXECUTIVE-RECEPTION	LAPTOP NOT WORKING	Valamburi. R.	General service done		Sathiya Priya. J. - Marketing Team	21/09/2022
Comp. Dt. : 22/10/2022 Status : Completed								
140	22100758	Chairman Office	36A TONER CHANGE	Shafiullah. R.	TONER CAHNGED		Priya. A. - Marketing Team	22/10/2022
Comp. Dt. : 22/12/2022 Status : Completed								
141	22121010	Chairman Office	keyboard not working	Balachandar. A.	NEW USB KEYBOARD CHANGED		Priya. A. - Marketing Team	22/12/2022
Comp. Dt. : 23/05/2023 Status : Completed								
142	23050921	Chairman Office	ms office problem	Selvam. D.	MS OFFICE REINSTALLED		Priya. A. - Marketing Team	24/05/2023
Dept Name : Medical Records - Computer Department Comp. Dt. : 12/05/2022 Status : Completed								
143	22050403	Obstetrics - Ward 208	NEED TO CHANGE PRINTER TONER AND SYSTEM ALSO NOT WORKING	Madhubalan. S.	12A TONER CHANGED AND SYSTEM WORKING FINE		Jerina. M. - Medical Records	12/05/2022
Comp. Dt. : 13/05/2022								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
144	22050453	Medical Records	NEED TO CHANGE NEW BARCODE STICKER	Valamburi. R.	NEW BARCODE STICKER CHANGED		Basheer Ahamed Khan. C - Medical Records	13/05/2022
Comp. Dt. : 25/05/2022								
Status : Completed								
145	22050961	Reception	SYSTEM PROBLEM	Jayaraj. J.	SMPS CHANGED		Manivannan. S. - Medical Records	25/05/2022
Comp. Dt. : 30/05/2022								
Status : Completed								
146	22051086	Male Surgery - Ward 204	Monitor display problem	Selvam. D.	RESET SETTING		Praveena. V. - Medical Records	30/05/2022
Comp. Dt. : 10/06/2022								
Status : Completed								
147	22060359	Male Surgery - Ward 204	paper jam	Selvam. D.	Teflon sleeve replaced		Praveena. V. - Medical Records	10/06/2022
Comp. Dt. : 20/07/2022								
Status : Completed								
148	22070745	Reception	New barcode sticker need to change	Selvam. D.	New barcode sticker changed		Maheswari. S. - Medical Records	20/07/2022
Comp. Dt. : 20/08/2022								
Status : Completed								
149	22080660	CASHCOUNTER IN RECEPTION	ribbon need to change	Selvam. D.	ribbon changed...		Murugan. J. - Medical Records	20/08/2022
Comp. Dt. : 02/09/2022								
Status : Completed								
150	22090105	Medical Records	PRINTER INK NEED TO BE FILLED	Madhubalan. S.	black ink filled		Iswin Joseph.M. - Medical Records	03/09/2022
Comp. Dt. : 20/10/2022								
Status : Completed								
151	22100691	Reception	COUNTER -5 NEW BARCODE STRICKER	Shafiullah. R.	NEW BARCODE STRICKER CHANGED		Martin Prabu.V. - Medical Records	20/10/2022
Comp. Dt. : 21/10/2022								
Status : Completed								
152	22100705	SUPER SPECILAITY OPD IN 2ND FLOOR	New system and barcode printer need to install	Prakash. P.	New system and barcode fixed		Martin Prabu.V. - Medical Records	21/10/2022
Comp. Dt. : 08/11/2022								
Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
153	22110313	Medical Records	SYSTEM NO POWER ON	Jayaraj. J.	SYSTEM RESTARTED		Martin Prabu.V. - Medical Records	08/11/2022
	Comp. Dt. : 19/11/2022							
	Status : Completed							
154	22110818	Male Surgery - Ward 204	printer paper jam	Selvam. D.	PRESSURE ROLLER AND TEFLON SLEEVE CHANGED		Praveena. V. - Medical Records	19/11/2022
	Comp. Dt. : 09/12/2022							
	Status : Completed							
155	22120437	Female Surgery - Ward 206	UPS PROBLEM	Jayaraj. J.	old ups changed		Praveena. V. - Medical Records	10/12/2022
	Comp. Dt. : 03/02/2023							
	Status : Completed							
156	23020081	Female Surgery - Ward 205	System no display	Selvam. D.	H310 mother board changed		Praveena. V. - Medical Records	04/02/2023
	Comp. Dt. : 28/02/2023							
	Status : Completed							
157	23021081	Medical Records	printer to be install	Balachandar. A.	printer installed		Iswin Joseph.M. - Medical Records	28/02/2023
	Comp. Dt. : 13/03/2023							
	Status : Completed							
158	23030486	Medical Records	BARCODE BLACK RIBBON CHANGE	Shafiullah. R.	WAX RIBBONCHANGED		Raj Kumar. K. - Medical Records	13/03/2023
	Comp. Dt. : 04/04/2023							
	Status : Completed							
159	23040127	CASHCOUNTER IN RECEPTION	KEYBOARD NOT WORKING	Jayaraj. J.	NEW USB KEYBOARD CHANGED		Murugan. J. - Medical Records	04/04/2023
	Comp. Dt. : 18/04/2023							
	Status : Completed							
160	23040554	Medical Records	CHANGE TONER	Valamburi. R.	12A TONER CHANGED		Raj Kumar. K. - Medical Records	18/04/2023
	Comp. Dt. : 10/05/2023							
	Status : Completed							
161	23050401	Medical Records	NEED TO CHANGE BARCODE STICKER	Valamburi. R.	BARCODE STICKER CHANGED		Martin Prabu.V. - Medical Records	11/05/2023
	Comp. Dt. : 23/05/2023							
	Status : Completed							
162	23050907	Medical Records	UPS NO POWER	Selvam. D.	UPS SWITCH CHANGED		Martin Prabu.V. - Medical Records	24/05/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 25/05/2023 Status : Completed								
163	23051012	Female Ortho - Ward 402	NEED TO CHANGE TONER	Harikrishnan. R.	12A Toner Changed.		Gowri. S. - Medical Records	25/05/2023
Comp. Dt. : 27/05/2023 Status : Completed								
164	23051097	Medical Records	NETWORK NOT WORKING	Selvam. D.	REFIX PATCH CARD		Avanthia. R. - Medical Records	27/05/2023
Comp. Dt. : 12/06/2023 Status : Completed								
165	23060410	Medical Records	KEYBOARD NOT WORKING	Shafiullah. R.	KEYBOARD CLEAN AND REFIXED		Martin Prabu.V. - Medical Records	12/06/2023
Comp. Dt. : 14/06/2023 Status : Completed								
166	23060508	Reception	NETWORK NOT WORKING	Shafiullah. R.	8 PORT REFIX THE PATCH CARD		Basheer Ahamed Khan. C - Medical Records	14/06/2023
Dept Name : MICROBIOLOGY - Computer Department Comp. Dt. : 06/12/2022 Status : Completed								
167	22120265	MICROBIOLOGY	PCR LAB SYSTEM BLUE SCREEN PROBLEM	Balachandar. A.	8gb ddr4 ram changed..		Anandh. P. - MICROBIOLOGY	06/12/2022
Comp. Dt. : 19/12/2022 Status : Completed								
168	22120839	MICROBIOLOGY IN COLLEGE	SYSTEM NOT WORKING - IN OFFICE	Jayaraj. J.	NETWORK CABLE REFIXED		Mageswari. R. - MICROBIOLOGY	20/12/2022
Comp. Dt. : 22/02/2023 Status : Completed								
169	23020834	MICROBIOLOGY IN COLLEGE	system no power on	Selvam. D.	new motherboard changed.		Gopal. R. - MICROBIOLOGY	22/02/2023
Comp. Dt. : 10/05/2023 Status : Completed								
170	23050396	MICROBIOLOGY	PRINTER MACHINE PAPER GOT STRUCK	Harikrishnan. R.	Paper removed sucefully.		Mageswari. R. - MICROBIOLOGY	11/05/2023
Comp. Dt. : 13/05/2023 Status : Completed								
171	23050555	MICROBIOLOGY IN COLLEGE	NETWOTK PORT NOT WORKING	Prakash. P.	I/O crimbed		Mangaiyarkarasi. T. - MICROBIOLOGY	16/05/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 24/05/2023 Status : Completed								
172	23050960	MICROBIOLOGY IN COLLEGE	SYSTEM NOT WORKING	Selvam. D.	SYSTEM WORKING FINE		Nivethighaa. G. - MICROBIOLOGY	24/05/2023
Dept Name : MS Office - Computer Department Comp. Dt. : 26/05/2022 Status : Completed								
173	22050974	EDP IN UNDERGROUND	ups no backup	Selvam. D.	ups lithium battery changed		Parasuraman. R. - Medical Records	26/05/2022
Comp. Dt. : 20/10/2022 Status : Completed								
174	22100700	SKILL LAB - MEDICAL COLLEGE	NEED TO INSTALL THE PRINTER WITH COMPUTER	Prakash. P.	NEW PRINTER INSTALLED		Elumalai. M. - MS Office	21/10/2022
Comp. Dt. : 19/11/2022 Status : Completed								
175	22110825	MS Office	SYSTEM NO POWER ON	Balachandar. A.	smps problem,new smps changed..		Nageswari. N. - MS Office	19/11/2022
Dept Name : Nursing Office - Computer Department Comp. Dt. : 18/05/2022 Status : Completed								
176	22050669	Post Operative Male - Ward 1	Printer not working	Selvam. D.	pressure roller and teflon sleeve changed		Jayabarathi. P. - Special Ward	18/05/2022
Comp. Dt. : 19/08/2022 Status : Completed								
177	22080652	Nursing College	Internet not working	Raja.B,Murugavel.R, Selvam. D.	through new fiber		Rajalakshmi. N. - Nursing Office	20/08/2022
Comp. Dt. : 30/01/2023 Status : Completed								
178	23011047	Nursing Office	NEED TO CHANGE PRINTER TONER	Selvam. D.	PRINTER TONER CHANGED		Muthazhagi. A. - Nursing Office	30/01/2023
Dept Name : Obstetrics & Gynaecology - Computer Department Comp. Dt. : 21/07/2022 Status : Completed								
179	22070789	Obstetrics - OPD	system not working	Prakash. P.	POwer Cable unplugged		Nivedita.K. - Obstetrics & Gynaecology	21/07/2022
Comp. Dt. : 29/10/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
180	22100952	SKILL LAB - MEDICAL COLLEGE	NEW PRINTER TO BE INSTALL	Balachandar. A.	New printer installed		Jayasree. M. - Obstetrics & Gynaecology	31/10/2022
Dept Name : OPD - Computer Department Comp. Dt. : 27/09/2022 Status : Completed								
181	22091072	ENT OPD	Printer problem	Selvam. D.	Print head and waste ink pad changed		Ezhilarasi. M. - OPD	27/09/2022
182	22091073	Audiometry & Speech Therapy	Adobe Software need to install	Selvam. D.	Adobe Software installed		Ezhilarasi. M. - OPD	27/09/2022
Dept Name : P.H.C. - Tiruvennainallur - Computer Department Comp. Dt. : 22/03/2023 Status : Completed								
183	23030892	TV Nulur	system no power	Selvam. D.	smmps changed. System working fine		Kanagasabai. D. - P.H.C. - Tiruvennainallur	22/03/2023
Dept Name : PAEDIATRICS - Computer Department Comp. Dt. : 18/01/2023 Status : Completed								
184	23010644	Paediatrics - OPD	No ups backup	Selvam. D.	NEW UPS CHANGED		Arul Kumaran. A - PAEDIATRICS	18/01/2023
Dept Name : PATHOLOGY - Computer Department Comp. Dt. : 23/06/2022 Status : Completed								
185	22060842	PATHOLOGY IN COLLEGE	Demo room system no power on	Murugavel.R	NEW SMPS CHANGED PROBLEM SLOVED		Erli Amel Ivan - PATHOLOGY	23/06/2022
Comp. Dt. : 21/10/2022 Status : Completed								
186	22100704	Pathology Lab	New system need to fix	Selvam. D.	New system fixed		Erli Amel Ivan - PATHOLOGY	21/10/2022
Comp. Dt. : 22/12/2022 Status : Completed								
187	22121002	PATHOLOGY IN COLLEGE	SYSTEM NETWORK FAILURE	Jayaraj. J.	NETWORK CABLE REFIXED AND REARRANGED		Kalaichelvi.M. - PATHOLOGY	22/12/2022
Comp. Dt. : 29/04/2023 Status : Completed								
188	23040988	PATHOLOGY IN COLLEGE	monitor not working	Balachandar. A.	NEW 22INCH ACER MONITOR CHANGED..		Kalaichelvi.M. - PATHOLOGY	29/04/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 10/05/2023 Status : Completed								
189	23050395	FNAC ROOM	SYSTEM PROBLEM	Madhubalan. S.	POWER CABLE REFIXED WORKING FINE		Muthamil.K. - PATHOLOGY	11/05/2023
Dept Name : PHARMACOLOGY - Computer Department Comp. Dt. : 09/09/2022 Status : Completed								
190	22090379	MEDICAL COLLEGE 2ND FLOOR	SYSTEM NO POWER ON	Jayaraj. J.	NEW SMPS CHANGED		Panchali. P. - PHARMACOLOGY	09/09/2022
Comp. Dt. : 18/04/2023 Status : Completed								
191	23040552	PHARMACOLOGY	PAPPER JAM IN PRINTER	Jayaraj. J.	PAPER JAM CLEAR		Nageswari. S. - PHARMACOLOGY	18/04/2023
Comp. Dt. : 01/06/2023 Status : Completed								
192	23060036	PHARMACOLOGY	hod system windows 10 update	Selvam. D.	DLAB SYSTEM SEND PHARMCOLOGY HOD		Nageswari. S. - PHARMACOLOGY	05/06/2023
Dept Name : Pharmacy - Computer Department Comp. Dt. : 11/05/2022 Status : Completed								
193	22050399	Pay Pharmacy	NEED TO CHANGE PRINTER RIBBON	Shafiullah. R.	10Mm ribbon changed		Veeraraghavan. R. - Pharmacy	11/05/2022
Comp. Dt. : 03/06/2022 Status : Completed								
194	22060129	Pay Pharmacy	NEED TO CHANGE PRINTER RIBBON	Shafiullah. R.	counter 2&3 10mt ribbon changed		Silambuselvan. P. - Pharmacy	03/06/2022
Comp. Dt. : 08/06/2022 Status : Completed								
195	22060296	Pay Pharmacy	keyboard letters not clear	Selvam. D.	USB KEYBOARD REPLACED		Silambuselvan. P. - Pharmacy	08/06/2022
196	22060297	Pay Pharmacy	letters not clear in keyboard	Selvam. D.	USB KEYBOARD REPLACED		Silambuselvan. P. - Pharmacy	08/06/2022
Comp. Dt. : 23/07/2022 Status : Completed								
197	22070854	Free Pharmacy	SYSTEM NOT WORKING	Selvam. D.	system working fine		Thilagavathi. T. - Pharmacy	23/07/2022
Comp. Dt. : 02/09/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
198	22090061	MEDICAL STORE IN BASEMENT	need change to printer ribbon	Madhubalan. S.	10m RIBBON CHANGED		Sujatha.S. - Pharmacy	02/09/2022
	Comp. Dt. : 13/12/2022 Status : Completed							
199	22120580	Pay Pharmacy	NEED TO CHANGE PRINTER RIBBON	Selvam. D.	RIBBON CHANGED		Silambuselvan. P. - Pharmacy	13/12/2022
	Comp. Dt. : 16/02/2023 Status : Completed							
200	23020618	Pay Pharmacy	NEED TO CHANGE PRINTER RIBBON	Selvam. D.	PRINTER RIBBON CHANGED		Silambuselvan. P. - Pharmacy	16/02/2023
	Comp. Dt. : 20/03/2023 Status : Completed							
201	23030811	Central Medical Stores	RIBBON NEED TO CHANGE	Selvam. D.	RIBBON CHANGED		Sheela. B. - Pharmacy	21/03/2023
	Comp. Dt. : 31/03/2023 Status : Completed							
202	23031350	Free Pharmacy	mouse click not working	Balachandar. A.	NEW USB MOUSE CHANGED..		Thilagavathi. T. - Pharmacy	01/04/2023
	Comp. Dt. : 18/04/2023 Status : Completed							
203	23040546	Pay Pharmacy	CHANGE RIBBON &PRINTER	Selvam. D.	changed 10m ribbon		Kanchana. P. - Pharmacy	18/04/2023
	Comp. Dt. : 25/05/2023 Status : Completed							
204	23051008	Free Pharmacy	UPS NO BACKUP	Jayaraj. J.	NEW LITHIUM BATTERY CHANGED		Janane. K. - Pharmacy	25/05/2023
	Dept Name : PHYSIOLOGY - Computer Department Comp. Dt. : 31/05/2022 Status : Completed							
205	22051132	PHYSIOLOGY	ups battery need to change	Selvam. D.	lithium battery changed		Jayanthi.A. - PHYSIOLOGY	31/05/2022
	Comp. Dt. : 08/10/2022 Status : Completed							
206	22100196	PHYSIOLOGY--COLLEGE	I\O FIXING	Shafiullah. R.	I\O FACE PLATE FIXING		Soundariya. K. - PHYSIOLOGY	08/10/2022
	Comp. Dt. : 15/03/2023 Status : Completed							


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
207	23030586	PHYSIOLOGY-- -COLLEGE	system no power on	Balachandar. A.	SMPS CHANGED		Jayanthi.A. - PHYSIOLOGY	15/03/2023
Dept Name : PICU & NICU - Computer Department Comp. Dt. : 08/06/2023 Status : Completed								
208	23060300	NICU	WIFI NOT WORKING	Shafiullah. R.	REFIX DEVICE PATCH CARD		Umamaheswari. P. - PICU & NICU	08/06/2023
Dept Name : Plastic Surgery - Computer Department Comp. Dt. : 17/10/2022 Status : Completed								
209	22100549	PLASTIC SURGERY OPD-223	MED PLUS NOT OPEN	Shafiullah. R.	REINSTALLED MEDPLUS		Kadhiravaraj. J. - Plastic Surgery	17/10/2022
Dept Name : POW & SICU - Computer Department Comp. Dt. : 02/09/2022 Status : Completed								
210	22090058	POW & SICU	computer monitor display problem	Madhubalan. S.	display working fine		Arulmozhi. D. - POW & SICU	02/09/2022
Dept Name : Quality Department - Computer Department Comp. Dt. : 07/05/2022 Status : Completed								
211	22050233	FORENSIC MEDICINE (3RD FLOOR) IN COLLEGE	SYSTEM NOT WORKING NABH CLASS SYSTEM	Jayaraj. J.	NEW SSD HARD DISK CHANGED		Jones Arokiam. M. - Quality Department	09/05/2022
Dept Name : Radio Diagnosis - Computer Department Comp. Dt. : 24/06/2022 Status : Completed								
212	22060901	RADIOLOGY	Printer paper jam	Selvam. D.	Presure roller changed		Jayalakshmi. D. - Radio Diagnosis	24/06/2022
Comp. Dt. : 27/06/2022 Status : Completed								
213	22060954	RADIOLOGY	mouse not working	Selvam. D.	mouse refixed and system restarts		Jayalakshmi. D. - Radio Diagnosis	27/06/2022
Comp. Dt. : 23/07/2022 Status : Completed								
214	22070853	RADIOLOGY	system to be shift	Balachandar. A.	system shifted		BALAVAITHEESWAR. R.L. - Radio Diagnosis	23/07/2022
Comp. Dt. : 09/08/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
215	22080297	RADIOLOGY	Pacs system problem	Selvam. D.	temp files cleared working fine		Jayalakshmi. D. - Radio Diagnosis	09/08/2022
	Comp. Dt. : 30/08/2022							
	Status : Completed							
216	22081035	RADIOLOGY	system network not working	Balachandar. A.	NETWORK SWITCH REFIXED		Elamparidhi. P. - Radio Diagnosis	30/08/2022
	Comp. Dt. : 06/09/2022							
	Status : Completed							
217	22090235	RADIOLOGY	monitor no power	Selvam. D.	Power cable refixed		Jayalakshmi. D. - Radio Diagnosis	06/09/2022
	Comp. Dt. : 20/10/2022							
	Status : Completed							
218	22100667	RADIOLOGY	O/S INSTALL	Balachandar. A.	o/s installed software installed		Manikandan. G. - Radio Diagnosis	20/10/2022
	Comp. Dt. : 31/03/2023							
	Status : Completed							
219	23031335	RADIOLOGY	system not login	Selvam. D.	system harddisk problem,new 1tb harddisk changed		Umamageswari. A. - Radio Diagnosis	31/03/2023
	Comp. Dt. : 13/04/2023							
	Status : Completed							
220	23040426	RADIOLOGY	Mouse not working	Selvam. D.	usb mouse changed		Jayalakshmi. D. - Radio Diagnosis	17/04/2023
	Dept Name : Reception - Computer Department							
	Comp. Dt. : 03/02/2023							
	Status : Completed							
221	23020080	1st floor	System no display	Selvam. D.	system working fine		Ranjithkumar. P. - Reception	06/02/2023
	Comp. Dt. : 09/03/2023							
	Status : Completed							
222	23030383	Reception	barcode change 3 numbers	Shafiullah. R.	NEW BARCODE STRICKER CHANGED		Jayakumar. R. - Reception	09/03/2023
	Comp. Dt. : 18/04/2023							
	Status : Completed							
223	23040547	CASHCOUNTER IN RECEPTION	CHANGE RIBBON	Selvam. D.	10m ribbon changed		Priya. S. - Reception	18/04/2023
	Dept Name : SMV Allied Health Sciences - Computer Department							
	Comp. Dt. : 29/04/2023							


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
224	23040989	MICROBIOLOGY IN COLLEGE	monitor not working	Balachandar. A.	new acer 22 inch monitor changed		Raffik Moideen. M. - SMV Allied Health Sciences	29/04/2023
Dept Name : Special Clinic - Computer Department								
Comp. Dt. : 11/05/2022								
Status : Completed								
225	22050398	Reception	NEED TO CHANGE BARCODE STICKER IN COUNTER 5	Shafiullah. R.	NEW STRICKER CHANGED		Vijayalakshmi. B. - Special Clinic	11/05/2022
Comp. Dt. : 27/07/2022								
Status : Completed								
226	22070987	Reception	counter 5 barcode problem	Selvam. D.	barcode ribbon refixed		Baskar. G. - Special Clinic - Reception	27/07/2022
Comp. Dt. : 30/08/2022								
Status : Completed								
227	22081026	Reception	New system to be fix	Balachandar. A.	New system fixed..		Senthil. M. - Special Clinic	30/08/2022
Comp. Dt. : 02/09/2022								
Status : Completed								
228	22090084	Reception	NEED TO PRINTER RIBBON CHANGING	Selvam. D.	COUNTER 2 BARCODE RIBBON CHANGED		Ramya. R. - Special Clinic - Reception	02/09/2022
Comp. Dt. : 12/09/2022								
Status : Completed								
229	22090449	Reception	counter 4 new barcode sticker change	Selvam. D.	New barcode sticker changed		Vijayalakshmi. B. - Special Clinic	12/09/2022
230	22090451	Reception	counter 6 revisit sticker changed	Selvam. D.	Revisit sticker changed		Vijayalakshmi. B. - Special Clinic	12/09/2022
Comp. Dt. : 14/09/2022								
Status : Completed								
231	22090562	Reception	counter 5 adobe software install	Selvam. D.	Adobe software installed		Savitha. K. - Special Clinic - Reception	14/09/2022
Comp. Dt. : 28/09/2022								
Status : Completed								
232	22091112	SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	mouse not working	Balachandar. A.	NEW USB MOUSE CHANGED		Monica Sales. D. - Special Clinic - Office	28/09/2022
233	22091124	Reception	SYSTEM - MONITOR PROBLEM COUNTER NO 7	Selvam. D.	system restarts		Baskar. G. - Special Clinic - Reception	29/09/2022
Comp. Dt. : 06/10/2022								

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
234	22100109	Reception	counter 2 system no power	Selvam. D.	POWER CARD REPLACED..		Baskar. G. - Special Clinic - Reception	06/10/2022
Comp. Dt. : 20/10/2022								
Status : Completed								
235	22100666	SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	12A TONER CHANGE	Shafiullah. R.	12A TONER CHANGED		Uma Maheswari. D. - Special OPD	20/10/2022
Comp. Dt. : 13/01/2023								
Status : Completed								
236	23010571	Reception	COUNTER 4 BARCODE PRINTER PROBLEM	Selvam. D.	NEW BARCODE PRINTER CHANGED		Vijayalakshmi. B. - Special Clinic	13/01/2023
Comp. Dt. : 01/03/2023								
Status : Completed								
237	23030009	Reception	NEED TO CHANGE OLD BARCODE STICKER	Harikrishnan. R.	revisit stricker changed		Vijayalakshmi. B. - Special Clinic	01/03/2023
Dept Name : Special Clinic - Dialysis - Computer Department								
Comp. Dt. : 20/12/2022								
Status : Completed								
238	22120930	DIALYSIS NEW UNIT IN 1ST FLOOR	PRINTER NOR WORKING	Madhubalan. S.	SYSTEM RESTATED PRINTER WORKING FINE		Swathika. K. - Special Clinic - Dialysis	21/12/2022
Dept Name : Special Clinic - Office - Computer Department								
Comp. Dt. : 05/12/2022								
Status : Completed								
239	22120151	SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	Mouse not working	Balachandar. A.	NEW USB MOUSE CHANGED		Thamizhselvi. S. - Administration	05/12/2022
Comp. Dt. : 16/03/2023								
Status : Completed								
240	23030638	SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	SYSTEM REARRANGE	Balachandar. A.	SYSTEM REARRANGED		Kaveri. R. - Special Clinic - Office	16/03/2023
Comp. Dt. : 22/03/2023								
Status : Completed								
241	23030893	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	printer problem	Selvam. D.	pressure roller and Teflon sleeve changed		Monica Sales. D. - Special Clinic - Office	22/03/2023
Comp. Dt. : 25/03/2023								
Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
242	23031076	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	PRINTER NOT WORKING	Shafiullah. R.	RESTART THE SYSTEM PRINTER WORKING		Monica Sales. D. - Special Clinic - Office	25/03/2023
Comp. Dt. : 04/04/2023 Status : Completed								
243	23040128	1st floor	SCAN NOT WORKING	Jayaraj. J.	SCANNER SETTING CHANGED AND RESTARED SCENNER		Kaveri. R. - Special Clinic - Office	04/04/2023
Comp. Dt. : 25/05/2023 Status : Completed								
244	23050978	SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	ups no power on	Selvam. D.	Power reset done		Thamizhselvi. S. - Administration	25/05/2023
245	23050979	SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	printer not working	Selvam. D.	printer usb cable refixed		Thamizhselvi. S. - Administration	25/05/2023
Comp. Dt. : 15/06/2023 Status : Completed								
246	23060525	SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	NEED TO CHANGE PRINTER TONER	Shafiullah. R.	MONICA 12A TONER CHANGED		Monica Sales. D. - Special Clinic - Office	15/06/2023
Dept Name : Special Clinic - Reception - Computer Department Comp. Dt. : 09/12/2022 Status : Completed								
247	22120398	Reception	system no power on	Balachandar. A.	smpls problem,new smpls changed..		Geetha. J. - Special Clinic - Reception	09/12/2022
Comp. Dt. : 21/12/2022 Status : Completed								
248	22120958	Reception	COUNTER 5 BARCODE RIBBON CHANGE	Balachandar. A.	12A TONER CHANGED		Geetha. J. - Special Clinic - Reception	21/12/2022
Comp. Dt. : 28/12/2022 Status : Completed								
249	22121258	Reception	counter no - 6 bar code sticker	Selvam. D.	Barcode ribbon changed		Gughan. P. - Special Clinic - Reception	28/12/2022
Comp. Dt. : 16/03/2023 Status : Completed								
250	23030659	Reception	COUNTER NO 5 BARCODE STICKER CHANGE	Selvam. D.	New barcode sticker changed		Baskar. G. - Special Clinic - Reception	16/03/2023
Comp. Dt. : 18/04/2023 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
251	23040559	Reception	COUNTER NO 2 INTER NET CONNECTION DISCONNECTED	Balachandar. A.	internet working		Baskar. G. - Special Clinic - Reception	18/04/2023
Comp. Dt. : 28/04/2023 Status : Completed								
252	23040965	Reception	COUNTER 1 KEYBOARD NOT WORKING	Madhubalan. S.	NEW USB KEYBOARD CHANGED		Ramkumar. S. - Special Clinic - Reception	28/04/2023
Comp. Dt. : 10/05/2023 Status : Completed								
253	23050394	Reception	COUNTER BARCODE STICKER PROBLEM	Valamburi. R.	PAPER JAM CLEARED		Geetha. J. - Special Clinic - Reception	11/05/2023
Dept Name : Special OPD - Computer Department Comp. Dt. : 12/05/2023 Status : Completed								
254	23050519	Reception	NEED TO CHANGE BARCODE STRICKER FOR COUNTER NO 5	Selvam. D.	new barcode sticker changed		Uma Maheswari. D. - Special OPD	12/05/2023
Comp. Dt. : 26/05/2023 Status : Completed								
255	23051072	Reception	Counter 4 barcode ribbon struck	Balachandar. A.	Stcker Refixed		Uma Maheswari. D. - Special OPD	26/05/2023
Comp. Dt. : 07/06/2023 Status : Completed								
256	23060219	Reception	counter 4 barcode ribbon change	Balachandar. A.	barcode ribbon changed		Uma Maheswari. D. - Special OPD	07/06/2023
Dept Name : Special Ward - Computer Department Comp. Dt. : 30/11/2022 Status : Completed								
257	22111264	Special Ward - C	NEED CHANGE TONER	Shafiullah. R.	12A TONER CHANGED		Vijai. M. - Medical Records	30/11/2022
Comp. Dt. : 16/12/2022 Status : Completed								
258	22120773	SPECIAL WARD - A1	SYSTEM NOT WORKING	Shafiullah. R.	SYSTEM WORKING PRINTER DOOR NOT CLOSE		Manjula. R. - Special Ward	16/12/2022
Comp. Dt. : 04/02/2023 Status : Completed								
259	23020129	Female Surgery - Ward 205	printer problem	Selvam. D.	Presure roller and teflon sleeve changed		Sangeetha. S. - Special Ward	06/02/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 08/04/2023 Status : Completed								
260	23040254	SPECIAL WARD---B	system no display	Selvam. D.	power cable refixed		Rajalakshmi. D. - Special Ward	10/04/2023
Comp. Dt. : 18/04/2023 Status : Completed								
261	23040563	SPECIAL WARD - A1	CHANGE TONER	Jayaraj. J.	12A TONER CHANGED		Manjula. R. - Special Ward	18/04/2023
Comp. Dt. : 10/05/2023 Status : Completed								
262	23050410	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	PRINTER CODE NOT COME	Balachandar. A.	PRINTER WORKING FINE		Sangeetha. C. - Special Ward	12/05/2023
Dept Name : Tele Exchange - Computer Department Comp. Dt. : 26/05/2022 Status : Completed								
263	22050975	Main Gate	main gate cctv ups no backup	Selvam. D.	lithium ups battery changed		Vivek. A. - Tele Exchange	26/05/2022
Dept Name : Transport - Computer Department Comp. Dt. : 06/05/2022 Status : Completed								
264	22050199	Transport	No display	Shafiullah. R.	New h61 mother board changed. Tested working fine		Ashok Kumar. K. - Transport	07/05/2022
Comp. Dt. : 17/10/2022 Status : Completed								
265	22100540	TRANSPORT DEPARTMENT IN COMMERCIAL COMPLEX	keyboard problem	Prakash. P.	new Key board Changed		Ashok Kumar. K. - Transport	17/10/2022
266	22100541	TRANSPORT DEPARTMENT IN COMMERCIAL COMPLEX	ups problem	Prakash. P.	new lithium UPS Changed		Ashok Kumar. K. - Transport	17/10/2022
Dept Name : UHC Villupuram - Computer Department Comp. Dt. : 26/05/2022 Status : Completed								
267	22051005	UHC Villupuram	not printing properly	Selvam. D.	Head cable changed		Asaithambi. R. - UHC Villupuram	27/05/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Work Type : Work Dept Name : Special Clinic - Computer Department Comp. Dt. : 25/07/2022 Status : Completed								
268	22070903	Special Clinic	medplus to be update	Balachandar. A.	medplus to be updated		Thamizhselvi. S. - Administration	25/07/2022
College Name : SMVMCH-COL Work Type : Complaint Dept Name : Anaesthesiology - Computer Department Comp. Dt. : 25/11/2022 Status : Completed								
269	22111093	ORTHO OT	NEED TO CHANGE PRINTER TONER	Selvam. D.	12A TONER CHANGED		Jayanthi.V. - Anaesthesiology	25/11/2022
Dept Name : ANATOMY - Computer Department Comp. Dt. : 29/06/2022 Status : Completed								
270	22061041	ANATOMY	NEED TO CHANGE PRINTER CARTRIDGE	Shafiullah. R.	88A toner changed		Mathivanan.B. - ANATOMY	30/06/2022
Comp. Dt. : 22/09/2022 Status : Completed								
271	22090873	ANATOMY	PROBELM IN SYSTEM [HOD ROOM]	Selvam. D.	WIN10 OS REINSTALLED.		Mathivanan.B. - ANATOMY	27/09/2022
Comp. Dt. : 29/09/2022 Status : Completed								
272	22091145	ANATOMY	PROBLEM IN SYSTEM [HOD SYSTEM] NOT WORKING	Jayaraj. J.	os reinstalled		Mathivanan.B. - ANATOMY	29/09/2022
Comp. Dt. : 30/09/2022 Status : Completed								
273	22091218	ANATOMY	NEED TO CHECK SYSTEM - WORD FILE NOT OPENED	Madhubalan. S.	Setting changed		Mathivanan.B. - ANATOMY	30/09/2022
Comp. Dt. : 20/01/2023 Status : Completed								
274	23010699	ANATOMY	NEED TO CHECK NET CONNECTION - PROBLEM IN HOD SYSTEM	Jayaraj. J.	WORKING FINE		Mathivanan.B. - ANATOMY	24/01/2023
Comp. Dt. : 13/05/2023 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
275	23050530	ANATOMY	NEED TO CHANGE TONER	Shafiullah. R.	88A TONER CHANGED		Mathivanan.B. - ANATOMY	13/05/2023
Dept Name : BIOCHEMISTRY - Computer Department Comp. Dt. : 01/06/2022 Status : Completed								
276	22060034	BIOCHEMISTRY-- -COLLEGE	SYSTEM NOT WORKING	Jayaraj. J.	antivirus scan		Preethi. A. - Blood Collection Centre	01/06/2022
Comp. Dt. : 12/07/2022 Status : Completed								
277	22070465	BIOCHEMISTRY-- -COLLEGE	PROBLEM IN SYSTEM DISPLAY	Madhubalan. S.	VGA CABLE REFIXED		Preethi. A. - Blood Collection Centre	14/07/2022
Comp. Dt. : 19/08/2022 Status : Completed								
278	22080616	BIOCHEMISTRY-- -COLLEGE	BIOMETRIC PUNCHING MACHINE NOT WORKING	Balachandar. A.	checked working fine...		Suganthi. P. - BIOCHEMISTRY	23/08/2022
Comp. Dt. : 22/10/2022 Status : Completed								
279	22100750	BIOCHEMISTRY-- -COLLEGE	(2051) SYSTEM VIRUS PROBLEM	Jayaraj. J.	virus scanned and reconnect domain		Suganthi. P. - BIOCHEMISTRY	25/10/2022
Comp. Dt. : 14/11/2022 Status : Completed								
280	22110511	BIOCHEMISTRY-- -COLLEGE	IN SYSTEM -INTERNET NOT CONNECTING	Jayaraj. J.	CONNECTED WORKING		Suganthi. P. - BIOCHEMISTRY	14/11/2022
Comp. Dt. : 22/11/2022 Status : Completed								
281	22110952	BIOCHEMISTRY-- -COLLEGE	STUDENT BIOMETRIC MACHINE NOT WORKING	Valamburi. R.	ready working fine..		Suganthi. P. - BIOCHEMISTRY	25/11/2022
Comp. Dt. : 17/04/2023 Status : Completed								
282	23040504	BIOCHEMISTRY-- -COLLEGE	NET WORK PROBLEM IN C R LAB	Balachandar. A.,Valamburi. R.,Selvam. D.	patch cable refixed		Anusuya. J. - BIOCHEMISTRY	19/04/2023
Comp. Dt. : 19/04/2023 Status : Completed								
283	23040606	BIOCHEMISTRY-- -COLLEGE	PRINTER NOT WORKING	Selvam. D.	PRINTER WORKING		Suganthi. P. - BIOCHEMISTRY	19/04/2023
Comp. Dt. : 27/04/2023 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
284	23040927	BIOCHEMISTRY-- -COLLEGE	NEED TO CHECK KEY BOARD - NOT WORKING	Jayaraj. J.	KEYBOARD CLEAN AND REFIXED		Suganthi. P. - BIOCHEMISTRY	28/04/2023
Comp. Dt. : 13/06/2023 Status : Completed								
285	23060437	BIOCHEMISTRY-- -COLLEGE	PROJECTOR LENS NOT CLEAR IN DEMO ROOM	Madhubalan. S.	PROJECTOR WORKING		Suganthi. P. - BIOCHEMISTRY	09/09/2023
Dept Name : COMMUNITY MEDICINE - Computer Department Comp. Dt. : 13/05/2022 Status : Completed								
286	22050459	COMMUNITY MEDICINE DEPT IN MEDICAL COLLEGE	IN OFFICE-CHANGE PRINTER TONER	Jayaraj. J.	88A TONER CHANGED		Sunitha. P. - COMMUNITY MEDICINE	13/05/2022
Comp. Dt. : 19/05/2022 Status : Completed								
287	22050703	COMMUNITY MEDICINE	PRINTER NOT WORKING IN NAC OFFICE	Madhubalan. S.	12A TONER CHANGED		Rajesh. D. - COMMUNITY MEDICINE	19/05/2022
Comp. Dt. : 01/06/2022 Status : Completed								
288	22060004	COMMUNITY MEDICINE DEPT IN MEDICAL COLLEGE	SYSTEM MONITOR DISPLAY PROBLEM	Valamburi. R.	NEW 19.5 INCH MONITOR CHANGED		Sunitha. P. - COMMUNITY MEDICINE	01/06/2022
289	22060009	COMMUNITY MEDICINE DEPT IN MEDICAL COLLEGE	MOUSE NOT WORKING	Valamburi. R.	working mouse		Raghavendran. V. - COMMUNITY MEDICINE	01/06/2022
Comp. Dt. : 06/06/2022 Status : Completed								
290	22060206	COMMUNITY MEDICINE DEPT IN MEDICAL COLLEGE	NEED TO CHECK SYSTEM [3NOS] NOT WORKING IN EPISTEMOLOGY UNIT	Jayaraj. J.	system not received daily followup		Sunitha. P. - COMMUNITY MEDICINE	21/06/2022
Comp. Dt. : 01/07/2022 Status : Completed								
291	22070007	COMMUNITY MEDICINE DEPT IN MEDICAL COLLEGE	NEED TO CHANGE TONER	Shafiullah. R.	88A TONER CHANGED		Sunitha. P. - COMMUNITY MEDICINE	01/07/2022
Comp. Dt. : 02/09/2022 Status : Completed								
292	22090113	COMMUNITY MEDICINE	PRINTER NOT WORKING	Shafiullah. R.	INK JET PRINTER HEAD CLEAN		Muthuvel. A. - COMMUNITY MEDICINE	05/09/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 13/10/2022								
Status : Completed								
293	22100411	COMMUNITY MEDICINE DEPT IN MEDICAL COLLEGE	PROBLEM IN EJECT PENDRIVE - NEED SUPPORT	Shafiullah. R.	DLAB SYSTEM CHANGED AND 4GB RAM UPGRADEO/S INSTALLED		Murugan.R. - COMMUNITY MEDICINE	19/10/2022
Comp. Dt. : 10/11/2022								
Status : Completed								
294	22110412	PHYSIOLOGY-- -COLLEGE	MEU SYSTEM NOT WORKING	Jayaraj. J.	UNINSTALLED UNWANTED APPS AND VIRUS CLEANED		Raghavendran. V. - COMMUNITY MEDICINE	11/11/2022
Comp. Dt. : 15/11/2022								
Status : Completed								
295	22110634	NAC OFFICE -3RD FLOOR IN MEDICAL COLLEGE	PRINTER NOT WORKING PROPERLY	Valamburi. R.	PRINTER CHECKED WORKING FINE		Rajesh. D. - COMMUNITY MEDICINE	16/11/2022
Comp. Dt. : 02/12/2022								
Status : Completed								
296	22120085	NAC OFFICE -3RD FLOOR IN MEDICAL COLLEGE	NEED TO CHANGE TONER	Shafiullah. R.	12A TONER CHANGED		Rajesh. D. - COMMUNITY MEDICINE	02/12/2022
Comp. Dt. : 02/01/2023								
Status : Completed								
297	23010023	COMMUNITY MEDICINE DEPT IN MEDICAL COLLEGE	SYSTEM NO POWER ON	Jayaraj. J.	MONITOR CABLE REFIXED		Poovizhi. K. - COMMUNITY MEDICINE	02/01/2023
Comp. Dt. : 05/01/2023								
Status : Completed								
298	23010201	COMMUNITY MEDICINE DEPT IN MEDICAL COLLEGE	NEED TO CHANGE TONER	Valamburi. R.	12A TONER CHANGED		Sunitha. P. - COMMUNITY MEDICINE	05/01/2023
Comp. Dt. : 31/01/2023								
Status : Completed								
299	23011094	PHYSIOLOGY-- -COLLEGE	PRINTER PAPER JAM	Shafiullah. R.	paper jam cleared		Raghavendran. V. - COMMUNITY MEDICINE	02/02/2023
Comp. Dt. : 09/02/2023								
Status : Completed								
300	23020342	NAC OFFICE -3RD FLOOR IN MEDICAL COLLEGE	NEED TO CHANGE PRINTER INK	Valamburi. R.	BLACK INK CHANGED		Rajesh. D. - COMMUNITY MEDICINE	09/02/2023
Comp. Dt. : 02/03/2023								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
301	23030079	COMMUNITY MEDICINE DEPT IN MEDICAL COLLEGE	NET WORK PROBLEM IN OFFICE SYSTEM	Madhubalan. S.	NETWORK WORKING		Sunitha. P. - COMMUNITY MEDICINE	02/03/2023
Comp. Dt. : 09/03/2023								
Status : Completed								
302	23030376	COMMUNITY MEDICINE DEPT IN MEDICAL COLLEGE	SYSTEM NOT WORKING	Balachandar. A.	WORKING FINE		Murugan.R. - COMMUNITY MEDICINE	15/03/2023
Comp. Dt. : 28/03/2023								
Status : Completed								
303	23031197	PHYSIOLOGY-- -COLLEGE	PRINTER NOT WORKING	Jayaraj. J.	printer working fine		Raghavendran. V. - COMMUNITY MEDICINE	29/03/2023
304	23031223	COMMUNITY MEDICINE DEPT IN MEDICAL COLLEGE	NEED TO CHANGE TONER [OFFICE ROOM]	Venkatesh. S.	88A toner changed		Sunitha. P. - COMMUNITY MEDICINE	29/03/2023
Comp. Dt. : 31/03/2023								
Status : Completed								
305	23031351	PHYSIOLOGY-- -COLLEGE	NEED TO REFIL PRINTER COLOUR INK	Madhubalan. S.	INK REFIL BLACK		Raghavendran. V. - COMMUNITY MEDICINE	04/04/2023
Comp. Dt. : 12/04/2023								
Status : Completed								
306	23040384	COMMUNITY MEDICINE DEPT IN MEDICAL COLLEGE	PROBELM IN PENDRIVE FIXING	Shafiullah. R.	Antivirus reinstalled		Murugan.R. - COMMUNITY MEDICINE	19/04/2023
Comp. Dt. : 02/05/2023								
Status : Completed								
307	23050062	NAC OFFICE -3RD FLOOR IN MEDICAL COLLEGE	PROBLEM IN KEY BOARD - NEED TO CHANGE	Shafiullah. R.	OLD KEYBOARD GIVEN		Rajesh. D. - COMMUNITY MEDICINE	03/05/2023
Comp. Dt. : 03/05/2023								
Status : Completed								
308	23050086	COMMUNITY MEDICINE DEPT IN MEDICAL COLLEGE	SYSTEM NOT WORKING	Shafiullah. R.	NO DISPLAY RAM CLEAN AND REFIXED		Murugan.R. - COMMUNITY MEDICINE	03/05/2023
Comp. Dt. : 26/05/2023								
Status : Completed								

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
309	23051023	COMMUNITY MEDICINE DEPT IN MEDICAL COLLEGE	NEED SOFTWARE INSTALLATION WORK - COMMUNITY MEDICINE DEPT IN MEDICAL COLLEGE III FLOOR	Jayaraj. J.	NITRO PDF SOFTWARE INSTALLED		Rajesh. D. - COMMUNITY MEDICINE	29/05/2023
Comp. Dt. :		30/05/2023						
Status :		Completed						
310	23051174	COMMUNITY MEDICINE DEPT IN MEDICAL COLLEGE	SYSTEM NOT WORKING	Jayaraj. J.	MONITOR POWER OFF		Murugan.R. - COMMUNITY MEDICINE	30/05/2023
Comp. Dt. :		07/06/2023						
Status :		Completed						
311	23060216	NAC OFFICE -3RD FLOOR IN MEDICAL COLLEGE	SYSTEM NOT WORKING	Harikrishnan. R.	OS and Hard Disk Changed.		Vijai. A. - COMMUNITY MEDICINE	09/06/2023
312	23060240	COMMUNITY MEDICINE DEPT IN MEDICAL COLLEGE	PROBLEM IN NET CONNECTION	Jayaraj. J.	network cable refixed checked working fine..		Sunitha. P. - COMMUNITY MEDICINE	07/06/2023
Comp. Dt. :		09/06/2023						
Status :		Completed						
313	23060313	NAC OFFICE -3RD FLOOR IN MEDICAL COLLEGE	NEED TO REFIL BLACK INK	Harikrishnan. R.	Ink Refilled.		Vijai. A. - COMMUNITY MEDICINE	09/06/2023
Comp. Dt. :		13/06/2023						
Status :		Completed						
314	23060450	COMMUNITY MEDICINE DEPT IN MEDICAL COLLEGE	SYSTEM PROBLEM - "WINDOW'S NOT SUPPORTED	Jayaraj. J.	WINDOWS 10 OS INSTALLED		Murugan.R. - COMMUNITY MEDICINE	16/06/2023
Comp. Dt. :		22/06/2023						
Status :		Completed						
315	23060798	NAC OFFICE -3RD FLOOR IN MEDICAL COLLEGE	NEED TO CHECK SYSTEM - EXCEL NOT WORKING	Jayaraj. J.	Excel setting done		Shruti. V. - COMMUNITY MEDICINE	22/06/2023
Comp. Dt. :		27/06/2023						
Status :		Completed						
316	23061022	COMMUNITY MEDICINE DEPT IN MEDICAL COLLEGE	SYSTEM & SOFTWARE PROBLEM	Jayaraj. J.	share checked fine		Sunitha. P. - COMMUNITY MEDICINE	01/07/2023
Comp. Dt. :		28/06/2023						
Status :		Completed						
317	23061040	NAC OFFICE -3RD FLOOR IN MEDICAL COLLEGE	NEED SYSTEM ANTIVIRUS	Jayaraj. J.	VIRUS CLEAN COMPLETED		Vijai. A. - COMMUNITY MEDICINE	28/06/2023

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Dept Name : Director Office - Computer Department Comp. Dt. : 17/05/2022 Status : Completed								
318	22050622	Director Office	NEED TO CHANGE TONER	Selvam. D.	12A toner changed		Jayasridhar. K. - Director Office	18/05/2022
Comp. Dt. : 19/05/2022 Status : Completed								
319	22050722	Lecture Hall 2	LCD REMOTE NOT WORKING	Jayaraj. J.	LCD BATTERY CHANGED		Prasanna.B. - Director Office	20/05/2022
Comp. Dt. : 30/07/2022 Status : Completed								
320	22071096	COMMUNITY MEDICINE	MOUSE NOT WORKING	Jayaraj. J.	REFIXED CHECKED		Vijai. A. - COMMUNITY MEDICINE	01/08/2022
Dept Name : FORENSIC MEDICINE - Computer Department Comp. Dt. : 20/05/2022 Status : Completed								
321	22050746	FORENSIC MEDICINE (3RD FLOOR) IN COLLEGE	NEED TO CHECK NET CONNETION - MAIL OPTION NOT WORKING	Madhubalan. S.	DATE AND TIME RESTART		Mathavi. B. - FORENSIC MEDICINE	20/05/2022
Comp. Dt. : 08/06/2022 Status : Completed								
322	22060313	FORENSIC MEDICINE (3RD FLOOR) IN COLLEGE	NEED TO CHANGE TIME IN SYSTEM - WRONGLY DISPLAY	Jayaraj. J.	Cmos battery changed		Mathavi. B. - FORENSIC MEDICINE	10/06/2022
Comp. Dt. : 14/07/2022 Status : Completed								
323	22070526	FORENSIC MEDICINE (3RD FLOOR) IN COLLEGE	NEED TO CHANGE TONER	Shafiullah. R.	88A toner changed		Mathavi. B. - FORENSIC MEDICINE	15/07/2022
Comp. Dt. : 20/12/2022 Status : Completed								
324	22120924	FORENSIC MEDICINE	SYSTEM SHIFTING WORK	Balachandar. A.	compliant double entered		Mathavi. B. - FORENSIC MEDICINE	21/12/2022
325	22120925	FORENSIC MEDICINE	SYSTEM SHIFTING WORK	Jayaraj. J.	SYSTEM SHIFTED.		Mathavi. B. - FORENSIC MEDICINE	22/12/2022
Comp. Dt. : 30/12/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
326	22121375	FORENSIC MEDICINE (3RD FLOOR) IN COLLEGE	SYSTEM NETWORK ISSUE	Madhubalan. S.	SYSTEM RESTART WORKING		Mathavi. B. - FORENSIC MEDICINE	30/12/2022
Comp. Dt. : 03/02/2023 Status : Completed								
327	23020108	FORENSIC MEDICINE (3RD FLOOR) IN COLLEGE	NEED TO CHANGE TONER	Prakash. P.	88A toner changed		Mathavi. B. - FORENSIC MEDICINE	06/02/2023
Comp. Dt. : 11/03/2023 Status : Completed								
328	23030459	FORENSIC MEDICINE (3RD FLOOR) IN COLLEGE	SYSTEM - NET WORK PROBLEM - NEED URGENT SERVICE	Jayaraj. J.	NET WORK CABLE REFIXED WORKING FINE		Mathavi. B. - FORENSIC MEDICINE	13/03/2023
Comp. Dt. : 25/03/2023 Status : Completed								
329	23031078	DEAN HOUSE	NEED TO CHECK SYSTEM - DISPLAY - PASSWARD WRONG	Prakash. P.	Domain reconfigure		Mathavi. B. - FORENSIC MEDICINE	27/03/2023
Comp. Dt. : 25/04/2023 Status : Completed								
330	23040806	FORENSIC MEDICINE (3RD FLOOR) IN COLLEGE	NEED TO BE CHANGE KEYBOARD ANOTHER PLACE FOR DEAN SIR FOR DEAN OFFICE	Shafiullah. R.	KEYBOARD ANOTHER PLACE CHANGED		Mathavi. B. - FORENSIC MEDICINE	25/04/2023
Comp. Dt. : 25/05/2023 Status : Completed								
331	23051010	FORENSIC MEDICINE (3RD FLOOR) IN COLLEGE	NEED TO CHECK NET CONNECTION - EXAM PURPOSE - NEED URGENT SERVICE	Raja.B,Prakash. P.,Shafiullah. R.	INTERNET CONNECTED		Mathavi. B. - FORENSIC MEDICINE	25/05/2023
Dept Name : Library - Computer Department Comp. Dt. : 24/01/2023 Status : Completed								
332	23010892	MEDICAL COLLEGE LIBRARY	SOFTWARE PROBLEM - NEED TO CHECK	Raja.B	SOFTWAREWORKING		Lakshmi Gandhan.S. - Library	28/01/2023
Comp. Dt. : 21/02/2023 Status : Completed								
333	23020789	medical college library 2nd floor	SYSTEM NOT WORKING	Valamburi. R.	SYSTEM WORKING		Elangovan.N. - library	21/02/2023
Comp. Dt. : 22/02/2023 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
334	23020831	Library	SYSTEM NOT WORKING	Madhubalan. S.	SYSTEM SMPS DUST CLEAN WORKING FINE		Elangovan.N. - Library	22/02/2023
Comp. Dt. : 21/03/2023 Status : Completed								
335	23030871	MEDICAL COLLEGE LIBRARY	SYSTEM NOT WORKING	Selvam. D.	system working fine		Manimaran. S. - Library	22/03/2023
Comp. Dt. : 28/03/2023 Status : Completed								
336	23031207	MEDICAL COLLEGE LIBRARY	DISPLAY PROBLEM IN MONITOR	Selvam. D.	monitor working fine		Anandhan.R. - Library	29/03/2023
Dept Name : MICROBIOLOGY - Computer Department Comp. Dt. : 16/05/2022 Status : Completed								
337	22050548	MICROBIOLOGY IN COLLEGE	NEED TO CHANGE TONER	Shafiullah. R.	12A TONER CHANGED		Anandh. P. - MICROBIOLOGY	17/05/2022
Comp. Dt. : 24/05/2022 Status : Completed								
338	22050878	MICROBIOLOGY IN COLLEGE	MOUSE NOT WORKING	Madhubalan. S.	MOUSE WORKING FINE		Buvana. C. - MICROBIOLOGY	25/05/2022
Comp. Dt. : 31/05/2022 Status : Completed								
339	22051140	MICROBIOLOGY IN COLLEGE	MOUSE NOT WORKING	Valamburi. R.	NEW USB MOUSE CHANGED		Buvana. C. - MICROBIOLOGY	31/05/2022
Comp. Dt. : 01/06/2022 Status : Completed								
340	22060022	MICROBIOLOGY IN COLLEGE	NEED TO CHANGE TONER	Jayaraj. J.	12A TONER CHANGED		Raffik Moideen. M. - SMV Allied Health Sciences	01/06/2022
Comp. Dt. : 20/06/2022 Status : Completed								
341	22060705	MICROBIOLOGY IN COLLEGE	PRINTER NOT WORKING	Selvam. D.	print que cleared		Buvana. C. - MICROBIOLOGY	20/06/2022
Comp. Dt. : 21/06/2022 Status : Completed								
342	22060751	MICROBIOLOGY IN COLLEGE	NEED TO CHECK PRINTER & SHARE - NAT WORKING	Shafiullah. R.	printer reinstalled and shared..		Praveenkumar. S. - MICROBIOLOGY	23/06/2022
343	22060753	MICROBIOLOGY IN COLLEGE	NEED TO CHANGE TONER	Jayaraj. J.	TONER CHANGED		Buvana. C. - MICROBIOLOGY	21/06/2022
Comp. Dt. : 28/06/2022								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
	Status : Completed							
344	22061018	MICROBIOLOGY	NETWORK PROBLEM(INTERNET NOT WORKING)	Jayaraj. J.	NETWORK CABLE LOOSE CONNECT REFIXED PROBLEM SLOVED		Raffik Moideen. M. - SMV Allied Health Sciences	28/06/2022
	Comp. Dt. : 04/07/2022							
	Status : Completed							
345	22070115	MICROBIOLOGY IN COLLEGE	NEED TO CHECK NET CONNECTION - NOT WORKING	Valamburi. R.	NET CONNECTION WORKING		Mageswari. R. - MICROBIOLOGY	04/07/2022
	Comp. Dt. : 07/07/2022							
	Status : Completed							
346	22070253	MICROBIOLOGY IN COLLEGE	PRINTER NOT WORKING	Jayaraj. J.	usp cable refixed		Mageswari. R. - MICROBIOLOGY	07/07/2022
	Comp. Dt. : 25/07/2022							
	Status : Completed							
347	22070926	MICROBIOLOGY IN COLLEGE	PROBLEM IN MEDPLUS	Shafiullah. R.	medplus setup installed		Praveenkumar. S. - MICROBIOLOGY	25/07/2022
	Comp. Dt. : 30/07/2022							
	Status : Completed							
348	22071094	MICROBIOLOGY IN COLLEGE	PROBLEM IN ATTENDANCE SOFTWARE & NET CONNECTION	Jayaraj. J.	network cable refixed		Raffik Moideen. M. - SMV Allied Health Sciences	02/08/2022
349	22071095	MICROBIOLOGY IN COLLEGE	NEED TO CHANGE TONER	Jayaraj. J.	12 A C TONER CHANGED		Raffik Moideen. M. - SMV Allied Health Sciences	01/08/2022
	Comp. Dt. : 23/08/2022							
	Status : Completed							
350	22080755	MICROBIOLOGY IN COLLEGE	SYSTEM PROBLEM	Prakash. P.	system Ram Clean , system Wroking		Praveenkumar. S. - MICROBIOLOGY	23/08/2022
	Comp. Dt. : 26/08/2022							
	Status : Completed							
351	22080913	MICROBIOLOGY IN COLLEGE	SYSTEM NOT WORKING	Jayaraj. J.	mother board and ram clean and refixed		Praveenkumar. S. - MICROBIOLOGY	05/09/2022
	Comp. Dt. : 29/08/2022							
	Status : Completed							
352	22080989	MICROBIOLOGY IN COLLEGE	SYSTEM NOT WORKING	Jayaraj. J.	system working fine		Buvana. C. - MICROBIOLOGY	02/09/2022
	Comp. Dt. : 30/08/2022							
	Status : Completed							
353	22081044	MICROBIOLOGY IN COLLEGE	PRINTER NOT WORKING	Madhubalan. S.	Printer working fine		Praveenkumar. S. - MICROBIOLOGY	01/09/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 01/09/2022 Status : Completed								
354	22090014	MICROBIOLOGY IN COLLEGE	SYSTEM NOT WORKING	Shafiullah. R.	operating system reinstalled		Praveenkumar. S. - MICROBIOLOGY	03/09/2022
Comp. Dt. : 16/09/2022 Status : Completed								
355	22090653	MICROBIOLOGY IN COLLEGE	PRINTER NOT WORKING	Madhubalan. S.	PRINTER POWER CABLE REFIXED		Buvana. C. - MICROBIOLOGY	16/09/2022
Comp. Dt. : 19/09/2022 Status : Completed								
356	22090752	MICROBIOLOGY IN COLLEGE	NEED TO CHANGE TONER	Prakash. P.	TONER CHANGED		Raffik Moideen. M. - SMV Allied Health Sciences	20/09/2022
Comp. Dt. : 21/09/2022 Status : Completed								
357	22090806	MICROBIOLOGY IN COLLEGE	PRINTER NOT WORKING	Prakash. P.	PRINTER OFFLINE SHOW KNOW WORKING		Raffik Moideen. M. - SMV Allied Health Sciences	21/09/2022
Comp. Dt. : 22/09/2022 Status : Completed								
358	22090866	MICROBIOLOGY IN COLLEGE	PROBLEM IN STUDENT ATTENDANCE SOFTWARE	Shafiullah. R.	ATTENDANCE SOFTWARE UPDATE		Raffik Moideen. M. - SMV Allied Health Sciences	23/09/2022
Comp. Dt. : 30/09/2022 Status : Completed								
359	22091216	MICROBIOLOGY IN COLLEGE	NEED TO CHANGE TONER	Madhubalan. S.	88A toner changed		Buvana. C. - MICROBIOLOGY	30/09/2022
Comp. Dt. : 09/11/2022 Status : Completed								
360	22110364	MICROBIOLOGY IN COLLEGE	CHANGE PRINTER CATRIDGE	Shafiullah. R.	12A toner changed		Raffik Moideen. M. - SMV Allied Health Sciences	10/11/2022
Comp. Dt. : 10/11/2022 Status : Completed								
361	22110391	MICROBIOLOGY IN COLLEGE	NEED TO CHANGE PRINTER TONER (PCR ROOM)	Madhubalan. S.	12A TONER CHANGED		Anandh. P. - MICROBIOLOGY	10/11/2022
Comp. Dt. : 18/11/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
362	22110765	MICROBIOLOGY IN COLLEGE	NET WORK PROBLEM	Murugavel.R	system restarted..		Raffik Moideen. M. - SMV Allied Health Sciences	18/11/2022
	Comp. Dt. : 24/11/2022							
	Status : Completed							
363	22111026	MICROBIOLOGY IN COLLEGE	CPU NOT WORKING	Madhubalan. S.	virus cleaned working fine		Praveenkumar. S. - MICROBIOLOGY	28/11/2022
	Comp. Dt. : 25/11/2022							
	Status : Completed							
364	22111076	MICROBIOLOGY IN COLLEGE	system no power on	Madhubalan. S.	SYSTEM POWER ON		Mageswari. R. - MICROBIOLOGY	25/11/2022
	Comp. Dt. : 23/12/2022							
	Status : Completed							
365	22121085	MICROBIOLOGY IN COLLEGE	NEED TO CHANGE PRINTER TONER	Madhubalan. S.	88A TONER CHANGED		Mageswari. R. - MICROBIOLOGY	23/12/2022
	Comp. Dt. : 21/02/2023							
	Status : Completed							
366	23020818	MICROBIOLOGY IN COLLEGE	NET PROBLEM	Madhubalan. S.	PACH CARD CABLE REFIXED NET WORKING FINE		Mathu. M. - MICROBIOLOGY	23/02/2023
	Comp. Dt. : 14/03/2023							
	Status : Completed							
367	23030532	MICROBIOLOGY IN COLLEGE	PROBLEM IN NET CONNECTION	Jayaraj. J.	bsnl problem		Yuvaraj. P. - MICROBIOLOGY	15/03/2023
	Comp. Dt. : 29/03/2023							
	Status : Completed							
368	23031250	MICROBIOLOGY IN COLLEGE	NEED TO CHECK SYSTEM VIRUS PROBLEM	Balachandar. A.	SYSTEM ANTIVUS SCANNED AND CLEARED		Nivethighaa. G. - MICROBIOLOGY	30/03/2023
	Comp. Dt. : 30/03/2023							
	Status : Completed							
369	23031300	MICROBIOLOGY IN COLLEGE	NEED TO CHECK NEW SYSTEM - MEDPLUS PROBLEM	Balachandar. A.	checked working fine		Mageswari. R. - MICROBIOLOGY	30/03/2023
	Comp. Dt. : 31/03/2023							
	Status : Completed							
370	23031336	MICROBIOLOGY IN COLLEGE	DUE TO SQUIRREL BITED, PROJECTOR SCREEN DAMAGE IN DEMO "B"	Shafiullah. R.	NEW SCREEN FIXED		Mageswari. R. - MICROBIOLOGY	12/06/2023
	Comp. Dt. : 22/04/2023							


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
371	23040706	MICROBIOLOGY IN COLLEGE	NEED TO CHANGE TONER	Harikrishnan. R.	88A Toner Changed		Mageswari. R. - MICROBIOLOGY	22/04/2023
Comp. Dt. : 17/05/2023								
Status : Completed								
372	23050711	MICROBIOLOGY IN COLLEGE	PRINTER NOT WORKING	Madhubalan. S.	printer working fine		Mageswari. R. - MICROBIOLOGY	18/05/2023
Comp. Dt. : 26/05/2023								
Status : Completed								
373	23051057	MICROBIOLOGY IN COLLEGE	NEED TO CHANGE TONER	Prakash. P.	88A Com Toner Changed		Mageswari. R. - MICROBIOLOGY	26/05/2023
Comp. Dt. : 02/06/2023								
Status : Completed								
374	23060069	MICROBIOLOGY IN COLLEGE	SYSTEM NET WORK PROBLEM - [OLD SYSTEM]	Harikrishnan. R.	INTER NET WORKING FINE		Mageswari. R. - MICROBIOLOGY	02/06/2023
Comp. Dt. : 15/06/2023								
Status : Completed								
375	23060551	MICROBIOLOGY IN COLLEGE	SYSTEM NETWORK PROBLEM	Prakash. P.	net cable unplugged, working		Mageswari. R. - MICROBIOLOGY	15/06/2023
Comp. Dt. : 24/06/2023								
Status : Completed								
376	23060896	MICROBIOLOGY IN COLLEGE	DISPLAY PROBLEM IN SYSTEM [NEW SYSTEM]	Selvam. D.	working fine		Mageswari. R. - MICROBIOLOGY	24/06/2023
Comp. Dt. : 26/06/2023								
Status : Completed								
377	23060930	MICROBIOLOGY IN COLLEGE	SYSTEM [OLD - 2NOS] NOT WORKING -	Harikrishnan. R.	System Restarted.		Mageswari. R. - MICROBIOLOGY	27/06/2023
Comp. Dt. : 28/06/2023								
Status : Completed								
378	23061081	MICROBIOLOGY IN COLLEGE	SYSTEM NOT WORKING [OLD SYSTEM]	Jayaraj. J.	virus problem,virus scanned		Mageswari. R. - MICROBIOLOGY	01/07/2023
Dept Name : MS Office - Computer Department								
Comp. Dt. : 23/02/2023								
Status : Completed								
379	23020906	MEDICAL COLLEGE III FLOOR	NET WORK PROBLEM - SIMULATION LAB	Valamburi. R.	working fine		Jayasri. S. - Skill Lab	27/02/2023
Comp. Dt. : 27/02/2023								

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
380	23021011	MEDICAL COLLEGE	NET WORK PROBLEM IN SIMULATION LAB	Selvam. D.	network done		Jayasri. S. - Skill Lab	27/02/2023
Comp. Dt. : 04/05/2023								
Status : Completed								
381	23050162	SKILL LAB - MEDICAL COLLEGE	SYSTEM NOT WORKING	Shafiullah. R.	projector speak sound setting		Elumalai. M. - MS Office	04/05/2023
Dept Name : PATHOLOGY - Computer Department								
Comp. Dt. : 06/05/2022								
Status : Completed								
382	22050198	PATHOLOGY IN COLLEGE	NEED TO CHANGE TONER [2NOS]	Jayaraj. J.	TONER CHANGED...		Sathia Rajesh. C. - PATHOLOGY	06/05/2022
Comp. Dt. : 20/05/2022								
Status : Completed								
383	22050753	PATHOLOGY IN COLLEGE	NEED TO CHANGE TONER	Jayaraj. J.	88A TONER CHANGED		Thavamani. K. - PATHOLOGY	20/05/2022
Comp. Dt. : 02/06/2022								
Status : Completed								
384	22060048	PATHOLOGY IN COLLEGE	NEED TO CHANGE TONER	Valamburi. R.	TONER CHANGED		Kalaichelvi.M. - PATHOLOGY	03/06/2022
Comp. Dt. : 06/06/2022								
Status : Completed								
385	22060198	PATHOLOGY IN COLLEGE	SYSTEM NOT WORKING	Jayaraj. J.	power cable refixed..		Thavamani. K. - PATHOLOGY	06/06/2022
386	22060210	PATHOLOGY IN COLLEGE	C P U NOT WORKING	Jayaraj. J.	power cable refixed		Thavamani. K. - PATHOLOGY	06/06/2022
387	22060222	PATHOLOGY IN COLLEGE	PROBLEM IN STUDENT'S SOFTWARE - NOT OPENED	Balachandar. A.	student software reinstalled		Thavamani. K. - PATHOLOGY	06/06/2022
Comp. Dt. : 16/06/2022								
Status : Completed								
388	22060615	PATHOLOGY IN COLLEGE	PRINTER NOT WORKING	Selvam. D.	working fine		Thavamani. K. - PATHOLOGY	16/06/2022
Comp. Dt. : 21/06/2022								
Status : Completed								
389	22060763	PATHOLOGY IN COLLEGE	NEED TO CHANGE TONER	Jayaraj. J.	TONER CHANGED		Kalaichelvi.M. - PATHOLOGY	21/06/2022
Comp. Dt. : 24/06/2022								
Status : Completed								
390	22060881	PATHOLOGY IN COLLEGE	PROBLEM IN NET CONNECTION	Balachandar. A.	cmos battery changed..		Sathia Rajesh. C. - PATHOLOGY	24/06/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 09/07/2022 Status : Completed								
391	22070369	PATHOLOGY IN COLLEGE	NEED TO CHANGE TONER	Selvam. D.	toner changed		Thavamani. K. - PATHOLOGY	13/07/2022
Comp. Dt. : 24/08/2022 Status : Completed								
392	22080815	PATHOLOGY IN COLLEGE	NEED TO CHANGE TONER	Shafiullah. R.	12A TONER CHANGED		Kalaichelvi.M. - PATHOLOGY	24/08/2022
Comp. Dt. : 06/09/2022 Status : Completed								
393	22090248	PATHOLOGY IN COLLEGE	NEED TO CHANGE TONER	Shafiullah. R.	88A TONER CHANGED		Thavamani. K. - PATHOLOGY	07/09/2022
Comp. Dt. : 10/09/2022 Status : Completed								
394	22090404	PATHOLOGY IN COLLEGE	NEED SOFTWARE UPDATE	Prakash. P.	ms office reinstalled..		Sathia Rajesh. C. - PATHOLOGY	12/09/2022
Comp. Dt. : 14/09/2022 Status : Completed								
395	22090538	PATHOLOGY IN COLLEGE	PROBLEM IN SYSTEM SCREEN - DISPLAY	Madhubalan. S.	SYSTEM VIDEO DRIVE UPDATE		Thavamani. K. - PATHOLOGY	16/09/2022
Comp. Dt. : 20/09/2022 Status : Completed								
396	22090757	PATHOLOGY IN COLLEGE	NEED TO CHANGE TONER	Prakash. P.	TONER CHANGED		Kalaichelvi.M. - PATHOLOGY	20/09/2022
Comp. Dt. : 23/09/2022 Status : Completed								
397	22090917	PATHOLOGY IN COLLEGE	NEED TO CHANGE MOUSE - DEMO 1 SYSTEM	Jayaraj. J.	OLD MOUSE CHANGED		Thavamani. K. - PATHOLOGY	28/09/2022
Comp. Dt. : 05/10/2022 Status : Completed								
398	22100044	PATHOLOGY IN COLLEGE	PROBLEM IN MONITOR	Madhubalan. S.	VGA CABLE ADJUSTMENT		Sathia Rajesh. C. - PATHOLOGY	05/10/2022
Comp. Dt. : 21/10/2022 Status : Completed								
399	22100732	PATHOLOGY IN COLLEGE	PDF FILE NOT OPENING	Jayaraj. J.	Setting changed		Thavamani. K. - PATHOLOGY	22/10/2022
Comp. Dt. : 07/11/2022								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
400	22110228	PATHOLOGY IN COLLEGE	SYSTEM NOT WORKING	Jayaraj. J.	install anti virus		Sathia Rajesh. C. - PATHOLOGY	07/11/2022
Comp. Dt. : 11/11/2022								
Status : Completed								
401	22110457	College - Pathalogy	CHANGE PRINTER TONER	Madhubalan. S.	12A TONER CHANGED		Kalaichelvi.M. - PATHOLOGY	11/11/2022
402	22110484	PATHOLOGY IN COLLEGE	IN SYSTEM NETWORK WORKING SLOWLY	Jayaraj. J.	I\O CHANGE AND SWITCH RESTARED		Sathia Rajesh. C. - PATHOLOGY	21/11/2022
Comp. Dt. : 24/11/2022								
Status : Completed								
403	22111025	PATHOLOGY IN COLLEGE	CHANGE PRINTER TONER	Jayaraj. J.	printer working fine		Sathia Rajesh. C. - PATHOLOGY	28/11/2022
Comp. Dt. : 25/11/2022								
Status : Completed								
404	22111115	PATHOLOGY IN COLLEGE	CHANGE PRINTER TONER	Jayaraj. J.	Printer working fine		Thavamani. K. - PATHOLOGY	28/11/2022
Comp. Dt. : 10/12/2022								
Status : Completed								
405	22120464	PATHOLOGY IN COLLEGE	SYSTEM NOT WORKING	Jayaraj. J.	I\O CABLE REFIXED		Muthamil.K. - PATHOLOGY	10/12/2022
Comp. Dt. : 12/12/2022								
Status : Completed								
406	22120539	PATHOLOGY IN COLLEGE	MEDPLUS SOFTWARE NOT WORKING	Murugavel.R	MEDPLUS SOFTWARE WORKING		Kalaichelvi.M. - PATHOLOGY	12/12/2022
Comp. Dt. : 13/12/2022								
Status : Completed								
407	22120568	PATHOLOGY IN COLLEGE	NEED TO CHANGE TONER	Shafiullah. R.	12A TONER CHANGED		Kalaichelvi.M. - PATHOLOGY	13/12/2022
408	22120577	PATHOLOGY IN COLLEGE	NEED TO CHANGE TONER [AGAIN]	Shafiullah. R.	88A TONER CHANGED		Sathia Rajesh. C. - PATHOLOGY	13/12/2022
Comp. Dt. : 15/12/2022								
Status : Completed								
409	22120673	PATHOLOGY IN COLLEGE	SYSTEM NOT WORKING	Shafiullah. R.	SYSTEM WORKING		Kalaichelvi.M. - PATHOLOGY	15/12/2022
410	22120736	PATHOLOGY IN COLLEGE	NEED TO CHECK NET CONNECTION - PPROBLEM	Shafiullah. R.	NETWORK RACK PROBLEM		Kalaichelvi.M. - PATHOLOGY	15/12/2022
Comp. Dt. : 20/12/2022								
Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
411	22120900	PATHOLOGY IN COLLEGE	MEDPLUS NOT WORKING	Jayaraj. J.	network issue working fine..		Kalaichelvi.M. - PATHOLOGY	21/12/2022
	Comp. Dt. : 09/01/2023							
	Status : Completed							
412	23010331	PATHOLOGY IN COLLEGE	CHANGE PRINTER TONER	Valamburi. R.	PRINTER TONER CHANGED		Kalaichelvi.M. - PATHOLOGY	09/01/2023
	Comp. Dt. : 14/01/2023							
	Status : Completed							
413	23010585	PATHOLOGY IN COLLEGE	NETWORK PROBLEM	Jayaraj. J.	WORKING FINE		Kalaichelvi.M. - PATHOLOGY	14/01/2023
	Comp. Dt. : 07/02/2023							
	Status : Completed							
414	23020210	PATHOLOGY IN COLLEGE	NEED TO CHANGE TONER	Madhubalan. S.	12A TONER CHANGED		Kalaichelvi.M. - PATHOLOGY	07/02/2023
	Comp. Dt. : 17/02/2023							
	Status : Completed							
415	23020709	PATHOLOGY IN COLLEGE	NEED TO CHANGE TONER	Shafiullah. R.	88A TONER CHANGED		Sathia Rajesh. C. - PATHOLOGY	17/02/2023
	Comp. Dt. : 13/03/2023							
	Status : Completed							
416	23030474	PATHOLOGY IN COLLEGE	NEED TO CHANGE TONER	Harikrishnan. R.	12A TONER CHANGED		Kalaichelvi.M. - PATHOLOGY	13/03/2023
	Comp. Dt. : 16/03/2023							
	Status : Completed							
417	23030642	PATHOLOGY IN COLLEGE	FOLDER NOT OPENED IN L C D	Venkatesh. S.	Folder opened		Thavamani. K. - PATHOLOGY	16/03/2023
	Comp. Dt. : 27/03/2023							
	Status : Completed							
418	23031091	PATHOLOGY IN COLLEGE	NEED TO CHANGE TONER	Harikrishnan. R.	88A TONER CHANGED		Thavamani. K. - PATHOLOGY	27/03/2023
419	23031119	PATHOLOGY IN COLLEGE	SYSTEM NET WORK PROBLEM	Jayaraj. J.	SYSTEM WORKING		Sathia Rajesh. C. - PATHOLOGY	28/03/2023
	Comp. Dt. : 28/03/2023							
	Status : Completed							
420	23031142	PATHOLOGY IN COLLEGE	NEED TO CHECK SYSTEM - MEDPLUS NOT WORKING	Madhubalan. S.	REFIX THE PATCH CARD		Kalaichelvi.M. - PATHOLOGY	28/03/2023
	Comp. Dt. : 04/04/2023							
	Status : Completed							


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
421	23040113	PATHOLOGY IN COLLEGE	MONITOR NOT WORKING	Valamburi. R.	monitor changed		Sathia Rajesh. C. - PATHOLOGY	11/04/2023
	Comp. Dt. : 19/04/2023							
	Status : Completed							
422	23040578	PATHOLOGY IN COLLEGE	NEED TO CHANGE TONER	Selvam. D.	12A toner changed		Kalaichelvi.M. - PATHOLOGY	19/04/2023
	Comp. Dt. : 05/05/2023							
	Status : Completed							
423	23050195	PATHOLOGY IN COLLEGE	MEDPLUS NOT WORKING	Jayaraj. J.	MEDPLUS SETTING CHANGED		Sathia Rajesh. C. - PATHOLOGY	06/05/2023
	Comp. Dt. : 09/05/2023							
	Status : Completed							
424	23050388	PATHOLOGY IN COLLEGE	PRINTER PAPER STUCK	Shafiullah. R.	PAPPER JAM CLEAR WORKING FINE		Thavamani. K. - PATHOLOGY	11/05/2023
	Comp. Dt. : 22/05/2023							
	Status : Completed							
425	23050853	PATHOLOGY IN COLLEGE	NEED TO CHANGE TONER	Harikrishnan. R.	12A TONER CHANGED		Kalaichelvi.M. - PATHOLOGY	22/05/2023
	Comp. Dt. : 29/05/2023							
	Status : Completed							
426	23051115	PATHOLOGY IN COLLEGE	NET WORK FAILURE	Murugavel.R	SWITCH ISSUE REPLACE THE NEW SWITCH		Sathia Rajesh. C. - PATHOLOGY	30/05/2023
	Comp. Dt. : 09/06/2023							
	Status : Completed							
427	23060338	PATHOLOGY IN COLLEGE	SYSTEM NOT WORKING	Shafiullah. R.	MEDPLUS SOFTWARE WORING		Kalaichelvi.M. - PATHOLOGY	09/06/2023
	Comp. Dt. : 15/06/2023							
	Status : Completed							
428	23060540	PATHOLOGY IN COLLEGE	(2010) NEED TO CHANGE PRINTER TONER	Prakash. P.	12A Comp Toner Changed		Sathia Rajesh. C. - PATHOLOGY	15/06/2023
	Comp. Dt. : 21/06/2023							
	Status : Completed							
429	23060755	PATHOLOGY IN COLLEGE	NEED TO CHANGE TONER	Harikrishnan. R.	88A Toner Changed.		Thavamani. K. - PATHOLOGY	21/06/2023
	Comp. Dt. : 23/06/2023							
	Status : Completed							
430	23060864	PATHOLOGY IN COLLEGE	SYSTEM NOT WORKING	Balachandar. A.	HEATZINK FAN CHANGED		Thavamani. K. - PATHOLOGY	23/06/2023

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Dept Name : PHARMACOLOGY - Computer Department Comp. Dt. : 22/06/2022 Status : Completed								
431	22060789	PHARMACOLOGY	NEED TO CHANGE TONER	Madhubalan. S.	12A TONER CHANGED		Devanathan. S. - PHARMACOLOGY	22/06/2022
Comp. Dt. : 05/07/2022 Status : Completed								
432	22070148	PHARMACOLOGY	MOUSE NOT WORKING - HOD SYSTEM	Jayaraj. J.	OLD MOUSE CHANGED		Panchali. P. - PHARMACOLOGY	05/07/2022
Comp. Dt. : 14/07/2022 Status : Completed								
433	22070533	PHARMACOLOGY	PRINTER NOT WORKING	Madhubalan. S.	RESTARTED COMPLETED		Panchali. P. - PHARMACOLOGY	14/07/2022
Comp. Dt. : 18/07/2022 Status : Completed								
434	22070652	PHARMACOLOGY	PRINTER NOT WORKING	Shafiullah. R.	TONER REFIXED		Panchali. P. - PHARMACOLOGY	18/07/2022
Comp. Dt. : 10/08/2022 Status : Completed								
435	22080369	PHARMACOLOGY	PROBLEM IN PROJECTOR	Shafiullah. R.	PROJECTOR WORKING SYSTEM VIRUS SCAN SHORT CUT VIRUS REMOVE		Panchali. P. - PHARMACOLOGY	11/08/2022
Comp. Dt. : 03/09/2022 Status : Completed								
436	22090136	PHARMACOLOGY	NEED TO CHECK PRINTER - & TONER PROBLEM	Jayaraj. J.	88A TONER CHANGED		Panchali. P. - PHARMACOLOGY	03/09/2022
Comp. Dt. : 12/12/2022 Status : Completed								
437	22120547	PHARMACOLOGY	CHANGE PRINTER TONER	Shafiullah. R.	88 TONER CHANGED		Panchali. P. - PHARMACOLOGY	13/12/2022
Comp. Dt. : 07/03/2023 Status : Completed								
438	23030274	PHARMACOLOGY	SYSTEM NOT OPENED AT DEMO ROOM	Madhubalan. S.	SYSTEM RESTARED		Devanathan. S. - PHARMACOLOGY	07/03/2023
Comp. Dt. : 08/03/2023 Status : Completed								
439	23030322	PHARMACOLOGY	NEED TO CHANGE TONER	Madhubalan. S.	88A TONER CHANGED		Nageswari. S. - PHARMACOLOGY	08/03/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Dept Name : PHYSIOLOGY - Computer Department Comp. Dt. : 18/05/2022 Status : Completed								
440	22050682	PHYSIOLOGY-- -COLLEGE	NEED TO CHANGE TONER	Madhubalan. S.	88a toner changed		Shanthini. M. - BIOCHEMISTRY	19/05/2022
Comp. Dt. : 20/05/2022 Status : Completed								
441	22050731	PHYSIOLOGY-- -COLLEGE	SYSTEM NOT WORKING	Madhubalan. S.	SYSTEM WORKING FINE		Shanthini. M. - BIOCHEMISTRY	20/05/2022
Comp. Dt. : 20/06/2022 Status : Completed								
442	22060719	PHYSIOLOGY-- -COLLEGE	NEED TO CHANGE TONER FOR HOD SIR ROOM	Jayaraj. J.	88A toner changed		Shanthini. M. - BIOCHEMISTRY	20/06/2022
Comp. Dt. : 23/08/2022 Status : Completed								
443	22080767	PHYSIOLOGY-- -COLLEGE	SYSTEM NOT WORKING	Prakash. P.	Excel problem resolved		Shanthini. M. - BIOCHEMISTRY	23/08/2022
Comp. Dt. : 14/09/2022 Status : Completed								
444	22090564	PHYSIOLOGY-- -COLLEGE	NEED TO CHANGE TONER	Madhubalan. S.	88A toner changed		Shanthini. M. - BIOCHEMISTRY	15/09/2022
Comp. Dt. : 17/10/2022 Status : Completed								
445	22100554	PHYSIOLOGY-- -COLLEGE	NEED TO CHECK SYSTEM - NOT WORKING [HOD SIR SYSTEM]	Jayaraj. J.	UPS PROBLEM NOW WORKING		Shanthini. M. - BIOCHEMISTRY	17/10/2022
Comp. Dt. : 11/11/2022 Status : Completed								
446	22110480	PHYSIOLOGY-- -COLLEGE	SYSTEM GETTING HANGED	Jayaraj. J.	AHS SOFTWARE REINSTALLED		Jayanthi.A. - PHYSIOLOGY	15/11/2022
Comp. Dt. : 24/11/2022 Status : Completed								
447	22111033	PHYSIOLOGY-- -COLLEGE	SYSTEM NOT WORKING AND INTERNET NOT CONNECTING	Jayaraj. J.	INTERNET WORKING		Jayanthi.A. - PHYSIOLOGY	26/11/2022
Comp. Dt. : 06/12/2022 Status : Completed								
448	22120230	PHYSIOLOGY-- -COLLEGE	SYSTEM NETWORK CONNECTING ISSUE	Jayaraj. J.	power issue		Jayanthi.A. - PHYSIOLOGY	07/12/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 09/12/2022 Status : Completed								
449	22120403	PHYSIOLOGY-- -COLLEGE	SYSTEM NOT WORKING	Jayaraj. J.	cpu fan and cmos battery changed		Jayanthi.A. - PHYSIOLOGY	16/12/2022
Comp. Dt. : 27/12/2022 Status : Completed								
450	22121209	PHYSIOLOGY-- -COLLEGE	CHANGE PRINTER TONER	Shafiullah. R.	88A TONER CHANGED		Jayanthi.A. - PHYSIOLOGY	27/12/2022
Comp. Dt. : 15/02/2023 Status : Completed								
451	23020596	PHYSIOLOGY-- -COLLEGE	U P S NOT WORKING	Madhubalan. S.,Selvam. D.,Shafiullah. R.	power switch changed		Shanthini. M. - BIOCHEMISTRY	23/05/2023
Comp. Dt. : 13/03/2023 Status : Completed								
452	23030509	PHYSIOLOGY-- -COLLEGE	SYSTEM NOT WORKING	Murugavel.R	NEW SMPS CHANGED		Shanthini. M. - BIOCHEMISTRY	14/03/2023
Comp. Dt. : 08/04/2023 Status : Completed								
453	23040234	PHYSIOLOGY-- -COLLEGE	STUDENT'S BIO METRIC MACHINE NOT WORKING	Shafiullah. R.	POWER ADAPTER CHANGED BIO MATRIC MACHINE WORKING		Jayanthi.A. - PHYSIOLOGY	08/04/2023
Comp. Dt. : 05/05/2023 Status : Completed								
454	23050197	PHYSIOLOGY-- -COLLEGE	NEED SYSTEM SERVICE	Jayaraj. J.	WORKING FINE		Shanthini. M. - BIOCHEMISTRY	05/05/2023
Comp. Dt. : 23/05/2023 Status : Completed								
455	23050920	PHYSIOLOGY-- -COLLEGE	PRINTER NOT WORKING	Selvam. D.	scanner unit cleaned and refixed		Jayanthi.A. - PHYSIOLOGY	29/05/2023
Comp. Dt. : 23/06/2023 Status : Completed								
456	23060891	PHYSIOLOGY-- -COLLEGE	NEED TO CHECK L C D SYSTEM NOT WORKING - DEMO ROOM 2	Madhubalan. S.	SMPS CHANGED		Jayanthi.A. - PHYSIOLOGY	28/06/2023
Dept Name : Quality Department - Computer Department Comp. Dt. : 05/05/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
457	22050160	FORENSIC MEDICINE (3RD FLOOR) IN COLLEGE	SYSTEM NOT WORKING - NABH CLASS ROOM - [DEMO ROOM]	Jayaraj. J.	cc celar and temp cleared.		Jones Arokiam. M. - Quality Department	07/05/2022
Dept Name : Skill Lab - Computer Department Comp. Dt. : 20/04/2023 Status : Completed								
458	23040657	MEDICAL COLLEGE III FLOOR	NEED TO CHANGE TONER FOR SIMULATION LAB	Harikrishnan. R.	12A TONER CHANGED		Jayasri. S. - Skill Lab	20/04/2023
Comp. Dt. : 22/04/2023 Status : Completed								
459	23040701	SIMULATION LAB - MEDICAL COLLEGE III FLOOR	NEED TO INSERT I P ADDRESS	Balachandar. A.	IP GIVEN FOR SKILL LAB		Jayasri. S. - Skill Lab	02/05/2023
Comp. Dt. : 12/05/2023 Status : Completed								
460	23050507	SIMULATION LAB - MEDICAL COLLEGE III FLOOR	SYSTEM NOT WORKING	Shafiullah. R.	SYSTE WORKING FINE		Jayasri. S. - Skill Lab	12/05/2023
Comp. Dt. : 14/06/2023 Status : Completed								
461	23060478	SIMULATION LAB - MEDICAL COLLEGE III FLOOR	C P U NOT WORKING - POWER OFF	Madhubalan. S.	SYSTEM WORKING FINE SMPS DRAIN		Jayasri. S. - Skill Lab	14/06/2023
Dept Name : SMV Allied Health Sciences - Computer Department Comp. Dt. : 09/05/2022 Status : Completed								
462	22050294	MICROBIOLOGY IN COLLEGE	PRINTER NOT WORKING - [AHS OFFICE ROOM]	Jayaraj. J.	PRINTER DRIVER REINSTALLED		Selvasundari. R. - SMV Allied Health Sciences	09/05/2022
Comp. Dt. : 02/12/2022 Status : Completed								
463	22120095	MICROBIOLOGY IN COLLEGE	NETWORK PROBLEM IN TUTOR ROOM	Valamburi. R.	NO INTERNET CONNECTION		Raffik Moideen. M. - SMV Allied Health Sciences	02/12/2022
Comp. Dt. : 05/12/2022 Status : Completed								
464	22120207	LECTURE HALL V	IN MEDICAL COLLEGE-CAMERA NOT CONNECTIONG INTO THE SYSTEM	Prakash. P.	reinstalled the kvms software		Raffik Moideen. M. - SMV Allied Health Sciences	06/12/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 15/12/2022								
Status : Completed								
465	22120734	MICROBIOLOGY IN COLLEGE	NEED TO CHECK NET CONNECTION - NOT WORKING	Shafiullah. R.	INTERNET WORKING		Raffik Moideen. M. - SMV Allied Health Sciences	15/12/2022
Comp. Dt. : 01/02/2023								
Status : Completed								
466	23020019	MICROBIOLOGY IN COLLEGE	NEED TO CHANGE TONER	Valamburi. R.	12A TONER CHANGED		Raffik Moideen. M. - SMV Allied Health Sciences	02/02/2023
Comp. Dt. : 06/04/2023								
Status : Completed								
467	23040185	MICROBIOLOGY IN COLLEGE	PROBLEM IN MONITOR DISPLAY	Harikrishnan. R.	moniter Chaged		Raffik Moideen. M. - SMV Allied Health Sciences	12/04/2023
Comp. Dt. : 26/04/2023								
Status : Completed								
468	23040850	MICROBIOLOGY IN COLLEGE	STUDENT ATTENDANCE SOFTWARE NOT WORKING	Balachandar. A.	fibrecable cut		Raffik Moideen. M. - SMV Allied Health Sciences	26/04/2023
Comp. Dt. : 05/06/2023								
Status : Completed								
469	23060157	MICROBIOLOGY IN COLLEGE	STUDENTS ATTENDANCE SOFTWARE NOT WORKING & NEED TO CHANGE TONER	Jayaraj. J.	students software installed and toner changed		Raffik Moideen. M. - SMV Allied Health Sciences	06/06/2023
Comp. Dt. : 23/06/2023								
Status : Completed								
470	23060848	Allied Health Sciences	NEED TO CHECK SYSTEM - CAMERA SOFTWARE NOT WORKING	Shafiullah. R.	SOFTWARE CONFIGURATION		Raffik Moideen. M. - SMV Allied Health Sciences	23/06/2023
Work Type : Network Cables								
Dept Name : MICROBIOLOGY - Computer Department								
Comp. Dt. : 22/07/2022								
Status : Completed								
471	22070821	MICROBIOLOGY IN COLLEGE	NEED TO CHECK NET CONNECTION - NOT WORKING	Jayaraj. J.	CHECKED AND RE FIXED WORKING FINE		Raffik Moideen. M. - SMV Allied Health Sciences	22/07/2022

College Name : SMVMCH-HOS

Work Type : Complaint

Dr. KAGNE. R.N.
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Dept Name : Administration - Computer Department Comp. Dt. : 04/05/2022 Status : Completed								
472	22050083	AO Office	NEED TO CHECK BROTHER PRINTER - PAPER JAM	Selvam. D.	paper jam clear		Kanimozhi. D. - Administration	04/05/2022
473	22050091	AO Office	NEED TO CHANGE TONER	Selvam. D.	Toner Changed		Saravanan. R. - Administration	04/05/2022
Comp. Dt. : 06/05/2022 Status : Completed								
474	22050189	General Stores[Linen]	U P S NOT WORKING	Selvam. D.	Lithium battery changed		Motheeswarar. R.S. - Administration	09/05/2022
Comp. Dt. : 11/05/2022 Status : Completed								
475	22050391	AO Office	(1177) PAPER JAMMED IN PRINTER-NEED TO FIX	Jayaraj. J.	PAPER JAM CLEARED		Sankardevi. G. - Administration	12/05/2022
Comp. Dt. : 16/05/2022 Status : Completed								
476	22050568	AO Office	KEYBOARD NOT WORKING	Valamburi. R.	KEYBOARD CLEAN AND REFIXED		Muthukrishnan. S. - Administration	18/05/2022
477	22050572	OSD	PROBLEM IN PRINTER - NEED TO CHECK	Madhubalan. S.	12a tonner refixed		Sugumaran. P. - Administration	18/05/2022
Comp. Dt. : 19/05/2022 Status : Completed								
478	22050698	AO Office	SYSTEM NOT WORKING	Selvam. D.	On/off switch serviced		Sumathy.R - Administration	19/05/2022
Comp. Dt. : 24/05/2022 Status : Completed								
479	22050860	AO Office	UPS SOUND PROBLEM - [MANI SIR SYSTEM]	Balachandar. A.	fan dust cleaned		Saravanan. R. - Administration	24/05/2022
480	22050917	AO Office	NEED TO CHANGE TONER	Shafiullah. R.	12A TONER CHANGED		Roopa. S. - Administration	24/05/2022
Comp. Dt. : 31/05/2022 Status : Completed								
481	22051139	AO Office	MOUSE NOT WORKING	Selvam. D.	usb mouse changed		Kathiravan. K. - Administration	31/05/2022
Comp. Dt. : 08/06/2022 Status : Completed								
482	22060321	AO Office	PRINTER NOT WORKING	Selvam. D.	toner sensor refixed and tested the printer working fine		Joupramanien.S. - Administration	09/06/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 10/06/2022								
Status : Completed								
483	22060379	AO Office	CHANGE PRINTER TONER	Balachandar. A.	PRINTER TONER CHANGED		Saravanan. R. - Administration	11/06/2022
Comp. Dt. : 13/06/2022								
Status : Completed								
484	22060445	AO Office	NEED TO CHANGE TONER	Jayaraj. J.	12A TONER CHANGED		Shyamala. R. - Administration	13/06/2022
Comp. Dt. : 15/06/2022								
Status : Completed								
485	22060587	General Stores[Linen]	NEED TO CHANGE PRINTER RIBBON	Balachandar. A.	PRINTER RIBBON CHANGED		Motheeswarar. R.S. - Administration	16/06/2022
Comp. Dt. : 27/06/2022								
Status : Completed								
486	22060972	General Stores[Linen]	PRINTER NOT WORKING	Selvam. D.	10m ribbon changed		Motheeswarar. R.S. - Administration	27/06/2022
Comp. Dt. : 28/06/2022								
Status : Completed								
487	22061008	OSD	PRINTER NOT WORKING	Murugavel.R	12 A TONER CHANGED		Sugumaran. P. - Administration	28/06/2022
Comp. Dt. : 30/06/2022								
Status : Completed								
488	22061118	AO Office	NEED TO CHANGE TONER	Shafiullah. R.	88A TONER CHANGED		Krishnasamy. K - Administration	30/06/2022
Comp. Dt. : 04/07/2022								
Status : Completed								
489	22070117	AO Office	NEED TO CHANGE TONER	Shafiullah. R.	12A TONER CHANGED		Saravanan. R. - Administration	04/07/2022
Comp. Dt. : 05/07/2022								
Status : Completed								
490	22070161	AO Office	NEED TO CHANGE TONER	Selvam. D.	12A toner changed		Kathiravan. K. - Administration	05/07/2022
491	22070164	AO Office	NEED TO CHANGE PRINTER CARTRIDGE - EPSON M205	Selvam. D.	black ink filled		Muthukrishnan. S. - Administration	05/07/2022
Comp. Dt. : 21/07/2022								
Status : Completed								
492	22070799	AO Office	SYSTEM NOT WORKING	Selvam. D.	System restarts working fine		Arumalai.K.A. - Administration	21/07/2022

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHAL KUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 29/07/2022								
Status : Completed								
493	22071068	AO Office	SYSTEM NOT WORKING	Selvam. D.	12A toner changed		Elumalai.K.A. - Administration	29/07/2022
Comp. Dt. : 30/07/2022								
Status : Completed								
494	22071107	AO Office	NEED TO CHANGE TONER	Shafiullah. R.	12a toner changed		Saravanan. R. - Administration	30/07/2022
Comp. Dt. : 02/08/2022								
Status : Completed								
495	22080104	AO Office	NEED TO CHANGE TONER	Balachandar. A.	12A toner changed		Roopa. S. - Administration	03/08/2022
Comp. Dt. : 05/08/2022								
Status : Completed								
496	22080207	AO Office	NEED TO CHANGE TONER	Selvam. D.	12A toner chaged		Kavitha. P. - Administration	06/08/2022
Comp. Dt. : 19/08/2022								
Status : Completed								
497	22080609	AO Office	NEED TO CHANGE TONER - HR ASSISTANT CABIN	Selvam. D.	12A toner changed		Saravanan. R. - Administration	19/08/2022
Comp. Dt. : 03/09/2022								
Status : Completed								
498	22090129	AO Office	SYSTEM NOT WORKING	Selvam. D.	Ram cleaned and refixed		Elumalai.K.A. - Administration	03/09/2022
Comp. Dt. : 05/09/2022								
Status : Completed								
499	22090189	AO Office	NEED TO CHANGE TONER	Shafiullah. R.	12A TONER CHANGED		Swaadhika. C. - Administration	05/09/2022
Comp. Dt. : 06/09/2022								
Status : Completed								
500	22090219	General Stores[Linen]	SLOW PROBLEM IN NETWORK	Selvam. D.	patch cable refixed		Motheeswarar. R.S. - Administration	06/09/2022
Comp. Dt. : 09/09/2022								
Status : Completed								
501	22090361	AO Office	NEED TO CHANGE TONER	Jayaraj. J.	12A toner changed		Roopa. S. - Administration	09/09/2022
502	22090374	AO Office	NEED TO CHANGE TONER	Valamburi. R.	12A toner changed		Kathiravan. K. - Administration	12/09/2022
Comp. Dt. : 13/09/2022								

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
	Status : Completed							
503	22090492	AO Office	NEED TO CHANGE RIBBON FOR DOT MATRIX PRINTER	Madhubalan. S.	10m ribbon changed		Anbarasan. R. - Administration	13/09/2022
	Comp. Dt. : 23/09/2022							
	Status : Completed							
504	22090930	AO Office	SYSTEM PROBLEM	Jayaraj. J.	Ram cleaed and refixed		Elumalai.K.A. - Administration	26/09/2022
	Comp. Dt. : 26/09/2022							
	Status : Completed							
505	22091016	AO Office	NEED TO CHANGE TONER	Valamburi. R.	toner changed		Saravanan. R. - Administration	26/09/2022
	Comp. Dt. : 27/09/2022							
	Status : Completed							
506	22091071	AO Office	NEED TO CHANGE KEY BOARD - STAND & LETTERS PROBLEM	Valamburi. R.	Usb keyboard changed		Nanthini Devi. R. K. - Administration	29/09/2022
	Comp. Dt. : 28/09/2022							
	Status : Completed							
507	22091136	AO Office	PRINTER NOT WORKING	Selvam. D.	print queue cleared		Nitheeshkumar. D. - Administration	29/09/2022
	Comp. Dt. : 13/10/2022							
	Status : Completed							
508	22100412	AO Office	NEED TO CHANGE TONER	Madhubalan. S.	12a toner changed		Nitheeshkumar. D. - Administration	13/10/2022
	Comp. Dt. : 14/10/2022							
	Status : Completed							
509	22100456	AO Office	NEED TO CHANGE TONER	Selvam. D.	88A TONER CHANGED		Shyamala. R. - Administration	14/10/2022
	Comp. Dt. : 15/10/2022							
	Status : Completed							
510	22100490	AO Office	KEYBOARD NOT WORKING	Madhubalan. S.	REFIX USB CABLE		Nitheeshkumar. D. - Administration	17/10/2022
	Comp. Dt. : 17/10/2022							
	Status : Completed							
511	22100534	AO Office	NEED TO CHANGE PRINTER TONER	Selvam. D.	12A toner changed		Saravanan. R. - Administration	17/10/2022
	Comp. Dt. : 26/10/2022							
	Status : Completed							


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
512	22100805	AO Office	PRINTER PROBLEM	Jayaraj. J.	PRINTE DRIVER UPDATE & PRINTER USB REFIXED		Gunavathi. S. - Administration	26/10/2022
	Comp. Dt. : 02/11/2022							
	Status : Completed							
513	22110028	AO Office	PRINTER NOT WORKING	Balachandar. A.	Printer working fine		Elumalai.K.A. - Administration	03/11/2022
	Comp. Dt. : 07/11/2022							
	Status : Completed							
514	22110199	AO Office	NEED TO CHANGE PRINTER TONER (RUBA MAM CABIN)	Balachandar. A.	PRINTER TONER CHANGED		Saravanan. R. - Administration	07/11/2022
	Comp. Dt. : 08/11/2022							
	Status : Completed							
515	22110283	AO Office	NEED TO CHANGE PRINTER TONER (ACCOUNTANT SYSTEM)	Shafiullah. R.	12A TONER CHANGED		Swaadhika. C. - Administration	08/11/2022
	Comp. Dt. : 14/11/2022							
	Status : Completed							
516	22110526	AO Office	NEED TO CHANGE PRINTER TONER	Shafiullah. R.	774 INK CHANGED		Nanthini Devi. R. K. - Administration	14/11/2022
	Comp. Dt. : 17/11/2022							
	Status : Completed							
517	22110713	AO Office	NEED TO CHANGE TONER	Selvam. D.	TONER CHANGED		Kathiravan. K. - Administration	18/11/2022
	Comp. Dt. : 05/12/2022							
	Status : Completed							
518	22120210	AO Office	CHANGE PRINTER CATRIDGE	Selvam. D.	PRINTER CATRIDGE CHANGED		Siva. E. - Administration	06/12/2022
	Comp. Dt. : 06/12/2022							
	Status : Completed							
519	22120250	AO Office	CHANGE PRINTER TONER	Madhubalan. S.	12A TONER CHANGED		Kathiravan. K. - Administration	06/12/2022
	Comp. Dt. : 09/12/2022							
	Status : Completed							
520	22120430	General Stores[Linen]	PRINTER NOT WORKING	Valamburi. R.	RIBBON CHANGED		Motheeswarar. R.S. - Administration	10/12/2022
	Comp. Dt. : 10/12/2022							
	Status : Completed							


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
521	22120470	AO Office	NEED TO CHANGE TONER	Valamburi. R.	TONER CHANGED		Roopa. S. - Administration	10/12/2022
	Comp. Dt. : 12/12/2022							
	Status : Completed							
522	22120524	AO Office	SYSTEM NOT WORKING	Jayaraj. J.	OS REPAIR AND TEMP FILE CLEANED		Kavitha. P. - Administration	12/12/2022
	Comp. Dt. : 19/12/2022							
	Status : Completed							
523	22120848	AO Office	NEED TO CHANGE PRINTER RIBBON - CASH COUNTER	Jayaraj. J.	10m RIBBON CHANGED		Anbarasan. R. - Administration	19/12/2022
	Comp. Dt. : 23/12/2022							
	Status : Completed							
524	22121054	AO Office	SYSTEM NOT WORKING	Madhubalan. S.	SYSTEM RESTATED WORKING FINE		Elumalai.K.A. - Administration	23/12/2022
525	22121055	AO Office	NETWORK & INVERTER NOT WORKING	Madhubalan. S.	NETWORK PATCH CABLE CHANGED WORKING FINE		Nanthini Devi. R. K. - Administration	23/12/2022
	Comp. Dt. : 04/01/2023							
	Status : Completed							
526	23010160	AO Office	CHANGE PRINTER TONER	Shafiullah. R.	PRINTER TONER CHANGED		Roopa. S. - Administration	04/01/2023
	Comp. Dt. : 07/01/2023							
	Status : Completed							
527	23010310	AO Office	CHANGE PRINTER TONER	Madhubalan. S.	12A TONER CHANGED		Kathiravan. K. - Administration	07/01/2023
	Comp. Dt. : 04/02/2023							
	Status : Completed							
528	23020143	General Stores[Linen]	NEED TO CHANGE TONER	Selvam. D.	TONER CHANGED		Motheeswarar. R.S. - Administration	04/02/2023
	Comp. Dt. : 06/02/2023							
	Status : Completed							
529	23020178	AO Office	SYSTEM NOT WORKING	Madhubalan. S.	SYSTEM RESTATER WORKING FINE		Elumalai.K.A. - Administration	06/02/2023
	Comp. Dt. : 20/02/2023							
	Status : Completed							
530	23020743	AO Office	NEED TO CHANGE TONER	Balachandar. A.	TONER CHANGED		Nitheeskumar. D. - Administration	20/02/2023
531	23020745	AO Office	NEED TO CHANGE TONER	Jayaraj. J.	12A toner changed		Shyamala. R. - Administration	20/02/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 23/02/2023 Status : Completed								
532	23020893	AO Office	NEED TO CHANGE DOT MATRIX PRINTER RIBBON	Selvam. D.	PRINTER RIBBON CHANGED		Anbarasan. R. - Administration	23/02/2023
Comp. Dt. : 02/03/2023 Status : Completed								
533	23030072	AO Office	NEED TO CHANGE TONER	Shafiullah. R.	12A TONER CHANGED		Kavitha. P. - Administration	02/03/2023
Comp. Dt. : 07/03/2023 Status : Completed								
534	23030270	AO Office	NEED TO CHANGE TONER	Jayaraj. J.	12A TONER CHANGED		Saravanan. R. - Administration	07/03/2023
Comp. Dt. : 10/03/2023 Status : Completed								
535	23030431	AO Office	NEED TO CHANGE PRINTER RIBBON FOR DOT MATRIX PRINTER	Selvam. D.	10m ribbon changed		Anbarasan. R. - Administration	10/03/2023
Comp. Dt. : 14/03/2023 Status : Completed								
536	23030544	AO Office	NEED TO CHANGE TONER	Selvam. D.	12A TONER CHANGED		Siva. E. - Administration	14/03/2023
Comp. Dt. : 23/03/2023 Status : Completed								
537	23030981	AO Office	NEED TO CHANGE TONER	Selvam. D.	12a toner changed		Nitheeshkumar. D. - Administration	25/03/2023
Comp. Dt. : 29/03/2023 Status : Completed								
538	23031240	AO Office	NEED TO CHANGE TONER [HP P1108]	Balachandar. A.	TONER CHANGED		Anbarasan. R. - Administration	30/03/2023
Comp. Dt. : 30/03/2023 Status : Completed								
539	23031292	AO Office	NEED TO CHANGE TONER	Murugavel.R	TONER CHANGED		Saravanan. R. - Administration	30/03/2023
Comp. Dt. : 04/04/2023 Status : Completed								
540	23040135	AO Office	SYSTEM NOT WORKING	Valamburi. R.	VGA CABLE REFIXED		Sankardevi. G. - Administration	04/04/2023
Comp. Dt. : 20/04/2023								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
541	23040675	AO Office	PRINTER - PAPER JAM	Selvam. D.	paper jam cleard		Gunavathi. S. - Administration	22/04/2023
Comp. Dt. : 25/04/2023								
Status : Completed								
542	23040793	AO Office	PRINTER NOT WORKING	Selvam. D.	old formatted board changed		Raja Prabu. V. - Administration	26/04/2023
543	23040812	AO Office	KEYBOARD NOT WORKING	Shafiullah. R.	REFIX THE USB CABLE		Nitheeshkumar. D. - Administration	25/04/2023
Comp. Dt. : 02/05/2023								
Status : Completed								
544	23050053	AO Office	NEED TO CHANGE TONER FOR S A O SIR OFFICE	Selvam. D.	TONER CHANGED		Kavitha. P. - Administration	02/05/2023
545	23050068	AO Office	SYSTEM NOT WORKING	Valamburi. R.	POWER CABLE REFIXED		Soupramanien.S. - Administration	04/05/2023
Comp. Dt. : 03/05/2023								
Status : Completed								
546	23050096	AO Office	NEED TO CHANGE TONER	Balachandar. A.	TONER CHANGED		Roopa. S. - Administration	03/05/2023
Comp. Dt. : 09/05/2023								
Status : Completed								
547	23050371	AO Office	PROBLEM IN TALLY	Balachandar. A.	NETWORK CABLE REFIXED		Siva. E. - Administration	11/05/2023
Comp. Dt. : 12/05/2023								
Status : Completed								
548	23050496	AO Office	PRINTER NOT WORKING	Selvam. D.	TONER REFIXED		Shyamala. R. - Administration	12/05/2023
Comp. Dt. : 22/05/2023								
Status : Completed								
549	23050886	General Stores[Linen]	NEED TO CHANGE PRINTER RIBBON	Shafiullah. R.	10MT RIBBON CHANGED		Motheeswarar. R.S. - Administration	22/05/2023
Comp. Dt. : 25/05/2023								
Status : Completed								
550	23051014	AO Office	NEED TO CHANGE TONER	Harikrishnan. R.	12A Toner Changed		Saravanan. R. - Administration	25/05/2023
Comp. Dt. : 12/06/2023								
Status : Completed								
551	23060425	AO Office	NEED TO CHANGE TONER	Shafiullah. R.	12A toner changed		Saravanan. R. - Administration	13/06/2023

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHAL KUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 17/06/2023 Status : Completed								
552	23060629	AO Office	NEED TO CHANGE TONER	Selvam. D.	12A toner changed		Sumathy.R - Administration	17/06/2023
Comp. Dt. : 19/06/2023 Status : Completed								
553	23060669	AO Office	SYSTEM SLOW PROBLEM	Murugavel.R	temp cleared and cc cleared.		Kavitha. P. - Administration	19/06/2023
Comp. Dt. : 20/06/2023 Status : Completed								
554	23060737	AO Office	NEED TO CHANGE HD 250 GOLD DOTMATICS PRINTER RIBBON	Jayaraj. J.	10m cartidge changed		Anbarasan. R. - Administration	20/06/2023
Comp. Dt. : 26/06/2023 Status : Completed								
555	23060952	General Stores[Furniture]	SYSTEM NOT WORKING	Selvam. D.	ups changed		Motheeswarar. R.S. - Administration	26/06/2023
Comp. Dt. : 30/06/2023 Status : Completed								
556	23061113	AO Office	NEED TO CHANGE TONER	Harikrishnan. R.	12A Toner Changed.		Saravanan. R. - Administration	30/06/2023
Dept Name : Anaesthesiology - Computer Department Comp. Dt. : 20/05/2022 Status : Completed								
557	22050774	ORTHO OT	MONITOR NOT WORKING	Selvam. D.	ram refixed and dust cleaned		Jayanthi.V. - Anaesthesiology	21/05/2022
Comp. Dt. : 26/05/2022 Status : Completed								
558	22050992	ORTHO OT	NEED TO CHANGE TONER	Shafiullah. R.	12A TONER CHANGED		Jayanthi.V. - Anaesthesiology	26/05/2022
Comp. Dt. : 30/08/2022 Status : Completed								
559	22081004	ORTHO OT	NEED TO CHANGE TONER	Balachandar. A.	TONER CHANGED		Jayanthi.V. - Anaesthesiology	30/08/2022
Comp. Dt. : 12/09/2022 Status : Completed								
560	22090453	ORTHO OT	NEED TO CHANGE TONER	Selvam. D.	12A toner changed		Jayanthi.V. - Anaesthesiology	12/09/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 02/01/2023 Status : Completed								
561	23010022	ORTHO OT	PRINTER NOT WORKING	Selvam. D.	Paper jam cleared		Jayanthi.V. - Anaesthesiology	02/01/2023
Comp. Dt. : 24/01/2023 Status : Completed								
562	23010849	ORTHO OT	SYSTEM NOT WORKING	Jayaraj. J.	RAM CLEAN AND REFIXED		Jayanthi.V. - Anaesthesiology	24/01/2023
Comp. Dt. : 01/02/2023 Status : Completed								
563	23020012	ORTHO OT	PRINTER NOT WORKING PAPER STUCK	Selvam. D.	Pressure roller and teflon sleeve replaced		Jayanthi.V. - Anaesthesiology	04/02/2023
Comp. Dt. : 13/02/2023 Status : Completed								
564	23020493	New OT	NEED TO CHECK WI FI CONNECTION - NOT WORKING	Shafiullah. R.	WIFI WORKING		RAMPRASATH. B. - Anaesthesiology	14/02/2023
Comp. Dt. : 02/03/2023 Status : Completed								
565	23030091	Main OT	NEED TO CHANGE TONER	Madhubalan. S.	12A TONER CHANGED		Jayanthi.V. - Anaesthesiology	02/03/2023
Comp. Dt. : 03/06/2023 Status : Completed								
566	23060107	ORTHO OT	NEED TO CHANGE TONER	Shafiullah. R.	12A TONER CHANGED		Jayanthi.V. - Anaesthesiology	03/06/2023
Comp. Dt. : 05/06/2023 Status : Completed								
567	23060127	ORTHO OT	PRINTER NOT WORKING	Selvam. D.	printer working fine		Jayanthi.V. - Anaesthesiology	06/06/2023
Dept Name : ANATOMY - Computer Department Comp. Dt. : 23/11/2022 Status : Completed								
568	22110971	ANATOMY	NEED TO CHANGE PRINTER TONER FOR HOD SYSTEM	Madhubalan. S.	88A TONER CHANGED		Mathivanan.B. - ANATOMY	23/11/2022
Dept Name : Audit Wing - Computer Department Comp. Dt. : 20/06/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
569	22060728	AO Office	NEED TO CHANGE TONER	Selvam. D.	12A toner changed		Sadhasivam. A. - Audit Wing	21/06/2022
	Comp. Dt. : 13/07/2022							
	Status : Completed							
570	22070522	AO Office	NEED TO CHANGE TONER	Valamburi. R.	TONER CHANGED		Hari Ram Singh. B. - Audit Wing	14/07/2022
	Comp. Dt. : 02/08/2022							
	Status : Completed							
571	22080088	AO Office	NEED TO CHANGE TONER	Selvam. D.	12A toner changed		Sadhasivam. A. - Audit Wing	03/08/2022
	Comp. Dt. : 29/09/2022							
	Status : Completed							
572	22091175	AO Office	NEED TO CHANGE TONER [12A]	Shafiullah. R.	12A TONER CHANGED		Hari Ram Singh. B. - Audit Wing	29/09/2022
	Comp. Dt. : 25/11/2022							
	Status : Completed							
573	22111094	AO Office	SYSTEM MONITOR DISPLAY BECAME BLUR	Balachandar. A.	New 22" monitor changed		Duwaaragesh. V. - Audit Wing	01/12/2022
	Comp. Dt. : 07/12/2022							
	Status : Completed							
574	22120341	AO Office	NEED TO CHANGE TONER	Shafiullah. R.	12A TONER CHANGED		Sadhasivam. A. - Audit Wing	07/12/2022
	Comp. Dt. : 24/01/2023							
	Status : Completed							
575	23010881	Audit Wing	NEED TO CHANGE TONER	Jayaraj. J.	12A TONER CHANGED		Hari Ram Singh. B. - Audit Wing	24/01/2023
	Comp. Dt. : 10/03/2023							
	Status : Completed							
576	23030420	AO Office	NEED TO CHANGE TONER	Selvam. D.	12a toner changed		Sadhasivam. A. - Audit Wing	10/03/2023
	Comp. Dt. : 15/05/2023							
	Status : Completed							
577	23050588	AO Office	NEED TO CHANGE TONER	Jayaraj. J.	12A TONER CHANGED		Hari Ram Singh. B. - Audit Wing	15/05/2023
	Dept Name : BIOCHEMISTRY - Computer Department							
	Comp. Dt. : 04/05/2022							
	Status : Completed							
578	22050102	Blood Collection Centre	NEED TO CHANGE STRICKER	Prakash. P.	revist sticker changed		Srinivasamurugan. V. - BIOCHEMISTRY	04/05/2022

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 16/05/2022 Status : Completed								
579	22050517	Blood Collection Centre	NEED TO CHANGE BARCODE STRICKER	Selvam. D.	BARCODE STRICKER CHANGED		Srinivasamurugan. V. - BIOCHEMISTRY	17/05/2022
Comp. Dt. : 17/05/2022 Status : Completed								
580	22050610	Blood Collection Centre	NEED TO CHANGE TONER	Selvam. D.	12A TONER CHANGED		Srinivasamurugan. V. - BIOCHEMISTRY	18/05/2022
Comp. Dt. : 30/05/2022 Status : Completed								
581	22051067	BIOCHEMISTRY	SYSTEM [2NOS] NOT WORKING	Valamburi. R.	Patch cable refixed		Sathyamurugan. E. - BIOCHEMISTRY	31/05/2022
Comp. Dt. : 31/05/2022 Status : Completed								
582	22051110	BIOCHEMISTRY	SYSTEM NOT WORKING	Selvam. D.	Patch cable refixed		Sathyamurugan. E. - BIOCHEMISTRY	31/05/2022
583	22051145	BIOCHEMISTRY	NEED TO CHANGE TONER 2 NOS	Prakash. P.	12A toner changed		Sathyamurugan. E. - BIOCHEMISTRY	01/06/2022
Comp. Dt. : 02/06/2022 Status : Completed								
584	22060047	BIOCHEMISTRY	PROBLEM IN SYSTEM MONITOR - DISPLAY	Valamburi. R.	New 18.5 Aoc monitor changed		Suganthi. P. - BIOCHEMISTRY	02/06/2022
585	22060069	BIOCHEMISTRY	SYSTEM NOT WORKING - PROBLEM IN NET WORK	Jayaraj. J.	LAN CABLE REFIXED		Sathyamurugan. E. - BIOCHEMISTRY	03/06/2022
Comp. Dt. : 03/06/2022 Status : Completed								
586	22060111	BIOCHEMISTRY	KEYBOARD NOT WORKING	Shafiullah. R.	USB LOGITECH KEYBOARD CHANGED		Sathyamurugan. E. - BIOCHEMISTRY	04/06/2022
Comp. Dt. : 07/06/2022 Status : Completed								
587	22060246	Blood Collection Centre	NEED TO CHANGE BARCODE STRICKER	Madhubalan. S.	BARCODE REVISITE STRICKER CHANGED		Srinivasamurugan. V. - BIOCHEMISTRY	07/06/2022
Comp. Dt. : 10/06/2022 Status : Completed								
588	22060398	Reception	IN COUNTER 8-CHANGE PRINTER TONER	Jayaraj. J.	12A toner changed		Srinivasamurugan. V. - BIOCHEMISTRY	10/06/2022
Comp. Dt. : 16/06/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
589	22060623	BIOCHEMISTRY	PRINTER NOT WORKING	Selvam. D.	Printer working fine		Anitha. R. - BIOCHEMISTRY	17/06/2022
	Comp. Dt. : 18/06/2022							
	Status : Completed							
590	22060686	Blood Collection Centre	NEED TO CHANGE BARCODE STRICKER	Balachandar. A.	BARCODE STRICKER CHANGED		Srinivasamurugan. V. - BIOCHEMISTRY	18/06/2022
	Comp. Dt. : 29/06/2022							
	Status : Completed							
591	22061086	Blood Collection Centre	NEED TO CHANGE BARCODE STRICKER	Murugavel.R	REVISIT STICKER CHANGED		Srinivasamurugan. V. - BIOCHEMISTRY	29/06/2022
	Comp. Dt. : 07/07/2022							
	Status : Completed							
592	22070293	Blood Collection Centre	BARCODE MACHINE NOT WORKING	Selvam. D.	barcode ribbon refixed		Srinivasamurugan. V. - BIOCHEMISTRY	07/07/2022
	Comp. Dt. : 11/07/2022							
	Status : Completed							
593	22070422	Blood Collection Centre	NEED TO CHANGE BARCODE STRICKER	Murugavel.R	sticker changed		Srinivasamurugan. V. - BIOCHEMISTRY	13/07/2022
	Comp. Dt. : 12/07/2022							
	Status : Completed							
594	22070463	Blood Collection Centre	NEED TO CHANGE PRINTER RIBBON	Shafiullah. R.	wax ribbon changed		Srinivasamurugan. V. - BIOCHEMISTRY	12/07/2022
	Comp. Dt. : 29/07/2022							
	Status : Completed							
595	22071045	BIOCHEMISTRY	PROBLEM IN MEDPLUS - NOT OPENED	Madhubalan. S.	NETWORK CABLE REFIXED MEDPLUS WORKING FINE		Sathyamurugan. E. - BIOCHEMISTRY	29/07/2022
596	22071054	BIOCHEMISTRY	SYSTEM [AGAIN] & PRINTER NOT WORKING	Selvam. D.	RJ 45 jack crumbed		Sathyamurugan. E. - BIOCHEMISTRY	29/07/2022
	Comp. Dt. : 02/08/2022							
	Status : Completed							
597	22080061	BIOCHEMISTRY	SYSTEM SLOW PROBLEM	Balachandar. A.	history cleared and cc cleared..		Srinivasamurugan. V. - BIOCHEMISTRY	02/08/2022
	Comp. Dt. : 05/08/2022							
	Status : Completed							
598	22080206	BIOCHEMISTRY	SYSTEM NOT WORKING - SLOW PROBLEM	Madhubalan. S.	checked system restarted..		Raja Raja Sozhan. R. BIOCHEMISTRY	06/08/2022
599	22080221	BIOCHEMISTRY	NEED TO CHANGE TONER	Madhubalan. S.	12A TONER CHANGED		Srinivasamurugan. V. - BIOCHEMISTRY	06/08/2022

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 06/08/2022								
Status : Completed								
600	22080230	Blood Collection Centre	NEED TO CHANGE BARCODE STRICKER	Selvam. D.	Revisit barcode sticker changed		Srinivasamurugan. V. - BIOCHEMISTRY	06/08/2022
Comp. Dt. : 12/08/2022								
Status : Completed								
601	22080447	BIOCHEMISTRY	SYSTEM SLOW PROBLEM	Jayaraj. J.	TEMP CLEARED AND CC CLEARED...		Srinivasamurugan. V. - BIOCHEMISTRY	17/08/2022
Comp. Dt. : 17/08/2022								
Status : Completed								
602	22080548	Biochemistry Lab-Hospital	SYSTEM NOT WORKING	Selvam. D.	system working fine		Sangeetha. S. - BIOCHEMISTRY	18/08/2022
Comp. Dt. : 30/08/2022								
Status : Completed								
603	22081041	Blood Collection Centre	NEED TO CHANGE BARCODE STRICKER	Shafiullah. R.	REVISIT BARCODE STRICKER CHANGED		Srinivasamurugan. V. - BIOCHEMISTRY	30/08/2022
Comp. Dt. : 01/09/2022								
Status : Completed								
604	22090034	BIOCHEMISTRY	NEED TO CHECK SYSTEM - SLOW PROBLEM	Shafiullah. R.	System working fine		Srinivasamurugan. V. - BIOCHEMISTRY	01/09/2022
Comp. Dt. : 06/09/2022								
Status : Completed								
605	22090238	BIOCHEMISTRY	SYSTEM NOT WORKING	Selvam. D.	System working fine		Srinivasamurugan. V. - BIOCHEMISTRY	06/09/2022
606	22090241	Blood Collection Centre	SYSTEM NOT WORKING	Selvam. D.	system working fine		Srinivasamurugan. V. - BIOCHEMISTRY	06/09/2022
Comp. Dt. : 07/09/2022								
Status : Completed								
607	22090277	BIOCHEMISTRY	NEED TO CHECK SYSTEM - NETWORK FAILURE	Selvam. D.	System working fine		Srinivasamurugan. V. - BIOCHEMISTRY	08/09/2022
Comp. Dt. : 08/09/2022								
Status : Completed								
608	22090338	BIOCHEMISTRY	SYSTEM & NETWORK SLOW PROBLEM	Selvam. D.	system working fine		Srinivasamurugan. V. - BIOCHEMISTRY	09/09/2022
Comp. Dt. : 09/09/2022								
Status : Completed								
609	22090368	BIOCHEMISTRY	NETWORK FAILURE - SYSTEM SLOW	Selvam. D.	system working fine		Srinivasamurugan. V. - BIOCHEMISTRY	09/09/2022

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
610	22090378	Blood Collection Centre	NEED TO CHANGE BARCODE PRINTER RIBBON	Valamburi. R.	Barcode ribbon changed		Srinivasamurugan. V. - BIOCHEMISTRY	12/09/2022
Comp. Dt. : 12/09/2022 Status : Completed								
611	22090457	Blood Collection Centre	NEED TO CHANGE BARCODE STRICKER	Selvam. D.	Revisit sticker changed		Srinivasamurugan. V. - BIOCHEMISTRY	12/09/2022
Comp. Dt. : 13/09/2022 Status : Completed								
612	22090503	Reception	NEED TO CHANGE TONER - COUNTER NO 8	Selvam. D.	counter 8 12a toner changed		Srinivasamurugan. V. - BIOCHEMISTRY	13/09/2022
Comp. Dt. : 17/09/2022 Status : Completed								
613	22090662	BIOCHEMISTRY	NEED TO CHANGE TONER	Jayaraj. J.	12A TONER CHANGED		Durga Devi. I. - BIOCHEMISTRY	17/09/2022
Comp. Dt. : 21/09/2022 Status : Completed								
614	22090803	BIOCHEMISTRY	SYSTEM NOT WORKING	Shafiullah. R.	NETWORK CABLE REFIXED..		Srinivasamurugan. V. - BIOCHEMISTRY	21/09/2022
Comp. Dt. : 05/10/2022 Status : Completed								
615	22100043	Blood Collection Centre	NEED TO CHANGE BARCODE STRICKER	Balachandar. A.	REVISIT STICKER CHANGED		Srinivasamurugan. V. - BIOCHEMISTRY	05/10/2022
Comp. Dt. : 12/10/2022 Status : Completed								
616	22100322	Biochemistry Lab-Hospital	SYSTEM NOT WORKING	Selvam. D.	Patch cable refixed.System working fine		Durga Devi. I. - BIOCHEMISTRY	12/10/2022
Comp. Dt. : 14/10/2022 Status : Completed								
617	22100441	Blood Collection Centre	NEED TO CHANGE BAR CODE STRICKER	Shafiullah. R.	REVISIT BARCODE STRICKER CHANGED		Srinivasamurugan. V. - BIOCHEMISTRY	14/10/2022
Comp. Dt. : 26/10/2022 Status : Completed								
618	22100788	BIOCHEMISTRY-- -COLLEGE	STUDENT ATTENDANCE FILE NOT OPEN	Balachandar. A.,Selvam. D.,Madhubalan. S.	system reinstalled		Suganthi. P. - BIOCHEMISTRY	28/10/2022
Comp. Dt. : 27/10/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
619	22100867	Blood Collection Centre	NEED TO CHANGE BARCODE STICKER	Selvam. D.	revisit sticker changed		Srinivasamurugan. V. - BIOCHEMISTRY	27/10/2022
	Comp. Dt. : 28/10/2022							
	Status : Completed							
620	22100878	Blood Collection Centre	SYSTEM NOT WORKING	Balachandar. A.	Lithium ups changed		Srinivasamurugan. V. - BIOCHEMISTRY	28/10/2022
	Comp. Dt. : 04/11/2022							
	Status : Completed							
621	22110113	Blood Collection Centre	PRINTER RIBBON PROBLEM	Selvam. D.	ribbon refixed		Srinivasamurugan. V. - BIOCHEMISTRY	04/11/2022
	Comp. Dt. : 09/11/2022							
	Status : Completed							
622	22110335	Blood Collection Centre	NEED TO CHANGE BARCODE STICKER	Selvam. D.	BARCODE STICKER CHANGED		Srinivasamurugan. V. - BIOCHEMISTRY	09/11/2022
	Comp. Dt. : 10/11/2022							
	Status : Completed							
623	22110425	Biochemistry Lab-Hospital	SYSTEM NETWORK FAILURE	Jayaraj. J.	NETWORK CABLE REFIXED		Srinivasamurugan. V. - BIOCHEMISTRY	10/11/2022
	Comp. Dt. : 16/11/2022							
	Status : Completed							
624	22110658	Biochemistry Lab-Hospital	SYSTEM NOT WORKING	Shafiullah. R.	SYSTEM SMPS POWER DRY AND ON NOW SYSTEM WORKING		Parameswari. G. - BIOCHEMISTRY	16/11/2022
	Comp. Dt. : 18/11/2022							
	Status : Completed							
625	22110776	BIOCHEMISTRY	NEED TO CHECK NET CONNECTION	Murugavel.R	system restrated..		Srinivasamurugan. V. - BIOCHEMISTRY	18/11/2022
	Comp. Dt. : 22/11/2022							
	Status : Completed							
626	22110939	BIOCHEMISTRY	SYSTEM NOT WORKING	Shafiullah. R.	SYSTEM WORKING		Gayathri. K. - BIOCHEMISTRY	23/11/2022
	Comp. Dt. : 24/11/2022							
	Status : Completed							
627	22111061	Biochemistry Lab-Hospital	SYSTEM SERVER SLOW	Balachandar. A.	working fine..		Vishnu Priya. B. - BIOCHEMISTRY	25/11/2022
	Comp. Dt. : 30/11/2022							
	Status : Completed							
628	22111293	Biochemistry Lab-Hospital	CHANGE LASER PRINTER CATRIDGE	Madhubalan. S.	12A TONER CHANGED		Srinivasamurugan. V. - BIOCHEMISTRY	01/12/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 01/12/2022 Status : Completed								
629	22120026	BIOCHEMISTRY	NET WORK PROBLEM - MEDPLUS NOT WORKING	Balachandar. A.	system restarted		Srinivasamurugan. V. - BIOCHEMISTRY	01/12/2022
Comp. Dt. : 02/12/2022 Status : Completed								
630	22120051	Blood Collection Centre	NEED TO CHANGE BARCODE STRICKER	Prakash. P.	REVISIT BARCODE STRICKER		Srinivasamurugan. V. - BIOCHEMISTRY	02/12/2022
Comp. Dt. : 07/12/2022 Status : Completed								
631	22120339	Reception	NEED TO CHANGE TONER FOR COUNTER NO 8	Shafiullah. R.	12A TONER CHANGED		Srinivasamurugan. V. - BIOCHEMISTRY	07/12/2022
632	22120340	BIOCHEMISTRY	SYSTEM NOT WORKING	Murugavel.R	SOFTWARE SLOW WORKING FINE		Sathyamurugan. E. - BIOCHEMISTRY	08/12/2022
Comp. Dt. : 27/12/2022 Status : Completed								
633	22121193	Reception	CPU NOT WORKING IN COUNTER NO 8	Balachandar. A.	SYSTEM SETTING CHANGE		Srinivasamurugan. V. - BIOCHEMISTRY	27/12/2022
Comp. Dt. : 31/12/2022 Status : Completed								
634	22121409	Biochemistry Lab-Hospital	IN SYSTEM-MEDPLUS SOFTWARE NOT WORKING	Selvam. D.	Software working fine		Srinivasamurugan. V. - BIOCHEMISTRY	04/01/2023
Comp. Dt. : 06/01/2023 Status : Completed								
635	23010252	Biochemistry Lab-Hospital	SOFTWARE SLOW	Murugavel.R	SOFTWARE WORKING FINE		Srinivasamurugan. V. - BIOCHEMISTRY	06/01/2023
Comp. Dt. : 07/01/2023 Status : Completed								
636	23010316	Biochemistry Lab-Hospital	SYSTEM WORKING SLOWLY AND EXIST TIME OUT	Selvam. D.	CHECKED WORKING FINE		Srinivasamurugan. V. - BIOCHEMISTRY	09/01/2023
Comp. Dt. : 09/01/2023 Status : Completed								
637	23010355	Biochemistry Lab-Hospital	SYSTEM WORKING SLOWLY	Valamburi. R.	TEMP FILE CLEAR		Srinivasamurugan. V. - BIOCHEMISTRY	09/01/2023
Comp. Dt. : 10/01/2023 Status : Completed								
638	23010425	Biochemistry Lab-Hospital	ALL SYSTEMS ARE NOT WORKING	Shafiullah. R.	SYSTEM WORKING		Raja Raja Sozhan. R. - BIOCHEMISTRY	10/01/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
639	23010427	Biochemistry Lab-Hospital	CHANGE PRINTER TONER	Shafiullah. R.	12A TONER CHANGED		Srinivasamurugan. V. - BIOCHEMISTRY	10/01/2023
	Comp. Dt. : 18/01/2023							
	Status : Completed							
640	23010639	BIOCHEMISTRY	SYSTEM SLOW PROBLEM	Balachandar. A.	system working fine		Srinivasamurugan. V. - BIOCHEMISTRY	20/01/2023
	Comp. Dt. : 19/01/2023							
	Status : Completed							
641	23010659	Blood Collection Centre	NEED TO CHANGE BARCODE STRICKER	Selvam. D.	REVISTE STICKER CHNAGED		Srinivasamurugan. V. - BIOCHEMISTRY	19/01/2023
642	23010677	Reception	NEED TO CHANGE TONER FOR COUNTER NO 8	Madhubalan. S.	12A TONER CHANGED		Srinivasamurugan. V. - BIOCHEMISTRY	19/01/2023
	Comp. Dt. : 23/01/2023							
	Status : Completed							
643	23010831	BIOCHEMISTRY	SYSTEM SOFTWARE NOT WORKING	Balachandar. A.	software installed		Vishnu Priya. B. - BIOCHEMISTRY	24/01/2023
	Comp. Dt. : 24/01/2023							
	Status : Completed							
644	23010858	BIOCHEMISTRY	NEED TO CHANGE BARCODE STRICKER	Shafiullah. R.	REVISIT BARCODE STRICKER CHANGED		Srinivasamurugan. V. - BIOCHEMISTRY	24/01/2023
	Comp. Dt. : 30/01/2023							
	Status : Completed							
645	23011058	BIOCHEMISTRY	SYSTEM NOT WORKING	Balachandar. A.	NETWORK ISSUE		Vishnu Priya. B. - BIOCHEMISTRY	30/01/2023
	Comp. Dt. : 02/02/2023							
	Status : Completed							
646	23020055	Reception	NEED TO CHANGE TONER FOR COUNTER NO 8	Madhubalan. S.	12A TONER CHANGED		Srinivasamurugan. V. - BIOCHEMISTRY	02/02/2023
	Comp. Dt. : 06/02/2023							
	Status : Completed							
647	23020172	Blood Collection Centre	NEED TO CHANGE BARCODE STRICKER	Selvam. D.	Revisit sticker changed		Srinivasamurugan. V. - BIOCHEMISTRY	06/02/2023
	Comp. Dt. : 08/02/2023							
	Status : Completed							
648	23020278	Reception	NEED TO CHANGE PRINTER TONER IN COUNTER NO. 8	Shafiullah. R.	12A TONER CHANGED		Srinivasamurugan. V. - BIOCHEMISTRY	08/02/2023
649	23020287	Reception	PRINTER NOT WORKING IN COUNTER NO. 9	Shafiullah. R.	PRINTER POWER ON		Srinivasamurugan. V. - BIOCHEMISTRY	08/02/2023

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHAL KUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 18/02/2023 Status : Completed								
650	23020727	Blood Collection Centre	NEED TO CHANGE BARCODE STRICKER	Balachandar. A.	New barcode sticker changed		Srinivasamurugan. V. - BIOCHEMISTRY	18/02/2023
Comp. Dt. : 28/02/2023 Status : Completed								
651	23021083	Biochemistry Lab-Hospital	PRINTER PROBLEM	Shafiullah. R.	12A TONER CHANGED		Sathyamurugan. E. - BIOCHEMISTRY	28/02/2023
Comp. Dt. : 02/03/2023 Status : Completed								
652	23030092	Blood Collection Centre	NEED TO CHANGE BARCODE STRICKER	Shafiullah. R.	REVISIT STRICKER CHANGED		Srinivasamurugan. V. - BIOCHEMISTRY	02/03/2023
Comp. Dt. : 06/03/2023 Status : Completed								
653	23030201	BIOCHEMISTRY	NEED TO CHANGE SYSTEM ANOTHER PLACE	Selvam. D.	System changed		Sathyamurugan. E. - BIOCHEMISTRY	06/03/2023
Comp. Dt. : 09/03/2023 Status : Completed								
654	23030372	Reception	need to change toner for counter no 8	Jayaraj. J.	12A TONER CHANGED		Srinivasamurugan. V. - BIOCHEMISTRY	09/03/2023
Comp. Dt. : 14/03/2023 Status : Completed								
655	23030520	Blood Collection Centre	NEED TO CHANGE BARCODE STRICKER	Madhubalan. S.	REVISIT STICKER CHANGED		Srinivasamurugan. V. - BIOCHEMISTRY	14/03/2023
Comp. Dt. : 22/03/2023 Status : Completed								
656	23030897	BIOCHEMISTRY	PROBLEM IN MEDPLUS	Raja.B	SOFTWARE WORKING		Sathyamurugan. E. - BIOCHEMISTRY	25/03/2023
Comp. Dt. : 23/03/2023 Status : Completed								
657	23030962	BIOCHEMISTRY-- -COLLEGE	SYSTEM NOT WORKING - NETWORK PROBLEM	Madhubalan. S.	CMOS BATTERY CHANGED NET WORKING FINE		Suganthi. P. - BIOCHEMISTRY	25/03/2023
Comp. Dt. : 28/03/2023 Status : Completed								
658	23031222	BIOCHEMISTRY	SYSTEM NOT WORKING - ROOM NO 44	Balachandar. A.	COMPLINAT DOUBLE ENTRY		Srinivasamurugan. V. BIOCHEMISTRY	30/03/2023
Comp. Dt. : 29/03/2023 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
659	23031270	BIOCHEMISTRY	SYSTEM SLOW PROBLEM	Selvam. D.	2gb ram upgraded		Srinivasamurugan. V. - BIOCHEMISTRY	30/03/2023
	Comp. Dt. : 31/03/2023							
	Status : Completed							
660	23031364	BIOCHEMISTRY	NEED TO CHECK SYSTEM SLOW & NET WORK PROBLEM	Selvam. D.	system working fine		Srinivasamurugan. V. - BIOCHEMISTRY	03/04/2023
	Comp. Dt. : 03/04/2023							
	Status : Completed							
661	23040070	Blood Collection Centre	NEED TO CHANGE BARCODE STRICKER	Venkatesh. S.	REVISIT STICHER CHANGED		Srinivasamurugan. V. - BIOCHEMISTRY	03/04/2023
	Comp. Dt. : 17/04/2023							
	Status : Completed							
662	23040524	BIOCHEMISTRY	NEED TO CHANGE TONER	Selvam. D.	12A TONER CHANGED		Srinivasamurugan. V. - BIOCHEMISTRY	18/04/2023
	Comp. Dt. : 25/04/2023							
	Status : Completed							
663	23040828	BIOCHEMISTRY	SYSTEM - NETWORK SLOW PROBLEM	Murugavel.R	NETWORK WORKING		Srinivasamurugan. V. - BIOCHEMISTRY	26/04/2023
	Comp. Dt. : 27/04/2023							
	Status : Completed							
664	23040896	Blood Collection Centre	NEED TO CHANGE BARCODE STRICKER	Harikrishnan. R.	Revisit Sticker Changed		Srinivasamurugan. V. - BIOCHEMISTRY	27/04/2023
	Comp. Dt. : 28/04/2023							
	Status : Completed							
665	23040976	BIOCHEMISTRY	SYSTEM NOT WORKING	Balachandar. A.	medplus software problem,server restatred		Srinivasamurugan. V. - BIOCHEMISTRY	29/04/2023
	Comp. Dt. : 05/05/2023							
	Status : Completed							
666	23050190	BIOCHEMISTRY	SYSTEM NOT WORKING	Selvam. D.	hard disk cable refixed		Srinivasamurugan. V. - BIOCHEMISTRY	05/05/2023
	Comp. Dt. : 12/05/2023							
	Status : Completed							
667	23050515	Blood Collection Centre	NEED TO CHANGE BARCODE STRICKER	Jayaraj. J.	REVISIT STRICKER CHANGED		Srinivasamurugan. V. - BIOCHEMISTRY	12/05/2023
	Comp. Dt. : 19/05/2023							
	Status : Completed							


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
668	23050805	BIOCHEMISTRY	NEED TO CHECK SYSTEM - NET PROBLEM - NOT WORKING - TIME OUT ERROR	Prakash. P.	Working software		Srinivasamurugan. V. - BIOCHEMISTRY	19/05/2023
669	23050821	Blood Collection Centre	NEED TO CHANGE BARCODE STRICKER & RIBBBON	Prakash. P.	BARCODE STRICKER & RIBBBON CHANGED		Srinivasamurugan. V. - BIOCHEMISTRY	19/05/2023
Comp. Dt. : 27/05/2023 Status : Completed								
670	23051100	Blood Collection Centre	PRINTER NOT WORKING	Prakash. P.	PRINTER PAPER JAM CLEAR		Srinivasamurugan. V. - BIOCHEMISTRY	27/05/2023
Comp. Dt. : 01/06/2023 Status : Completed								
671	23060045	BIOCHEMISTRY	SYSTEM NET WORK PROBLEM	Shafiullah. R.	NETWORK WORKING FINE		Srinivasamurugan. V. - BIOCHEMISTRY	01/06/2023
Comp. Dt. : 05/06/2023 Status : Completed								
672	23060151	BIOCHEMISTRY	SYSTEM PROBLEM - DISPLAY TIME OUT EXPIRY	Shafiullah. R.	SYSTEM WORKING FINE		Srinivasamurugan. V. - BIOCHEMISTRY	05/06/2023
673	23060155	Blood Collection Centre	SYSTEM NOT WORKING	Shafiullah. R.	SYSTEM WORKING FINE		Srinivasamurugan. V. - BIOCHEMISTRY	05/06/2023
Comp. Dt. : 07/06/2023 Status : Completed								
674	23060213	BIOCHEMISTRY	KEY BOARD PROBLEM " ENTER" BUTTON NOT WORKING	Prakash. P.	new USB KeyBoard Changed		Srinivasamurugan. V. - BIOCHEMISTRY	07/06/2023
675	23060253	Blood Collection Centre	NEED TO CHANGE BARCODE STRICKER	Shafiullah. R.	REVISIT BARCODE STRICKER CHANGED		Srinivasamurugan. V. - BIOCHEMISTRY	07/06/2023
Comp. Dt. : 08/06/2023 Status : Completed								
676	23060292	BIOCHEMISTRY	SYSTEM SLOW PROBLEM	Madhubalan. S.	SYSTEM WORKIG FINE		Srinivasamurugan. V. - BIOCHEMISTRY	08/06/2023
Comp. Dt. : 09/06/2023 Status : Completed								
677	23060332	BIOCHEMISTRY	SYSTEM NOT WORKING	Jayaraj. J.	WORKING FINE		Vishnu Priya. B. - BIOCHEMISTRY	09/06/2023
678	23060335	BIOCHEMISTRY	SYSTEM NET WORK PROBLEM	Jayaraj. J.	WORKING FINE		Srinivasamurugan. V. - BIOCHEMISTRY	09/06/2023
Comp. Dt. : 10/06/2023 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
679	23060372	BIOCHEMISTRY	SYSTEM NOT WORKING - DISPLAY TIME OUT EXPIRY	Selvam. D.	system working fine		Srinivasamurugan. V. - BIOCHEMISTRY	12/06/2023
Comp. Dt. : 15/06/2023 Status : Completed								
680	23060542	Biochemistry Lab-Hospital	NET NOT WORKING	Prakash. P.	net working		Parameswari. G. - BIOCHEMISTRY	15/06/2023
681	23060558	Blood Collection Centre	NEED TO CHANGE BARCODE STICKER	Harikrishnan. R.	REVISIT STRICKER CHANGED		Srinivasamurugan. V. - BIOCHEMISTRY	15/06/2023
Comp. Dt. : 19/06/2023 Status : Completed								
682	23060683	BIOCHEMISTRY	SYSTEM NOT WORKING	Shafiullah. R.	system working fine		Vishnu Priya. B. - BIOCHEMISTRY	20/06/2023
Comp. Dt. : 21/06/2023 Status : Completed								
683	23060795	BIOCHEMISTRY	NET WORK - SYSTEM - NOT WORKING	Harikrishnan. R.	System Restarted.		Vishnu Priya. B. - BIOCHEMISTRY	22/06/2023
Comp. Dt. : 22/06/2023 Status : Completed								
684	23060828	BIOCHEMISTRY	SYSTEM NOT WORKING	Prakash. P.	WORKING FINE		Parameswari. G. - BIOCHEMISTRY	23/06/2023
685	23060840	BIOCHEMISTRY	NEED TO CHANGE TONER	Harikrishnan. R.	Toner Changed.		Srinivasamurugan. V. - BIOCHEMISTRY	22/06/2023
Comp. Dt. : 23/06/2023 Status : Completed								
686	23060874	Reception	NEED TO CHANGE TONER FOR COUNTER NO 8	Selvam. D.	12A TONER CHANGED		Srinivasamurugan. V. - BIOCHEMISTRY	23/06/2023
Comp. Dt. : 27/06/2023 Status : Completed								
687	23061027	BIOCHEMISTRY	NEED TO CHANGE BARCODE STRICKER	Harikrishnan. R.	REVISIT STRICKER CHANGED		Srinivasamurugan. V. - BIOCHEMISTRY	27/06/2023
688	23061035	BIOCHEMISTRY	SYSTEM - NET WORK PROBLEM	Murugavel.R	working fine		Srinivasamurugan. V. - BIOCHEMISTRY	28/06/2023
Comp. Dt. : 30/06/2023 Status : Completed								
689	23061121	BIOCHEMISTRY	PROBLEM IN SOFTWARE	Balachandar. A.	software slow ready working		Vishnu Priya. B. - BIOCHEMISTRY	01/07/2023
Dept Name : Biomedical - Computer Department Comp. Dt. : 14/06/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
690	22060534	Biomedical	NEED TO CHANGE TONER	Madhubalan. S.	12A TONER CHANGED		Vignesh. D. - Biomedical	14/06/2022
Comp. Dt. : 06/09/2022 Status : Completed								
691	22090206	Biomedical	NEED TO CHANGE TONER	Selvam. D.	12A toner changed		Vignesh. D. - Biomedical	06/09/2022
Comp. Dt. : 14/11/2022 Status : Completed								
692	22110529	Biomedical	PRINTER NOT WORKING	Murugavel.R	RE INSTALLED		Gurumoorthy. G. - Biomedical	14/11/2022
Comp. Dt. : 29/11/2022 Status : Completed								
693	22111253	Biomedical	CHANGE PRINTER TONER	Balachandar. A.	PRINTER TONER CHANGED		Gurumoorthy. G. - Biomedical	30/11/2022
Comp. Dt. : 08/12/2022 Status : Completed								
694	22120357	Biomedical	SYSTEM WORKING SLOWLY	Jayaraj. J.	TEMP FILE CLEANED		Gurumoorthy. G. - Biomedical	10/12/2022
Comp. Dt. : 10/01/2023 Status : Completed								
695	23010417	Biomedical	CHANGE PRINTER TONER	Jayaraj. J.	12A TONER CHANGED		Gurumoorthy. G. - Biomedical	10/01/2023
Comp. Dt. : 07/03/2023 Status : Completed								
696	23030287	Biomedical	NEED TO CHANGE TONER	Harikrishnan. R.	12A TONER CHANGED		Gurumoorthy. G. - Biomedical	07/03/2023
Comp. Dt. : 10/05/2023 Status : Completed								
697	23050393	Biomedical	PRINTER TONER PROBLEM	Valamburi. R.	TONER CHANGED		Vignesh. D. - Biomedical	11/05/2023
Dept Name : BLOOD BANK - Computer Department Comp. Dt. : 15/07/2022 Status : Completed								
698	22070581	Blood Bank	SYSTEM NOT WORKING	Jayaraj. J.	System working fine		Ganesh. V. - BLOOD BANK	16/07/2022
Comp. Dt. : 20/08/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
699	22080653	Blood Bank	SYSTEM NOT WORKING	Selvam. D.	monitor power cable refixed		Sivasankari.I. - BLOOD BANK	20/08/2022
	Comp. Dt. : 04/11/2022							
	Status : Completed							
700	22110116	Blood Bank	REQUEST TO DO SOFTWARE INSTALLATION	Selvam. D.	Software reinstalled		Ganesh. V. - BLOOD BANK	04/11/2022
	Comp. Dt. : 14/12/2022							
	Status : Completed							
701	22120640	Blood Bank	SYSTEM NOT WORKING	Selvam. D.	SYSTEM WORKING		Lakshmi.K. - BLOOD BANK	15/12/2022
	Comp. Dt. : 10/01/2023							
	Status : Completed							
702	23010399	Blood Bank	CHANGE PRINTER TONER	Selvam. D.	PRINTER TONER CHANGED		Ganesh. V. - BLOOD BANK	10/01/2023
	Comp. Dt. : 01/02/2023							
	Status : Completed							
703	23020038	Blood Bank	KEYBOARD NOT WORKING	Madhubalan. S.	KEYBOARD WORKING FINE		Ganesh. V. - BLOOD BANK	01/02/2023
	Comp. Dt. : 01/03/2023							
	Status : Completed							
704	23030035	Blood Bank	SYSTEM NOT WORKING	Madhubalan. S.	SYSTEM RESTATED WORKING FINE		Sivasankari.I. - BLOOD BANK	01/03/2023
	Comp. Dt. : 11/05/2023							
	Status : Completed							
705	23050457	Blood Bank	PROBLEM IN NET CONNECTION	Valamburi. R.	NEW JACK FIXED		Ganesh. V. - BLOOD BANK	12/05/2023
	Comp. Dt. : 16/05/2023							
	Status : Completed							
706	23050666	Blood Bank	PROBLEM IN NET CONNECTION	Prakash. P.	REFIX THE PATCH CARD		Ganesh. V. - BLOOD BANK	16/05/2023
	Comp. Dt. : 01/06/2023							
	Status : Completed							
707	23060027	Blood Bank	NEED MEDPLUS INSTALLATION	Madhubalan. S.	MEDPLUS INSTALLED		Ganesh. V. - BLOOD BANK	01/06/2023
	Comp. Dt. : 12/06/2023							
	Status : Completed							
708	23060403	Blood Bank	KEYBOARD NOT WORKING	Shafiullah. R.	PS2 KEYBOARD RESTRA THE SYSTEM		Shri Priya. R. - BLOOD BANK	12/06/2023

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 20/06/2023 Status : Completed								
709	23060695	Blood Bank	U P S NOT WORKING	Balachandar. A.	battery changed		Ganesh. V. - BLOOD BANK	28/06/2023
Dept Name : Blood Collection Centre - Computer Department Comp. Dt. : 11/05/2022 Status : Completed								
710	22050381	Reception	DESPATHCH -NEED TO CHANGE PRINTER TONER(1021)	Valamburi. R.	12A TONER CHANGED		Kasthuribai. J. - Blood Collection Centre	11/05/2022
Comp. Dt. : 22/07/2022 Status : Completed								
711	22070844	Reception	NEED TO CHANGE TONER	Murugavel.R	TONER CHANGED		Muthalamma. R. - BLOOD BANK	22/07/2022
Comp. Dt. : 17/08/2022 Status : Completed								
712	22080552	lab report issuing counter 8 in reception	MEDPLUS SOFTWARE NOT WORKING	Selvam. D.	working fine		Kasthuribai. J. - Blood Collection Centre	18/08/2022
Comp. Dt. : 18/08/2022 Status : Completed								
713	22080599	Blood Collection Centre	NEED TO CHANGE BARCODE STICKER	Balachandar. A.	Revisit sticker changed		Muthalamma. R. - BLOOD BANK	18/08/2022
Comp. Dt. : 21/10/2022 Status : Completed								
714	22100740	Blood Collection Centre	SYSTEM NOT WORKING	Prakash. P.	power cable refixed		Kasthuribai. J. - Blood Collection Centre	22/10/2022
Comp. Dt. : 22/10/2022 Status : Completed								
715	22100747	Reception	NEED TO CHANGE TONER IN COUNTER NO. 8	Madhubalan. S.	12A TONER CHANGED		Nisha. B. - BIOCHEMISTRY	22/10/2022
Comp. Dt. : 03/11/2022 Status : Completed								
716	22110096	lab report issuing counter 8 in reception	IN COUNTER 9 CHANGE PRINTER TONER	Jayaraj. J.	PRINTER TONER CHANGED		Kasthuribai. J. - Blood Collection Centre	04/11/2022
Comp. Dt. : 05/11/2022 Status : Completed								
717	22110165	lab report issuing counter 8 in reception	PRINTER PROBLEM	Valamburi. R.	PRINTER AGAIN STARTED WORKING AUTOMATICALLY		Nisha. B. - BIOCHEMISTRY	05/11/2022

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 08/11/2022								
Status : Completed								
718	22110278	Reception	NEED TO CHANGE PRINTER TONER IN COUNTER NO.8	Madhubalan. S.	12A TONER CHANGED		Kasthuribai. J. - Blood Collection Centre	08/11/2022
Comp. Dt. : 10/11/2022								
Status : Completed								
719	22110416	lab report issuing counter 8 in reception	IN COUNTER 9-PRINTER NOT WORKING	Selvam. D.	Solinod switch serviced		Kasthuribai. J. - Blood Collection Centre	10/11/2022
Comp. Dt. : 14/11/2022								
Status : Completed								
720	22110555	lab report issuing counter 8 in reception	CHANGE PRINTER TONER	Valamburi. R.	12A toner changed		Kasthuribai. J. - Blood Collection Centre	15/11/2022
Comp. Dt. : 15/11/2022								
Status : Completed								
721	22110567	lab report issuing counter 8 in reception	SYSTEM NOT WORKING	Balachandar. A.	Os reinstalled		Kasthuribai. J. - Blood Collection Centre	16/11/2022
Comp. Dt. : 21/11/2022								
Status : Completed								
722	22110864	lab report issuing counter 8 in reception	CHANGE PRINTER TONER	Balachandar. A.	12A toner changed		Kasthuribai. J. - Blood Collection Centre	21/11/2022
723	22110887	Blood Collection Centre	CHANGE BARCODE STICKER	Shafiullah. R.	revisit stricker changed		Matchagandhi. V. - Blood Collection Centre	21/11/2022
724	22110892	lab report issuing counter 8 in reception	PRINTER PROBLEM	Selvam. D.	12 A TONER CHANGED PROBLEM SLOVED		Kasthuribai. J. - Blood Collection Centre	22/11/2022
Comp. Dt. : 23/11/2022								
Status : Completed								
725	22111008	lab report issuing counter 8 in reception	PRINTER PROBLEM	Shafiullah. R.	printer working		Thamaraiselvi. B. - BIOCHEMISTRY	23/11/2022
Comp. Dt. : 08/12/2022								
Status : Completed								
726	22120343	Reception	SYSTEM NOT WORKING - MEDPLUS NOT OPENED - COUNTER NO 8	Balachandar. A.	SYSTEM RESTARTED..		Kasthuribai. J. - Blood Collection Centre	08/12/2022
Comp. Dt. : 13/12/2022								
Status : Completed								
727	22120569	lab report issuing counter 8 in reception	CHANGE PRINTER TONER	Shafiullah. R.	12A toner changed		Kasthuribai. J. - Blood Collection Centre	13/12/2022
Comp. Dt. : 21/12/2022								

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt	
Status : Completed									
728	22120955	Reception	NEED TO CHANGE TONER IN COUNTER 8	Balachandar. A.	TONER CHANGED		Kasthuribai. J. - Blood Collection Centre	21/12/2022	
729	22120982	Reception	NEED TO CHANGE TONER IN COUNTER 9	Madhubalan. S.	12A TONER CHANGED		Kasthuribai. J. - Blood Collection Centre	21/12/2022	
Comp. Dt. : 26/12/2022									
Status : Completed									
730	22121178	Reception	NEED TO CHANGE TONER IN COUNTER 8	Selvam. D.	12A toner changed		Kasthuribai. J. - Blood Collection Centre	26/12/2022	
Comp. Dt. : 03/01/2023									
Status : Completed									
731	23010106	lab report issuing counter 8 in reception	CHANGE PRINTER TONER	Selvam. D.	12A toner changed		Kasthuribai. J. - Blood Collection Centre	04/01/2023	
Comp. Dt. : 09/01/2023									
Status : Completed									
732	23010369	Blood Collection Centre	CHANGE BARCODE STICKER	Madhubalan. S.	REVISIT STICKER CHANGED		Suguna. K. - Blood Collection Centre	09/01/2023	
Comp. Dt. : 10/01/2023									
Status : Completed									
733	23010418	lab report issuing counter 8 in reception	CHANGE PRINTER TONER	Balachandar. A.	PRINTER TONER CHANGED		Kasthuribai. J. - Blood Collection Centre	10/01/2023	
734	23010426	lab report issuing counter 8 in reception	IN COUNTER 8-SYSTEM SOFTWARE NOT WORKING	Jayaraj. J.	WORKING FINE		Kasthuribai. J. - Blood Collection Centre	11/01/2023	
Comp. Dt. : 16/03/2023									
Status : Completed									
735	23030668	Reception	NEED TO CHANGE TONER FOR COUNTER NO 8	Selvam. D.	12A toner changed		Kasthuribai. J. - Blood Collection Centre	17/03/2023	
Comp. Dt. : 15/06/2023									
Status : Completed									
736	23060559	Reception	NEED TO CHANGE PRINTER RIBBON IN COUNTER NO 8	Selvam. D.	REVISIT STICKER CHANGED		Preethi. A. - Blood Collection Centre	15/06/2023	
Dept Name : Canteen - Boys Hostel - Computer Department									
Comp. Dt. : 16/05/2022									
Status : Completed									
737	22050581	Boys hostel	PROBLEM IN CCTV CAMERA MONITOR DISPLAY	Jayaraj. J.	MONITOR CHANGED	 Dr. KAGNE. R.N DEAN SRI MANAKULA VINAYAGAR MEDICAL COLLEGE & HOSPITAL KALITHEERTHALKUPPAM, PUDUCHERRY-605107.	Sambasivam. K. - Canteen - Boys Hostel	19/05/2022	
Comp. Dt. : 25/05/2022									
Status : Completed									

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
738	22050932	Boys hostel	NEED TO CHECK SYSTEM - SOFTWARE NOT WORKING	Valamburi. R.	DHCP TRUBLESHOOT WORKING FINE..		Kesavaraj. P. - Canteen - Boys Hostel	25/05/2022
	Comp. Dt. : 04/06/2022							
	Status : Completed							
739	22060160	Boys hostel	MOUSE NOT WORKING	Valamburi. R.	old mouse changed		Anand. G. - Transport	06/06/2022
	Comp. Dt. : 15/06/2022							
	Status : Completed							
740	22060574	Boys hostel	NEED TO CHANGE TONER	Selvam. D.	TONER CHANGED		Kesavaraj. P. - Canteen - Boys Hostel	16/06/2022
	Comp. Dt. : 20/06/2022							
	Status : Completed							
741	22060720	Boys hostel	system - student software not working	Madhubalan. S.	SYSTEM RESTATED AND NETWORK CABLE REFIXED. SOFTWARE WORKING FINE		Elumalai. M. - Canteen - Boys Hostel	20/06/2022
	Comp. Dt. : 07/07/2022							
	Status : Completed							
742	22070254	DIET DEPARMENT	PROBLEM IN NET CONNECTION	Madhubalan. S.	NETWORK CABLE REFIXED		Anand. G. - Transport	08/07/2022
	Comp. Dt. : 19/09/2022							
	Status : Completed							
743	22090698	Boys hostel	NEED TO CHANGE MOUSE CABLE FOR DAMAGED BY THE RAT	Jayaraj. J.	NEW USB MOUSE CHANGED		Kesavaraj. P. - Canteen - Boys Hostel	20/09/2022
744	22090750	Boys hostel	PRINTER NOT WORKING	Balachandar. A.	PENDING JOB CLEARED		Elumalai. M. - Canteen - Boys Hostel	20/09/2022
	Comp. Dt. : 24/09/2022							
	Status : Completed							
745	22090970	Boys hostel	NEED TO CHECK WI FI CONNECTION - NOT WORKING	Valamburi. R.	checked working fine..		Sambasivam. K. - Canteen - Boys Hostel	11/10/2022
	Comp. Dt. : 05/10/2022							
	Status : Completed							
746	22100034	Boys hostel	MOUSE NOT WORKING	Shafiullah. R.	MOUSE CABLE CHANGED		Anand. G. - Transport	05/10/2022
	Comp. Dt. : 06/10/2022							
	Status : Completed							


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
747	22100088	Boys hostel	MOUSE NOT WORKING	Jayaraj. J.	MOUSE USB CABLE CHANGED		Kesavaraj. P. - Canteen - Boys Hostel	07/10/2022
Comp. Dt. : 19/10/2022 Status : Completed								
748	22100633	Boys hostel	(2812)MOUSE NOT WORKING	Prakash. P.	MOUSE CHANGED		Anand. G. - Transport	20/10/2022
Comp. Dt. : 28/10/2022 Status : Completed								
749	22100909	Boys hostel	CHANGE PRINTER CATRIDGE-KITCHEN ENTRANCE AREA	Selvam. D.	12A toner changed		Kesavaraj. P. - Canteen - Boys Hostel	29/10/2022
Comp. Dt. : 05/11/2022 Status : Completed								
750	22110178	Boys hostel	IN COMPUTER ROOM-SYSTEM NOT WORKING	Balachandar. A.	DOMAIN REFIXED WORKING FINE..		Kesavaraj. P. - Canteen - Boys Hostel	07/11/2022
Comp. Dt. : 10/11/2022 Status : Completed								
751	22110422	BOY HOSTEL MESS	SYSTEM, NOT WORKING-2812	Madhubalan. S.,Valamburi. R.,Balachandar. A.	Point to point adjusted.Tested its working fine		Elumalai. M. - Canteen - Boys Hostel	16/11/2022
Comp. Dt. : 23/11/2022 Status : Completed								
752	22110969	Boys hostel	SYSTEM NOT WORKING - POWER PROBLEM	Prakash. P.	Os reinstalled		Kesavaraj. P. - Canteen - Boys Hostel	26/11/2022
Comp. Dt. : 20/12/2022 Status : Completed								
753	22120916	Boys hostel	SYSTEM NOT WORKING IN COMPUTER ROOM	Selvam. D.	IP ADDRESS GIVEN WORKING		Elumalai. M. - Canteen - Boys Hostel	26/12/2022
Comp. Dt. : 06/01/2023 Status : Completed								
754	23010274	Boys hostel	(2812) PRINTER NOT WORKING	Madhubalan. S.	PRINTER USB CABLE REFIXED WORKING FINE		Anand. G. - Transport	06/01/2023
Comp. Dt. : 25/01/2023 Status : Completed								
755	23010899	Boys hostel	NEED TO CHANGE TONER	Shafiullah. R.	12A TONER CHAGED		Kesavaraj. P. - Canteen - Boys Hostel	25/01/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 21/03/2023 Status : Completed								
756	23030882	Boys hostel	NEED TO CHANGE PRINTER TONER	Prakash. P.	12A TONER CHANGED		Kesavaraj. P. - Canteen - Boys Hostel	21/03/2023
Dept Name : Canteen - Hospital - Computer Department Comp. Dt. : 21/07/2022 Status : Completed								
757	22070811	DIET DEPARMENT	NEED TO CHANGE TONER	Madhubalan. S.	12A TONER CHANGED		Suriyaprakash. R. J. - Canteen - Hospital	22/07/2022
Comp. Dt. : 29/07/2022 Status : Completed								
758	22071052	DIET DEPARMENT	SOFTWARE PROBLEM - NEED TO CHECK	Selvam. D.	user need to get approval for head of Dept.		Suriyaprakash. R. J. - Canteen - Hospital	02/08/2022
Comp. Dt. : 26/09/2022 Status : Completed								
759	22091017	DIET DEPARMENT	NEED TO CHECK KEYBOARD & MOUSE - NOT WORKING	Madhubalan. S.	SYSTEM RESTATED KEYBOARD MOUSE WORKING FINE		Suriyaprakash. R. J. - Canteen - Hospital	26/09/2022
Comp. Dt. : 27/09/2022 Status : Completed								
760	22091038	DIET DEPARMENT	NEED TO CHECK NET CONNECTION	Valamburi. R.	NETWORK CABLE REFIXED		Suriyaprakash. R. J. - Canteen - Hospital	27/09/2022
Comp. Dt. : 22/11/2022 Status : Completed								
761	22110914	DIET DEPARMENT	SYSTEM NOT WORKING	Balachandar. A.	system restarted..		Suriyaprakash. R. J. - Canteen - Hospital	22/11/2022
Comp. Dt. : 20/12/2022 Status : Completed								
762	22120882	DIET DEPARMENT	NETWORK PROBLEM	Murugavel.R	IP CHANGED NETWORKING FINE		Suriyaprakash. R. J. - Canteen - Hospital	20/12/2022
Comp. Dt. : 23/12/2022 Status : Completed								
763	22121057	DIET DEPARMENT	NETWORK PROBLEM	Madhubalan. S.	Patch cable refixed		Suriyaprakash. R. J. - Canteen - Hospital	26/12/2022
Comp. Dt. : 26/12/2022 Status : Completed								
764	22121137	DIET DEPARMENT	SYSTEM NOT WORKING	Selvam. D.	system working fine		Suriyaprakash. R. J. - Canteen - Hospital	26/12/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
	Comp. Dt. : 31/12/2022							
	Status : Completed							
765	22121385	DIET DEPARMENT	SYSTEM NETWORK ISSUE	Shafiullah. R.	patch cable refixed		Suriyaprakash. R. J. - Canteen - Hospital	02/01/2023
	Comp. Dt. : 19/01/2023							
	Status : Completed							
766	23010650	DIET DEPARMENT	NEED TO CHECK NET CONNECTION - PROBLEM	Balachandar. A.	ip address given		Suriyaprakash. R. J. - Canteen - Hospital	19/01/2023
	Comp. Dt. : 27/01/2023							
	Status : Completed							
767	23010955	DIET DEPARMENT	SYSTEM NOT WORKING-1440	Shafiullah. R.	As of now there is no problem in the system hence the call closed		Suriyaprakash. R. J. - Canteen - Hospital	02/02/2023
	Comp. Dt. : 21/02/2023							
	Status : Completed							
768	23020801	DIET DEPARMENT	NET NOT WORKING	Valamburi. R.	NET WORKING		Suriyaprakash. R. J. - Canteen - Hospital	21/02/2023
	Comp. Dt. : 03/03/2023							
	Status : Completed							
769	23030114	DIET DEPARMENT	SYSTEM NOT WORKING	Selvam. D.	Power drained and tested system working fine		Suriyaprakash. R. J. - Canteen - Hospital	03/03/2023
	Comp. Dt. : 07/03/2023							
	Status : Completed							
770	23030275	DIET DEPARMENT	NEED TO CHANGE TONER	Harikrishnan. R.	12A TONER CHANGED		Suriyaprakash. R. J. - Canteen - Hospital	07/03/2023
	Comp. Dt. : 21/03/2023							
	Status : Completed							
771	23030870	DIET DEPARMENT	NET PROBLEM - SYSTEM NOT WORKING	Selvam. D.	patch cable refixed		Suriyaprakash. R. J. - Canteen - Hospital	22/03/2023
	Comp. Dt. : 27/03/2023							
	Status : Completed							
772	23031089	DIET DEPARMENT	SYSTEM NOT WORKING	Shafiullah. R.	DISPLAY PROBLEM CLEAN RAM AND REFIX		Suriyaprakash. R. J. - Canteen - Hospital	27/03/2023
	Comp. Dt. : 20/06/2023							
	Status : Completed							
773	23060710	DIET DEPARMENT	NEED TO CHANGE TONER	Madhubalan. S.	12A TONER CHANGED		Suriyaprakash. R. J. - Canteen - Hospital	21/06/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Dept Name : Canteen-Girls Hostel - Computer Department Comp. Dt. : 29/09/2022 Status : Completed								
774	22091153	Ladies hostel Phase-II	NEED TO REARRANGE WIFI CABLES	Valamburi. R.	REARRANGE WIFI CABLES		Malliga. K. - Canteen-Girls Hostel	05/10/2022
Comp. Dt. : 04/02/2023 Status : Completed								
775	23020134	Ladies hostel Phase-II	WI -FI SIGNAL PROBLEM	Balachandar. A.	checked all floor working fine		Malliga. K. - Canteen-Girls Hostel	14/02/2023
Comp. Dt. : 24/03/2023 Status : Completed								
776	23031015	J.R Quateres	NEED TO CHECK CAMERA MONITOR - NOT WORKING	Prakash. P.	power cable refixed		Virgin Mary - Canteen-Girls Hostel	29/03/2023
Comp. Dt. : 25/04/2023 Status : Completed								
777	23040816	Ladies hostel Phase-II	NEED TO CHECK NET WORK CONNECTION - PROBLEM IN ROOM NO 19	Shafiullah. R.	USER LOGIN PROBLEM		Malliga. K. - Canteen-Girls Hostel	26/04/2023
Comp. Dt. : 12/06/2023 Status : Completed								
778	23060395	JR Quarters	NEED TO CHECK WI FI CONNECTION NOT WORKING	Prakash. P.	ELECTRICAL NETURAL POWER CUT NOW WORKING		Virgin Mary - Canteen-Girls Hostel	12/06/2023
Dept Name : CARDIOLOGY - Computer Department Comp. Dt. : 20/06/2022 Status : Completed								
779	22060718	ECHO CARDIO GRAM	NEED TO CHANGE PRINTER CARTRIDGE	Selvam. D.	Print head cleaned. Tested the printer working fine		Chitra. V. - CARDIOLOGY	20/06/2022
Comp. Dt. : 28/06/2022 Status : Completed								
780	22060992	ECHO CARDIO GRAM	NEED TO CHANGE PRINTER CARTRIDGE	Selvam. D.	print head clean and nozzel check		Ramani Palanivel.P. - CARDIOLOGY	28/06/2022
Comp. Dt. : 05/07/2022 Status : Completed								
781	22070134	ECHO CARDIO GRAM	SYSTEM SLOW PROBLEM	Selvam. D.	temp files cleared and check the system working fine		Ramani Palanivel.P. - CARDIOLOGY	05/07/2022
Comp. Dt. : 07/07/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
782	22070270	ECHO CARDIO GRAM	PRINTER NOT WORKING	Selvam. D.	Head cleaning done		Ramani Palanivel.P. - CARDIOLOGY	07/07/2022
	Comp. Dt. : 20/07/2022							
	Status : Completed							
783	22070754	ECHO CARDIO GRAM	NEED TO REFIL PRINTER INK [BLACK]	Selvam. D.	black ink changed		Aarthi. A. - CARDIOLOGY	20/07/2022
	Comp. Dt. : 21/07/2022							
	Status : Completed							
784	22070808	ECHO CARDIO GRAM	PRINTER NOT WORKING	Murugavel.R	Print queue cleared and tested the printer working fine		Aarthi. A. - CARDIOLOGY	21/07/2022
	Comp. Dt. : 09/08/2022							
	Status : Completed							
785	22080338	ECHO CARDIO GRAM	T M T SYSTEM NOT WORKING	Selvam. D.	Ram cleaned and refixed		Ramani Palanivel.P. - CARDIOLOGY	10/08/2022
	Comp. Dt. : 12/08/2022							
	Status : Completed							
786	22080428	ECHO CARDIO GRAM	NEED TO CHECK T M T SYSTEM - NOT WORKING	Jayaraj. J.	RAM CHANGED		Aarthi. A. - CARDIOLOGY	12/08/2022
	Comp. Dt. : 01/09/2022							
	Status : Completed							
787	22090047	ECHO CARDIO GRAM	NEED TO REFIL PRINTER INK	Shafiullah. R.	BLACK INK REFILL		Chitra. V. - CARDIOLOGY	01/09/2022
	Comp. Dt. : 09/09/2022							
	Status : Completed							
788	22090348	ECHO CARDIO GRAM	PRINTER NOT WORKING	Balachandar. A.	power cable refixed		Aarthi. A. - CARDIOLOGY	09/09/2022
	Comp. Dt. : 28/10/2022							
	Status : Completed							
789	22100889	ECHO CARDIO GRAM	NEED TO CHANGE TONER	Selvam. D.	Black ink filled		Chitra. V. - CARDIOLOGY	28/10/2022
	Comp. Dt. : 18/11/2022							
	Status : Completed							
790	22110767	ECG ROOM NEAR MEDICINE OPD	PRINTER NOT WORKING	Selvam. D.	printer working fine		Aarthi. A. - CARDIOLOGY	19/11/2022
	Comp. Dt. : 14/01/2023							
	Status : Completed							
791	23010587	ECHO CARDIO GRAM	SYSTEM NOT WORKING	Jayaraj. J.	SYSTEM RESTARED		Ramani Palanivel.P. - CARDIOLOGY	14/01/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 09/02/2023 Status : Completed								
792	23020322	ECHO CARDIO GRAM	PRINTER NOT WORKING	Valamburi. R.	POWER CABLE REFIXED		Ramani Palanivel.P. - CARDIOLOGY	09/02/2023
Comp. Dt. : 28/02/2023 Status : Completed								
793	23021062	ECHO CARDIO GRAM	(1090)KEYBOARD NOT WORKING	Shafiullah. R.	LOGITECH USB KEYBOARD CHANGED		Ramani Palanivel.P. - CARDIOLOGY	28/02/2023
Comp. Dt. : 23/03/2023 Status : Completed								
794	23030948	ECHO CARDIO GRAM	NEED TO CHANGE TONER	Shafiullah. R.	88A TONER CHANGED		Chitra. V. - CARDIOLOGY	23/03/2023
Comp. Dt. : 03/04/2023 Status : Completed								
795	23040039	ECHO CARDIO GRAM	PRINTER NOT WORKING	Jayaraj. J.	PRINTER WORKING		Ramani Palanivel.P. - CARDIOLOGY	03/04/2023
Comp. Dt. : 15/04/2023 Status : Completed								
796	23040445	ECHO CARDIO GRAM	PRINTER NOT WORKING	Selvam. D.	nozzel clean		Ramani Palanivel.P. - CARDIOLOGY	17/04/2023
Comp. Dt. : 09/05/2023 Status : Completed								
797	23050381	ECHO CARDIO GRAM	PRINTER NOT WORKING	Valamburi. R.	PRINTER WORKING		Ramani Palanivel.P. - CARDIOLOGY	12/05/2023
Comp. Dt. : 15/05/2023 Status : Completed								
798	23050567	ECHO CARDIO GRAM	PRINTER NOT WORKING	Shafiullah. R.	INK FLUSH PRINTER WORKING		Ramani Palanivel.P. - CARDIOLOGY	15/05/2023
799	23050571	Cath Lab	C P U NOT WORKING	Shafiullah. R.	NO DISPLAY AMC COMPANY PROBLEM INFORM TO BIOMEDICAL		Deva Arul Selva Sagayaraj. A. - CARDIOLOGY	15/05/2023
Comp. Dt. : 17/05/2023 Status : Completed								
800	23050702	Cath Lab	SERVER NOT WORKING	Balachandar. A.	Network cable refixed.		Deva Arul Selva Sagayaraj. A. - CARDIOLOGY	17/05/2023
Comp. Dt. : 26/05/2023 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
801	23051059	ECHO CARDIO GRAM	NEED TO REFIL CARTRIDGE	Shafiullah. R.	Cartridge Refilled.		Ramani Palanivel.P. - CARDIOLOGY	26/05/2023
	Comp. Dt. : 01/06/2023							
	Status : Completed							
802	23060013	ECHO CARDIO GRAM	PRINTER NOT WORKING	Madhubalan. S.	INK DARK FLUSHING CLEAR. WORKING FINE		Ramani Palanivel.P. - CARDIOLOGY	01/06/2023
	Dept Name : Cardiothoracic ICU - Computer Department							
	Comp. Dt. : 06/02/2023							
	Status : Completed							
803	23020193	CTVS INSIDE ORTHO OT	CD DRIVE NOT WORKING	Jayaraj. J.	cd drive dust cleaned.		Sadham Husain. S. - Cardiothoracic ICU	09/02/2023
	Dept Name : Cardiothoracic Surgery - Computer Department							
	Comp. Dt. : 16/06/2022							
	Status : Completed							
804	22060593	CTVS-ROOM NO.225 -2ND FLOOR	SYSTEM NOT WORKING	Balachandar. A.	power cable refixed		Mohammed Altaf. M. - Cardiothoracic Surgery	16/06/2022
	Comp. Dt. : 03/01/2023							
	Status : Completed							
805	23010085	CTVS-ROOM NO.225 -2ND FLOOR	system not working	Balachandar. A.	smpls changed		Rajasekar. M. - Cardiothoracic Surgery	04/01/2023
	Comp. Dt. : 03/05/2023							
	Status : Completed							
806	23050118	CTVS-ROOM NO.225 -2ND FLOOR	PROBLEM IN PRINTER	Shafiullah. R.	printer working fine		Madhumitha. S. - Cardiothoracic Surgery	05/05/2023
	Comp. Dt. : 13/05/2023							
	Status : Completed							
807	23050546	CTVS-ROOM NO.225 -2ND FLOOR	PRINTER PAPER JAM - INTERCOM NO 1255	Shafiullah. R.	PRINTER PAPER JAM REMOVED		Vishakha. M. - Cardiothoracic Surgery	16/05/2023
	Comp. Dt. : 17/05/2023							
	Status : Completed							
808	23050717	CTVS-ROOM NO.225 -2ND FLOOR	PRINTER NOT WORKING	Selvam. D.	printer working fine		Madhumitha. S. - Cardiothoracic Surgery	18/05/2023
	Comp. Dt. : 01/06/2023							
	Status : Completed							


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
809	23060016	CTVS-ROOM NO.225 -2ND FLOOR	PRINTER NOT WORKING	Shafiullah. R.	PRINTER SETTING CHANGED		Vishakha. M. - Cardiothoracic Surgery	01/06/2023
810	23060039	CTVS-ROOM NO.225 -2ND FLOOR	PRINTER NOT WORKING	Balachandar. A.	PENDING JOB CLEARED		Madhumitha. S. - Cardiothoracic Surgery	02/06/2023
Comp. Dt. : 20/06/2023 Status : Completed								
811	23060725	CTVS-ROOM NO.225 -2ND FLOOR	MEDPLUS - NET PROBLEM - NEED TO CHECK	Prakash. P.	Network problem fixed		Madhumitha. S. - Cardiothoracic Surgery	20/06/2023
Comp. Dt. : 26/06/2023 Status : Completed								
812	23060967	CTVS-ROOM NO.225 -2ND FLOOR	PRINTER NOT WORKING	Selvam. D.	system restart		Madhumitha. S. - Cardiothoracic Surgery	27/06/2023
Comp. Dt. : 30/06/2023 Status : Completed								
813	23061118	CTVS-ROOM NO.225 -2ND FLOOR	SYSTEM NOT WORKING	Shafiullah. R.	SYSTEM WORKING FINE		Vishakha. M. - Cardiothoracic Surgery	30/06/2023
Dept Name : Cath Lab - Computer Department Comp. Dt. : 25/05/2022 Status : Completed								
814	22050945	Cath Lab	MOUSE NOT WORKING	Madhubalan. S.	SYSTEM RESTATE MOUSE WILL BE WORKING		Muthukumaran. S. - Cath Lab	25/05/2022
Comp. Dt. : 04/07/2022 Status : Completed								
815	22070089	Cath Lab	MOUSE NOT WORKING	Valamburi. R.	mouse usb cable unplugged		Muthukumaran. S. - Cath Lab	04/07/2022
Comp. Dt. : 07/10/2022 Status : Completed								
816	22100142	Cath Lab	MOUSE NOT WORKING	Selvam. D.	MOUSE REFIXED		Muthukumaran. S. - Cath Lab	07/10/2022
Comp. Dt. : 27/04/2023 Status : Completed								
817	23040931	Cath Lab	SYSTEM NOT WORKING	Jayaraj. J.	SYSTEM TEMP FILE CLEAN AND RESTARED		Muthukumaran. S. - Cath Lab	27/04/2023
Dept Name : Civil - Execution - Computer Department Comp. Dt. : 20/05/2022								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
818	22050734	Civil - Execution	KEYBOARD NOT WORKING	Balachandar. A.	KEYBOARD USB REFIXED...		Surendhiran. R. - Civil - Execution	23/05/2022
Comp. Dt. : 04/06/2022								
Status : Completed								
819	22060165	CIVIL EXECUTION OFFICE	Printer not working.	Murugavel.R	reinstall printer drive		Murugan.N. - Civil - Execution	04/06/2022
Comp. Dt. : 14/06/2022								
Status : Completed								
820	22060496	Civil - Execution	NEED TO CHECK SYSTEM - NET WORK PROBLEM	Prakash. P.	REFIX PATCHCARD NETWORK WORKING		Surendhiran. R. - Civil - Execution	14/06/2022
Comp. Dt. : 23/09/2022								
Status : Completed								
821	22090923	CIVIL	COMPUTER NOT WORKING	Jayaraj. J.	TEMP FILE CLEAR		Surendhiran. R. - Civil - Execution	26/09/2022
Comp. Dt. : 30/09/2022								
Status : Completed								
822	22091229	Civil - Execution	NEED TO RECOVERY DISKTOP FILES - DELETED UNFORTUNATELY	Selvam. D.	restore done		Praveen Kumar. K. - Civil - Execution	30/09/2022
Comp. Dt. : 10/10/2022								
Status : Completed								
823	22100246	Civil - Execution	AUTO CAD SOFTWARE NOT RESPONDING	Balachandar. A.	AutoCAD software reinstalled		Sasikala. P. - Civil - Execution	13/10/2022
Comp. Dt. : 13/10/2022								
Status : Completed								
824	22100382	Civil - Maintenance	NEED TO CHECK PRINTER TO XEROX MACHINE CONNECTION - PRINT NOT COMING	Madhubalan. S.	XEROX MACHINE CABLE REFIXED WORKING FINE		Surendhiran. R. - Civil - Execution	13/10/2022
Comp. Dt. : 14/11/2022								
Status : Completed								
825	22110505	Civil - Execution	XEROX MACHINE PRINTER NOT WORKING	Balachandar. A.	working fine		Surendhiran. R. - Civil - Execution	16/11/2022
826	22110553	CIVIL EXECUTION OFFICE	SYSTEM GETTING HANG	Balachandar. A.	temp file cleared		Surendhiran. R. - Civil - Execution	16/11/2022
Comp. Dt. : 16/11/2022								
Status : Completed								
827	22110637	CIVIL EXECUTION OFFICE	SYSTEM NOT WORKING	Murugavel.R	SYSTEM WORKING FINE		Surendhiran. R. - Civil - Execution	16/11/2022

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 17/11/2022 Status : Completed								
828	22110708	CIVIL EXECUTION OFFICE	UPS PROBLEM	Balachandar. A.	lithum ups changed		Surendhiran. R. - Civil - Execution	21/11/2022
Comp. Dt. : 19/11/2022 Status : Completed								
829	22110813	Civil - Maintenance	MOUSE NOT WORKING	Balachandar. A.	USB MOUSE REFIXED		Surendhiran. R. - Civil - Execution	19/11/2022
Comp. Dt. : 21/11/2022 Status : Completed								
830	22110848	CIVIL MAINTENANCE OFFICE	NEED TO CHECK MOUSE NOT WORKING	Selvam. D.	USB MOUSE CHANGED		Surendhiran. R. - Civil - Execution	21/11/2022
Comp. Dt. : 16/12/2022 Status : Completed								
831	22120772	Civil - Maintenance	U P S NOT WORKING	Jayaraj. J.	NEW UPS CHANGED		Surendhiran. R. - Civil - Execution	18/01/2023
Comp. Dt. : 17/02/2023 Status : Completed								
832	23020683	Civil - Execution	XEROX MACHINE - PRINT IS NOT CLEAR	Selvam. D.	not my side issue manikandar tranders		Surendhiran. R. - Civil - Execution	17/02/2023
Comp. Dt. : 15/04/2023 Status : Completed								
833	23040442	Civil - Execution	NEED TO CHANGE MONITOR PROBE	Balachandar. A.	power cable refixed		Surendhiran. R. - Civil - Execution	17/04/2023
Comp. Dt. : 31/05/2023 Status : Completed								
834	23051238	Civil - Execution	NET WORK PROBLEM	Murugavel.R	CHECKED UPS TRIP PROBLEM SLOVED		Surendhiran. R. - Civil - Execution	01/06/2023
Dept Name : Civil - Maintenance - Computer Department Comp. Dt. : 14/07/2022 Status : Completed								
835	22070566	Civil - Maintenance	PROBLEM IN UPS BACKUP	Selvam. D.	New numeric ups changed		Barathi. P. - Civil - Maintenance	16/07/2022
Comp. Dt. : 11/08/2022 Status : Completed								
836	22080403	Civil - Execution	SYSTEM NOT WORKING	Balachandar. A.	SYSTEM RESTORED...		Barathi. P. - Civil - Maintenance	11/08/2022
Comp. Dt. : 06/10/2022								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
837	22100115	Civil - Maintenance	NEED TO CHANGE TONER	Madhubalan. S.	12A toner changed		Gurunathan. V. - Civil - Maintenance	06/10/2022
Comp. Dt. : 16/11/2022								
Status : Completed								
838	22110692	CIVIL MAINTENANCE OFFICE	SYSTEM WORKING SLOWLY	Murugavel.R	2gb DDR3 RAM upgrade		Barathi. P. - Civil - Maintenance	29/12/2022
Comp. Dt. : 24/01/2023								
Status : Completed								
839	23010872	CIVIL MAINTENANCE OFFICE	Printer toner not working in properly, need to be change	Shafiullah. R.	12A TONER CHANGED		Gurunathan. V. - Civil - Maintenance	24/01/2023
Comp. Dt. : 31/01/2023								
Status : Completed								
840	23011099	PRESS	UPS NOT WORKING	Madhubalan. S.	online ups problem complaint forwarded to electrical		Thirunavukkarasu. V. - Civil - Maintenance	02/02/2023
Comp. Dt. : 27/03/2023								
Status : Completed								
841	23031130	Civil - Maintenance	NEED TO CHANGE TONER	Harikrishnan. R.	88A TONER CHANGED		Barathi. P. - Civil - Maintenance	27/03/2023
Comp. Dt. : 28/03/2023								
Status : Completed								
842	23031170	OSD	NEED TO CHANGE TONER FOR [O S D SIR SYSTEM]	Selvam. D.	12a TONER CHANGED		Barathi. P. - Civil - Maintenance	28/03/2023
Comp. Dt. : 26/04/2023								
Status : Completed								
843	23040854	CIVIL MAINTENANCE OFFICE	PROBLEM IN U P S BACK UP	Murugavel.R	Lithium ups changed		Barathi. P. - Civil - Maintenance	24/05/2023
Dept Name : Clinical Department - Computer Department								
Comp. Dt. : 04/05/2022								
Status : Completed								
844	22050114	CLINICAL DEPARTMENT IN 2ND FLOOR	NEED TO CHANGE TONER	Shafiullah. R.	88A TONER CHANGED		Kheerthikaa. V. - Clinical Department	05/05/2022
Comp. Dt. : 14/05/2022								
Status : Completed								
845	22050507	CLINICAL DEPARTMENT IN 3RD FLOOR	PRINTER NOT WORKING	Selvam. D.	Paper jam cleared and it working fine		Arvi. A. - Clinical Department	18/05/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 16/05/2022								
Status : Completed								
846	22050579	CLINICAL DEPARTMENT IN 2ND FLOOR	NEED TO CHANGE TONER	Jayaraj. J.	TONER CHANGED		Shuruthi. B. - Clinical Department	18/05/2022
Comp. Dt. : 19/05/2022								
Status : Completed								
847	22050724	CLINICAL DEPARTMENT IN 3RD FLOOR	NEED TO CHANGE TONER	Madhubalan. S.	12A TONER CHANGED		Manimegalai. M. - Clinical Department	19/05/2022
Comp. Dt. : 20/05/2022								
Status : Completed								
848	22050730	CLINICAL DEPARTMENT IN 4th FLOOR	NEED TO CHANGE TONER	Selvam. D.	88a toner changed		Vimal. P. - Clinical Department	20/05/2022
849	22050760	CLINICAL DEPARTMENT IN 2ND FLOOR	NEED TO CHECK NET CONNECTION FOR SEMINOR ROOM	Balachandar. A.	NETWORK CABLE REFIXED		Shuruthi. B. - Clinical Department	23/05/2022
Comp. Dt. : 24/05/2022								
Status : Completed								
850	22050905	CLINICAL DEPARTMENT IN 4th FLOOR	NEED TO CHANGE TONER	Jayaraj. J.	12A TONER CHANGED		Bhuvana.M. - Clinical Department	24/05/2022
851	22050907	CLINICAL DEPARTMENT IN 3RD FLOOR	NEED TO CHECK LED SCREEN - DISPLAY PROBLEM IN SEMINOR ROOM	Jayaraj. J.	VGA CABLE REFIX		Sangeetha. C. - Clinical Department	24/05/2022
Comp. Dt. : 25/05/2022								
Status : Completed								
852	22050929	CLINICAL DEPARTMENT IN 3RD FLOOR	NEED TO CHECK SYSTEM - SHARE & SOFTWARE NOT WORKING	Madhubalan. S.	NETWORK CABLE REFIXED		Sangeetha. C. - Clinical Department	25/05/2022
Comp. Dt. : 30/05/2022								
Status : Completed								
853	22051104	CLINICAL DEPARTMENT IN 2ND FLOOR	NEED TO CHANGE TONER	Madhubalan. S.	12A TONER CHANGED		Kheerthikaa. V. - Clinical Department	30/05/2022
Comp. Dt. : 31/05/2022								
Status : Completed								
854	22051124	CLINICAL DEPARTMENT IN 3RD FLOOR	NEED TO CHECK NETWORK CONNECTION	Shafiullah. R.	Network cable refixed		Sangeetha. C. - Clinical Department	31/05/2022
Comp. Dt. : 03/06/2022								
Status : Completed								
855	22060103	Dean (Academic) Office	NEED TO CHANGE TONER	Balachandar. A.	TONER CHANGED		Vijayalakshmi.N - Clinical Department	03/06/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 07/06/2022 Status : Completed								
856	22060268	CLINICAL DEPARTMENT IN 2ND FLOOR	NEED TO CHANGE TONER	Selvam. D.	88a toner changed		Shuruthi. B. - Clinical Department	07/06/2022
Comp. Dt. : 08/06/2022 Status : Completed								
857	22060318	CLINICAL DEPARTMENT IN 3RD FLOOR	NEED TO CHANGE TONER	Madhubalan. S.	88A TONER CHANGED		Selvi. A. - Clinical Department	08/06/2022
Comp. Dt. : 10/06/2022 Status : Completed								
858	22060393	CLINICAL DEPARTMENT IN 4th FLOOR	CHNAGE PRINTER TONER	Madhubalan. S.	88A TONER CHANGED		Suguna. D. - Clinical Department	10/06/2022
Comp. Dt. : 15/06/2022 Status : Completed								
859	22060583	CLINICAL DEPARTMENT IN 4th FLOOR	PRINTER NOT WORKING - OG ROOM	Balachandar. A.	checked working fine..		Vimal. P. - Clinical Department	16/06/2022
Comp. Dt. : 17/06/2022 Status : Completed								
860	22060640	Ophthalmology - OPD	SYSTEM NOT WORKING	Murugavel.R	STARTUP REPAIR PROBLEM RUN CHKDSK AND FIXED PROBLEM SLOVED		Suguna. D. - Clinical Department	17/06/2022
Comp. Dt. : 24/06/2022 Status : Completed								
861	22060878	CLINICAL DEPARTMENT IN 2ND FLOOR	SOFTWARE NOT WORKING	Balachandar. A.	history cleaned working fine..		Kheerthikaa. V. - Clinical Department	24/06/2022
Comp. Dt. : 28/06/2022 Status : Completed								
862	22061012	CLINICAL DEPARTMENT IN 4th FLOOR	PROBLEM IN U P S - BACKUP NOT MAINTAINED	Selvam. D.	New ups battey changed		Bhuvana.M. - Clinical Department	15/07/2022
863	22061013	TB & Chest / Psychiatry	PRINTER NOT WORKING	Selvam. D.	Teflon sleeve and pick up roller changed		Parasuraman. R. - Medical Records	29/06/2022
Comp. Dt. : 11/07/2022 Status : Completed								
864	22070439	CLINICAL DEPARTMENT IN 3RD FLOOR	NEED TP CHANGE TONER	Selvam. D.	88A toner changed		Manimegalai. M. - Clinical Department	13/07/2022
Comp. Dt. : 15/07/2022 Status : Completed								
865	22070576	CLINICAL DEPARTMENT IN 2ND FLOOR	NEED TO CHANGE TONER	Jayaraj. J.	88a toner changed		Kheerthikaa. V. - Clinical Department	15/07/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 18/07/2022 Status : Completed								
866	22070667	CLINICAL DEPARTMENT IN 3RD FLOOR	NEED TO CHECK NET CONNECTION - NOT WORKING AT SEMINOR ROOM [RIGHT SIDE]]	Shafiullah. R.	REFIX PATCH CARD		Manimegalai. M. - Clinical Department	18/07/2022
Comp. Dt. : 23/07/2022 Status : Completed								
867	22070857	CLINICAL DEPARTMENT IN 3RD FLOOR	NEED TO CHECK BIO METRIC CABLE CONNECTION - PROBLEM	Selvam. D.	RJ 45 jack crimmpped		Selvi. A. - Clinical Department	25/07/2022
868	22070865	CLINICAL DEPARTMENT IN 3RD FLOOR	NEED TO CHANGE CORRECT TIME IN BIOMETRIC MACHINE - WRONG TIME DISPLAY	Balachandar. A.	set time given software		Sangeetha. C. - Clinical Department	23/07/2022
Comp. Dt. : 26/07/2022 Status : Completed								
869	22070966	CLINICAL DEPARTMENT IN 2ND FLOOR	NEED TO CHECK U P S - NOT WORKING	Balachandar. A.	New ups changed		Shuruthi. B. - Clinical Department	29/07/2022
Comp. Dt. : 04/08/2022 Status : Completed								
870	22080156	Reception	IN COUNT 5 CHANGE NEW BARCODE STICKER	Selvam. D.	Barcode ribbon chagned		Suguna. D. - Clinical Department	04/08/2022
871	22080181	CLINICAL DEPARTMENT IN 4th FLOOR	SYSTEM NOT WORKING	Madhubalan. S.	UPS NEW BATTERY CHANGED		Suguna. D. - Clinical Department	29/08/2022
Comp. Dt. : 05/08/2022 Status : Completed								
872	22080203	CLINICAL DEPARTMENT IN 3RD FLOOR	PRINTER NOT WORKING	Madhubalan. S.	PRINTER WORKING FINE		Sangeetha. C. - Clinical Department	06/08/2022
Comp. Dt. : 09/08/2022 Status : Completed								
873	22080329	CLINICAL DEPARTMENT IN 4th FLOOR	NEED TO CHANGE TONER	Jayaraj. J.	88A toner changed		Vimal. P. - Clinical Department	09/08/2022
Comp. Dt. : 12/08/2022 Status : Completed								
874	22080454	CLINICAL DEPARTMENT IN 4th FLOOR	MOUSE NOT WORKING - OG DEPT	Jayaraj. J.	MOUSE PAD CHANGED		Vimal. P. - Clinical Department	13/08/2022
Comp. Dt. : 13/08/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
875	22080464	CLINICAL DEPARTMENT IN 4th FLOOR	C P U NOT WORKING	Prakash. P.	RAM CLEANED AND DUST CLEARED		Suguna. D. - Clinical Department	13/08/2022
	Comp. Dt. : 17/08/2022							
	Status : Completed							
876	22080521	CLINICAL DEPARTMENT IN 4th FLOOR	SYSTEM MOUSE NOT WORKING	Selvam. D.	Mouse refixed		Vimal. P. - Clinical Department	17/08/2022
	Comp. Dt. : 18/08/2022							
	Status : Completed							
877	22080558	CLINICAL DEPARTMENT IN 4th FLOOR	UPS NOT WORKING	Balachandar. A.	UPS RAW POWER TEMPERUARY GIVEN		Suguna. D. - Clinical Department	20/08/2022
878	22080562	CLINICAL DEPARTMENT IN 4th FLOOR	CHANGE PRINTER TONER	Selvam. D.	88A toner changed		Suguna. D. - Clinical Department	18/08/2022
	Comp. Dt. : 20/08/2022							
	Status : Completed							
879	22080662	CLINICAL DEPARTMENT IN 3RD FLOOR	NEED TO CHANGE TONER	Jayaraj. J.	toner changed		Sangeetha. C. - Clinical Department	20/08/2022
	Comp. Dt. : 22/08/2022							
	Status : Completed							
880	22080727	CLINICAL DEPARTMENT IN 4th FLOOR	NEED TO CHANGE TONER	Madhubalan. S.	12A TONER CHANGED		Bhuvana.M. - Clinical Department	22/08/2022
	Comp. Dt. : 05/09/2022							
	Status : Completed							
881	22090191	CLINICAL DEPARTMENT IN 3RD FLOOR	NEED TO CHANGE TONER	Madhubalan. S.	88A toner changed		Manimegalai. M. - Clinical Department	05/09/2022
	Comp. Dt. : 07/09/2022							
	Status : Completed							
882	22090259	CLINICAL DEPARTMENT IN 4th FLOOR	C P U NOT OPEN	Balachandar. A.	power cable refixed		Suguna. D. - Clinical Department	07/09/2022
	Comp. Dt. : 14/09/2022							
	Status : Completed							
883	22090534	CLINICAL DEPARTMENT IN 2ND FLOOR	NEED TO CHANGE TONER	Madhubalan. S.	88A toner changed		Vijayalakshmi.N - Clinical Department	14/09/2022
	Comp. Dt. : 15/09/2022							
	Status : Completed							
884	22090592	CLINICAL DEPARTMENT IN 3RD FLOOR	SCANNER NOT WORKING	Shafiullah. R.	SCANNER WORKING		Selvi. A. - Clinical Department	15/09/2022
	Comp. Dt. : 16/09/2022							
	Status : Completed							


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
885	22090655	CLINICAL DEPARTMENT IN 3RD FLOOR	PRINTER NOT WORKING	Selvam. D.	toner refixed		Parasuraman. R. - Medical Records	17/09/2022
	Comp. Dt. : 19/09/2022							
	Status : Completed							
886	22090720	CLINICAL DEPARTMENT IN 3RD FLOOR	PRINTER NOT WORKING	Jayaraj. J.	12A TONER CHANGED		Parasuraman. R. - Medical Records	19/09/2022
	Comp. Dt. : 26/09/2022							
	Status : Completed							
887	22091002	CLINICAL DEPARTMENT IN 2ND FLOOR	NEED TO CHANGE TONER	Madhubalan. S.	88A TONER CHANGED		Shuruthi. B. - Clinical Department	26/09/2022
	Comp. Dt. : 27/09/2022							
	Status : Completed							
888	22091053	PSYCHIATRY OPD	SYSTEM NOT WORKING	Valamburi. R.	POWER CABLE REFIXED		Parasuraman. R. - Medical Records	27/09/2022
	Comp. Dt. : 29/09/2022							
	Status : Completed							
889	22091167	CLINICAL DEPARTMENT IN 2ND FLOOR	NEED TO CHANGE TONER	Shafiullah. R.	88A TONER CHANGED		Kheerthikaa. V. - Clinical Department	29/09/2022
	Comp. Dt. : 07/10/2022							
	Status : Completed							
890	22100131	CLINICAL DEPARTMENT IN 4th FLOOR	PROBLEM IN U P S	Selvam. D.	Reset the power setting		Suguna. D. - Clinical Department	11/10/2022
	Comp. Dt. : 13/10/2022							
	Status : Completed							
891	22100374	CLINICAL DEPARTMENT IN 3RD FLOOR	SYSTEM NOT WORKING	Madhubalan. S.	system hard disk refixed working fine		Parasuraman. R. - Medical Records	13/10/2022
	Comp. Dt. : 19/10/2022							
	Status : Completed							
892	22100645	Clinical Department	NEED TO CHANGE PRINTER TONER	Shafiullah. R.	12A TONER CHANGED		Bhuvana.M. - Clinical Department	19/10/2022
	Comp. Dt. : 28/10/2022							
	Status : Completed							
893	22100927	CLINICAL DEPARTMENT IN 2ND FLOOR	IN ROOM NO.6 NEPHRO DOCTOR ROOM-SYSTEM UPS BACKUP POWER PROBLEM	Balachandar. A.	Lithium ups battery changed		Selvi. A. - Clinical Department	31/10/2022
894	22100928	CLINICAL DEPARTMENT IN 2ND FLOOR	CHANGE PRINTER TONER	Selvam. D.	PRINTER TONER CHANGED		Suguna. D. - Clinical Department	29/10/2022
	Comp. Dt. : 02/11/2022							


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
895	22110025	CLINICAL DEPARTMENT IN 3RD FLOOR	BIOMETRIC MACHINE NOT CONNECTING	Balachandar. A.	RJ45 jack fixed		Selvi. A. - Clinical Department	03/11/2022
896	22110034	CLINICAL DEPARTMENT IN 4th FLOOR	PRINTER NOT WORKING	Selvam. D.	88A toner changed		Suguna. D. - Clinical Department	07/11/2022
Comp. Dt. : 05/11/2022								
Status : Completed								
897	22110186	CLINICAL DEPARTMENT IN 3RD FLOOR	SYSTEM LOOSE CONNECTION-OFTENLY GETTING POWER OFF	Balachandar. A.	system and monitor power cable refixed..		Sangeetha. C. - Clinical Department	05/11/2022
Comp. Dt. : 15/11/2022								
Status : Completed								
898	22110573	CLINICAL DEPARTMENT IN 4th FLOOR	PRINTER NOT WORKING	Jayaraj. J.	Paper jam cleared		Suguna. D. - Clinical Department	16/11/2022
Comp. Dt. : 18/11/2022								
Status : Completed								
899	22110785	CLINICAL DEPARTMENT IN 2ND FLOOR	NEED TO CHANGE TONER	Shafiullah. R.	88A TONER CHANGED		Shuruthi. B. - Clinical Department	18/11/2022
Comp. Dt. : 21/11/2022								
Status : Completed								
900	22110886	CLINICAL DEPARTMENT IN 4th FLOOR	SYSTEM NOT WORKING	Balachandar. A.	system restarted		Parasuraman. R. - Medical Records	21/11/2022
901	22110895	CLINICAL DEPARTMENT IN 3RD FLOOR	SYSTEM KEYBOARD NOT WORKING	Balachandar. A.	new usb keybaord changed		Parasuraman. R. - Medical Records	22/11/2022
Comp. Dt. : 22/11/2022								
Status : Completed								
902	22110935	Surgery OPD	BIOMETRIC NOT WORKING NEAR SURGERY DEMO ROOM	Shafiullah. R.	BIOMETRIC WORKING		Kheerthikaa. V. - Clinical Department	23/11/2022
Comp. Dt. : 23/11/2022								
Status : Completed								
903	22111014	CLINICAL DEPARTMENT IN 3RD FLOOR	SCANNER NOT WORKING	Madhubalan. S.	SCANER USB CABLE REFIXED WORKING FINE		Selvi. A. - Clinical Department	25/11/2022
Comp. Dt. : 26/11/2022								
Status : Completed								
904	22111133	CLINICAL DEPARTMENT IN 3RD FLOOR	CHANGE PRINTER TONER	Madhubalan. S.	88A TONER CHANGED		Manimegalai. M. - Clinical Department	26/11/2022
Comp. Dt. : 28/11/2022								
Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
905	22111176	CLINICAL DEPARTMENT IN 2ND FLOOR	UPS POWER BACKUP PROBLEM	Selvam. D.	Lithuum ups changed		Vijayalakshmi.N - Clinical Department	28/11/2022
906	22111186	CLINICAL DEPARTMENT IN 4th FLOOR	CHANGE PRINTER TONER	Selvam. D.	12A toner changed		Bhuvana.M. - Clinical Department	28/11/2022
Comp. Dt. : 30/11/2022								
Status : Completed								
907	22111275	OG-OPD	NEED TO CHECK BIOMETRIC MACHINE - NOT WORKING AT DEMO ROOM	Shafiullah. R.	checked working fine..		Vimal. P. - Clinical Department	30/11/2022
Comp. Dt. : 02/12/2022								
Status : Completed								
908	22120093	CLINICAL DEPARTMENT IN 4th FLOOR	PRINTER NOT WORKING	Selvam. D.	printer working fine		Bhuvana.M. - Clinical Department	02/12/2022
Comp. Dt. : 06/12/2022								
Status : Completed								
909	22120256	CLINICAL DEPARTMENT IN 2ND FLOOR	CHANGE PRINTER TONER	Balachandar. A.	PRINTER TONER CHANGED		Kheerthikaa. V. - Clinical Department	06/12/2022
910	22120263	CLINICAL DEPARTMENT IN 2ND FLOOR	DEAN ACADEMIC ROOM-PRINTER PAPER JAM	Prakash. P.	SOLINOD SWITCH ADDED		Vijayalakshmi.N - Clinical Department	07/12/2022
Comp. Dt. : 13/12/2022								
Status : Completed								
911	22120572	OG-OPD	BIOMETRIC NOT WORKING - OG OPD DEMO ROOM	Balachandar. A.	BIOMETRIC MACHINE RESTART		Vimal. P. - Clinical Department	13/12/2022
Comp. Dt. : 14/12/2022								
Status : Completed								
912	22120661	OG-OPD	PROBLEM FOR BIO METRIC DOWNLOAD	Shafiullah. R.	BIO METRIC DOWNLOADING		Vimal. P. - Clinical Department	15/12/2022
913	22120666	CLINICAL DEPARTMENT IN 3RD FLOOR	PRINTER NOT WORKING	Prakash. P.	PRINTER WORKING		Manimegalai. M. - Clinical Department	15/12/2022
914	22120669	CLINICAL DEPARTMENT IN 2ND FLOOR	PRINTER NOT WORKING	Shafiullah. R.	printer working		Kheerthikaa. V. - Clinical Department	14/12/2022
Comp. Dt. : 15/12/2022								
Status : Completed								
915	22120690	CLINICAL DEPARTMENT IN 4th FLOOR	NEED TO CHANGE TONER	Prakash. P.	88A TONER CHANGED		Suguna. D. - Clinical Department	15/12/2022
Comp. Dt. : 19/12/2022								
Status : Completed								
916	22120873	CLINICAL DEPARTMENT IN 2ND FLOOR	MOUSE NOT WORKING	Balachandar. A.	system restarted		Luruthi. B. - Clinical Department	20/12/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 22/12/2022								
Status : Completed								
917	22121026	PSYCHIATRY OPD	CPU NOT WORKING	Jayaraj. J.	CPU FAN CHANGED PROBLEM SLOVED		Priya. S. - Clinical Department	24/12/2022
Comp. Dt. : 27/12/2022								
Status : Completed								
918	22121230	CLINICAL DEPARTMENT IN 2ND FLOOR	SYSTEM MONITOR CABLE LOOSE CONNECTION PROBLEM	Balachandar. A.	power cable refixed..		Kheerthikaa. V. - Clinical Department	28/12/2022
Comp. Dt. : 30/12/2022								
Status : Completed								
919	22121380	CLINICAL DEPARTMENT IN 3RD FLOOR	PRINTER NOT WORKING	Shafiullah. R.	PENIDNG JOB CLEARED..		Selvi. A. - Clinical Department	02/01/2023
Comp. Dt. : 03/01/2023								
Status : Completed								
920	23010098	CLINICAL DEPARTMENT IN 3RD FLOOR	CHANGE PRINTER TONER	Jayaraj. J.	12A TONER CHANGED		Parasuraman. R. - Medical Records	03/01/2023
921	23010108	SEMINAR ROOM IN 3RD FLOOR-HOSPITAL	PROJECTOR NOT WORKING	Shafiullah. R.	VGA CABLE REFIX		Sangeetha. C. - Clinical Department	03/01/2023
Comp. Dt. : 05/01/2023								
Status : Completed								
922	23010214	CLINICAL DEPARTMENT IN 4th FLOOR	SYSTEM UPS NOT WORKING	Jayaraj. J.	New ups changed		Vimal. P. - Clinical Department	21/01/2023
923	23010238	CLINICAL DEPARTMENT IN 3RD FLOOR	CHANGE PRINTER TONER	Selvam. D.	88a Toner changed		Selvi. A. - Clinical Department	05/01/2023
Comp. Dt. : 06/01/2023								
Status : Completed								
924	23010257	CLINICAL DEPARTMENT IN 4th FLOOR	(2610) NEED TO PRINTER TONER	Shafiullah. R.	88A TONER CHANGED		Suguna. D. - Clinical Department	06/01/2023
Comp. Dt. : 07/01/2023								
Status : Completed								
925	23010298	CLINICAL DEPARTMENT IN 4th FLOOR	NEED TO CHANGE PRINTER TONER	Selvam. D.	88A TONER CHANGED		Vimal. P. - Clinical Department	07/01/2023
Comp. Dt. : 09/01/2023								
Status : Completed								
926	23010337	CLINICAL DEPARTMENT IN 2ND FLOOR	CHANGE PRINTER TONER	Balachandar. A.	PRINTER TONER CHANGED		Kheerthikaa. V. - Clinical Department	09/01/2023
Comp. Dt. : 10/01/2023								
Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
927	23010379	CLINICAL DEPARTMENT IN 2ND FLOOR	CHANGE PRINTER TONER	Balachandar. A.	PRINTER TONER CHANGED		Kheerthikaa. V. - Clinical Department	10/01/2023
928	23010405	CLINICAL DEPARTMENT IN 4th FLOOR	CHANGE PRINTER TONER	Selvam. D.	PRINTER TONER CHANGED		Bhuvana.M. - Clinical Department	10/01/2023
929	23010413	CLINICAL DEPARTMENT IN 4th FLOOR	SYSTEM MONITOR NOT WORKING	Selvam. D.	19" inch monitor changed		Suguna. D. - Clinical Department	11/01/2023
Comp. Dt. : 13/01/2023								
Status : Completed								
930	23010572	CLINICAL DEPARTMENT IN 2ND FLOOR	PROBLEM IN PROJECTOR - DEAN ACA SEMINAR HALL	Shafiullah. R.	working projector		Vijayalakshmi.N - Clinical Department	21/01/2023
Comp. Dt. : 14/01/2023								
Status : Completed								
931	23010588	CLINICAL DEPARTMENT IN 2ND FLOOR	PROBLEM IN C P U	Selvam. D.	RAM REFIXED		Kheerthikaa. V. - Clinical Department	14/01/2023
Comp. Dt. : 19/01/2023								
Status : Completed								
932	23010657	CLINICAL DEPARTMENT IN 3RD FLOOR	BACKUP PROBLEM IN UPS	Balachandar. A.	ONLINE UPS CALL FORWARDED TO ELECTRICAL DEPT		Selvi. A. - Clinical Department	01/02/2023
Comp. Dt. : 20/01/2023								
Status : Completed								
933	23010701	CLINICAL DEPARTMENT IN 4th FLOOR	UPS NOT WORKING	Selvam. D.	lithum battery one cell changed		Suguna. D. - Clinical Department	27/01/2023
934	23010739	CLINICAL DEPARTMENT IN 3RD FLOOR	NEED TO CHANGE TONER	Selvam. D.	88A toner changed		Selvi. A. - Clinical Department	21/01/2023
Comp. Dt. : 25/01/2023								
Status : Completed								
935	23010930	CLINICAL DEPARTMENT IN 3RD FLOOR	PRINTER - SHAREING PEOBLEM	Selvam. D.	shared the printer		Kanchana. A. - Super Speciality OPD	27/01/2023
Comp. Dt. : 02/02/2023								
Status : Completed								
936	23020056	CLINICAL DEPARTMENT IN 4th FLOOR	PROBLEM IN C P U	Balachandar. A.	antivirus installed and scanned		Vimal. P. - Clinical Department	02/02/2023
Comp. Dt. : 03/02/2023								
Status : Completed								
937	23020083	CLINICAL DEPARTMENT IN 4th FLOOR	SYSTEM NOT WORKING	Madhubalan. S.	SYSTEM RESTATED WORKING FINE		Bhuvana.M. - Clinical Department	03/02/2023
Comp. Dt. : 06/02/2023								
Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
938	23020200	CLINICAL DEPARTMENT IN 2ND FLOOR	PRINTER NOT WORKING	Selvam. D.	catridge problem informed to consen departmen		Bhuvana.M. - Clinical Department	07/02/2023
Comp. Dt. : 14/02/2023 Status : Completed								
939	23020544	CLINICAL DEPARTMENT IN 2ND FLOOR	NEED TO CHANGE TONER	Madhubalan. S.	TONER CHANGED		Kheerthikaa. V. - Clinical Department	15/02/2023
Comp. Dt. : 18/02/2023 Status : Completed								
940	23020730	CLINICAL DEPARTMENT IN 3RD FLOOR	SYSTEM NOT WORKING	Balachandar. A.	hdd cable refixed		Priya. S. - Clinical Department	18/02/2023
Comp. Dt. : 21/02/2023 Status : Completed								
941	23020826	CLINICAL DEPARTMENT IN 3RD FLOOR	PRINTER NOT WORKING	Harikrishnan. R.	POWER CABLE REFIXED WORKING FINE		Sangeetha. C. - Clinical Department	21/02/2023
Comp. Dt. : 22/02/2023 Status : Completed								
942	23020839	CLINICAL DEPARTMENT IN 4th FLOOR	(2610) SYSTEM NOT WORKING	Selvam. D.	SYSTEM WORKING FINE		Suguna. D. - Clinical Department	22/02/2023
Comp. Dt. : 23/02/2023 Status : Completed								
943	23020890	CLINICAL DEPARTMENT IN 3RD FLOOR	NEED TO REPLACE SYSTEM , FROM ROOM NO 2 TO 7	Selvam. D.,Jayaraj. J.,Venkatesh. S.	system changed		Kanchana. A. - Super Speciality OPD	24/02/2023
944	23020899	CLINICAL DEPARTMENT IN 4th FLOOR	NEED TO REPLACE SYSTEM FROM IV FLOOR TO III FLOOR	Selvam. D.,Valamburi. R.,Venkatesh. S.	System interchanged		Bhuvana.M. - Clinical Department	24/02/2023
Comp. Dt. : 25/02/2023 Status : Completed								
945	23020972	CLINICAL DEPARTMENT IN 4th FLOOR	NEED UPS	Balachandar. A.	Lithium ups changed		Suguna. D. - Clinical Department	22/03/2023
946	23020983	PSYCHIATRY OPD	MOUSE NOT WORKING	Selvam. D.	usb cable refixed		Priya. S. - Clinical Department	27/02/2023
Comp. Dt. : 27/02/2023 Status : Completed								
947	23021013	CLINICAL DEPARTMENT IN 3RD FLOOR	NEED TO CHANGE TONER	Shafiullah. R.	88A toner chaned		Selvi. A. - Clinical Department	27/02/2023
Comp. Dt. : 28/02/2023 Status : Completed								
948	23021082	CLINICAL DEPARTMENT IN 2ND FLOOR	NEED TO CHANGE PRINTER TONER	Balachandar. A.	PRINTER TONER,CHANGED		Shuruthi. B. - Clinical Department	28/02/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 04/03/2023								
Status : Completed								
949	23030162	CLINICAL DEPARTMENT IN 2ND FLOOR	C P U NOT WORKING	Valamburi. R.	power cable refixed		Shuruthi. B. - Clinical Department	08/03/2023
Comp. Dt. : 08/03/2023								
Status : Completed								
950	23030308	CLINICAL DEPARTMENT IN 4th FLOOR	PRINTER NOT WORKING	Selvam. D.	usb cable refixed		Suguna. D. - Clinical Department	08/03/2023
Comp. Dt. : 09/03/2023								
Status : Completed								
951	23030364	CLINICAL DEPARTMENT IN 2ND FLOOR	SYSTEM NOT WORKING ROOM NO 6 [LEFT SIDE]	Selvam. D.	NETWORK WORKING		Selvi. A. - Clinical Department	16/03/2023
Comp. Dt. : 10/03/2023								
Status : Completed								
952	23030417	CLINICAL DEPARTMENT IN 3RD FLOOR	NEED TO CHANGE TONER	Selvam. D.	12A toner changed		Bhuvana.M. - Clinical Department	10/03/2023
Comp. Dt. : 11/03/2023								
Status : Completed								
953	23030458	CLINICAL DEPARTMENT IN 3RD FLOOR	SYSTEM NOT WORKING	Shafiullah. R.	power cable refixed..		Sasireka. A. - Clinical Department	13/03/2023
Comp. Dt. : 13/03/2023								
Status : Completed								
954	23030479	CLINICAL DEPARTMENT IN 3RD FLOOR	NEED TO CHANGE TONER	Shafiullah. R.	88A TONER CHANGED		Sangeetha. C. - Clinical Department	13/03/2023
Comp. Dt. : 16/03/2023								
Status : Completed								
955	23030632	CLINICAL DEPARTMENT IN 3RD FLOOR	NEED TO CHANGE TONER	Balachandar. A.	TONER CHANGED		Bhuvana.M. - Clinical Department	16/03/2023
Comp. Dt. : 20/03/2023								
Status : Completed								
956	23030813	PSYCHIATRY OPD	MOUSE NOT WORKING	Madhubalan. S.	SYSTEM RESTATED MOUSE WORKING FINE		Priya. S. - Clinical Department	21/03/2023
957	23030826	Paediatrics - OPD	PROBLEM IN PROJECTOR & U P S AT DEMO ROOM	Shafiullah. R.	projector and ups working		Manimegalai. M. - Clinical Department	20/03/2023
Comp. Dt. : 21/03/2023								
Status : Completed								
958	23030841	CLINICAL DEPARTMENT IN 2ND FLOOR	DISPLAY PROBLEM IN SYSTEM -	Shafiullah. R.	System working fine		Shuruthi. B. - Clinical Department	22/03/2023
Comp. Dt. : 22/03/2023								

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL,
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
959	23030922	CLINICAL DEPARTMENT IN 3RD FLOOR	NEED TO CHANGE PRINTER TONER	Shafiullah. R.	88A Toner changed		Manimegalai. M. - Clinical Department	22/03/2023
Comp. Dt. : 31/03/2023								
Status : Completed								
960	23031340	CLINICAL DEPARTMENT IN 3RD FLOOR	NEED SYSTEM CONNECTION WORK	Madhubalan. S.	SYSTEM CONNECTED		Sangeetha. C. - Clinical Department	31/03/2023
Comp. Dt. : 01/04/2023								
Status : Completed								
961	23040022	CLINICAL DEPARTMENT IN 2ND FLOOR	MONITOR NOT WORKING - [DEAN ACA. SIR SYSTEM]	Balachandar. A.	NETWORK CABLE REFIXED		Shuruthi. B. - Clinical Department	01/04/2023
Comp. Dt. : 03/04/2023								
Status : Completed								
962	23040065	TB & Chest OPD	FAX SYSTEM NOT WORKING	Balachandar. A.	user password forgetted,not mail to edp		Bhuvana.M. - Clinical Department	04/04/2023
Comp. Dt. : 06/04/2023								
Status : Completed								
963	23040201	CLINICAL DEPARTMENT IN 3RD FLOOR	NEED TO CHANGE TONER	Selvam. D.	toner refixed		Bhuvana.M. - Clinical Department	08/04/2023
Comp. Dt. : 10/04/2023								
Status : Completed								
964	23040270	CLINICAL DEPARTMENT IN 3RD FLOOR	PRINTER NOT WORKING	Shafiullah. R.	REFIX THE USB CABLE		Priya. S. - Clinical Department	10/04/2023
Comp. Dt. : 11/04/2023								
Status : Completed								
965	23040340	CLINICAL DEPARTMENT IN 2ND FLOOR	NEED TO CHANGE TONER	Venkatesh. S.	88A TONER CHANGED		Shuruthi. B. - Clinical Department	11/04/2023
Comp. Dt. : 20/04/2023								
Status : Completed								
966	23040652	CLINICAL DEPARTMENT IN 4th FLOOR	NEED TO CHANGE TONER	Shafiullah. R.	88A TONER CHANGED		Vimal. P. - Clinical Department	20/04/2023
967	23040670	CLINICAL DEPARTMENT IN 3RD FLOOR	C P U NOT WORKING AT SEMINOR ROOM [RIGHT SIDE]	Jayaraj. J.	power cable refixed		Priya. S. - Clinical Department	22/04/2023
Comp. Dt. : 24/04/2023								
Status : Completed								
968	23040754	CLINICAL DEPARTMENT IN 2ND FLOOR	MOUSE NOT WORKING [HOD SYSTEM - ROOM NO 7]	Shafiullah. R.	REFIX THE MOUSE WORKING		Bhuvana.M. - Clinical Department	24/04/2023

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 25/04/2023								
Status : Completed								
969	23040809	CLINICAL DEPARTMENT IN 3RD FLOOR	NEED TO CHANGE TONER	Shafiullah. R.	88A TONER CHANGED		Manimegalai. M. - Clinical Department	25/04/2023
Comp. Dt. : 27/04/2023								
Status : Completed								
970	23040910	CLINICAL DEPARTMENT IN 3RD FLOOR	"SHARE " NOT WORKING	Prakash. P.	network cable refixed		Manimegalai. M. - Clinical Department	27/04/2023
Comp. Dt. : 02/05/2023								
Status : Completed								
971	23050063	CLINICAL DEPARTMENT IN 4th FLOOR	NEED TO CHANGE TONER	Harikrishnan. R.	88A Toner Changed.		Suguna. D. - Clinical Department	02/05/2023
Comp. Dt. : 03/05/2023								
Status : Completed								
972	23050110	CLINICAL DEPARTMENT IN 3RD FLOOR	NEED TO CHANGE TONER	Balachandar. A.	88A TONER CHANGED		Selvi. A. - Clinical Department	03/05/2023
Comp. Dt. : 05/05/2023								
Status : Completed								
973	23050213	Male Psychiatry - Ward 405	MOUSE NOT WORKING	Selvam. D.	SYSTEM AND MOUSE WORKING		Priya. S. - Clinical Department	06/05/2023
Comp. Dt. : 08/05/2023								
Status : Completed								
974	23050265	CLINICAL DEPARTMENT IN 3RD FLOOR	PRINTER & SHARE NOT WORKING	Balachandar. A.	WORKING FINE		Sangeetha. C. - Clinical Department	15/05/2023
Comp. Dt. : 15/05/2023								
Status : Completed								
975	23050598	CLINICAL DEPARTMENT IN 2ND FLOOR	SYSTEM NOT WORKING ROOM NO 7	Jayaraj. J.	UPS BATTERY CHANGED		Bhuvana.M. - Clinical Department	24/05/2023
976	23050606	CLINICAL DEPARTMENT IN 2ND FLOOR	NEED TO CHANGE TONER	Jayaraj. J.	88A TONER CHANGED		Shuruthi. B. - Clinical Department	15/05/2023
Comp. Dt. : 23/05/2023								
Status : Completed								
977	23050932	CLINICAL DEPARTMENT IN 2ND FLOOR	SYSTEM NOT WORKING - ROOM NO 7	Shafiullah. R.	multiple complain		Bhuvana.M. - Clinical Department	24/05/2023
Comp. Dt. : 24/05/2023								
Status : Completed								
978	23050968	CLINICAL DEPARTMENT IN 2ND FLOOR	SYSTEM NOT WORKING ROOM NO 4	Jayaraj. J.,Selvam. D.,Shafiullah. R.	CPU FAN CHANGED		Saranya. S. - Clinical Department	25/05/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
979	23050974	CLINICAL DEPARTMENT IN 3RD FLOOR	BIO METRIC DATA CABLE NOT WORKING	Selvam. D.	NEW PATCH CARD CABEL CHANGED		Sangeetha. C. - Clinical Department	25/05/2023
Comp. Dt. : 25/05/2023 Status : Completed								
980	23051016	CLINICAL DEPARTMENT IN 3RD FLOOR	NEED TO CHANGE TONER	Shafiullah. R.	88A TONER CHANGED		Sangeetha. C. - Clinical Department	25/05/2023
Comp. Dt. : 27/05/2023 Status : Completed								
981	23051093	CLINICAL DEPARTMENT IN 3RD FLOOR	NEED TO CHANGE TONER	Shafiullah. R.	88 TONER CHANGED		Selvi. A. - Clinical Department	27/05/2023
Comp. Dt. : 30/05/2023 Status : Completed								
982	23051198	CLINICAL DEPARTMENT IN 4th FLOOR	NEED TO CHANGE TONER	Selvam. D.	88a toner changed		Suguna. D. - Clinical Department	30/05/2023
983	23051199	CLINICAL DEPARTMENT IN 4th FLOOR	NEED TO CHANGE TONER [ENT DEPT]	Selvam. D.	88A TONER CHANGED		Sasireka. A. - Clinical Department	30/05/2023
984	23051210	CLINICAL DEPARTMENT IN 3RD FLOOR	NEED TO CHANGE TONER	Harikrishnan. R.	12A Toner Changed.		Priya. S. - Clinical Department	31/05/2023
Comp. Dt. : 31/05/2023 Status : Completed								
985	23051215	CLINICAL DEPARTMENT IN 2ND FLOOR	NEED TO CHANGE TONER	Madhubalan. S.	88A toner changed		Saranya. S. - Clinical Department	31/05/2023
986	23051259	CLINICAL DEPARTMENT IN 2ND FLOOR	NEED TO REFIL PRINTER INK	Shafiullah. R.	ink refilled		Vijayalakshmi.N - Clinical Department	31/05/2023
Comp. Dt. : 01/06/2023 Status : Completed								
987	23060030	CLINICAL DEPARTMENT IN 3RD FLOOR	NEED TO CHANGE TONER FOR [MEDICINE]	Madhubalan. S.	88A TONER CHANGED		Sangeetha. C. - Clinical Department	01/06/2023
Comp. Dt. : 16/06/2023 Status : Completed								
988	23060571	CLINICAL DEPARTMENT IN 4th FLOOR	SYSTEM NOT WORKING	Balachandar. A.	settings changed		Suguna. D. - Clinical Department	16/06/2023
989	23060608	CLINICAL DEPARTMENT IN 2ND FLOOR	PRINTER NOT WORKING	Jayaraj. J.	88a toner changed		Saranya. S. - Clinical Department	16/06/2023
Comp. Dt. : 22/06/2023 Status : Completed								
990	23060831	CLINICAL DEPARTMENT IN 3RD FLOOR	NEED TO CHANGE TONER [MEDICINE]	Harikrishnan. R.	Toner Changed.		Sangeetha. C. - Clinical Department	22/06/2023
Comp. Dt. : 27/06/2023 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
991	23061018	CLINICAL DEPARTMENT IN 2ND FLOOR	NEED TO CHANGE TONER	Selvam. D.	88a toner changed		Shuruthi. B. - Clinical Department	05/07/2023
Dept Name : CLINICAL PATHOLOGY - Computer Department Comp. Dt. : 05/05/2022 Status : Completed								
992	22050154	Clinical Pathology	PRINTER NOT WORKING	Prakash. P.	Paper jam cleared		Vinod Gnana Kumar. D. - CLINICAL PATHOLOGY	05/05/2022
Comp. Dt. : 18/05/2022 Status : Completed								
993	22050645	Clinical Pathology	KEY BOARD NOT WORKING	Selvam. D.	antivirus uninstalled		Vinod Gnana Kumar. D. - CLINICAL PATHOLOGY	18/05/2022
994	22050662	Clinical Pathology	NEED TO CHANGE BARCODE STRICKER	Selvam. D.	BARCODE STRICKER CHANGED		Sivasakthi. D. - CLINICAL PATHOLOGY	18/05/2022
Comp. Dt. : 23/05/2022 Status : Completed								
995	22050810	Clinical Pathology	BARCODE PRINTER NOT WORKING	Prakash. P.	BARCODE PRINTER Paper Jam , Clear		Vinod Gnana Kumar. D. - CLINICAL PATHOLOGY	23/05/2022
Comp. Dt. : 26/05/2022 Status : Completed								
996	22050993	Clinical Pathology	NEED TO CHECK BARCODE PRINTER - STRICKER JAM	Shafiullah. R.	STRICKER JAM CLEARD		Prabavathi. T. - CLINICAL PATHOLOGY	26/05/2022
Comp. Dt. : 02/06/2022 Status : Completed								
997	22060046	Clinical Pathology	NEED TO CHANGE TONER	Balachandar. A.	TONER CHANGED		Vinothini. R. - CLINICAL PATHOLOGY	02/06/2022
Comp. Dt. : 10/06/2022 Status : Completed								
998	22060365	Clinical Pathology	CHANGE BARCODE STICKER	Madhubalan. S.	REVISITE STICKER CHANGED		Valli. G. - CLINICAL PATHOLOGY	10/06/2022
Comp. Dt. : 13/06/2022 Status : Completed								
999	22060474	Clinical Pathology	NEED TO CHECK KEYBOARD - NOT WORKING	Madhubalan. S.	KEYBOARD WORKING FINE		Vinod Gnana Kumar. D. - CLINICAL PATHOLOGY	13/06/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 14/06/2022								
Status : Completed								
1000	22060528	Clinical Pathology	NEED TO CHANGE TONER	Madhubalan. S.	12A TONER CHANGED		Gowri. S. - CLINICAL PATHOLOGY	14/06/2022
Comp. Dt. : 04/07/2022								
Status : Completed								
1001	22070100	Clinical Pathology	NEED TO CHANGE BARCODE STRICKER	Selvam. D.	Revist Sticker Changed		Velvizhi. R. - CLINICAL PATHOLOGY	04/07/2022
Comp. Dt. : 07/07/2022								
Status : Completed								
1002	22070276	Clinical Pathology	SYSTEM NOT WORKING	Selvam. D.	system working fine		Velvizhi. R. - CLINICAL PATHOLOGY	07/07/2022
Comp. Dt. : 09/07/2022								
Status : Completed								
1003	22070355	Clinical Pathology	SYSTEM NOT WORKING	Selvam. D.	patch cable refixed		Valli. G. - CLINICAL PATHOLOGY	09/07/2022
Comp. Dt. : 11/07/2022								
Status : Completed								
1004	22070401	Clinical Pathology	NEED TO CHANGE BARCODE STRICKER	Madhubalan. S.	new barcode sticker chagned		Valli. G. - CLINICAL PATHOLOGY	13/07/2022
Comp. Dt. : 27/07/2022								
Status : Completed								
1005	22071006	Clinical Pathology	NEED TO CHANGE BARCODE STRICKER	Balachandar. A.	BARCODE STRICKER CHANGED		Gowri. S. - CLINICAL PATHOLOGY	27/07/2022
1006	22071038	Clinical Pathology	NEED TO CHANGE PRINTER RIBBON FOR BARCODE PRINTER	Balachandar. A.	PRINTER RIBBON CHANGED		Valli. G. - CLINICAL PATHOLOGY	27/07/2022
Comp. Dt. : 08/08/2022								
Status : Completed								
1007	22080253	Clinical Pathology	PRINTER NOT WORKING	Jayaraj. J.	SYSTEM RESTARTED		Vinod Gnana Kumar. D. - CLINICAL PATHOLOGY	08/08/2022
Comp. Dt. : 19/08/2022								
Status : Completed								
1008	22080640	Pathology Lab	CHANGE PRINTER TONER	Selvam. D.	12A toner changed		Thatchayini. S. - CLINICAL PATHOLOGY	19/08/2022
Comp. Dt. : 22/08/2022								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
1009	22080686	Clinical Pathology	NEED TO CHANGE BARCODE STRICKER	Selvam. D.	revisit sticker changed		Valli. G. - CLINICAL PATHOLOGY	22/08/2022
Comp. Dt. : 01/09/2022								
Status : Completed								
1010	22090002	Clinical Pathology	PROBLEM IN MEDPLUS - NOT OPENED	Balachandar. A.	network cable refixed		Arulvizhi. K. - CLINICAL PATHOLOGY	01/09/2022
Comp. Dt. : 07/09/2022								
Status : Completed								
1011	22090274	Clinical Pathology	NEED TO CHANGE TONER	Madhubalan. S.	88A TONER CHANGED		Vinod Gnana Kumar. D. - CLINICAL PATHOLOGY	07/09/2022
Comp. Dt. : 06/10/2022								
Status : Completed								
1012	22100119	Clinical Pathology	NEED TO CHANGE TONER	Prakash. P.	TONER CHANGED		Vinothini. R. - CLINICAL PATHOLOGY	06/10/2022
Comp. Dt. : 13/10/2022								
Status : Completed								
1013	22100428	Clinical Pathology	NEED TO CHANGE BARCODE STRICKER	Shafiullah. R.	REVISITE STRICKER BARCODE CHANGED		Malathi. M. - CLINICAL PATHOLOGY	13/10/2022
Comp. Dt. : 14/11/2022								
Status : Completed								
1014	22110490	Clinical Pathology	NEED TO CHANGE BARCODE STICKER	Shafiullah. R.	REVISIT STICKER CHANGED		Arulvizhi. K. - CLINICAL PATHOLOGY	14/11/2022
Comp. Dt. : 22/11/2022								
Status : Completed								
1015	22110896	Clinical Pathology	NEED TO CHANGE TONER	Madhubalan. S.	12A TONER CHANGED		Vinothini. R. - CLINICAL PATHOLOGY	22/11/2022
Comp. Dt. : 07/12/2022								
Status : Completed								
1016	22120280	Pathology Lab	CHANGE PRINTER TONER	Madhubalan. S.	12A TONER CHANGED		Vinod Gnana Kumar. D. - CLINICAL PATHOLOGY	07/12/2022
Comp. Dt. : 12/12/2022								
Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1017	22120504	Clinical Pathology	NEED TO CHANGE BARCODE STICKER	Shafiullah. R.	REVISIT STICKER CHANGED		Vinod Gnana Kumar. D. - CLINICAL PATHOLOGY	12/12/2022
Comp. Dt. : 24/12/2022 Status : Completed								
1018	22121114	Pathology Lab	SYSTEM OFTENLY GETTING HANGING PROBLEM	Jayaraj. J.	WORKING FINE		Vinod Gnana Kumar. D. - CLINICAL PATHOLOGY	24/12/2022
Comp. Dt. : 29/12/2022 Status : Completed								
1019	22121317	Pathology Lab	CHANGE BARCODE STICKER	Selvam. D.	New barcode sticker changed		Velvizhi. R. - CLINICAL PATHOLOGY	29/12/2022
Comp. Dt. : 02/01/2023 Status : Completed								
1020	23010021	Pathology Lab	2 NO'S SYSTEM NOT WORKING	Shafiullah. R.	8port switch power cable lose		Malathi. M. - CLINICAL PATHOLOGY	02/01/2023
Comp. Dt. : 05/01/2023 Status : Completed								
1021	23010228	Pathology Lab	CHANGE PRINTER RIBBON	Madhubalan. S.	barcode ribbon and sticker changed		Vinothini. R. - CLINICAL PATHOLOGY	05/01/2023
Comp. Dt. : 09/01/2023 Status : Completed								
1022	23010326	Pathology Lab	BARCODE PRINTER PROBLEM	Shafiullah. R.	BARCODE STICKER STICK REMOVED		Valli. G. - CLINICAL PATHOLOGY	09/01/2023
Comp. Dt. : 10/01/2023 Status : Completed								
1023	23010411	Pathology Lab	BARCODE PRINTER NOT WORKING	Jayaraj. J.	BARCODE PRINTER CLEAN AND REFIXED		Malathi. M. - CLINICAL PATHOLOGY	10/01/2023
Comp. Dt. : 21/01/2023 Status : Completed								
1024	23010764	Clinical Pathology	NEED TO CHANGE BARCODE STRICKER	Shafiullah. R.	REFIX THE BARCODE STRICKER		Vinod Gnana Kumar. D. - CLINICAL PATHOLOGY	21/01/2023
Comp. Dt. : 24/01/2023 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1025	23010894	Clinical Pathology	SYSTEM [3NOS] NOT WORKING	Balachandar. A.	SOFTWARE WORKING FINE		Malathi. M. - CLINICAL PATHOLOGY	24/01/2023
Comp. Dt. : 27/01/2023 Status : Completed								
1026	23010947	Clinical Pathology	NEED TO CHANGE TONER	Shafiullah. R.	12A TONER CHANGED		Vinod Gnana Kumar. D. - CLINICAL PATHOLOGY	27/01/2023
Comp. Dt. : 10/02/2023 Status : Completed								
1027	23020367	Clinical Pathology	MEDPLUS NOT WORKING - CLINICAL PATHOLOGY LAB	Shafiullah. R.	NETWORK SWITCH PROMBLE REFIXED		Vinod Gnana Kumar. D. - CLINICAL PATHOLOGY	10/02/2023
Comp. Dt. : 14/02/2023 Status : Completed								
1028	23020513	Clinical Pathology	NEED TO CHANGE BARCODE STRICKER	Shafiullah. R.	REVISITE STICKER CHANGED		Vinod Gnana Kumar. D. - CLINICAL PATHOLOGY	14/02/2023
Comp. Dt. : 17/02/2023 Status : Completed								
1029	23020662	Clinical Pathology	MEDPLUS SOFTWARE PROBLEM	Selvam. D.	Patch cable refixed		Vinod Gnana Kumar. D. - CLINICAL PATHOLOGY	17/02/2023
Comp. Dt. : 08/03/2023 Status : Completed								
1030	23030331	Clinical Pathology	NEED TO CHANGE BARCODE STRICKER	Shafiullah. R.	REVISIT STRICKER CHANGED		Vinod Gnana Kumar. D. - CLINICAL PATHOLOGY	08/03/2023
Comp. Dt. : 20/03/2023 Status : Completed								
1031	23030761	Clinical Pathology	SYSTEM NO WORKING	Valamburi. R.	system working fine		Velvizhi. R. - CLINICAL PATHOLOGY	22/03/2023
1032	23030833	Clinical Pathology	NEED TO CHANGE PRINTER TONER	Shafiullah. R.	12A TONER CHANGED		Valli. G. - CLINICAL PATHOLOGY	20/03/2023
Comp. Dt. : 28/03/2023 Status : Completed								
1033	23031225	Clinical Pathology	NEED TO CHANGE BARCODE PRINTER RIBBON	Valamburi. R.	barcode ribbon changed		Sivasakthi. D. - CLINICAL PATHOLOGY	29/03/2023
Comp. Dt. : 29/03/2023								

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
1034	23031231	Clinical Pathology	NEED TO CHANGE BARCODE STRICKER	Shafiullah. R.	REVISIT STRICKER CHANGED		Gowri. S. - CLINICAL PATHOLOGY	29/03/2023
1035	23031269	Clinical Pathology	KEYBOARD NOT WORKING	Selvam. D.	new ps2 keyboard changed..		Vinod Gnana Kumar. D. - CLINICAL PATHOLOGY	30/03/2023
Comp. Dt. : 03/04/2023								
Status : Completed								
1036	23040034	Clinical Pathology	NEED TO CHANGE TONER	Madhubalan. S.	88A TONER CHANGED		Velvizhi. R. - CLINICAL PATHOLOGY	03/04/2023
Comp. Dt. : 04/04/2023								
Status : Completed								
1037	23040126	Clinical Pathology	NEED TO CHANGE TONER	Shafiullah. R.	12A TONER CHANGED		Vinod Gnana Kumar. D. - CLINICAL PATHOLOGY	04/04/2023
Comp. Dt. : 22/04/2023								
Status : Completed								
1038	23040690	Clinical Pathology	NEED TO REFIX MONITOR	Harikrishnan. R.	MONITER BACE REFIXED		Vinod Gnana Kumar. D. - CLINICAL PATHOLOGY	22/04/2023
Comp. Dt. : 26/04/2023								
Status : Completed								
1039	23040838	Clinical Pathology	SYSTEM NOT WORKING	Jayaraj. J.	SYSTEM MOTHER BOARD CLEAN AND SYSTEM REFIXED		Vinod Gnana Kumar. D. - CLINICAL PATHOLOGY	26/04/2023
Comp. Dt. : 28/04/2023								
Status : Completed								
1040	23040982	Clinical Pathology	MEDPLUS NOT WORKING	Shafiullah. R.	SOFTWARE PROBLEM,SERVER RESTARTED		Vinod Gnana Kumar. D. - CLINICAL PATHOLOGY	29/04/2023
Comp. Dt. : 03/05/2023								
Status : Completed								
1041	23050105	Clinical Pathology	NEED TO CHANGE BARCODE PRINTER RIBBON	Selvam. D.	WAX RIBOON CHANGED		Pramila. B. - CLINICAL PATHOLOGY	03/05/2023
Comp. Dt. : 08/05/2023								
Status : Completed								
1042	23050264	Clinical Pathology	BARCODE PRINTER NOT WORKING	Selvam. D.	Barcode sticker refixed		Vinod Gnana Kumar. D. - CLINICAL PATHOLOGY	08/05/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 26/05/2023 Status : Completed								
1043	23051021	Clinical Pathology	NEED TO CHANGE BARCODE STRICKER	Selvam. D.	revisit sticker changed		Velvizhi. R. - CLINICAL PATHOLOGY	26/05/2023
Comp. Dt. : 05/06/2023 Status : Completed								
1044	23060153	Clinical Pathology	MEDPLUS NOT WORKING	Shafiullah. R.	MEDPLUS WORKING		Vinod Gnana Kumar. D. - CLINICAL PATHOLOGY	05/06/2023
Comp. Dt. : 09/06/2023 Status : Completed								
1045	23060336	Clinical Pathology	SYSTEM NOT WORKING	Jayaraj. J.	WORKING FINE		Malathi. M. - CLINICAL PATHOLOGY	09/06/2023
Comp. Dt. : 12/06/2023 Status : Completed								
1046	23060374	Clinical Pathology	NEED TO CHANGE BARCODE STRICKER	Selvam. D.	Revisit sticker changed		Vinod Gnana Kumar. D. - CLINICAL PATHOLOGY	12/06/2023
Comp. Dt. : 27/06/2023 Status : Completed								
1047	23061024	Clinical Pathology	SYSTEM DISPLAY PROBLEM & NEED TO CHANGE TONER	Shafiullah. R.	MONITOR WORKING FINE AND 12A TONER CHANGED		Vinod Gnana Kumar. D. - CLINICAL PATHOLOGY	27/06/2023
Dept Name : COMMUNITY MEDICINE - Computer Department Comp. Dt. : 05/07/2022 Status : Completed								
1048	22070147	NAC OFFICE 4TH FLOOR	SYSTEM NOT WORKING [MEDICAL COLLEGE COMMUNITY MEDICINE]	Jayaraj. J.	NEW SMPS CHANGED		Rajesh. D. - COMMUNITY MEDICINE	05/07/2022
Comp. Dt. : 05/09/2022 Status : Completed								
1049	22090157	COMMUNITY MEDICINE DEPT IN MEDICAL COLLEGE	NEED TO CHANGE INK	Jayaraj. J.	ink filled		Rajesh. D. - COMMUNITY MEDICINE	05/09/2022
Comp. Dt. : 29/09/2022 Status : Completed								
1050	22091182	COMMUNITY MEDICINE DEPT IN MEDICAL COLLEGE	NEED TO CHANGE TONER	Madhubalan. S.	12A TONER CHANGED		Sunitha. P. - COMMUNITY MEDICINE	30/09/2022

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 10/10/2022 Status : Completed								
1051	22100208	COMMUNITY MEDICINE DEPT IN MEDICAL COLLEGE	INSIDE SYSTEM THE BROKEN PART OF PEN DRIVE, NEED TO REMOVE	Shafiullah. R.	REMOVED AND FIXIED		Murugan.R. - COMMUNITY MEDICINE	10/10/2022
Comp. Dt. : 25/03/2023 Status : Completed								
1052	23031068	PHYSIOLOGY-- -COLLEGE	PRINTER NOT WORKING	Jayaraj. J.	SHARING GIVEN		Raghavendran. V. - COMMUNITY MEDICINE	25/03/2023
Comp. Dt. : 15/05/2023 Status : Completed								
1053	23050563	COMMUNITY MEDICINE DEPT IN MEDICAL COLLEGE	NEED TO CHECK SYSTEM - DISPLAY , MONITOR PROBLEM IN STATISTICS UNIT	Madhubalan. S.	NEW AOC 18 inch MONITER CHANGED		Sunitha. P. - COMMUNITY MEDICINE	01/06/2023
Comp. Dt. : 05/06/2023 Status : Completed								
1054	23060147	COMMUNITY MEDICINE DEPT IN MEDICAL COLLEGE	NEED SOFTWARE INSTALLATION	Jayaraj. J.	SOFTWARE INSTALLED		Rajesh. D. - COMMUNITY MEDICINE	07/06/2023
Dept Name : Computer Department - Computer Department Comp. Dt. : 16/11/2022 Status : Completed								
1055	22110641	Obstetrics - Ward 208	CHANGE PRINTER TONER	Shafiullah. R.	12A TONER CHANGED		Jerina. M. - Medical Records	16/11/2022
Comp. Dt. : 17/05/2023 Status : Completed								
1056	23050690	Boys hostel P.H-III	WIFI NOT WORKING	Prakash. P.	Electrical Extension box fuse changed		Prakash. P. - Computer Department	18/05/2023
Comp. Dt. : 18/05/2023 Status : Completed								
1057	23050729	Medical Records	SYSTEM NOT WORKING [TEST]	Shafiullah. R.	TESTING SMS WORKING FINE		Shafiullah. R. - Computer Department	18/05/2023
Dept Name : COVID Ward - Computer Department Comp. Dt. : 20/06/2022 Status : Completed								
1058	22060708	Female Ortho - Ward 402	NEED TO CHANGE TONER	Selvam. D.	12A toner changed		Girija. G. - Female Ortho Ward	20/06/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 29/06/2022 Status : Completed								
1059	22061064	WARD-406	PRINTER NOT WORKING	Shafiullah. R.	PAPAER JAM CLEARED		Kavitha. S. - Derm,Pulmo,Psych Ward	29/06/2022
Dept Name : Derm,Pulmo,Psych Ward - Computer Department Comp. Dt. : 04/06/2022 Status : Completed								
1060	22060155	Male Ortho - Ward 403	NEED TO CHANGE TONER	Madhubalan. S.	12A TONER CHANGED		Manjula. P. - Male Ortho Ward	04/06/2022
Comp. Dt. : 22/06/2022 Status : Completed								
1061	22060803	TB AND CHEST WARD-405	PRINTER NOT WORKING	Selvam. D.	SENSOR PAPER JAM CLEARED		Sarathkumar. R. - Derm,Pulmo,Psych Ward	22/06/2022
Comp. Dt. : 01/07/2022 Status : Completed								
1062	22070037	PSYCHIATRY WARD	PRINTER NOT WORKING	Selvam. D.	printer serviced		Sarathkumar. R. - Derm,Pulmo,Psych Ward	07/07/2022
Comp. Dt. : 11/08/2022 Status : Completed								
1063	22080408	TB AND CHEST WARD-405	PRINTER NOT WORKING	Valamburi. R.	PRINTER WORKING SETTING CHANGED		Saranya. M. - Derm,Pulmo,Psych Ward	11/08/2022
Comp. Dt. : 07/09/2022 Status : Completed								
1064	22090285	PSYCHIATRY WARD	NEED TO CHANGE TONER	Selvam. D.	TONER CHANGED		Sarathkumar. R. - Derm,Pulmo,Psych Ward	08/09/2022
Comp. Dt. : 23/09/2022 Status : Completed								
1065	22090937	PSYCHIATRY WARD	SYSTEM DISPLAY PROBLEM	Madhubalan. S.	MONITER SETTING CHANGED		Sarathkumar. R. - Derm,Pulmo,Psych Ward	26/09/2022
Comp. Dt. : 26/10/2022 Status : Completed								
1066	22100792	PSYCHIATRY WARD	NEED TO CHANGE PRINTER TONER	Madhubalan. S.	12A TONER CHANGED		Sarathkumar. R. - Derm,Pulmo,Psych Ward	26/10/2022

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 01/12/2022 Status : Completed								
1067	22120018	Male Psychiatry	PRINTER NOT WORKING	Shafiullah. R.	PRINTER WORKING		Sarathkumar. R. - Derm,Pulmo,Psych Ward	01/12/2022
Comp. Dt. : 10/12/2022 Status : Completed								
1068	22120485	PSYCHIATRY WARD	SYSTEM WORKING SLOWLY	Shafiullah. R.	SYSTEM WORKING FINE		Sarathkumar. R. - Derm,Pulmo,Psych Ward	10/12/2022
Comp. Dt. : 29/12/2022 Status : Completed								
1069	22121316	PSYCHIATRY WARD	CHANGE PRINTER TONER	Madhubalan. S.	12A TONER CHANGED		Sarathkumar. R. - Derm,Pulmo,Psych Ward	29/12/2022
Comp. Dt. : 03/02/2023 Status : Completed								
1070	23020087	Male Psychiatry - Ward 405	NEED TO CHANGE TONER	Selvam. D.	12a toner changed		Sarathkumar. R. - Derm,Pulmo,Psych Ward	04/02/2023
Comp. Dt. : 01/03/2023 Status : Completed								
1071	23030007	Male Psychiatry - Ward 405	PROBLEM IN SYSTEM DISPLAY	Shafiullah. R.	RESET THE DISPLAY SETTING		Sarathkumar. R. - Derm,Pulmo,Psych Ward	01/03/2023
Comp. Dt. : 06/03/2023 Status : Completed								
1072	23030219	Male Psychiatry - Ward 405	NEED TO CHANGE TONER	Jayaraj. J.	12A TONER CHANGED		Sarathkumar. R. - Derm,Pulmo,Psych Ward	06/03/2023
Comp. Dt. : 17/03/2023 Status : Completed								
1073	23030708	Male Psychiatry - Ward 405	PRINTER NOT WORKING	Shafiullah. R.	12A TONER CHANGED		Kavitha. S. - Derm,Pulmo,Psych Ward	17/03/2023
Comp. Dt. : 20/03/2023 Status : Completed								
1074	23030832	PSYCHIATRY WARD	PRINTER NOT WORKING	Harikrishnan. R.	printer working fine		Sarathkumar. R. - Derm,Pulmo,Psych	22/03/2023
Comp. Dt. : 30/03/2023								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
1075	23031293	Male Psychiatry - Ward 405	PRINTER NOT WORKING	Selvam. D.	usb cable refixed		Sarathkumar. R. - Derm,Pulmo,Psych Ward	30/03/2023
Comp. Dt. : 25/04/2023								
Status : Completed								
1076	23040818	Male Psychiatry - Ward 405	NEED TO CHANGE TONER	Shafiullah. R.	12A TONER CHANGED		Bharathi. A - Derm,Pulmo,Psych Ward	25/04/2023
Comp. Dt. : 12/05/2023								
Status : Completed								
1077	23050510	Male Psychiatry - Ward 405	NEED TO CHANGE TONER	Shafiullah. R.	12A TONER CHANGED		Sarathkumar. R. - Derm,Pulmo,Psych Ward	12/05/2023
Comp. Dt. : 13/06/2023								
Status : Completed								
1078	23060474	Male Psychiatry - Ward 405	NEED TO CHANGE TONER	Jayaraj. J.	12A TONER CHANGED		Sarathkumar. R. - Derm,Pulmo,Psych Ward	13/06/2023
Comp. Dt. : 20/06/2023								
Status : Completed								
1079	23060724	Male Psychiatry - Ward 405	PROBLEM IN MEDPLUS - NOT OPENED	Shafiullah. R.	NETWORK PROBLEM REFIXED		Sarathkumar. R. - Derm,Pulmo,Psych Ward	21/06/2023
Dept Name : Dermatology & Vener. - Computer Department								
Comp. Dt. : 07/10/2022								
Status : Completed								
1080	22100162	DERMATOLOGY OPD	U P S BATTERY NOT WORKING	Shafiullah. R.	ups changed		Jayachandran. M. - Dermatology & Vener.	15/10/2022
Comp. Dt. : 10/02/2023								
Status : Completed								
1081	23020388	DERMATOLOGY OPD	WINDOWS SOFTWARE UPDATE	Balachandar. A.	ANTIVIRUS UNINSTALLED		Jayachandran. M. - Dermatology & Vener.	16/02/2023
Comp. Dt. : 21/02/2023								
Status : Completed								
1082	23020822	DERMATOLOGY OPD	WIFI NOT WORKING ROOM NO 72	Murugavel.R	WIFI WORKING FINE		ANUSUYA. S - Dermatology & Vener.	24/02/2023
Comp. Dt. : 26/06/2023								
Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1083	23060957	DERMATOLOGY OPD	WIFI CONNECTION - SLOW PROBLEM ROOM NO 71 [HOD SYSTEM]	Balachandar. A.	BSNL PROBLEM,SOLVED		Jayachandran. M. - Dermatology & Vener.	26/06/2023
Dept Name : Dialysis - Computer Department Comp. Dt. : 20/03/2023 Status : Completed								
1084	23030806	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	PRINTER NOT WORKING	Selvam. D.	Printer working fine		Monika. A. - Dialysis	20/03/2023
Dept Name : Director Office - Computer Department Comp. Dt. : 14/07/2022 Status : Completed								
1085	22070551	Director Office	NEED TO CHANGE TONER	Shafiullah. R.	12A TONER CHANGED		Vijayalakshmi. G. D. - Director Office	14/07/2022
Dept Name : Electrical Maintenance - Computer Department Comp. Dt. : 12/07/2022 Status : Completed								
1086	22070477	POWER ROOM NEAR RADIOLOGY	PRINTER NOT WORKING - NEED URGENT SERVICE	Shafiullah. R.	PDF FORMATE		Vaithianathan.M - Electrical Maintenance	12/07/2022
Comp. Dt. : 05/08/2022 Status : Completed								
1087	22080208	Electrical Maintenance	NEED TO CHANGE TONER	Madhubalan. S.	12A TONER CHANGED		Vaithianathan.M - Electrical Maintenance	05/08/2022
Comp. Dt. : 03/11/2022 Status : Completed								
1088	22110058	Electrical Maintenance	MOUSE NOT WORKING	Selvam. D.	mouse cleaned and refixed		Vaithianathan.M - Electrical Maintenance	03/11/2022
Comp. Dt. : 12/12/2022 Status : Completed								
1089	22120506	Electrical Maintenance	NEED TO CHANGE PRINTER TONER	Selvam. D.	12A toner changed		Azhagappan. J. - Electrical Maintenance	12/12/2022
Comp. Dt. : 04/05/2023 Status : Completed								
1090	23050143	BASEMENT	NET WORK NOT WORKING AT BASEMENT POWER ROOM	Valamburi. R.	NETWORK WORKING		Vaithianathan.M - Electrical Maintenance	05/05/2023
Comp. Dt. : 06/05/2023 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1091	23050235	POWER ROOM NEAR RADIOLOGY	NEED TO CHANGE TONER	Shafiullah. R.	12A TONER CHANGED		Vaithianathan.M - Electrical Maintenance	06/05/2023
Dept Name : EMERGENCY MEDICINE - Computer Department Comp. Dt. : 16/05/2022 Status : Completed								
1092	22050527	Casualty	NEED TO CHANGE TONER	Jayaraj. J.	12A TONER CHANGED		Devi. S - EMERGENCY MEDICINE	16/05/2022
Comp. Dt. : 06/06/2022 Status : Completed								
1093	22060223	Casualty	PRINTER NOT WORKING	Selvam. D.	Print queue cleared and tested the printer working fine		Bhuvaneswari. M. - ENT & Ophthal Ward	07/06/2022
Comp. Dt. : 08/06/2022 Status : Completed								
1094	22060282	Casualty	NEED TO CHANGE TONER	Selvam. D.	12a toner changed		Devi. S - EMERGENCY MEDICINE	08/06/2022
Comp. Dt. : 27/06/2022 Status : Completed								
1095	22060981	Casualty	NEED TO CHANGE TONER	Prakash. P.	12A Comp Toner Changed		Raja. A. - EMERGENCY MEDICINE	28/06/2022
Comp. Dt. : 30/07/2022 Status : Completed								
1096	22071114	Casualty	PRINTER NOT WORKING	Shafiullah. R.	PRINTER QUEUE CLEAN		Kanimozhi. E. - EMERGENCY MEDICINE	30/07/2022
Comp. Dt. : 03/08/2022 Status : Completed								
1097	22080106	Casualty	PRINTER NOT WORKING	Selvam. D.	Toner refixed		Kanimozhi. E. - EMERGENCY MEDICINE	03/08/2022
1098	22080138	Casualty	NEED TO CHANGE TONER & PRINTER NOT WORKING	Balachandar. A.	12A TONER CHANGED		Kanimozhi. E. - EMERGENCY MEDICINE	04/08/2022
Comp. Dt. : 10/08/2022 Status : Completed								
1099	22080368	Casualty	NEED TO CHANGE TONER	Madhubalan. S.	PRINTER SETTING CHANGED		Rajipriya. K. - EMERGENCY MEDICINE	10/08/2022
Comp. Dt. : 25/08/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1100	22080836	Casualty	SYSTEM NOT WORKING	Valamburi. R.	working fine		Kanimozhi. E. - EMERGENCY MEDICINE	25/08/2022
Comp. Dt. : 19/09/2022 Status : Completed								
1101	22090722	Casualty	NEED TO CHANGE TONER	Shafiullah. R.	12A TONER CHANGED		Kazhagamani. V. - EMERGENCY MEDICINE	19/09/2022
Comp. Dt. : 06/10/2022 Status : Completed								
1102	22100120	Casualty	NEED TO CHANGE TONER	Balachandar. A.	12A toner changed		Rajipriya. K. - EMERGENCY MEDICINE	06/10/2022
Comp. Dt. : 13/10/2022 Status : Completed								
1103	22100392	Casualty	NEED TO CHECK SYSTEM MONITOR - PROBLEM IN DISPLAY	Madhubalan. S.	DISPLAY SETTING CHANGED		Veeramani. D. - EMERGENCY MEDICINE	13/10/2022
Comp. Dt. : 22/10/2022 Status : Completed								
1104	22100754	Casualty	NEED TO CHANGE PRINTER TONER	Madhubalan. S.	12A TONER CHANGED		Kanimozhi. E. - EMERGENCY MEDICINE	22/10/2022
Comp. Dt. : 05/11/2022 Status : Completed								
1105	22110181	MAIN CASUALTY	PRINTER NOT WORKING	Balachandar. A.	pending job cleared		Racida. R. - EMERGENCY MEDICINE	05/11/2022
Comp. Dt. : 11/11/2022 Status : Completed								
1106	22110462	FEVER CLINIC	SYSTEM NOT WORKING	Madhubalan. S.	SYSTEM WORKING FINE		Veeramani. D. - EMERGENCY MEDICINE	11/11/2022
Comp. Dt. : 16/11/2022 Status : Completed								
1107	22110635	Casualty	CHANGE PRINTER CATRIDGE	Murugavel.R	12A TONER CHANGED		Sasirekha. K. - EMERGENCY MEDICINE	16/11/2022
Comp. Dt. : 29/11/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1108	22111224	FEVER CLINIC	PRINTER NOT WORKING	Balachandar. A.	printer working fine		Sowmiya. S. - EMERGENCY MEDICINE	01/12/2022
	Comp. Dt. : 07/12/2022							
	Status : Completed							
1109	22120336	Casualty	NEED TO CHANGE TONER	Jayaraj. J.	12A TONER CHANGED		Sasirekha. K. - EMERGENCY MEDICINE	07/12/2022
	Comp. Dt. : 28/12/2022							
	Status : Completed							
1110	22121294	FEVER CLINIC	PRINTER NOT WORKING	Selvam. D.	Print queue cleared		Yuvaraj. G - EMERGENCY MEDICINE	29/12/2022
	Comp. Dt. : 29/12/2022							
	Status : Completed							
1111	22121337	Casualty	CHANGE PRINTER TONER	Madhubalan. S.	12A TONER CHANGED		Kanimozhi. E. - EMERGENCY MEDICINE	29/12/2022
	Comp. Dt. : 12/01/2023							
	Status : Completed							
1112	23010515	FEVER CLINIC	SYSTEM STARTUP ISSUE	Jayaraj. J.	LAPTOP RESTARED		Sowmiya. S. - EMERGENCY MEDICINE	12/01/2023
	Comp. Dt. : 18/01/2023							
	Status : Completed							
1113	23010606	Casualty	PRINTER PAPER NOT PIIKUP	Balachandar. A.	PAPER JAM REMOVED AND REFIXED		Kanimozhi. E. - EMERGENCY MEDICINE	18/01/2023
	Comp. Dt. : 06/02/2023							
	Status : Completed							
1114	23020174	Casualty	NEED TO CHECK NET CONNECTION	Selvam. D.	patch cable refixed		Dhanalakshmi. M. - EMERGENCY MEDICINE	06/02/2023
	Comp. Dt. : 09/02/2023							
	Status : Completed							
1115	23020345	Casualty	NEED TO CHANGE TONER	Jayaraj. J.	12A TONER CHANGED		Sasirekha. K. - EMERGENCY MEDICINE	09/02/2023
	Comp. Dt. : 15/02/2023							
	Status : Completed							


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1116	23020574	TB & Chest OPD	NEED TO CHECK WI FI CONNECTION - NOT WORKING	Murugavel.R	Wifi device fixed and checked working fine		Uvaraj. M. - EMERGENCY MEDICINE	20/02/2023
		Comp. Dt. : 16/02/2023 Status : Completed						
1117	23020614	Casualty	NEED TO CHANGE PRINTER TONER	Selvam. D.	PRINTER TONER CHANGED		Kanimozhi. E. - EMERGENCY MEDICINE	16/02/2023
		Comp. Dt. : 17/02/2023 Status : Completed						
1118	23020706	Casualty	PRINTER NOT WORKING	Shafiullah. R.	REFIX TONER PRINTER WORKING		Kanimozhi. E. - EMERGENCY MEDICINE	17/02/2023
		Comp. Dt. : 21/02/2023 Status : Completed						
1119	23020819	Casualty	PRINTER NOT WORKING	Madhubalan. S.	TONER REFIXED WORKING FINE		Kazhagamani. V. - EMERGENCY MEDICINE	21/02/2023
		Comp. Dt. : 14/03/2023 Status : Completed						
1120	23030564	Casualty	PRINTER NOT WORKING	Madhubalan. S.	SYSTEM RESTATED PRINTER WORKING FINE		Kazhagamani. V. - EMERGENCY MEDICINE	14/03/2023
		Comp. Dt. : 17/03/2023 Status : Completed						
1121	23030682	Casualty	NEED TO CHANGE TONER	Selvam. D.	toner refixed		Raja. A. - EMERGENCY MEDICINE	17/03/2023
		Comp. Dt. : 20/03/2023 Status : Completed						
1122	23030786	Casualty	NEED TO CHANGE TONER + PRINTER NOT WORKING	Harikrishnan. R.	12a toner changed		Balamurugan. M. - EMERGENCY MEDICINE	20/03/2023
		Comp. Dt. : 27/03/2023 Status : Completed						
1123	23031088	Casualty	SYSTEM DISPLAY PROBLEM	Jayaraj. J.	setting changed		Racida. R. - EMERGENCY MEDICINE	27/03/2023
		Comp. Dt. : 08/04/2023 Status : Completed						


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1124	23040233	FEVER CLINIC	SYSTEM NOT WORKING	Harikrishnan. R.	Laptop Restarted.		Sasirekha. K. - EMERGENCY MEDICINE	08/04/2023
Comp. Dt. : 29/04/2023 Status : Completed								
1125	23041010	Casualty	NEED TO CHANGE TONER	Shafiullah. R.	12A TONER CHANGED		Kanimozhi. E. - EMERGENCY MEDICINE	29/04/2023
Comp. Dt. : 05/05/2023 Status : Completed								
1126	23050189	FEVER CLINIC	SYSTEM NOT WORKING	Jayaraj. J.	System Restarted.		Sowmiya. S. - EMERGENCY MEDICINE	05/05/2023
Comp. Dt. : 08/05/2023 Status : Completed								
1127	23050333	Casualty	PRINTER NOT WORKING	Harikrishnan. R.	WORKING FINE		Kanimozhi. E. - EMERGENCY MEDICINE	11/05/2023
Comp. Dt. : 10/05/2023 Status : Completed								
1128	23050414	Casualty	PRINTER NOT WORKING	Valamburi. R.	working fine		Racida. R. - EMERGENCY MEDICINE	11/05/2023
Comp. Dt. : 29/05/2023 Status : Completed								
1129	23051141	Casualty	NEED TO CHANGE TONER	Harikrishnan. R.	12A Toner Changed.		Kanimozhi. E. - EMERGENCY MEDICINE	29/05/2023
Comp. Dt. : 14/06/2023 Status : Completed								
1130	23060499	Casualty	PRINTER NOT WORKING	Shafiullah. R.	cable refixed		Sasirekha. K. - EMERGENCY MEDICINE	14/06/2023
Comp. Dt. : 19/06/2023 Status : Completed								
1131	23060665	Male Medical - Ward 302	SYSTEM NOT WORKING	Prakash. P.	POWER ISSUE UPS POWER ON		Sumithradevi. S. - EMERGENCY MEDICINE	19/06/2023
Dept Name : Endoscopy - Computer Department Comp. Dt. : 05/05/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1132	22050135	Endoscopy	NEED TO REFIL COLOUR INK FOR PRINTER	Shafiullah. R.	REFIL ALL COLOUR AND HEAD CLEAN		Vijayalakshmi. G. - Endoscopy	05/05/2022
	Comp. Dt. : 11/05/2022							
	Status : Completed							
1133	22050385	Endoscopy	PRINTER PROBLEM	Jayaraj. J.	WORKING FINE		Vijayalakshmi. G. - Endoscopy	11/05/2022
	Comp. Dt. : 01/07/2022							
	Status : Completed							
1134	22070036	Endoscopy	PRINTER NOT WORKING	Shafiullah. R.	setting changed		Vijayalakshmi. G. - Endoscopy	02/07/2022
	Comp. Dt. : 09/07/2022							
	Status : Completed							
1135	22070393	Endoscopy	NEED TO CHANGE PRINTER CARTRIDGE	Valamburi. R.	printer working fine		Vijayalakshmi. G. - Endoscopy	18/07/2022
	Comp. Dt. : 18/11/2022							
	Status : Completed							
1136	22110764	Endoscopy	NEED TO CHECK SYSTEM IMAGE QUALITY - PROBLEM	Prakash. P.	System working fine		Vijayalakshmi. G. - Endoscopy	19/11/2022
	Comp. Dt. : 20/03/2023							
	Status : Completed							
1137	23030808	Endoscopy	NEED TO CHANGE TONER	Selvam. D.	Ink filled		Vijayalakshmi. G. - Endoscopy	20/03/2023
	Comp. Dt. : 23/05/2023							
	Status : Completed							
1138	23050901	Endoscopy	PRINTER NOT WORKING	Prakash. P.	printer working fine		Tamilselvi. E. - Endoscopy	24/05/2023
	Comp. Dt. : 27/05/2023							
	Status : Completed							
1139	23051078	Endoscopy	PRINTER NOT WORKING	Selvam. D.	BLACK INK REFILL		Tamilselvi. E. - Endoscopy	27/05/2023
	Comp. Dt. : 02/06/2023							
	Status : Completed							
1140	23060072	Endoscopy	PRINTER NOT WORKING	Balachandar. A.	nozzle clean power flusing		Tamilselvi. E. - Endoscopy	02/06/2023
	Comp. Dt. : 09/06/2023							
	Status : Completed							
1141	23060311	Endoscopy	PRINTER NOT WORKING	Shafiullah. R.	old ink pad changed		Vijayalakshmi. G. - Endoscopy	15/06/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Dept Name : ENT & Ophthal Ward - Computer Department Comp. Dt. : 27/08/2022 Status : Completed								
1142	22080947	Female Medical - Ward 306	SYSTEM NOT WORKING	Shafiullah. R.	SYSTEM WORKING ONLY CHANGED 12A TONER CHANGED		Bhuvaneswari. M. - ENT & Ophthal Ward	27/08/2022
Comp. Dt. : 06/09/2022 Status : Completed								
1143	22090239	Female Medical - Ward 305	SYSTEM NOT WORKING	Selvam. D.	Power setting done		Bhuvaneswari. M. - ENT & Ophthal Ward	06/09/2022
Comp. Dt. : 07/10/2022 Status : Completed								
1144	22100130	Female Medical - Ward 305	SYSTEM NOT WORKING	Selvam. D.	power issue solved		Bhuvaneswari. M. - ENT & Ophthal Ward	07/10/2022
Comp. Dt. : 12/10/2022 Status : Completed								
1145	22100359	Female Medical - Ward 306	PRINTER NOT WORKING	Valamburi. R.	Printer working fine		Bhuvaneswari. M. - ENT & Ophthal Ward	13/10/2022
Comp. Dt. : 21/10/2022 Status : Completed								
1146	22100706	Female Medical - Ward 306	NEED TO CHANGE PRINTER TONER	Valamburi. R.	12A toner changed		Bhuvaneswari. M. - ENT & Ophthal Ward	21/10/2022
Comp. Dt. : 22/10/2022 Status : Completed								
1147	22100745	Female Medical - Ward 305	SYSTEM NOT WORKING	Selvam. D.	SYSTEM WORKING FINE		Bhuvaneswari. M. - ENT & Ophthal Ward	22/10/2022
1148	22100746	Female Medical - Ward 306	SYSTEM NOT WORKING	Selvam. D.	SYSTEM WORKING FINE		Bhuvaneswari. M. - ENT & Ophthal Ward	22/10/2022
Comp. Dt. : 25/10/2022 Status : Completed								
1149	22100782	Female Medical - Ward 305	SYSTEM NOT WORKING (FEMALE MEDICAL - 305,306)	Madhubalan. S.	305 SYSTEM WORKING FINE, 306 PRINTER TONER REFIXED WORKING FINE		Bhuvaneswari. M. - ENT & Ophthal Ward	26/10/2022
Comp. Dt. : 11/11/2022 Status : Completed								
1150	22110468	Female Medical - Ward 305	SYSTEM NOT WORKING	Shafiullah. R.	PRINTER PAUSES REMOVE		Bhuvaneswari. M. - ENT & Ophthal Ward	11/11/2022
Comp. Dt. : 18/11/2022								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
1151	22110752	Female Medical - Ward 306	NEED TO CHANGE PRINTER TONER	Balachandar. A.	PRINTER TONER CHANGED		Bhuvaneswari. M. - ENT & Ophthal Ward	18/11/2022
Comp. Dt. : 28/11/2022								
Status : Completed								
1152	22111180	Male Ortho - Ward 403	PRINTER NOT WORKING	Selvam. D.	Paper jam cleared		Vijayakumar. G. - ENT & Ophthal Ward	28/11/2022
Comp. Dt. : 08/12/2022								
Status : Completed								
1153	22120346	Female Medical - Ward 306	PRINTER NOT WORKING	Murugavel.R	Paper Pickup Problem.		Bhuvaneswari. M. - ENT & Ophthal Ward	09/12/2022
Comp. Dt. : 19/01/2023								
Status : Completed								
1154	23010678	Female Medical - Ward 306	NEED TO CHANGE TONER	Madhubalan. S.	12A TONER CHANGED		Bhuvaneswari. M. - ENT & Ophthal Ward	20/01/2023
Comp. Dt. : 08/02/2023								
Status : Completed								
1155	23020301	Male Ortho - Ward 403	SYSTEM NETWORK PROBLEM	Shafiullah. R.	REFIX THE NETWORK PATCH CARD		Vijayakumar. G. - ENT & Ophthal Ward	09/02/2023
Comp. Dt. : 15/02/2023								
Status : Completed								
1156	23020573	Female Medical - Ward 306	NEED TO CHANGE TONER	Balachandar. A.	PRINTER TONER CHANGED		Bhuvaneswari. M. - ENT & Ophthal Ward	15/02/2023
Comp. Dt. : 28/02/2023								
Status : Completed								
1157	23021073	ICU	NEED TO CHANGE PRINTER TONER	Shafiullah. R.	12A TONER CHANGED		Maheswaran. D. - ENT & Ophthal Ward	28/02/2023
Comp. Dt. : 07/03/2023								
Status : Completed								
1158	23030267	Female Medical - Ward 306	SYSTEM NOT WORKING	Shafiullah. R.	REFIX THE RAM		Bhuvaneswari. M. - ENT & Ophthal Ward	07/03/2023
Comp. Dt. : 30/03/2023								
Status : Completed								
1159	23031318	ICU	NEED TO CHANGE TONER	Jayaraj. J.	TONER WORKING NOT CHANGING		Maheswaran. D. - ENT & Ophthal Ward	31/03/2023
Comp. Dt. : 12/04/2023								
Status : Completed								
1160	23040377	Male Ortho - Ward 403	NEED TO CHANGE TONER	Shafiullah. R.	shake and refix toner		Vijayakumar. G. - ENT & Ophthal Ward	12/04/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 27/04/2023 Status : Completed								
1161	23040921	ICU	PRINTER PAPER JAM	Selvam. D.	printer working fine		Maheswaran. D. - ENT & Ophthal Ward	02/05/2023
Comp. Dt. : 04/05/2023 Status : Completed								
1162	23050160	Female Medical - Ward 305	PRINTER NOT WORKING	Harikrishnan. R.	Clear The Paper Jam.		Bhuvaneswari. M. - ENT & Ophthal Ward	04/05/2023
Comp. Dt. : 11/05/2023 Status : Completed								
1163	23050422	Female Medical - Ward 305	NEED TO CHECK PRINTER NOT WORKING & CHANGE TONER	Madhubalan. S.	WORKING FINE		Bhuvaneswari. M. - ENT & Ophthal Ward	11/05/2023
Comp. Dt. : 22/05/2023 Status : Completed								
1164	23050854	ENT WARD-407	NEED TO CHANGE TONER	Shafiullah. R.	12A TONER CHANGED		Samundeeswari. E. - ENT & Ophthal Ward	22/05/2023
Dept Name : Female Medical Ward - Computer Department Comp. Dt. : 09/05/2022 Status : Completed								
1165	22050263	Female Medical - Ward 305	SYSTEM NOT WORKING	Balachandar. A.	New hard disk changed		Gnanasoundari. G - Female Medical Ward	18/05/2022
Comp. Dt. : 01/06/2022 Status : Completed								
1166	22060006	Female Medical - Ward 306	NEED TO CHANGE TONER	Madhubalan. S.	12A TONER CHANGED		Vaitheeswari. A. - Female Medical Ward	01/06/2022
Comp. Dt. : 01/07/2022 Status : Completed								
1167	22070009	Female Medical - Ward 306	NEED TO CHANGE TONER	Shafiullah. R.	TONER CHANGED		Vaitheeswari. A. - Female Medical Ward	02/07/2022
Comp. Dt. : 06/07/2022 Status : Completed								
1168	22070212	Female Medical - Ward 306	NEED TO CHANGE TONER	Shafiullah. R.	12A TONER CHANGED		Vaitheeswari. A. - Female Medical Ward	06/07/2022
Comp. Dt. : 03/08/2022 Status : Completed								
1169	22080135	Female Medical - Ward 306	NEED TO CHANGE TONER	Selvam. D.	12A toner changed		Vaitheeswari. A. - Female Medical Ward	03/08/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 23/09/2022 Status : Completed								
1170	22090938	Female Medical - Ward 306	PRINTER NOT WORKING	Madhubalan. S.	SYSTEM RESTATE PRINTER WORKING FINE		Gnanasoundari. G - Female Medical Ward	26/09/2022
Comp. Dt. : 31/12/2022 Status : Completed								
1171	22121412	Female Medical - Ward 305	SYSTEM NOT WORKING	Madhubalan. S.	SYSTEM WORKING FINE		Gnanasoundari. G - Female Medical Ward	02/01/2023
Comp. Dt. : 07/03/2023 Status : Completed								
1172	23030283	Free Pharmacy	NEED TO CHANGE PRINTER RIBBON	Shafiullah. R.	10MTS ribbon changed		Johnsi Rani. N. - Female Medical Ward	07/03/2023
Comp. Dt. : 10/04/2023 Status : Completed								
1173	23040269	Female Medical - Ward 305	PRINTER NOT WORKING	Shafiullah. R.	printer working fine		Anto Valani. A. - Female Medical Ward	17/04/2023
Comp. Dt. : 04/05/2023 Status : Completed								
1174	23050176	Male Medical - Ward 302	SYSTEM NOT WORKING	Selvam. D.	SYSTEM WORKING FINE		Vaitheeswari. A. - Female Medical Ward	06/05/2023
Dept Name : Female Ortho Ward - Computer Department Comp. Dt. : 07/06/2022 Status : Completed								
1175	22060263	Dressing	NEED TO CHECK PROJECTOR - FOCUS NOT CLEAR - ROOM NO 52 [DRESSING OPD]	Madhubalan. S.	LCD LENS DUST CLEAN AND SETTING CHANGED		Badmasri. P. - OPD	07/06/2022
Comp. Dt. : 07/07/2022 Status : Completed								
1176	22070262	Male Ortho - Ward 403	SYSTEM NOT WORKING	Madhubalan. S.	SYSTEM WORKING FINE		Sandhiya. L. - Male Ortho Ward	07/07/2022
Comp. Dt. : 01/08/2022 Status : Completed								
1177	22080025	Female Ortho - Ward 402	NEED TO CHANGE TONER	Murugavel.R	12 A C TONER CHANGED		Dhansulakshmi. K. - Female Ortho Ward	01/08/2022
Comp. Dt. : 10/08/2022 Status : Completed								
1178	22080350	Female Ortho - Ward 402	PRINTER NOT WORKING	Shafiullah. R.	PRESSURE ROLL CHANGED		Punitha. E. - Female Ortho Ward	11/08/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 22/08/2022 Status : Completed								
1179	22080707	Female Ortho - Ward 402	PRINTER NOT WORKING	Selvam. D.	Print queue cleared and tested the printer working fine		Girija. G. - Female Ortho Ward	22/08/2022
Comp. Dt. : 06/09/2022 Status : Completed								
1180	22090247	Female Ortho - Ward 401	PRINTER NOT WORKING	Selvam. D.	Paper jam cleared and tested the printer working fine		Girija. G. - Female Ortho Ward	08/09/2022
Comp. Dt. : 15/09/2022 Status : Completed								
1181	22090573	Female Ortho - Ward 402	NEED TO PRIENT NOT WORKING	Selvam. D.	toner refixed		Girija. G. - Female Ortho Ward	15/09/2022
Comp. Dt. : 19/09/2022 Status : Completed								
1182	22090723	Female Ortho - Ward 402	PRINTER NOT WORKING	Jayaraj. J.	12A TONER CHANGED		Girija. G. - Female Ortho Ward	19/09/2022
Comp. Dt. : 23/09/2022 Status : Completed								
1183	22090919	Female Ortho - Ward 402	NEED TO CHANGE TONER	Shafiullah. R.	12A TONER CHANGED		Girija. G. - Female Ortho Ward	23/09/2022
Comp. Dt. : 13/10/2022 Status : Completed								
1184	22100427	Female Ortho - Ward 402	PRINTER NOT WORKING	Shafiullah. R.	PRINTER WORKING FINE		Punithavathi. E. - Female Ortho Ward	13/10/2022
Comp. Dt. : 15/12/2022 Status : Completed								
1185	22120725	Female Ortho - Ward 402	NEED TO CHANGE TONER	Selvam. D.	12A TONER CHANGED		Dhansulakshmi. K. - Female Ortho Ward	17/12/2022
Comp. Dt. : 16/12/2022 Status : Completed								
1186	22120782	Female Ortho - Ward 402	PRINTER NOT WORKING	Shafiullah. R.	PRINTER WORKING		Girija. G. - Female Ortho Ward	22/12/2022
Comp. Dt. : 07/02/2023 Status : Completed								
1187	23020211	Female Ortho - Ward 401	SYSTEM NOT WORKING	Jayaraj. J.	SYSTEM REPAIR AND SETTING CHANGED		Dhansulakshmi. K. - Female Ortho Ward	07/02/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Dept Name : Female Surgery - Computer Department Comp. Dt. : 09/06/2022 Status : Completed								
1188	22060325	Male Surgery - Ward 204	NEED TO CHANGE TONER	Selvam. D.	TONER CHANGED		Sasikala. A. - Male Surgery	09/06/2022
Comp. Dt. : 24/06/2022 Status : Completed								
1189	22060866	Male Surgery - Ward 204	PRINTER NOT WORKING	Murugavel.R	PRINTER QUEUE CLEARED PRINTER WORKING FINE		Sivasankari. T. - Male Surgery	24/06/2022
Comp. Dt. : 20/07/2022 Status : Completed								
1190	22070761	Female Surgery - Ward 205	PRINTER NOT WORKING	Selvam. D.	general service done		Saranya. V. - Female Surgery	22/07/2022
Comp. Dt. : 25/07/2022 Status : Completed								
1191	22070891	Female Surgery - Ward 206	SYSTEM NOT WORKING	Selvam. D.	Electrical problem, solved system working fine		Vinodhini. K. - Female Surgery	25/07/2022
Comp. Dt. : 17/08/2022 Status : Completed								
1192	22080546	Female Surgery - Ward 206	SYSTEM POWER OFF PROBLEM	Selvam. D.	SYSTEM WORKING FINE		Vaidegi. S. - Female Surgery	18/08/2022
Comp. Dt. : 02/09/2022 Status : Completed								
1193	22090102	Male Surgery - Ward 204	PRINTER NOT WORKING	Madhubalan. S.	Presure roller and teflon sleeve changed		Vaidegi. S. - Female Surgery	05/09/2022
Comp. Dt. : 16/09/2022 Status : Completed								
1194	22090649	Male Surgery - Ward 203	NEED TO CHECK SYSTEM " MED PLUS " NOT WORKING	Shafiullah. R.	medpluse working		Vinodhini. K. - Female Surgery	16/09/2022
Comp. Dt. : 16/11/2022 Status : Completed								
1195	22110689	Male Surgery - Ward 203	IN DEMO ROOM-SYSTEM NOT WORKING	Shafiullah. R.	OS PROLEM,OS REINSTALLED.READY		Subashini. D. - Gynac Ward	21/11/2022
Comp. Dt. : 09/02/2023 Status : Completed								
1196	23020325	Female Surgery - Ward 205	2NOS MONITOR NOT WORKING	Shafiullah. R.	WRONG COMPALINE TO BIODMEDICAL DEPT		Subeela. R. - ICU	09/02/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 16/04/2023 Status : Completed								
1197	23040471	Male Surgery - Ward 204	NEED TO CHANGE TONER	Harikrishnan. R.	TONER CHANGED		Saranya. V. - Female Surgery	17/04/2023
Dept Name : Gas Power Plant - Computer Department Comp. Dt. : 17/05/2023 Status : Completed								
1198	23050677	Printing Press	NEED TO CHECK NET - NOT WORKING	Prakash. P.	Network is Working		Mahi Mohan Ram.S. - Gas Power Plant	24/05/2023
Dept Name : Gastroenterology - Computer Department Comp. Dt. : 30/08/2022 Status : Completed								
1199	22081037	SPECIAL OPD IN 2ND FLOOR	NEED TO CHECK WI-FI CONNECTION - SLOW PROBLEM	Balachandar. A.	poe refixed		Vanitha. G. - NEUROLOGY	01/09/2022
Dept Name : GENERAL MEDICINE - Computer Department Comp. Dt. : 11/08/2022 Status : Completed								
1200	22080421	General Medicine - OPD	NEED TO CHECK SYSTEM - NOT WORKING IN ROOM NO 16	Selvam. D.	new smps changed		Suman Babu. I.S.S. - General Medicine	17/08/2022
Dept Name : Guest House - Indian Bank - Computer Department Comp. Dt. : 06/08/2022 Status : Completed								
1201	22080241	Guest House - Indian Bank	MOUSE NOT WORKING	Balachandar. A.	new usb mouse changed...		John. H. - Guest House - Indian Bank	09/08/2022
Comp. Dt. : 15/11/2022 Status : Completed								
1202	22110625	Guest House - Indian Bank	CPU PROBLEM-SYSTEM NO POWER ON	Balachandar. A.	NEW SMPS CHANGED		John. H. - Guest House - Indian Bank	25/11/2022
Comp. Dt. : 28/12/2022 Status : Completed								
1203	22121281	Guest House - Indian Bank	SYSTEM UPS PROBLEM	Balachandar. A.	Numeric ups changed		John. H. - Guest House - Indian Bank	28/01/2023
Dept Name : Gynac Ward - Computer Department Comp. Dt. : 04/05/2022 Status : Completed								
1204	22050075	Obstetrics - Ward 207	SYSTEM NOT WORKING	Prakash. P.	Sysytem Working desktop file reset		Ashwini. V. - Gynac Ward	04/05/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 10/06/2022 Status : Completed								
1205	22060362	Obstetrics - Ward 208	SYSTEM MOUSE NOT WORKING	Madhubalan. S.	MOUSE REFIXED		Ashwini. V. - Gynac Ward	10/06/2022
Comp. Dt. : 18/06/2022 Status : Completed								
1206	22060675	Obstetrics - Ward 207	SYSTEM NOT WORKING	Shafiullah. R.	SYSTEM WORKING FINE FILE FINDING WORK		Sangeetha. J. - Gynac Ward	18/06/2022
Comp. Dt. : 05/08/2022 Status : Completed								
1207	22080212	Obstetrics - Ward 207	SYSTEM , MOUSE & KEY BOARD NOT WORKING	Madhubalan. S.	OLD KEYBOARD CHANGED		Ashwini. V. - Gynac Ward	06/08/2022
Comp. Dt. : 15/11/2022 Status : Completed								
1208	22110594	Obstetrics - Ward 207	SYSTEM NOT WORKING	Selvam. D.	system working fine		Ashwini. V. - Gynac Ward	16/11/2022
Comp. Dt. : 13/01/2023 Status : Completed								
1209	23010570	Female Surgery - Ward 206	NEED TO CHANGE PRINTER TONER	Shafiullah. R.	12A TONER CHANGED		Amsavalli. S. - Gynac Ward	13/01/2023
Comp. Dt. : 19/01/2023 Status : Completed								
1210	23010686	Female Surgery - Ward 206	SYSTEM & PRINTER NOT WORKING	Madhubalan. S.	UPS RESTATED WORKING FINE		Amsavalli. S. - Gynac Ward	25/01/2023
Comp. Dt. : 24/02/2023 Status : Completed								
1211	23020918	Obstetrics - Ward 208	SYSTEM & PRINTER NOT WORKING	Jayaraj. J.	Monitor power cable refixed		Divya. K. - Gynac Ward	24/02/2023
Comp. Dt. : 05/06/2023 Status : Completed								
1212	23060114	Obstetrics - Ward 208	SYSTEM NOT WORKING	Selvam. D.	printer working fine		Subasri. G. - Gynac Ward	06/06/2023
Comp. Dt. : 16/06/2023 Status : Completed								
1213	23060596	Gynaecology - Ward 209	KEY BOARD NOT WORKING	Shafiullah. R.	KEY BOARD WORKING FINE		Sangeetha. J. - Gynac Ward	16/06/2023
Dept Name : Hospital Infection Control - Computer Department Comp. Dt. : 04/11/2022								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
1214	22110153	HICC ROOM IN 4TH FLOOR-403	INFECTION CONTROL ROOM-SYSTEM POWER ON PROBLEM	Selvam. D.	UPS CHANGED.		Kalaivani. P. - Hospital Infection Control	08/11/2022
Comp. Dt. : 17/11/2022								
Status : Completed								
1215	22110732	HICC ROOM IN 4TH FLOOR-403	UPS PROBLEM	Jayaraj. J.	NEW LITHIUM UPS CHANGED		Anitha. N. - Hospital Infection Control	17/12/2022
Comp. Dt. : 27/06/2023								
Status : Completed								
1216	23060993	HICC	SYSTEM NOT WORKING	Balachandar. A.	SYSTEM OS REINSTALLED		Anitha. N. - Hospital Infection Control	30/06/2023
Dept Name : Housekeeping - Computer Department								
Comp. Dt. : 18/05/2022								
Status : Completed								
1217	22050677	OSD	NEED TO CHECK PRINTER - PAPER JAM	Selvam. D.	Printer working fine		Naresh. R - Housekeeping	19/05/2022
Dept Name : ICCU - Computer Department								
Comp. Dt. : 04/05/2022								
Status : Completed								
1218	22050071	ICCU	NEED TO CHANGE TONER	Selvam. D.	Toner Changed		Ammu. R. - ICCU	04/05/2022
Comp. Dt. : 16/05/2022								
Status : Completed								
1219	22050513	ICCU	NEED TO CHANGE TONER	Selvam. D.	12a toner changed		Ammu. R. - ICCU	16/05/2022
Comp. Dt. : 28/05/2022								
Status : Completed								
1220	22051040	ICCU	NEED TO CHANGE TONER	Madhubalan. S.	12A TONER CHANGED		Ammu. R. - ICCU	28/05/2022
Comp. Dt. : 04/06/2022								
Status : Completed								
1221	22060163	ICCU	PRINTER NOT WORKING	Madhubalan. S.	PRINTER USB CABLE CHANGED		Ammu. R. - ICCU	04/06/2022
Comp. Dt. : 30/06/2022								
Status : Completed								
1222	22061125	ICCU	NEED TO CHANGE TONER	Selvam. D.	12 A TONER CHANGED		Ammu. R. - ICCU	30/06/2022
Comp. Dt. : 05/07/2022								
Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1223	22070163	ICCU	PRINTER NOT WORKING	Madhubalan. S.	system restarts working fine		Ammu. R. - ICCU	05/07/2022
	Comp. Dt. : 06/07/2022							
	Status : Completed							
1224	22070206	ICCU	PRINTER NOT WORKING	Selvam. D.	Printer working fine		Ammu. R. - ICCU	07/07/2022
	Comp. Dt. : 01/08/2022							
	Status : Completed							
1225	22080007	ICCU	NEED TO CHANGE TONER	Balachandar. A.	TONER CHANGED		Ammu. R. - ICCU	01/08/2022
	Comp. Dt. : 19/08/2022							
	Status : Completed							
1226	22080617	ICCU	SYSTEM NOT WORKING	Madhubalan. S.	SYSTEM POWER CABLE REFIXED		Ammu. R. - ICCU	19/08/2022
	Comp. Dt. : 25/08/2022							
	Status : Completed							
1227	22080834	ICCU	NEED TO CHANGE TONER	Valamburi. R.	toner changed		Ammu. R. - ICCU	25/08/2022
	Comp. Dt. : 27/08/2022							
	Status : Completed							
1228	22080928	ICCU	SYSTEM NOT WORKING	Prakash. P.	FILE MIISING DONT RECOVER		Ammu. R. - ICCU	27/08/2022
	Comp. Dt. : 26/09/2022							
	Status : Completed							
1229	22091025	ICCU	PRINTER NOT WORKING	Shafiullah. R.	PRINTER PAUSE RELEASED		Ammu. R. - ICCU	26/09/2022
	Comp. Dt. : 28/09/2022							
	Status : Completed							
1230	22091104	ICCU	SYSTEM NOT WORKING	Valamburi. R.	PRINTER TONER CHANGED		Hemasri. M. - ICCU	28/09/2022
	Comp. Dt. : 29/09/2022							
	Status : Completed							
1231	22091149	ICCU	SYSTEM NOT WORKING	Prakash. P.	power cable refixed		Hemasri. M. - ICCU	30/09/2022
	Comp. Dt. : 30/09/2022							
	Status : Completed							
1232	22091209	ICCU	PRINTER NOT WORKING	Madhubalan. S.	setting done		Ammu. R. - ICCU	30/09/2022
	Comp. Dt. : 05/10/2022							
	Status : Completed							


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1233	22100023	ICCU	PROBLEM IN PRINTER - TONER	Shafiullah. R.	toner refixed		Saradha. G. - ICCU	05/10/2022
	Comp. Dt. : 07/10/2022							
	Status : Completed							
1234	22100140	ICCU	NEED TO CHANGE TONER	Balachandar. A.	TONER CHANGED		Ramya. V. - ICCU	07/10/2022
	Comp. Dt. : 18/10/2022							
	Status : Completed							
1235	22100580	ICCU	NEED TO CHANGE TONER	Valamburi. R.	12A TONER CHANGED		Ammu. R. - ICCU	18/10/2022
	Comp. Dt. : 31/10/2022							
	Status : Completed							
1236	22100995	ICCU	NEED TO CHANGE PRINTER TONER	Jayaraj. J.	12A TONER CHANGED		Ammu. R. - ICCU	31/10/2022
	Comp. Dt. : 15/11/2022							
	Status : Completed							
1237	22110622	ICCU	CHANGE PRINTER TONER	Valamburi. R.	TONER CHANGED		Ammu. R. - ICCU	15/11/2022
	Comp. Dt. : 28/11/2022							
	Status : Completed							
1238	22111187	ICCU	SYSTEM NO POWER ON	Selvam. D.	system working fine		Saradha. G. - ICCU	28/11/2022
	Comp. Dt. : 30/11/2022							
	Status : Completed							
1239	22111259	ICCU	NEED TO CHANGE TONER	Shafiullah. R.	12A TONER CHANGED		Ammu. R. - ICCU	30/11/2022
	Comp. Dt. : 05/12/2022							
	Status : Completed							
1240	22120170	ICCU	PRINTER NOT WORKING	Madhubalan. S.	PRINTER SETTING CHANGED		Ammu. R. - ICCU	05/12/2022
	Comp. Dt. : 15/12/2022							
	Status : Completed							
1241	22120680	ICCU	NEED TO CHANGE TONER	Shafiullah. R.	12A TONER CHANGED		Ammu. R. - ICCU	15/12/2022
	Comp. Dt. : 27/12/2022							
	Status : Completed							
1242	22121199	ICCU	CHANGE PRINTER TONER	Shafiullah. R.	REPATED COMPLAINE		Ammu. R. - ICCU	27/12/2022
	Comp. Dt. : 03/01/2023							
	Status : Completed							


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1243	23010096	ICCU	PRINTER NOISE PROBLEM	Shafiullah. R.	INSIDE NEEDLE REMOVED IN THE PRINTER WORKING		Ammu. R. - ICCU	03/01/2023
	Comp. Dt. : 09/01/2023							
	Status : Completed							
1244	23010336	ICCU	CHANGE PRINTER TONER	Balachandar. A.	PRINTER TONER CHANGED		Ammu. R. - ICCU	09/01/2023
	Comp. Dt. : 21/01/2023							
	Status : Completed							
1245	23010777	ICCU	NEED TO CHANGE TONER	Madhubalan. S.	12A TONER CHANGED		Ammu. R. - ICCU	21/01/2023
	Comp. Dt. : 27/01/2023							
	Status : Completed							
1246	23010953	ICCU	NEED TO CHECK PRINTER & CHANGE TONER	Shafiullah. R.	REFIX TONER		Ramya. V. - ICCU	27/01/2023
	Comp. Dt. : 15/02/2023							
	Status : Completed							
1247	23020571	ICCU	NEED TO CHANGE TONER	Balachandar. A.	TONER CHANGED		Kamali. S. - ICCU	15/02/2023
	Comp. Dt. : 10/03/2023							
	Status : Completed							
1248	23030397	ICCU	PRINTER NOT WORKING	Selvam. D.	printer working fine		Mohamed Salahuddeen. M. - ICCU	10/03/2023
1249	23030402	ICCU	PRINTER NOT WORKING	Selvam. D.	printer working fine		Mohamed Salahuddeen. M. - ICCU	10/03/2023
	Comp. Dt. : 15/03/2023							
	Status : Completed							
1250	23030609	ICU	NEED TO CHANGE TONER - ICU EXTN	Shafiullah. R.	12A TONER CHANGED		Ravivarma. P. - ICCU	15/03/2023
	Comp. Dt. : 31/03/2023							
	Status : Completed							
1251	23031344	ICCU	NEED TO CHANGE TONER	Jayaraj. J.	TONER WORKING NOT CHANGING		Saradha. G. - ICCU	31/03/2023
	Comp. Dt. : 03/04/2023							
	Status : Completed							
1252	23040042	ICCU	NEED TO CHANGE TONER	Shafiullah. R.	12A TONER CHANGED		Ammu. R. - ICCU	03/04/2023
	Comp. Dt. : 12/04/2023							


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
1253	23040368	ICCU	PRINTER NOT WORKING	Jayaraj. J.	printer working fine		Ammu. R. - ICCU	17/04/2023
Comp. Dt. : 17/04/2023								
Status : Completed								
1254	23040506	ICCU	PRINTER NOT WORKING	Selvam. D.	pending job cleared..		Ammu. R. - ICCU	18/04/2023
Comp. Dt. : 04/05/2023								
Status : Completed								
1255	23050134	ICCU	SYSTEM NOT WORKING	Shafiullah. R.	SYSTEM WORKING FINE		Hemasri. M. - ICCU	04/05/2023
Comp. Dt. : 12/05/2023								
Status : Completed								
1256	23050508	ICCU	PRINTER NOT WORKING	Selvam. D.	USB CABLE REFIXED		Ammu. R. - ICCU	12/05/2023
Comp. Dt. : 25/05/2023								
Status : Completed								
1257	23050982	ICCU	NEED TO CHANGE TONER	Madhubalan. S.	12A TONER CHANGED		Suriyakala. A. - ICCU	25/05/2023
Comp. Dt. : 26/06/2023								
Status : Completed								
1258	23060954	ICCU	NEED TO CHANGE TONER	Murugavel.R	12A toner changed		Ammu. R. - ICCU	26/06/2023
Dept Name : ICU - Computer Department								
Comp. Dt. : 04/07/2022								
Status : Completed								
1259	22070084	ICU	SYSTEM NOT WORKING	Selvam. D.	System Working		Latha. K. - ICU	04/07/2022
Comp. Dt. : 13/07/2022								
Status : Completed								
1260	22070509	ICU	NEED TO CHANGE TONER	Shafiullah. R.	12A TONER CHANGED		Chandra. S. - ICU	14/07/2022
Comp. Dt. : 10/08/2022								
Status : Completed								
1261	22080367	ICU	NEED TO CHANGE TONER	Madhubalan. S.	12A TONER CHANGED		Chandra. S. - ICU	10/08/2022
Comp. Dt. : 18/08/2022								
Status : Completed								
1262	22080584	ICU	PRINTER PROBLEM	Selvam. D.	Print queue cleared and tested the printer working fine		imala. S. P. - ICU	18/08/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 08/09/2022 Status : Completed								
1263	22090343	ICU	NEED TO CHANGE TONER	Shafiullah. R.	12ATONER CHANGED		Hemamalini. A. - ICU	09/09/2022
Comp. Dt. : 15/09/2022 Status : Completed								
1264	22090576	ICU	SYSTEM NOT WORKING	Shafiullah. R.	SYSTEM WORKING FINE		Regina Mary. S. - ICU	15/09/2022
Comp. Dt. : 01/10/2022 Status : Completed								
1265	22100001	ICU	NEED TO CHECK PRINTER - NOT WORKING	Selvam. D.	toner refixed		Regina Mary. S. - ICU	05/10/2022
Comp. Dt. : 04/11/2022 Status : Completed								
1266	22110146	ICU	PRINTER PAPER JAM	Selvam. D.	paper jam cleared		Uma Maheswari. A. - ICU	04/11/2022
Comp. Dt. : 08/11/2022 Status : Completed								
1267	22110303	ICU	SYSTEM NOT WORKING	Jayaraj. J.	SYSTEM RESTARTED		Regina Mary. S. - ICU	08/11/2022
Comp. Dt. : 26/12/2022 Status : Completed								
1268	22121181	ICU	PRINTER NOT WORKING	Balachandar. A.	PRINTER WORKING		Hemamalini. A. - ICU	27/12/2022
Comp. Dt. : 25/01/2023 Status : Completed								
1269	23010928	ICU	PRINTER NOT WORKING	Selvam. D.	printer working fine		Hemamalini. A. - ICU	27/01/2023
Comp. Dt. : 01/02/2023 Status : Completed								
1270	23020030	ICU	NEED TO CHANGE TONER	Madhubalan. S.	12A TONER CHANGED		Latha. K. - ICU	01/02/2023
Comp. Dt. : 11/05/2023 Status : Completed								
1271	23050429	ICU	PRINTER NOT WORKING	Madhubalan. S.	SETTING CHANGED WORKING FINE		Latha. K. - ICU	11/05/2023
Comp. Dt. : 12/05/2023 Status : Completed								
1272	23050490	Female Surgery - Ward 205	U P S NOT WORKING	Selvam. D.	lithium ups battery changed		Leela. R. - ICU	22/05/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Dept Name : Labour Ward - Computer Department Comp. Dt. : 11/05/2022 Status : Completed								
1273	22050383	Labour Room	NEED TO CHANGE PRINTER TONER	Madhubalan. S.	12A TONER CHANGED		Sathiyavathi. S. - Labour Ward	11/05/2022
Comp. Dt. : 30/05/2022 Status : Completed								
1274	22051108	labour room -pow	PRINTER NOT WORKING	Madhubalan. S.	PRINTER WORKING FINE		Thenmozhi. J. - Labour Ward	30/05/2022
Comp. Dt. : 02/06/2022 Status : Completed								
1275	22060056	labour room -pow	NEED TO CHANGE TONER	Shafiullah. R.	12A toner changed		Priyanka. R. - Labour Ward	02/06/2022
Comp. Dt. : 14/06/2022 Status : Completed								
1276	22060501	labour room -pow	PRINTER NOT WORKING	Shafiullah. R.	PRITNER QUEUE CLEAN		Sathiyavathi. S. - Labour Ward	14/06/2022
Comp. Dt. : 27/06/2022 Status : Completed								
1277	22060966	labour room -pow	NEED TO CHANGE TONER	Jayaraj. J.	12A TONER CHANGED		Priyanka. R. - Labour Ward	27/06/2022
Comp. Dt. : 21/07/2022 Status : Completed								
1278	22070801	labour room -pow	NEED TO CHANGE TONER	Selvam. D.	12A toner changed		Thenmozhi. J. - Labour Ward	21/07/2022
Comp. Dt. : 30/07/2022 Status : Completed								
1279	22071088	Labour Room	PRINTER NOT WORKING - NEED URGENT SERVICE	Shafiullah. R.	printe queue clear		Thenmozhi. J. - Labour Ward	30/07/2022
Comp. Dt. : 06/08/2022 Status : Completed								
1280	22080223	Labour Room	PRINTER NOT WORKING	Selvam. D.	Print queue cleared and tested the printer working fine		Sathiyavathi. S. - Labour Ward	06/08/2022
Comp. Dt. : 24/08/2022 Status : Completed								
1281	22080787	labour room -pow	NEED TO CHANGE TONER	Shafiullah. R.	12A TONER CHANGED		Priyanka. R. - Labour Ward	24/08/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 03/09/2022								
Status : Completed								
1282	22090124	labour room -pow	NEED TO CHANGE TONER	Jayaraj. J.	12A toner changed		Iyshwariya. M. - Labour Ward	03/09/2022
Comp. Dt. : 08/09/2022								
Status : Completed								
1283	22090332	labour room -pow	PRINTER NOT WORKING	Selvam. D.	Printer working fine		Priyanka. R. - Labour Ward	08/09/2022
Comp. Dt. : 10/09/2022								
Status : Completed								
1284	22090389	labour room -pow	PRINTER NOT WORKING	Jayaraj. J.	pending job cleared..		Priyanka. R. - Labour Ward	12/09/2022
Comp. Dt. : 30/09/2022								
Status : Completed								
1285	22091208	labour room -pow	NEED TO CHANGE TONER	Madhubalan. S.	12A TONER CHANGED		Jayapriya. D. - Labour Ward	30/09/2022
Comp. Dt. : 02/11/2022								
Status : Completed								
1286	22110038	labour room -pow	PRINTER NOT WORKING	Selvam. D.	12A toner changed		Priyanka. R. - Labour Ward	03/11/2022
Comp. Dt. : 09/11/2022								
Status : Completed								
1287	22110321	labour room -pow	PRINTER NOT WORKING	Selvam. D.	print queue cleared		Brema. V. - Labour Ward	10/11/2022
Comp. Dt. : 24/11/2022								
Status : Completed								
1288	22111060	Labour Room	PRINTER NOT WORKING	Selvam. D.	PRINTER WORKING		Kanimozhi. S. - Labour Ward	25/11/2022
Comp. Dt. : 26/11/2022								
Status : Completed								
1289	22111134	labour room -pow	PRINTER NOT WORKING	Selvam. D.	PRINTER WORKING		Brema. V. - Labour Ward	28/11/2022
Comp. Dt. : 06/12/2022								
Status : Completed								
1290	22120225	labour room -pow	PRINTER NOT WORKING	Madhubalan. S.	PRINTER WORKING FINE		Santhiya. A. - Labour Ward	06/12/2022
Comp. Dt. : 08/12/2022								
Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1291	22120355	labour room -pow	CHANGE PRINTER TONER	Jayaraj. J.	PRINTER TONER CHANGED		Iyshwariya. M. - Labour Ward	08/12/2022
	Comp. Dt. : 09/12/2022							
	Status : Completed							
1292	22120407	Labour Room	PRINTER NOT WORKING	Prakash. P.	printer working fine		Santhiya. A. - Labour Ward	13/12/2022
	Comp. Dt. : 27/12/2022							
	Status : Completed							
1293	22121213	labour room -pow	SYSTEM SOFTWARE UPDATION NEED TO DO	Shafiullah. R.	MEDPLUS UPDATE 13-12-2022		Brema. V. - Labour Ward	27/12/2022
	Comp. Dt. : 10/01/2023							
	Status : Completed							
1294	23010383	labour room -pow	PRINTER NOT WORKING	Jayaraj. J.	PRINTER SETTING CHANGED		Priyanka. R. - Labour Ward	10/01/2023
	Comp. Dt. : 18/01/2023							
	Status : Completed							
1295	23010607	Labour Room	PRINTER NOT WORKING	Madhubalan. S.	SYSTEM RESTATE PRINTER WORKING FINE		Brema. V. - Labour Ward	18/01/2023
	Comp. Dt. : 19/01/2023							
	Status : Completed							
1296	23010651	labour room -pow	NEED TO CHANGE TONER	Madhubalan. S.	12A TONER CHANGED		Brema. V. - Labour Ward	19/01/2023
	Comp. Dt. : 17/02/2023							
	Status : Completed							
1297	23020704	Labour Room	NEED TO CHANGE TONER	Shafiullah. R.	12A TONER CHANGED		Sathiyavathi. S. - Labour Ward	17/02/2023
	Comp. Dt. : 21/02/2023							
	Status : Completed							
1298	23020782	Labour Room	PRINTER NOT WORKING	Shafiullah. R.	papper jam clear printer working fine		Iyshwariya. M. - Labour Ward	21/02/2023
	Comp. Dt. : 10/03/2023							
	Status : Completed							
1299	23030386	Labour Room	PRINTER NOT WORKING	Selvam. D.	12A toner changed		Brema. V. - Labour Ward	10/03/2023
	Comp. Dt. : 20/04/2023							
	Status : Completed							
1300	23040656	labour room -pow	NEED TO CHANGE TONER	Shafiullah. R.	REFIX THE TONER		Brema. V. - Labour Ward	20/04/2023

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 24/04/2023 Status : Completed								
1301	23040716	labour room -pow	NEED TO CHANGE TONER	Harikrishnan. R.	12A Toner Changed.		Priyanka. R. - Labour Ward	24/04/2023
Comp. Dt. : 02/05/2023 Status : Completed								
1302	23050048	labour room -pow	NEED TO CHANGE TONER	Harikrishnan. R.	12a TONER CHANGED.		Priyanka. R. - Labour Ward	02/05/2023
Comp. Dt. : 03/06/2023 Status : Completed								
1303	23060086	Labour Room	NEED TO CHANGE TONER	Harikrishnan. R.	12A Toner Changed.		Sathiyavathi. S. - Labour Ward	03/06/2023
Dept Name : Male Medical Ward - Computer Department Comp. Dt. : 04/05/2022 Status : Completed								
1304	22050069	Male Medical - Ward 304	PRINTER NOT WORKING	Selvam. D.	printer working		Vijayalakshmi. S. - Male Medical Ward	04/05/2022
Comp. Dt. : 05/05/2022 Status : Completed								
1305	22050159	Male Medical - Ward 303	MOUSE NOT WORKING	Jayaraj. J.	NEW PS2 MOUSE CHANGED		Vijayalakshmi. S. - Male Medical Ward	06/05/2022
Comp. Dt. : 14/05/2022 Status : Completed								
1306	22050500	Male Medical - Ward 301	NEED TO CHANGE PRINTER TONER	Selvam. D.	PRINTER TONER CHANGED		Yugapriya. M. - Male Medical Ward	17/05/2022
Comp. Dt. : 30/05/2022 Status : Completed								
1307	22051074	Male Medical Ward	SYSTEM NOT WORKING BOTH 301 & 302 WARD	Selvam. D.	Electrical issue solved. Tested the system working fine		Soniya Gandhi. A. - Male Medical Ward	31/05/2022
Comp. Dt. : 16/06/2022 Status : Completed								
1308	22060598	Male Medical - Ward 302	SYSTEM NOT WORKING	Balachandar. A.	checked working fine..		Soniya Gandhi. A. - Male Medical Ward	16/06/2022
Comp. Dt. : 23/06/2022 Status : Completed								
1309	22060825	Male Medical - Ward 301	NEED TO CHANGE TONER	Prakash. P.	TONER CHANGED		Kanmani. R. - Male Medical Ward	23/06/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 02/08/2022								
Status : Completed								
1310	22080101	Male Medical - Ward 301	PRINTER NOT WORKING	Selvam. D.	Printer working fine		Soniya Gandhi. A. - Male Medical Ward	03/08/2022
Comp. Dt. : 30/08/2022								
Status : Completed								
1311	22081036	Male Medical - Ward 301	NEED TO CHANGE TONER	Balachandar. A.	TONER CHANGED		Soniya Gandhi. A. - Male Medical Ward	30/08/2022
Comp. Dt. : 27/09/2022								
Status : Completed								
1312	22091046	Male Medical - Ward 301	NEED TO CHANGE TONER & ALSO PRINTER NOT WORKING	Madhubalan. S.	TONER CHANGED		Kanmani. R. - Male Medical Ward	27/09/2022
Comp. Dt. : 22/11/2022								
Status : Completed								
1313	22110912	Male Medical - Ward 301	NEED TO CHANGE TONER	Balachandar. A.	TONER CHANGED		Kanmani. R. - Male Medical Ward	22/11/2022
Comp. Dt. : 23/12/2022								
Status : Completed								
1314	22121046	Male Medical - Ward 301	NEED TO CHANGE TONER	Madhubalan. S.	12A TONER CHANGED		Kanmani. R. - Male Medical Ward	23/12/2022
1315	22121059	Male Medical - Ward 302	MOUSE NOT WORKING	Madhubalan. S.	USB CABLE REFIXED WORKING		Soniya Gandhi. A. - Male Medical Ward	23/12/2022
1316	22121082	Male Medical - Ward 304	NEED TO CHANGE PRINTER TONER	Shafiullah. R.	12A TONER CHANGED		Soniya Gandhi. A. - Male Medical Ward	23/12/2022
Comp. Dt. : 31/12/2022								
Status : Completed								
1317	22121384	Male Medical - Ward 303	PRINTER NOT WORKING	Shafiullah. R.	Paper jam cleared and general service done		Gowri. P. - Male Medical Ward	02/01/2023
Comp. Dt. : 11/01/2023								
Status : Completed								
1318	23010482	Male Medical - Ward 301	CHANGE PRINTER TONER	Selvam. D.	12A toner changed		Soniya Gandhi. A. - Male Medical Ward	11/01/2023
Comp. Dt. : 23/02/2023								
Status : Completed								
1319	23020880	Male Medical - Ward 303	SYSTEM NOT WORKING	Selvam. D.	Background setting changed		Vijayalakshmi. S. - Male Medical Ward	23/02/2023
Comp. Dt. : 20/03/2023								
Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1320	23030792	Male Medical - Ward 303	MOUSE NOT WORKING	Harikrishnan. R.	New ps/2 mouse changed..		Vijayalakshmi. S. - Male Medical Ward	22/03/2023
1321	23030795	Male Medical - Ward 301	NEED TO CHANGE TONER	Harikrishnan. R.	12a toner changed		Soniya Gandhi. A. - Male Medical Ward	20/03/2023
Comp. Dt. : 13/04/2023 Status : Completed								
1322	23040394	Male Medical - Ward 301	NEED TO CHANGE TONER	Selvam. D.	12a toner changed		Soniya Gandhi. A. - Male Medical Ward	13/04/2023
Comp. Dt. : 08/06/2023 Status : Completed								
1323	23060285	Male Medical - Ward 301	NEED TO CHANGE TONER	Shafiullah. R.	12A TONER CHANGED		Soniya Gandhi. A. - Male Medical Ward	08/06/2023
Comp. Dt. : 22/06/2023 Status : Completed								
1324	23060833	Male Medical - Ward 301	PRINTER NOT WORKING	Shafiullah. R.	printer paper jam cleared		Geedhanjali. I - Male Medical Ward	26/06/2023
Comp. Dt. : 24/06/2023 Status : Completed								
1325	23060900	Male Medical - Ward 301	PRINTER NOT WORKING	Selvam. D.	printer pickup roller cleared and solinod swioch serviced		Karthikeyan. I. - Male Medical Ward	26/06/2023
Comp. Dt. : 28/06/2023 Status : Completed								
1326	23061046	Male Medical - Ward 301	PRINTER NOT WORKING	Selvam. D.	USB cable refixed		Kanmani. R. - Male Medical Ward	28/06/2023
Dept Name : Male Ortho Ward - Computer Department Comp. Dt. : 10/05/2022 Status : Completed								
1327	22050329	Female Ortho - Ward 402	NEED TO CHECK PRINTER & CHANGE TONER	Madhubalan. S.	12A TONER CHANGED		Anbuselvi. P. - Female Ortho Ward	10/05/2022
Comp. Dt. : 08/06/2022 Status : Completed								
1328	22060283	TB AND CHEST WARD-405	PRINTER NOT WORKING	Balachandar. A.	printer top cover serviced		Saranya. M. - Derm,Pulmo,Psych Ward	17/06/2022
1329	22060306	Male Ortho - Ward 404	SYSTEM NOT WORKING	Jayaraj. J.	NETWORK SWICTH RESTARTED		Rajasree. R. - Male Ortho Ward	08/06/2022
Comp. Dt. : 15/06/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1330	22060554	Male Ortho - Ward 403	NEED TO CHANGE TONER	Balachandar. A.	TONER CHANGED		Rajasree. R. - Male Ortho Ward	15/06/2022
	Comp. Dt. : 16/07/2022							
	Status : Completed							
1331	22070622	Paediatrics - Ward 308	NEED TO CHANGE TONER	Selvam. D.	toner changed		Saranya. M. - Derm,Pulmo,Psych Ward	18/07/2022
	Comp. Dt. : 25/07/2022							
	Status : Completed							
1332	22070914	Male Ortho - Ward 404	SYSTEM NOT WORKING	Selvam. D.	Domain reconfigure done		Rajasree. R. - Male Ortho Ward	25/07/2022
	Comp. Dt. : 02/08/2022							
	Status : Completed							
1333	22080092	Male Ortho - Ward 403	SYSTEM NOT WORKING	Selvam. D.	Power Tripped and solved tested working fine		Sandhiya. L. - Male Ortho Ward	03/08/2022
	Comp. Dt. : 03/08/2022							
	Status : Completed							
1334	22080119	Male Ortho - Ward 403	NEED TO CHANGE TONER	Selvam. D.	12A toner changed		Rajasree. R. - Male Ortho Ward	03/08/2022
	Comp. Dt. : 12/08/2022							
	Status : Completed							
1335	22080446	Male Ortho - Ward 404	SYSTEM NOT WORKING	Shafiullah. R.	RESTART AND TEMP CLEAN		Rajasree. R. - Male Ortho Ward	12/08/2022
	Comp. Dt. : 13/08/2022							
	Status : Completed							
1336	22080467	Male Ortho - Ward 404	SYSTEM [2 NOS] NOT WORKING	Balachandar. A.	POWER CABLE REFIXED		Rajasree. R. - Male Ortho Ward	13/08/2022
	Comp. Dt. : 01/09/2022							
	Status : Completed							
1337	22090036	Male Ortho - Ward 403	PRINTER NOT WORKING	Madhubalan. S.	PRINTER POWER CABLE REFIXED		Rajasree. R. - Male Ortho Ward	01/09/2022
	Comp. Dt. : 02/09/2022							
	Status : Completed							
1338	22090068	Male Ortho - Ward 404	PRINTER NOT WORKING	Madhubalan. S.	TONER REFIXED WORKING FINE		Rajasree. R. - Male Ortho Ward	02/09/2022
	Comp. Dt. : 07/09/2022							
	Status : Completed							
1339	22090284	Male Ortho - Ward 404	PRINTER NOT WORKING	Selvam. D.	TONER REFIXED		Jenit Jerlin. D. - Male Ortho Ward	08/09/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 15/09/2022								
Status : Completed								
1340	22090585	Male Ortho - Ward 403	SYSTEM NOT WORKING	Selvam. D.	Network cable refixed		Jenit Jerlin. D. - Male Ortho Ward	15/09/2022
Comp. Dt. : 17/09/2022								
Status : Completed								
1341	22090679	Male Ortho - Ward 403	SYSTEM NET WORK FAILURE	Shafiullah. R.	REFIX PATCH CARD		Gayathri. R. - Male Ortho Ward	17/09/2022
Comp. Dt. : 28/09/2022								
Status : Completed								
1342	22091131	Male Ortho - Ward 403	SYSTEM & PRINTER NOT WORKING	Madhubalan. S.	TONER REFIXED WORKING FINE		Rajasree. R. - Male Ortho Ward	28/09/2022
Comp. Dt. : 29/09/2022								
Status : Completed								
1343	22091180	Male Ortho - Ward 403	NEED TO CHANGE TONER	Selvam. D.	TONER CHANGED		Maheswari. J. - Male Ortho Ward	30/09/2022
Comp. Dt. : 15/10/2022								
Status : Completed								
1344	22100482	Male Ortho - Ward 403	SYSTEM NOT WORKING	Shafiullah. R.	SAME COMPLAINE		Gayathri. S. - Male Ortho Ward	17/10/2022
1345	22100501	Male Ortho - Ward 403	SYSTEM NOT WORKING	Shafiullah. R.	NO POWER FOR SYSTEM		Gayathri. S. - Male Ortho Ward	17/10/2022
Comp. Dt. : 20/10/2022								
Status : Completed								
1346	22100680	Male Ortho - Ward 404	SYSTEM NOT WORKING	Balachandar. A.	MOUSE CHANGED		Manikandan. V. - Male Ortho Ward	20/10/2022
Comp. Dt. : 26/10/2022								
Status : Completed								
1347	22100818	Male Ortho - Ward 403	CHANGE PRINTER TONER	Madhubalan. S.	12A TONER CHANGED		Rajasree. R. - Male Ortho Ward	26/10/2022
Comp. Dt. : 25/11/2022								
Status : Completed								
1348	22111119	Male Ortho - Ward 403	PRENTER PROBLEM PAPPER JAM	Selvam. D.	PAPER JAM CLEARED		Maheswari. J. - Male Ortho Ward	25/11/2022
Comp. Dt. : 05/12/2022								
Status : Completed								
1349	22120194	Paediatrics - Ward 309	CHANGE PRINTER TONER	Shafiullah. R.	PRINT WORKING		Rajasree. R. - Male Ortho Ward	05/12/2022

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 09/12/2022 Status : Completed								
1350	22120448	Male Ortho - Ward 403	PRINTER NOT WORKING	Prakash. P.	printer working		Rajasree. R. - Male Ortho Ward	16/12/2022
Comp. Dt. : 13/12/2022 Status : Completed								
1351	22120607	Male Ortho - Ward 403	SYSTEM NOT WORKING	Shafiullah. R.	SYSTEM WORKING FINE		Rajasree. R. - Male Ortho Ward	15/12/2022
Comp. Dt. : 21/12/2022 Status : Completed								
1352	22120972	Male Ortho - Ward 403	SYSTEM NOT WORKING	Madhubalan. S.	SYSTEM WORKING FINE		Rajasree. R. - Male Ortho Ward	21/12/2022
Comp. Dt. : 23/12/2022 Status : Completed								
1353	22121096	Male Ortho - Ward 403	SYSTEM DISCONNECTING WORK	Shafiullah. R.	REFIX SYSTEM		Rajasree. R. - Male Ortho Ward	23/12/2022
Comp. Dt. : 04/01/2023 Status : Completed								
1354	23010187	Male Ortho - Ward 404	PRINTER NOT WORKING	Selvam. D.	Paper sensor cleaned and refixed		Manjula. P. - Male Ortho Ward	05/01/2023
Comp. Dt. : 06/01/2023 Status : Completed								
1355	23010284	Male Ortho - Ward 403	PRINTER NOT WORKING	Madhubalan. S.	12A TONER CHANGED		Rajasree. R. - Male Ortho Ward	06/01/2023
Comp. Dt. : 27/01/2023 Status : Completed								
1356	23010963	Male Ortho - Ward 404	SYSTEM NO POWER ON	Shafiullah. R.	UPS POWER SUPPLY A.C POWER CHANGED		Maheswari. J. - Male Ortho Ward	27/01/2023
Comp. Dt. : 09/02/2023 Status : Completed								
1357	23020313	Male Ortho - Ward 403	SYSTEM & PRINTER NOT WORKING	Shafiullah. R.	SYSTEM AND PRINTER WORKING		Sandhiya. L. - Male Ortho Ward	09/02/2023
Comp. Dt. : 16/02/2023 Status : Completed								
1358	23020638	Male Ortho - Ward 403	NEED TO CHANGE PRINTER TONER	Madhubalan. S.	12A Toner Changed	 Dr. KAGNE. R.N DEAN SRI MANAKULA VINAYAGAR MEDICAL COLLEGE & HOSPITAL KALITHEERTHALKUPPAM, PUDUCHERRY-605107.	Manjula. P. - Male Ortho Ward	16/02/2023
1359	23020656	Male Ortho - Ward 403	NEED TO CHANGE PRINTER TONER	Madhubalan. S.	12A Toner Changed		Maheswari. J. - Male Ortho Ward	16/02/2023
Comp. Dt. : 23/02/2023								

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
	Status : Completed							
1360	23020882	Male Ortho - Ward 403	SYSTEM NET PROBLEM	Selvam. D.	NETWORK WORKING		Maheswari. J. - Male Ortho Ward	23/02/2023
	Comp. Dt. : 25/02/2023							
	Status : Completed							
1361	23020970	Male Ortho - Ward 403	PROBLEM IN SYSTEM	Selvam. D.	RJ45 jack crimped		Maheswari. J. - Male Ortho Ward	25/02/2023
	Comp. Dt. : 08/03/2023							
	Status : Completed							
1362	23030320	Male Ortho - Ward 404	SYSTEM NOT WORKING	Shafiullah. R.	REFIX THE POWER CABLE		Rajasree. R. - Male Ortho Ward	08/03/2023
	Comp. Dt. : 28/03/2023							
	Status : Completed							
1363	23031216	Male Ortho Ward	SYSTEM NETWORK FAILURE	Shafiullah. R.	switch power off		Manjula. P. - Male Ortho Ward	29/03/2023
	Comp. Dt. : 16/04/2023							
	Status : Completed							
1364	23040475	Male Ortho - Ward 403	NEED TO CHANGE TONER	Harikrishnan. R.	TONER CHANGED		Maheswari. J. - Male Ortho Ward	17/04/2023
	Comp. Dt. : 17/04/2023							
	Status : Completed							
1365	23040516	Male Ortho - Ward 403	NEED TO CHANGE TONER	Shafiullah. R.	TONER CHANGED		Rajasree. R. - Male Ortho Ward	18/04/2023
	Comp. Dt. : 02/05/2023							
	Status : Completed							
1366	23050037	Male Ortho - Ward 403	PRINTER NOT WORKING	Shafiullah. R.	printer working system hange power off and on working system		Rajasree. R. - Male Ortho Ward	02/05/2023
	Comp. Dt. : 15/05/2023							
	Status : Completed							
1367	23050586	Male Ortho - Ward 403	PRINTER NOT WORKING	Shafiullah. R.	PRINTER FUSER CLEAN AND FIX		Gayathri. S. - Male Ortho Ward	16/05/2023
	Comp. Dt. : 09/06/2023							
	Status : Completed							
1368	23060317	Male Ortho - Ward 403	SYSTEM NOT WORKING	Balachandar. A.	Network cable refixed..		Manjula. P. - Male Ortho Ward	09/06/2023
	Comp. Dt. : 17/06/2023							
	Status : Completed							


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1369	23060627	Male Ortho - Ward 403	PRINTER NOT WORKING	Shafiullah. R.	toner refixed		Maheswari. J. - Male Ortho Ward	17/06/2023
Comp. Dt. : 27/06/2023 Status : Completed								
1370	23061001	Male Ortho - Ward 403	SYSTEM NOT WORKING	Selvam. D.	network cable refixed		Manjula. P. - Male Ortho Ward	28/06/2023
Dept Name : Male Surgery - Computer Department Comp. Dt. : 12/05/2022 Status : Completed								
1371	22050408	Female Surgery - Ward 206	PRINTER PROBLEM	Selvam. D.	set as default printer		Saranya. V. - Female Surgery	12/05/2022
Comp. Dt. : 16/05/2022 Status : Completed								
1372	22050541	Male Surgery - Ward 201	PRINTER NOT WORKING	Shafiullah. R.	REFIX 12A TONER CHANGED		Sarmila. M. - Female Surgery	16/05/2022
Comp. Dt. : 17/05/2022 Status : Completed								
1373	22050609	Male Surgery - Ward 201	NEED TO CHANGE TONER	Selvam. D.	12A TONER CHANGED		Sugumari. M. - Male Surgery	18/05/2022
Comp. Dt. : 03/06/2022 Status : Completed								
1374	22060122	Male Surgery - Ward 201	PRINTER NOT WORKING	Jayaraj. J.	printer driver reinstalled		Kanimozhi. N - Male Surgery	06/06/2022
Comp. Dt. : 11/06/2022 Status : Completed								
1375	22060428	Male Surgery - Ward 201	PRINTER NOT WORKING	Shafiullah. R.	printer working fine		Sarmila. M. - Female Surgery	16/06/2022
Comp. Dt. : 28/06/2022 Status : Completed								
1376	22060986	Male Surgery - Ward 201	PRINTER NOT WORKING - NEED URGENT SERVICE	Balachandar. A.	Printer working fine		Malathy. S - Male Surgery	30/06/2022
Comp. Dt. : 08/07/2022 Status : Completed								
1377	22070335	Male Surgery - Ward 202	SYSTEM NOT WORKING	Jayaraj. J.	SYSTEM RESTARTED		Sarmila. M. - Female Surgery	08/07/2022
Comp. Dt. : 09/07/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1378	22070374	Female Surgery - Ward 206	SYSTEM NOT WORKING	Shafiullah. R.	RESTATRTED COMPLETED		Vaidegi. S. - Female Surgery	14/07/2022
	Comp. Dt. : 15/07/2022							
	Status : Completed							
1379	22070610	Male Surgery - Ward 201	NEED TO CHANGE TONER	Madhubalan. S.	12A TONER CHANGED		Malathy. S - Male Surgery	15/07/2022
	Comp. Dt. : 19/08/2022							
	Status : Completed							
1380	22080637	Male Surgery - Ward 201	CHANGE PRINTER TONER	Jayaraj. J.	PRINTER TONER CHANGED..		Malathy. S - Male Surgery	20/08/2022
	Comp. Dt. : 26/08/2022							
	Status : Completed							
1381	22080888	Male Surgery - Ward 201	PRINTER NOT WORKING	Shafiullah. R.	PRINTER QUEUE CLEAN		Kanimozhi. N - Male Surgery	26/08/2022
	Comp. Dt. : 06/09/2022							
	Status : Completed							
1382	22090228	Male Surgery - Ward 201	PRINTER NOT WORKING	Selvam. D.	Printer working fine		Sarmila. M. - Female Surgery	06/09/2022
	Comp. Dt. : 08/09/2022							
	Status : Completed							
1383	22090298	Male Surgery - Ward 201	PRINTER & SYSTEM NOT WORKING	Jayaraj. J.	Patch cable refixed		Sarmila. M. - Female Surgery	08/09/2022
	Comp. Dt. : 23/09/2022							
	Status : Completed							
1384	22090918	Male Surgery - Ward 202	PRINTER NOT WORKING	Shafiullah. R.	PRINTER WORKING NETWORK REFIX PATCH CARD		Sasikala. A. - Male Surgery	23/09/2022
	Comp. Dt. : 28/09/2022							
	Status : Completed							
1385	22091102	Male Surgery - Ward 201	PRINTER NOT WORKING	Valamburi. R.	paper jam cleared		Sarmila. M. - Female Surgery	29/09/2022
	Comp. Dt. : 30/09/2022							
	Status : Completed							
1386	22091193	Male Surgery - Ward 202	SYSTEM NOT WORKING - POWER PROBLEM	Selvam. D.	system working fine		Sarmila. M. - Female Surgery	30/09/2022
	Comp. Dt. : 05/10/2022							
	Status : Completed							
1387	22100046	Male Surgery - Ward 201	PRINTER NOT WORKING	Shafiullah. R.	RESTART SYSTEM PRINTER WORKING		Sarmila. M. - Female Surgery	05/10/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
	Comp. Dt. : 06/10/2022							
	Status : Completed							
1388	22100113	Male Surgery - Ward 201	PRINTER NOT WORKING	Selvam. D.	printer working fine		Sugumari. M. - Male Surgery	07/10/2022
	Comp. Dt. : 14/10/2022							
	Status : Completed							
1389	22100453	Male Surgery - Ward 201	NEED TO CHANGE TONER	Shafiullah. R.	12A TONER CHANGED		Malathy. S - Male Surgery	14/10/2022
	Comp. Dt. : 26/10/2022							
	Status : Completed							
1390	22100812	Male Surgery - Ward 204	SYSTEM NOT WORKING	Madhubalan. S.	SYSTEM RAM REFIXED WORKING FINE		Sasikala. A. - Male Surgery	26/10/2022
	Comp. Dt. : 18/11/2022							
	Status : Completed							
1391	22110791	Male Surgery - Ward 202	NEED TO CHECK SYSTEM - NOT WORKING	Shafiullah. R.	SYSTEM WORKING FINE		Ananthi. S. - Male Surgery	18/11/2022
	Comp. Dt. : 21/11/2022							
	Status : Completed							
1392	22110870	Male Surgery - Ward 202	SYSTEM NOT WORKING	Selvam. D.	System restarted		Ananthi. S. - Male Surgery	21/11/2022
	Comp. Dt. : 12/12/2022							
	Status : Completed							
1393	22120501	Female Surgery - Ward 205	CPU NOT WORKING	Jayaraj. J.	ram refixed and dust cleaned..		Ezhilarasi. E. - Male Surgery	21/12/2022
	Comp. Dt. : 06/02/2023							
	Status : Completed							
1394	23020150	Male Surgery - Ward 202	NEED TO CHANGE PRINTER TONER	Selvam. D.	12A toner chagned		Malathy. S - Male Surgery	06/02/2023
	Comp. Dt. : 16/02/2023							
	Status : Completed							
1395	23020637	Male Surgery - Ward 201	SYSTEM NOT WORKING	Madhubalan. S.	System Restarted Working Fine		Sarmila. M. - Female Surgery	16/02/2023
	Comp. Dt. : 30/03/2023							
	Status : Completed							
1396	23031326	Male Surgery - Ward 204	NEED TO CHANGE TONER	Jayaraj. J.	TONER WORKING NOT CHANGING		Mahalakshmi. L. - Male Surgery	31/03/2023
	Comp. Dt. : 05/04/2023							
	Status : Completed							


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1397	23040144	Male Surgery - Ward 202	PRINTER NOT WORKING	Shafiullah. R.	REINSTALL THE PRINTER DRIVE		Sangeedha. M. - Male Surgery	05/04/2023
	Comp. Dt. : 25/04/2023							
	Status : Completed							
1398	23040795	Male Medical - Ward 303	MONITOR NOT WORKING	Harikrishnan. R.	compilan shifted to bio medical crt monitor		Mahalakshmi. L. - Male Surgery	25/04/2023
	Comp. Dt. : 04/05/2023							
	Status : Completed							
1399	23050157	Male Surgery - Ward 201	NEED TO REFIL COLOUR INK FOR PRINTER	Harikrishnan. R.	12A Toner Changed		Malathy. S - Male Surgery	04/05/2023
	Comp. Dt. : 25/05/2023							
	Status : Completed							
1400	23050981	Male Surgery - Ward 202	SYSTEM NOT WORKING	Selvam. D.	patch cable refixed		Kanimozhi. N - Male Surgery	25/05/2023
	Comp. Dt. : 02/06/2023							
	Status : Completed							
1401	23060068	Male Surgery - Ward 202	SYSTEM NOT WORKING - PROBLEM IN WARD DOCUMENT	Balachandar. A.	files identified and recovered.		Sasikala. A. - Male Surgery	02/06/2023
	Comp. Dt. : 12/06/2023							
	Status : Completed							
1402	23060378	Male Surgery - Ward 201	SYSTEM NOT WORKING	Shafiullah. R.	SYSTEM WORKING FINE MS WORD WORKING		Sivasankari. T. - Male Surgery	12/06/2023
	Comp. Dt. : 27/06/2023							
	Status : Completed							
1403	23060998	Male Surgery - Ward 202	NEED TO CHANGE TONER	Selvam. D.	12A TONER CHANGED		Sasikala. A. - Male Surgery	27/06/2023
	Dept Name : Management - Chairman - Computer Department							
	Comp. Dt. : 29/05/2023							
	Status : Completed							
1404	23051165*	Female Surgery - Ward 206	NEED TO CHANGE TONER		12A toner changed		Pushpa - Management - Chairman	29/05/2023
	Dept Name : Marketing Team - Computer Department							
	Comp. Dt. : 31/05/2022							
	Status : Completed							
1405	22051123	Reception	SYSTEM NOT WORKING - REVISIT COUNTER	Shafiullah. R.	SYSTEM WORKING FINE		Gathiya Priya. J. - Marketing Team	31/05/2022

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 03/06/2022 Status : Completed								
1406	22060137	IVF ART CLINIC-INSIDE OF OG OPD(NO.68)	UPS DISPLAY " LOW BATTERY"	Shafiullah. R.	ELECTRICAL PROBLEM		Sathiya. M. - Marketing Team	03/06/2022
Comp. Dt. : 01/07/2022 Status : Completed								
1407	22070039	Reception	NEED TO CHECK LAPTOP - PRINTER CONNECTION - CC COUNTER	Balachandar. A.	PRINTER SHARED		Sathiya Priya. J. - Marketing Team	01/07/2022
Comp. Dt. : 02/07/2022 Status : Completed								
1408	22070052	IVF ART CLINIC-INSIDE OF OG OPD(NO.68)	NEED TO CHANGE BARCODE STRICKER	Balachandar. A.	NEW STICKER CHANGED		Sathiya. M. - Marketing Team	02/07/2022
Comp. Dt. : 13/07/2022 Status : Completed								
1409	22070512	IVF ART CLINIC-INSIDE OF OG OPD(NO.68)	SYSTEM NOT WORKING - NEED URGENT SERVICE	Balachandar. A.	POWER CABLE REFIXED		Sathiya. M. - Marketing Team	14/07/2022
Comp. Dt. : 14/07/2022 Status : Completed								
1410	22070531	IVF ART CLINIC-INSIDE OF OG OPD(NO.68)	SYSTEM NOT WORKING	Balachandar. A.	POwer Cable Refixed		Sathiya. M. - Marketing Team	14/07/2022
Comp. Dt. : 27/07/2022 Status : Completed								
1411	22071036	Special Ward - C	NEED TO CHANGE TONER	Jayaraj. J.	12A TONER CHANGED		Dhanalakshmi. D. - Marketing Team	27/07/2022
Comp. Dt. : 25/08/2022 Status : Completed								
1412	22080856	FEVER CLINIC	NEED TO CHANGE TONER	Shafiullah. R.	12A TONER CHANGED		Amirtharaj. A. - Marketing Team	25/08/2022
Comp. Dt. : 13/09/2022 Status : Completed								
1413	22090475	IVF ART CLINIC-INSIDE OF OG OPD(NO.68)	PRINTER NOT WORKING	Selvam. D.	USB cable refixed		Dhanalakshmi. D. - Marketing Team	13/09/2022
Comp. Dt. : 24/09/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1414	22090966	Reception	NEED TO CHECK LAPTOP - NOT WORKING	Selvam. D.	alternate laptop given		Sathiya Priya. J. - Marketing Team	29/09/2022
	Comp. Dt. : 01/10/2022							
	Status : Completed							
1415	22100007	Chairman Office	SYSTEM NOT WORKING	Selvam. D.	system restrated		Priya. A. - Marketing Team	05/10/2022
	Comp. Dt. : 10/10/2022							
	Status : Completed							
1416	22100259	FEVER CLINIC	PRINTER - PAPER JAM	Shafiullah. R.	Paper jam cleared		Amirtharaj. A. - Marketing Team	10/10/2022
	Comp. Dt. : 15/10/2022							
	Status : Completed							
1417	22100492	Reception	LAPTOP NOT WORKING	Shafiullah. R.	LAPTOP WORKING FINE		Sathiya Priya. J. - Marketing Team	17/10/2022
	Comp. Dt. : 20/10/2022							
	Status : Completed							
1418	22100699	Chairman Office	PRINTER NOT WORKING	Selvam. D.	SYSTEM RESTART PRINTER WORKING		Priya. A. - Marketing Team	20/10/2022
	Comp. Dt. : 22/10/2022							
	Status : Completed							
1419	22100755	Chairman Office	NEED TO CHANGE PRINTER TONER	Shafiullah. R.	DOBULE COMPLAIN		Priya. A. - Marketing Team	22/10/2022
	Comp. Dt. : 02/11/2022							
	Status : Completed							
1420	22110031	CUSTOMER CARE EXECUTIVE-RECEPTIO N	IN SYSTEM DATE SETUP NEED TO BE CHANGE	Madhubalan. S.	Date and time changed		Sathiya Priya. J. - Marketing Team	03/11/2022
	Comp. Dt. : 05/11/2022							
	Status : Completed							
1421	22110176	IVF ART CLINIC-INSIDE OF OG OPD(NO.68)	BARCODE PRINTER PROBLEM	Selvam. D.	barcode ribbon changed		Sathiya. M. - Marketing Team	05/11/2022
	Comp. Dt. : 08/11/2022							
	Status : Completed							
1422	22110276	Reception	MEDPLUS SOFTWARE NEED TO BE UPDATED IN COUNTER NO.1	Shafiullah. R.	MEDPLUS WORKING FINE		Sathiya Priya. J. - Marketing Team	08/11/2022
	Comp. Dt. : 10/11/2022							
	Status : Completed							


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1423	22110417	CUSTOMER CARE EXECUTIVE-RECEPTION	LAPTOP KEYPAD ALIGNMENT ISSUE	Jayaraj. J.	KEYBOARD CLEANED AND SYSTEM RESTARED		Sathiya Priya. J. - Marketing Team	10/11/2022
	Comp. Dt. : 19/11/2022 Status : Completed							
1424	22110831	Chairman Office	SYSTEM NOT WORKING	Jayaraj. J.	system working fine		Priya. A. - Marketing Team	21/11/2022
	Comp. Dt. : 23/11/2022 Status : Completed							
1425	22111005	Chairman Office	SYSTEM GETTING POWER OFF OFTENLY	Jayaraj. J.	K7 INSTALLED AND VIRUS CLEANED		Priya. A. - Marketing Team	23/11/2022
	Comp. Dt. : 19/12/2022 Status : Completed							
1426	22120855	CUSTOMER CARE EXECUTIVE-RECEPTION	MOUSE NOT WORKING	Jayaraj. J.	WORKING FINE		Sathiya Priya. J. - Marketing Team	24/12/2022
	Comp. Dt. : 20/12/2022 Status : Completed							
1427	22120890	Chairman Office	KEYBOARD WIRE NEED TO BE CHANGE (RECEPTION)	Balachandar. A.	new usb keyboard changed..		Priya. A. - Marketing Team	20/12/2022
	Comp. Dt. : 21/12/2022 Status : Completed							
1428	22120952	Chairman Office	MONITOR CABLE DAMAGE	Madhubalan. S.	NEW POWER CABLE CHANGED		Priya. A. - Marketing Team	21/12/2022
	Comp. Dt. : 09/02/2023 Status : Completed							
1429	23020341	Special Ward - C	NETWORK PROBLEM	Shafiullah. R.	REFIX PATCH CARD		Vijayalakshmi. V. - Marketing Team	09/02/2023
	Comp. Dt. : 11/02/2023 Status : Completed							
1430	23020418	SPECIAL WARD---B	SYSTEM NOT WORKING	Selvam. D.	system working fine		Shameena Begum. A. - Marketing Team	11/02/2023
	Comp. Dt. : 20/02/2023 Status : Completed							
1431	23020742	Special Ward - C	MEDPLUS & SYSTEM PROBLEM - NOT WORKING	Shafiullah. R.	REFIX THE PATCH CARD		Vijayalakshmi. V. - Marketing Team	21/02/2023
	Comp. Dt. : 22/02/2023 Status : Completed							


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1432	23020855	CUSTOMER CARE EXECUTIVE-RECEPTIO N	LAPTOP --CHARGING PROBLEM	Selvam. D.	POWER CABLE REFIXED		Sathiya Priya. J. - Marketing Team	22/02/2023
	Comp. Dt. : 08/03/2023 Status : Completed							
1433	23030302	IVF ART CLINIC-INSIDE OF OG OPD(NO.68)	SYSTEM NOT WORKING	Selvam. D.	Bios setting changed		Sathiya. M. - Marketing Team	08/03/2023
	Comp. Dt. : 24/03/2023 Status : Completed							
1434	23031019	Reception	NEED TO CHECK LAPTOP CABLE - NOT WORKING	Shafiullah. R.	refix laptop fixed		Sathiya Priya. J. - Marketing Team	24/03/2023
	Comp. Dt. : 30/03/2023 Status : Completed							
1435	23031275	Reception	NEED TO CHECK LAPTOP CABLE - NOT WORKING	Balachandar. A.	cable refixed,checked working fine		Sathiya Priya. J. - Marketing Team	31/03/2023
	Comp. Dt. : 12/04/2023 Status : Completed							
1436	23040374	Reception	DATA CABLE NOT WORKING	Jayaraj. J.	2M PATCH CARD CHANGED		Sathiya Priya. J. - Marketing Team	12/04/2023
	Comp. Dt. : 26/04/2023 Status : Completed							
1437	23040849	Chairman Office	FAX MACHINE NOT WORKING	Murugavel.R	Telephone Department problem		Priya. A. - Marketing Team	28/04/2023
1438	23040856	Chairman Office	FAX NOT WORKING - [AGAIN]	Murugavel.R	compliant double entry		Priya. A. - Marketing Team	28/04/2023
	Comp. Dt. : 13/05/2023 Status : Completed							
1439	23050535	Chairman Office	FAX NOT WORKING - NEED URGENT SERVICE	Murugavel.R	TELEPHONE LINE FAX ISSUE		Priya. A. - Marketing Team	15/05/2023
1440	23050537	Chairman Office	SYSTEM NOT WORKING	Jayaraj. J.	VIRUS SCAN AND CLEANED		Priya. A. - Marketing Team	15/05/2023
	Comp. Dt. : 24/05/2023 Status : Completed							
1441	23050964	IVF ART CLINIC-INSIDE OF OG OPD(NO.68)	NEED TO CHANGE BAR CODE STRICKER	Shafiullah. R.	NEW BARCODE STRICKER		Sathiya. M. - Marketing Team	24/05/2023
	Comp. Dt. : 09/06/2023 Status : Completed							


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1442	23060316	CUSTOMER CARE EXECUTIVE-RECEPTION	LAPTOP DATA CABLE NOT WORKING	Jayaraj. J.	CHARGER ADAPTER CHANGE AND LAN PORT CLEANED		Sathiya Priya. J. - Marketing Team	09/06/2023
		Comp. Dt. : 20/06/2023 Status : Completed						
1443	23060711	IVF ART CLINIC-INSIDE OF OG OPD(NO.68)	NEED TO CHANGE TONER	Balachandar. A.	TONER CHANGED		Sathiya. M. - Marketing Team	21/06/2023
		Comp. Dt. : 27/06/2023 Status : Completed						
1444	23061000	CUSTOMER CARE EXECUTIVE-RECEPTION	NEED TO CHECK LAPTOP CABLE - DATA CABLE NOT WORKING	Selvam. D.	USB LAN GIVEN AND INSTALLED		Sathiya Priya. J. - Marketing Team	27/06/2023
		Comp. Dt. : 28/06/2023 Status : Completed						
1445	23061048	CUSTOMER CARE EXECUTIVE-RECEPTION	LAPTOP NOT WORKING	Murugavel.R	On board network card fixed		Sathiya Priya. J. - Marketing Team	30/06/2023
		Comp. Dt. : 30/06/2023 Status : Completed						
1446	23061108	CUSTOMER CARE EXECUTIVE-RECEPTION	LAPTOP CABLE PROBLEM - NOT WORKING	Murugavel.R	usb network connector fixed		Sathiya Priya. J. - Marketing Team	30/06/2023
		Dept Name : Medical Records - Computer Department Comp. Dt. : 02/05/2022 Status : Completed						
1447	22050029	Male Medical - Ward 304	MOUSE NOT WORKING	Selvam. D.	usb cable refixed		Mohanapriya. A. - Medical Records	02/05/2022
		Comp. Dt. : 04/05/2022 Status : Completed						
1448	22050063	Medical Records	SYSTEM NOT WORKING	Selvam. D.	hdd cable refixed		Basheer Ahamed Khan. C - Medical Records	04/05/2022
1449	22050095	CASHCOUNTER IN RECEPTION	NEED TO CHANGE RIBBON 2NOS	Selvam. D.	10MTS RIBBON CHANGED		Priya. S. - Reception	05/05/2022
1450	22050101	Medical Records	NEED TO CHANGE TONER	Prakash. P.	12A Cpompl Toner Changed		Basheer Ahamed Khan. C - Medical Records	04/05/2022
		Comp. Dt. : 05/05/2022 Status : Completed						
1451	22050134	CASHCOUNTER IN RECEPTION	SYSTEM NOT WORKING	Jayaraj. J.	lan cable refixed		Priya. S. - Reception	05/05/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1452	22050165	Male Surgery - Ward 204	SYSTEM SLOW PROBLEM	Shafiullah. R.	clear temp files		Praveena. V. - Medical Records	06/05/2022
	Comp. Dt. : 09/05/2022 Status : Completed							
1453	22050274	Male Medical - Ward 304	PRINTER NOT WORKING	Madhubalan. S.	NEW PRINTER POWER CABLE CHANGED		Mohanapriya. A. - Medical Records	09/05/2022
	Comp. Dt. : 10/05/2022 Status : Completed							
1454	22050320	Male Medical - Ward 304	SYSTEM NOT WORKING	Madhubalan. S.	NEW SMPS CHANGED		Mohanapriya. A. - Medical Records	10/05/2022
	Comp. Dt. : 13/05/2022 Status : Completed							
1455	22050481	Medical Records	CHANGE PRINTER TONER	Jayaraj. J.	12A TONER CHANGED		Basheer Ahamed Khan. C - Medical Records	13/05/2022
	Comp. Dt. : 16/05/2022 Status : Completed							
1456	22050531	Male Medical - Ward 304	SYSTEM NOT WORKING	Shafiullah. R.	SYSTEM WORKING FINE		Mohanapriya. A. - Medical Records	16/05/2022
1457	22050540	Male Medical - Ward 304	NEED TO CHANGE TONER	Shafiullah. R.	12A TONER CHANGED		Mohanapriya. A. - Medical Records	16/05/2022
1458	22050547	Medical Records	NEED TO CHECK SYSTEM - PROBLEM	Jayaraj. J.	SYSTEM SETTING CHANGED		Avanthia. R. - Medical Records	16/05/2022
1459	22050561	Male Surgery - Ward 204	PROBLEM IN PRINTER	Madhubalan. S.	12A TONER CHANGED		Praveena. V. - Medical Records	16/05/2022
	Comp. Dt. : 19/05/2022 Status : Completed							
1460	22050688	CASHCOUNTER IN RECEPTION	NEED TO CHANGE PRINTER RIBBON	Selvam. D.	10m ribbon changed		Priya. S. - Reception	19/05/2022
	Comp. Dt. : 20/05/2022 Status : Completed							
1461	22050733	Obstetrics - Ward 208	SYSTEM NOT WORKING	Balachandar. A.	system boot settings changed...		Jerina. M. - Medical Records	20/05/2022
	Comp. Dt. : 23/05/2022 Status : Completed							
1462	22050809	CASHCOUNTER IN RECEPTION	SYSTEM NOT WORKING	Balachandar. A.	SYSTEM RESTARTED		Priya. S. - Reception	23/05/2022
1463	22050837	ENT WARD-407	NEED TO CHANGE TONER	Shafiullah. R.	12A TONER CHANGED		Jeyasudha. V. - Medical Records	23/05/2022
	Comp. Dt. : 24/05/2022							


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
1464	22050852	Medical Records	LASER PRINTER NOT WORKING	Murugavel.R	PRINTER WORKING FINE		Basheer Ahamed Khan. C - Medical Records	24/05/2022
Comp. Dt. : 25/05/2022								
Status : Completed								
1465	22050921	Medical Records	NEED TO CHANGE SYSTEM MONITOR - DISPLAY PROBLEM - SYSTEM NO 7	Murugavel.R	ACER 18.5 MONITOR CHANGED		Martin Prabu.V. - Medical Records	25/05/2022
1466	22050928	Medical Records	NEED TO CHANGE TONER [RAJI SYSTEM]	Murugavel.R	12A TONER CHANGED		Martin Prabu.V. - Medical Records	25/05/2022
Comp. Dt. : 26/05/2022								
Status : Completed								
1467	22050978	Male Medical - Ward 304	PRINTER NOT WORKING	Valamburi. R.	toner refixed and print queue cleared		Mohanapriya. A. - Medical Records	26/05/2022
1468	22051004	Medical Records	NEED TO REFIL PRINTER INK	Selvam. D.	Black ink filled		Iswin Joseph.M. - Medical Records	27/05/2022
Comp. Dt. : 30/05/2022								
Status : Completed								
1469	22051081	Medical Records	NEED TO CHANGE BARCODE STRICKER	Selvam. D.	New barcode sticker changed		Basheer Ahamed Khan. C - Medical Records	30/05/2022
Comp. Dt. : 31/05/2022								
Status : Completed								
1470	22051114	Obstetrics - Ward 208	NEED TO CHANGE TONER	Jayaraj. J.	12A TONER CHANGED		Jerina. M. - Medical Records	31/05/2022
Comp. Dt. : 01/06/2022								
Status : Completed								
1471	22060002	Male Medical - Ward 303	SYSTEM NOT WORKING	Shafiullah. R.	DISPLAY SCREEN RESET		Mohanapriya. A. - Medical Records	01/06/2022
Comp. Dt. : 02/06/2022								
Status : Completed								
1472	22060067	Male Medical - Ward 304	NEED TO CHANGE TONER	Prakash. P.	12AComp Tonner Changed		Mohanapriya. A. - Medical Records	02/06/2022
Comp. Dt. : 06/06/2022								
Status : Completed								
1473	22060185	Medical Records	NEED TO CHANGE TONER	Valamburi. R.	12A TONER CHANGED		Raj Kumar. K. - Medical Records	06/06/2022
Comp. Dt. : 07/06/2022								
Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1474	22060245	Male Surgery - Ward 204	NEED TO CHANGE TONER	Selvam. D.	12A toner changed		Praveena. V. - Medical Records	07/06/2022
	Comp. Dt. : 15/06/2022 Status : Completed							
1475	22060543	CASHCOUNTER IN RECEPTION	NEED TO CHANGE PRINTER RIBBON 2 NOS	Murugavel.R	10 M RIBBON 2 NOS CHANGED		Priya. S. - Reception	15/06/2022
1476	22060589	Female Medical - Ward 306	NEED TO CHANGE TONER	Balachandar. A.	TONER CHANGED		Mohanapriya. A. - Medical Records	16/06/2022
	Comp. Dt. : 16/06/2022 Status : Completed							
1477	22060625	Medical Records	NEED TO CHANGE TONER	Selvam. D.	TONER CHANGED		Martin Prabu.V. - Medical Records	17/06/2022
	Comp. Dt. : 17/06/2022 Status : Completed							
1478	22060664	Medical Records	NEED TO CHANGE BARCODE STRICEKER	Balachandar. A.	BARCODE STRICEKER CHANGED		Martin Prabu.V. - Medical Records	18/06/2022
	Comp. Dt. : 20/06/2022 Status : Completed							
1479	22060722	Medical Records	BARCODE PRINTER NOT WORKING	Selvam. D.	Control panel switch changed		Basheer Ahamed Khan. C - Medical Records	21/06/2022
	Comp. Dt. : 21/06/2022 Status : Completed							
1480	22060744	Male Medical - Ward 304	NEED TO CHANGE TONER	Shafiullah. R.	12A TONER CHANGED		Mohanapriya. A. - Medical Records	21/06/2022
	Comp. Dt. : 22/06/2022 Status : Completed							
1481	22060790	Reception	NEED TO CHANGE BARCODE STRICKER FOR COUNTER NO 9	Shafiullah. R.	COUNTER 9 BARCODE STRICKER CHANGED		Basheer Ahamed Khan. C - Medical Records	22/06/2022
1482	22060819	ENT WARD-407	NEED TO CHANGE TONER	Shafiullah. R.	12A TONER CHANGED		Jeyasudha. V. - Medical Records	22/06/2022
	Comp. Dt. : 23/06/2022 Status : Completed							
1483	22060854	Medical Records	NEED SOFTWARE UPDATION	Murugavel.R	3 SYSTEMS MEDPLUS SOFTWARE UPDATE 11.06.2022		Iswin Joseph.M. - Medical Records	23/06/2022
	Comp. Dt. : 24/06/2022 Status : Completed							


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1484	22060884	Male Surgery - Ward 204	NEED TO CHANGE TONER	Murugavel.R	OLD TONER SHAKED AND FIXED NOW WORKING FINE		Praveena. V. - Medical Records	24/06/2022
1485	22060903	Medical Records	NEED TO CHANGE BARCODE STRICKER	Shafiullah. R.	NEW BARCODE STRICKER CHANGED		Raj Kumar. K. - Medical Records	24/06/2022
Comp. Dt. : 25/06/2022 Status : Completed								
1486	22060906	CASHCOUNTER IN RECEPTION	PRINTER NOT WORKING	Selvam. D.	Tamil software installed		Iyyanar. D. - Medical Records	27/06/2022
1487	22060922	Medical Records	NEED TO CHANGE TONER	Madhubalan. S.	12A TONER CHANGED		Raj Kumar. K. - Medical Records	25/06/2022
Comp. Dt. : 27/06/2022 Status : Completed								
1488	22060949	Medical Records	NEED TO CHANGE RIBBON FOR BARCODE PRINTER	Jayaraj. J.	BARCODE RIBBON CHANGED		Basheer Ahamed Khan. C - Medical Records	27/06/2022
1489	22060982	Medical Records	NEED TO CHECK NETWORK CONNECTION - [2525 SYSTEM]	Prakash. P.	NETWORK Cable unplugged		Iswin Joseph.M. - Medical Records	28/06/2022
Comp. Dt. : 28/06/2022 Status : Completed								
1490	22061026	Medical Records	NEED TO CHECK BARCODE PRINTER - NOT WORKING	Shafiullah. R.	BARCODE RIBBON CHANGED		Maheswari. S. - Medical Records	29/06/2022
1491	22061029	Medical Records	NEED TO CHANGE BARCODE STRICKER	Murugavel.R	NEW BARCODE STICKER CHANGED		Maheswari. S. - Medical Records	28/06/2022
Comp. Dt. : 29/06/2022 Status : Completed								
1492	22061039	Obstetrics - Ward 208	NEED TO CHANGE TONER	Shafiullah. R.	12A TONER CHANGED		Jerina. M. - Medical Records	29/06/2022
1493	22061089	Male Surgery - Ward 204	PRINTER NOT WORKING	Selvam. D.	System restarts and tested the printer working fine		Praveena. V. - Medical Records	30/06/2022
Comp. Dt. : 02/07/2022 Status : Completed								
1494	22070065	Medical Records	NEED TO CHANGE TONER	Balachandar. A.	12A Compl Tonner Changed		Raj Kumar. K. - Medical Records	04/07/2022
Comp. Dt. : 07/07/2022 Status : Completed								
1495	22070244	CASHCOUNTER IN RECEPTION	PRINTER NOT WORKING	Selvam. D.	Setting done		Iyyanar. D. - Medical Records	07/07/2022
1496	22070286	Medical Records	PRINTER NOT WORKING	Selvam. D.	Patch cable refixed		Iswin Joseph.M. - Medical Records	08/07/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 08/07/2022								
Status : Completed								
1497	22070323	Male Medical - Ward 304	NEED TO CHANGE TONER	Selvam. D.	TONER CHANGED		Mohanapriya. A. - Medical Records	08/07/2022
1498	22070344	Medical Records	PRINTER NOT WORKING	Selvam. D.	system restarts		Iswin Joseph.M. - Medical Records	08/07/2022
1499	22070347	Medical Records	NEED TO EXTEND NETWORK CONNECTION CABLE	Valamburi. R.	CABLE REFIXED		Basheer Ahamed Khan. C - Medical Records	14/07/2022
Comp. Dt. : 09/07/2022								
Status : Completed								
1500	22070390	Medical Records	NEED TO REFIL PRINTER INK	Selvam. D.	black ink filled		Iswin Joseph.M. - Medical Records	13/07/2022
Comp. Dt. : 11/07/2022								
Status : Completed								
1501	22070421	Medical Records	NEED TO CHANGE TONER	Valamburi. R.	12A toner changed		Iswin Joseph.M. - Medical Records	13/07/2022
Comp. Dt. : 13/07/2022								
Status : Completed								
1502	22070501	Male Medical - Ward 304	SYSTEM NOT WORKING	Selvam. D.	Domain reconfigure done		Mohanapriya. A. - Medical Records	13/07/2022
Comp. Dt. : 15/07/2022								
Status : Completed								
1503	22070572	ENT WARD-407	NEED TO CHANGE TONER	Selvam. D.	12A toner changed		Jeyasudha. V. - Medical Records	15/07/2022
1504	22070603	Medical Records	NEED TO CHANGE STRICKER	Madhubalan. S.	NEW STICKER CHANGED		Basheer Ahamed Khan. C - Medical Records	15/07/2022
Comp. Dt. : 18/07/2022								
Status : Completed								
1505	22070651	Medical Records	SYSTEM SLOW PROBLEM	Valamburi. R.	RAM INCREASED		Iswin Joseph.M. - Medical Records	19/07/2022
Comp. Dt. : 19/07/2022								
Status : Completed								
1506	22070697	Medical Records	NEED TO CHANGE TONER	Madhubalan. S.	12A TONER CHANGED		Raj Kumar. K. - Medical Records	19/07/2022
1507	22070728	Medical Records	NEED TO PROVIDE U P S FOR 2525 SYSTEM	Valamburi. R.	Lithium battery ups changed		Martin Prabu.V. - Medical Records	22/07/2022
Comp. Dt. : 20/07/2022								
Status : Completed								
1508	22070752	Obstetrics - Ward 208	NEED TO CHANGE TONER	Selvam. D.	12A Compl Toner Changed		Jerina. M. - Medical Records	21/07/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 21/07/2022 Status : Completed								
1509	22070788	Medical Records	NEED TO CHECK SYSTEM - 2525 - [PROBLEM IN COMPLAINT SAVE]	Murugavel.R	CHECKED AND RESTART PROBLEM SLOVED		Martin Prabu.V. - Medical Records	21/07/2022
Comp. Dt. : 22/07/2022 Status : Completed								
1510	22070825	Medical Records	NEED TO CHANGE BARCODE STRICKER	Murugavel.R	NEW STICKER CHANGED		Raj Kumar. K. - Medical Records	22/07/2022
Comp. Dt. : 25/07/2022 Status : Completed								
1511	22070893	Medical Records	NEED TO CHANGE TONER	Shafiullah. R.	12A toner changed		Raj Kumar. K. - Medical Records	25/07/2022
1512	22070909	CASHCOUNTER IN RECEPTION	NEED TO CHANGE PRINTER RIBBON [2NOS]	Murugavel.R	2 NOS 10 M RIBBON CHANGED CHANGED		Priya. S. - Reception	25/07/2022
1513	22070916	Medical Records	SCANNER NOT WORKING	Jayaraj. J.	Setting reset done		Martin Prabu.V. - Medical Records	25/07/2022
Comp. Dt. : 26/07/2022 Status : Completed								
1514	22070959	Reception	NEED TO CHECK BAR CODE PRINTER - ERROR - COUNTER NO 9	Selvam. D.	barcode ribbon replaced		Maheswari. S. - Medical Records	26/07/2022
1515	22070964	Male Medical - Ward 301	SYSTEM NOT WORKING	Balachandar. A.	System working fine		Mohanapriya. A. - Medical Records	27/07/2022
1516	22070972	Medical Records	NEED TO CHECK PRINTER CONNECTION PROBLEM IN SYSTEM NO 6	Selvam. D.	patch cable refixed and system restarted		Martin Prabu.V. - Medical Records	27/07/2022
Comp. Dt. : 27/07/2022 Status : Completed								
1517	22071004	Reception	NEED TO CHANGE BARCODE STRICKER FOR COUNTER NO 9	Balachandar. A.	BARCODE STRICKER CHANGED		Maheswari. S. - Medical Records	27/07/2022
Comp. Dt. : 29/07/2022 Status : Completed								
1518	22071074	ENT WARD-407	PRINTER NOT WORKING	Selvam. D.	print queue cleared and tested the printer working fine		Jeyasudha. V. - Medical Records	29/07/2022
1519	22071084	Medical Records	NEED TO CHANGE BARCODE STRICKER	Selvam. D.	NEW STICKER CHANGED		Raj Kumar. K. - Medical Records	30/07/2022
Comp. Dt. : 30/07/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1520	22071112	Male Medical - Ward 301	NEED TO CHANGE TONER	Murugavel.R	12 A C TONER CHANGED		Mohanapriya. A. - Medical Records	01/08/2022
Comp. Dt. : 01/08/2022 Status : Completed								
1521	22080006	Obstetrics - Ward 208	NEED TO CHANGE TONER	Balachandar. A.	12 A C TONER CHANGED		Jerina. M. - Medical Records	01/08/2022
1522	22080017	Medical Records	NEED TO CHANGE TONER	Balachandar. A.	TONER CHANGED		Raj Kumar. K. - Medical Records	01/08/2022
1523	22080020	Reception	NEED TOO CHANGE BARCODE STRICKER FOR COUNTER NO 9	Valamburi. R.	NO STICKER CHANGED PRINTER PROBLEM FIXED		Maheswari. S. - Medical Records	01/08/2022
1524	22080049	Medical Records	MOUSE NOT WORKING - SYSTEM NO 6 [MRS. SANGEETHA SYSTEM]	Selvam. D.	USB cable refixed		Martin Prabu.V. - Medical Records	02/08/2022
Comp. Dt. : 02/08/2022 Status : Completed								
1525	22080053	Male Surgery - Ward 204	NEED TO CHANGE TONER	Valamburi. R.	88A tonr changed		Praveena. V. - Medical Records	03/08/2022
1526	22080065	CASHCOUNTER IN RECEPTION	NEED TO CHANGE PRINTER RIBBON [2 NOS]	Selvam. D.	10m ribbon changed		Iyyanar. D. - Medical Records	02/08/2022
Comp. Dt. : 06/08/2022 Status : Completed								
1527	22080245	Medical Records	NEED TO CHANGE TONER	Selvam. D.	12A TONER CHANGED		Basheer Ahamed Khan. C - Medical Records	08/08/2022
Comp. Dt. : 09/08/2022 Status : Completed								
1528	22080305	Medical Records	NEED TO REFIL PRINTER INK	Shafiullah. R.	Black ink filled		Iswin Joseph.M. - Medical Records	09/08/2022
Comp. Dt. : 10/08/2022 Status : Completed								
1529	22080385	Medical Records	NET CONNECTION PROBLEM	Selvam. D.	8 port switch refixed		Martin Prabu.V. - Medical Records	10/08/2022
Comp. Dt. : 12/08/2022 Status : Completed								
1530	22080430	Medical Records	NEED TO CHECK NET CONNECTION & MOUSE FOR SYSTEM NO 6 - NOT WORKING	Shafiullah. R.	NET CONNECT AND MOUSE WORKING		Martin Prabu.V. - Medical Records	12/08/2022
1531	22080455	Medical Records	NEED TO CHANGE TONER	Prakash. P.	12A TONER CHANGED		Raj Kumar. K. - Medical Records	12/08/2022
Comp. Dt. : 13/08/2022								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
1532	22080466	Male Medical - Ward 301	NEED TO CHANGE TONER	Prakash. P.	TONER CHANGED		Mohanapriya. A. - Medical Records	13/08/2022
Comp. Dt. : 17/08/2022								
Status : Completed								
1533	22080529	ENT WARD-407	CHNAGE PRINTER TONER	Selvam. D.	12A toner changed		Jeyasudha. V. - Medical Records	17/08/2022
Comp. Dt. : 18/08/2022								
Status : Completed								
1534	22080596	Medical Records	PRINTER PROBLEM	Madhubalan. S.	PRINTER POWER CABLE REFIXED		Sangeetha. R. - Medical Records	18/08/2022
Comp. Dt. : 19/08/2022								
Status : Completed								
1535	22080618	Medical Records	NEED TO CHANGE PRINTER RIBBON	Selvam. D.	10M RIBBON CHANGED		Kaveri. K. - Medical Records	19/08/2022
Comp. Dt. : 20/08/2022								
Status : Completed								
1536	22080667	Medical Records	PRINTER NOT WORKING	Jayaraj. J.	black ink filled		Martin Prabu.V. - Medical Records	20/08/2022
Comp. Dt. : 22/08/2022								
Status : Completed								
1537	22080704	Medical Records	NEED TO CHANGE TONER FOR RAJKUMAR PRINTER	Jayaraj. J.	12A toner changed		Martin Prabu.V. - Medical Records	22/08/2022
Comp. Dt. : 23/08/2022								
Status : Completed								
1538	22080745	Obstetrics - Ward 208	NEED TO CHANGE TONER	Balachandar. A.	12A toner chaged		Jerina. M. - Medical Records	23/08/2022
1539	22080757	CASHCOUNTER IN RECEPTION	NEED TO CHANGE PRINTER RIBBON	Selvam. D.	10m ribbon changed		Priya. S. - Reception	23/08/2022
Comp. Dt. : 26/08/2022								
Status : Completed								
1540	22080873	Medical Records	NEED TO CHANGE TONER	Shafiullah. R.	12A TONER CHAGED		Iswin Joseph.M. - Medical Records	26/08/2022
1541	22080915	Male Surgery - Ward 204	NEED TO CHANGE TONER	Prakash. P.	TONER CHANGED		Praveena. V. - Medical Records	27/08/2022
Comp. Dt. : 29/08/2022								
Status : Completed								
1542	22080972	Medical Records	NEED TO CHANGE BARCODE STRICKER	Balachandar. A.	BARCODE STRICKER CHANGED		Kumar. K. - Medical Records	29/08/2022

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHAL KUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 01/09/2022								
Status : Completed								
1543	22090017	ENT WARD-407	SYSTEM SLOW PROBLEM	Selvam. D.	Updates off		Jeyasudha. V. - Medical Records	02/09/2022
Comp. Dt. : 03/09/2022								
Status : Completed								
1544	22090120	Male Medical - Ward 302	MEDPLUS & MOUSE NOT WORKING	Valamburi. R.	working fine		Mohanapriya. A. - Medical Records	03/09/2022
Comp. Dt. : 05/09/2022								
Status : Completed								
1545	22090164	Medical Records	NEED TO CHANGE TONER [RAJKUMAR SYSTEM]	Selvam. D.	12A toner changed		Martin Prabu.V. - Medical Records	05/09/2022
Comp. Dt. : 07/09/2022								
Status : Completed								
1546	22090253	Medical Records	NET SLOW PROBLEM - NEED TO CHECK SYSTEM	Murugavel.R	software issue ready working fine..		Martin Prabu.V. - Medical Records	07/09/2022
1547	22090280	Medical Records	MOUSE NOT WORKING	Jayaraj. J.	MOUSE CHECKED WORKING FINE..		Basheer Ahamed Khan. C - Medical Records	09/09/2022
Comp. Dt. : 08/09/2022								
Status : Completed								
1548	22090297	Medical Records	NEED TO CHANGE TONER [RAJKUMAR PRINTER]	Jayaraj. J.	TONER CHANGED		Martin Prabu.V. - Medical Records	08/09/2022
1549	22090299	Obstetrics - Ward 208	NEED TO CHANGE TONER	Jayaraj. J.	12A toner changed		Jerina. M. - Medical Records	08/09/2022
Comp. Dt. : 09/09/2022								
Status : Completed								
1550	22090344	Medical Records	NEED TO CHECK SYSTEM - NOT WORKING [NO 6]	Jayaraj. J.	POWER CABLE REFIXED		Martin Prabu.V. - Medical Records	09/09/2022
1551	22090350	CASHCOUNTER IN RECEPTION	NEED TO CHANGE PRINTER RIBBON [3NOS]	Selvam. D.	PRINTER RIBBON CHANGED		Iyyanar. D. - Medical Records	09/09/2022
Comp. Dt. : 13/09/2022								
Status : Completed								
1552	22090468	Medical Records	ISSUE - CASESHEET UPLOAD IN MEDPLUS	Selvam. D.	casesheet uploaded		Martin Prabu.V. - Medical Records	23/09/2022
1553	22090491	CASHCOUNTER IN RECEPTION	PROBLEM IN PRINTER	Selvam. D.	10m cartridge changed		Priya. S. - Reception	13/09/2022
Comp. Dt. : 14/09/2022								
Status : Completed								
1554	22090541	Male Medical - Ward 301	NEED TO CHANGE TONER	Shafiullah. R.	12A TONER CHANGED		Mohanapriya. A. - Medical Records	14/09/2022

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHAL KUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 15/09/2022 Status : Completed								
1555	22090580	Obstetrics - Ward 208	PRINTER NOT WORKING	Selvam. D.	toner refixed		Jerina. M. - Medical Records	15/09/2022
Comp. Dt. : 17/09/2022 Status : Completed								
1556	22090672	Medical Records	NEED TO CHANGE TONER	Madhubalan. S.	12A toner changed		Basheer Ahamed Khan. C - Medical Records	17/09/2022
Comp. Dt. : 19/09/2022 Status : Completed								
1557	22090710	ENT WARD-407	NEED TO CHANGE TONER	Jayaraj. J.	12A TONER CHANGED		Jeyasudha. V. - Medical Records	19/09/2022
Comp. Dt. : 20/09/2022 Status : Completed								
1558	22090756	CASHCOUNTER IN RECEPTION	NEED TO REALIGN PRINTER RIBBIN - ALIGNMENT CHANGED	Balachandar. A.	printer catridge changed...		Priya. S. - Reception	21/09/2022
Comp. Dt. : 22/09/2022 Status : Completed								
1559	22090864	Male Surgery - Ward 203	PROBLEM IN MEDPLUS - NOT OPEN	Valamburi. R.	SYSTEM RESTARTED, SOFTWARE WORKING		Praveena. V. - Medical Records	22/09/2022
1560	22090880	Medical Records	NEED TO CHANGE TONER	Balachandar. A.	TONER CHANGED		Raj Kumar. K. - Medical Records	22/09/2022
Comp. Dt. : 26/09/2022 Status : Completed								
1561	22091022	Obstetrics - Ward 208	NEED TO CHANGE TONER	Shafiullah. R.	12A TONER CHANGED		Jerina. M. - Medical Records	26/09/2022
Comp. Dt. : 27/09/2022 Status : Completed								
1562	22091043	Male Surgery - Ward 204	NEED TO CHANGE TONER	Valamburi. R.	TONER CHANGED		Praveena. V. - Medical Records	27/09/2022
1563	22091052	Male Medical - Ward 301	NEED TO CHANGE TONER	Madhubalan. S.	12A TONER CHANGED		Mohanapriya. A. - Medical Records	27/09/2022
Comp. Dt. : 29/09/2022 Status : Completed								
1564	22091177	Medical Records	NEED TO CHECK SYSTEM - PROBLEM IN COMPLAINTS SAVE	Selvam. D.	working fine		Martin Prabu.V. - Medical Records	30/09/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 30/09/2022								
Status : Completed								
1565	22091192	Reception	CASH COUNTER CHANGE TO PRINTER RIBBON	Selvam. D.	10m ribbon changed		Iyyanar. D. - Medical Records	30/09/2022
1566	22091232	Medical Records	NEED TO CHANGE TONER	Selvam. D.	12 A toner changed		Raj Kumar. K. - Medical Records	30/09/2022
Comp. Dt. : 05/10/2022								
Status : Completed								
1567	22100037	Medical Records	PROBLEM IN SOFTWARE - NOT WORKING	Shafiullah. R.	SOFTWARE WORKING FINE		Martin Prabu.V. - Medical Records	05/10/2022
1568	22100048	ENT WARD-407	PRINTER NOT WORKING	Balachandar. A.	PENDING PRINTER CLEAR		Jeyasudha. V. - Medical Records	05/10/2022
Comp. Dt. : 07/10/2022								
Status : Completed								
1569	22100141	ENT WARD-407	NEED TO CHANGE TONER	Balachandar. A.	TONER CHANGED..		Jeyasudha. V. - Medical Records	07/10/2022
1570	22100147	Medical Records	NEED TO CHANGE TONER	Selvam. D.	12A toner changed		Raj Kumar. K. - Medical Records	07/10/2022
1571	22100165	Male Surgery - Ward 204	NEED TO CHANGE TONER	Shafiullah. R.	88A TONER CHANGED		Praveena. V. - Medical Records	08/10/2022
Comp. Dt. : 10/10/2022								
Status : Completed								
1572	22100260	Obstetrics - Ward 208	MEDPLUS NOT WORKING	Shafiullah. R.	RESET PASSWORD		Jerina. M. - Medical Records	10/10/2022
Comp. Dt. : 11/10/2022								
Status : Completed								
1573	22100268	Paediatrics - Ward 309	SYSTEM NOT WORKING	Selvam. D.	system working fine		Jerina. M. - Medical Records	11/10/2022
Comp. Dt. : 12/10/2022								
Status : Completed								
1574	22100317	Female Ortho - Ward 402	MOUSE NOT WORKING NEED ONE MOUSE PAD	Balachandar. A.	NEW USB MOUSE CHANGED AND MOUSE PAD GIVEN		Jeyasudha. V. - Medical Records	12/10/2022
1575	22100360	Male Medical - Ward 301	NEED TO CHANGE TONER	Valamburi. R.	12A toner changed		Mohanapriya. A. - Medical Records	13/10/2022
Comp. Dt. : 13/10/2022								
Status : Completed								
1576	22100384	Medical Records	SOFTWARE PROBELM - SYSTEM NO 3	Selvam. D.	Setting done		Iswin Joseph.M. - Medical Records	13/10/2022
1577	22100388	Medical Records	NEED TO CHANGE TONER	Selvam. D.	12A TONER CHANGED		Raj Kumar. K. - Medical Records	13/10/2022
1578	22100417	Medical Records	MOUSE NOT WORKING - SYSTEM NO 7	Shafiullah. R.	MOUSE WORKING FINE		Martin Prabu.V. - Medical Records	13/10/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 14/10/2022		Status : Completed						
1579	22100446	Medical Records	PRINTER NOT WORKING	Valamburi. R.	POWER CABLE REFIXED		Iswin Joseph.M. - Medical Records	14/10/2022
Comp. Dt. : 21/10/2022		Status : Completed						
1580	22100717	Obstetrics - Ward 208	MEDPLUS SOFTWARE SLOW - OBSTETRICS WARD 208 & 207	Selvam. D.	Network issue solved..		Jerina. M. - Medical Records	21/10/2022
1581	22100723	Medical Records	CHANGE PRINTER TONER	Selvam. D.	PRINTER TONER CHANGED		Basheer Ahamed Khan. C - Medical Records	21/10/2022
1582	22100729	Medical Records	PRINTER TONER NEED TO BE CHANGE	Selvam. D.	12A toner changed		Jerina. M. - Medical Records	22/10/2022
Comp. Dt. : 22/10/2022		Status : Completed						
1583	22100742	Male Surgery - Ward 204	PRINTER PROBLEM	Selvam. D.	12A toner changed		Praveena. V. - Medical Records	22/10/2022
1584	22100763	Female Ortho - Ward 402	PRINTER PROBLEM	Madhubalan. S.	SYSTEM RESTATE PRINTER WORKING FINE		Yogeswari. P. - Super Speciality OPD	22/10/2022
Comp. Dt. : 25/10/2022		Status : Completed						
1585	22100766	Female Ortho - Ward 402	PRINTER NOT WORKING	Madhubalan. S.	toner refixed working fine		Jeyasudha. V. - Medical Records	25/10/2022
1586	22100779	Medical Records	NEED TO CHANGE PRINTER TONER	Jayaraj. J.	12A toner changed		Basheer Ahamed Khan. C - Medical Records	25/10/2022
Comp. Dt. : 26/10/2022		Status : Completed						
1587	22100829	Female ENT - Ward 402	(1414) NEED TO CHANGE PRINTER TONER	Shafiullah. R.	12A TONER CHANGED		Yogeswari. P. - Super Speciality OPD	26/10/2022
Comp. Dt. : 27/10/2022		Status : Completed						
1588	22100850	Medical Records	BARCODE PRINTER NOT WORKING PROPERLY	Selvam. D.	Barcode printer working fine		Basheer Ahamed Khan. C - Medical Records	27/10/2022
Comp. Dt. : 28/10/2022		Status : Completed						
1589	22100874	Male Medical - Ward 302	SYSTEM NOT WORKING	Selvam. D.	Patch cable refixed		Mohanapriya. A. - Medical Records	28/10/2022
1590	22100875	Male Medical - Ward 301	NEED TO CHANGE TONER	Selvam. D.	12A toner changed		Mohanapriya. A. - Medical Records	28/10/2022

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1591	22100887	Male Surgery - Ward 204	NEED TO CHANGE TONER	Madhubalan. S.	General service done		Praveena. V. - Medical Records	28/10/2022
	Comp. Dt. : 29/10/2022 Status : Completed							
1592	22100951	Male Medical - Ward 301	SYSTEM NOT WORKING	Shafiullah. R.	SYSTEM WORKING FINE		Mohanapriya. A. - Medical Records	31/10/2022
	Comp. Dt. : 31/10/2022 Status : Completed							
1593	22100984	Female Ortho - Ward 402	NEED TO CHANGE PRINTER TONER	Selvam. D.	12A TONER CHANGED		Jeyasudha. V. - Medical Records	31/10/2022
1594	22101038	Female ENT - Ward 402	PRINTER PAPER STUCKING PROBLEM	Selvam. D.	PRINTER WORKING		Yogeswari. P. - Super Speciality OPD	02/11/2022
	Comp. Dt. : 02/11/2022 Status : Completed							
1595	22110002	Male Surgery - Ward 204	PRINTER NOT WORKING	Selvam. D.	General service done		Praveena. V. - Medical Records	03/11/2022
	Comp. Dt. : 03/11/2022 Status : Completed							
1596	22110071	Medical Records	CHANGE PRINTER TONER	Madhubalan. S.	12A TONER CHANGED		Raj Kumar. K. - Medical Records	03/11/2022
1597	22110073	Male Surgery - Ward 204	PRINTER PROBLEM	Selvam. D.	General service done		Praveena. V. - Medical Records	04/11/2022
	Comp. Dt. : 05/11/2022 Status : Completed							
1598	22110163	Paediatrics - Ward 308	SYSTEM MONITOR SCREEN DISPLAY SEEMS SMALL	Selvam. D.	monitor setting reset done		Deepa. S. - Medical Records	05/11/2022
	Comp. Dt. : 08/11/2022 Status : Completed							
1599	22110264	Medical Records	NEED TO CHANGE BARCODE STICKER	Valamburi. R.	STICKER CHANGED		Basheer Ahamed Khan. C - Medical Records	08/11/2022
1600	22110266	CASHCOUNTER IN RECEPTION	NEED TO CHANGE PRINTER RIBBON - 2 NOS	Valamburi. R.	RIBBON CHANGED		Iyyanar. D. - Medical Records	08/11/2022
	Comp. Dt. : 09/11/2022 Status : Completed							
1601	22110326	Male Medical - Ward 301	NEED TO CHANGE TONER	Madhubalan. S.	12A toner changed		Mohanapriya. A. - Medical Records	10/11/2022
	Comp. Dt. : 10/11/2022 Status : Completed							


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1602	22110379	SUPER SPECILAITY OPD IN 2ND FLOOR	SYSTEM NOT WORKING	Selvam. D.	System working fine		Punitha. P. - Medical Records	10/11/2022
	Comp. Dt. : 11/11/2022							
	Status : Completed							
1603	22110451	Male Medical - Ward 301	SYSTEM PROBLEM	Shafiullah. R.	SYSTEM WORKING FINE		Mohanapriya. A. - Medical Records	11/11/2022
	Comp. Dt. : 14/11/2022							
	Status : Completed							
1604	22110499	Male Surgery - Ward 201	PRINTER NOT WORKING	Shafiullah. R.	12A TONER CHANGED		Praveena. V. - Medical Records	14/11/2022
1605	22110500	Male Surgery - Ward 204	PRINTER NOT WORKING	Shafiullah. R.	General service done		Praveena. V. - Medical Records	16/11/2022
1606	22110522	Medical Records	NEED TO CHANGE PRINTER TONER	Shafiullah. R.	TONER CHANGED		Raj Kumar. K. - Medical Records	14/11/2022
	Comp. Dt. : 15/11/2022							
	Status : Completed							
1607	22110631	Female Medical - Ward 305	SYSTEM MOUSE NOT WORKING	Shafiullah. R.	DELL MOUSE CHANGED		Mohanapriya. A. - Medical Records	17/11/2022
	Comp. Dt. : 16/11/2022							
	Status : Completed							
1608	22110680	SPECIAL OPD IN 2ND FLOOR	IN RECEPTION-SYSTEM NO POWER ON	Valamburi. R.	POWER CABLE REFIXED		Punitha. P. - Medical Records	16/11/2022
	Comp. Dt. : 17/11/2022							
	Status : Completed							
1609	22110704	ENT WARD-407	CHANGE PRINTER TONER	Shafiullah. R.	12A TOWER CHANGED		Jeyasudha. V. - Medical Records	17/11/2022
1610	22110706	CASHCOUNTER IN RECEPTION	CHANGE PRINTER RIBBON	Selvam. D.	PRINTER RIBBON CHANGED		Iyyanar. D. - Medical Records	18/11/2022
1611	22110710	Female Ortho - Ward 402	NEED TO CHECK PRINTER - NOT WORKING	Shafiullah. R.	PAPER JAM CLEAR		Yogeswari. P. - Super Speciality OPD	18/11/2022
1612	22110711	Male Surgery - Ward 204	PRINTER NOT WORKING	Shafiullah. R.	PAPER JAM CLEAR		Praveena. V. - Medical Records	18/11/2022
1613	22110736	Male Surgery - Ward 201	SYSTEM MOUSE NOT WORKING	Shafiullah. R.	MOUSE WORKING FINE		Praveena. V. - Medical Records	18/11/2022
1614	22110737	Male Surgery - Ward 201	SYSTEM, MONITOR PROBLEM	Shafiullah. R.	SYSTEM WORKING FINE		Praveena. V. - Medical Records	17/11/2022
	Comp. Dt. : 18/11/2022							
	Status : Completed							
1615	22110749	Paediatrics - Ward 308	NEED TO CHANGE TONER	Balachandar. A.	TONER CHANGED		Deepa. S. - Medical Records	18/11/2022
	Comp. Dt. : 19/11/2022							
	Status : Completed							

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1616	22110802	Medical Records	PROBLEM IN SOFTWARE	Jayaraj. J.	MEDPLUS SOFTWARE INSTALLED		Martin Prabu.V. - Medical Records	19/11/2022
	Comp. Dt. : 21/11/2022							
	Status : Completed							
1617	22110874	Paediatrics - Ward 308	PRINTER PAPER JAM	Selvam. D.	PAPER JAM CLEARED		Deepa. S. - Medical Records	22/11/2022
	Comp. Dt. : 22/11/2022							
	Status : Completed							
1618	22110948	Male Surgery - Ward 204	PRINTER NOT WORKING	Shafiullah. R.	paper jamk cleared		Praveena. V. - Medical Records	23/11/2022
	Comp. Dt. : 23/11/2022							
	Status : Completed							
1619	22110981	CASHCOUNTER IN RECEPTION	PRINTER PROBLEM	Selvam. D.	10m RIBBON CHANGED		Iyyanar. D. - Medical Records	23/11/2022
1620	22110997	Medical Records	CHANGE PRINTER TONER	Selvam. D.	12A toner changed		Raj Kumar. K. - Medical Records	23/11/2022
1621	22111009	Medical Records	PRINTER PROBLEM	Selvam. D.	General service done		Raj Kumar. K. - Medical Records	24/11/2022
	Comp. Dt. : 25/11/2022							
	Status : Completed							
1622	22111110	Female Ortho - Ward 402	CHANGE PRINTER TONER	Shafiullah. R.	12A TONER CHANGED		Yogeswari. P. - Super Speciality OPD	25/11/2022
	Comp. Dt. : 29/11/2022							
	Status : Completed							
1623	22111199	CASHCOUNTER IN RECEPTION	PRINTER NOT WORKING	Selvam. D.	paper tractor refixed		Iyyanar. D. - Medical Records	01/12/2022
	Comp. Dt. : 30/11/2022							
	Status : Completed							
1624	22111265	Paediatrics - Ward 308	CPU NOT WORKING	Shafiullah. R.	SMPS CHANGED		Deepa. S. - Medical Records	01/12/2022
1625	22111277	Obstetrics - Ward 208	MEDPLUS NOT WORKING	Balachandar. A.	CHECKED MWORKING FINE..		Jerina. M. - Medical Records	30/11/2022
1626	22111279	Medical Records	NEED TO CHANGE TONER (RAJI SYSTEM)	Balachandar. A.	12A TONER CHANGED		Martin Prabu.V. - Medical Records	01/12/2022
1627	22111285	Male Surgery - Ward 204	CHANGE PRINTER TONER	Shafiullah. R.	88A TONER CHANGED		Praveena. V. - Medical Records	01/12/2022
	Comp. Dt. : 02/12/2022							
	Status : Completed							
1628	22120052	Medical Records	NET PROBLEM - 2525 SYSTEM	Prakash. P.	NETWORKING		Martin Prabu.V. - Medical Records	02/12/2022

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 03/12/2022								
Status : Completed								
1629	22120137	Male Medical - Ward 301	NEED TO CHANGE PRINTER TONER	Selvam. D.	PRINTER TONER CHANGED		Mohanapriya. A. - Medical Records	06/12/2022
Comp. Dt. : 05/12/2022								
Status : Completed								
1630	22120165	Female Ortho - Ward 402	PRINTER NOT WORKING	Madhubalan. S.	TONER REFIXED WORKING FINE		Yogeswari. P. - Super Speciality OPD	05/12/2022
1631	22120171	Male Surgery - Ward 204	PRINTER NOT WORKING	Madhubalan. S.	SYSTEM RESTATED PRINTER WORKING FINE		Praveena. V. - Medical Records	05/12/2022
Comp. Dt. : 06/12/2022								
Status : Completed								
1632	22120222	Medical Records	MOUSE NOT WORKING	Madhubalan. S.	NEW MOUSE PAD CHANGED		Basheer Ahamed Khan. C - Medical Records	06/12/2022
1633	22120228	Male Surgery - Ward 201	PRINTER NOT WORKING	Valamburi. R.	PAPER JAM CLEARED		Pushparaj. J. - Medical Records	06/12/2022
Comp. Dt. : 07/12/2022								
Status : Completed								
1634	22120276	Female Medical - Ward 306	NEED TO CHANGE TONER	Madhubalan. S.	12A TONER CHANGED		Amala. U. - Medical Records	07/12/2022
1635	22120282	Obstetrics - Ward 208	NEED TO CHANGE PRINTER TONER	Madhubalan. S.	12A TONER CHANGED		Jerina. M. - Medical Records	07/12/2022
1636	22120284	Female Surgery - Ward 205	SYSTEM NO POWER ON	Madhubalan. S.	SYSTEM WORKING FINE		Pushparaj. J. - Medical Records	07/12/2022
1637	22120328	Paediatrics - Ward 308	C P U NOT WORKING	Balachandar. A.	power cable refixed		Deepa. S. - Medical Records	08/12/2022
1638	22120332	Medical Records	NEED TO REFIL PRINTER INK	Shafiullah. R.	REFIL PRINTER INK		Iswin Joseph.M. - Medical Records	07/12/2022
1639	22120338	Paediatrics - Ward 308	PRINTER NOT WORKING	Murugavel.R	Paper Jam Clear to Paper		Deepa. S. - Medical Records	09/12/2022
Comp. Dt. : 08/12/2022								
Status : Completed								
1640	22120342	CASHCOUNTER IN RECEPTION	NEED TO CHANGE PRINTER RIBBON	Balachandar. A.	PRINTER RIBBON CHANGED		Iyyanar. D. - Medical Records	08/12/2022
1641	22120351	Female Surgery - Ward 205	MOUSE NOT WORKING	Murugavel.R	old mouse installed		Praveena. V. - Medical Records	08/12/2022
1642	22120354	Medical Records	CHANGE PRINTER TONER	Jayaraj. J.	12A TONER CHANGED		Raj Kumar. K. - Medical Records	08/12/2022
1643	22120381	Male Surgery - Ward 201	NEED TO CHANGE TONER	Valamburi. R.	TONER CHANGED		Pushparaj. J. - Medical Records	09/12/2022
Comp. Dt. : 09/12/2022								
Status : Completed								
1644	22120397	Male Surgery - Ward 201	NEED TO CHANGE TONER	Valamburi. R.	DOUBLE ENTRY		Pushparaj. J. - Medical Records	09/12/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1645	22120401	Female Surgery - Ward 206	SYSTEM POWER PROBLEM AUTOMATICALLY SHUT DOWN	Balachandar. A.	new lithium ups battery changed		Praveena. V. - Medical Records	17/12/2022
		Comp. Dt. : 10/12/2022 Status : Completed						
1646	22120458	Male Medical - Ward 304	NEED TO PROVIDE NEW MOUSE & C P U NOT WORKING	Madhubalan. S.	NEW MOUSE CHANGED AND SYSTEM WORKING FINE		Mohanapriya. A. - Medical Records	21/12/2022
		Comp. Dt. : 12/12/2022 Status : Completed						
1647	22120495	Male Medical - Ward 303	CPU NOT WORKING	Jayaraj. J.	SYSTEM MOTHERBOARD PROBLEM,NEW MOTHERBOARD CHANGED..		Mohanapriya. A. - Medical Records	02/01/2023
1648	22120505	ENT WARD-407	NEED CHANGE TONER	Shafiullah. R.	12A TONER CHANGED		Jeyasudha. V. - Medical Records	12/12/2022
		Comp. Dt. : 14/12/2022 Status : Completed						
1649	22120655	Female Medical - Ward 305	SYSTEM NOT WORKING	Selvam. D.	Multiple complaint locked		Mohanapriya. A. - Medical Records	26/12/2022
		Comp. Dt. : 15/12/2022 Status : Completed						
1650	22120675	Obstetrics - Ward 208	SYSTEM NOT WORKING	Selvam. D.	system working fine		Jerina. M. - Medical Records	26/12/2022
1651	22120676	ENT WARD-407	SYSTEM NOT WORKING	Selvam. D.	Power drained and reconnect		Jeyasudha. V. - Medical Records	26/12/2022
1652	22120684	Female Medical - Ward 305	SYSTEM NOT WORKING	Selvam. D.	ram cleaned and refixed		Amala. U. - Medical Records	26/12/2022
1653	22120701	Medical Records	NEED TO CHANGE TONER	Shafiullah. R.	12A TONER CHANGED		Raj Kumar. K. - Medical Records	15/12/2022
		Comp. Dt. : 16/12/2022 Status : Completed						
1654	22120753	Male Medical - Ward 303	CPU NOT WORKING	Shafiullah. R.	SYSTEM WORKING		Mohanapriya. A. - Medical Records	16/12/2022
		Comp. Dt. : 19/12/2022 Status : Completed						
1655	22120834	Male Medical - Ward 304	PRINTER NOT WORKING	Madhubalan. S.	PRINTER POWER CABLE REFIXED WORKING FINE		Mohanapriya. A. - Medical Records	19/12/2022
1656	22120844	Paediatrics - Ward 308	SOFTWARE PROBLEM	Madhubalan. S.	medplus reinstalled		Deepa. S. - Medical Records	21/12/2022
1657	22120866	Male Medical - Ward 303	COMPUTER NOT WORKING	Madhubalan. S.	MUTIPLE COMPLIANT		Mohanapriya. A. - Medical Records	24/12/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1658	22120870	Medical Records	NEED TO CHANGE BARCODE STICKER	Selvam. D.	BARCODE STICKER CHANGED		Basheer Ahamed Khan. C - Medical Records	20/12/2022
Comp. Dt. : 20/12/2022 Status : Completed								
1659	22120880	Medical Records	PRINTER NOT WORKING	Balachandar. A.	PENDING JOB CLERED		Iswin Joseph.M. - Medical Records	22/12/2022
1660	22120904	Male Medical - Ward 303	SYSTEM NOT WORKING	Madhubalan. S.	system ram dust cleaned..		Mohanapriya. A. - Medical Records	21/12/2022
Comp. Dt. : 21/12/2022 Status : Completed								
1661	22120981	Male Surgery - Ward 201	CPU NOT WORKING	Jayaraj. J.	CPU WORKING FINE		Pushparaj. J. - Medical Records	22/12/2022
Comp. Dt. : 23/12/2022 Status : Completed								
1662	22121040	CASHCOUNTER IN RECEPTION	NEED TO CHANGE PRINTER RIBBON	Madhubalan. S.	10m RIBBON CHENGED		Iyyanar. D. - Medical Records	23/12/2022
1663	22121041	Medical Records	NEED TO CHANGE TONER	Madhubalan. S.	12A TONER CHANGED		Raj Kumar. K. - Medical Records	23/12/2022
1664	22121075	Male Surgery - Ward 202	PRINTER NOT WORKING	Shafiullah. R.	REFIX TONER		Praveena. V. - Medical Records	23/12/2022
1665	22121087	Female Surgery - Ward 206	NEED TO CHANGE PRINTER TONER	Shafiullah. R.	12A TONER CHANGED		Praveena. V. - Medical Records	23/12/2022
1666	22121095	Medical Records	NEED TO CHANGE PRINTER INK	Shafiullah. R.	INK REFILLED		Iswin Joseph.M. - Medical Records	24/12/2022
Comp. Dt. : 24/12/2022 Status : Completed								
1667	22121105	Obstetrics - Ward 208	PRINTER NOT WORKING	Selvam. D.	PRINTER CLEARED		Jerina. M. - Medical Records	24/12/2022
Comp. Dt. : 26/12/2022 Status : Completed								
1668	22121168	Female Ortho - Ward 402	PRINTER NOT WORKING	Balachandar. A.	PENDING JOB CLEARED..		Yogeswari. P. - Super Speciality OPD	28/12/2022
Comp. Dt. : 27/12/2022 Status : Completed								
1669	22121253	Male Medical - Ward 304	PRINTER NOT WORKING	Shafiullah. R.	PRINTER WORKING		Mohanapriya. A. - Medical Records	29/12/2022
Comp. Dt. : 28/12/2022 Status : Completed								
1670	22121283	Medical Records	CHANGE PRINTER TONER	Selvam. D.	PRINTER TONER CHANGED		Raj Kumar. K. - Medical Records	29/12/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1671	22121290	Medical Records	CHANGE PRINTER TONER	Shafiullah. R.	WARD NO.208 TONER CHANGED		Jerina. M. - Medical Records	28/12/2022
1672	22121291	Female Ortho - Ward 402	CHANGE PRINTER TONER	Shafiullah. R.	12A TONER CHANGED		Yogeswari. P. - Super Speciality OPD	28/12/2022
Comp. Dt. : 29/12/2022								
Status : Completed								
1673	22121308	Female Medical - Ward 305	UPS NOT WORKING	Selvam. D.	New ups Installed		Amala. U. - Medical Records	20/01/2023
1674	22121319	Female Medical - Ward 306	NEED TO CHANGE PRINTER TONER	Madhubalan. S.	12A TONER CHANGED		Amala. U. - Medical Records	29/12/2022
Comp. Dt. : 02/01/2023								
Status : Completed								
1675	23010001	Male Medical - Ward 304	PRINTER PAPER JAM	Selvam. D.	PAPER JAM CLEAR		Gowri. S. - Medical Records	03/01/2023
1676	23010012	Female Surgery - Ward 205	SYSTEM PROBLEM	Madhubalan. S.	STANDBY SYSTEM GIVEN		Praveena. V. - Medical Records	21/01/2023
Comp. Dt. : 03/01/2023								
Status : Completed								
1677	23010069	Reception	NEED TO CHANGE BARCODE STICKER IN COUNTER NO 9	Shafiullah. R.	NEW BARCODE STICKER CHANGED		Nisha. R. - Medical Records	03/01/2023
1678	23010071	Medical Records	NEED TO CHANGE PRINTER TONER	Madhubalan. S.	12A TONER CHANGED		Raj Kumar. K. - Medical Records	03/01/2023
1679	23010103	Male Surgery - Ward 201	CHANGE PRINTER TONER	Jayaraj. J.	12A TONER CHANGED		Pushparaj. J. - Medical Records	03/01/2023
1680	23010109	CASHCOUNTER IN RECEPTION	PRINTER RIBBON NEED TO CHANGE FOR BOTH PRINTERS	Shafiullah. R.	10mts RIBBON CHANGED 2 COUNTER		Iyyanar. D. - Medical Records	03/01/2023
Comp. Dt. : 04/01/2023								
Status : Completed								
1681	23010126	Male Surgery - Ward 204	CPU NOT WORKING	Selvam. D.	Ram cleaned and refixed		Praveena. V. - Medical Records	04/01/2023
1682	23010127	Male Surgery - Ward 204	PRINTER NOT WORKING	Shafiullah. R.	PRINTER POWER BUTTON CHANGED		Praveena. V. - Medical Records	09/01/2023
1683	23010161	Paediatrics - Ward 308	CHANGE PRINTER TONER	Madhubalan. S.	PRINTER TONER CHANGED		Deepa. S. - Medical Records	04/01/2023
1684	23010169	Male Medical - Ward 304	PRINTER PAPER JAM	Shafiullah. R.	PAPER JAM CLEAR		Mohanapriya. A. - Medical Records	05/01/2023
Comp. Dt. : 05/01/2023								
Status : Completed								
1685	23010236	ENT WARD-407	SYSTEM MOUSE NOT WORKING	Jayaraj. J.	MOUSE CHANGED		Jeyasudha. V. - Medical Records	05/01/2023
Comp. Dt. : 06/01/2023								
Status : Completed								

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1686	23010264	Female Medical - Ward 306	PRINTER NOT WORKING(1313)	Shafiullah. R.	refix the usb cable printer working		Amala. U. - Medical Records	06/01/2023
	Comp. Dt. : 07/01/2023							
	Status : Completed							
1687	23010297	ENT WARD-407	NEED TO CHANGE TONER	Selvam. D.	12A TONER CHANGED		Jeyasudha. V. - Medical Records	07/01/2023
1688	23010305	Paediatrics - Ward 308	SYSTEM NETWORK NOT CONNECTED	Madhubalan. S.	SYSTEM RESTATED MEDPLUS WORKING FINE		Gowri. S. - Medical Records	07/01/2023
	Comp. Dt. : 09/01/2023							
	Status : Completed							
1689	23010372	Male Medical - Ward 304	PRINTER NOT WORKING	Selvam. D.	printer working fine		Mohanapriya. A. - Medical Records	10/01/2023
	Comp. Dt. : 10/01/2023							
	Status : Completed							
1690	23010374	Obstetrics & Gynecology WARD-209	NEED TO CHACK MEDPLUS NOT WORKING	Jayaraj. J.	WORKING FINE		Jerina. M. - Medical Records	10/01/2023
1691	23010401	Paediatrics - Ward 310	SYSTEM UPS PROBLEM	Jayaraj. J.	NEW UPS CHANGED		Deepa. S. - Medical Records	14/01/2023
1692	23010412	Paediatrics - Ward 309	SYSTEM NO POWER ON	Jayaraj. J.	power cable refixed		Deepa. S. - Medical Records	10/01/2023
	Comp. Dt. : 11/01/2023							
	Status : Completed							
1693	23010469	Paediatrics - Ward 309	CHANGE PRINTER TONER	Jayaraj. J.	12A TONER CHANGED		Deepa. S. - Medical Records	11/01/2023
1694	23010474	CASHCOUNTER IN RECEPTION	CHANGE PRINTER RIBBON FOR BOTH 2 PRINTERS	Jayaraj. J.	10M RIBBON CHANGED		Iyyanar. D. - Medical Records	11/01/2023
1695	23010490	Male Medical - Ward 304	CHANGE PRINTER TONER	Selvam. D.	12A toner changed		Mohanapriya. A. - Medical Records	11/01/2023
	Comp. Dt. : 12/01/2023							
	Status : Completed							
1696	23010506	ENT WARD-407	MOUSE NOT WORKING	Jayaraj. J.	MOUSE USB CABLE REFIXED		Jeyasudha. V. - Medical Records	12/01/2023
1697	23010530	TB AND CHEST WARD-405	PRINTER NOT WORKING	Madhubalan. S.	printer working fine		Muthazhagi. S. - Medical Records	12/01/2023
	Comp. Dt. : 13/01/2023							
	Status : Completed							
1698	23010575	Medical Records	NEWLY CONNECTED 2 SYSTEMS NOT WORKING	Jayaraj. J.	POWER CABLE REFIXED		Basheer Ahamed Khan. C - Medical Records	13/01/2023
	Comp. Dt. : 18/01/2023							
	Status : Completed							


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1699	23010605	Male Surgery - Ward 204	SYSTEM PROBLEM	Madhubalan. S.	Gear assembly problem. unable to service so alternate printer given		Praveena. V. - Medical Records	23/01/2023
1700	23010612	Male Medical - Ward 301	PRINTER NOT WORKING	Madhubalan. S.	POWER CABLE REFIXED WORKING FINE		Mohanapriya. A. - Medical Records	18/01/2023
Comp. Dt. : 19/01/2023								
Status : Completed								
1701	23010685	Medical Records	SYSTEM NOT WORKING	Valamburi. R.	Power cable refixed		Martin Prabu.V. - Medical Records	21/01/2023
Comp. Dt. : 20/01/2023								
Status : Completed								
1702	23010700	Paediatrics - Ward 308	UPS NOT WORKING	Madhubalan. S.	UPS RESETTED WORKING FINE		Deepa. S. - Medical Records	20/01/2023
Comp. Dt. : 21/01/2023								
Status : Completed								
1703	23010755	Paediatrics - Ward 308	MEDPLUS NOT WORKING	Shafiullah. R.	REFIX THE PATCHCARD		Deepa. S. - Medical Records	21/01/2023
Comp. Dt. : 23/01/2023								
Status : Completed								
1704	23010799	Obstetrics - Ward 208	NEED TO CHANGE TONER	Balachandar. A.	12a toner changed		Jerina. M. - Medical Records	23/01/2023
1705	23010824	Paediatrics - Ward 308	NEED TO CHECK SYSTEM TIME - WRONGLY DISPLAY	Balachandar. A.	CMOS BATTERY CHANGED		Deepa. S. - Medical Records	30/01/2023
Comp. Dt. : 24/01/2023								
Status : Completed								
1706	23010866	Medical Records	NEED TO CONNECT BAR CODE PRINTER	Shafiullah. R.	REINSTALLED ANOTHER COMPUTER BAR CODE PRINTER		Martin Prabu.V. - Medical Records	24/01/2023
1707	23010884	Reception	NEED TO CHANGE BARCODE STRICKER FOR COUNTER NO 9	Jayaraj. J.	NEW BARCODE STRICKER CHANGED		Kaveri. K. - Medical Records	24/01/2023
Comp. Dt. : 25/01/2023								
Status : Completed								
1708	23010897	Female Ortho - Ward 402	NEED TO CHANGE TONER	Balachandar. A.	12A TONER CHANGED		Gowri. S. - Medical Records	25/01/2023
1709	23010907	Medical Records	NEED TO CHANGE TONER	Balachandar. A.	TONER CHANGED		Martin Prabu.V. - Medical Records	25/01/2023
1710	23010933	Medical Records	NEED TO CHANGE BARCODE STRICKER	Selvam. D.	new barcode sticker changed		Martin Prabu.V. - Medical Records	25/01/2023
Comp. Dt. : 30/01/2023								
Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1711	23011041	Reception	NEED TO CHANGE BARCODE STRICKER FOR COUNTER NO 9	Madhubalan. S.	COUNTER 9 NEW STICKER CAHNGED		Prabhakaran. S. - Medical Records	30/01/2023
1712	23011055	Medical Records	NEED TO CHECK BARCODE PRINTER - NOT WORKING	Valamburi. R.	CABLE REFIXED		Basheer Ahamed Khan. C - Medical Records	30/01/2023
1713	23011076	Medical Records	NEED TO CHANGE BARCODE STRICKER	Madhubalan. S.	BARCODE STRICKER CHANGED		Martin Prabu.V. - Medical Records	30/01/2023
Comp. Dt. : 31/01/2023 Status : Completed								
1714	23011088	Male Surgery - Ward 204	PRINTER NOT WORKING	Selvam. D.	pint queue cleared		Praveena. V. - Medical Records	31/01/2023
Comp. Dt. : 01/02/2023 Status : Completed								
1715	23020020	Medical Records	NEED TO CHANGE BARCODE STRICKER	Madhubalan. S.	NEW STICKER CHANGED		Martin Prabu.V. - Medical Records	01/02/2023
1716	23020032	Medical Records	NEED TO CHANGE TONER	Madhubalan. S.	12A TONER CHANGED		Martin Prabu.V. - Medical Records	01/02/2023
Comp. Dt. : 02/02/2023 Status : Completed								
1717	23020053	Female Surgery - Ward 205	NET WORK PROBLEM	Madhubalan. S.	Patch cable refixed		Pushparaj. J. - Medical Records	03/02/2023
1718	23020065	Paediatrics - Ward 308	NEED TO CHECK NET CONNECTION - PROBLEM	Selvam. D.	working fine		Vijayakumari. P. - Medical Records	04/02/2023
1719	23020072	Medical Records	NEED TO CHANGE BARCODE STRICKER	Madhubalan. S.	New barcode sticker changed		Martin Prabu.V. - Medical Records	03/02/2023
Comp. Dt. : 03/02/2023 Status : Completed								
1720	23020103	Male Surgery - Ward 204	NEED TO CHANGE TONER	Selvam. D.	12a toner changed		Praveena. V. - Medical Records	04/02/2023
Comp. Dt. : 04/02/2023 Status : Completed								
1721	23020117	Medical Records	SYSTEM NOT WORKING	Selvam. D.	patch cable refixed		Martin Prabu.V. - Medical Records	04/02/2023
1722	23020118	Medical Records	NEED TO CHANGE BARCODE STRICKER	Selvam. D.	BARCODE STRICKER CHANGED		Martin Prabu.V. - Medical Records	04/02/2023
1723	23020145	Female Ortho - Ward 402	PRINTER TONER PROBLEM	Selvam. D.	12a toner chagned		Amala. U. - Medical Records	06/02/2023
Comp. Dt. : 06/02/2023 Status : Completed								
1724	23020208	Medical Records	NEED TO CHANGE BARCODE STICKER	Selvam. D.	New barcode sticker changed		Raj Kumar. K. - Medical Records	07/02/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 07/02/2023								
Status : Completed								
1725	23020243	Male Medical - Ward 304	NEED TO CHANGE TONER	Selvam. D.	12A toner changed		Mohanapriya. A. - Medical Records	08/02/2023
1726	23020258	Female Ortho - Ward 401	MOUSE NOT WORKING	Jayaraj. J.	mouse cable refixed		Vijayakumari. P. - Medical Records	08/02/2023
Comp. Dt. : 08/02/2023								
Status : Completed								
1727	23020276	ENT WARD-407	NEED TO CHANGE PRINTER TONER	Shafiullah. R.	12A TONER CHANGED		Jeyasudha. V. - Medical Records	08/02/2023
1728	23020283	Obstetrics - Ward 208	NEED TO CHANGE PRINTER TONER	Shafiullah. R.	12A TONER CHANGED		Jerina. M. - Medical Records	08/02/2023
1729	23020299	Medical Records	NEED TO CHANGE BARCODE STICKER	Selvam. D.	New barcode sticker changed		Raj Kumar. K. - Medical Records	08/02/2023
1730	23020310	Female Ortho - Ward 401	SYSTEM NOT WORKING	Shafiullah. R.	SYSTEM WORKING FINE		Gowri. S. - Medical Records	09/02/2023
Comp. Dt. : 09/02/2023								
Status : Completed								
1731	23020318	Medical Records	PRINTER NOT WORKING	Valamburi. R.	TONER CHANGED		Raj Kumar. K. - Medical Records	09/02/2023
Comp. Dt. : 10/02/2023								
Status : Completed								
1732	23020406	Paediatrics - Ward 308	SYSTEM NOT WORKING	Selvam. D.	system working fine		Deepa. S. - Medical Records	11/02/2023
1733	23020414	Male Ortho - Ward 403	SYSTEM NOT WORKING	Selvam. D.	system working fine		Gowri. S. - Medical Records	11/02/2023
Comp. Dt. : 13/02/2023								
Status : Completed								
1734	23020499	Medical Records	NEED TO CHANGE BARCODE STRICKER	Selvam. D.	BARCODE STRICKER CHANGED		Martin Prabu.V. - Medical Records	14/02/2023
1735	23020504	Paediatrics - Ward 308	NEED TO CHANGE TONER	Shafiullah. R.	12A TONER CHANGED		Deepa. S. - Medical Records	14/02/2023
Comp. Dt. : 14/02/2023								
Status : Completed								
1736	23020551	Medical Records	NEED TO CHANGE BARCODE PRINTER RIBBON	Shafiullah. R.	WAX RIBBON CHANGED		Martin Prabu.V. - Medical Records	14/02/2023
1737	23020561	Female Medical - Ward 306	NEED TO CHANGE TONER	Madhubalan. S.	TONER CHANGED		Amala. U. - Medical Records	15/02/2023
Comp. Dt. : 15/02/2023								
Status : Completed								
1738	23020599	Medical Records	NEED TO CHANGE BARCODE STRICKER	Madhubalan. S.	BARCODE STRICKER CHANGED		Martin Prabu.V. - Medical Records	15/02/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 16/02/2023 Status : Completed								
1739	23020636	Medical Records	NEED TO CHANGE PRINTER TONER	Selvam. D.	PRINTER TONER CHANGED		Rajkumar. V. - Medical Records	16/02/2023
Comp. Dt. : 17/02/2023 Status : Completed								
1740	23020673	Male Medical - Ward 303	SYSTEM NOT WORKING	Shafiullah. R.	MONITOR DISPLAY SETTING RESET		Mohanapriya. A. - Medical Records	17/02/2023
Comp. Dt. : 21/02/2023 Status : Completed								
1741	23020791	ENT WARD-407	MOUSE NOT WORKING	Shafiullah. R.	NEW USB MOUSE CHANGED		Vijayakumari. P. - Medical Records	21/02/2023
1742	23020825	Paediatrics - Ward 308	PROBLEM IN SOFTWARE	Shafiullah. R.	SOFTWARE WORKING		Deepa. S. - Medical Records	21/02/2023
Comp. Dt. : 22/02/2023 Status : Completed								
1743	23020833	Paediatrics - Ward 308	SYSTEM NOT WORKING	Shafiullah. R.	SYSTEM WORKING FINE		Deepa. S. - Medical Records	22/02/2023
1744	23020842	CASHCOUNTER IN RECEPTION	NEED TO CHANGE TWO PRINTERS RIBBON	Madhubalan. S.	COUNTER 1 AND 2 10m RIBBON CHANGED		Iyyanar. D. - Medical Records	22/02/2023
1745	23020848	ENT & Ophthal Ward	MOUSE NOT WORKING	Selvam. D.	MOUSE REFIXED		Jeyasudha. V. - Medical Records	22/02/2023
1746	23020878	Medical Records	NEED TO CHANGE BARCODE STICKER	Valamburi. R.	New barcode sticker changed		Raj Kumar. K. - Medical Records	22/02/2023
Comp. Dt. : 23/02/2023 Status : Completed								
1747	23020883	Female Surgery - Ward 206	PRINTER NOT WORKING	Selvam. D.	TONER REFIXED		Vijayakumari. P. - Medical Records	23/02/2023
1748	23020889	Medical Records	SYSTEM NOT WORKING	Selvam. D.	Power setting changed		Martin Prabu.V. - Medical Records	23/02/2023
Comp. Dt. : 24/02/2023 Status : Completed								
1749	23020953	Female Surgery - Ward 206	PRINTER SOUND PROBLEM	Selvam. D.	fuser assembly refixed		Pushparaj. J. - Medical Records	27/02/2023
Comp. Dt. : 25/02/2023 Status : Completed								
1750	23020966	Medical Records	NEED TO CHANGE TONER	Shafiullah. R.	12A TONER CHANGED		Martin Prabu.V. - Medical Records	25/02/2023
Comp. Dt. : 27/02/2023 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1751	23020996	Female Ortho - Ward 402	NEED TO CHANGE TONER	Shafiullah. R.	12a Toner changed		Gowri. S. - Medical Records	27/02/2023
1752	23021014	Paediatrics - Ward 308	SYSTEM NOT WORKING	Madhubalan. S.	System working fine		Deepa. S. - Medical Records	03/03/2023
1753	23021025	Medical Records	NEED TO CHANGE BARCODE STRICKER	Selvam. D.	BARCODE STRICKER CHANGED		Martin Prabu.V. - Medical Records	27/02/2023
Comp. Dt. : 28/02/2023 Status : Completed								
1754	23021059	CASHCOUNTER IN RECEPTION	PRINTER PROBLEM	Selvam. D.	PRINTER WORKING		Iyyanar. D. - Medical Records	28/02/2023
Comp. Dt. : 01/03/2023 Status : Completed								
1755	23030042	Male Medical - Ward 304	NEED TO CHANGE TONER	Shafiullah. R.	12A TONER CHANGED		Mohanapriya. A. - Medical Records	01/03/2023
1756	23030047	Male Surgery - Ward 204	NEED TO CHANGE TONER	Harikrishnan. R.	12A toner changed		Praveena. V. - Medical Records	02/03/2023
1757	23030048	Medical Records	PRINTER NOT WORKING	Selvam. D.	Pritter head cleaning done		Martin Prabu.V. - Medical Records	03/03/2023
Comp. Dt. : 02/03/2023 Status : Completed								
1758	23030090	Male Medical Ward	NEED TO REPLACE PRINTER FOR WARD NO 304 TO 303	Selvam. D.	NO NEED TO INTERCHANGED THE PRINTER		Mohanapriya. A. - Medical Records	02/03/2023
Comp. Dt. : 04/03/2023 Status : Completed								
1759	23030170	SUPER SPECILAITY OPD IN 2ND FLOOR	NEED TO CHANGE BARCODE STRICKER	Shafiullah. R.	STRICKER NOT CHANGED STRICKER JAM REMOVED		Punitha. P. - Medical Records	04/03/2023
1760	23030174	Female Medical - Ward 305	NEED TO REFIX SYSTEM CONNECTION - PROBLEM	Selvam. D.	Refixed the system connection		Amala. U. - Medical Records	06/03/2023
Comp. Dt. : 06/03/2023 Status : Completed								
1761	23030193	Medical Records	PROBLEM IN MEDPLUS-SYSTEM NO 8	Jayaraj. J.	SYSTEM RESTARTED..		Martin Prabu.V. - Medical Records	07/03/2023
1762	23030237	Obstetrics - Ward 208	NEED TO CHANGE TONER	Harikrishnan. R.	TONER CHANGED		Jerina. M. - Medical Records	07/03/2023
1763	23030238	Male Psychiatry - Ward 405	PRINTER NOT WORKING	Jayaraj. J.	12A TONER CHANGED		Muthazhagi. S. - Medical Records	07/03/2023
Comp. Dt. : 07/03/2023 Status : Completed								
1764	23030294	Medical Records	PRINTER NOT WORKING	Jayaraj. J.	HEAD CLEAN		Iswin Joseph.M. - Medical Records	07/03/2023
Comp. Dt. : 13/03/2023								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
1765	23030481	Paediatrics - Ward 308	PRINTER NOT WORKING	Shafiullah. R.	RESTART THE SYSTEM PRINTER WORKING		Deepa. S. - Medical Records	13/03/2023
1766	23030493	Medical Records	NEED TO CHANGE BARCODE PRINTER BLOCK RIBBON	Shafiullah. R.	BARCODE RIBBON CHANGED		Raj Kumar. K. - Medical Records	13/03/2023
1767	23030512	Medical Records	NEED TO CHANGE TONER	Selvam. D.	TONER CHAN GED		Raj Kumar. K. - Medical Records	15/03/2023
Comp. Dt. : 14/03/2023								
Status : Completed								
1768	23030517	ENT WARD-407	PRINTER NOT WORKING	Selvam. D.	printer working		Vijayakumari. P. - Medical Records	14/03/2023
1769	23030521	Paediatrics - Ward 308	NEED TO CHANGE TONER	Madhubalan. S.	TONER CHANGED		Deepa. S. - Medical Records	15/03/2023
Comp. Dt. : 15/03/2023								
Status : Completed								
1770	23030620	ENT WARD-407	NEED TO CHANGE TONER	Jayaraj. J.	12A TONER CHANGED		Vijayakumari. P. - Medical Records	15/03/2023
Comp. Dt. : 21/03/2023								
Status : Completed								
1771	23030843	SUPER SPECILAITY OPD IN 2ND FLOOR	SYSTEM NOT WORKING	Shafiullah. R.	UPS POWER RESET NOW WORKING		Punitha. P. - Medical Records	21/03/2023
Comp. Dt. : 22/03/2023								
Status : Completed								
1772	23030921	Medical Records	NEED TO CHANGE BARCODE STICKER	Harikrishnan. R.	New barcode sticker changed		Kaveri. K. - Medical Records	22/03/2023
Comp. Dt. : 23/03/2023								
Status : Completed								
1773	23030939	Female Ortho - Ward 402	NEED TO CHANGE TONER	Madhubalan. S.	12A TONER CHANGED		Gowri. S. - Medical Records	23/03/2023
Comp. Dt. : 24/03/2023								
Status : Completed								
1774	23031028	SURGERY	NEED TO CHANGE TONER WARD NO 202 & 206	Venkatesh. S.	12A TONER CHANGED		Pushparaj. J. - Medical Records	24/03/2023
Comp. Dt. : 25/03/2023								
Status : Completed								
1775	23031035	Obstetrics - Ward 208	PRINTER NOT WORKING	Shafiullah. R.	printer driver install		Jerina. M. - Medical Records	25/03/2023
1776	23031067	Medical Records	NEED TO CHANGE TONER	Madhubalan. S.	12A TONER CHANGED		Raj Kumar. K. - Medical Records	25/03/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 27/03/2023								
Status : Completed								
1777	23031101	PSYCHIATRY WARD	PRINTER NOT WORKING	Shafiullah. R.	Paper sensor cleaned and refixed		Muthazhagi. S. - Medical Records	28/03/2023
Comp. Dt. : 28/03/2023								
Status : Completed								
1778	23031186	Paediatrics - Ward 310	MEDPLUS NOT WORKING - FEMALE MEDICINE WARD 310	Selvam. D.	Power issue solved		Amala. U. - Medical Records	29/03/2023
1779	23031202	Paediatrics - Ward 308	MEDPLUS NOT WORKING	Shafiullah. R.	medplus working		Deepa. S. - Medical Records	29/03/2023
1780	23031210	Male Medical - Ward 304	NEED TO CHANGE TONER	Jayaraj. J.	12A TONER CHANGED		Vijayakumari. P. - Medical Records	31/03/2023
Comp. Dt. : 30/03/2023								
Status : Completed								
1781	23031287	Medical Records	NEED TO CHECK SYSTEM MONITOR - DISPLAY PROBLEM - SYSTEM NO 6	Balachandar. A.	MONITOR CABLE REFIXED		Martin Prabu.V. - Medical Records	17/04/2023
1782	23031301	Male Surgery - Ward 204	SYSTEM - PROBLEM	Selvam. D.	word setting changed		Praveena. V. - Medical Records	31/03/2023
Comp. Dt. : 03/04/2023								
Status : Completed								
1783	23040063	Medical Records	NEED TO CHANGE TONER	Madhubalan. S.	12A TONER CHANGED		Raj Kumar. K. - Medical Records	03/04/2023
Comp. Dt. : 06/04/2023								
Status : Completed								
1784	23040176	Female Medical - Ward 306	NEED TO CHANGE TONER	Harikrishnan. R.	12A toner changed.		Amala. U. - Medical Records	06/04/2023
1785	23040190	Obstetrics - Ward 208	NEED TO CHANGE TONER	Selvam. D.	12a toner changed		Jerina. M. - Medical Records	08/04/2023
1786	23040211	Medical Records	BARCODE PRINTER NOT WORKING	Selvam. D.	Paper eject switch changed		Martin Prabu.V. - Medical Records	08/04/2023
Comp. Dt. : 11/04/2023								
Status : Completed								
1787	23040302	ENT WARD-407	NEED TO CHANGE TONER	Shafiullah. R.	12a toner changed		Jeyasudha. V. - Medical Records	11/04/2023
Comp. Dt. : 12/04/2023								
Status : Completed								
1788	23040351	Medical Records	NEED TO CHANGE TONER	Jayaraj. J.	12A TONER CHANGED		Raj Kumar. K. - Medical Records	12/04/2023
1789	23040378	ENT WARD-407	PROBLEM IN TONER	Shafiullah. R.	12A TONER CHANGED		Jeyasudha. V. - Medical Records	12/04/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 13/04/2023								
Status : Completed								
1790	23040390	Female Ortho - Ward 402	NEED TO CHANGE TONER	Selvam. D.	12a toner changed		Gowri. S. - Medical Records	13/04/2023
Comp. Dt. : 15/04/2023								
Status : Completed								
1791	23040431	Medical Records	SYSTEM NOT WORKING	Shafiullah. R.	system working fine		Martin Prabu.V. - Medical Records	17/04/2023
Comp. Dt. : 17/04/2023								
Status : Completed								
1792	23040485	Paediatrics - Ward 308	SYSTEM NOT WORKING	Harikrishnan. R.	ups problem resolved.		Deepa. S. - Medical Records	19/04/2023
1793	23040486	Medical Records	NEED TO CHANGE NEW BARCODE STRICKER	Harikrishnan. R.	NEW BARCODE STRICKER CHANGED		Martin Prabu.V. - Medical Records	17/04/2023
1794	23040492	MEDICAL COLLEGE	NEED TO CHECK SYSTEN - AUDIO PROBLEM	Selvam. D.	AUDIO WORKING		Martin Prabu.V. - Medical Records	18/04/2023
Comp. Dt. : 24/04/2023								
Status : Completed								
1795	23040765	Female Surgery - Ward 206	NEED TO CHANGE TONER	Shafiullah. R.	12ATONER CHANGED		Pushparaj. J. - Medical Records	24/04/2023
1796	23040774	CASHCOUNTER IN RECEPTION	PRINTER NOT WORKING	Madhubalan. S.	10MTR RIBBON CHANGED		Iyyanar. D. - Medical Records	24/04/2023
Comp. Dt. : 25/04/2023								
Status : Completed								
1797	23040787	Female Ortho - Ward 401	SYSTEM NOT WORKING	Harikrishnan. R.	Power Cable Insert Properly.		Gowri. S. - Medical Records	25/04/2023
Comp. Dt. : 26/04/2023								
Status : Completed								
1798	23040870	Medical Records	NEED TO CHANGE TONER	Madhubalan. S.	12a toner changed		Raj Kumar. K. - Medical Records	27/04/2023
Comp. Dt. : 02/05/2023								
Status : Completed								
1799	23050014	Medical Records	SYSTEM NOT WORKING	Selvam. D.	RAM CLEAN REFIX		Basheer Ahamed Khan. C - Medical Records	02/05/2023
Comp. Dt. : 04/05/2023								
Status : Completed								
1800	23050119	SPECIAL OPD IN 2ND FLOOR	SYSTEM NOT WORKING - INTERCOM NO 1233	Shafiullah. R.	UPS RESET SWITCH NOW WORKING		Parasuraman. R. - Medical Records	04/05/2023
Comp. Dt. : 05/05/2023								

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
1801	23050181	SPECIAL OPD IN 2ND FLOOR	system not working - intercom no 1233	Selvam. D.	UPS POWERED ON		Prabhakaran. S. - Medical Records	05/05/2023
1802	23050182	Medical Records	NEED TO INTERCHANGE U P S	Harikrishnan. R.	INTERCHANGE UPS OPPOSITE SIDE FIX		Martin Prabu.V. - Medical Records	05/05/2023
1803	23050209	Paediatrics - Ward 308	SYSTEM NOT WORKING	Selvam. D.	SYSTEM WORKING FINE		Deepa. S. - Medical Records	06/05/2023
Comp. Dt. : 06/05/2023								
Status : Completed								
1804	23050226	Medical Records	MOUSE NOT WORKING	Jayaraj. J.	PS2 NEW MOUSE CHANGED		Basheer Ahamed Khan. C - Medical Records	06/05/2023
1805	23050231	SPECIAL OPD IN 2ND FLOOR	BARCODE PRINTER NOT WORKING	Shafiullah. R.	REFIX THE USB CABLE RECONNECT		Parasuraman. R. - Medical Records	06/05/2023
1806	23050247	Medical Records	NEED TO CHANGE TONER	Shafiullah. R.	12A TONER CHANGED		Raj Kumar. K. - Medical Records	06/05/2023
Comp. Dt. : 08/05/2023								
Status : Completed								
1807	23050292	Medical Records	NEED TO CHANGE TONER	Murugavel.R	12A Toner Changed.		Raj Kumar. K. - Medical Records	08/05/2023
Comp. Dt. : 09/05/2023								
Status : Completed								
1808	23050340	Female Ortho - Ward 402	NEED TO CHANGE TONER	Madhubalan. S.	12A TONER CHANGED		Gowri. S. - Medical Records	09/05/2023
Comp. Dt. : 11/05/2023								
Status : Completed								
1809	23050424	ENT WARD-407	PRINTER NOT WORKING	Madhubalan. S.	SOLINOD SWITCH SERVICED		Jeyasudha. V. - Medical Records	12/05/2023
1810	23050445	SPECIAL OPD IN 2ND FLOOR	BARCODE MACHINE NOT WORKING	Shafiullah. R.	BARCODE PRINTER WORKING FINE		Parasuraman. R. - Medical Records	12/05/2023
1811	23050459	Male Medical - Ward 303	NEED TO CHANGE TONER	Shafiullah. R.	12A TONER CHANGED		Mohanapriya. A. - Medical Records	12/05/2023
Comp. Dt. : 12/05/2023								
Status : Completed								
1812	23050481	SPECIAL OPD IN 2ND FLOOR	NEED TO CHANGE BARCODE STRICKER	Shafiullah. R.	NEW BARCODE STRICKER CHANGED		Parasuraman. R. - Medical Records	12/05/2023
1813	23050503	CASHCOUNTER IN RECEPTION	NEED TO CHANGE PRINTER RIBBON 2 NOS	Selvam. D.	10M RIBBON CHANGED		Iyyanar. D. - Medical Records	12/05/2023
Comp. Dt. : 13/05/2023								
Status : Completed								
1814	23050531	Medical Records	NEED TO CHANGE TONER	Prakash. P.	12a toner changed		Kumar. K. - Medical Records	13/05/2023

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 15/05/2023								
Status : Completed								
1815	23050562	SPECIAL OPD IN 2ND FLOOR	SYSTEM NOT WORKING	Shafiullah. R.	UPS RESET SYSTEM WORKING		Prabhakaran. S. - Medical Records	16/05/2023
1816	23050593	Male Surgery - Ward 204	NEED TO CHANGE TONER	Madhubalan. S.	12A TONER CHANGED		Praveena. V. - Medical Records	15/05/2023
Comp. Dt. : 17/05/2023								
Status : Completed								
1817	23050675	Male Ortho - Ward 403	PRINTER NOT WORKING	Selvam. D.	Paper pickup sensor cleaned and refixed		Gowri. S. - Medical Records	22/05/2023
Comp. Dt. : 18/05/2023								
Status : Completed								
1818	23050728	Medical Records	PROBLEM IN COMPLAINT SOFTWARE [TEST]	Shafiullah. R.	TESTING WORKING SMS FINE		Martin Prabu.V. - Medical Records	18/05/2023
1819	23050750	Paediatrics - Ward 308	NEED TO CHANGE TONER	Shafiullah. R.	12A TONER CHANGED		Deepa. S. - Medical Records	18/05/2023
Comp. Dt. : 19/05/2023								
Status : Completed								
1820	23050816	Medical Records	NEED TO CHANGE BARCODE STRICKER	Balachandar. A.	BARCODE STRICKER CHANGED		Martin Prabu.V. - Medical Records	19/05/2023
Comp. Dt. : 20/05/2023								
Status : Completed								
1821	23050833	Male Medical - Ward 304	PRINTER NOT WORKING	Selvam. D.	solinod switch serviced		Mohanapriya. A. - Medical Records	23/05/2023
Comp. Dt. : 22/05/2023								
Status : Completed								
1822	23050860	Female Surgery - Ward 206	C P U NOT WORKING	Shafiullah. R.	CPU WORKING FINE		Pushparaj. J. - Medical Records	24/05/2023
1823	23050861	Medical Records	NEED TO CHANGE TONER	Shafiullah. R.	12A TONER CHANGED		Raj Kumar. K. - Medical Records	22/05/2023
Comp. Dt. : 23/05/2023								
Status : Completed								
1824	23050895	ENT WARD-407	NEED TO CHANGE TONER	Selvam. D.	already toner changed. user raised a wrong complaint		Jeyasudha. V. - Medical Records	23/05/2023
Comp. Dt. : 25/05/2023								
Status : Completed								
1825	23050983	Female Medical - Ward 306	NEED TO CHANGE TONER	Prakash. P.	12A TONER CHANGED		Amala. U. - Medical Records	25/05/2023
1826	23051006	Medical Records	NEED TO CHANGE TONER	Madhubalan. S.	12A TONER CHANGED		Raj Kumar. K. - Medical Records	25/05/2023

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 29/05/2023								
Status : Completed								
1827	23051166	Female Surgery - Ward 206	NEED TO CHANGE TONER	Selvam. D.	12A toner changed		Pushparaj. J. - Medical Records	29/05/2023
Comp. Dt. : 01/06/2023								
Status : Completed								
1828	23060021	Female Ortho - Ward 401	SYSTEM NOT WORKING	Shafiullah. R.	New UPS Replaced. Ward 402.		Gowri. S. - Medical Records	05/06/2023
Comp. Dt. : 02/06/2023								
Status : Completed								
1829	23060073	Medical Records	NEED TO CHANGE PRINTER TONNER	Balachandar. A.	PRINTER TONER CHANGED		Basheer Ahamed Khan. C - Medical Records	02/06/2023
Comp. Dt. : 06/06/2023								
Status : Completed								
1830	23060200	Obstetrics - Ward 208	PRINTER NOT WORKING	Selvam. D.	printer working fine		Jerina. M. - Medical Records	06/06/2023
1831	23060205	Male Medical - Ward 304	NEED TO CHANGE TONER	Balachandar. A.	TONER CHANGED		Mohanapriya. A. - Medical Records	07/06/2023
Comp. Dt. : 07/06/2023								
Status : Completed								
1832	23060214	Medical Records	NET WORK PROBLEM	Prakash. P.	8 port Switch Power Cable Unplugged , cable plugged Working		Martin Prabu.V. - Medical Records	07/06/2023
Comp. Dt. : 08/06/2023								
Status : Completed								
1833	23060288	Obstetrics - Ward 208	NEED TO CHANGE TONER	Harikrishnan. R.	12A Toner Changed.		Jerina. M. - Medical Records	08/06/2023
Comp. Dt. : 09/06/2023								
Status : Completed								
1834	23060328	Male Medical - Ward 304	PRINTER NOT WORKING	Shafiullah. R.	PRINTER SETUP REINSTALLED		Mohanapriya. A. - Medical Records	09/06/2023
Comp. Dt. : 10/06/2023								
Status : Completed								
1835	23060368	Female Ortho - Ward 402	SYSTEM NOT WORKING	Selvam. D.	sytem working fine		Gowri. S. - Medical Records	12/06/2023
Comp. Dt. : 12/06/2023								
Status : Completed								
1836	23060400	Medical Records	NEED TOCHANGE TONER	Shafiullah. R.	12A TONER CHANGED		Raj Kumar. K. - Medical Records	12/06/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 13/06/2023 Status : Completed								
1837	23060456	Medical Records	NEED TO REFIL PRINTER INK	Selvam. D.	INK REFILLED		Iswin Joseph.M. - Medical Records	13/06/2023
Comp. Dt. : 15/06/2023 Status : Completed								
1838	23060523	Female Medical - Ward 305	PRINTER INTER CHANGE WORK.ROOM NO-306 TO 305 (1316)	Shafiullah. R.	ROOM NO-306 TO 305 PRINTER INTERCHANGE APPROVED BY MARTIN PRABU		Amala. U. - Medical Records	15/06/2023
1839	23060529	ENT WARD-407	UPS NOT WORKIG	Harikrishnan. R.	UPS Restarted.		Jeyasudha. V. - Medical Records	15/06/2023
1840	23060569	Obstetrics - Ward 207	MEDPLUS NOT WORKING	Shafiullah. R.	MEDPLUS WORKING		Jerina. M. - Medical Records	16/06/2023
Comp. Dt. : 16/06/2023 Status : Completed								
1841	23060579	Obstetrics - Ward 208	PRINTER NOT WORKING	Shafiullah. R.	PRINTER POWER SWITCH ON		Jerina. M. - Medical Records	16/06/2023
1842	23060600	PSYCHIATRY WARD	(1411) PRINTER NOT WORKING	Shafiullah. R.	PAPER JAM CLEAR PRINTER WORKING FINE		Muthazhagi. S. - Medical Records	16/06/2023
Comp. Dt. : 19/06/2023 Status : Completed								
1843	23060660	Medical Records	NEED TO CHANGE TONER	Shafiullah. R.	12A TONER CHANGED		Raj Kumar. K. - Medical Records	19/06/2023
Comp. Dt. : 20/06/2023 Status : Completed								
1844	23060691	Female Ortho - Ward 402	NEED TO CHANGE TONER	Balachandar. A.	TONER CHANGED		Gowri. S. - Medical Records	20/06/2023
1845	23060727	Female Ortho - Ward 402	MEDPLUS NOT WORKING - ALL WARDS IN IV FLOOR ALSO NET PROBLEM	Prakash. P.	Network problem fixed		Gowri. S. - Medical Records	20/06/2023
Comp. Dt. : 22/06/2023 Status : Completed								
1846	23060812	SPECIAL OPD IN 2ND FLOOR	NEED TO CHECK BARCODE STRICKER - STUCK	Shafiullah. R.	REFIX THE STRICKER		Punitha. P. - Medical Records	22/06/2023
1847	23060824	Medical Records	U P S NOT WORKING	Jayaraj. J.	reset done		Iswin Joseph.M. - Medical Records	28/06/2023
Comp. Dt. : 24/06/2023 Status : Completed								
1848	23060903	Male Surgery - Ward 204	NEED TO CHANGE TONER	Shafiullah. R.	12A TONER CHANGED		Veena. V. - Medical Records	24/06/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 26/06/2023 Status : Completed								
1849	23060941	Medical Records	NEED TO CHANGE BARCODE PRINTER RIBBON	Balachandar. A.	BARCODE PRINTER RIBBON CHANGED		Martin Prabu.V. - Medical Records	26/06/2023
1850	23060964	ENT WARD-407	NEED TO CHANGE TONER	Jayaraj. J.	TONER CHANGED		Jeyasudha. V. - Medical Records	26/06/2023
Comp. Dt. : 28/06/2023 Status : Completed								
1851	23061065	Medical Records	NEED TO CHANGE TONER	Selvam. D.	12A toner changed		Raj Kumar. K. - Medical Records	28/06/2023
1852	23061074	Medical Records	NEED TO CHANGE BARCODE STRICKER	Selvam. D.	New barcode sticker changed		Raj Kumar. K. - Medical Records	28/06/2023
Comp. Dt. : 30/06/2023 Status : Completed								
1853	23061090	Male Psychiatry - Ward 405	SYSTEM - DISPLAY PROBLEM	Shafiullah. R.	DISPLAY SETTING CHANGED		Muthazhagi. S. - Medical Records	30/06/2023
1854	23061101	Female Surgery - Ward 206	NEED TO CHANGE TONER	Shafiullah. R.	12A TONER CHANGED		Pushparaj. J. - Medical Records	30/06/2023
1855	23061104	Medical Records	U P S NOT WORKING	Murugavel.R	New ups changed		Raj Kumar. K. - Medical Records	30/06/2023
1856	23061111	Male Medical - Ward 304	NEED TO CHANGE TONER	Harikrishnan. R.	12A Toner Changed.		Mohanapriya. A. - Medical Records	30/06/2023
Dept Name : MICROBIOLOGY - Computer Department Comp. Dt. : 08/06/2022 Status : Completed								
1857	22060287	MICROBIOLOGY	PRINTER NOT WORKING	Selvam. D.	PRINTER DRIVER REINSTALLED		Punitha. P. - MICROBIOLOGY	08/06/2022
Comp. Dt. : 13/06/2022 Status : Completed								
1858	22060440	MICROBIOLOGY IN COLLEGE	SYSTEM NOT WORKING IN A H S ROOM [PROBLEM IN STUDENT ATTENDANCE]	Shafiullah. R.	software build updated..		Raffik Moideen. M. - SMV Allied Health Sciences	15/06/2022
Comp. Dt. : 30/06/2022 Status : Completed								
1859	22061109	MICROBIOLOGY	SYSTEM NOT WORKING - SLOW PROBLEM	Jayaraj. J.	HDD PROBLEM	HDD CHANGED	Karthik. S. - MICROBIOLOGY	06/07/2022
Comp. Dt. : 15/07/2022 Status : Completed								
1860	22070568	MICROBIOLOGY	NEED TO REPLACE SYSTEM & PRINTER	Shafiullah. R.	INFOM TO LAB GIVE PURCHASE NEW CATRAGIE		Karthik. S. - MICROBIOLOGY	15/07/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 06/09/2022 Status : Completed								
1861	22090240	MICROBIOLOGY	SYSTEM NOT WORKING	Selvam. D.	system working fine		Ilakkiya. V. - MICROBIOLOGY	06/09/2022
Comp. Dt. : 12/09/2022 Status : Completed								
1862	22090456	microbiology lab	NEED TO CHANGE CARTRIDGE	Balachandar. A.	instrument printer so informed to purchase manger		Karthik. S. - MICROBIOLOGY	13/09/2022
Comp. Dt. : 13/10/2022 Status : Completed								
1863	22100386	MICROBIOLOGY	NEED TO CHANGE PRINTER FROM ROOM NO 43 TO NEXT ROOM	Selvam. D.	printer inter changed		Karthik. S. - MICROBIOLOGY	13/10/2022
Comp. Dt. : 08/11/2022 Status : Completed								
1864	22110268	microbiology lab	NETWORK TRANSFER TO ANOTHER SYSTEM (ROOM NO.43)	Selvam. D.	ip assigned to another system		Karthik. S. - MICROBIOLOGY	09/11/2022
Comp. Dt. : 10/12/2022 Status : Completed								
1865	22120457	MICROBIOLOGY	NEED TO CHANGE TONER	Valamburi. R.	CATRIDGE CHANGED		Aruljothi. S. - MICROBIOLOGY	10/12/2022
Comp. Dt. : 10/02/2023 Status : Completed								
1866	23020395	microbiology opd lab	SYSTEM NETWORK SLOW	Raja.B	network working		Vinothini. V. - MICROBIOLOGY	15/02/2023
Comp. Dt. : 17/02/2023 Status : Completed								
1867	23020695	MICROBIOLOGY IN COLLEGE	SYSTEM & NETWORK PROBLEM - NEED TO CHECK	Madhubalan. S.	SYSTEM WORKING FINE AND PACH CABLE REFIXED WORKING FINE		Nivethighaa. G. - MICROBIOLOGY	23/02/2023
Comp. Dt. : 25/02/2023 Status : Completed								
1868	23020992	MICROBIOLOGY	SYSTEM - KEYBOARD ERROR	Selvam. D.	keyboard interchanged		Karthik. S. - MICROBIOLOGY	27/02/2023
Comp. Dt. : 01/03/2023 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1869	23030039	MICROBIOLOGY	NEED TO CHANGE TONER	Shafiullah. R.	12A TONER CHANGED		Aruljothi. S. - MICROBIOLOGY	01/03/2023
Comp. Dt. : 06/03/2023 Status : Completed								
1870	23030205	MICROBIOLOGY	NEED TO CHANGE NET CONNECTION - ANOTHER SYSTEM	Murugavel.R	CHANGED IP ASSIGN		Karthik. S. - MICROBIOLOGY	06/03/2023
Comp. Dt. : 06/04/2023 Status : Completed								
1871	23040208	Blood Collection Centre	NEED TO CHANGE TONER FOR COUNTER NO 8	Selvam. D.	12A toner changed		Buvana. C. - MICROBIOLOGY	06/04/2023
Comp. Dt. : 17/04/2023 Status : Completed								
1872	23040537	Reception	NEED TO CHANGE TONER COUNTER NO 8	Shafiullah. R.	12A TONER CHANGED		Buvana. C. - MICROBIOLOGY	17/04/2023
Comp. Dt. : 13/05/2023 Status : Completed								
1873	23050527	MICROBIOLOGY	SYSTEM SLOW PROBLEM	Selvam. D.	system working fine		Karthik. S. - MICROBIOLOGY	13/05/2023
Comp. Dt. : 26/05/2023 Status : Completed								
1874	23051045	MICROBIOLOGY	PRINTER NOT WORKING	Selvam. D.	paper jam cleared		Kohila. S. - MICROBIOLOGY	26/05/2023
Comp. Dt. : 10/06/2023 Status : Completed								
1875	23060348	MICROBIOLOGY	NEED TO CHECK SYSTEM NOT WORKING - MEDPLUS SLOW PROBLEM AND KEYBOARD PROBLEM	Balachandar. A.	antivirus scanned and new usb keyboard changed		Karthik. S. - MICROBIOLOGY	10/06/2023
Comp. Dt. : 12/06/2023 Status : Completed								
1876	23060377	MICROBIOLOGY	KEY BOARD NOT WORKING	Selvam. D.	ps2 keyboard changed		Vinothini. V. - MICROBIOLOGY	12/06/2023
Dept Name : MS Office - Computer Department Comp. Dt. : 26/05/2022 Status : Completed								
1877	22050983	MS Office	NEED TO CHANGE TONER FOR LASER PRINTER	Selvam. D.	12A TONER CHANGED		Ianikandan. A. - MS	26/05/2022
Comp. Dt. : 07/06/2022								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
1878	22060236	MS Office	NEED TO CHECK UPS & SYSTEM - NOT WORKING	Balachandar. A.	lithium ups changed and system working fine		Nageswari. N. - MS Office	08/06/2022
Comp. Dt. : 13/06/2022								
Status : Completed								
1879	22060481	MS Office	NEED TO CHECK KEY BOARD - NOT WORKING	Madhubalan. S.	KEYBOARD REFIXED		Nageswari. N. - MS Office	13/06/2022
Comp. Dt. : 18/07/2022								
Status : Completed								
1880	22070683	MS Office	PRINTER NOT WORKING	Selvam. D.	pick roller cleaned and refixed		Hemavathi. P. - MS Office	20/07/2022
Comp. Dt. : 03/08/2022								
Status : Completed								
1881	22080114	MS Office	PRINTER NOT WORKING	Prakash. P.	Paper pick up roller cleaned and refixed		Hemavathi. P. - MS Office	03/08/2022
Comp. Dt. : 17/08/2022								
Status : Completed								
1882	22080550	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	MEDPLUS SOFTWARE NOT WORKING	Selvam. D.	software working fine		Pushpa. V. - MS Office	18/08/2022
Comp. Dt. : 02/11/2022								
Status : Completed								
1883	22110001	MS Office	CPU NOT WORKING	Jayaraj. J.	POWER CABLE REFIX		Nageswari. N. - MS Office	02/11/2022
Comp. Dt. : 07/11/2022								
Status : Completed								
1884	22110188	MS Office	CPU NOT WORKING	Balachandar. A.	SYSTEM INTERMEDIATE NO POWER ON,SYSTEM NOT RECEIVED		Nageswari. N. - MS Office	10/11/2022
Comp. Dt. : 30/12/2022								
Status : Completed								
1885	22121372	MS Office	SYSTEM NO POWER ON	Jayaraj. J.	SYSTEM WORKING		Nageswari. N. - MS Office	30/12/2022
Comp. Dt. : 01/03/2023								
Status : Completed								
1886	23030003	MS Office	SYSTEM NT WORKING	Shafiullah. R.	power switch clean and fixed		Nageswari. N. - MS Office	01/03/2023
Comp. Dt. : 20/03/2023								
Status : Completed								

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1887	23030829	MS Office	PRINTER NOT WORKING	Selvam. D.	printer working fine		Rajalakshmi. G. - MS Office	22/03/2023
	Comp. Dt. : 03/04/2023							
	Status : Completed							
1888	23040074	MS Office	SYSTEM NOT WORKING - POWER PROBLEM	Selvam. D.	MONITOR POWER CABLE REFIX		Rajalakshmi. G. - MS Office	03/04/2023
	Comp. Dt. : 11/04/2023							
	Status : Completed							
1889	23040291	MS Office	C P U NOT WORKING	Prakash. P.	power cable refixed		Rajalakshmi. G. - MS Office	11/04/2023
	Comp. Dt. : 28/04/2023							
	Status : Completed							
1890	23040959	MS Office	MONITOR NOT WORKING - NEED TO CHECK	Balachandar. A.	new aoc 18.5 monitor changed..		Nageswari. N. - MS Office	29/04/2023
	Comp. Dt. : 16/05/2023							
	Status : Completed							
1891	23050623	MS Office	SYSTEM NOT WORKING	Shafiullah. R.	power switch on		Soussila. M. - Clinical Department	16/05/2023
	Comp. Dt. : 10/06/2023							
	Status : Completed							
1892	23060369	MS Office	NEED TO CHECK U P S [2NOS] PROBLEM	Selvam. D.	ups reset done		Kalaarasi. R. - Director Office	10/06/2023
	Comp. Dt. : 14/06/2023							
	Status : Completed							
1893	23060490	MS Office	PRINTER NOT WORKING	Shafiullah. R.	PRINTER PAPER JAM REMOVED /12A TONER CHANGED		Nageswari. N. - MS Office	14/06/2023
	Dept Name : Nephrology - Computer Department							
	Comp. Dt. : 31/05/2022							
	Status : Completed							
1894	22051111	DIALYSIS NEW UNIT IN 1ST FLOOR	NEED TO CHANGE TONER	Madhubalan. S.	12A TONER CHANGED		Kamal. B. - Nephrology	31/05/2022
	Comp. Dt. : 13/06/2022							
	Status : Completed							
1895	22060476	DIALYSIS NEW UNIT IN 1ST FLOOR	PROBLEM IN SYSTEM CABLE	Shafiullah. R.	NETWORKING WORKING FINE		Kamal. B. - Nephrology	13/06/2022
	Comp. Dt. : 30/06/2022							
	Status : Completed							


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1896	22061120	DIALYSIS NEW UNIT IN 1ST FLOOR	NEED TO CHANGE TONER	Selvam. D.	88A toner changed		Kamal. B. - Nephrology	30/06/2022
	Comp. Dt. : 04/07/2022 Status : Completed							
1897	22070072	DIALYSIS NEW UNIT IN 1ST FLOOR	MOUSE NOT WORKING	Balachandar. A.	usb Cable unplugged Working		Kamal. B. - Nephrology	04/07/2022
	Comp. Dt. : 03/08/2022 Status : Completed							
1898	22080132	DIALYSIS NEW UNIT IN 1ST FLOOR	MOUSE NOT WORKING	Selvam. D.	USB mouse changed		Kamal. B. - Nephrology	04/08/2022
	Comp. Dt. : 17/08/2022 Status : Completed							
1899	22080490	DIALYSIS NEW UNIT IN 1ST FLOOR	NEED TO CHANGE PRINTER TONNER	Valamburi. R.	TONER CHANGED		Kamal. B. - Nephrology	17/08/2022
	Comp. Dt. : 05/10/2022 Status : Completed							
1900	22100081	DIALYSIS NEW UNIT IN 1ST FLOOR	NEED TO CHANGE TONER	Jayaraj. J.	TONER CHANGED		Kamal. B. - Nephrology	06/10/2022
	Comp. Dt. : 03/11/2022 Status : Completed							
1901	22110099	DIALYSIS NEW UNIT IN 1ST FLOOR	CHANGE PRINTER TONER	Madhubalan. S.	PRINTER TONER CHANGED		Kamal. B. - Nephrology	04/11/2022
	Comp. Dt. : 05/12/2022 Status : Completed							
1902	22120167	DIALYSIS NEW UNIT IN 1ST FLOOR	NEED TO CHANGE TONER	Shafiullah. R.	12A TONER CHANGED		Kamal. B. - Nephrology	05/12/2022
	Comp. Dt. : 02/02/2023 Status : Completed							
1903	23020071	DIALYSIS NEW UNIT IN 1ST FLOOR	NEED TO CHANGE TONER	Prakash. P.	12A toner changed		Kamal. B. - Nephrology	04/02/2023
	Comp. Dt. : 14/03/2023 Status : Completed							
1904	23030541	Nephrology	NET WORK PROBLEM - NEED TO CHECK URGENT	Selvam. D.	patch cable refixed		Ravikumar. P. - Nephrology	14/03/2023
	Comp. Dt. : 31/03/2023 Status : Completed							
1905	23031362	DIALYSIS NEW UNIT IN 1ST FLOOR	NEED TO CHANGE TONER	Shafiullah. R.	88A TONER CHANGED		Kamal. B. - Nephrology	31/03/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 07/06/2023 Status : Completed								
1906	23060218	DIALYSIS NEW UNIT IN 1ST FLOOR	NEED TO CHANGE TONER	Jayaraj. J.	12A TONER CHANGED		Kamal. B. - Nephrology	07/06/2023
Dept Name : NEUROLOGY - Computer Department Comp. Dt. : 09/05/2022 Status : Completed								
1907	22050257	EEG	SYSTEM NOT WORKING	Balachandar. A.	HARDDISK PROBLEM,NEW HADD CHANGED,OS INSTALLED..		Vasuki. P. - NEUROLOGY	18/05/2022
Comp. Dt. : 21/05/2022 Status : Completed								
1908	22050795	EEG	PRINTER NOT WORKING	Selvam. D.	Printer driver installed		Vasuki. P. - NEUROLOGY	23/05/2022
Comp. Dt. : 09/07/2022 Status : Completed								
1909	22070373	EEG	NEED TO CHECK PORTABLE LAPTOP FOR N C S MACHINE - NOT WORKING	Prakash. P.	CHECKED AND WORKING FINE		Vasuki. P. - NEUROLOGY	14/07/2022
Comp. Dt. : 13/07/2022 Status : Completed								
1910	22070495	EEG	C P U NOT WORKING	Selvam. D.	system working fine		Vasuki. P. - NEUROLOGY	13/07/2022
Comp. Dt. : 13/10/2022 Status : Completed								
1911	22100387	EEG	SYSTEM NOT WORKING	Valamburi. R.	VGA CABLE REFIXED WORKING FINE		Vasuki. P. - NEUROLOGY	13/10/2022
Comp. Dt. : 15/10/2022 Status : Completed								
1912	22100496	EEG	EEG MACHINE HP TONNER NEED TO BE CHANGE (MODEL-1007)	Shafiullah. R.	88A TONER CHANGED		Vasuki. P. - NEUROLOGY	17/10/2022
Comp. Dt. : 29/12/2022 Status : Completed								
1913	22121341	EEG	PRINTER NOT WORKING	Balachandar. A.	setting changed		Vasuki. P. - NEUROLOGY	30/12/2022
Comp. Dt. : 04/01/2023 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1914	23010180	EEG	HP LASER PRINTER -TONER NEED TO BE CHANGE	Shafiullah. R.	88A TONER CHANGED		Vasuki. P. - NEUROLOGY	05/01/2023
Comp. Dt. : 08/04/2023 Status : Completed								
1915	23040241	EEG	NEED MOUSE PAD 2 NOS	Selvam. D.	Mouse pad changed		Vasuki. P. - NEUROLOGY	10/04/2023
Comp. Dt. : 13/04/2023 Status : Completed								
1916	23040414	EEG	PRINTER NOT WORKING	Jayaraj. J.	POWER CABLE REFIXED		Vasuki. P. - NEUROLOGY	13/04/2023
Comp. Dt. : 16/04/2023 Status : Completed								
1917	23040478	EEG	C P U NOT WORKING - NEED TO CHECK SYSTEM	Madhubalan. S.	system working fine		Vasuki. P. - NEUROLOGY	17/04/2023
Comp. Dt. : 19/04/2023 Status : Completed								
1918	23040611	EEG	NEED TO CHANGE TONER	Shafiullah. R.	88A TONER CHANGED		Vasuki. P. - NEUROLOGY	19/04/2023
Comp. Dt. : 24/04/2023 Status : Completed								
1919	23040769	EEG	PRINTER NOT WORKING	Shafiullah. R.	Printer Restarted		Vasuki. P. - NEUROLOGY	25/04/2023
Comp. Dt. : 13/05/2023 Status : Completed								
1920	23050534	EEG	NEED TO CHANGE TONER	Jayaraj. J.	setting changed		Vasuki. P. - NEUROLOGY	13/05/2023
Comp. Dt. : 26/06/2023 Status : Completed								
1921	23060938	EEG	PRINTER NOT WORKING	Jayaraj. J.	PRINTER SETTING CHANGED		Vasuki. P. - NEUROLOGY	26/06/2023
Dept Name : Nursing Office - Computer Department Comp. Dt. : 04/05/2022 Status : Completed								
1922	22050106	Nursing Office	SYSTEM NOT WORKING	Valamburi. R.	restarts the system		Muthazhagi. A. - Nursing Office	05/05/2022
Comp. Dt. : 23/05/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1923	22050836	Nursing Office	SYSTEM NOT WORKING	Madhubalan. S.	SYSTEM WORKING FINE		Muthazhagi. A. - Nursing Office	23/05/2022
	Comp. Dt. : 20/06/2022							
	Status : Completed							
1924	22060698	Nursing Office	SYSTEM NOT WORKING	Selvam. D.	System working fine		Muthazhagi. A. - Nursing Office	20/06/2022
	Comp. Dt. : 27/06/2022							
	Status : Completed							
1925	22060941	Nursing Office	SYSTEM NOT WORKING	Selvam. D.	usb keyboard refixed		Muthazhagi. A. - Nursing Office	27/06/2022
	Comp. Dt. : 13/07/2022							
	Status : Completed							
1926	22070508	Nursing Office	SYSTEM NOT WORKING	Selvam. D.	Temp cleared and tested system working fine		Muthazhagi. A. - Nursing Office	13/07/2022
	Comp. Dt. : 02/08/2022							
	Status : Completed							
1927	22080083	Casualty	PRINTER NOT WORKING	Selvam. D.	printer working fine		Sudha.L. - Nursing Office	03/08/2022
	Comp. Dt. : 03/08/2022							
	Status : Completed							
1928	22080142	Nursing Office	SYSTEM NOT WORKING	Selvam. D.	settings changed		Muthazhagi. A. - Nursing Office	04/08/2022
	Comp. Dt. : 04/08/2022							
	Status : Completed							
1929	22080145	Nursing Office	SYSTEM NOT WORKING	Selvam. D.	excel seeting changed		Muthazhagi. A. - Nursing Office	04/08/2022
	Comp. Dt. : 10/08/2022							
	Status : Completed							
1930	22080379	Female Medical - Ward 305	C P U & SYSTEM NOT WORKING	Selvam. D.	UPS power on tested the system working fine		Leena Grace. B. - Nursing Office	10/08/2022
	Comp. Dt. : 20/08/2022							
	Status : Completed							
1931	22080680	Nursing Office	PRINTER NOT WORKING	Selvam. D.	system restarts		Muthazhagi. A. - Nursing Office	20/08/2022
	Comp. Dt. : 29/08/2022							
	Status : Completed							
1932	22080988	Nursing Office	NEED TO CHANGE TONER	Balachandar. A.	TONER CHANGED		Muthazhagi. A. - Nursing Office	30/08/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 08/09/2022 Status : Completed								
1933	22090333	SPECIAL WARD---B	PRINTER NOT WORKING	Shafiullah. R.	TONER REFIX AND DOOR ADJUST REFIX		Tamilarasi.C. - Nursing Office	09/09/2022
Comp. Dt. : 10/09/2022 Status : Completed								
1934	22090409	Male Ortho - Ward 404	PRINTER NOT WORKING	Shafiullah. R.	PRINTER TONER REFIX		Chandralekha. S. - Nursing Office	10/09/2022
Comp. Dt. : 13/09/2022 Status : Completed								
1935	22090485	SPECIAL WARD---B	PRINTER NOT WORKING	Madhubalan. S.	SYSTEM RESTATE PRINTER WORKING FINE		Tamilarasi.C. - Nursing Office	13/09/2022
Comp. Dt. : 04/11/2022 Status : Completed								
1936	22110143	Nursing Office	CHANGE PRINTER TONER	Balachandar. A.	PRINTER TONER CHANGED		Muthazhagi. A. - Nursing Office	04/11/2022
Comp. Dt. : 15/11/2022 Status : Completed								
1937	22110626	Nursing Office	SYSTEM PROBLEM	Balachandar. A.	power cable refixed		Muthazhagi. A. - Nursing Office	17/11/2022
Comp. Dt. : 23/11/2022 Status : Completed								
1938	22111010	Nursing Office	CHANGE PRINTER TONER	Balachandar. A.	PRINTER TONER CHANGED		Muthazhagi. A. - Nursing Office	23/11/2022
Comp. Dt. : 10/12/2022 Status : Completed								
1939	22120478	Nursing Office	SYSTEM KEYBOARD IS VERY HARD TO USE	Madhubalan. S.	KEYBOARD WORKING		Muthazhagi. A. - Nursing Office	12/12/2022
Comp. Dt. : 12/12/2022 Status : Completed								
1940	22120538	Nursing Office	SYSTEM MOUSE NOT WORKING	Jayaraj. J.	MOUSE USB CABLE REFIX		Muthazhagi. A. - Nursing Office	12/12/2022
Comp. Dt. : 18/01/2023 Status : Completed								
1941	23010636	Nursing Office	MOUSE NOT WORKING	Prakash. P.	new USb Mouse Changed		Muthazhagi. A. - Nursing Office	18/01/2023
Comp. Dt. : 31/03/2023 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1942	23031348	Nursing Office	NEED TO CHANGE TONER	Madhubalan. S.	12A TONER CHANGED		Muthazhagi. A. - Nursing Office	31/03/2023
Comp. Dt. : 27/04/2023 Status : Completed								
1943	23040908	Male Surgery - Ward 202	PRINTER NOT WORKING - PAPER JAM	Shafiullah. R.	PAPER JAM CLEAR		Kowsalya. G. - Male Surgery	27/04/2023
Comp. Dt. : 08/05/2023 Status : Completed								
1944	23050262	Nursing Office	DISPLAY PROBLEM IN SYSTEM	Balachandar. A.	monitor cable refixed		Muthazhagi. A. - Nursing Office	12/05/2023
Comp. Dt. : 22/06/2023 Status : Completed								
1945	23060800	Nursing Office	SYSTEM NOT WORKING	Balachandar. A.	system working fine		Muthazhagi. A. - Nursing Office	22/06/2023
Dept Name : Nutrition & Dietetics - Computer Department Comp. Dt. : 03/06/2022 Status : Completed								
1946	22060134	DIET DEPARMENT	MOUSE NOR WORKING	Shafiullah. R.	MOUSE PAD GIVEN		Shanmugapriya. J. - Nutrition & Dietetics	04/06/2022
Comp. Dt. : 25/06/2022 Status : Completed								
1947	22060927	DIET DEPARMENT	PRINTER NOT WORKING	Madhubalan. S.	SYSTEM RESTATED THE PRINTER WILL BE WORKING FINE		Krishna Priya. E. - Nutrition & Dietetics	25/06/2022
Comp. Dt. : 28/06/2022 Status : Completed								
1948	22061005	DIET DEPARMENT	KEYBOARD NOT WORKING	Selvam. D.	OLD KEYBOARD CHANGED WORKING FINE		Shanmugapriya. J. - Nutrition & Dietetics	28/06/2022
Dept Name : OPD - Computer Department Comp. Dt. : 04/05/2022 Status : Completed								
1949	22050115	DENTAL OPD -2ND FLOOR	SYSTEM NOT WORKING	Shafiullah. R.	REFIX USB CABLE REFIXIED		Lakshmi Devi. R. - OPD	05/05/2022
Comp. Dt. : 06/05/2022 Status : Completed								
1950	22050183	Paediatrics - OPD	SYSTEM NOT WORKING IN DEMO ROOM	Shafiullah. R.	ups not on now working		Yamala.D. - OPD	06/05/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 20/05/2022								
Status : Completed								
1951	22050764	GASTROENTROLOGY OPD-2ND FLOOR	NEED TO CHANGE TONER - OPD NO 225	Selvam. D.	88A toner changed		Suvitha. R. - OPD	21/05/2022
Comp. Dt. : 11/06/2022								
Status : Completed								
1952	22060418	Male Ortho - Ward 403	SOFTWARE & PRINTER NOT WORKING	Shafiullah. R.	SOFTWARE AND PRINTER WORKING FINE		Vanitha. P. - Male Ortho Ward	11/06/2022
Comp. Dt. : 16/06/2022								
Status : Completed								
1953	22060599	DENTAL OPD -2ND FLOOR	NEED TO CHECK NET CONNECTION - NOT WORKING	Balachandar. A.	checked working fine..		Lakshmi Devi. R. - OPD	16/06/2022
Comp. Dt. : 24/06/2022								
Status : Completed								
1954	22060879	DENTAL OPD -2ND FLOOR	U P S PROBLEM	Selvam. D.	lithium battery changed		Lakshmi Devi. R. - OPD	29/06/2022
Comp. Dt. : 29/06/2022								
Status : Completed								
1955	22061078	UROLOGY--OPD	SYSTEM NOT WORKING - OPD NO 222	Shafiullah. R.	UPS PROBLEM LITHIUM BATTERY CHANGED		Lavanya. M. - OPD	02/07/2022
Comp. Dt. : 04/07/2022								
Status : Completed								
1956	22070116	GASTROENTROLOGY OPD-2ND FLOOR	NEED TO CHANGE TONER - OPD 225	Shafiullah. R.	88A TONER CHANGED		Suvitha. R. - OPD	04/07/2022
Comp. Dt. : 07/07/2022								
Status : Completed								
1957	22070259	IVF ART CLINIC-INSIDE OF OG OPD(NO.68)	SYSTEM NOT WORKING [GEETHA MADAM]	Balachandar. A.	system working fine		Rajasekari. R. - OPD	13/07/2022
1958	22070281	OG-OPD	BIOAPSY ROOM SYSTEM DISPLAYING "ERROR"	Jayaraj. J.,Balachandar. A.,Madhubalan. S.	hdd problem,smps and hdd changed os installed,colspro software installed		Velangkanni. K. - OPD	26/07/2022
Comp. Dt. : 26/07/2022								
Status : Completed								
1959	22070969	Surgery OPD	NEED TO CHECK PROJECTOR - NOT WORKING IN DEMO ROOM	Jayaraj. J.	POWER CABLE CONNCTED		Indhira. M. - OPD	26/07/2022
Comp. Dt. : 27/07/2022								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
	Status : Completed							
1960	22071009	OG-OPD	BIOPSY ROOM MOUSE NOT WORKING	Balachandar. A.	NEW PS2 MOUSE CHANGED		Velangkanni. K. - OPD	27/07/2022
	Comp. Dt. : 05/08/2022							
	Status : Completed							
1961	22080210	SPECIAL OPD	NEED TO CHANGE TONER - SPECIAL OPD 225	Shafiullah. R.	88A TONER CHANGED		Suvitha. R. - OPD	06/08/2022
	Comp. Dt. : 23/08/2022							
	Status : Completed							
1962	22080744	PLASTIC SURGERY OPD-223	PRINTER NOT WORKING - OPD NO 214	Balachandar. A.	Power cable refixed		Lakshmidevi. A - OPD	23/08/2022
	Comp. Dt. : 25/08/2022							
	Status : Completed							
1963	22080832	DENTAL OPD -2ND FLOOR	PRINTER NOT WORKING	Valamburi. R.	toner changed		Kanakarani. R. - OPD	25/08/2022
	Comp. Dt. : 26/08/2022							
	Status : Completed							
1964	22080893	PLASTIC SURGERY OPD-223	SYSTEM & PRINTER NOT WORKING	Shafiullah. R.	monitor power cable refix		Lakshmidevi. A - OPD	26/08/2022
	Comp. Dt. : 02/09/2022							
	Status : Completed							
1965	22090093	ENT OPD	ENDOSCOPE PRINTER NOT WORKING	Madhubalan. S.	ink filled tested the printer working fine		Ezhilarasi. M. - OPD	02/09/2022
	Comp. Dt. : 03/09/2022							
	Status : Completed							
1966	22090122	PSYCHIATRY OPD	NEED TO CHANGE TONER - ROOM NO 75	Jayaraj. J.	toner changed		Bhuvaneswari. G. - P.H.C. - Tiruvonnainallur	03/09/2022
	Comp. Dt. : 07/09/2022							
	Status : Completed							
1967	22090283	DENTAL OPD -2ND FLOOR	PROBLEM IN U P S	Selvam. D.	UPS CHANGED		Kanakarani. R. - OPD	14/09/2022
	Comp. Dt. : 16/09/2022							
	Status : Completed							
1968	22090625	ENT OPD	SYSTEM NOT WORKING	Jayaraj. J.	RAM CLEAN AND REFIXED		Ezhilarasi. M. - OPD	16/09/2022
	Comp. Dt. : 17/09/2022							
	Status : Completed							


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1969	22090674	ENT OPD	SYSTEM NOT WORKING - ENDOSCOPY SYSTEM	Valamburi. R.	NEW SMPS CHANGED		Ezhilarasi. M. - OPD	17/09/2022
	Comp. Dt. : 19/09/2022							
	Status : Completed							
1970	22090718	Obstetrics & Gynecology - OPD	SYSTEM NOT WORKING	Balachandar. A.	POWER CABLE REFIX		Velangkanni. K. - OPD	22/09/2022
	Comp. Dt. : 24/09/2022							
	Status : Completed							
1971	22090968	OG-OPD	SYSTEM NOT WORKING [HOD SYSTEM]	Madhubalan. S.	SYSTEM WORKING FINE		Velangkanni. K. - OPD	26/09/2022
	Comp. Dt. : 26/09/2022							
	Status : Completed							
1972	22091005	PSYCHIATRY OPD	PROBLEM IN STSTEM DISPLAY	Valamburi. R.	power cable refixed		Bhuvaneswari. G. - P.H.C. - Tiruvonnainallur	26/09/2022
	Comp. Dt. : 28/09/2022							
	Status : Completed							
1973	22091111	CTVS-ROOM NO.225 -2ND FLOOR	SYSTEM NOT WORKING	Valamburi. R.	power cable refixed		Suvitha. R. - OPD	28/09/2022
1974	22091121	CTVS-ROOM NO.225 -2ND FLOOR	KEYBOARD NOT WORKING	Valamburi. R.	keyboard cable refixed		Suvitha. R. - OPD	28/09/2022
1975	22091123	PLASTIC SURGERY OPD-223	SCANER NOT WORKING	Balachandar. A.	driver reinstalled		Lakshmidivi. A - OPD	28/09/2022
	Comp. Dt. : 29/09/2022							
	Status : Completed							
1976	22091176	PSYCHIATRY OPD	SYSTEM MONITOR PROBLEM	Shafiullah. R.,Selvam. D.,Madhubalan. S.	New 22inch Monitor changed		Bhuvaneswari. G. - P.H.C. - Tiruvonnainallur	30/09/2022
	Comp. Dt. : 01/10/2022							
	Status : Completed							
1977	22100008	PSYCHIATRY OPD	PROBLEM IN MEDPLUS - NOT OPENED	Selvam. D.	patchcard refix medplus working		Bhuvaneswari. G. - P.H.C. - Tiruvonnainallur	05/10/2022
	Comp. Dt. : 07/10/2022							
	Status : Completed							
1978	22100160	ENT OPD	NEED TO CHANGE DATA CABLE	Jayaraj. J.	4M LAN CABLE CHANGED		Ezhilarasi. M. - OPD	08/10/2022
	Comp. Dt. : 13/10/2022							
	Status : Completed							


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1979	22100402	DENTAL OPD -2ND FLOOR	NEED TO CHECK WI FI CONNECTION - NOT WORKING	Valamburi. R.	power cable refixed		Lakshmi Devi. R. - OPD	13/10/2022
		Comp. Dt. : 17/10/2022 Status : Completed						
1980	22100529	ENT OPD	NEED SYSTEM REPLACE FROM DEMO ROOM TO HOD ROOM	Selvam. D.	DEMO ROOM SYSTEM SHIFT TO HOD ROOM		Ezhilarasi. M. - OPD	17/10/2022
		Comp. Dt. : 18/10/2022 Status : Completed						
1981	22100594	CTVS-ROOM NO.225 -2ND FLOOR	PROBLEM IN XEROX MACHINE TO PRINTER	Shafiullah. R.	PRINTER SETTING CHANGED		Suvitha. R. - OPD	19/10/2022
1982	22100615	ENT OPD	SYSTEM NOT WORKING	Shafiullah. R.	Electrical breaker off		Kamala.D. - OPD	19/10/2022
		Comp. Dt. : 25/10/2022 Status : Completed						
1983	22100773	SPECIALITY OPD	NEED TO CHANGE PRINTER CARTRIDGE (CTVS)	Madhubalan. S.	88A TONER CHANGED		Suvitha. R. - OPD	25/10/2022
		Comp. Dt. : 03/11/2022 Status : Completed						
1984	22110082	ENT OPD	IN ENDOSCOPY ROOM-SYSTEM KEYBOARD NOT WORKING	Jayaraj. J.	KEYBOARD REFIXED		Ezhilarasi. M. - OPD	03/11/2022
		Comp. Dt. : 04/11/2022 Status : Completed						
1985	22110121	CTVS-ROOM NO.225 -2ND FLOOR	PRINTER NOT WORKING	Selvam. D.	PRINTER WORKING FINE		Suvitha. R. - OPD	04/11/2022
		Comp. Dt. : 19/11/2022 Status : Completed						
1986	22110822	IVF ART CLINIC-INSIDE OF OG OPD(NO.68)	SYSTEM PROBLEM	Selvam. D.	New monitor changed		Rajasekari. R. - OPD	25/11/2022
		Comp. Dt. : 26/11/2022 Status : Completed						
1987	22111140	CARDIOLOGY OPD	SYSTEM MONITOR NOT WORKING	Madhubalan. S.	MONITOR POWER CABLE REFIXED WORKING FINE		Radhika. R. - OPD	26/11/2022
1988	22111149	CARDIOLOGY OPD	SYSTEM NO POWER ON	Madhubalan. S.	monitor power problem. Replaced the 18 inch monitor		Suvitha. R. - OPD	28/11/2022
		Comp. Dt. : 28/11/2022						


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
1989	22111164	UROLOGY--OPD	SYSTEM NO POWER ON	Selvam. D.	ups connected		Lavanya. M. - OPD	03/12/2022
1990	22111173	Ophthalmology - OPD	SYSTEM NOT WORKING	Shafiullah. R.	BOOTING TIMEING PROBLEM TEMP FILE CLEAN		Seetha. R. - OPD	28/11/2022
1991	22111192	Paediatrics - OPD	SYSTEM NOT WORKING [HOD SYSTEM]	Prakash. P.	Restarts the system		Murugeshwari. V. - OPD	29/11/2022
Comp. Dt. : 29/11/2022								
Status : Completed								
1992	22111252	OG-OPD	SYSTEM NO POWER ON IN BIOPSY ROOM	Madhubalan. S.	MONITOR CHANGED		Velangkanni. K. - OPD	02/12/2022
Comp. Dt. : 01/12/2022								
Status : Completed								
1993	22120030	CARDIOLOGY OPD	NETWORK SLOW - MEDPLUS NOT WORKING	Selvam. D.	system restarted		Radhika. R. - OPD	01/12/2022
1994	22120031	CTVS-ROOM NO.225 -2ND FLOOR	PRINTER NOT WORKING	Shafiullah. R.	PRINTR DEFAULT SET		Suvitha. R. - OPD	01/12/2022
Comp. Dt. : 03/12/2022								
Status : Completed								
1995	22120106	UROLOGY--OPD	PRINTER NOT WORKING	Prakash. P.	printer sharing connected		Lavanya. M. - OPD	03/12/2022
Comp. Dt. : 06/12/2022								
Status : Completed								
1996	22120268	Ophthalmology - OPD	UPS POWER BACKUP PROBLEM	Balachandar. A.	BATTERY CHANGED UPS GIVEN		Seetha. R. - OPD	07/12/2022
Comp. Dt. : 15/12/2022								
Status : Completed								
1997	22120679	DENTAL OPD -2ND FLOOR	WI-FI NOT WORKING	Selvam. D.	WIFI WORKING		Lakshmi Devi. R. - OPD	15/12/2022
Comp. Dt. : 21/12/2022								
Status : Completed								
1998	22120980	OG-OPD	KEYBOARD NOT WORKING	Madhubalan. S.	USB CABLE REFIXED WORKING FINE		Velangkanni. K. - OPD	21/12/2022
Comp. Dt. : 22/12/2022								
Status : Completed								
1999	22121023	ENT OPD	KEYBOARD NOT WORKING	Balachandar. A.	KEYBOARD WORKING		Kamala.D. - OPD	22/12/2022
Comp. Dt. : 26/12/2022								
Status : Completed								
2000	22121139	CTVS-ROOM NO.225 -2ND FLOOR	PRINTER NOT WORKING	Selvam. D.	Printer driver reconnect		Suvitha. R. - OPD	26/12/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 04/01/2023 Status : Completed								
2001	23010168	NEUROLOGY OPD-2ND FLOOR	PRINTER NOT WORKING	Madhubalan. S.	printer working fine		Radhika. R. - OPD	05/01/2023
Comp. Dt. : 12/01/2023 Status : Completed								
2002	23010509	OG-OPD	SYSTEM CPU PROBLEM IN HOD ROOM	Balachandar. A.	ram refixed		Velangkanni. K. - OPD	12/01/2023
Comp. Dt. : 25/01/2023 Status : Completed								
2003	23010914	CTVS-ROOM NO.225 -2ND FLOOR	NEED TO CHANGE TONER	Madhubalan. S.	88A TONER CHANGED		Suvitha. R. - OPD	25/01/2023
Comp. Dt. : 07/02/2023 Status : Completed								
2004	23020218	GASTROENTROLOGY OPD-2ND FLOOR	SYSTEM NOT WORKING - OPD NO 225	Jayaraj. J.	VIRUS SCAN AND CLEANED		Suvitha. R. - OPD	07/02/2023
Comp. Dt. : 09/02/2023 Status : Completed								
2005	23020340	CTVS-ROOM NO.225 -2ND FLOOR	PRINTER NOT WORKING	Shafiullah. R.	PRINTER WORKING		Suvitha. R. - OPD	09/02/2023
Comp. Dt. : 14/02/2023 Status : Completed								
2006	23020522	CTVS	PRINTER NOT WORKING	Selvam. D.	Scanner unit cleaned and refixed		Suvitha. R. - OPD	20/02/2023
Comp. Dt. : 21/02/2023 Status : Completed								
2007	23020821	Surgery OPD	IN DEMO ROOM PROJECTOR NOT WORKING	Shafiullah. R.	VGA CABLE REFIXED		Indhira. M. - OPD	21/02/2023
Comp. Dt. : 27/02/2023 Status : Completed								
2008	23021038	ENT OPD	PRINTER NOT WORKING	Selvam. D.	pickup roller problem.Repalced the pickup roller working fine		Ezhilarasi. M. - OPD	13/03/2023
Comp. Dt. : 31/03/2023 Status : Completed								
2009	23031330	Plastic Surgery	PRINTER STUCK - PAPER JAM	Madhubalan. S.	PAPER CLEAR WORKING FINE		Shmidevi. A - OPD	03/04/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2010	23031356	TB & Chest OPD	FAX SYSTEM NOT WORKING	Jayaraj. J.	Pacs working		Jothi.R. - OPD	03/04/2023
	Comp. Dt. : 01/04/2023							
	Status : Completed							
2011	23040011	CTVS-ROOM NO.225 -2ND FLOOR	NETWORK PROBLEM	Balachandar. A.	NETWORK CABLE REFIXIED		Suvitha. R. - OPD	01/04/2023
	Comp. Dt. : 26/04/2023							
	Status : Completed							
2012	23040843	Paediatrics - OPD	SYSTEM NOT WORKING	Valamburi. R.	VGA CABLE REFIX		Subashree. R. - OPD	26/04/2023
	Comp. Dt. : 27/04/2023							
	Status : Completed							
2013	23040938	CTVS-ROOM NO.225 -2ND FLOOR	PRINTER NOT WORKING	Selvam. D.	printer working fine		Suvitha. R. - OPD	28/04/2023
	Comp. Dt. : 28/04/2023							
	Status : Completed							
2014	23040977	SPECIALITY OPD	PRINTER NOT WORKING	Shafiullah. R.	A4 PAPER PRINTCOING AND LAB SHEET JAM		Suvitha. R. - OPD	29/04/2023
	Comp. Dt. : 05/05/2023							
	Status : Completed							
2015	23050216	Ophthalmology - OPD	NEED TO CHECK SYSTEM CAMERA - NOT WORKING	Selvam. D.	camera working fine		Seetha. R. - OPD	22/05/2023
	Comp. Dt. : 15/05/2023							
	Status : Completed							
2016	23050592	PSYCHIATRY OPD	NEED TO CHANGE TONER	Jayaraj. J.	88A TONER CHANGED		Indumathi. T. - OPD	15/05/2023
	Comp. Dt. : 17/05/2023							
	Status : Completed							
2017	23050704	TB & Chest OPD	SYSTEM NOT WORKING - NET WORK PROBLEM - SLOW	Shafiullah. R.	SYSTEM TEMP CLEAR		Jothi.R. - OPD	18/05/2023
	Comp. Dt. : 19/05/2023							
	Status : Completed							
2018	23050796	Ophthalmology - OPD	NEED TO CHECK NET CONNECTION FOR PERIMETRY MACHINE	Selvam. D.,Shafiullah. R.,Prakash. P.	checked working fine		Seetha. R. - OPD	22/05/2023
2019	23050797	Male Surgery - Ward 202	PRINTER NOT WORKING	Prakash. P.	Printer Power Cable unplugged		Priyadharshini. S. - OPD	19/05/2023
	Comp. Dt. : 25/05/2023							
	Status : Completed							


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2020	23050976	CTVS-ROOM NO.225 -2ND FLOOR	KEY BOARD NOT WORKING	Madhubalan. S.	SYSTEM RESTATED KEYBOARD WORKING FINE		Suvitha. R. - OPD	25/05/2023
Comp. Dt. : 29/05/2023 Status : Completed								
2021	23051109	Male Surgery	SYSTEM NOT WORKING BOTH WARD NO 201 & 202	Jayaraj. J.	UPS POWER CABLE REFIXED & KEYBOARD CLEAN REFIXED		Priyadharshini. S. - OPD	29/05/2023
2022	23051133	CTVS-ROOM NO.225 -2ND FLOOR	NEED TO CHANGE TONER	Harikrishnan. R.	12A Toner Changed.		Suvitha. R. - OPD	29/05/2023
Comp. Dt. : 12/06/2023 Status : Completed								
2023	23060427	OG-OPD	SYSTEM NOT WORKING - BIOPSY ROOM	Shafiullah. R.	MONITOR CHANGED		Velangkanni. K. - OPD	15/06/2023
Comp. Dt. : 19/06/2023 Status : Completed								
2024	23060682	TB & Chest OPD	NEED TO CHECK WI FI - NOT WORKING	Shafiullah. R.	OBG OPD WIFI REFIX		Jothi.R. - OPD	21/06/2023
Comp. Dt. : 28/06/2023 Status : Completed								
2025	23061085	PLASTIC SURGERY OPD-223	MOUSE NOT WORKING	Shafiullah. R.	REFIX MOUSE WORKING		Lakshmidevi. A - OPD	30/06/2023
Dept Name : Operation Theatre - Computer Department Comp. Dt. : 15/06/2022 Status : Completed								
2026	22060584	SPECIALITY OT	MOUSE NOT WORKING	Balachandar. A.	old mouse changed		Palaniraja. G. - Operation Theatre	16/06/2022
Comp. Dt. : 02/07/2022 Status : Completed								
2027	22070062	OG OT	C P U NOT WORKING	Balachandar. A.	Software reinstalled		Amudha. V. - Operation Theatre	02/07/2022
Comp. Dt. : 06/07/2022 Status : Completed								
2028	22070184	ORTHO OT	SYSTEM NOT WORKING	Valamburi. R.	System restarts		Mahalakshmi. G. - Operation Theatre	07/07/2022
Comp. Dt. : 07/07/2022 Status : Completed								
2029	22070252	OG OT	PROBLEM IN SYSTEM RECORDI NG	Jayaraj. J.	software reinstalled		Kanjani. V. - Operation Theatre	08/07/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 23/08/2022 Status : Completed								
2030	22080766	SPECIALITY OT	C P U PROBLEM IN EMERGENCY ENT MONITOR	Selvam. D.	working fine		Sobiya. N. - Operation Theatre	01/09/2022
Comp. Dt. : 14/09/2022 Status : Completed								
2031	22090529	SPECIALITY OT	NEED TO CHECK ALL U P S - NOT WORKING	Selvam. D.	This call is forwarded to electrical		Daiseyrani. A. - Operation Theatre	17/09/2022
Comp. Dt. : 28/09/2022 Status : Completed								
2032	22091139	OG OT	NEED TO CHECK " RECORD SOFTWARE" NOT WORKING	Balachandar. A.	system hdd problem,new hdd changed working fine,system unable to take ot staff,daily informed not ta		Ranjani. V. - Operation Theatre	05/10/2022
Comp. Dt. : 09/11/2022 Status : Completed								
2033	22110371	OG OT	RECORDING NOT WORKING	Balachandar. A.	OS INSTALLED		Amudha. V. - Operation Theatre	16/11/2022
Comp. Dt. : 27/12/2022 Status : Completed								
2034	22121222	SPECIALITY OT	SYSTEM NOT WORKING	Balachandar. A.	system working fine		Sobiya. N. - Operation Theatre	02/01/2023
Comp. Dt. : 06/01/2023 Status : Completed								
2035	23010279	Female Ortho - Ward 402	PRINTER NOT WORKING	Madhubalan. S.	PRINTER WORKING FINE		Pavadarani. S. - Operation Theatre	06/01/2023
Comp. Dt. : 03/05/2023 Status : Completed								
2036	23050097	SPECIALITY OT	NEED TO CHECK WI FI CONNECTION - NOT WORKING	Selvam. D.,Prakash. P.,Valamburi. R.	WIFI DEVICE FIXED		Kousalya. S. - Operation Theatre	12/05/2023
Dept Name : Ophthalmology - Computer Department Comp. Dt. : 09/05/2022 Status : Completed								
2037	22050288	Ophthalmology - OPD	SYSTEM NOT WORKING	Madhubalan. S.	POWER CABLE REFIXED		Rajeswari.V. - Ophthalmology	09/05/2022
Comp. Dt. : 15/06/2022								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
2038	22060577	OPHTHALMOLOGY	NEED TO CHANGE TONER FOR "B SCAN" & OCD ROOM	Balachandar. A.	printer ink flusing and nozzle clean done...		Rajeswari.V. - Ophthalmology	17/06/2022
Comp. Dt. : 27/06/2022								
Status : Completed								
2039	22060937	Ophthalmology - OPD	NEED INSTALLATION BODONI FONT	Selvam. D.	Tamil software installed		Rajeswari.V. - Ophthalmology	27/06/2022
Comp. Dt. : 27/08/2022								
Status : Completed								
2040	22080926	Ophthalmology - OPD	SYSTEM NOT WORKING	Balachandar. A.	temp clear,cc cleared		Rajeswari.V. - Ophthalmology	30/08/2022
Comp. Dt. : 20/09/2022								
Status : Completed								
2041	22090769	Ophthalmology - OPD	NEED TO CHANGE TONER	Prakash. P.	TONER CHANGED		Rajeswari.V. - Ophthalmology	20/09/2022
Comp. Dt. : 18/10/2022								
Status : Completed								
2042	22100604	Ophthalmology - OPD	SYSTEM SPEAKER AND MIC	Selvam. D.	SPEAKER CABLE REFIXED		Rajeswari.V. - Ophthalmology	22/10/2022
Comp. Dt. : 18/11/2022								
Status : Completed								
2043	22110797	Ophthalmology - OPD	PRINTER NOT WORKING	Shafiullah. R.	REFIX THE USB CABLE		Rajeswari.V. - Ophthalmology	18/11/2022
Comp. Dt. : 24/12/2022								
Status : Completed								
2044	22121129	Ophthalmology - OPD	PRINTER NOT WORKING	Balachandar. A.	PAPER JAM CLEARED		Rajeswari.V. - Ophthalmology	27/12/2022
Comp. Dt. : 09/01/2023								
Status : Completed								
2045	23010349	Ophthalmology - OPD	PRINTER NOT WORKING	Valamburi. R.	PRINTER PAPER JAM		Rajeswari.V. - Ophthalmology	09/01/2023
Comp. Dt. : 07/03/2023								
Status : Completed								
2046	23030290	Ophthalmology - OPD	PRINTER NOT WORKING	Shafiullah. R.	PRINTER PAPER JAM CLEAR		Rajeswari.V. - Ophthalmology	07/03/2023
Comp. Dt. : 25/03/2023								
Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2047	23031038	Ophthalmology - OPD	SYSTEM NOT WORKING	Selvam. D.	system working fine		Rajeswari.V. - Ophthalmology	27/03/2023
Dept Name : ORTHOPAEDICS - Computer Department Comp. Dt. : 13/09/2022 Status : Completed								
2048	22090501	Orthopaedics - OPD	NEED TO CHECK NET CONNECTION - ROOM NO 62	Madhubalan. S.	network cable refixed		Manjula. P. - ORTHOPAEDICS	14/09/2022
Comp. Dt. : 23/03/2023 Status : Completed								
2049	23030940	Orthopaedics - OPD	NEED TO CHECK SYSTEM - NOT WORKING [HOD SIR SYSTEM]	Selvam. D.	Monitor power cable refixed		Raja. V. - ORTHOPAEDICS	23/03/2023
Dept Name : P.H.C. - Tiruvennainallur - Computer Department Comp. Dt. : 09/07/2022 Status : Completed								
2050	22070388	Tiruvannainallur	PROBLEM IN C P U	Valamburi. R.	system working fine		Kanagasabai. D. - P.H.C. - Tiruvannainallur	13/07/2022
Dept Name : PAEDIATRICS - Computer Department Comp. Dt. : 04/05/2022 Status : Completed								
2051	22050092	Paediatrics - Ward 309	DISPLAY PROBLEM IN PROJECTOR - DEMO ROOM	Prakash. P.	laptop display mode changed		ANCY JENILET RAJENDRAN - PAEDIATRICS	04/05/2022
Comp. Dt. : 11/08/2022 Status : Completed								
2052	22080412	Paediatrics - OPD	MONITOR NOT WORKING AT HOD ROOM	Shafiullah. R.	POWER CABLE REFIX		Manju @ Brinda. V. - PAEDIATRICS	11/08/2022
Comp. Dt. : 17/03/2023 Status : Completed								
2053	23030716	RICU	PRINTER NOT WORKING & NEED TO CHANGE TONER	Shafiullah. R.	12A TONER CHANGED		KARIKALAN. A. - PAEDIATRICS	17/03/2023
Comp. Dt. : 03/05/2023 Status : Completed								
2054	23050101	Paediatrics - OPD	NEED TO CHECK SYSTEM - NOT WORKING AT HOD ROOM	Valamburi. R.	POWER CABLE REFIXED		Kanimozhi. T. - PAEDIATRICS	03/05/2023
Comp. Dt. : 21/06/2023								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
2055	23060778	Paediatrics - Ward 308	MEDPLUS NOT WORKING	Murugavel.R	network issue solved		DEEPA @ DEVIKA. R. - PAEDIATRICS	21/06/2023
Dept Name : Paediatrics Ward - Computer Department								
Comp. Dt. : 10/05/2022								
Status : Completed								
2056	22050351	Paediatrics - Ward 309	PRINTER PROBLEM & NEED CHANGE TONER	Shafiullah. R.	12A TONER CHANGED		Chitra. P. - Paediatrics Ward	10/05/2022
Comp. Dt. : 08/07/2022								
Status : Completed								
2057	22070301	Paediatrics - Ward 309	NEED TO CHANGE TONER	Madhubalan. S.	12A TONER CHANGED		Chitra. P. - Paediatrics Ward	08/07/2022
Comp. Dt. : 29/08/2022								
Status : Completed								
2058	22080997	Paediatrics - Ward 309	NEED TO CHANGE TONER	Shafiullah. R.	12A Toner changed		Chitra. P. - Paediatrics Ward	29/08/2022
Comp. Dt. : 30/09/2022								
Status : Completed								
2059	22091201	Paediatrics Ward	SYSTEM NOT WORKING [BOTH 309 & 310]	Madhubalan. S.	SYSTEM WORKING FINE		Chitra. P. - Paediatrics Ward	30/09/2022
Comp. Dt. : 07/10/2022								
Status : Completed								
2060	22100132	Paediatrics Ward	SYSTEM NOT WORKING WARD NO 309 & 310	Selvam. D.	Power issue solved		Chitra. P. - Paediatrics Ward	07/10/2022
Comp. Dt. : 12/10/2022								
Status : Completed								
2061	22100352	Paediatrics - Ward 309	SYSTEM NOT WORKING	Valamburi. R.	System working fine		Chitra. P. - Paediatrics Ward	13/10/2022
Comp. Dt. : 28/10/2022								
Status : Completed								
2062	22100880	Paediatrics - Ward 309	SYSTEM NOT WORKING	Madhubalan. S.	SYSTEM WORKING FINE		Chitra. P. - Paediatrics Ward	28/10/2022
Comp. Dt. : 31/10/2022								
Status : Completed								
2063	22101032	Paediatrics - Ward 309	PRINTER NOT WORKING	Selvam. D.	Print queue cleared and tested the printer working fine		Naveena. N. - Paediatrics Ward	02/11/2022
Comp. Dt. : 09/11/2022								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
2064	22110377	Paediatrics - Ward 310	SYSTEM NOT WORKING	Madhubalan. S.	new H310 motherboard changed,working fine		Chitra. P. - Paediatrics Ward	06/12/2022
Comp. Dt. : 18/11/2022								
Status : Completed								
2065	22110750	Paediatrics Ward	C P U NOT WORKING - WARD NO 307	Balachandar. A.	MOTHERBOARD PROBLEM,H310 NEW MOTHERBOARD CHANGED		Chitra. P. - Paediatrics Ward	06/12/2022
Comp. Dt. : 19/11/2022								
Status : Completed								
2066	22110812	Paediatrics - Ward 308	NEED TO CHECK SYSTEM & PRINTER (COUNTING & PREVIEW PROBLEM)	Jayaraj. J.	system and printer working fine		Chitra. P. - Paediatrics Ward	21/11/2022
Comp. Dt. : 29/11/2022								
Status : Completed								
2067	22111235	Paediatrics - Ward 308	MOUSE NOT WORKING	Shafiullah. R.	NEW MOUSE CHANGED		Chitra. P. - Paediatrics Ward	01/12/2022
Comp. Dt. : 01/12/2022								
Status : Completed								
2068	22120025	Paediatrics - Ward 308	UPS NOT WORKING	Shafiullah. R.	ups given installed..		Chitra. P. - Paediatrics Ward	08/12/2022
Comp. Dt. : 05/12/2022								
Status : Completed								
2069	22120195	Paediatrics - Ward 309	SYSTEM NO POWER ON	Shafiullah. R.	SYSTEM WORKING		Chitra. P. - Paediatrics Ward	05/12/2022
Comp. Dt. : 30/01/2023								
Status : Completed								
2070	23011070	Paediatrics - Ward 308	PRINTER NOT WORKING	Madhubalan. S.	PRINTER WORKING FINE		Sangeetha. E. - Paediatrics Ward	30/01/2023
Comp. Dt. : 28/03/2023								
Status : Completed								
2071	23031209	Paediatrics - Ward 308	PROBLEM IN MED PLUS - NOT WORKING	Shafiullah. R.	software working		Chitra. P. - Paediatrics Ward	29/03/2023
Comp. Dt. : 26/04/2023								
Status : Completed								
2072	23040869	Female Medical - Ward 306	SYSTEM NOT WORKING	Shafiullah. R.	SYSTEM WORKING FINE		Naveena. N. - Paediatrics Ward	26/04/2023
Dept Name : PATHOLOGY - Computer Department								

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 27/06/2022								
Status : Completed								
2073	22060938	FNAC ROOM	NEED TO CHECK SYSTEM - NOT WORKING & CHANGE TONER	Balachandar. A.	REPAIR OS AND RAM CHANGED PROBLEM SLOVED		Muthamil.K. - PATHOLOGY	27/06/2022
Comp. Dt. : 29/06/2022								
Status : Completed								
2074	22061047	FNAC ROOM	NEED TO CHANGE TONER	Selvam. D.	12a TONER CHANGED		Muthamil.K. - PATHOLOGY	29/06/2022
Comp. Dt. : 08/07/2022								
Status : Completed								
2075	22070315	FNAC ROOM	SYSTEM NOT WORKING - ROOM NO 46	Valamburi. R.	system working fine		Muthamil.K. - PATHOLOGY	13/07/2022
Comp. Dt. : 15/07/2022								
Status : Completed								
2076	22070578	PATHOLOGY IN COLLEGE	NEED TO CHANGE TONER	Prakash. P.	88A toner changed		Kalaichelvi.M. - PATHOLOGY	15/07/2022
Comp. Dt. : 22/09/2022								
Status : Completed								
2077	22090896	FNAC ROOM	SYSTEM NOT WORKING - ROOM NO 46	Madhubalan. S.	POWER CABLE REFIXED		Janaki. E. - PATHOLOGY	23/09/2022
Comp. Dt. : 13/10/2022								
Status : Completed								
2078	22100370	PATHOLOGY IN COLLEGE	NEED TO CHANGE TONER	Selvam. D.,Jayaraj. J.,Shafiullah. R.	12A toner changed		Kalaichelvi.M. - PATHOLOGY	13/10/2022
Comp. Dt. : 20/10/2022								
Status : Completed								
2079	22100656	FNAC ROOM	NEED TO CHANGE PRINTER TONER	Selvam. D.	12A TONER CHANGED		Vijayalakshmi. R. - PATHOLOGY	20/10/2022
Comp. Dt. : 29/10/2022								
Status : Completed								
2080	22100940	FNAC ROOM	SYSTEM NOT WORKING	Jayaraj. J.	SATA CABLE REFIXED & RAM CLEAN AND REFIXED		Vijayalakshmi. R. - PATHOLOGY	29/10/2022
Comp. Dt. : 31/10/2022								
Status : Completed								
2081	22100985	FNAC ROOM	(1012) SYSTEM NOT WORKING	Shafiullah. R.	DOMAIN REINSTALLED		Vijayalakshmi. R. - PATHOLOGY	31/10/2022
Comp. Dt. : 07/11/2022								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
	Status : Completed							
2082	22110193	FNAC ROOM	SYSTEM NOT WORKING	Madhubalan. S.	OS INSTALLED WORKING FINE		Sheelavathi. J. - PATHOLOGY	08/11/2022
	Comp. Dt. : 11/11/2022							
	Status : Completed							
2083	22110472	FNAC ROOM	SYSTEM NOT WORKING	Shafiullah. R.	LITHUM BATTERY UPS CHANGED		Vijayalakshmi. R. - PATHOLOGY	17/11/2022
	Comp. Dt. : 21/11/2022							
	Status : Completed							
2084	22110836	FNAC ROOM	NEED TO CHECK SYSTEM - NOT WORKING	Madhubalan. S.	SYSTEM RESTATED WORKING FINE		Sheelavathi. J. - PATHOLOGY	21/11/2022
	Comp. Dt. : 25/11/2022							
	Status : Completed							
2085	22111083	FNAC ROOM	SYSTEM UPS SOUND PROBLEM	Balachandar. A.	WORKING FINE		Vijayalakshmi. R. - PATHOLOGY	25/11/2022
	Comp. Dt. : 03/12/2022							
	Status : Completed							
2086	22120104	FNAC ROOM	SYSTEM NOT WORKING	Selvam. D.	Switch on the system		Muthamil.K. - PATHOLOGY	03/12/2022
	Comp. Dt. : 06/12/2022							
	Status : Completed							
2087	22120239	PATHOLOGY IN COLLEGE	SYSTEM NETWORK CONNECTING ISSUE	Jayaraj. J.	power issue		Kalaichelvi.M. - PATHOLOGY	07/12/2022
	Comp. Dt. : 23/12/2022							
	Status : Completed							
2088	22121053	FNAC ROOM	NEED TO CHANGE TONER	Shafiullah. R.	12A TONER CHANGED		Janaki. E. - PATHOLOGY	23/12/2022
	Comp. Dt. : 28/12/2022							
	Status : Completed							
2089	22121295	PATHOLOGY IN COLLEGE	SYSTEM NOT WORKING	Madhubalan. S.	system os issue,win10 OS REINSTALLED		Kalaichelvi.M. - PATHOLOGY	02/01/2023
	Comp. Dt. : 31/12/2022							
	Status : Completed							
2090	22121397	FNAC ROOM	SYSTEM NO POWER ON	Selvam. D.	Power cable refixed		Janaki. E. - PATHOLOGY	02/01/2023
	Comp. Dt. : 19/04/2023							
	Status : Completed							
2091	23040588	FNAC ROOM	NEED TO CHANGE TONER - ROOM NO 46	Harikrishnan. R.	12A toner changed.		Janaki. E. - PATHOLOGY	19/04/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 28/04/2023 Status : Completed								
2092	23040950	FNAC ROOM	SYSTEM NOT WORKING	Shafiullah. R.	NO DISPLAY RAM CLEAN AND FIX		Janaki. E. - PATHOLOGY	29/04/2023
Comp. Dt. : 02/05/2023 Status : Completed								
2093	23050013	FNAC ROOM	SYSTEM NOT WORKING	Shafiullah. R.	REFIX THE POWER CARD		Vijayalakshmi. R. - PATHOLOGY	02/05/2023
Comp. Dt. : 12/05/2023 Status : Completed								
2094	23050468	Clinical Pathology	SYSTEM NOT WORKING - ROOMNO 46	Shafiullah. R.	NO DISPLAY RAM REFIXED		Muthamil.K. - PATHOLOGY	12/05/2023
Comp. Dt. : 13/05/2023 Status : Completed								
2095	23050526	FNAC ROOM	SYSTEM NOT WORKING - ROOM NO 46	Selvam. D.	system working fine		Muthamil.K. - PATHOLOGY	13/05/2023
Comp. Dt. : 15/05/2023 Status : Completed								
2096	23050556	FNAC ROOM	SYSTEM NOT WORKING - ROOM NO 46	Prakash. P.	SYSTEM RESTARED		Muthamil.K. - PATHOLOGY	15/05/2023
Comp. Dt. : 30/06/2023 Status : Completed								
2097	23061134	FNAC ROOM	SYSTEM NOT WORKING - ROOM NO 46	Balachandar. A.	domain refixed		Sheelavathi. J. - PATHOLOGY	01/07/2023
Dept Name : PHARMACOLOGY - Computer Department Comp. Dt. : 04/07/2022 Status : Completed								
2098	22070126	PHARMACOLOGY	SYSTEM NOT WORKING	Jayaraj. J.	TEMP FILES CLEAREED		Panchali. P. - PHARMACOLOGY	05/07/2022
Dept Name : Pharmacy - Computer Department Comp. Dt. : 02/05/2022 Status : Completed								
2099	22050024	Pay Pharmacy	NEED TO CHANGE PRINTER RIBBON	Shafiullah. R.	REFIX THE CATRIAGE		Silambuselman. P. - Pharmacy	02/05/2022
Comp. Dt. : 06/05/2022 Status : Completed								
2100	22050214	Pay Pharmacy	NEED TO CHANGE RIBBON 2NOS	Balachandar. A.	10m ribbon changed		Silambuselman. P. - Pharmacy	07/05/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 09/05/2022 Status : Completed								
2101	22050289	Pay Pharmacy	PRINTER NOT WORKING	Selvam. D.	print head cable changed		Silambuselvan. P. - Pharmacy	10/05/2022
Comp. Dt. : 10/05/2022 Status : Completed								
2102	22050328	Pay Pharmacy	NEED TO CHANGE RIBBON	Selvam. D.	10m ribbon changed		Silambuselvan. P. - Pharmacy	10/05/2022
2103	22050338	Pay Pharmacy	PRINTER NOT WORKING NEED URGENT SERVICE	Selvam. D.	10m ribbon changed		Silambuselvan. P. - Pharmacy	10/05/2022
Comp. Dt. : 12/05/2022 Status : Completed								
2104	22050433	Pay Pharmacy	CHANGE PRINTER RIBBON	Jayaraj. J.	10M RIBBON CHANGED		Veeraraghavan. R. - Pharmacy	12/05/2022
Comp. Dt. : 13/05/2022 Status : Completed								
2105	22050447	Pay Pharmacy	SYSTEM NOT WORKING	Selvam. D.	System restarts		Mathivanan. K. - Pharmacy	14/05/2022
2106	22050456	Free Pharmacy	NEED TO CHANGE PRINTER RIBBON	Jayaraj. J.	10m ribbon changed		Thilagavathi. T. - Pharmacy	13/05/2022
Comp. Dt. : 14/05/2022 Status : Completed								
2107	22050490	Pay Pharmacy	SYSTEM NOT WORKING	Selvam. D.	Bios setting changed		Ramya. R. - Pharmacy	16/05/2022
2108	22050494	Free Pharmacy	SYSTEM NOT WORKING	Balachandar. A.	system restarted		Thilagavathi. T. - Pharmacy	14/05/2022
Comp. Dt. : 16/05/2022 Status : Completed								
2109	22050542	Pay Pharmacy	SYSTEM NOT WORKING	Shafiullah. R.	SYSTEM HANGE RESTART COMPUTER		Silambuselvan. P. - Pharmacy	16/05/2022
Comp. Dt. : 17/05/2022 Status : Completed								
2110	22050605	Pay Pharmacy	NEED TO CHANGE PRINTER RIBBON FOR SYSTEM NO 2	Prakash. P.	10m ribbon changed		Silambuselvan. P. - Pharmacy	17/05/2022
2111	22050631	Pay Pharmacy	NEED TO CHANGE PRINTER RIBBON	Madhubalan. S.	10M RIBBON CHANGED		Silambuselvan. P. - Pharmacy	18/05/2022
Comp. Dt. : 18/05/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2112	22050668	Free Pharmacy	SYSTEM NOT WORKING	Selvam. D.	SYSTEM WORKING FINE		Thilagavathi. T. - Pharmacy	18/05/2022
	Comp. Dt. : 19/05/2022							
	Status : Completed							
2113	22050727	Pay Pharmacy	PRINTER NOT WORKING	Selvam. D.	Printer driver reconnected		Silambuselvan. P. - Pharmacy	20/05/2022
	Comp. Dt. : 20/05/2022							
	Status : Completed							
2114	22050732	Pay Pharmacy	NEED TO CHANGE PRINTER RIBBON	Jayaraj. J.	COUNTER 1&2 10MTS RIBBON CHANGED		Silambuselvan. P. - Pharmacy	20/05/2022
	Comp. Dt. : 21/05/2022							
	Status : Completed							
2115	22050781	Free Pharmacy	NEED TO CHANGE RIBBON & SYSTEM PROBLEM	Balachandar. A.	10m ribbon changed and system working fine		Thilagavathi. T. - Pharmacy	21/05/2022
	Comp. Dt. : 23/05/2022							
	Status : Completed							
2116	22050847	Pay Pharmacy	NEED TO CHANGE RIBBON	Shafiullah. R.	COUNTER 3 10MT RIBBON CHANGED		Silambuselvan. P. - Pharmacy	23/05/2022
	Comp. Dt. : 25/05/2022							
	Status : Completed							
2117	22050941	Pay Pharmacy	PRINTER NOT WORKING - PAPER JAM	Murugavel.R	paper jam clear		Silambuselvan. P. - Pharmacy	25/05/2022
	Comp. Dt. : 26/05/2022							
	Status : Completed							
2118	22050972	Pay Pharmacy	NEED TO CHANGE PRINTER RIBBON	Valamburi. R.	10m ribbon changed		Silambuselvan. P. - Pharmacy	26/05/2022
2119	22051000	Pay Pharmacy	PRINTER NOT WORKING	Selvam. D.	Ribbon refixed tested printer working fine		Silambuselvan. P. - Pharmacy	27/05/2022
	Comp. Dt. : 31/05/2022							
	Status : Completed							
2120	22051127	Pay Pharmacy	NEED TO CHANGE PRINTER RIBBON	Madhubalan. S.	COUNTER 1 AND 2 10m RIBBON CHANGED		Silambuselvan. P. - Pharmacy	31/05/2022
2121	22051148	Pay Pharmacy	NEED TO CHECK PRINTER -NOT WORKING - & NEED TO CHANGE TONER	Selvam. D.	10m ribbon changed and printer working fine		Silambuselvan. P. - Pharmacy	01/06/2022
	Comp. Dt. : 06/06/2022							
	Status : Completed							
2122	22060229	Pay Pharmacy	PRINTER NOT WORKING	Shafiullah. R.	10m cartridged changed		Silambuselvan. P. - Pharmacy	07/06/2022

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 08/06/2022 Status : Completed								
2123	22060288	Pay Pharmacy	NEED TO CHANGE PRINTER RIBBON	Selvam. D.	10m ribbon changed in counter 2 and 3		Silambuselvan. P. - Pharmacy	08/06/2022
Comp. Dt. : 09/06/2022 Status : Completed								
2124	22060324	Free Pharmacy	SYSTEM NOT WORKING	Selvam. D.	SYSTEM RESTATED		Thilagavathi. T. - Pharmacy	09/06/2022
Comp. Dt. : 10/06/2022 Status : Completed								
2125	22060360	Pay Pharmacy	NEED TO CHANGE PRINTER RIBBON	Selvam. D.	10m ribbon changed		Veeraraghavan. R. - Pharmacy	10/06/2022
Comp. Dt. : 14/06/2022 Status : Completed								
2126	22060497	Pay Pharmacy	PRINTER NOT WORKING	Shafiullah. R.	COUTNER 2 PRINTER REINSTALLE AND 80 COLUMNS CATRIAGES CHANGED		Silambuselvan. P. - Pharmacy	14/06/2022
2127	22060533	Pay Pharmacy	NEED TO CHANGE PRINTER RIBBON	Madhubalan. S.	COUNTER 3 10m RIBBON CHANGED		Silambuselvan. P. - Pharmacy	14/06/2022
Comp. Dt. : 21/06/2022 Status : Completed								
2128	22060773	Pay Pharmacy	NEED TO CHANGE PRINTER RIBBON	Balachandar. A.	PRINTER RIBBON CHANGED		Silambuselvan. P. - Pharmacy	22/06/2022
Comp. Dt. : 22/06/2022 Status : Completed								
2129	22060800	Pay Pharmacy	PRINTER NOT WORKING & NEED TO CHANGE RIBBON	Balachandar. A.	RIBBON CHANGED		Silambuselvan. P. - Pharmacy	23/06/2022
2130	22060808	MEDICAL STORE IN BASEMENT	NEED TO CHANGE PRINTER RIBBON	Balachandar. A.	PRINTER RIBBON CHANGED		Sujatha.S. - Pharmacy	23/06/2022
Comp. Dt. : 23/06/2022 Status : Completed								
2131	22060829	Pay Pharmacy	SYSTEM SLOW PROBLEM	Valamburi. R.	SYSTEM CHECKED		Silambuselvan. P. - Pharmacy	23/06/2022
2132	22060833	Pay Pharmacy	NEED TO CHANGE PRINTER RIBBON	Valamburi. R.	10 M RIBBON CHANGED		Silambuselvan. P. - Pharmacy	23/06/2022
Comp. Dt. : 24/06/2022 Status : Completed								
2133	22060897	Pay Pharmacy	PRINTER NOT WORKING	Shafiullah. R.	COUNTER 1 RIBBON COMING OUTSIDE REFIX RIBBON		Silambuselvan. P. - Pharmacy	24/06/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 28/06/2022								
Status : Completed								
2134	22061001	Pay Pharmacy	NEED TO CHANGE PRINTER RIBBON 2NOS	Jayaraj. J.	10 M RIBBON 2 NOS CHANGED		Silambuselvan. P. - Pharmacy	28/06/2022
2135	22061025	Pay Pharmacy	NEED TO CHANGE PRINTER RIBBON	Jayaraj. J.	PRINTER RIBBON CHANGED		Silambuselvan. P. - Pharmacy	29/06/2022
Comp. Dt. : 30/06/2022								
Status : Completed								
2136	22061119	Pay Pharmacy	NEED TO CHANGE PRINTER RIBBON	Selvam. D.	10m ribbon changed		Silambuselvan. P. - Pharmacy	30/06/2022
Comp. Dt. : 01/07/2022								
Status : Completed								
2137	22070016	Pay Pharmacy	NEED TO CHANGE PRINTER RIBBON	Balachandar. A.	10m ribbon changed		Silambuselvan. P. - Pharmacy	01/07/2022
Comp. Dt. : 05/07/2022								
Status : Completed								
2138	22070149	Free Pharmacy	NEED TO CHANGE PRINTER RIBBON	Balachandar. A.	10M RIBBON CHANGED		Thilagavathi. T. - Pharmacy	05/07/2022
Comp. Dt. : 06/07/2022								
Status : Completed								
2139	22070197	Pay Pharmacy	NEED TO CHANGE PRINTER RIBBON	Valamburi. R.	PRINTER RIBBON CHANGED		Silambuselvan. P. - Pharmacy	07/07/2022
Comp. Dt. : 07/07/2022								
Status : Completed								
2140	22070280	Free Pharmacy	SYSTEM NOT WORKING	Selvam. D.	system restarts		Thilagavathi. T. - Pharmacy	07/07/2022
Comp. Dt. : 08/07/2022								
Status : Completed								
2141	22070302	Pay Pharmacy	NEED TO CHANGE PRINTER RIBBON	Madhubalan. S.	10m RIBBON CHANGED		Silambuselvan. P. - Pharmacy	08/07/2022
Comp. Dt. : 11/07/2022								
Status : Completed								
2142	22070444	Pay Pharmacy	PRINTER & SYSTEM NOT WORKING - NEED URGENT SERVICE	Selvam. D.	sysem and printer working fine		Silambuselvan. P. - Pharmacy	13/07/2022
Comp. Dt. : 12/07/2022								
Status : Completed								
2143	22070473	Pay Pharmacy	NEED TO CHANGE PRINTER RIBBON	Shafiullah. R.	10MTS RIBBON CHANGED		Silambuselvan. P. - Pharmacy	12/07/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 13/07/2022								
Status : Completed								
2144	22070490	Pay Pharmacy	NEED TO CHANGE PRINTER RIBBON	Selvam. D.	10m ribbon changed		Silambuselvan. P. - Pharmacy	13/07/2022
Comp. Dt. : 14/07/2022								
Status : Completed								
2145	22070538	Pay Pharmacy	NEED TO CHANGE PRINTER RIBBON	Valamburi. R.	PRINTER RIBBON CHANGED		Silambuselvan. P. - Pharmacy	14/07/2022
Comp. Dt. : 19/07/2022								
Status : Completed								
2146	22070716	Pay Pharmacy	SYSTEM NOT WORKING - NEED URGENT SERVICE	Selvam. D.	system working fine		Silambuselvan. P. - Pharmacy	20/07/2022
2147	22070727	Pay Pharmacy	NEED TO CHANGE PRINTER RIBBON [2 NOS]	Selvam. D.	10m ribbon changed		Silambuselvan. P. - Pharmacy	20/07/2022
Comp. Dt. : 20/07/2022								
Status : Completed								
2148	22070753	Free Pharmacy	KEYBOARD NOT WORKING	Selvam. D.	New usb keyboard changed		Thilagavathi. T. - Pharmacy	20/07/2022
Comp. Dt. : 23/07/2022								
Status : Completed								
2149	22070867	Pay Pharmacy	NEED TO CHANGE PRINTER RIBBON	Selvam. D.	PRINTER RIBBON CHANGED		Silambuselvan. P. - Pharmacy	23/07/2022
Comp. Dt. : 25/07/2022								
Status : Completed								
2150	22070930	Pay Pharmacy	SYSTEM NOT WORKING	Shafiullah. R.	system working fine		Silambuselvan. P. - Pharmacy	25/07/2022
Comp. Dt. : 29/07/2022								
Status : Completed								
2151	22071080	Pay Pharmacy	CHANGE PRINTER RIBBON	Shafiullah. R.	counter - 3 ribbon changed		Veeraraghavan. R. - Pharmacy	30/07/2022
Comp. Dt. : 01/08/2022								
Status : Completed								
2152	22080036	Pay Pharmacy	NEED TO CHANGE PRINTER RIBBIN & PRINTER NOT WORKING	Selvam. D.	10MTS RIBBON CHANGED AND SYS RESTRAT		Silambuselvan. P. - Pharmacy	01/08/2022
Comp. Dt. : 02/08/2022								
Status : Completed								
2153	22080087	Free Pharmacy	SYSTEM NOT WORKING	Murugavel.R	network cable refixed		Thilagavathi. T. - Pharmacy	03/08/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2154	22080096	Pay Pharmacy	NEED TO CHANGE PRINTER RIBBON 2 NOS	Selvam. D.	10m ribbon changed		Silambuselvan. P. - Pharmacy	03/08/2022
	Comp. Dt. : 03/08/2022							
	Status : Completed							
2155	22080113	Pay Pharmacy	PRINTER NOT WORKING - NEED URGENT SERVICE	Selvam. D.	Paper tractor refixed and tested five bill working fine		Silambuselvan. P. - Pharmacy	03/08/2022
	Comp. Dt. : 05/08/2022							
	Status : Completed							
2156	22080215	Pay Pharmacy	NEED TO CHECK PRINTER NOT WORKING - NEED TO CHANGE PRINTER RIBBON	Madhubalan. S.	COUNTER 3 10m RIBBON CHANGED		Silambuselvan. P. - Pharmacy	06/08/2022
	Comp. Dt. : 08/08/2022							
	Status : Completed							
2157	22080270	Pay Pharmacy	NEED TO CHANGE PRINTER RIBBON	Madhubalan. S.	10m RIBBON CHANGED		Silambuselvan. P. - Pharmacy	08/08/2022
	Comp. Dt. : 09/08/2022							
	Status : Completed							
2158	22080345	Pay Pharmacy	NEED TO CHANGE PRINTER RIBBON	Jayaraj. J.	10M RIBBON CHANGED		Silambuselvan. P. - Pharmacy	09/08/2022
	Comp. Dt. : 12/08/2022							
	Status : Completed							
2159	22080456	Pay Pharmacy	NEED TO CHANGE PRINTER RIBBON	Jayaraj. J.	10M RIBBON CHANGED		Silambuselvan. P. - Pharmacy	13/08/2022
	Comp. Dt. : 17/08/2022							
	Status : Completed							
2160	22080547	Pay Pharmacy	CHANGE PRINTER RIBBON	Selvam. D.	10m ribbon changed		Veeraraghavan. R. - Pharmacy	18/08/2022
	Comp. Dt. : 19/08/2022							
	Status : Completed							
2161	22080610	Pay Pharmacy	NEED TO CHANGE RIBBON - 2 NOS	Selvam. D.	COUNTER 3 AND 4 10m RIBBON CHANGED		Vasanthamurugan. S. - Pharmacy	19/08/2022
	Comp. Dt. : 22/08/2022							
	Status : Completed							
2162	22080713	Pay Pharmacy	PRINTER NOT WORKING	Selvam. D.	tracktor refixed		Silambuselvan. P. - Pharmacy	22/08/2022
	Comp. Dt. : 26/08/2022							
	Status : Completed							


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2163	22080871	Free Pharmacy	NEED TO CHANGE PRINTER RIBBON	Shafiullah. R.	10mts RIBBON CHANGED		Thilagavathi. T. - Pharmacy	26/08/2022
2164	22080916	Pay Pharmacy	NEED TO CHANGE PRINTER RIBBON	Madhubalan. S.	10m RIBBON CHANGED		Silambuselvan. P. - Pharmacy	26/08/2022
Comp. Dt. : 27/08/2022								
Status : Completed								
2165	22080941	Free Pharmacy	SYSTEM NOT WORKING	Prakash. P.	POWER CABLE REFIXED		Jhansirani. T. - Pharmacy	27/08/2022
Comp. Dt. : 29/08/2022								
Status : Completed								
2166	22080958	Pay Pharmacy	SYSTEM NOT WORKING - SYSTEM NO 1	Selvam. D.	Ram cleaned and refixed		Silambuselvan. P. - Pharmacy	29/08/2022
Comp. Dt. : 02/09/2022								
Status : Completed								
2167	22090071	Pay Pharmacy	NEED TO CHANGE RIBBON	Madhubalan. S.	COUNTER 1 AND 3 10m RIBBON CHANGED		Sivabalan. S. - Pharmacy	02/09/2022
Comp. Dt. : 03/09/2022								
Status : Completed								
2168	22090121	Pay Pharmacy	NEED TO CHANGE RIBBON	Valamburi. R.	ribbon changed		Silambuselvan. P. - Pharmacy	03/09/2022
Comp. Dt. : 06/09/2022								
Status : Completed								
2169	22090204	Pay Pharmacy	NEED TO CHANGE PRINTER RIBBON	Selvam. D.	10m ribbon changed		Silambuselvan. P. - Pharmacy	06/09/2022
Comp. Dt. : 14/09/2022								
Status : Completed								
2170	22090517	Pay Pharmacy	NEED TO CHANGE PRINTER RIBBON	Madhubalan. S.	10m RIBBON CHANGED		Silambuselvan. P. - Pharmacy	14/09/2022
Comp. Dt. : 16/09/2022								
Status : Completed								
2171	22090632	Free Pharmacy	PRINTER NOT WORKING	Jayaraj. J.	PRINTER ROLLER CHANGED		Thilagavathi. T. - Pharmacy	16/09/2022
Comp. Dt. : 21/09/2022								
Status : Completed								
2172	22090821	Pay Pharmacy	PRINTER NOT WORKING	Selvam. D.	PRINTER SERVICED		Silambuselvan. P. - Pharmacy	21/09/2022
2173	22090845	Pay Pharmacy	NEED TO CHANGE RIBBON	Selvam. D.	RIBBON CHANGED		Silambuselvan. P. - Pharmacy	21/09/2022
Comp. Dt. : 24/09/2022								

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
2174	22090958	Pay Pharmacy	NEED TO CHANGE PRINTER RIBBON	Madhubalan. S.	counter 1,2 and 3 10m ribbon changed		Silambuselvan. P. - Pharmacy	24/09/2022
Comp. Dt. : 29/09/2022								
Status : Completed								
2175	22091184	Pay Pharmacy	NEED TO CHANGE PRINTER RIBBON 2NOS	Madhubalan. S.	10m ribbon changed		Silambuselvan. P. - Pharmacy	30/09/2022
Comp. Dt. : 30/09/2022								
Status : Completed								
2176	22091191	Pay Pharmacy	SYSTEM SLOW PROBLEM	Selvam. D.	system working fine		Silambuselvan. P. - Pharmacy	30/09/2022
Comp. Dt. : 05/10/2022								
Status : Completed								
2177	22100047	Pay Pharmacy	NEED TO CHANGE PRINTER RIBBON	Shafiullah. R.	COUNTER 3 10 MTS RIBBON CHANGED		Silambuselvan. P. - Pharmacy	05/10/2022
Comp. Dt. : 06/10/2022								
Status : Completed								
2178	22100111	Pay Pharmacy	KEY BOARD PROBLEM	Prakash. P.	NEW USB KEYBOARD CHANGED..		Silambuselvan. P. - Pharmacy	06/10/2022
Comp. Dt. : 10/10/2022								
Status : Completed								
2179	22100229	Pay Pharmacy	PROBLEM IN PRINTER & SYSTEM - NEED TO CHECK	Selvam. D.	Printer working fine		Silambuselvan. P. - Pharmacy	11/10/2022
Comp. Dt. : 11/10/2022								
Status : Completed								
2180	22100278	Pay Pharmacy	NEED TO CHANGE PRINTER RIBBON	Selvam. D.	PRINTER RIBBON CHANGED		Silambuselvan. P. - Pharmacy	11/10/2022
Comp. Dt. : 13/10/2022								
Status : Completed								
2181	22100400	Pay Pharmacy	NEED TO CHANGE PRINTER RIBBON	Valamburi. R.	RIBBON CHANGED		Silambuselvan. P. - Pharmacy	13/10/2022
Comp. Dt. : 14/10/2022								
Status : Completed								
2182	22100475	Pay Pharmacy	NEED TO CHANGE PRINTER RIBBON	Shafiullah. R.	COUNTER 1&4 10MTS RIBBON CHANGED		Silambuselvan. P. - Pharmacy	14/10/2022
Comp. Dt. : 18/10/2022								
Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2183	22100599	Pay Pharmacy	NEED TO CHANGE PRINTER RIBBON	Selvam. D.	PRINTER RIBBON CHANGED		Veeraraghavan. R. - Pharmacy	18/10/2022
Comp. Dt. : 20/10/2022 Status : Completed								
2184	22100679	Pay Pharmacy	SYSTEM AND PRINTER NOT WORKING	Shafiullah. R.	SYSTEM WORKING PRINTER FEED PROBLEM FINISH		Sivabalan. S. - Pharmacy	20/10/2022
2185	22100696	Free Pharmacy	NEED TO CHANGE PRINTER RIBBON	Shafiullah. R.	10M RIBBON CHANGED		Thilagavathi. T. - Pharmacy	20/10/2022
Comp. Dt. : 21/10/2022 Status : Completed								
2186	22100739	Pay Pharmacy	NEED TO CHANGE PRINTER RIBBON	Jayaraj. J.	10m ribbon chagned		Mathivanan. K. - Pharmacy	22/10/2022
Comp. Dt. : 25/10/2022 Status : Completed								
2187	22100777	Pay Pharmacy	NEED TO CHANGE PRINTER RIBBON	Madhubalan. S.	10m RIBBON CHANGED		Veeraraghavan. R. - Pharmacy	25/10/2022
Comp. Dt. : 26/10/2022 Status : Completed								
2188	22100806	Pay Pharmacy	SYSTEM NOT WORKING	Jayaraj. J.	POWER CABLE REFIXED		Sivabalan. S. - Pharmacy	26/10/2022
Comp. Dt. : 27/10/2022 Status : Completed								
2189	22100841	Pay Pharmacy	NEED TO CHANGE PRINTER RIBBON	Selvam. D.	10m ribbon changed		Sivabalan. S. - Pharmacy	27/10/2022
Comp. Dt. : 28/10/2022 Status : Completed								
2190	22100925	MEDICAL STORE IN BASEMENT	CHANGE PRINTER RIBBON	Selvam. D.	PRINTER RIBBON CHANGED		Sujatha.S. - Pharmacy	29/10/2022
2191	22100938	Pay Pharmacy	CHANGE PRINTER RIBBON	Selvam. D.	PRINTER RIBBON CHANGED		Sivasakthi. S. - Pharmacy	29/10/2022
Comp. Dt. : 31/10/2022 Status : Completed								
2192	22101026	Pay Pharmacy	NEED TO CHANGE ONE PRINTER RIBBON	Madhubalan. S.	PRINTER RIBBON CHANGED		Nandhini. P. - Pharmacy	02/11/2022
2193	22101033	MEDICAL STORE IN BASEMENT	PRINTER NOT WORKING	Shafiullah. R.	USB CABLE REFIXED		Sheela. B. - Pharmacy	02/11/2022
Comp. Dt. : 03/11/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2194	22110069	Pay Pharmacy	CHANGE PRINTER RIBBON	Madhubalan. S.	10m RIBBON CHANGED		Raja Raja Cholan. D. - Pharmacy	03/11/2022
2195	22110100	Pay Pharmacy	CHANGE PRINTER RIBBON	Madhubalan. S.	10m RIBBON CHANGED		Veeraraghavan. R. - Pharmacy	03/11/2022
Comp. Dt. : 05/11/2022								
Status : Completed								
2196	22110169	Pay Pharmacy	SYSTEM POWER ON PROBLEM	Balachandar. A.	hard disk cable refixed..		Gowridhasan. M. - Pharmacy	05/11/2022
Comp. Dt. : 07/11/2022								
Status : Completed								
2197	22110256	Pay Pharmacy	CHANGE PRINTER RIBBON	Selvam. D.	PRINTER RIBBON CHANGED		Sivasakthi. S. - Pharmacy	09/11/2022
Comp. Dt. : 10/11/2022								
Status : Completed								
2198	22110413	Pay Pharmacy	PRINTER NOT WORKING PROPERLY	Jayaraj. J.	SYSTEM RESTARTED		Nazreen Begam. M. - Pharmacy	10/11/2022
Comp. Dt. : 14/11/2022								
Status : Completed								
2199	22110543	Pay Pharmacy	CHANGE PRINTER TONER	Valamburi. R.	10m ribbon changed		Dhandapani. V. - Pharmacy	15/11/2022
Comp. Dt. : 15/11/2022								
Status : Completed								
2200	22110627	Pay Pharmacy	CHANGE PRINTER RIBBON	Shafiullah. R.	10M RIBBION CHANGED		Veeraraghavan. R. - Pharmacy	15/11/2022
Comp. Dt. : 16/11/2022								
Status : Completed								
2201	22110693	Pay Pharmacy	CHANGE PRINTER RIBBON	Shafiullah. R.	COUNTER 3 10 MTS RIBBON CHANGED		Veeraraghavan. R. - Pharmacy	16/11/2022
Comp. Dt. : 17/11/2022								
Status : Completed								
2202	22110699	Free Pharmacy	CHANGE PRINTER RIBBON	Murugavel.R	RIBBON CHANGED		Thilagavathi. T. - Pharmacy	17/11/2022
2203	22110733	Pay Pharmacy	CHANGE PRINTER RIBBON	Madhubalan. S.	COUNTER 1&3 PRINTER RIBBON CHANGED		Sivabalan. S. - Pharmacy	17/11/2022
Comp. Dt. : 18/11/2022								
Status : Completed								
2204	22110757	Pay Pharmacy	NEED TO CHANGE PRINTER RIBBON	Selvam. D.	10m ribbon changed		Silambuselvan. P. - Pharmacy	21/11/2022
Comp. Dt. : 21/11/2022								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
2205	22110862	Pay Pharmacy	CHANGE PRINTER RIBBON	Shafiullah. R.	10m ribbon changed		Veeraraghavan. R. - Pharmacy	21/11/2022
Comp. Dt. : 22/11/2022								
Status : Completed								
2206	22110959	Pay Pharmacy	NEED TO CHANGE PRINTER RIBBON (3 NOS)	Balachandar. A.	PRINTER RIBBON CHANGED		Silambuselvan. P. - Pharmacy	23/11/2022
Comp. Dt. : 23/11/2022								
Status : Completed								
2207	22110995	Pay Pharmacy	PRINTER NOT PRINTING PROPERLY	Madhubalan. S.	PRINTER WORKING FINE		Veeraraghavan. R. - Pharmacy	23/11/2022
2208	22110996	Pay Pharmacy	CHANGE PRINTER RIBBON	Madhubalan. S.	10m RIBBON CHANGED		Veeraraghavan. R. - Pharmacy	23/11/2022
Comp. Dt. : 24/11/2022								
Status : Completed								
2209	22111048	MEDICAL STORE IN BASEMENT	PRINTER PROBLEM	Selvam. D.	TONER CHANGED		Sriram. B. - Pharmacy	25/11/2022
Comp. Dt. : 25/11/2022								
Status : Completed								
2210	22111097	Pay Pharmacy	NEED TO CHANGE PRINTER RIBBON	Shafiullah. R.	COUNTER 1&3 10 MTS RIBBON CHANGED		Silambuselvan. P. - Pharmacy	25/11/2022
2211	22111120	Pay Pharmacy	NEED TO CHANGE PRINTER RIBBON 2 NOS	Selvam. D.	REPATED COMPLAIN		Nandhini. P. - Pharmacy	25/11/2022
Comp. Dt. : 30/11/2022								
Status : Completed								
2212	22111286	Pay Pharmacy	CHANGE PRINTER RIBBON	Selvam. D.	PRINTER RIBBON CHANGED		Rameshkumar. R. - Pharmacy	30/11/2022
2213	22111289	Pay Pharmacy	PRINTER NO.1 NOT WOKRING	Selvam. D.	Paper tractor refixed and 10m ribbon changed		Nandhini. P. - Pharmacy	01/12/2022
Comp. Dt. : 05/12/2022								
Status : Completed								
2214	22120187	Pay Pharmacy	PRINTER PROBLEM	Selvam. D.	print cartridge refixed		Kowsalya. A. - Pharmacy	05/12/2022
Comp. Dt. : 07/12/2022								
Status : Completed								
2215	22120299	Pay Pharmacy	CHANGE PRINTER RIBBON -3 NOS	Madhubalan. S.	COUNTER 2 AND 3 10m RIBBON CHANGED		Sivasakthi. S. - Pharmacy	07/12/2022
Comp. Dt. : 10/12/2022								
Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2216	22120456	Pay Pharmacy	NEED TO CHANGE PRINTER RIBBON	Valamburi. R.	RIBBON NCHANGED		Silambuselvan. P. - Pharmacy	10/12/2022
	Comp. Dt. : 12/12/2022							
	Status : Completed							
2217	22120553	MEDICAL STORE IN BASEMENT	NEED TO CHANGE PRINTER RIBBON	Valamburi. R.	PRINTER RIBBON CHANGED		Sheela. B. - Pharmacy	12/12/2022
	Comp. Dt. : 13/12/2022							
	Status : Completed							
2218	22120604	Free Pharmacy	SYSTEM NOT WORKING	Balachandar. A.	REFIX PATCH CARD		Thilagavathi. T. - Pharmacy	13/12/2022
	Comp. Dt. : 15/12/2022							
	Status : Completed							
2219	22120692	Free Pharmacy	CHANGE PRINTER RIBBON	Shafiullah. R.	10mts ribbon changed		Thilagavathi. T. - Pharmacy	15/12/2022
2220	22120719	Pay Pharmacy	PRINTER NOT WORKING	Shafiullah. R.	PRINTER WORKING		Silambuselvan. P. - Pharmacy	15/12/2022
	Comp. Dt. : 16/12/2022							
	Status : Completed							
2221	22120786	Pay Pharmacy	NEED TO CHANGE PRINTER RIBBON	Madhubalan. S.	counter 1,2,3 10m ribbon changed		Silambuselvan. P. - Pharmacy	16/12/2022
	Comp. Dt. : 19/12/2022							
	Status : Completed							
2222	22120836	Pay Pharmacy	PRINTER NOT WORKING - 2 NOS	Madhubalan. S.	PRINTER WORKING FINE		Dhandapani. V. - Pharmacy	20/12/2022
	Comp. Dt. : 21/12/2022							
	Status : Completed							
2223	22120943	Pay Pharmacy	NEED TO CHANGE PRINTER RIBBON	Balachandar. A.	PRINTER RIBBON CHANGED		Gowsalya. V. - Pharmacy	21/12/2022
2224	22120992	Pay Pharmacy	NEED TO CHANGE PRINTER RIBBON	Balachandar. A.	PRINTER RIBBON CHANGED		Veeraraghavan. R. - Pharmacy	22/12/2022
	Comp. Dt. : 22/12/2022							
	Status : Completed							
2225	22120996	Pay Pharmacy	NEED TO CHANGE PRINTER RIBBON	Madhubalan. S.	COUNTER 1 AND 3 10m PRINTER RIBBON CHANGE		Gowsalya. V. - Pharmacy	22/12/2022
	Comp. Dt. : 26/12/2022							
	Status : Completed							
2226	22121192	Pay Pharmacy	NEED TO CHANGE PRINTER RIBBON & PRINTER NOT WORKING	Madhubalan. S.	COUNTER 3 AND 4 10m RIBBOM CHANGED		Gowsalya. V. - Pharmacy	26/12/2022

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 27/12/2022								
Status : Completed								
2227	22121225	Pay Pharmacy	NEED TO CHANGE PRINTER RIBBON	Madhubalan. S.	10m RIBBON CHANGED		Ramya. R. - Pharmacy	27/12/2022
Comp. Dt. : 30/12/2022								
Status : Completed								
2228	22121355	Pay Pharmacy	CHANGE PRINTER RIBBON	Jayaraj. J.	PRINTER RIBBON CHANGE		Rameshkumar. R. - Pharmacy	31/12/2022
Comp. Dt. : 04/01/2023								
Status : Completed								
2229	23010188	Pay Pharmacy	2 NO'S PRINTER RIBBON NEED TO BE CHANGE	Madhubalan. S.	PRINTER RIBBON CHANGED		Veeraraghavan. R. - Pharmacy	04/01/2023
Comp. Dt. : 07/01/2023								
Status : Completed								
2230	23010296	Pay Pharmacy	PRINTER NOT WORKING	Selvam. D.	PRINTER WORKING 10M RIBBON CHANGED		Rameshkumar. R. - Pharmacy	07/01/2023
Comp. Dt. : 09/01/2023								
Status : Completed								
2231	23010327	Pay Pharmacy	CHANGE PRINTER RIBBON	Selvam. D.	PRINTER RIBBON CHANGED		Veeraraghavan. R. - Pharmacy	09/01/2023
Comp. Dt. : 11/01/2023								
Status : Completed								
2232	23010434	Pay Pharmacy	CHANGE PRINTER RIBBON	Selvam. D.	PRINTER RIBBON CHANGED		Veeraraghavan. R. - Pharmacy	11/01/2023
2233	23010435	Pay Pharmacy	PRINTER NOT WORKING	Selvam. D.	General service done		Veeraraghavan. R. - Pharmacy	11/01/2023
Comp. Dt. : 13/01/2023								
Status : Completed								
2234	23010551	Pay Pharmacy	PRINTER NOT WORKING	Selvam. D.	System restarts and tested its working fine		Kumar. R. - Pharmacy	13/01/2023
Comp. Dt. : 18/01/2023								
Status : Completed								
2235	23010628	Pay Pharmacy	NEED TO CHECK PRINTER - NOT WORKING	Selvam. D.	Printer ribbon lever adjust		Silambuselvan. P. - Pharmacy	18/01/2023
Comp. Dt. : 21/01/2023								
Status : Completed								
2236	23010753	Pay Pharmacy	NEED TO CHANGE PRINTER RIBBON	Madhubalan. S.	10m RIBBON CHANGED		Silambuselvan. P. - Pharmacy	21/01/2023
Comp. Dt. : 24/01/2023								

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
2237	23010871	Pay Pharmacy	NEED TO CHANGE PRINTER RIBBON	Jayaraj. J.	10M RIBBON CHANGED		Silambuselvan. P. - Pharmacy	24/01/2023
2238	23010885	Pay Pharmacy	PRINTER NOT WORKING	Jayaraj. J.	SETTING CHANGED		Silambuselvan. P. - Pharmacy	24/01/2023
Comp. Dt. : 25/01/2023								
Status : Completed								
2239	23010901	Pay Pharmacy	NEED TO CHECK PRINTER ALIGNMENT - PROBLEM	Shafiullah. R.	RIBBON REFIX		Silambuselvan. P. - Pharmacy	25/01/2023
2240	23010910	Pay Pharmacy	NEED TO CHANGE KEY BOARD	Shafiullah. R.	OLD KEYBOARD CHANGED		Silambuselvan. P. - Pharmacy	25/01/2023
Comp. Dt. : 27/01/2023								
Status : Completed								
2241	23010974	Pay Pharmacy	MOUSE NOT WORKING	Madhubalan. S.	SYSTEM RESTATED MOUSE WORKING FINE		Gowsalya. V. - Pharmacy	27/01/2023
2242	23010990	Pay Pharmacy	NEED TO CHANGE PRINTER RIBBON	Madhubalan. S.	COUNTER 1&3 10MTS PRINTER RIBBON		Gowridhasan. M. - Pharmacy	28/01/2023
Comp. Dt. : 30/01/2023								
Status : Completed								
2243	23011049	Pay Pharmacy	NEED TO CHANGE PRINTER RIBBON	Madhubalan. S.	10m RIBBON CHANGED		Silambuselvan. P. - Pharmacy	30/01/2023
2244	23011080	Pay Pharmacy	NEED TO CHECK PRINTER RIBBON - STUCK	Selvam. D.	Ribbon changed		Silambuselvan. P. - Pharmacy	31/01/2023
Comp. Dt. : 31/01/2023								
Status : Completed								
2245	23011082	Pay Pharmacy	NEED TO CHANGE PRINTER RIBBON	Selvam. D.	ribbon changed		Silambuselvan. P. - Pharmacy	31/01/2023
2246	23011085	Pay Pharmacy	SYSTEM NOT WORKING	Selvam. D.	system working fine		Silambuselvan. P. - Pharmacy	31/01/2023
Comp. Dt. : 01/02/2023								
Status : Completed								
2247	23020018	Pay Pharmacy	PRINTER NOT WORKING	Selvam. D.	General service done		Silambuselvan. P. - Pharmacy	03/02/2023
Comp. Dt. : 02/02/2023								
Status : Completed								
2248	23020061	Pay Pharmacy	NEED TO CHANGE PRINTER RIBBON - SYSTEM NO 3	Selvam. D.	PRINTER RIBBON CHANGED		Silambuselvan. P. - Pharmacy	03/02/2023
2249	23020074	Pay Pharmacy	NEED TO CHANGE PRINTER RIBBON	Selvam. D.	10m ribbon changed		Silambuselvan. P. - Pharmacy	03/02/2023
Comp. Dt. : 03/02/2023								
Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2250	23020094	Free Pharmacy	SYSTEM NOT WORKING	Selvam. D.	POWER CABLE REFIXED		Thilagavathi. T. - Pharmacy	04/02/2023
2251	23020100	Pay Pharmacy	PRINTER NOT WORKING	Selvam. D.	printer working fine		Raja Raja Cholan. D. - Pharmacy	04/02/2023
Comp. Dt. : 04/02/2023 Status : Completed								
2252	23020142	Pay Pharmacy	NEED TO CHANGE PRINTER RIBBON	Selvam. D.	PRINTER RIBBON CHANGED		Silambuselvan. P. - Pharmacy	04/02/2023
Comp. Dt. : 06/02/2023 Status : Completed								
2253	23020161	Free Pharmacy	SYSTEM NOT WORKING	Murugavel.R	patch cable refixed		Thilagavathi. T. - Pharmacy	06/02/2023
2254	23020197	Pay Pharmacy	PRINTER NOT WORKING	Selvam. D.	paper setting changed		Silambuselvan. P. - Pharmacy	06/02/2023
2255	23020203	Pay Pharmacy	NEED TO CHANGE PRINTER RIBBON	Selvam. D.	10m ribbon changed		Silambuselvan. P. - Pharmacy	07/02/2023
Comp. Dt. : 07/02/2023 Status : Completed								
2256	23020252	Pay Pharmacy	PRINTER NOT WORKING	Selvam. D.	paper ejection setting done		Sivabalan. S. - Pharmacy	08/02/2023
Comp. Dt. : 08/02/2023 Status : Completed								
2257	23020303	Pay Pharmacy	PRINTER NOT WORKING	Selvam. D.	RIBBON CHANGED		Vasanthamurugan. S. - Pharmacy	08/02/2023
Comp. Dt. : 09/02/2023 Status : Completed								
2258	23020334	Pay Pharmacy	NEED TO CHANGE PRINTER RIBBON	Valamburi. R.	PRINTER RIBBON CHANGED		Selvakumar. S. - Pharmacy	09/02/2023
2259	23020365	Pay Pharmacy	NEED TO CHANGE PRINTER RIBBON	Valamburi. R.	PRINTER RIBBON CHANGED		Veeraraghavan. R. - Pharmacy	09/02/2023
Comp. Dt. : 10/02/2023 Status : Completed								
2260	23020371	Free Pharmacy	SYSTEM NOT WORKING	Jayaraj. J.	power cable refixed		Jhansirani. T. - Pharmacy	10/02/2023
Comp. Dt. : 11/02/2023 Status : Completed								
2261	23020431	Pay Pharmacy	PRINTER NOT WORKING	Selvam. D.	printer working fine		Silambuselvan. P. - Pharmacy	11/02/2023
Comp. Dt. : 13/02/2023 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2262	23020466	MEDICAL STORE IN BASEMENT	NEED TO CHANGE PRINTER RIBBON	Selvam. D.	10m ribbon changed		Sujatha.S. - Pharmacy	13/02/2023
2263	23020469	Free Pharmacy	NEED TO CHANGE PRINTER RIBBON	Selvam. D.	10m ribbon changed		Thilagavathi. T. - Pharmacy	13/02/2023
Comp. Dt. :		14/02/2023						
Status :		Completed						
2264	23020524	Pay Pharmacy	NEED TO CHANGE PRINTER RIBBON 3 NOS	Shafiullah. R.	COUTER NO -3 10 MTS RIBBON CHANGED		Silambuselvan. P. - Pharmacy	14/02/2023
2265	23020537	Pay Pharmacy	PRINTER NOT WORKING	Selvam. D.	Paper setting adjust		Silambuselvan. P. - Pharmacy	14/02/2023
Comp. Dt. :		15/02/2023						
Status :		Completed						
2266	23020581	Pay Pharmacy	PRINTER ALIGNMENT PROBLEM	Selvam. D.	PRINTER SERVICED		Silambuselvan. P. - Pharmacy	16/02/2023
Comp. Dt. :		20/02/2023						
Status :		Completed						
2267	23020761	Pay Pharmacy	NEED TO CHANGE PRINTER RIBBON	Jayaraj. J.	10m ribbon changed		Silambuselvan. P. - Pharmacy	20/02/2023
Comp. Dt. :		22/02/2023						
Status :		Completed						
2268	23020851	Pay Pharmacy	ONE PRINTER NOT WORKING	Selvam. D.	printer serviced		Silambuselvan. P. - Pharmacy	22/02/2023
2269	23020857	Pay Pharmacy	NEED TO CHANGE ONE MOUSE	Selvam. D.	OLD MOUSE CHANGED		Silambuselvan. P. - Pharmacy	22/02/2023
Comp. Dt. :		25/02/2023						
Status :		Completed						
2270	23020965	Pay Pharmacy	PRINTER NOT WORKING	Selvam. D.	10m RIBBON CHANGED		Silambuselvan. P. - Pharmacy	25/02/2023
Comp. Dt. :		27/02/2023						
Status :		Completed						
2271	23021024	Free Pharmacy	SYSTEM NOT WORKING	Jayaraj. J.	os reinstalled and software installed.		Thilagavathi. T. - Pharmacy	28/02/2023
Comp. Dt. :		28/02/2023						
Status :		Completed						
2272	23021074	Pay Pharmacy	CHANGE PRINTER RIBBON	Shafiullah. R.	COUNTER 2&3 10M RIBBON CHANGED		Rameshkumar. R. - Pharmacy	28/02/2023
Comp. Dt. :		01/03/2023						
Status :		Completed						
2273	23030013	Pay Pharmacy	PRINTER NOT WORKING PROPERLY	Shafiullah. R.	printer working		Nazreen Begam. M. - Pharmacy	01/03/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 02/03/2023								
Status : Completed								
2274	23030111	Pay Pharmacy	NEED TO CHANGE PRINTER RIBBON	Selvam. D.	10Mts ribbon changed		Silambuselvan. P. - Pharmacy	03/03/2023
Comp. Dt. : 07/03/2023								
Status : Completed								
2275	23030273	Pay Pharmacy	NEED TO CHANGE PRINTER RIBBON	Jayaraj. J.	10M RIBBON CHANGED		Silambuselvan. P. - Pharmacy	07/03/2023
Comp. Dt. : 08/03/2023								
Status : Completed								
2276	23030329	Pay Pharmacy	NEED TO CHANGE PRINTER RIBBON 3 NOS	Valamburi. R.	10m ribbon changed		Silambuselvan. P. - Pharmacy	09/03/2023
Comp. Dt. : 09/03/2023								
Status : Completed								
2277	23030365	Pay Pharmacy	PRINTER NOT WORKING	Selvam. D.	Printer working fine		Silambuselvan. P. - Pharmacy	09/03/2023
Comp. Dt. : 10/03/2023								
Status : Completed								
2278	23030438	Pay Pharmacy	NEED TO CHANGE PRINTER RIBBON	Jayaraj. J.	PRINTER RIBBON CHANGED		Silambuselvan. P. - Pharmacy	11/03/2023
Comp. Dt. : 15/03/2023								
Status : Completed								
2279	23030619	Pay Pharmacy	NEED TO CHANGE PRINTER RIBBON	Jayaraj. J.	10M RIBBON CHANGED		Silambuselvan. P. - Pharmacy	15/03/2023
Comp. Dt. : 17/03/2023								
Status : Completed								
2280	23030687	Pay Pharmacy	NEED TO CHANGE PRINTER RIBBON	Selvam. D.	10m ribbon changed		Silambuselvan. P. - Pharmacy	17/03/2023
2281	23030729	Free Pharmacy	SYSTEM NOT WORKING	Selvam. D.	ram cleaned and refixed		Thilagavathi. T. - Pharmacy	18/03/2023
Comp. Dt. : 18/03/2023								
Status : Completed								
2282	23030738	Pay Pharmacy	SYSTEM NOT WORKING & NEED TO CHANGE PRINTER RIBBON	Balachandar. A.	system checked working fine..		Silambuselvan. P. - Pharmacy	18/03/2023
Comp. Dt. : 21/03/2023								
Status : Completed								
2283	23030834	Pay Pharmacy	NEED TO CHANGE PRINTER RIBBON	Madhubalan. S.	10m ribbon changed		Silambuselvan. P. - Pharmacy	21/03/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 22/03/2023 Status : Completed								
2284	23030908	Pay Pharmacy	NEED TO CHANGE PRINTER RIBBON	Valamburi. R.	10m RIBBON CHANGED		Silambuselvan. P. - Pharmacy	22/03/2023
Comp. Dt. : 23/03/2023 Status : Completed								
2285	23030942	Pay Pharmacy	NEED TO CHANGE PRINTER RIBBON	Selvam. D.	10m riibon changed		Silambuselvan. P. - Pharmacy	23/03/2023
Comp. Dt. : 24/03/2023 Status : Completed								
2286	23030992	Free Pharmacy	SYSTEM NOT WORKING	Balachandar. A.	sytem working fine		Thilagavathi. T. - Pharmacy	27/03/2023
Comp. Dt. : 25/03/2023 Status : Completed								
2287	23031057	Pay Pharmacy	PRINTER SOUND PROBLEM & NEED TO CHANGE RIBBON	Shafiullah. R.	PRINTER WORKING FINE. 10m RIBBON CHNAGED		Silambuselvan. P. - Pharmacy	25/03/2023
Comp. Dt. : 27/03/2023 Status : Completed								
2288	23031105	Pay Pharmacy	PRINTER NOT WORKING	Selvam. D.	printer working fine		Silambuselvan. P. - Pharmacy	29/03/2023
2289	23031134	Pay Pharmacy	NEED TO CHANGE PRINTER RIBBON	Selvam. D.	10m ribbon changed		Silambuselvan. P. - Pharmacy	28/03/2023
Comp. Dt. : 30/03/2023 Status : Completed								
2290	23031299	Pay Pharmacy	NEED TO CHANGE PRINTER CARTRIDGE 1NO [BROKEN] & PRINTER RIBBON 3 NOS	Balachandar. A.	10m ribbon changed		Silambuselvan. P. - Pharmacy	30/03/2023
Comp. Dt. : 01/04/2023 Status : Completed								
2291	23040003	Free Pharmacy	SYSTEM NOT WORKING	Murugavel.R	temp clear and cc cleared		Jhansirani. T. - Pharmacy	04/04/2023
2292	23040009	Pay Pharmacy	NEED TO CHANGE PRINTER RIBBON	Murugavel.R	PRINTER RIBBON CHANGED		Silambuselvan. P. - Pharmacy	01/04/2023
2293	23040021	Pay Pharmacy	PRINTER NOT WORKING	Murugavel.R	PRINTER WORKING		Silambuselvan. P. - Pharmacy	01/04/2023
Comp. Dt. : 03/04/2023 Status : Completed								
2294	23040029	Free Pharmacy	SYSTEM NOT WORKING	Jayaraj. J.	harddisk problem,new ssd harddisk changed..		Jhansirani. T. - Pharmacy	05/04/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2295	23040060	Pay Pharmacy	PRINTER NOT WORKING	Shafiullah. R.	PRINTER WORKING FINE		Silambuselvan. P. - Pharmacy	03/04/2023
2296	23040071	Pay Pharmacy	NEED TO CHANGE PRINTER RIBBON	Shafiullah. R.	10mts ribbon changed		Silambuselvan. P. - Pharmacy	03/04/2023
Comp. Dt. : 04/04/2023 Status : Completed								
2297	23040095	Pay Pharmacy	NEED TO CHANGE PRINTER RIBBON & PRINTER NOT WORKING	Jayaraj. J.	10M RIBBON CHANGED		Silambuselvan. P. - Pharmacy	04/04/2023
Comp. Dt. : 08/04/2023 Status : Completed								
2298	23040215	Free Pharmacy	SYSTEM NOT WORKING	Madhubalan. S.	UPS RESTATED SYSTEM WORKING FINE		Jhansirani. T. - Pharmacy	08/04/2023
Comp. Dt. : 10/04/2023 Status : Completed								
2299	23040267	Free Pharmacy	SYSTEM NOT WORKING	Selvam. D.	power cable refixed		Thilagavathi. T. - Pharmacy	10/04/2023
Comp. Dt. : 12/04/2023 Status : Completed								
2300	23040375	Pay Pharmacy	PRINTER NOT WORKING	Jayaraj. J.	PRINTER WORKING FINE		Silambuselvan. P. - Pharmacy	12/04/2023
2301	23040388	Pay Pharmacy	NEED TO CHANGE PRINTER RIBBON 2NOS	Shafiullah. R.	10MTR RIBBON CHANGED		Silambuselvan. P. - Pharmacy	12/04/2023
Comp. Dt. : 13/04/2023 Status : Completed								
2302	23040412	Pay Pharmacy	NEED TO CHANGE PRINTER RIBBON	Jayaraj. J.	10M RIBBON CHANGED		Silambuselvan. P. - Pharmacy	13/04/2023
Comp. Dt. : 17/04/2023 Status : Completed								
2303	23040489	Pay Pharmacy	NEED TO CHANGE PRINTER RIBBON	Jayaraj. J.	10m ribbon changed		Silambuselvan. P. - Pharmacy	17/04/2023
Comp. Dt. : 19/04/2023 Status : Completed								
2304	23040595	Pay Pharmacy	NEED TO CHANGE PRINTER RIBBON [3NOS]	Selvam. D.	10m ribbon changed		Silambuselvan. P. - Pharmacy	19/04/2023
Comp. Dt. : 20/04/2023 Status : Completed								
2305	23040685	Pay Pharmacy	PRINTER NOT WORKING	Harikrishnan. R.	printer working fine		Silambuselvan. P. - Pharmacy	22/04/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 22/04/2023 Status : Completed								
2306	23040693	Free Pharmacy	SYSTEM NOT WORKING	Harikrishnan. R.	SYSTEM NO DISPLAY,NEW G41 MOTHERBOARD CHANGED.		Jhansirani. T. - Pharmacy	26/04/2023
Comp. Dt. : 26/04/2023 Status : Completed								
2307	23040837	Free Pharmacy	SYSTEM NOT WORKING	Jayaraj. J.	UPS POWER ON		Jhansirani. T. - Pharmacy	26/04/2023
2308	23040858	Pay Pharmacy	NEED TO CHANGE PRINTER RIBBON	Jayaraj. J.	10m ribbon changed		Silambuselvan. P. - Pharmacy	26/04/2023
Comp. Dt. : 28/04/2023 Status : Completed								
2309	23040953	Pay Pharmacy	NEED TO CHANGE PRINTER RIBBON	Jayaraj. J.	PRINTER RIBBON CHANGED		Silambuselvan. P. - Pharmacy	29/04/2023
Comp. Dt. : 02/05/2023 Status : Completed								
2310	23050039	Pay Pharmacy	NEED TO CHANGE PRINTER RIBBON FOR 4 PRINTERS 4 NOS	Shafiullah. R.	10mts ribbon counter 1,3&4 changed		Silambuselvan. P. - Pharmacy	02/05/2023
2311	23050069	Free Pharmacy	NEED TO CHANGE PRINTER RIBBON	Selvam. D.	10m ribbon changed		Thilagavathi. T. - Pharmacy	04/05/2023
Comp. Dt. : 03/05/2023 Status : Completed								
2312	23050109	Free Pharmacy	PROBLEM IN PRINTER HEAD	Selvam. D.	Cartridge refixed. No printhead issue		Thilagavathi. T. - Pharmacy	03/05/2023
2313	23050115	Pay Pharmacy	NEED TO CHANGE PRINTER RIBBON	Murugavel.R	PRINTER RIBBON CHANGED		Silambuselvan. P. - Pharmacy	04/05/2023
Comp. Dt. : 04/05/2023 Status : Completed								
2314	23050168	MEDICAL STORE IN BASEMENT	PRINTER NOT WORKING	Balachandar. A.	printer working fine		Sujatha.S. - Pharmacy	05/05/2023
Comp. Dt. : 06/05/2023 Status : Completed								
2315	23050240	Pay Pharmacy	NEED TO CHANGE PRINTER RIBBON [4 NOS]	Selvam. D.	10m ribbon changed		Silambuselvan. P. - Pharmacy	06/05/2023
2316	23050241	Pay Pharmacy	PROBLEM IN PRINTER HEAD	Selvam. D.	ribbon issue. ribbon changed		Silambuselvan. P. - Pharmacy	06/05/2023
Comp. Dt. : 09/05/2023 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2317	23050347	Pay Pharmacy	NEED TO CHANGE PRINTER RIBBON	Shafiullah. R.	COUNTER 3 10 MTS CHANGED		Silambuselvan. P. - Pharmacy	09/05/2023
	Comp. Dt. : 11/05/2023							
	Status : Completed							
2318	23050420	Pay Pharmacy	NEED TO CHANGE PRINTER RIBBON	Shafiullah. R.	10m RIBBON CHANGED		Silambuselvan. P. - Pharmacy	11/05/2023
	Comp. Dt. : 13/05/2023							
	Status : Completed							
2319	23050547	Pay Pharmacy	NEED TO CHANGE PRINTER RIBBON	Shafiullah. R.	counter 2&3 10m ribbon changed		Silambuselvan. P. - Pharmacy	13/05/2023
	Comp. Dt. : 18/05/2023							
	Status : Completed							
2320	23050732	Pay Pharmacy	NEED TO CHANGE PRINTER RIBBON	Shafiullah. R.	Reppet Complent		Silambuselvan. P. - Pharmacy	19/05/2023
2321	23050761	Pay Pharmacy	NEED TO CHANGE PRINTER RIBBON	Madhubalan. S.	Ribbon Changed		Silambuselvan. P. - Pharmacy	19/05/2023
	Comp. Dt. : 19/05/2023							
	Status : Completed							
2322	23050787	Pay Pharmacy	NEED TO CHANGE PRINTER RIBBON	Balachandar. A.	PRINTER RIBBON CHANGED		Silambuselvan. P. - Pharmacy	19/05/2023
	Comp. Dt. : 22/05/2023							
	Status : Completed							
2323	23050889	MEDICAL STORE IN BASEMENT	NEED TO CHANGE PRINTER RIBBON	Jayaraj. J.	10MT RIBBON CHANGED		Sujatha.S. - Pharmacy	22/05/2023
	Comp. Dt. : 23/05/2023							
	Status : Completed							
2324	23050915	Pay Pharmacy	NEED TO CHANGE PRINTER RIBBON	Shafiullah. R.	10mt RIBBON CHANGED 2NOS		Silambuselvan. P. - Pharmacy	23/05/2023
	Comp. Dt. : 26/05/2023							
	Status : Completed							
2325	23051046	MEDICAL STORE IN BASEMENT	PROBLEM IN PRINTER	Selvam. D.	printer working fine		Deepa. K. - Pharmacy	29/05/2023
	Comp. Dt. : 31/05/2023							
	Status : Completed							
2326	23051226	Free Pharmacy	NEED TO CHANGE PRINTER RIBBON	Shafiullah. R.	10mts ribbon changed		Thilagavathi. T. - Pharmacy	31/05/2023
2327	23051233	Pay Pharmacy	NEED TO CHANGE PRINTER RIBBON	Selvam. D.	10M RIBBON AND 10M CARTRIDGE CHANGED		Silambuselvan. P. - Pharmacy	31/05/2023
	Comp. Dt. : 03/06/2023							

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
2328	23060106	Pay Pharmacy	NEED TO CHANGE PRINTER RIBBON	Madhubalan. S.	10MTS 3 NOS RIBBON CHANGED		Silambuselvan. P. - Pharmacy	03/06/2023
Comp. Dt. : 06/06/2023								
Status : Completed								
2329	23060197	Pay Pharmacy	NEED TO CHANGE PRINTER RIBBON	Selvam. D.	10m ribbon changed		Silambuselvan. P. - Pharmacy	06/06/2023
Comp. Dt. : 07/06/2023								
Status : Completed								
2330	23060229	Free Pharmacy	U P S NO POWER ON	Balachandar. A.	UPS POWER CHANGED		Thilagavathi. T. - Pharmacy	07/06/2023
Comp. Dt. : 08/06/2023								
Status : Completed								
2331	23060262	Free Pharmacy	NEED TO CHECK U P S - POWER OFF	Balachandar. A.	lithium ups changed		Thilagavathi. T. - Pharmacy	08/06/2023
Comp. Dt. : 09/06/2023								
Status : Completed								
2332	23060320	Pay Pharmacy	NEED TO CHANGE PRINTER RIBBON	Selvam. D.	10M RIBBON CHANGED		Silambuselvan. P. - Pharmacy	09/06/2023
Comp. Dt. : 10/06/2023								
Status : Completed								
2333	23060352	Pay Pharmacy	PRINTER NOT WORKING	Selvam. D.	Paper tractor refixed		Silambuselvan. P. - Pharmacy	10/06/2023
Comp. Dt. : 13/06/2023								
Status : Completed								
2334	23060449	Pay Pharmacy	NEED TO CHANGE PRINTER RIBBON	Selvam. D.	10m ribbon changed		Silambuselvan. P. - Pharmacy	13/06/2023
2335	23060463	Pay Pharmacy	PRINTER NOT WORKING	Selvam. D.	stand by printer fixed		Silambuselvan. P. - Pharmacy	13/06/2023
Comp. Dt. : 14/06/2023								
Status : Completed								
2336	23060513	Pay Pharmacy	NEED TO CHANGE PRINTER RIBBON	Balachandar. A.	10m ribbon changed		Silambuselvan. P. - Pharmacy	15/06/2023
Comp. Dt. : 20/06/2023								
Status : Completed								
2337	23060709	Pay Pharmacy	NEED TO CHANGE PRINTER RIBBON & CHECK PRINTER - NOT WORKING	Prakash. P.	10m ribbon changed and printer problem fixed		Silambuselvan. P. - Pharmacy	20/06/2023

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 21/06/2023 Status : Completed								
2338	23060785	MEDICAL STORE IN BASEMENT	PRINTER NOT WORKING	Selvam. D.	replaced the printer		Sheela. B. - Pharmacy	23/06/2023
Comp. Dt. : 22/06/2023 Status : Completed								
2339	23060830	Pay Pharmacy	NEED TO CHANGE PRINTER RIBBON	Shafiullah. R.	counter 1&3 10mts ribbon changed		Silambuselvan. P. - Pharmacy	22/06/2023
Comp. Dt. : 23/06/2023 Status : Completed								
2340	23060887	Pay Pharmacy	PRINTER NOT WPRKING	Selvam. D.	printer working fine		Silambuselvan. P. - Pharmacy	24/06/2023
Comp. Dt. : 28/06/2023 Status : Completed								
2341	23061082	Pay Pharmacy	NEED TO CHANGE PRINTER RIBBON [3 NOS]	Balachandar. A.	PRINTER RIBBON CHANGED		Silambuselvan. P. - Pharmacy	28/06/2023
Comp. Dt. : 30/06/2023 Status : Completed								
2342	23061131	Pay Pharmacy	NEED TO CHANGE PRINTER RIBBON	Selvam. D.	10m ribbon changed		Silambuselvan. P. - Pharmacy	01/07/2023
Dept Name : PHYSIOLOGY - Computer Department Comp. Dt. : 05/04/2023 Status : Completed								
2343	23040155	PHYSIOLOGY--COLLEGE	NEED TO CHANGE TONER	Valamburi. R.	88A TONER CHANGED		Jayanthi.A. - PHYSIOLOGY	05/04/2023
Dept Name : Physiotherapy - Computer Department Comp. Dt. : 25/06/2022 Status : Completed								
2344	22060912	Physiotherapy	NEED TO CHECK U P S - PROBLEM	Balachandar. A.	New numeric ups changed		Ezhilan.K. - Physiotherapy	16/07/2022
Comp. Dt. : 25/08/2022 Status : Completed								
2345	22080825	Physiotherapy	SYSTEM NOT WORKING	Balachandar. A.	SMPS PROBLEM,NEW SMPS CHANGED..		Ezhilan.K. - Physiotherapy	27/08/2022
Comp. Dt. : 09/02/2023 Status : Completed								
2346	23020333	Physiotherapy	SYSTEM NOT WORKING	Shafiullah. R.	REFIX POWERCARD FROM MONITOR		Ezhilan.K. - Physiotherapy	09/02/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Dept Name : PICU & NICU - Computer Department Comp. Dt. : 16/05/2022 Status : Completed								
2347	22050525	NICU	NEED TO CHANGE TONER - & PRINTER PROBLEM	Selvam. D.	12A toner changed		Parameswari. P. - PICU & NICU	16/05/2022
Comp. Dt. : 02/08/2022 Status : Completed								
2348	22080085	ICU	PRINTER NOT WORKING	Selvam. D.	printer working fine		Arya. K. - PICU & NICU	03/08/2022
Comp. Dt. : 19/08/2022 Status : Completed								
2349	22080632	PICU	SYSTEM NOT WORKING	Jayaraj. J.	POWER CABLE REFIXED		Poovathal. K. - PICU & NICU	20/08/2022
Comp. Dt. : 17/09/2022 Status : Completed								
2350	22090675	NICU	NEED TO CHANGE TONER	Madhubalan. S.	12A TONER CHANGED		Revathy. I. - PICU & NICU	17/09/2022
Comp. Dt. : 02/11/2022 Status : Completed								
2351	22110041	ICU	PRINTER NOT WORKING	Selvam. D.	printer working fine		Poovathal. K. - PICU & NICU	03/11/2022
Comp. Dt. : 14/11/2022 Status : Completed								
2352	22110523	NICU	NEED TO PROVIDE INTERNET CONNECTION TO THE SYSTEM	Selvam. D.	SYSTEM FIXED AND NET CONNECTED		Parameswari. P. - PICU & NICU	14/11/2022
Comp. Dt. : 22/11/2022 Status : Completed								
2353	22110963	PICU	SYSTEM NOT WORKING (NEW PICU)	Shafiullah. R.	SYSTEM CABLE REFIX		Poovathal. K. - PICU & NICU	22/11/2022
Comp. Dt. : 08/12/2022 Status : Completed								
2354	22120372	PICU	SYSTEM NOT WORKING	Madhubalan. S.	SYSTEM POWER CABLE REFIXED WORKING FINE		Poovathal. K. - PICU & NICU	09/12/2022
Comp. Dt. : 12/12/2022 Status : Completed								
2355	22120536	PICU & NICU	SYSTEM NO POWER ON	Jayaraj. J.	RAM CLEAN REFIX		Poovathal. K. - PICU & NICU	12/12/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 13/12/2022								
Status : Completed								
2356	22120575	PICU	SYSTEM NOT WORKING - CABLE PROBLEM	Balachandar. A.	REFIX VGA CABLE		Poovathal. K. - PICU & NICU	13/12/2022
Comp. Dt. : 24/12/2022								
Status : Completed								
2357	22121109	PICU	SYSTEM NOT WORKING (NEW PICU)	Balachandar. A.	NEW 8GB RAM CHANGED ACER SUPPORT		Poovathal. K. - PICU & NICU	04/01/2023
Comp. Dt. : 28/12/2022								
Status : Completed								
2358	22121276	PICU & NICU	SYSTEM NOT WORKING	Balachandar. A.	RAM REFIXED.		Vijayalakshmi. C. - PICU & NICU	28/12/2022
Comp. Dt. : 05/01/2023								
Status : Completed								
2359	23010244	NEW NICU & PICU-2ND FLOOR	IN PICU-SYSTEM NOT WORKING-MESSAGE SHOWING CABLE NOT CONNECTED	Jayaraj. J.	SYSTEM RESTARTED		Poovathal. K. - PICU & NICU	05/01/2023
Comp. Dt. : 21/01/2023								
Status : Completed								
2360	23010792	PICU	system cable not working	Shafiullah. R.	system working fine		Parameswari. P. - PICU & NICU	23/01/2023
Comp. Dt. : 03/02/2023								
Status : Completed								
2361	23020097	PICU	PRINTER NOT WORKING	Selvam. D.	solinod switch serviced		Thirushayeni. A. - PICU & NICU	03/02/2023
Comp. Dt. : 10/02/2023								
Status : Completed								
2362	23020393	NICU	SYSTEM NOT WORKING	Shafiullah. R.	PRINTER PENDING QUEUE CLEAN		Parameswari. P. - PICU & NICU	10/02/2023
Comp. Dt. : 16/02/2023								
Status : Completed								
2363	23020660	PICU & NICU	(1271) SYSTEM NOT WORKING PROPERLY	Shafiullah. R.	system checked working fine		Vijayalakshmi. C. - PICU & NICU	18/02/2023
Comp. Dt. : 27/02/2023								
Status : Completed								
2364	23021006	NICU	SYSTEM NOT WORKING	Selvam. D.	RAM CLEANED AND REFIXED		Parameswari. K. - PICU & NICU	27/02/2023
Comp. Dt. : 10/03/2023								

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
2365	23030384	PICU	NEED TO CHECK SYSTEM - SCREEN DISPLAY COLOUR CHANGE	Selvam. D.	System working fine		Thirushayeni. A. - PICU & NICU	10/03/2023
Comp. Dt. : 04/05/2023								
Status : Completed								
2366	23050147	PICU	PRINTER NOT WORKING	Harikrishnan. R.	12A Toner Changed		Poovathal. K. - PICU & NICU	04/05/2023
Comp. Dt. : 03/06/2023								
Status : Completed								
2367	23060112	PICU	NEED TO CHANGE TONER - PRINTER NOT WORKING	Shafiullah. R.	PRINTER WORKING FINE AND NOT CHANGED TONER		Krishnaveni. S. - PICU & NICU	03/06/2023
Comp. Dt. : 07/06/2023								
Status : Completed								
2368	23060250	PICU	NEED TO CHANGE TONER	Harikrishnan. R.	12A toner changed.		Umamaheswari. P. - PICU & NICU	07/06/2023
Comp. Dt. : 08/06/2023								
Status : Completed								
2369	23060299	PICU	NEED TO CHANGE TONER & PRINTER NOT WORKING	Shafiullah. R.	12A TONER CHANGE & POWER ISSUE NOW WORKING		Umamaheswari. P. - PICU & NICU	08/06/2023
Dept Name : Plastic Surgery - Computer Department								
Comp. Dt. : 12/06/2023								
Status : Completed								
2370	23060389	PLASTIC SURGERY OPD-223	SYSTEM NOT WORKING	Harikrishnan. R.	lithium ups changed		Naveen. S. - Plastic Surgery	13/06/2023
Dept Name : POW & SICU - Computer Department								
Comp. Dt. : 09/05/2022								
Status : Completed								
2371	22050286	Post Operative	PRINTER NOT WORKING	Shafiullah. R.	12A TONER CHANGED		Pragadeesh. V. - POW & SICU	09/05/2022
Comp. Dt. : 14/05/2022								
Status : Completed								
2372	22050499	SICU	PRINTER PROBLEM	Selvam. D.	12a toner changed		Jamuna. K - POW & SICU	16/05/2022
Comp. Dt. : 16/05/2022								
Status : Completed								
2373	22050546	POW & SICU	NEED TO CHANGE TONER & PRINTER SERVICE	Selvam. D.	12A TONER CHANGED		Muthulakshmi. A. - POW & SICU	16/05/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 23/05/2022 Status : Completed								
2374	22050829	SICU	PRINTER NOT WORKING	Shafiullah. R.	PRINTER WORKING FINE		Praveena. E. - POW & SICU	23/05/2022
Comp. Dt. : 13/06/2022 Status : Completed								
2375	22060469	SICU	PRINTER NOT WORKING	Jayaraj. J.	12A TONER CHANGED		Jayapradha. J. - POW & SICU	13/06/2022
Comp. Dt. : 29/06/2022 Status : Completed								
2376	22061040	SICU	PRINTER NOT WORKING	Shafiullah. R.	Printer working fine		Arulmozhi. D. - POW & SICU	30/06/2022
Comp. Dt. : 30/06/2022 Status : Completed								
2377	22061095	POW & SICU	PRINTER NOT WORKING	Shafiullah. R.	TEFLON SLIEVE, ROLLER AND HEATING ELEMENT CHANGED PROBLEM SLOVED		Aruldevi. S. - POW & SICU	02/07/2022
Comp. Dt. : 18/07/2022 Status : Completed								
2378	22070654	POW & SICU	PRINTER NOT WORKING	Murugavel.R	PRINTER QUE CLEARED WORKING FINE		Pragadeesh. V. - POW & SICU	18/07/2022
Comp. Dt. : 19/07/2022 Status : Completed								
2379	22070690	POW & SICU	NEED TO CHANGE TONER	Selvam. D.	toner refixed		Valarmathy. K. - POW & SICU	19/07/2022
Comp. Dt. : 21/07/2022 Status : Completed								
2380	22070805	SICU	PROBLEM IN U P S & [BACK - UP]	Selvam. D.	NEW UPS REFIXED		Subhasini. S. - POW & SICU	01/08/2022
Comp. Dt. : 20/08/2022 Status : Completed								
2381	22080676	POW & SICU	NEED TO CHECK SYSTEM - DISPLAY PROBLEM	Selvam. D.	Monitor setting adjusted		Jamuna. K - POW & SICU	20/08/2022
Comp. Dt. : 17/09/2022 Status : Completed								
2382	22090690	POW & SICU	PRINTER NOT WORKING	Madhubalan. S.	REFIX TONER PRINTER WORKING		Subhasini. S. - POW & SICU	17/09/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 30/09/2022								
Status : Completed								
2383	22091188	ICCU	SYSTEM NOT WORKING	Selvam. D.	power cable refixed		Lakshmipriya. P. - POW & SICU	30/09/2022
Comp. Dt. : 05/10/2022								
Status : Completed								
2384	22100058	POW & SICU	SYSTEM NOT WORKING	Selvam. D.	MONITOR SETTING CHANGED		Jamuna. K - POW & SICU	05/10/2022
Comp. Dt. : 12/10/2022								
Status : Completed								
2385	22100320	Post Operative	NEED TO CHANGE PRINTER TONNER	Balachandar. A.	PRINTER TONNER CHANGED		Kausalya. V. - POW & SICU	12/10/2022
Comp. Dt. : 23/11/2022								
Status : Completed								
2386	22110970	POW & SICU	PRINTER NOT WORKING - PAPER JAM	Selvam. D.	Teflon sleeve changed		Silambarasi. A. - POW & SICU	25/11/2022
Comp. Dt. : 03/12/2022								
Status : Completed								
2387	22120112	SICU	PRINTER NOT WORKING - SICU POST OP	Shafiullah. R.	PRINTER PAPER JAM CLEAR		Jamuna. K - POW & SICU	03/12/2022
2388	22120132	SICU	SYSTEM NOT WORKING - SICU POW	Shafiullah. R.	SYSTEM WORKING		Asha. A. - POW & SICU	06/12/2022
Comp. Dt. : 09/12/2022								
Status : Completed								
2389	22120404	POW & SICU	PRINTER NOT WORKING	Prakash. P.	Pressure Roller And Tepln Sheet Changed		Jamuna. K - POW & SICU	09/12/2022
Comp. Dt. : 17/12/2022								
Status : Completed								
2390	22120804	POW & SICU	NEED TO CHANGE TONER	Jayaraj. J.	12A TONER CHANGED		Jamuna. K - POW & SICU	17/12/2022
Comp. Dt. : 28/12/2022								
Status : Completed								
2391	22121262	POW & SICU	KEYBOARD NOT WORKING	Balachandar. A.	CABLE REFIXED..		Jamuna. K - POW & SICU	28/12/2022
Comp. Dt. : 20/02/2023								
Status : Completed								
2392	23020739	POW & SICU	NEED TO CHANGE TONER	Jayaraj. J.	12A TONER CHANGED		Lakshmi. R. - POW & SICU	20/02/2023
Comp. Dt. : 28/02/2023								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
2393	23021049	SICU	PRINTER NOT WORKING	Selvam. D.	printer working fine		Jamuna. K - POW & SICU	02/03/2023
Comp. Dt. : 27/03/2023								
Status : Completed								
2394	23031106	SICU	PRINTER NOT WORKING	Shafiullah. R.	printer working fine		Praveena. E. - POW & SICU	28/03/2023
Comp. Dt. : 28/04/2023								
Status : Completed								
2395	23040951	POW & SICU	SYSTEM NOT WORKING	Balachandar. A.	MONITOR RESET		Jayapradha. J. - POW & SICU	29/04/2023
Comp. Dt. : 08/05/2023								
Status : Completed								
2396	23050305	POW & SICU	NEED TO CHANGE TONER	Harikrishnan. R.	12A Toner Changed.		Jamuna. K - POW & SICU	08/05/2023
Comp. Dt. : 01/06/2023								
Status : Completed								
2397	23060009	POW & SICU	NEED TO CHANGE TONER	Harikrishnan. R.	12A Toner Changed.		Jamuna. K - POW & SICU	01/06/2023
Comp. Dt. : 26/06/2023								
Status : Completed								
2398	23060978	POW & SICU	PRINTER NOT WORKING	Selvam. D.	scanner unit cleaned and refixed		Mugeshmuthu. M. - POW & SICU	28/06/2023
Dept Name : Printing Press - Computer Department								
Comp. Dt. : 22/06/2022								
Status : Completed								
2399	22060801	PRESS	PRINTER NOT WORKING	Prakash. P.	PRINTER QUEU CLEARD		Thirunavukarassu. K. - Printing Press	22/06/2022
Dept Name : PSYCHIATRY - Computer Department								
Comp. Dt. : 04/01/2023								
Status : Completed								
2400	23010164	PSYCHIATRY OPD	SYSTEM UPS NOT WOKRING	Madhubalan. S.	New nurmeric ups changed		VASANTH. K. - PSYCHIATRY	18/01/2023
Dept Name : Quality Department - Computer Department								
Comp. Dt. : 07/05/2022								
Status : Completed								
2401	22050226	NAC OFFICE 4TH FLOOR	SYSTEM NOT WORKING	Balachandar. A.	cc cleared and temp clared..		Suganthi. M. - Quality Department	07/05/2022

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 09/05/2022								
Status : Completed								
2402	22050258	NAC OFFICE 4TH FLOOR	NEED TO CHANGE TONER	Balachandar. A.	TONER CHANGED		Suganthi. M. - Quality Department	09/05/2022
Comp. Dt. : 18/05/2022								
Status : Completed								
2403	22050660	NAC OFFICE 4TH FLOOR	PROBLEM IN SYSTEM	Shafiullah. R.	ANTIVIRUS UNINSTALLED		Suganthi. M. - Quality Department	18/05/2022
Comp. Dt. : 11/06/2022								
Status : Completed								
2404	22060417	NAC OFFICE 4TH FLOOR	SYSTEM NOT WORKING	Balachandar. A.,Madhubalan. S.,Murugavel.R	SETTING CHANGED		Suganthi. M. - Quality Department	11/06/2022
Comp. Dt. : 25/06/2022								
Status : Completed								
2405	22060913	NABH OFFICE	NEED TO CHECK U P S - PROBLEM	Jayaraj. J.	Checked the ups working fine		Jones Arokiam. M. - Quality Department	27/06/2022
Comp. Dt. : 04/07/2022								
Status : Completed								
2406	22070090	NAC OFFICE 4TH FLOOR	NEED TO CHECK NET CONNECTION - NOT WORKING	Murugavel.R	Net Working		Suganthi. M. - Quality Department	04/07/2022
Comp. Dt. : 05/07/2022								
Status : Completed								
2407	22070136	NABH OFFICE	SYSTEM NOT WORKING	Madhubalan. S.	SYSTEM WORKING FINE		Jones Arokiam. M. - Quality Department	05/07/2022
Comp. Dt. : 16/07/2022								
Status : Completed								
2408	22070619	MS Office	PROBLEM IN SYSTEM & NET WORK	Selvam. D.	8 port switch power on		Suganthi. M. - Quality Department	18/07/2022
Comp. Dt. : 24/08/2022								
Status : Completed								
2409	22080785	MS Office	NEED TO CHECK U P S - NOT WORKING	Balachandar. A.	12V battery changed		Suganthi. M. - Quality Department	30/09/2022
Comp. Dt. : 10/09/2022								
Status : Completed								
2410	22090384	MS Office	PROBLEM IN SYSTEM - NEED TO CHECK	Balachandar. A.	VIRUS SCAN		Suganthi. M. - Quality Department	10/09/2022
Comp. Dt. : 13/09/2022								

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
2411	22090466	MS Office	SYSTEM NOT WORKING	Balachandar. A.	RAM CHANGED..		Suganthi. M. - Quality Department	13/09/2022
Comp. Dt. : 10/10/2022								
Status : Completed								
2412	22100214	MS Office	NEED TO CHECK NETWORK CONNECTION - NOT WORKING	Madhubalan. S.	INTERNET WORKING FINE		Pradeep Kumar. S. - Quality Department	10/10/2022
Comp. Dt. : 13/10/2022								
Status : Completed								
2413	22100373	MS Office	PROBLEM IN C P U - NEED TO CHECK	Valamburi. R.	power cable refixed		Pradeep Kumar. S. - Quality Department	13/10/2022
2414	22100405	MS Office	NEED TO CHECK NET CONNECTION - NOT WORKING	Valamburi. R.	8 port power cable refixed		Pradeep Kumar. S. - Quality Department	13/10/2022
Comp. Dt. : 18/10/2022								
Status : Completed								
2415	22100561	MS Office	SYSTEM NOT WORKING	Balachandar. A.	system heatsing paste added.		Suganthi. M. - Quality Department	28/10/2022
Comp. Dt. : 07/11/2022								
Status : Completed								
2416	22110230	NABH OFFICE	TONER NOT WORKING	Shafiullah. R.	12A TONER CHANGED		Pradeep Kumar. S. - Quality Department	07/11/2022
Comp. Dt. : 01/02/2023								
Status : Completed								
2417	23020037	OLD SKILL LAB V FLOOR	NEED NEW NET CONNECTION	Balachandar. A.	network given		Suganthi. M. - Quality Department	18/02/2023
Comp. Dt. : 27/06/2023								
Status : Completed								
2418	23061019	NABH OFFICE	NET SLOW PROBLEM	Prakash. P.	BSNL PROBLEM		Pradeep Kumar. S. - Quality Department	27/06/2023
Dept Name : Radio Diagnosis - Computer Department								
Comp. Dt. : 05/05/2022								
Status : Completed								
2419	22050132	RADIOLOGY	NEED TO CHANGE TONER	Selvam. D.	36a TONER CHANGED		Jayalakshmi. D. - Radio Diagnosis	05/05/2022
Comp. Dt. : 06/05/2022								
Status : Completed								
2420	22050185	RADIOLOGY	MOUSE NOT WORKING	Jayaraj. J.	MOUSE CABLE REFIXED		Manikandan.V. - Radio Diagnosis	06/05/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 09/05/2022 Status : Completed								
2421	22050275	SCAN - GROUND FLOOR - BLOOD BANK OPP	SYSTEM NOT WORKING	Shafiullah. R.	SYSTEM WORKING FINE		Jayalakshmi. D. - Radio Diagnosis	10/05/2022
Comp. Dt. : 11/05/2022 Status : Completed								
2422	22050376	CT Scan	CHANGE PRINTER TONER	Valamburi. R.	12A TONER CHANGED		Jayalakshmi. D. - Radio Diagnosis	11/05/2022
Comp. Dt. : 16/05/2022 Status : Completed								
2423	22050518	SCAN - GROUND FLOOR - BLOOD BANK OPP	C P U NOT WORKING	Jayaraj. J.	SYSTEM MOTHER BOARD CLEAN AND REFIXED		Kanimozhi. D. - Radio Diagnosis	17/05/2022
Comp. Dt. : 19/05/2022 Status : Completed								
2424	22050719	CT Scan	NEED TO CHECK PRINTER - NOT WORKING	Madhubalan. S.	PRINTER POWER CABLE REFIXED		Mahendran.V. - Radio Diagnosis	19/05/2022
Comp. Dt. : 06/06/2022 Status : Completed								
2425	22060175	SCAN - GROUND FLOOR - BLOOD BANK OPP	NEED TO CHECK C P U - NOT WORKING	Balachandar. A.	power cable refixed..		Kanimozhi. D. - Radio Diagnosis	06/06/2022
Comp. Dt. : 07/06/2022 Status : Completed								
2426	22060267	SCAN - GROUND FLOOR - BLOOD BANK OPP	NEED TO CHANGE TONER	Madhubalan. S.	12A TONER CHANGED		Kanimozhi. D. - Radio Diagnosis	07/06/2022
Comp. Dt. : 08/06/2022 Status : Completed								
2427	22060303	SCAN - GROUND FLOOR - BLOOD BANK OPP	SYSTEM NOT WORKING	Balachandar. A.	power cable refixed...		Kanimozhi. D. - Radio Diagnosis	08/06/2022
Comp. Dt. : 21/06/2022 Status : Completed								
2428	22060748	MRI	NEED TO CHANGE TONER FOR MRI PRINTER	Selvam. D.	88A toner changed		Jayalakshmi. D. - Radio Diagnosis	21/06/2022
Comp. Dt. : 25/06/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2429	22060921	XRay	C R MOUSE NOT WORKING	Madhubalan. S.	MOUSE WORKING FINE		Manikandan.V. - Radio Diagnosis	25/06/2022
	Comp. Dt. : 01/07/2022							
	Status : Completed							
2430	22070043	CT Scan	CT SYSTEM SLOW PROBLEM	Balachandar. A.	TEMP CLEAR AND CC CLEARED		Jayalakshmi. D. - Radio Diagnosis	02/07/2022
	Comp. Dt. : 21/07/2022							
	Status : Completed							
2431	22070807	SCAN - GROUND FLOOR - BLOOD BANK OPP	PRINTER NOT WORKING - PAPER JAM	Murugavel.R	printer paper jam cleared		Kanimozhi. D. - Radio Diagnosis	22/07/2022
	Comp. Dt. : 26/07/2022							
	Status : Completed							
2432	22070947	XRay	C R MOUSE NOT WORKING	Jayaraj. J.	MOUSE REFIXED		Manikandan. G. - Radio Diagnosis	26/07/2022
	Comp. Dt. : 29/07/2022							
	Status : Completed							
2433	22071072	RADIOLOGY	KEYBOARD NOT WORKING	Madhubalan. S.	KEYBOARD USB CABLE REFIXED WORKING FINE		Jayalakshmi. D. - Radio Diagnosis	29/07/2022
	Comp. Dt. : 12/08/2022							
	Status : Completed							
2434	22080440	RADIOLOGY	NEED TO CHANGE TONER FOR CT PRINTER	Jayaraj. J.	12A TONER CHANGED		Jayalakshmi. D. - Radio Diagnosis	12/08/2022
	Comp. Dt. : 19/08/2022							
	Status : Completed							
2435	22080612	RADIOLOGY	SYSTEM NO. 1 NOT WORKING IN PACS ROOM	Madhubalan. S.	TEMP FILES CLEAR		VENMANI. M - Radio Diagnosis	19/08/2022
	Comp. Dt. : 05/09/2022							
	Status : Completed							
2436	22090171	SCAN - GROUND FLOOR - BLOOD BANK OPP	NEED TO CHANGE TONER	Selvam. D.	12A TONER CHANGED		Kanimozhi. D. - Radio Diagnosis	05/09/2022
	Comp. Dt. : 09/09/2022							
	Status : Completed							
2437	22090373	SCAN - GROUND FLOOR - BLOOD BANK OPP	MONITOR NOT WORKING	Jayaraj. J.	MONITOR POWER CABLE REFIXED		Kanimozhi. D. - Radio Diagnosis	09/09/2022
	Comp. Dt. : 22/09/2022							
	Status : Completed							


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2438	22090874	XRy	NEED TO CHANGE TONER	Valamburi. R.	toner changed		Manikandan.V. - Radio Diagnosis	23/09/2022
Comp. Dt. : 30/09/2022 Status : Completed								
2439	22091207	CT Scan	NEED TO CHANGE TONER FOR CT ROOM	Murugavel.R	12A TONER CHANGED		Jayalakshmi. D. - Radio Diagnosis	30/09/2022
Comp. Dt. : 17/10/2022 Status : Completed								
2440	22100531	CT Scan	SYSTEM NOT WORKING	Shafiullah. R.	SYSTEM WORKING FILE OPEN SETTING CHANGE		Adilakshmi. T. - Radio Diagnosis	17/10/2022
Comp. Dt. : 29/10/2022 Status : Completed								
2441	22100961	RADIOLOGY	MOUSE NOT WORKING IN CR ROOM - X- RAY DEPARTMENT	Madhubalan. S.	usb port refixed mouse working fine		Manikandan. G. - Radio Diagnosis	29/10/2022
Comp. Dt. : 04/11/2022 Status : Completed								
2442	22110145	SCAN - GROUND FLOOR - BLOOD BANK OPP	INTERNET NOT WORKING	Selvam. D.	internet working fine		Kanimozhi. D. - Radio Diagnosis	04/11/2022
Comp. Dt. : 05/11/2022 Status : Completed								
2443	22110166	SCAN - GROUND FLOOR - BLOOD BANK OPP	INTERNET NOT CONNECTING AND NETWORK ISSUE	Balachandar. A.	JACK CRIMBING DONE..		Kanimozhi. D. - Radio Diagnosis	05/11/2022
Comp. Dt. : 09/11/2022 Status : Completed								
2444	22110324	RADIOLOGY	UPS NOT WORKING	Selvam. D.	Restart the system working fine		Sudha. D. - Radio Diagnosis	09/11/2022
Comp. Dt. : 11/11/2022 Status : Completed								
2445	22110446	XRy	IN CR ROOM-UPS PROBLEM	Shafiullah. R.	ELECTRICAL COMPLAIN		Manikandan.V. - Radio Diagnosis	14/11/2022
2446	22110478	RADIOLOGY	NEED TO CHANGE TONER	Shafiullah. R.	36A TONER CHANGED		Jayalakshmi. D. - Radio Diagnosis	11/11/2022
Comp. Dt. : 15/11/2022 Status : Completed								
2447	22110595	SCAN - GROUND FLOOR - BLOOD BANK OPP	CHANGE PRINTER TONER	Selvam. D.	12A toner changed		Kanimozhi. D. - Radio Diagnosis	16/11/2022

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 21/11/2022								
Status : Completed								
2448	22110846	SCAN - GROUND FLOOR - BLOOD BANK OPP	NEED TO CHECK INTERNET CONNECTION	Valamburi. R.	NEW IO CHANGED		Kanimozhi. D. - Radio Diagnosis	22/11/2022
Comp. Dt. : 23/11/2022								
Status : Completed								
2449	22110978	XRay	SYSTEM MOUSE NOT WORKING	Selvam. D.	Mouse refixed		Balabaskaran. A. - Radio Diagnosis	23/11/2022
Comp. Dt. : 25/11/2022								
Status : Completed								
2450	22111109	MRI	CHANGE PRINTER TONER	Selvam. D.	88A TONER CHANGED		Jayalakshmi. D. - Radio Diagnosis	25/11/2022
Comp. Dt. : 29/11/2022								
Status : Completed								
2451	22111232	XRay	MOUSE NOT WORKING - CR SYSTEM	Shafiullah. R.	p/s 2 mouse change		Manikandan.V. - Radio Diagnosis	29/11/2022
Comp. Dt. : 03/12/2022								
Status : Completed								
2452	22120123	SCAN - GROUND FLOOR - BLOOD BANK OPP	UPS NOT WORKING	Shafiullah. R.	electrical ups		Sudha. D - Radio Diagnosis	05/12/2022
Comp. Dt. : 07/12/2022								
Status : Completed								
2453	22120296*	RADIOLOGY	SYSTEM NO POWER ON	Prakash. P.	power cable refixed		Jayalakshmi. D. - Radio Diagnosis	02/01/2023
Comp. Dt. : 20/12/2022								
Status : Completed								
2454	22120889	BASEMENT SCAN	CT REPORTING SYSTEM NOT WORKING - (LIBRARY)	Madhubalan. S.	RAM CLEAN AND REFIXED WORKING FINE		Jayalakshmi. D. - Radio Diagnosis	20/12/2022
2455	22120891	SCAN - GROUND FLOOR - BLOOD BANK OPP	FILE SHARING PROBLEM	Balachandar. A.	NETWORK CABLE REFIXED..		Kanimozhi. D. - Radio Diagnosis	22/12/2022
Comp. Dt. : 22/12/2022								
Status : Completed								
2456	22121004	SCAN - GROUND FLOOR - BLOOD BANK OPP	SYSTEM NOT WORKING	Balachandar. A.	MONITOR POWER CABLE REFIXED.		Jayalakshmi. D. - Radio Diagnosis	22/12/2022
Comp. Dt. : 24/12/2022								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
2457	22121113	RADIOLOGY	SYSTEM NO POWER ON	Jayaraj. J.	RAM CLEAN AND REFIXED		Jayalakshmi. D. - Radio Diagnosis	24/12/2022
Comp. Dt. : 28/12/2022								
Status : Completed								
2458	22121277	RADIOLOGY	SYSTEM PACS NOT LOGIN IN PACS ROOM	Balachandar. A.	PACS RECONFIGURED.		Jayalakshmi. D. - Radio Diagnosis	28/12/2022
Comp. Dt. : 04/01/2023								
Status : Completed								
2459	23010121	SCAN - GROUND FLOOR - BLOOD BANK OPP	PRINTER PROBLEM (SOUND COMING)	Shafiullah. R.	printer working fine		Kanimozhi. D. - Radio Diagnosis	04/01/2023
Comp. Dt. : 05/01/2023								
Status : Completed								
2460	23010237	SCAN - GROUND FLOOR - BLOOD BANK OPP	CHANGE PRINTER TONER	Selvam. D.	12A toner changed		Kanimozhi. D. - Radio Diagnosis	05/01/2023
Comp. Dt. : 09/01/2023								
Status : Completed								
2461	23010328	RADIOLOGY	IN DEMO ROOM-SYSTEM INTERNET NOT CONECTED	Selvam. D.	INTERNET WORKING		BHARATHI. M. - Radio Diagnosis	09/01/2023
Comp. Dt. : 11/01/2023								
Status : Completed								
2462	23010476	RADIOLOGY	PRINTER NOT WORKING IN CT SCAN	Selvam. D.	Print queue cleared		Jayalakshmi. D. - Radio Diagnosis	11/01/2023
Comp. Dt. : 13/01/2023								
Status : Completed								
2463	23010582	SCAN - GROUND FLOOR - BLOOD BANK OPP	SYSTEM AUTOMATTICALLY SHUTDOWN	Madhubalan. S.	SYSTEM POWER CABLE REFIXED WORKING FINE		Kanimozhi. D. - Radio Diagnosis	13/01/2023
Comp. Dt. : 02/02/2023								
Status : Completed								
2464	23020063	RADIOLOGY	NEED TO CHANGE TONER FOR MRI SYSTEM	Balachandar. A.	TONER CHANGED		Jayalakshmi. D. - Radio Diagnosis	02/02/2023
Comp. Dt. : 03/02/2023								
Status : Completed								
2465	23020095	RADIOLOGY	M R I REPORTING SYSTEM NOT WORKING	Balachandar. A.	OS reinstalled and testing its working fine		Jayalakshmi. D. - Radio Diagnosis	06/02/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 06/02/2023								
Status : Completed								
2466	23020205	RADIOLOGY	NEED TO CHANGE TONER FOR CT PRINTER	Shafiullah. R.	12 A TONER CHANGED		Jayalakshmi. D. - Radio Diagnosis	06/02/2023
Comp. Dt. : 14/02/2023								
Status : Completed								
2467	23020510	SCAN - GROUND FLOOR - BLOOD BANK OPP	SYSTEM NOT WORKING	Shafiullah. R.	CLEAN AND REFIX		Kanimozhi. D. - Radio Diagnosis	14/02/2023
Comp. Dt. : 24/02/2023								
Status : Completed								
2468	23020954	SCAN - GROUND FLOOR - BLOOD BANK OPP	NEED TO CHANGE TONER	Prakash. P.	12A toner changed		Kanimozhi. D. - Radio Diagnosis	25/02/2023
Comp. Dt. : 28/02/2023								
Status : Completed								
2469	23021044	XRy	MOUSE NOT WORKING(1522)	Selvam. D.	mouse working fine		Arunmuthu. M. - Radio Diagnosis	02/03/2023
Comp. Dt. : 02/03/2023								
Status : Completed								
2470	23030078	XRy	MOUSE NOT WORKING - CR SYSTEM	Shafiullah. R.	PS2 MOUSE CHANGED		Manikandan. G. - Radio Diagnosis	02/03/2023
Comp. Dt. : 10/03/2023								
Status : Completed								
2471	23030419	RADIOLOGY HOD ROOM	SYSTEM NOT WORKING [BASEMENT RADIOLOGY]	Jayaraj. J.	POWER CABLE REFIXED		Jayalakshmi. D. - Radio Diagnosis	10/03/2023
Comp. Dt. : 14/03/2023								
Status : Completed								
2472	23030537	XRy	MOUSE NOT WORKING - FAX ROOM	Jayaraj. J.	mouse missing		Manikandan.V. - Radio Diagnosis	15/03/2023
Comp. Dt. : 27/03/2023								
Status : Completed								
2473	23031137	RADIOLOGY	SYSTEM NOT WORKING IN FAX ROOM	Shafiullah. R.,Balachandar. A.,Selvam. D.	Hard disk not detected. New hard disk changed. os installed		Jayalakshmi. D. - Radio Diagnosis	29/03/2023
Comp. Dt. : 17/04/2023								
Status : Completed								
2474	23040493	XRy	PRINTER NOT WORKING - FAX ROOM	Shafiullah. R.	36A TONER CHANGED PRINTER WORKING		Manikandan.V. - Radio Diagnosis	17/04/2023

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHAL KUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2475	23040494	XRay	C. R. MOUSE NOT WORKING	Shafiullah. R.	MOUSE BASE CLEAN AND WORKING		Manikandan.V. - Radio Diagnosis	17/04/2023
		Comp. Dt. : 25/04/2023 Status : Completed						
2476	23040825	SCAN - GROUND FLOOR - BLOOD BANK OPP	SYSTEM NOT WORKING	Jayaraj. J.	SYSTEM SETTING CHANGED		Kanimozhi. D. - Radio Diagnosis	25/04/2023
		Comp. Dt. : 03/05/2023 Status : Completed						
2477	23050111	SCAN - GROUND FLOOR - BLOOD BANK OPP	need to change toner	Balachandar. A.	12A TONER CHANGED		Kanimozhi. D. - Radio Diagnosis	03/05/2023
		Comp. Dt. : 15/05/2023 Status : Completed						
2478	23050602	CT Scan	FAX & PRINT NOT WORKING IN CT MACHINE	Shafiullah. R.	BIO MEDICAL PROBLEM WRONG COMPLAIN		Bharani. N. - Radio Diagnosis	18/05/2023
		Comp. Dt. : 17/05/2023 Status : Completed						
2479	23050691	RADIOLOGY	SYSTEM NOT WORKING	Shafiullah. R.	FILE SERVER SHARING PROBLEM RESTART THE SYSTEM		Jayalakshmi. D. - Radio Diagnosis	17/05/2023
		Comp. Dt. : 01/06/2023 Status : Completed						
2480	23060007	RADIOLOGY	NEED TO RECONNECT PRINTER	Shafiullah. R.	PRINTER CONNECTED		Jayalakshmi. D. - Radio Diagnosis	01/06/2023
		Comp. Dt. : 06/06/2023 Status : Completed						
2481	23060173	BASEMENT SCAN	PRBLEM IN SYSTEM [SHARE] - OFFICE SYSTEM	Jayaraj. J.	RJ45 jack crimmbd		Jayalakshmi. D. - Radio Diagnosis	06/06/2023
		Comp. Dt. : 13/06/2023 Status : Completed						
2482	23060435	SCAN - GROUND FLOOR - BLOOD BANK OPP	NETWORK PROBLEM	Shafiullah. R.	SYSTEM AND RAM CLEAN REFIX		Kanimozhi. D. - Radio Diagnosis	13/06/2023
		Comp. Dt. : 19/06/2023 Status : Completed						
2483	23060656	RADIOLOGY	MOUSE NOT WORKING [FAX ROOM]	Shafiullah. R.	RIGHT CLICK BUTTON WORKING FINE		Jayalakshmi. D. - Radio Diagnosis	19/06/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 22/06/2023 Status : Completed								
2484	23060826	RADIOLOGY	NEED TO CHANGE TONER FOR MRI PRINTER	Madhubalan. S.	PRINTER TONER CHANGED		Jayalakshmi. D. - Radio Diagnosis	23/06/2023
Comp. Dt. : 23/06/2023 Status : Completed								
2485	23060852	SCAN - GROUND FLOOR - BLOOD BANK OPP	SYSTEM PROBLEM - NET & SHARE NOT WORKING	Shafiullah. R.	8PORT PLUGE REFIX		Kanimozhi. D. - Radio Diagnosis	23/06/2023
Comp. Dt. : 26/06/2023 Status : Completed								
2486	23060958	SCAN - GROUND FLOOR - BLOOD BANK OPP	NEED TO CHECK SHARE & NET CONNECTION - PROBLEM	Balachandar. A.	NETWORK CABLE CRIMBING DONE..		Sudha. D. - Radio Diagnosis	26/06/2023
2487	23060969	SCAN - GROUND FLOOR - BLOOD BANK OPP	NET & SHARE NOT WORKING - OUTSIDE SYSTEM	Balachandar. A.	I/O REFIXED WORKING FINE..		Kanimozhi. D. - Radio Diagnosis	26/06/2023
Dept Name : Reception - Computer Department Comp. Dt. : 05/05/2022 Status : Completed								
2488	22050121	Reception	NEED TO CHANGE RIBBON FOR COUNTER NO 9	Selvam. D.	COUNTER RIBBON CHANGED		Ranjithkumar. P. - Reception	05/05/2022
Comp. Dt. : 10/05/2022 Status : Completed								
2489	22050365	Reception	NEED TO CHANGE RIBBON & BARCODE STRICKER FOR COUNTER NO 9	Madhubalan. S.	10RIBBON AND NEW STRICKER CHANGED		Ranjithkumar. P. - Reception	10/05/2022
Comp. Dt. : 17/05/2022 Status : Completed								
2490	22050620	CASHCOUNTER IN RECEPTION	NEED TO CHANGE RIBBON	Jayaraj. J.	10M RIBBON CHANGED		Ranjithkumar. P. - Reception	17/05/2022
Comp. Dt. : 31/05/2022 Status : Completed								
2491	22051137	CASHCOUNTER IN RECEPTION	NEED TO CHANGE PRINTER RIBBON FOR BOTH PRINTERS	Shafiullah. R.	COUNTER 1&2 10MTS RIBBON CHANGED		Murugan. S. - Reception	31/05/2022
Comp. Dt. : 01/06/2022 Status : Completed								
2492	22060041	Reception	NEED TO CHANGE RIBBON & STRICKER FOR COUNTER NO 7	Shafiullah. R.	NEW STICKER AND WAX RIBBON CHANGED		Ranjithkumar. P. - Reception	01/06/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 02/06/2022 Status : Completed								
2493	22060043	CASHCOUNTER IN RECEPTION	SYSTEM NOT WORKING	Madhubalan. S.	SMPS REFIXED DUST CLEAN		Ranjithkumar. P. - Reception	02/06/2022
Comp. Dt. : 10/06/2022 Status : Completed								
2494	22060394	Reception	IN COUNTER 8-SYSTEM POWER OFF	Madhubalan. S.	system working fine		Sankari. K. - Reception	10/06/2022
2495	22060402	Reception	CHANGE BARCODE STICKER	Selvam. D.	New barcode sticker changed		Jayakumar. R. - Reception	10/06/2022
Comp. Dt. : 15/06/2022 Status : Completed								
2496	22060537	CASHCOUNTER IN RECEPTION	PRINTER NOT WORKING	Balachandar. A.	OIL ADDED AND CHECKED		Murugan. S. - Reception	15/06/2022
Comp. Dt. : 16/06/2022 Status : Completed								
2497	22060597	CASHCOUNTER IN RECEPTION	NEED TO CHANGE PRINTER RIBBON	Balachandar. A.	10m ribbon changed		Ranjithkumar. P. - Reception	16/06/2022
Comp. Dt. : 21/06/2022 Status : Completed								
2498	22060743	CASHCOUNTER IN RECEPTION	PROBLEM IN MONITOR - DISPLAY NOT CLEAR	Balachandar. A.	New smps changed		Murugan. S. - Reception	21/06/2022
Comp. Dt. : 29/06/2022 Status : Completed								
2499	22061035	CASHCOUNTER IN RECEPTION	NEED TO CHANGE PRINTER RIBBON 2NOS	Selvam. D.	PRINTER RIBBON CHANGED		Murugan. S. - Reception	29/06/2022
2500	22061083	Reception	NEED TO CHANGE BARCODE STRICKER FOR COUNTER NO 9 & 10	Murugavel.R	2 NOS NEW STICKER AND 1 NO BARCODE RIBBON GIVEN		Jayakumar. R. - Reception	29/06/2022
Comp. Dt. : 15/07/2022 Status : Completed								
2501	22070591	CASHCOUNTER IN RECEPTION	NEED TO CHANGE PRINTER RIBBON FOR 2 PRINTERS	Jayaraj. J.	10m ribbon changed		Murugan. S. - Reception	15/07/2022
Comp. Dt. : 03/08/2022 Status : Completed								
2502	22080105	CASHCOUNTER IN RECEPTION	NEED TO CHANGE PRINTER RIBBON	Selvam. D.	10m ribbon changed		Ranjithkumar. P. - Reception	03/08/2022
Comp. Dt. : 05/08/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2503	22080201	CASHCOUNTER IN RECEPTION	NEED TO CHECK PRINTER - PROBLEM IN PRINTER HEAD	Shafiullah. R.	Ribbon adjustment setting done		Murugan. S. - Reception	06/08/2022
	Comp. Dt. : 10/08/2022							
	Status : Completed							
2504	22080391	CASHCOUNTER IN RECEPTION	NEED TO CHANGE PRINTER RIBBON	Selvam. D.	PRINTER RIBBON CHANGED		Ranjithkumar. P. - Reception	11/08/2022
	Comp. Dt. : 12/08/2022							
	Status : Completed							
2505	22080462	Reception	NEED TO CHANGE BARCODE STRICKER AND RIBBEN	Jayaraj. J.	BARCODE STRICKER CHANGED...		Jayakumar. R. - Reception	13/08/2022
	Comp. Dt. : 06/09/2022							
	Status : Completed							
2506	22090249	CASHCOUNTER IN RECEPTION	KEYBOARD NOT WORKING	Selvam. D.	Keyboard refixed		Jayakumar. R. - Reception	07/09/2022
	Comp. Dt. : 15/09/2022							
	Status : Completed							
2507	22090594	CASHCOUNTER IN RECEPTION	PRINTER NOT WORKING	Selvam. D.	Ribbon refixed		Ranjithkumar. P. - Reception	15/09/2022
	Comp. Dt. : 19/09/2022							
	Status : Completed							
2508	22090713	CASHCOUNTER IN RECEPTION	NEED TO CHECK PRINTER - ALIGNMENT PROBLEM [BOTH 2 NOS]	Selvam. D.	Alignment done		Ranjithkumar. P. - Reception	19/09/2022
	Comp. Dt. : 21/09/2022							
	Status : Completed							
2509	22090802	CASHCOUNTER IN RECEPTION	PROBLEM IN PRINTER	Selvam. D.	PRINTER SERVICED		Murugan. S. - Reception	21/09/2022
	Comp. Dt. : 23/09/2022							
	Status : Completed							
2510	22090910	CASHCOUNTER IN RECEPTION	PROBLEM IN BILLING PRINTER COUNTER NO 9	Selvam. D.	General service done		Ranjithkumar. P. - Reception	26/09/2022
2511	22090925	CASHCOUNTER IN RECEPTION	NEED TO CHANGE BARCODE STRICKER FOR COUNTER NO 9	Balachandar. A.	BARCODE STRICKER CHANGED		Ranjithkumar. P. - Reception	23/09/2022
	Comp. Dt. : 05/10/2022							
	Status : Completed							
2512	22100035	CASHCOUNTER IN RECEPTION	PRINTER NOT WORKING	Selvam. D.	GENERAL SERVICE DONE		Murugan. S. - Reception	05/10/2022

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 11/10/2022								
Status : Completed								
2513	22100299	Reception	NEED TO CHECK KEY BOARD - NOT WORKING	Selvam. D.	cleaned and refixed		Jayakumar. R. - Reception	11/10/2022
Comp. Dt. : 12/10/2022								
Status : Completed								
2514	22100364	CASHCOUNTER IN RECEPTION	BILLING PRINTER NOT WORKING	Selvam. D.	LPT cable refixed		Jayakumar. R. - Reception	12/10/2022
Comp. Dt. : 17/10/2022								
Status : Completed								
2515	22100547	CASHCOUNTER IN RECEPTION	PRINTER NOT WORKING	Balachandar. A.	power cable refixed.		Ranjithkumar. P. - Reception	17/10/2022
2516	22100553	CASHCOUNTER IN RECEPTION	SYSTEM NOT WORKING	Shafiullah. R.	MEDPLUS NOT OPEN REFIX PATCH CARD		Karthik. V. - Reception	17/10/2022
Comp. Dt. : 19/10/2022								
Status : Completed								
2517	22100620	CASHCOUNTER IN RECEPTION	NEED TO CHANGE PRINTER RIBBON - 2 NOS	Prakash. P.	CASH COUNTER 10MTS RIBBON CHANGED		Priya. S. - Reception	19/10/2022
Comp. Dt. : 20/10/2022								
Status : Completed								
2518	22100693	Reception	NEED TO CHANGE BARCODE STICKER IN COUNTER NO.9	Balachandar. A.	double entry		Ranjithkumar. P. - Reception	20/10/2022
2519	22100698	Reception	MEDPLUS NOT WORKING IN COUNTER NO.9	Balachandar. A.	medplus working		Ranjithkumar. P. - Reception	20/10/2022
Comp. Dt. : 05/11/2022								
Status : Completed								
2520	22110160	Reception	BARCODE STICKER MACHINE NOT WORKING IN COUNTER NO.9	Selvam. D.	Logic board problem unable to service		Ranjithkumar. P. - Reception	21/11/2022
Comp. Dt. : 07/11/2022								
Status : Completed								
2521	22110253	Reception	IN COUNTER 9 -KEYBOARD NOT WORKING	Selvam. D.	Keyboard serviced		Jayakumar. R. - Reception	09/11/2022
Comp. Dt. : 15/11/2022								
Status : Completed								
2522	22110600	Reception	IN COUNTER 9-PRINTER PROBLEM	Selvam. D.	Printer working fine		Jayakumar. R. - Reception	16/11/2022
Comp. Dt. : 16/11/2022								

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
2523	22110688	Reception	IN COUNTER 9-SYSTEM NOT WORKING	Valamburi. R.	USB LAN FIXED		Ranjithkumar. P. - Reception	16/11/2022
Comp. Dt. : 23/11/2022								
Status : Completed								
2524	22110965	Reception	PRINTER NOT WORKING - COUNTER NO 9	Shafiullah. R.	PRINTER POERRCABLE REIFXED		Ranjithkumar. P. - Reception	23/11/2022
Comp. Dt. : 28/11/2022								
Status : Completed								
2525	22111163	CASHCOUNTER IN RECEPTION	SYSTEM MOUSE NOT WORKING	Shafiullah. R.	MOUSE CHANGED		Murugan. S. - Reception	28/11/2022
2526	22111197	Reception	IN COUNTER 9-CHANGE BARCODE STICKER	Balachandar. A.	BARCODE STICKER CHANGED		Ranjithkumar. P. - Reception	29/11/2022
Comp. Dt. : 01/12/2022								
Status : Completed								
2527	22120022	CASHCOUNTER IN RECEPTION	NEED TO CHANGE PRINTER RIBBON	Shafiullah. R.	10M RIBBON CHANGED		Ranjithkumar. P. - Reception	01/12/2022
2528	22120048	CASHCOUNTER IN RECEPTION	NEED TO CHANGE PRINTER RIBBON & STRICKER FOR COUNTER NO.9	Jayaraj. J.	RIBBON & STRICKER CHANGED		Ranjithkumar. P. - Reception	02/12/2022
Comp. Dt. : 06/12/2022								
Status : Completed								
2529	22120262	Reception	CHANGE BARCODE STICKER IN COUNTER 9	Jayaraj. J.	BARCODE STICKER CHANGED		Ranjithkumar. P. - Reception	06/12/2022
Comp. Dt. : 10/12/2022								
Status : Completed								
2530	22120469	CASHCOUNTER IN RECEPTION	SYSTEM NOT WORKING	Valamburi. R.	SYSTEM WORKING FINE		Murugan. S. - Reception	10/12/2022
Comp. Dt. : 19/12/2022								
Status : Completed								
2531	22120830	CASHCOUNTER IN RECEPTION	SYSTEM NOT WORKING - 2 NOS	Madhubalan. S.	SYSTEM WORKING FINE		Karthik. V. - Reception	19/12/2022
Comp. Dt. : 20/12/2022								
Status : Completed								
2532	22120908	CASHCOUNTER IN RECEPTION	SYSTEM NOT WORKING	Prakash. P.	SYSTEM WORKING FINE		Murugan. S. - Reception	20/12/2022
Comp. Dt. : 21/12/2022								
Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2533	22120994	CASUALTY RECEPTION	NEED TO CHANGE BARCODE STICKER IN COUNTER 9	Madhubalan. S.	COUNTER 9 NEW STICKER CHANGED		Ranjithkumar. P. - Reception	21/12/2022
Comp. Dt. : 30/12/2022 Status : Completed								
2534	22121381	Reception	NEED TO CHANGE BARCODE STICKER IN COUNTER 9	Prakash. P.	BARCODE STICKER CHANGED		Jayakumar. R. - Reception	31/12/2022
Comp. Dt. : 31/12/2022 Status : Completed								
2535	22121403	Reception	CHANGE PRINTER TONER IN COUNTER 9	Madhubalan. S.	12A TONER CHANGED		Murugan. S. - Reception	31/12/2022
Comp. Dt. : 04/01/2023 Status : Completed								
2536	23010151	CASHCOUNTER IN RECEPTION	SYSTEM MOUSE NOT WORKING	Shafiullah. R.	system restate mouse working fine		Priya. S. - Reception	05/01/2023
Comp. Dt. : 06/01/2023 Status : Completed								
2537	23010287	Reception	COUNTER NO=-9,NEED TO CHANGE BARCODE STICKER AND RIBBON ALSO	Madhubalan. S.	NEW BARCODE STRICKER AND BARCODE RIBBON CHANGED		Ranjithkumar. P. - Reception	07/01/2023
Comp. Dt. : 11/01/2023 Status : Completed								
2538	23010502	Reception	CHANGE BARCODE STICKER IN COUNTER 9	Shafiullah. R.	BARCODE STICKER CHANGED		Karthik. V. - Reception	12/01/2023
Comp. Dt. : 12/01/2023 Status : Completed								
2539	23010511	CASHCOUNTER IN RECEPTION	PRINTER NOT WORKING PROPERLY	Jayaraj. J.	PRINTER SETTING CHANGED		Ranjithkumar. P. - Reception	12/01/2023
Comp. Dt. : 21/01/2023 Status : Completed								
2540	23010749	Reception	NEED TO CHANGE STRICKER FOR COUNTER NO 9	Jayaraj. J.	NEW STRICKER CHANGED		Ranjithkumar. P. - Reception	21/01/2023
Comp. Dt. : 25/01/2023 Status : Completed								
2541	23010927	CASHCOUNTER IN RECEPTION	MOUSE NOT WORKING	Valamburi. R.	MOUSE WORKING		Murugan. S. - Reception	25/01/2023
2542	23010931	CASHCOUNTER IN RECEPTION	NEED TO CHANGE PRINTER RIBBON [2NOS]	Shafiullah. R.	10 mts ribbon changed 2 nos		Priya. S. - Reception	25/01/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 27/01/2023 Status : Completed								
2543	23010951	Reception	MOUSE NOT WORKING COUNTER NO 10	Selvam. D.	USB MOUSE REFIX		Murugan. S. - Reception	27/01/2023
Comp. Dt. : 28/01/2023 Status : Completed								
2544	23010995	Reception	MOUSE NOT WORKING	Madhubalan. S.	NEW USB MOUSE CHANGED		Sankari. K. - Reception	28/01/2023
Comp. Dt. : 02/02/2023 Status : Completed								
2545	23020073	Reception	NEED TO CHANGE BARCODE STRICKER FOR COUNTER NO 9	Selvam. D.	New barcode sticker changed		Ranjithkumar. P. - Reception	03/02/2023
Comp. Dt. : 04/02/2023 Status : Completed								
2546	23020116	CASHCOUNTER IN RECEPTION	NEED TO CHANGE PRINTER RIBBON	Selvam. D.	10m ribbon changed		Priya. S. - Reception	04/02/2023
Comp. Dt. : 13/02/2023 Status : Completed								
2547	23020450	CASHCOUNTER IN RECEPTION	NEED TO CHANGE PRINTER RIBBON FOR BILLING MACHINE	Shafiullah. R.	COUNTER 9 10 MTS RIBBON CHANGED		Ranjithkumar. P. - Reception	13/02/2023
Comp. Dt. : 17/02/2023 Status : Completed								
2548	23020689	Reception	SYSTEM NOT WORKING - COUNTER NO 10	Shafiullah. R.	SYSTEM WORKING		Sankari. K. - Reception	17/02/2023
2549	23020711	Reception	NEED TO CHANGE STRICKER FOR COUNTER NO 9	Shafiullah. R.	NEW BARCODE STRICKER CHANGED		Ranjithkumar. P. - Reception	17/02/2023
Comp. Dt. : 02/03/2023 Status : Completed								
2550	23030084	CASHCOUNTER IN RECEPTION	PRINTER NOT WORKING NEED URGENT SERVICE	Shafiullah. R.	PRINTER ADJUST SETTING		Karthik. V. - Reception	02/03/2023
2551	23030108	CASHCOUNTER IN RECEPTION	NEED TO CHANGE RIBBON & STRICKER FOR COUNTER NO 9	Shafiullah. R.	NEW STRICKER AND WAX RIBBON CHANGED		Ranjithkumar. P. - Reception	03/03/2023
Comp. Dt. : 03/03/2023 Status : Completed								
2552	23030157	CASHCOUNTER IN RECEPTION	NEED TO CHANGE BARCODE STRICKER	Selvam. D.	BARCODE STRICKER CAHNGED		Karthik. V. - Reception	04/03/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 09/03/2023 Status : Completed								
2553	23030378	CASHCOUNTER IN RECEPTION	NEED TO CHANGE PRINTER RIBBON 2NOS	Jayaraj. J.	10M RIBBON CHANGED		Ranjithkumar. P. - Reception	09/03/2023
Comp. Dt. : 10/03/2023 Status : Completed								
2554	23030436	Reception	NEED TO CHECK SYSTEM - "CONTROL F" NOT WORKING	Jayaraj. J.	MICROSOFT EXCEL SETTING CHANGED		Sankari. K. - Reception	10/03/2023
Comp. Dt. : 20/03/2023 Status : Completed								
2555	23030763	CASHCOUNTER IN RECEPTION	SYSTEM NOT WORKING	Selvam. D.	system working fine		Murugan. S. - Reception	20/03/2023
Comp. Dt. : 23/03/2023 Status : Completed								
2556	23030980	Reception	NEED TO CHANGE PRINTER RIBBON & STRICKER FOR COUNTER NO 9	Madhubalan. S.	STRICKER AND RIBBON CHANGED		Ranjithkumar. P. - Reception	24/03/2023
Comp. Dt. : 24/03/2023 Status : Completed								
2557	23031025	Reception	NEED TO CHANGE BARCODE STRICKER [2NOS] & RIBBON FOR COUNTER NO 9	Balachandar. A.	barcode stricker conter 3,9 and ribbon changed		Jayakumar. R. - Reception	24/03/2023
Comp. Dt. : 08/04/2023 Status : Completed								
2558	23040214	CASHCOUNTER IN RECEPTION	PRINTER NOT WORKING	Valamburi. R.	working fine well		Murugan. S. - Reception	08/04/2023
Comp. Dt. : 12/04/2023 Status : Completed								
2559	23040386	Reception	NEED TO CHANGE PRINTER RIBBON & STRICKER FOR COUNTER NO 9	Shafiullah. R.	2 NO'S NEW STRICKER CHANGED		Ranjithkumar. P. - Reception	12/04/2023
Comp. Dt. : 15/04/2023 Status : Completed								
2560	23040430	CASHCOUNTER IN RECEPTION	SYSTEM NOT WORKING	Jayaraj. J.	system working fine		Priya. S. - Reception	17/04/2023
Comp. Dt. : 25/04/2023 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2561	23040832	Reception	NEED TO CHANGE BARCODE STRICKER FOR COUNTER NO 9	Shafiullah. R.	BARCODE STRICKER CHANGED		Viknesh. V. - Reception	26/04/2023
Comp. Dt. : 27/04/2023 Status : Completed								
2562	23040940	CASHCOUNTER IN RECEPTION	NEED TO CHANGE STRICKER & RIBBON FOR COUNTER NO 9	Madhubalan. S.	STRICKER and RIBBON CHANGED		Ranjithkumar. P. - Reception	28/04/2023
Comp. Dt. : 05/05/2023 Status : Completed								
2563	23050215	CASHCOUNTER IN RECEPTION	NEED TO CHANGE PRINTER RIBBON & STRICKER	Selvam. D.	RIBBON AND STICKER CHANGED		Ranjithkumar. P. - Reception	06/05/2023
Comp. Dt. : 09/05/2023 Status : Completed								
2564	23050389	Reception	NEED TO CHANGE BARCODE STRICKER	Valamburi. R.	BARCODE STRICKER CHANGED		Jayakumar. R. - Reception	11/05/2023
Comp. Dt. : 16/05/2023 Status : Completed								
2565	23050632	CASHCOUNTER IN RECEPTION	NEED TO CHANGE PRINTER RIBBON COUNTER NO 11	Selvam. D.	10m ribbon changed		Murugan. S. - Reception	16/05/2023
Comp. Dt. : 23/05/2023 Status : Completed								
2566	23050928	CASHCOUNTER IN RECEPTION	NEED TO CHANGE STRICKER FOR COUNTER NO 9	Shafiullah. R.	NEW STRICKER CHANGED 2 NOS AND WAX RIBBON CHANGED		Ranjithkumar. P. - Reception	24/05/2023
Comp. Dt. : 25/05/2023 Status : Completed								
2567	23050992	Pay Pharmacy	NEED TO CHANGE PRINTER RIBBON 3 NOS	Shafiullah. R.	10MTS CATRIAGE COUNT 2		Silambarasan. K. - Reception	25/05/2023
2568	23050996	CASHCOUNTER IN RECEPTION	PRINTER NOT WORKING	Selvam. D.	PRINTER RIBBON REFIX		Priya. S. - Reception	25/05/2023
Comp. Dt. : 31/05/2023 Status : Completed								
2569	23051248	Reception	KEYBOARD CABLE PROBLEM IN COUNTER NO 12	Madhubalan. S.	OLD KEYBOARD CHANGED		Murugan. S. - Reception	31/05/2023
Comp. Dt. : 01/06/2023 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2570	23060017	CASHCOUNTER IN RECEPTION	PRINTER NOT WORKING	Madhubalan. S.	POWER CABLE REFIXED WORKING FINE		Priya. S. - Reception	01/06/2023
		Comp. Dt. : 05/06/2023 Status : Completed						
2571	23060122	Reception	SYSTEM NOT WORKING - COUNTER NO 10	Balachandar. A.	KEYBOARD CHANGED		Sankari. K. - Reception	05/06/2023
2572	23060156	CASHCOUNTER IN RECEPTION	NEED TO CHANGE PRINTER RIBBON 2NOS	Shafiullah. R.	CASH COUNTER 1@2 10MTS RIBBON CHANGED		Murugan. S. - Reception	05/06/2023
		Comp. Dt. : 08/06/2023 Status : Completed						
2573	23060294	CASHCOUNTER IN RECEPTION	PRINTER NOT WORKING	Selvam. D.	Paper jam cleared		Priya. S. - Reception	08/06/2023
		Comp. Dt. : 12/06/2023 Status : Completed						
2574	23060432	CASHCOUNTER IN RECEPTION	NEED TO CHANGE STRICKER & PRINTER RIBBON	Jayaraj. J.	STRICKER AND RIBBON CHANGED		Ranjithkumar. P. - Reception	13/06/2023
		Comp. Dt. : 15/06/2023 Status : Completed						
2575	23060526	Reception	COUNTER NO-10,KEYBOARD NOT WORKING	Shafiullah. R.	PS2 KEYBOARD REFIX AND SYSTEM RESTART		Sankari. K. - Reception	15/06/2023
		Comp. Dt. : 16/06/2023 Status : Completed						
2576	23060614	Reception	NEED TO CHANGE NEW BARCODE STICKER	Harikrishnan. R.	2no's new stricker changed		Amarvan. N. - Reception	17/06/2023
		Comp. Dt. : 21/06/2023 Status : Completed						
2577	23060751	CASHCOUNTER IN RECEPTION	NEED TO CHANGE PRINTER RIBBON 2NOS	Madhubalan. S.	COUNTER 1 & 2 10m RIBBON CHANGED		Ranjithkumar. P. - Reception	21/06/2023
		Comp. Dt. : 27/06/2023 Status : Completed						
2578	23061037	CASHCOUNTER IN RECEPTION	NEED TO CHANGE PRINTER RIBBON - NEED URGENT SERVICE	Shafiullah. R.	10m ribbon changed		Priya. S. - Reception	28/06/2023
		Comp. Dt. : 28/06/2023 Status : Completed						
2579	23061080	CASHCOUNTER IN RECEPTION	BILLING PRINTER STUCK	Balachandar. A.	PRINTER SERVICED		Jayakumar. R. - Reception	28/06/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Dept Name : RICU - Computer Department Comp. Dt. : 21/05/2022 Status : Completed								
2580	22050796	RICU	PRINTER NOT WORKING	Selvam. D.	PRINTER WORKING FINE		Arunkumar. D. - POW & SICU	23/05/2022
Comp. Dt. : 26/12/2022 Status : Completed								
2581	22121167	ICU	SYSTEM NOT WORKING	Balachandar. A.	SYSTEM WORKING FINE		Tamililakkiya. K. - RICU	27/12/2022
Comp. Dt. : 07/06/2023 Status : Completed								
2582	23060237	ICU	NEED TO CHANGE TONER	Shafiullah. R.	12A TONER CHANGED		Silambarasan. S. - RICU	07/06/2023
Dept Name : Security - SIS - Computer Department Comp. Dt. : 31/12/2022 Status : Completed								
2583	22121402	Reception	CHANGE PRINTER TONER IN COUNTER 9	Valamburi. R.	USER NAME ENTERED WRONGLY		Murugan. S. - Security - SIS	31/12/2022
Dept Name : Skill Lab - Computer Department Comp. Dt. : 10/12/2022 Status : Completed								
2584	22120454	ICU	PRINTER NOT WORKING	Valamburi. R.	PENDING JOB CLEARED		Santhiya. P. - Skill Lab	10/12/2022
Comp. Dt. : 27/12/2022 Status : Completed								
2585	22121197	ICU	NEED TO CHANGE PRINTER TONER	Shafiullah. R.	12A TONER CHANGED		Santhiya. P. - Skill Lab	27/12/2022
Dept Name : SMV Allied Health Sciences - Computer Department Comp. Dt. : 13/03/2023 Status : Completed								
2586	23030513	MICROBIOLOGY IN COLLEGE	NEED TO CHANGE TONER FOR TUTOR SYSTEM	Jayaraj. J.	12A TONER CHANGED		Raffik Moideen. M. - SMV Allied Health Sciences	15/03/2023
Comp. Dt. : 29/03/2023 Status : Completed								
2587	23031261	MICROBIOLOGY IN COLLEGE	NET WORK PROBLEM - NEED TO CHECK SYSTEM	Shafiullah. R.	NETWORKING		Raffik Moideen. M. - SMV Allied Health Sciences	01/04/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 02/05/2023 Status : Completed								
2588	23050047	MICROBIOLOGY IN COLLEGE	SYSTEM CAMERA SOFTWARE NOT WORKING IN TUTOR ROOM	Valamburi. R.	CAMERA CONFIGURED COMPLETED		Raffik Moideen. M. - SMV Allied Health Sciences	04/05/2023
Comp. Dt. : 21/06/2023 Status : Completed								
2589	23060764	MICROBIOLOGY IN COLLEGE	CAMERA SOFTWARE NOT WORKING	Shafiullah. R.	CAMERA WORKING		Raffik Moideen. M. - SMV Allied Health Sciences	23/06/2023
Dept Name : Special Clinic - Computer Department Comp. Dt. : 02/05/2022 Status : Completed								
2590	22050003	Reception	NEED TO CHANGE STRICKER FOR COUNTER NO 3 & 4 - CHANGE RIBBON FOR COUNTER NO 3	Shafiullah. R.	COUNTER NO 3&4 NEW STRICKER CHANGED AND COUNTER 2 BARCODE RIBBON JAM CLEAR		Baskar. G. - Special Clinic - Reception	02/05/2022
2591	22050040	Reception	NEED TO CHANGE RIBBON FOR COUNTER NO 3	Balachandar. A.	Ribbon changed		Baskar. G. - Special Clinic - Reception	04/05/2022
2592	22050048	Reception	PRINTER PROBLEM IN COUNTER NO 8	Madhubalan. S.	Toner Changed		Baskar. G. - Special Clinic - Reception	04/05/2022
2593	22050050	Special Ward - C	SYSTEM NOT WORKING [FEMALE SIDE]	Selvam. D.	System Working		Baskar. G. - Special Clinic - Reception	04/05/2022
Comp. Dt. : 04/05/2022 Status : Completed								
2594	22050113	Reception	NEED TO CHANGE STRICKER FOR COUNTER NO 4	Selvam. D.	NEW STRICKER CHANGED		Baskar. G. - Special Clinic - Reception	05/05/2022
Comp. Dt. : 06/05/2022 Status : Completed								
2595	22050167	Reception	NEED TO CHANGE STRICKER [NEW REG] FOR COUNTER NO 3 & 4	Murugavel.R	COUNTER 2,3,4 NEW STRICKER CHANGED		Baskar. G. - Special Clinic - Reception	06/05/2022
2596	22050168	SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	PRINTER NOT WORKING	Balachandar. A.	os reinstalled and printer installed..		Uma Maheswari. D. - Special OPD	09/05/2022
2597	22050219	Reception	PRINTER NOT WORKING IN COUNTER NO 5	Selvam. D.	Power cable refixed		Baskar. G. - Special Clinic - Reception	07/05/2022
Comp. Dt. : 07/05/2022 Status : Completed								
2598	22050221	Special Ward - C	NEED TO CHANGE TONER	Balachandar. A.	TONER CHANGED		Geetha. J. - Special Clinic - Reception	07/05/2022

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2599	22050228	SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	PRINTER & SYSTEM NOT WORKING	Selvam. D.	printer shared and settings changed...		Uma Maheswari. D. - Special OPD	09/05/2022
Comp. Dt. :		09/05/2022						
Status :		Completed						
2600	22050269	Reception	NEED TO CHANGE STRICKER FOR COUNTER NO 2 & 3	Madhubalan. S.	COUNTER 2,3,5 NEW STICKER CHANGED		Baskar. G. - Special Clinic - Reception	09/05/2022
Comp. Dt. :		10/05/2022						
Status :		Completed						
2601	22050318	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	BARCODE MACHINE NOT WORKING	Selvam. D.	Power cable refixed		Saranya. S. - Clinical Department	10/05/2022
2602	22050344	Reception	NEED TO CHANGE RIBBON & STRICKER FOR COUNTER NO 5	Madhubalan. S.	COUNTER 5 BARCODE AND NEW STICKER CHANGED		Baskar. G. - Special Clinic - Reception	10/05/2022
2603	22050354	Reception	NEED TO CHANGE STRICKER FOR COUNTER NO 3	Shafiullah. R.	NEW STRICKER CHANGED		Baskar. G. - Special Clinic - Reception	10/05/2022
Comp. Dt. :		11/05/2022						
Status :		Completed						
2604	22050394	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	NEED TO CHANGE BARCODE STICKER RIBBON	Madhubalan. S.	BARCODE RIBBON CHANGED		Saranya. S. - Clinical Department	11/05/2022
Comp. Dt. :		12/05/2022						
Status :		Completed						
2605	22050412	Reception	NEED TO CHANGE PRINTR RIBBON-COUNTER NO-3.	Selvam. D.	barcode ribbon changed		Vijai. M. - Medical Records	12/05/2022
2606	22050442	Reception	CHANGE BARCODE STICKER IN COUNTER 4	Shafiullah. R.	NEW BARCODE STICKER CHANGED		Baskar. G. - Special Clinic - Reception	12/05/2022
Comp. Dt. :		13/05/2022						
Status :		Completed						
2607	22050454	Reception	NEED TO CHANGE REVISIT BARCODE STICKER	Selvam. D.	REVISIT BARCODE STICKER CHANGED		Vijayalakshmi. B. - Special Clinic	13/05/2022
2608	22050474	Reception	IN COUNTER 2-CHANGE BARCODE STICKER	Jayaraj. J.	BARCODE STICKER CHANGED		Baskar. G. - Special Clinic - Reception	13/05/2022
Comp. Dt. :		16/05/2022						
Status :		Completed						
2609	22050512	Reception	MOUSE NOT WORKING - COUNTER NO 9	Jayaraj. J.	USB MOUSE CABLE REFIXED		Baskar. G. - Special Clinic - Reception	16/05/2022
2610	22050559	Reception	NEED TO CHANGE STRICKER FOR COUNTER NO 3	Jayaraj. J.	COUNTER 3 NEW STRICKER CHANGED		Baskar. G. - Special Clinic - Reception	16/05/2022

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2611	22050571	SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	PROBLEM IN MED PLUS	Shafiullah. R.	SYSTEM DATE CHANGED		Uma Maheswari. D. - Special OPD	17/05/2022
Comp. Dt. :		17/05/2022						
Status :		Completed						
2612	22050589	Reception	SENCOR NOT WORKING IN COUNTER NO 6	Balachandar. A.	usb cable refixed...		Vijayalakshmi. B. - Special Clinic	17/05/2022
2613	22050591	Reception	LAPTOP NOT WORKING - COUNTER NO 1	Balachandar. A.	Laptop cooling fan and keyboard changed		Baskar. G. - Special Clinic - Reception	07/06/2022
2614	22050637	Reception	NEED TO CHECK SYSTEM - NOT WORKING - COUNTER NO 2	Balachandar. A.	system working fine		Baskar. G. - Special Clinic - Reception	19/05/2022
Comp. Dt. :		18/05/2022						
Status :		Completed						
2615	22050638	Reception	NEED TO CHANGE STRICKER FOR COUNTER NO 4	Jayaraj. J.	NEW BARCODE STRICKER CHANGED		Baskar. G. - Special Clinic - Reception	18/05/2022
2616	22050646	Reception	NEED TO CHANGE STRICKER FOR COUNTER NO 2	Balachandar. A.	STRICKER CHANGED		Baskar. G. - Special Clinic - Reception	18/05/2022
2617	22050657	Reception	NEED TO CHECK SYSTEM - NOT WORKING - COUNTER NO 2	Balachandar. A.	System working fine		Baskar. G. - Special Clinic - Reception	19/05/2022
2618	22050674	Reception	NEED TO CHANGE BARCODE STRICKER FOR COUNTER NO 5	Selvam. D.	New barcode sticker changed		Baskar. G. - Special Clinic - Reception	19/05/2022
Comp. Dt. :		19/05/2022						
Status :		Completed						
2619	22050684	Reception	NEED TO CHANGE REVISIT STRICKER FOR COUNTER NO 6	Selvam. D.	Revisit sticker changed		Baskar. G. - Special Clinic - Reception	19/05/2022
2620	22050687	Reception	NEED TO CHANGE STRICKER FOR COUNTER NO 6	Selvam. D.	Revisit sticker changed		Baskar. G. - Special Clinic - Reception	19/05/2022
2621	22050710	Reception	NEED TO CHANGE RIBBON FOR COUNTER NO 8	Madhubalan. S.	12A TONER CHANGED		Baskar. G. - Special Clinic - Reception	19/05/2022
2622	22050729	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	NEED TO CHANGE TONER	Madhubalan. S.	12A TONER CHANGED		Saranya. S. - Clinical Department	19/05/2022
Comp. Dt. :		20/05/2022						
Status :		Completed						
2623	22050751	Reception	NEED TO CHECK BARCODE PRINTER - NOT WORKING	Selvam. D.	COUTER 5 BARCODE PRINTER WORKING AND WAX RIBBON CHANGED		Baskar. G. - Special Clinic - Reception	20/05/2022
Comp. Dt. :		21/05/2022						
Status :		Completed						


Dr. KAGNE. R.N.
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2624	22050779	Reception	NEED TO CHANGE BARCODE STRICKER FOR COUNTER NO 4	Balachandar. A.	BARCODE STRICKER CHANGED		Baskar. G. - Special Clinic - Reception	21/05/2022
2625	22050806	Reception	NEED TO CHANGE STRICKER FOR COUNTER NO 2	Selvam. D.	New barcode sticker changed		Baskar. G. - Special Clinic - Reception	23/05/2022
Comp. Dt. : 23/05/2022								
Status : Completed								
2626	22050812	Reception	NEED TO CHANGE STRICKER FOR COUNTER NO 3 & 5	Selvam. D.	New barcode sticker changed		Baskar. G. - Special Clinic - Reception	23/05/2022
2627	22050820	Reception	NEED TO CHANGE RIBBON FOR COUNTER NO 6	Balachandar. A.	RIBBON CHANGED		Baskar. G. - Special Clinic - Reception	23/05/2022
2628	22050826	SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	NEED TO CHANGE TONER	Madhubalan. S.	12A TONER CHANGED		Monica Sales. D. - Special Clinic - Office	23/05/2022
2629	22050839	Reception	NEED TO CHANGE STRICKER FOR COUNTER NO 5	Balachandar. A.	STRICKER CHANGED		Baskar. G. - Special Clinic - Reception	23/05/2022
2630	22050846	Reception	PRINTER NOT WORKING - COUNTER NO 9	Shafiullah. R.	printer pickup roll clean printer working fine		Baskar. G. - Special Clinic - Reception	23/05/2022
Comp. Dt. : 24/05/2022								
Status : Completed								
2631	22050856	Reception	NEED TO CHANGE REVISIT STRICKER FOR COUNTER NO 6	Madhubalan. S.	COUNTER 6 REVISITE STICKER CHANGED		Baskar. G. - Special Clinic - Reception	24/05/2022
2632	22050875	Reception	NEED TO CHANGE TONER FOR COUNTER NO 9 + SYSTEM NOT WORKING COUNTER NO 1	Shafiullah. R.	12a TONER CHANGED COUNTER 9 + SYSTEM WORKING FINE COUNTER 1		Baskar. G. - Special Clinic - Reception	24/05/2022
Comp. Dt. : 25/05/2022								
Status : Completed								
2633	22050946	Reception	NEED TO CHANGE STRICKER FOR COUNTER NO 3	Madhubalan. S.	COUNTER 3 NEW STICKER CHANGED		Baskar. G. - Special Clinic - Reception	25/05/2022
2634	22050958	Reception	NEED TO CHANGE BARCODE STRICKER FOR COUNTER NO 4	Valamburi. R.	BARCODE STRICKER CHANGED		Baskar. G. - Special Clinic - Reception	25/05/2022
2635	22050962	Reception	NEED TO CHANGE STRICKER FOR COUNTER NO 3 & 5	Balachandar. A.	STRICKER CHANGED		Baskar. G. - Special Clinic - Reception	25/05/2022
Comp. Dt. : 26/05/2022								
Status : Completed								
2636	22050973	Reception	NEED TO CHANGE TONER FOR COUNTER NO 8	Valamburi. R.	12a TONER CHANGED		Baskar. G. - Special Clinic - Reception	26/05/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2637	22050985	Reception	MONITOR DAMAGE - NEED TO CHANGE - FOR COUNTER NO 1	Shafiullah. R.	hp monitor changed		Baskar. G. - Special Clinic - Reception	30/05/2022
2638	22050987	SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	BIO METRIC MACHINE NOT WORKING	Balachandar. A.	settings changed..		Kalaivani. K. - Special Clinic - Office	27/05/2022
Comp. Dt. : 27/05/2022 Status : Completed								
2639	22051019	Reception	NEED TO CHANGE STRICKER FOR COUNTER NO 5	Balachandar. A.	STRICKER CHANGED		Baskar. G. - Special Clinic - Reception	27/05/2022
2640	22051028	Reception	NEED TO CHANGE STRICKER FOR COUNTER NO 3	Shafiullah. R.	NEW STRICKER CHANGED		Baskar. G. - Special Clinic - Reception	27/05/2022
Comp. Dt. : 31/05/2022 Status : Completed								
2641	22051130	Reception	NEED TO CHANGE STRICKER FOR COUNTER NO 5	Madhubalan. S.	COUNTER 5 NEW STICKER CHANGED		Baskar. G. - Special Clinic - Reception	31/05/2022
2642	22051147	Reception	NEED TO CHANGE STRICKER FOR COUNTER NO 4	Shafiullah. R.	New barcode sticker changed		Baskar. G. - Special Clinic - Reception	01/06/2022
Comp. Dt. : 01/06/2022 Status : Completed								
2643	22060037	Reception	SCANNER NOT WORKING IN COUNTER NO 1	Madhubalan. S.	SCANNER WORKING FINE		Baskar. G. - Special Clinic - Reception	01/06/2022
2644	22060039	Reception	NEED TO CHANGE STRICKER FOR COUNTER NO 3	Madhubalan. S.	new stricker changed		Baskar. G. - Special Clinic - Reception	01/06/2022
Comp. Dt. : 02/06/2022 Status : Completed								
2645	22060044	Reception	NEED TO CHANGE STRICKER FOR COUNTER NO 5	Madhubalan. S.	NEW STICKER CHANGED		Baskar. G. - Special Clinic - Reception	02/06/2022
2646	22060063	Reception	NEED TO CHANGE RIBBON FOR COUNTER NO 3	Balachandar. A.	RIBBON CHANGED		Baskar. G. - Special Clinic - Reception	02/06/2022
2647	22060093	Reception	NEED TO CHANGE STRICKER FOR COUNTER NO 3	Selvam. D.	new barcode sticker changed		Baskar. G. - Special Clinic - Reception	02/06/2022
Comp. Dt. : 03/06/2022 Status : Completed								
2648	22060110	Reception	NEED TO CHANGE STRICKER FOR COUNTER NO 5	Jayaraj. J.	STRICKER CHANGED		Baskar. G. - Special Clinic - Reception	03/06/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2649	22060116	Reception	NEED TO CHANGE REVISIT STRICKER FOR COUNTER NO 6	Jayaraj. J.	REVISIT STRICKER CHANGED		Baskar. G. - Special Clinic - Reception	03/06/2022
2650	22060147	Reception	NEED TO CHECK UPS LINE CONNECTION FOR COUNTER NO 1 - DUE TO POWER PROBLEM SYSTEM AUTOMATICALLY SHUT	Shafiullah. R.	COMPLAIN SHIFT TO ELECTRICAL DEPT		Baskar. G. - Special Clinic - Reception	04/06/2022
Comp. Dt. : 06/06/2022 Status : Completed								
2651	22060205	Reception	NEED TO CHANGE TONER FOR COUNTER NO 8	Madhubalan. S.	12A toner changed		Baskar. G. - Special Clinic - Reception	06/06/2022
2652	22060227	Reception	NEED TO CHANGE STRICKER FOR COUNTER NO 2	Jayaraj. J.	NEW STRICKER CHANGED		Baskar. G. - Special Clinic - Reception	06/06/2022
2653	22060230	Reception	NEED TO CHANGE STRICKER FOR COUNTER NO 5	Madhubalan. S.	STRICKER CHANGED		Baskar. G. - Special Clinic - Reception	07/06/2022
Comp. Dt. : 07/06/2022 Status : Completed								
2654	22060274	Special Ward - C	NEED TO CHANGE TONER	Madhubalan. S.	12A TONER CHANGED		Geetha. J. - Special Clinic - Reception	07/06/2022
Comp. Dt. : 08/06/2022 Status : Completed								
2655	22060289	Reception	SCANNER NOT WORKING - COUNTER NO 1	Selvam. D.	scanner working fine		Baskar. G. - Special Clinic - Reception	08/06/2022
2656	22060301	Reception	NEED TO CHANGE STRICKER FOR COUNTER NO 4 & 5 & REVISIT STRICKER FOR COUNTER NO 6	Madhubalan. S.	COUNTER 4,5 AND 6 NEW STICHER, REVISIT STICKER CHANGED		Baskar. G. - Special Clinic - Reception	08/06/2022
2657	22060312	Special Ward - C	SYSTEM NOT WORKING	Jayaraj. J.	NETWORK SWICTH RESTARTED		Geetha. J. - Special Clinic - Reception	08/06/2022
2658	22060320	Reception	NEED TO CHANGE RIBBON FOR COUNTER NO 5	Balachandar. A.	barcode ribbon changed		Baskar. G. - Special Clinic - Reception	09/06/2022
Comp. Dt. : 09/06/2022 Status : Completed								
2659	22060326	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	NEED TO CHANGE TONER	Madhubalan. S.	12A TONER CHANGED		Saranya. S. - Clinical Department	09/06/2022
2660	22060342	SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	NEED SCANNER INSTALLATION	Balachandar. A.	NEW SCANNER INSTALLED		Thamizhselvi. S. - Administration	09/06/2022
2661	22060351	Reception	NEED TO CHANGE BARCODE STRICKER FOR COUNTER NO 4	Balachandar. A.	BARCODE STRICKER CHANGED		Baskar. G. - Special Clinic - Reception	09/06/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 10/06/2022								
Status : Completed								
2662	22060396	Reception	IN COUNTER 2 CHNAGE BARCODE STICKER.	Madhubalan. S.	COUNTER 2 NEW STICKER CHANGED		Savitha. K. - Special Clinic - Reception	10/06/2022
Comp. Dt. : 11/06/2022								
Status : Completed								
2663	22060410	Reception	NEED TO CHANGE STRICKER FOR COUNTER NO 5	Madhubalan. S.	COUNTER 5 NEW STICKER CHANGED		Baskar. G. - Special Clinic - Reception	11/06/2022
2664	22060426	Reception	NEED TO CHANGE BARCODE STRICKER FOR COUNTER NO 4	Murugavel.R	BARCODE STRICKER CHANGED		Baskar. G. - Special Clinic - Reception	11/06/2022
Comp. Dt. : 13/06/2022								
Status : Completed								
2665	22060449	Reception	NEED TO CHANGE STRICKER FOR COUNTER NO 4	Jayaraj. J.	NEW BARCODE STRICKER CHANGED		Baskar. G. - Special Clinic - Reception	13/06/2022
2666	22060478	Reception	NEED TO CHANGE PRINTER RIBBON FOR COUNTER NO 4	Jayaraj. J.	COUNTER 4 BARCODE STICKER CHANGED		Baskar. G. - Special Clinic - Reception	13/06/2022
Comp. Dt. : 14/06/2022								
Status : Completed								
2667	22060491	SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	NEED BIOMETRIC INSTALLATION	Balachandar. A.	NEW biometric installed...		Thamizhselvi. S. - Administration	14/06/2022
2668	22060515	Reception	NEED TO CHANGE STRICKER FOR COUNTER NO 5 & REVISIT STRICKER FOR COUNTER NO 6	Shafiullah. R.	NEW STRICKE COUNTER 5 AND COUNTER 6 REVISIT STICKER CHANGED		Baskar. G. - Special Clinic - Reception	14/06/2022
Comp. Dt. : 15/06/2022								
Status : Completed								
2669	22060551	Reception	NEED TO CHANGE STRICKER FOR COUNTER NO 3	Balachandar. A.	STRICKER CHANGED		Baskar. G. - Special Clinic - Reception	15/06/2022
2670	22060560	Reception	NEED TO CHANGE RIBBON FOR COUNTER NO 6	Balachandar. A.	RIBBON REFIXED..		Baskar. G. - Special Clinic - Reception	15/06/2022
2671	22060570	Reception	NEED TO CHANGE BARCODE STRICKER FOR COUNTER NO 4	Balachandar. A.	BARCODE STRICKER CHANGED		Baskar. G. - Special Clinic - Reception	15/06/2022
2672	22060590	Reception	NEED TO CHANGE TONER FOR COUNTER NO 8	Balachandar. A.	COUNTER TONER CHANGED		Baskar. G. - Special Clinic - Reception	16/06/2022
Comp. Dt. : 16/06/2022								
Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2673	22060594	Reception	NEED TO CHANGE BARCODE STRICKER FOR COUNTER NO 3 & RIBBON FOR COUNTER NO 5	Selvam. D.	Counter 5 ribbon refixed and counter 3 new barcode sticker changed		Baskar. G. - Special Clinic - Reception	16/06/2022
Comp. Dt. : 17/06/2022								
Status : Completed								
2674	22060633	Reception	NEED TO CHANGE STRICKER FOR COUNTER NO 2 & 3	Balachandar. A.	STRICKER CHANGED		Baskar. G. - Special Clinic - Reception	17/06/2022
Comp. Dt. : 18/06/2022								
Status : Completed								
2675	22060682	Reception	NEED TO CHANGE RIBBON & STRICKER FOR COUNTER NO 5	Selvam. D.	RIBBON & STRICKER CHANGED		Baskar. G. - Special Clinic - Reception	18/06/2022
Comp. Dt. : 20/06/2022								
Status : Completed								
2676	22060694	Reception	NEED TO CHANGE TONER FOR COUNTER NO 8	Valamburi. R.	TONER CHANGED		Baskar. G. - Special Clinic - Reception	20/06/2022
2677	22060703	SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	NEED TO CHANGE TONER	Madhubalan. S.	12a toner changed		Uma Maheswari. D. - Special OPD	20/06/2022
2678	22060710	Reception	NEED TO CHANGE RIBBON FOR COUNTER NO 6	Madhubalan. S.	COUNTER 6 BARCODE RIBBON CHANGED		Baskar. G. - Special Clinic - Reception	20/06/2022
2679	22060715	Reception	PROBLEM IN BARCODE PRINTER - COUNTER NO 4	Madhubalan. S.	BARCODE RIBBON REFIXED		Baskar. G. - Special Clinic - Reception	20/06/2022
2680	22060731	SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	NEED TO CHANGE TONER	Madhubalan. S.	12A toner changed		Monica Sales. D. - Special Clinic - Office	21/06/2022
Comp. Dt. : 21/06/2022								
Status : Completed								
2681	22060759	Reception	NEED TO CHANGE STRICKER FOR COUNTER NO 4	Shafiullah. R.	STRICKER CHANGED		Baskar. G. - Special Clinic - Reception	21/06/2022
2682	22060764	Reception	NEED TO CHANGE STRICKER FOR COUNTER NO 5	Balachandar. A.	STRICKER CHANGED		Baskar. G. - Special Clinic - Reception	21/06/2022
Comp. Dt. : 22/06/2022								
Status : Completed								
2683	22060785	Reception	PRINTER NOT WORKING - COUNTER NO 2	Balachandar. A.	barcode refix and re arranged		Baskar. G. - Special Clinic - Reception	22/06/2022
Comp. Dt. : 23/06/2022								
Status : Completed								
2684	22060821	Reception	NEED TO CHANGE RIBBON FOR COUNTER NO 4	Murugavel.R	NEW BARCODE RIBBON CHANGED		Baskar. G. - Special Clinic - Reception	23/06/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 24/06/2022 Status : Completed								
2685	22060883	Reception	PROBLEM IN BARCODE PRINTER - JAM	Jayaraj. J.	RIBBON REFIXED PROBLEM SLOVED		Baskar. G. - Special Clinic - Reception	24/06/2022
Comp. Dt. : 27/06/2022 Status : Completed								
2686	22060940	Reception	SCANER NOT WORKING COUNTER NO 6	Selvam. D.	Barcode scanner refixed		Baskar. G. - Special Clinic - Reception	27/06/2022
2687	22060967	Reception	NEED TO CHANGE STRICKER FOR COUNTER NO 5	Shafiullah. R.	STRICKER CHANGED		Baskar. G. - Special Clinic - Reception	27/06/2022
Comp. Dt. : 29/06/2022 Status : Completed								
2688	22061033	Reception	NEED TO CHANGE STRICKER FOR COUNTER NO 4 & 5	Balachandar. A.	STRICKER CHANGED		Baskar. G. - Special Clinic - Reception	29/06/2022
2689	22061067	Reception	CHROME NOT WORKING - COUNTER NO 2	Valamburi. R.	CHROME WORKING		Baskar. G. - Special Clinic - Reception	30/06/2022
Comp. Dt. : 30/06/2022 Status : Completed								
2690	22061090	Reception	NEED TO CHANGE PRINTER RIBBON FOR COUNTER NO 3	Murugavel.R	BARODE CODE RIBBON CHANGED		Baskar. G. - Special Clinic - Reception	30/06/2022
2691	22061101	Reception	PRINTER NOT WORKING COUNTER NO 1 & CHANGE STRICKER FOR COUNTER NO 4	Selvam. D.	COUNTER 1 PRINTER WORKING &NEW STRICKER CHANGED COUNTER 4		Baskar. G. - Special Clinic - Reception	30/06/2022
2692	22061108	Reception	NEED TO CHANGE REVISIT STRICKER FOR COUNTER NO 6	Prakash. P.	REVISIT STRICKER CHANGEDCOUNTER NO.6		Baskar. G. - Special Clinic - Reception	30/06/2022
Comp. Dt. : 01/07/2022 Status : Completed								
2693	22070005	Reception	NEED TO CHANGE STRICKER FOR COUNTER NO 5	Jayaraj. J.	STRICKER CHANGED		Baskar. G. - Special Clinic - Reception	01/07/2022
2694	22070026	SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	NEED TO CHANGE TONER	Shafiullah. R.	12A TONER CHANGED		Thamizhselvi. S. - Administration	01/07/2022
Comp. Dt. : 02/07/2022 Status : Completed								
2695	22070066	Reception	NEED TO CHANGE PRINTER RIBBON FOR COUNTER NO 3	Selvam. D.	barcode ribbon changed		Baskar. G. - Special Clinic - Reception	04/07/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 04/07/2022								
Status : Completed								
2696	22070074	Reception	NEED TO CHANGE STRICKER FOR COUNTER NO 5	Valamburi. R.	COUNTER NO 5 NEW Barcode Sticker Changed		Baskar. G. - Special Clinic - Reception	04/07/2022
Comp. Dt. : 05/07/2022								
Status : Completed								
2697	22070135	Reception	NEED SCANNER INSTALATION WORK - SCANNER FROM SPECILAL OPD	Selvam. D.	scanner installed		Baskar. G. - Special Clinic - Reception	05/07/2022
2698	22070143	Reception	NEED TO CHANGE STRICKER FOR COUNTER NO 5	Valamburi. R.	COUNTER 5 NEW STICKER CHANGED		Baskar. G. - Special Clinic - Reception	05/07/2022
2699	22070173	Reception	SYSTEM NOT WORKING - COUNTER NO 8	Shafiullah. R.	SYSTEM WORKING FINE		Baskar. G. - Special Clinic - Reception	05/07/2022
2700	22070181	Reception	NEED TO CHANGE TONER FOR COUNTER NO 9	Shafiullah. R.	12A TONER CHANGED		Baskar. G. - Special Clinic - Reception	05/07/2022
Comp. Dt. : 06/07/2022								
Status : Completed								
2701	22070198	Reception	BIO METRIC FINGER PRINTER NOT WORKING COUNTER NO 1	Balachandar. A.	FINGER PRINTER MACHINE INSTALLED		Baskar. G. - Special Clinic - Reception	15/07/2022
2702	22070201	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	SYSTEM NOT WORKING	Selvam. D.	Domain reconfigure and the system working fine		Saranya. S. - Clinical Department	07/07/2022
2703	22070208	SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	FINGER PRINT NOT WORKING	Balachandar. A.	RD services updated..		Kalaivani. K. - Special Clinic - Office	08/07/2022
Comp. Dt. : 08/07/2022								
Status : Completed								
2704	22070309	Reception	NEED TO CHANGE STRICKER FOR COUNTER NO 4 & 5	Valamburi. R.	STRICKER CHANGED		Baskar. G. - Special Clinic - Reception	08/07/2022
2705	22070336	Reception	NEED TO CHANGE STRICKER FOR COUNTER NO 2 & 3	Valamburi. R.	STRICKER CHANGED		Baskar. G. - Special Clinic - Reception	08/07/2022
2706	22070337	Reception	PRINTER NOT WORKING COUNTER NO 9	Balachandar. A.	SYSTEM RESTATED		Baskar. G. - Special Clinic - Reception	08/07/2022
2707	22070338	Reception	NEED TO CHANGE RIBBON FOR COUNTER NO 5	Valamburi. R.	RIBBON CHANGED		Baskar. G. - Special Clinic - Reception	08/07/2022
2708	22070342	SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	NEED TO CHANGE TONER	Balachandar. A.	TONER CHANGED		Monica Sales. D. - Special Clinic - Office	08/07/2022
Comp. Dt. : 09/07/2022								
Status : Completed								

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2709	22070376	Reception	NEED TO CHANGE REVISIT STRICKER FOR COUNTER NO 6	Madhubalan. S.	REVISIT STICKER CHANGED		Baskar. G. - Special Clinic - Reception	09/07/2022
2710	22070378	Reception	NEED TO CHANGE STRICKER FOR COUNTER NO 3	Valamburi. R.	Sticker changed		Baskar. G. - Special Clinic - Reception	13/07/2022
Comp. Dt. : 11/07/2022 Status : Completed								
2711	22070427	Reception	NEED TO CHANGE STRICKER FOR COUNTER NO 4	Madhubalan. S.	sticker changed		Baskar. G. - Special Clinic - Reception	13/07/2022
Comp. Dt. : 12/07/2022 Status : Completed								
2712	22070472	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	NEED TO CHANGE BARCODE STRICKER	Shafiullah. R.	NEW STRICKER CHANGED		Saranya. S. - Clinical Department	12/07/2022
Comp. Dt. : 13/07/2022 Status : Completed								
2713	22070504	Reception	SYSTEM NOT WORKING - AUTOMATICALLY SHUT DOWN - COUNTER NO 5	Shafiullah. R.	REPAIR O/S FIXIED		Baskar. G. - Special Clinic - Reception	13/07/2022
2714	22070519	Reception	NEED TO CHANGE PRINTER RIBBON FOR COUNTER NO 4	Shafiullah. R.	PRINTER RIBBON CHANGED		Baskar. G. - Special Clinic - Reception	14/07/2022
Comp. Dt. : 14/07/2022 Status : Completed								
2715	22070525	Reception	NEED TO CHANGE STRICKER FOR COUNTER NO 4	Shafiullah. R.	COUNTER NO 4 & 5 NEW STIRCKER CHANGED		Baskar. G. - Special Clinic - Reception	14/07/2022
2716	22070527	Reception	SYSTEM NOT WORKING COUNTER NO 8 - NEED URGENT SERVICE	Balachandar. A.	SYSTEM WORKING		Baskar. G. - Special Clinic - Reception	14/07/2022
2717	22070534	Reception	SYSTEM PROBLEM [PDF] - COUNTER NO 1	Murugavel.R	PDF INSTALLED		Baskar. G. - Special Clinic - Reception	14/07/2022
2718	22070555	Reception	NEED TO CHANGE TONER FOR COUNTER NO 8	Madhubalan. S.	TONER CHANGED		Baskar. G. - Special Clinic - Reception	14/07/2022
2719	22070560	SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	PRINTER NOT WORKING	Selvam. D.	Printer queue cleard and system restarted		Monica Sales. D. - Special Clinic - Office	15/07/2022
Comp. Dt. : 15/07/2022 Status : Completed								
2720	22070596	Reception	NEED TO CHANGE STRICKER FOR COUNTER NO 4 & 5	Shafiullah. R.	NEW STRICKER COUNTER 3 & 5 CHANGED		Baskar. G. - Special Clinic - Reception	15/07/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2721	22070616	Reception	NEED TO CHANGE BARCODE STRICKER FOR COUNTER NO 9	Jayaraj. J.	BARCODE STRICKER CHANGED		Baskar. G. - Special Clinic - Reception	18/07/2022
Comp. Dt. : 16/07/2022 Status : Completed								
2722	22070623	Reception	NEED TO CHANGE COUNTER NO 5 FOR COUNTER NO 5	Shafiullah. R.	COUNTER NO 5wax RIBBON CHANGED		Baskar. G. - Special Clinic - Reception	16/07/2022
Comp. Dt. : 18/07/2022 Status : Completed								
2723	22070633	Reception	NEED TO CHANGE PRINTER RIBBON FOR COUNTER NO 6	Madhubalan. S.	COUNTER 6 BARCODE RIBBON CHANGED		Baskar. G. - Special Clinic - Reception	18/07/2022
2724	22070659	Reception	NEED BIOMETRIC INSTALLATION FOR COUNTER NO 1	Balachandar. A.	BIOMETRIC INSTALLED		Baskar. G. - Special Clinic - Reception	18/07/2022
2725	22070669	Reception	NEED TO CHANGE STRICKER FOR COUNTER NO 5	Balachandar. A.	STRICKER CHANGED		Baskar. G. - Special Clinic - Reception	18/07/2022
2726	22070671	Reception	BARCODE SCANNER NOT WORKING COUNTER NO 9	Shafiullah. R.	REFIX USB CABLE BARCODE SCANNER		Baskar. G. - Special Clinic - Reception	18/07/2022
Comp. Dt. : 19/07/2022 Status : Completed								
2727	22070688	Reception	NEED TO CHANGE STRICKER FOR COUNTER NO 4 & 3	Selvam. D.	New sticker changed		Baskar. G. - Special Clinic - Reception	19/07/2022
2728	22070692	SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	NEED TO CHECK NET CONNECTION - NET NOT WORKING	Balachandar. A.	8port switch power on		Thamizhselvi. S. - Administration	19/07/2022
Comp. Dt. : 20/07/2022 Status : Completed								
2729	22070748	Reception	NEED TO CHANGE "REVISIT" STRICKER FOR COUNTER NO 6	Selvam. D.	REVISIT" STRICKER CHANGED		Baskar. G. - Special Clinic - Reception	20/07/2022
2730	22070766	Reception	NEED TO CHANGE STRICKER FOR COUNTER NO 3 & 4	Balachandar. A.	COUNTER NO 3 & 4 NEW STRICKER Changed		Baskar. G. - Special Clinic - Reception	21/07/2022
Comp. Dt. : 21/07/2022 Status : Completed								
2731	22070771	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	NEED TO CHANGE BARCODE STRICKER	Prakash. P.	NEW STICKER CHANGED		Saranya. S. - Clinical Department	21/07/2022
2732	22070790	Reception	NEED TO CHECK BARCODE MACHINE - NOT WORKING	Selvam. D.	New sticker refixed		Baskar. G. - Special Clinic - Reception	21/07/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 22/07/2022								
Status : Completed								
2733	22070824	Reception	NEED TO CHANGE STRICKER FOR COUNTER NO 5	Murugavel.R	NEW STICKER CHANGED		Baskar. G. - Special Clinic - Reception	22/07/2022
2734	22070833	Reception	SCANNER NOT WORKING - COUNTER NO 4	Shafiullah. R.	REFIX USB CABLE		Baskar. G. - Special Clinic - Reception	22/07/2022
Comp. Dt. : 25/07/2022								
Status : Completed								
2735	22070882	Reception	NEED TO CHANGE STRICKER FOR COUNTER NO 4 & 5	Selvam. D.	New barcode sticker changed		Baskar. G. - Special Clinic - Reception	25/07/2022
2736	22070883	Reception	NEED TO CHANGE RIBBON FOR COUNTER NO 3 & 4	Balachandar. A.	RIBBON CHANGED		Baskar. G. - Special Clinic - Reception	25/07/2022
2737	22070908	Reception	PRINTER NOT WORKING - COUNTER NO 8	Murugavel.R	PAPER JAM CLEARED PROBLEM SLOVED		Baskar. G. - Special Clinic - Reception	25/07/2022
2738	22070910	SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	NEED TO CHANGE TONER	Murugavel.R	12 A COMPATITABLE TONER CHANGED		Kalaivani. K. - Special Clinic - Office	25/07/2022
Comp. Dt. : 26/07/2022								
Status : Completed								
2739	22070946	Reception	NEED TO CHANGE STRICKER FOR COUNTER NO 4 & 5	Jayaraj. J.	NEW STRICKER CHANGED		Baskar. G. - Special Clinic - Reception	26/07/2022
2740	22070982	Reception	PRINTER NOT WORKING - COUNTER NO 8	Selvam. D.	pick up roller cleaned and refixed		Baskar. G. - Special Clinic - Reception	27/07/2022
Comp. Dt. : 27/07/2022								
Status : Completed								
2741	22071007	Reception	NEED TO CHANGE STRICKER FOR COUNTER NO 5	Balachandar. A.	STRICKER CHANGED		Baskar. G. - Special Clinic - Reception	27/07/2022
2742	22071035	Reception	NEED TO CHANGE STRICKER FOR COUNTER NO 2 & 3	Murugavel.R	STRICKER CHANGED		Baskar. G. - Special Clinic - Reception	27/07/2022
Comp. Dt. : 29/07/2022								
Status : Completed								
2743	22071073	SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	NEED TO CHANGE TONER	Madhubalan. S.	12A TONER CHNAGED		Uma Maheswari. D. - Special OPD	29/07/2022
Comp. Dt. : 01/08/2022								
Status : Completed								
2744	22080041	Reception	NEED TO CHANGE STRICKER FOR COUNTER NO 4	Shafiullah. R.	COUNTER NO 4 NEW STRICKER CHANGED		Baskar. G. - Special Clinic - Reception	01/08/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2745	22080044	Reception	NEED TO CHANGE STRICKER FOR COUNTER NO 2 , 4 & 5	Shafiullah. R.	COUNTER NO 2 , 5 NEW STRICKER CHANGED		Baskar. G. - Special Clinic - Reception	01/08/2022
Comp. Dt. : 02/08/2022								
Status : Completed								
2746	22080056	SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	NEED SOFTWARE INSTALLATION	Balachandar. A.	SOFTWARE INSTALLED		Kaveri. R. - Special Clinic - Office	02/08/2022
2747	22080066	Reception	NEED TO CHANGE STRICKER FOR COUNTER NO 4 & 6	Selvam. D.	STRICKER CHANGED		Baskar. G. - Special Clinic - Reception	02/08/2022
2748	22080086	SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	NEED TO CHECK U P S - BACKUP PROBLEM	Balachandar. A.	12V battery changed		Kalaivani. K. - Special Clinic - Office	30/09/2022
2749	22080091	SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	KEY BOARD NOT WORKING	Selvam. D.	new usb keyboard changed		Kalaivani. K. - Special Clinic - Office	06/08/2022
Comp. Dt. : 04/08/2022								
Status : Completed								
2750	22080164	Reception	CHANGE BARCODE PRINTER RIBBON IN COUNTER 3	Selvam. D.	barcode ribbon changed		Baskar. G. - Special Clinic - Reception	04/08/2022
2751	22080175	SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	CHANGE PRINTER TONER	Balachandar. A.	PRINTER TONER CHANGED		Monica Sales. D. - Special Clinic - Office	04/08/2022
2752	22080178	Reception	NEED TO CHANGE PRINTER RIBBON FOR COUNTER NO 2	Balachandar. A.	PRINTER RIBBON CHANGED		Baskar. G. - Special Clinic - Reception	04/08/2022
Comp. Dt. : 05/08/2022								
Status : Completed								
2753	22080192	SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	PRINTER NOT WORKING	Shafiullah. R.	PRINTER SEETING CHANGE		Monica Sales. D. - Special Clinic - Office	05/08/2022
Comp. Dt. : 06/08/2022								
Status : Completed								
2754	22080225	SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	NEED TO CHECK KEYBOARD - NOT WORKING	Selvam. D.	Multiple complaint locked		Kalaivani. K. - Special Clinic - Office	06/08/2022
2755	22080226	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	NEED TO CHECK PRINTER - PAPER JAM	Madhubalan. S.	TONER REFIXED AND PRINTER CLEAN		Saranya. S. - Clinical Department	06/08/2022
Comp. Dt. : 08/08/2022								
Status : Completed								
2756	22080246	Reception	NEED TO CHANGE STRICKER FOR COUNTER NO 5	Prakash. P.	NEW BARCODE STRICKER CHANGED		Baskar. G. - Special Clinic - Reception	08/08/2022

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2757	22080277	Reception	NEED TO CHANGE BARCODE STRICKER FOR REVISIT COUNTER NO 6	Madhubalan. S.	COUNTER REVISIT STICKER CHANGED		Baskar. G. - Special Clinic - Reception	08/08/2022
Comp. Dt. : 09/08/2022 Status : Completed								
2758	22080292	Reception	NEED TO CHANGE STRICKER FOR COUNTER NO 3	Shafiullah. R.	COUNTER NO 3&9 NEW STRICKER CHANGED		Baskar. G. - Special Clinic - Reception	09/08/2022
2759	22080306	SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	PROBLEM IN U P S	Balachandar. A.	12V battery changed		Thamizhselvi. S. - Administration	30/09/2022
2760	22080317	Reception	NEED TO CHECK NET CONNECTION FOR COUNTER NO 1	Selvam. D.	System restarts and tested working fine		Baskar. G. - Special Clinic - Reception	09/08/2022
2761	22080334	Reception	PRINTER NOT WORKING COUNTER NO 8	Selvam. D.	Printer working fine		Baskar. G. - Special Clinic - Reception	10/08/2022
Comp. Dt. : 10/08/2022 Status : Completed								
2762	22080357	Reception	NEED TO CHANGE BARCODE FOR COUNTER NO 3	Madhubalan. S.	BARCODE CHANGED		Baskar. G. - Special Clinic - Reception	10/08/2022
Comp. Dt. : 11/08/2022 Status : Completed								
2763	22080411	Reception	NEED TO CHANGE STRICKER FOR COUNTER NO 4	Shafiullah. R.	STRICKER CHANGED		Baskar. G. - Special Clinic - Reception	11/08/2022
Comp. Dt. : 12/08/2022 Status : Completed								
2764	22080458	Reception	NEED TO CHANGE STRICKER FOR COUNTER NO 3	Shafiullah. R.	NEW STRICKER CHANGED		Baskar. G. - Special Clinic - Reception	12/08/2022
Comp. Dt. : 13/08/2022 Status : Completed								
2765	22080474	Reception	NEED TO CHANGE BARCODE STRICKER FOR COUNTER NO 9	Balachandar. A.	BARCODE STRICKER CHANGED...		Baskar. G. - Special Clinic - Reception	13/08/2022
Comp. Dt. : 17/08/2022 Status : Completed								
2766	22080488	Reception	NEED TO CHANGE RIBBON IN COUNTER NO 4	Selvam. D.	RIBBON CHANGED		Savitha. K. - Special Clinic - Reception	17/08/2022
Comp. Dt. : 18/08/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2767	22080570	Reception	IN COUNTER 5 CHANGR PRINTER RIBBON	Valamburi. R.	barcode ribbon changed		Savitha. K. - Special Clinic - Reception	18/08/2022
		Comp. Dt. : 19/08/2022 Status : Completed						
2768	22080645	Reception	CHANGE PRINTER TONER IN COUNTER 1	Jayaraj. J.	12A toner changed		Baskar. G. - Special Clinic - Reception	20/08/2022
		Comp. Dt. : 20/08/2022 Status : Completed						
2769	22080664	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	PRINTER - PAPER JAM	Balachandar. A.	PAPER JAM CLEARED		Saranya. S. - Clinical Department	20/08/2022
2770	22080683	Reception	NEED TO CHANGE STRICKER FOR COUNTER NO 5	Balachandar. A.	STRICKER CHANGED		Baskar. G. - Special Clinic - Reception	20/08/2022
		Comp. Dt. : 22/08/2022 Status : Completed						
2771	22080699	Reception	NEED TO CHANGE PRINTER RIBBON FOR COUNTER NO 6	Jayaraj. J.	barcode ribbon changed		Baskar. G. - Special Clinic - Reception	22/08/2022
2772	22080725	Reception	NEED TO CHANGE STRICKER FOR COUNTER NO 4	Valamburi. R.	New barcode sticker changed		Baskar. G. - Special Clinic - Reception	22/08/2022
		Comp. Dt. : 23/08/2022 Status : Completed						
2773	22080756	Reception	NEED TO CHANGE BARCODE STRICKER FOR COUNTER NO 9	Balachandar. A.	New barcode sticker changed		Baskar. G. - Special Clinic - Reception	23/08/2022
2774	22080758	Reception	NEED TO CHANGE STRICKER FOR COUNTER NO 4 & 5	Selvam. D.	New barcode sticker changed		Baskar. G. - Special Clinic - Reception	23/08/2022
		Comp. Dt. : 24/08/2022 Status : Completed						
2775	22080809	Reception	NEED TO CHANGE TONER FOR COUNTER NO 8	Jayaraj. J.	TONER CHANGED		Baskar. G. - Special Clinic - Reception	25/08/2022
2776	22080812	Reception	NEED TO CHANGE STRICKER FOR COUNTER NO 3	Shafiullah. R.	NEW STRICKER CHANGED		Baskar. G. - Special Clinic - Reception	24/08/2022
		Comp. Dt. : 25/08/2022 Status : Completed						
2777	22080820	Reception	SYSTEM NOT WORKING - COUNTER NO 2	Selvam. D.	SMPS REFIXED		Baskar. G. - Special Clinic - Reception	25/08/2022
2778	22080821	Reception	NEED TO CHANGE STRICKER FOR COUNTER NO 3	Selvam. D.	STRICKER CHANGED		Baskar. G. - Special Clinic - Reception	25/08/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 26/08/2022								
Status : Completed								
2779	22080868	Reception	NEED TO CHECK KEYBOARD - NOT WORKING - COUNTER NO 2	Shafiullah. R.	counter 2 keyboard refix		Baskar. G. - Special Clinic - Reception	26/08/2022
2780	22080880	Reception	NEED TO CHANGE BARCODE STRICKER FOR COUNTER NO 9	Shafiullah. R.	COUNTER NO 9 NEW STRICKER CHANGED		Baskar. G. - Special Clinic - Reception	26/08/2022
2781	22080898	SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	SCANNER NOT WORKING	Prakash. P.	ReInstalled Scan .Working		Monica Sales. D. - Special Clinic - Office	27/08/2022
2782	22080912	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	NEED TO CHANGE TONER	Selvam. D.	12A TONER CHANGED		Saranya. S. - Clinical Department	26/08/2022
2783	22080922	Reception	NEED TO CHANGE PRINTER RIBBON FOR COUNTER NO 3	Madhubalan. S.	COUNTER 3 BBON CHANGED		Baskar. G. - Special Clinic - Reception	26/08/2022
Comp. Dt. : 27/08/2022								
Status : Completed								
2784	22080948	Reception	NEED TO CHANGE STRICKER FOR COUNTER NO 2	Shafiullah. R.	STRICKER CHANGED		Baskar. G. - Special Clinic - Reception	27/08/2022
Comp. Dt. : 29/08/2022								
Status : Completed								
2785	22080955	Reception	NEED TO CHANGE STRICKER AND RIBBON FOR COUNTER NO 4 & 5	Balachandar. A.	COUNTER 4,5 RIBBON AND NEW STICKER CHANGED		Baskar. G. - Special Clinic - Reception	29/08/2022
2786	22080964	SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	NEED TO CHANGE TONER	Madhubalan. S.	12A TONER CHANGED		Kalaivani. K. - Special Clinic - Office	29/08/2022
2787	22080987	Reception	NEED TO CHANGE TONER FOR COUNTER NO 8	Madhubalan. S.	12 TONER CHANGED		Baskar. G. - Special Clinic - Reception	29/08/2022
Comp. Dt. : 30/08/2022								
Status : Completed								
2788	22081012	Reception	NEED TO CHANGE STRICKER FOR COUNTER NO 2	Selvam. D.	STRICKER CHANGED		Baskar. G. - Special Clinic - Reception	30/08/2022
Comp. Dt. : 02/09/2022								
Status : Completed								
2789	22090101	SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	BIOMETRIC NOT WORKING	Jayaraj. J.	setting changed and tested working fine		Kalaivani. K. - Special Clinic - Office	02/09/2022
Comp. Dt. : 03/09/2022								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
2790	22090126	Reception	NEED TO CHECK SCANNER - NOT WORKING COUNTER NO 1	Selvam. D.	scanner setting changed		Baskar. G. - Special Clinic - Reception	03/09/2022
2791	22090144	Reception	NEED TO CHANGE NEW REGISTRATION STRICKER FOR COUNTER NO 4	Jayaraj. J.	New barcode sticker changed		Baskar. G. - Special Clinic - Reception	03/09/2022
Comp. Dt. : 05/09/2022								
Status : Completed								
2792	22090149	Reception	NEED TO CHANGE STRICKER FOR COUNTER NO 2 & 3	Jayaraj. J.	NEW BARCODE STRICKER CHANGED		Baskar. G. - Special Clinic - Reception	05/09/2022
2793	22090174	Reception	NEED TO CHANGE REVISIT STRICKER FOR COUNTER NO 6	Madhubalan. S.	Power cable refixed		Baskar. G. - Special Clinic - Reception	05/09/2022
2794	22090185	Reception	NEED TO CHECK POWER PARCORD PRIENTER	Jayaraj. J.	Power cable refixed		Baskar. G. - Special Clinic - Reception	05/09/2022
Comp. Dt. : 06/09/2022								
Status : Completed								
2795	22090202	Reception	NEED TO CHECK PRINTER NOT WORKING - COUNTER NO 1	Selvam. D.	Reinstalled the printer driver		Baskar. G. - Special Clinic - Reception	06/09/2022
2796	22090210	Reception	COUTER (1) SCAN NOT WORKING	Selvam. D.	scanner setting changed		Baskar. G. - Special Clinic - Reception	06/09/2022
2797	22090224	Reception	NEED TO CHANGE STRICKER FOR COUNTER NO 3 & 5	Selvam. D.	New barcode sticker changed in counter 3 and 5		Baskar. G. - Special Clinic - Reception	06/09/2022
2798	22090250	Reception	BAR CODE MACHINE NOT WORKING - COUNTER NO 2	Selvam. D.	Barcode ribbon refixed		Baskar. G. - Special Clinic - Reception	07/09/2022
Comp. Dt. : 08/09/2022								
Status : Completed								
2799	22090319	SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	NEED TO REFIL COLOUR PRINTER INK	Selvam. D.	PRINTER INK REFILLED		Kaveri. R. - Special Clinic - Office	08/09/2022
2800	22090322	SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	NEED TO CHANGE TONER	Selvam. D.	TONER CHANGED		Thamizhselvi. S. - Administration	08/09/2022
Comp. Dt. : 09/09/2022								
Status : Completed								
2801	22090346	Reception	NEED TO CHANGE STRICKER FOR COUNTER NO 4	Shafiullah. R.	STRICKER CHANGED		Baskar. G. - Special Clinic - Reception	09/09/2022
2802	22090367	Reception	SCANNER NOT WORKING - COUNTER NO 2	Jayaraj. J.	USB CABLE REFIXED		Baskar. G. - Special Clinic - Reception	09/09/2022
Comp. Dt. : 10/09/2022								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
2803	22090385	Reception	SYSTEM PROBLEM - COUNTER NO 2	Jayaraj. J.	POWER CABLE LOOSE REFIX		Baskar. G. - Special Clinic - Reception	10/09/2022
2804	22090407	Reception	BARCODE MACHINE NOT WORKING COUNTER NO 3	Shafiullah. R.	REFIX PRINTER WAX RIBBON		Baskar. G. - Special Clinic - Reception	10/09/2022
Comp. Dt. : 12/09/2022								
Status : Completed								
2805	22090432	Reception	NEED TO CHANGE RIBBON FOR COUNTER NO 5	Selvam. D.	Barcode ribbon changed		Baskar. G. - Special Clinic - Reception	12/09/2022
2806	22090444	Reception	NEED TO CHANGE STRICKER & REVISIT STRICKER FOR COUNTER NO 5 & 6	Selvam. D.	New barcode sticker and revisit sticker changed		Baskar. G. - Special Clinic - Reception	12/09/2022
Comp. Dt. : 13/09/2022								
Status : Completed								
2807	22090494	SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	NEED TO CHANGE TONER	Madhubalan. S.	12a toner changed		Monica Sales. D. - Special Clinic - Office	13/09/2022
2808	22090499	DIALYSIS NEW UNIT IN 1ST FLOOR	PRINTER NOT WORKING	Selvam. D.	General service done		Nandhini.M. - Special Clinic - Reception	14/09/2022
2809	22090505	Special Ward - C	NEED TO CHANGE TONER	Jayaraj. J.	12A toner changed		Geetha. J. - Special Clinic - Reception	14/09/2022
Comp. Dt. : 14/09/2022								
Status : Completed								
2810	22090528	Reception	NEED TO CHANGE STRICKER FOR COUNTER NO 4 & 5	Madhubalan. S.	counter 4 and 5 new sticker changed		Baskar. G. - Special Clinic - Reception	14/09/2022
2811	22090548	Reception	NEED TO INSTALL DONGLE	Selvam. D.	installed working fine		Baskar. G. - Special Clinic - Reception	17/09/2022
2812	22090549	Reception	NEED TO CHANGE STRICKER FOR COUNTER NO 4	Selvam. D.	New barcode sticker changed		Baskar. G. - Special Clinic - Reception	14/09/2022
Comp. Dt. : 15/09/2022								
Status : Completed								
2813	22090571	Reception	NEED TO COUTER -2 KEY BOARD NOT WORKING AND COUTER -4 PARCODE STICKER	Balachandar. A.	NEW USB KEYBAORD AND BARCODE STICKER CAHNGED		Savitha. K. - Special Clinic - Reception	15/09/2022
Comp. Dt. : 17/09/2022								
Status : Completed								
2814	22090660	Reception	NEED TO CHANGE STRICKER FOR COUNTER NO 3 & 5	Madhubalan. S.	COUNTER 3 AND 5 NEW STICKER CHANGED		Baskar. G. - Special Clinic - Reception	17/09/2022
2815	22090676	SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	NEED TO CHECK SYSTEM - SHUTDOWN AUTOMATICALLY	Shafiullah. R.	MONITOR NEVER SLEEP SETTING CHANGED		Kalaivani. K. - Special Clinic - Office	17/09/2022

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHAL KUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 19/09/2022								
Status : Completed								
2816	22090728	Reception	NEED TO CHANGE TONER FOR COUNTER NO 8	Shafiullah. R.	12A TONER CHANGED		Baskar. G. - Special Clinic - Reception	19/09/2022
Comp. Dt. : 20/09/2022								
Status : Completed								
2817	22090759	Reception	NEED TO CHANGE STRICKER FOR COUNTER NO 4	Balachandar. A.	STRICKER CHANGED		Baskar. G. - Special Clinic - Reception	20/09/2022
2818	22090774	SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	SYSTEM AGAIN PROBLEM	Prakash. P.	working fine		Kalaivani. K. - Special Clinic - Office	23/09/2022
Comp. Dt. : 21/09/2022								
Status : Completed								
2819	22090804	Reception	NEED TO CHANGE STRICKER & RIBBON FOR COUNTER NO 3 & 5	Shafiullah. R.	STRICKER CHANGED		Baskar. G. - Special Clinic - Reception	21/09/2022
2820	22090836	Reception	NEED TO CHANGE STRICKER FOR COUNTER NO 4	Balachandar. A.	STRICKER CHANGED		Baskar. G. - Special Clinic - Reception	21/09/2022
2821	22090846	Reception	NEED TO CHANGE RIBBON FOR COUNTER NO 8	Balachandar. A.	RIBBON GIVEN		Baskar. G. - Special Clinic - Reception	21/09/2022
2822	22090850	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	NEED TO CHANGE TONER	Shafiullah. R.	TONER CHANGED		Saranya. S. - Clinical Department	21/09/2022
Comp. Dt. : 22/09/2022								
Status : Completed								
2823	22090867	Special Ward - C	PRINTER NOT WORKING - NEED URGENT SERVICE	Balachandar. A.	print queue cleared		Vijayalakshmi. B. - Special Clinic	23/09/2022
2824	22090882	Reception	NEED TO CHANGE STRICKER FOR COUNTER NO 4	Valamburi. R.	New barcode sticker changed		Baskar. G. - Special Clinic - Reception	23/09/2022
Comp. Dt. : 23/09/2022								
Status : Completed								
2825	22090922	Reception	NEED TO CHANGE PRINTER RIBBON	Selvam. D.	PRINTER RIBBON CHANGED		Baskar. G. - Special Clinic - Reception	23/09/2022
2826	22090946	Reception	NEED TO CHANGE STRICKER FOR COUNTER NO 3	Madhubalan. S.	COUNTER 3 NEW STICKER CHANGED		Baskar. G. - Special Clinic - Reception	23/09/2022
2827	22090955	Reception	SYSTEM NOT WORKING COUNTER NO 8	Madhubalan. S.	PRINTER WORKING FINE		Baskar. G. - Special Clinic - Reception	23/09/2022
Comp. Dt. : 26/09/2022								
Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2828	22090995	Reception	NEED TO CHANGE STRICKER FOR COUNTER NO 2 , 3 & 6	Balachandar. A.	COUNTER 2,3 NEW STICKER AND COUNTER 6 REVISITE STICKER CHANGED		Baskar. G. - Special Clinic - Reception	26/09/2022
2829	22091007	Reception	NEED TO CHANGE RIBBON FOR COUNTER NO 6	Madhubalan. S.	COUNTER 6 BARCODE RIBBON CHANGED		Baskar. G. - Special Clinic - Reception	26/09/2022
Comp. Dt. : 27/09/2022								
Status : Completed								
2830	22091047	DIALYSIS NEW UNIT IN 1ST FLOOR	NEED TO CHANGE TONER	Madhubalan. S.	88A TONER CHANGED		Nandhini.M. - Special Clinic - Reception	27/09/2022
2831	22091069	SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	NEED TO CHANGE TONER	Jayaraj. J.	TONER CHANGED		Thamizhselvi. S. - Administration	27/09/2022
2832	22091081	SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	NEED TO CHECK TONER - PROBLEM	Valamburi. R.	toner changed		Thamizhselvi. S. - Administration	30/09/2022
Comp. Dt. : 28/09/2022								
Status : Completed								
2833	22091128	Reception	NEED TO CHANGE BARCODE STRICKER [2NOS] FOR COUNTER NO 4	Jayaraj. J.	BARCODE STRICKER CHANGED		Baskar. G. - Special Clinic - Reception	28/09/2022
2834	22091132	SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	NEED TO CHANGE TONER	Balachandar. A.	Scanner unit cleaned and refixed		Kalaivani. K. - Special Clinic - Office	28/09/2022
Comp. Dt. : 29/09/2022								
Status : Completed								
2835	22091150	Reception	NEED TO CHECK SCANNER - NOT WORKING IN COUNTER NO 1	Valamburi. R.	working fine		Baskar. G. - Special Clinic - Reception	30/09/2022
Comp. Dt. : 01/10/2022								
Status : Completed								
2836	22100006	Reception	NEED TO CHANGE REVISIT STRICKER FOR COUNTER NO 6	Valamburi. R.	REVISIT STRICKER CHANGED		Baskar. G. - Special Clinic - Reception	05/10/2022
Comp. Dt. : 03/10/2022								
Status : Completed								
2837	22100013	Reception	NEED TO CHANGE STRICKER FOR COUNTER NO 3	Shafiullah. R.	NEW STICKER COUNTER 3,4&5 CHANGED		Baskar. G. - Special Clinic - Reception	03/10/2022
Comp. Dt. : 05/10/2022								
Status : Completed								
2838	22100020	Reception	SYSTEM NOT WORKING COUNTER NO 3	Selvam. D.	New usb mouse changed		Baskar. G. - Special Clinic - Reception	05/10/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 06/10/2022								
Status : Completed								
2839	22100086	Reception	NEED TO CHECK PRINTER - PAPER JAM	Selvam. D.	Reinstall the printer driver		Baskar. G. - Special Clinic - Reception	06/10/2022
2840	22100098	SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	NEED SOFTWARE INSTALLATION FOR FINGER PRINT	Balachandar. A.	NEED SOFTWARE INSTALLAED		Kalaivani. K. - Special Clinic - Office	12/10/2022
2841	22100104	Reception	NEED TO REFIX PRINTER RIBBON FOR COUNTER NO 5 & SCANNER NOT WORKING IN COUNTER NO 2	Selvam. D.	Ribbon refixed and scanner usb cable refixed		Baskar. G. - Special Clinic - Reception	06/10/2022
2842	22100117	Reception	NEED TO CHANGE TONER FOR COUNTER NO 8	Madhubalan. S.	TONER CHANGED		Baskar. G. - Special Clinic - Reception	06/10/2022
Comp. Dt. : 07/10/2022								
Status : Completed								
2843	22100125	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	PRINTER NOT WORKING	Selvam. D.	Paper jam cleared		Saranya. S. - Clinical Department	07/10/2022
2844	22100139	Special Ward - A	NEED TO CHANGE TONER	Balachandar. A.	TONER CHANGED		Muthamizraja. M. - Special Clinic - Reception	07/10/2022
2845	22100148	Reception	NEED TO CHANGE TONER FOR COUNTER NO 9	Selvam. D.	12A toner changed		Baskar. G. - Special Clinic - Reception	07/10/2022
Comp. Dt. : 10/10/2022								
Status : Completed								
2846	22100202	Reception	NEED TO CHANGE BARCODE FOR COUNTER NO 4 & 5 & PRINTER PROBLEM & NOT WORKING IN COUNTER NO 2	Balachandar. A.	COUNTER 4 & 5 BARCODE STICKER CHANGED. COUNTER 2 PRINTER WORKING FINE		Baskar. G. - Special Clinic - Reception	10/10/2022
2847	22100213	Reception	NEED TO CHANGE PRINTER RIBBON FOR COUNTER NO 4	Balachandar. A.	COUNTER 4 RIBBON CHANGED		Baskar. G. - Special Clinic - Reception	10/10/2022
2848	22100237	Reception	NEED TO CHECK SCANNER - NOT WORKING - COUNTER NO 2	Madhubalan. S.	COUNTER 2 SCANNER WORKING FINE		Baskar. G. - Special Clinic - Reception	10/10/2022
2849	22100257	Reception	PRINTER NOT WORKING - COUNTER NO 1	Balachandar. A.	Ps2 keyboard changed		Baskar. G. - Special Clinic - Reception	10/10/2022
Comp. Dt. : 13/10/2022								
Status : Completed								
2850	22100381	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	SCANNER NOT WORKING	Selvam. D.	Power cable refixed		Kabilan. R. - Special Clinic - Office	13/10/2022
2851	22100423	SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	PRINTER NOT WORKING	Selvam. D.	Printer driver reinstalled		Kaveri. R. - Special Clinic - Office	13/10/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 14/10/2022								
Status : Completed								
2852	22100451	Reception	NEED TO CHANGE BARCODE STRICKER FOR COUNTER NO 4 & 5	Madhubalan. S.	NEW STICKER CHANGED 4&5		Baskar. G. - Special Clinic - Reception	14/10/2022
2853	22100468	Reception	NEED TO CHANGE REVISIT STRICKER FOR COUNTER NO 6	Madhubalan. S.	COUNTER 6 REVISIT STRICKER CHANGED		Baskar. G. - Special Clinic - Reception	14/10/2022
2854	22100472	Reception	NEED TO CHANGE BARCODE STRICKER FOR COUNTER NO 11	Shafiullah. R.	COUNTER 9 NEW BARCODE STRICKER CHANGED		Baskar. G. - Special Clinic - Reception	14/10/2022
Comp. Dt. : 15/10/2022								
Status : Completed								
2855	22100491	Reception	NEED TO CHANGE BARCODE STICKER IN COUNTER NO:6	Shafiullah. R.	WAX RIBOON REFIX AND HEAD CELAN		Thiyagarajan. K. - Special Clinic - Fever Clinic	17/10/2022
Comp. Dt. : 17/10/2022								
Status : Completed								
2856	22100507	Reception	NEED TO REFIX PRINTER RIBBON - PROBLEM - COUNTER NO 4	Shafiullah. R.	RIBBON REFIX PRINTER		Baskar. G. - Special Clinic - Reception	17/10/2022
2857	22100508	Reception	NEED TO INSTALL PHOTOSHOP FOR COUNTER NO 2	Selvam. D.	Photoshop installed		Baskar. G. - Special Clinic - Reception	17/10/2022
2858	22100522	Reception	NEED TO REPLACE SCANNER FROM COUNTER NO 4 TO COUNTER NO 2	Shafiullah. R.	REMOVED COUNTER 4 TO FIX TO COUNTER 3		Baskar. G. - Special Clinic - Reception	17/10/2022
2859	22100525	Reception	MEDPLUS NOT WORKING - COUNTER NO 5	Shafiullah. R.	REFIX PATCH CARD		Baskar. G. - Special Clinic - Reception	17/10/2022
2860	22100542	Reception	SYSTEM NETWORK PROBLEM IN COUNTER NO. 5	Shafiullah. R.	REFIX PATCH CARD		Vijayalakshmi. B. - Special Clinic	17/10/2022
Comp. Dt. : 18/10/2022								
Status : Completed								
2861	22100559	Reception	SYSTEM NOT WORKING COUNTER NO 5	Shafiullah. R.	DOMIN REFIX		Baskar. G. - Special Clinic - Reception	18/10/2022
Comp. Dt. : 19/10/2022								
Status : Completed								
2862	22100619	Reception	NEED TO CHANGE BARCODE STICKER IN COUNTER NO:6	Shafiullah. R.	REVISIT BARCODE STRICKER CHANGED		Vijayalakshmi. B. - Special Clinic	19/10/2022
2863	22100623	Reception	NEED TO CHANGE BARCODE STRICKER IN COUNTER NO. 5	Selvam. D.	NEW BARCODE STRICKER CHANGED		Baskar. G. - Special Clinic - Reception	19/10/2022

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 20/10/2022								
Status : Completed								
2864	22100688	Reception	PRINTER PROBLEM IN COUNTER NO:4	Shafiullah. R.	REFIX BAR CODE RIBBON		Thiyagarajan. K. - Special Clinic - Fever Clinic	20/10/2022
Comp. Dt. : 21/10/2022								
Status : Completed								
2865	22100721	DIALYSIS NEW UNIT IN 1ST FLOOR	SYSTEM NEED TO BE REARRANGE	Prakash. P.	system connected..		Swathika. K. - Special Clinic - Dialysis	21/10/2022
2866	22100731	Reception	IN COUNTER 3 CHANGE BARCODE STICKER	Jayaraj. J.	BARCODE STICKER CHANGED		Baskar. G. - Special Clinic - Reception	21/10/2022
Comp. Dt. : 22/10/2022								
Status : Completed								
2867	22100744	DIALYSIS NEW UNIT IN 1ST FLOOR	PRINTER NOT WORKING	Selvam. D.	Printer driver reinstalled		Swathika. K. - Special Clinic - Dialysis	22/10/2022
Comp. Dt. : 25/10/2022								
Status : Completed								
2868	22100768	Reception	NEED TO CHANGE PRINTER RIBBON IN COUNTER NO:4	Selvam. D.	Barcode ribbon changed		Geetha. J. - Special Clinic - Reception	25/10/2022
Comp. Dt. : 26/10/2022								
Status : Completed								
2869	22100789	Reception	NEED TO CHANGE BARCODE STICKER IN COUNTER NO. 6	Madhubalan. S.	COUNTER 6 BARCODE AND REVISIT STICKER CHANGED		Ramya. R. - Special Clinic - Reception	26/10/2022
2870	22100790	Reception	NEED TO CHANGE PRINTER RIBBON	Madhubalan. S.	BARCODE RIBBON CHANGED		Ramya. R. - Special Clinic - Reception	26/10/2022
2871	22100795	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	NEED TO CHANGE BARCODE STICKER	Prakash. P.	NEW STICKER CHANGED		Saranya. S. - Clinical Department	26/10/2022
2872	22100836	SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	CHANGE PRINTER TONER	Shafiullah. R.	12A TONER CHANGED		Kalaivani. K. - Special Clinic - Office	26/10/2022
Comp. Dt. : 28/10/2022								
Status : Completed								
2873	22100891	Reception	NEED TO CHANGE BARCODE STICKER IN COUNTER 5	Selvam. D.	New barcode sticker changed		Geetha. J. - Special Clinic - Reception	28/10/2022
2874	22100892	Reception	NEED TO CHANGE PRINTER RIBBON IN COUNTER 5	Selvam. D.	COUNTER 5 BARCODE RIBBON CHANGED		Geetha. J. - Special Clinic - Reception	28/10/2022
2875	22100921	Reception	IN COUNTER 4 BARCODE PRINTER PROBLEM	Selvam. D.	Barcode ribbon refixed		Geetha. J. - Special Clinic - Reception	28/10/2022
Comp. Dt. : 29/10/2022								

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
2876	22100948	Reception	NEED TO CHANGE BARCODE STICKER IN COUNTER 5	Jayaraj. J.	NEW STRICKER CHANGED		Geetha. J. - Special Clinic - Reception	29/10/2022
Comp. Dt. : 31/10/2022								
Status : Completed								
2877	22100982	Reception	NEED TO CHANGE PRINTER RIBBON IN COUNTER NO.4	Selvam. D.	STRICKER RIBBON CHANGED		Geetha. J. - Special Clinic - Reception	31/10/2022
2878	22100996	Reception	BARCODE STICKER MACHINE NOT WORKING	Jayaraj. J.	BARCODE MACHINE WORKING		Geetha. J. - Special Clinic - Reception	02/11/2022
Comp. Dt. : 02/11/2022								
Status : Completed								
2879	22110033	Reception	IN COUNTER 5 AND 6 CHANGE BARCODE STICKER(NEED 3 NO'S)	Selvam. D.	New barcode sticker changed		Vijayalakshmi. B. - Special Clinic	03/11/2022
2880	22110042	Reception	IN COUNTER 2 -CHANGE PRINTER TONER	Valamburi. R.	12A toner changed		Geetha. J. - Special Clinic - Reception	03/11/2022
Comp. Dt. : 05/11/2022								
Status : Completed								
2881	22110170	Reception	NEED TO CHANGE BARCODE STICKER AND RIBBON IN COUNTER NO. 4	Balachandar. A.	BARCODE STICKER CHANGED & RIBBON CHANGED		Geetha. J. - Special Clinic - Reception	05/11/2022
2882	22110171	Reception	NEED TO CHANGE BARCODE STICKER IN COUNTER NO.5	Balachandar. A.	BARCODE STICKER CHANGED		Geetha. J. - Special Clinic - Reception	05/11/2022
2883	22110187	Reception	IN COUNTER 5-KEYBOARD ENTER KEY NOT WORKING	Prakash. P.	new key board Changed		Thiyagarajan. K. - Special Clinic - Fever Clinic	05/11/2022
Comp. Dt. : 07/11/2022								
Status : Completed								
2884	22110197	Reception	NEED TO CHANGE BARCODE STICKER IN COUNTER NO.6	Balachandar. A.	BARCODE STICKER CHANGED		Vijayalakshmi. B. - Special Clinic	07/11/2022
2885	22110236	Reception	IN COUNTER 5-PRINTER RIBBON PROBLEM	Selvam. D.	Ribbon refixed		Thiyagarajan. K. - Special Clinic - Fever Clinic	07/11/2022
2886	22110239	Reception	IN COUNTER 4 AND 5-CHANGE BARCODE STICKER	Jayaraj. J.	BARCODE STICKER CHANGED		Thiyagarajan. K. - Special Clinic - Fever Clinic	07/11/2022
Comp. Dt. : 08/11/2022								
Status : Completed								
2887	22110260	Reception	KEYBOARD NOT WORKING IN COUNTER NO.6	Valamburi. R.	OLD KEYBOARD CHANGED		Vijayalakshmi. B. - Special Clinic	08/11/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2888	22110272	SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	NEED TO CHANGE PRINTER TONER	Madhubalan. S.	12A TONER CHANGED		Monica Sales. D. - Special Clinic - Office	08/11/2022
		Comp. Dt. : 11/11/2022						
		Status : Completed						
2889	22110442	Reception	IN COUNTER 5-CHANGE BARCODE STICKER	Madhubalan. S.	COUNTER 5 NEW STICKER CHANGED		Muthamizraja. M. - Special Clinic - Reception	11/11/2022
		Comp. Dt. : 14/11/2022						
		Status : Completed						
2890	22110502	Reception	IN COUNTER 6-CHANGE BARCODE STICKER	Balachandar. A.	STICKER CHANGED		Vijayalakshmi. B. - Special Clinic	14/11/2022
2891	22110524	Reception	IN COUNTER 5-BARCODE PRINTER PROBLEM	Shafiullah. R.	SETTING CHANGED		Geetha. J. - Special Clinic - Reception	14/11/2022
2892	22110544	DIALYSIS NEW UNIT IN 1ST FLOOR	PRINTER NOT WORKING	Valamburi. R.	setting changed		Nandhini.M. - Special Clinic - Reception	15/11/2022
2893	22110552	Reception	IN COUNTER 5-BARCODE PRINTER PROBLEM	Selvam. D.	Barcode printer refixed		Thiyagarajan. K. - Special Clinic - Fever Clinic	15/11/2022
2894	22110554	Reception	IN COUNTER 4-BARCODE PRINTER RIBBON PROBLEM	Madhubalan. S.	BARCODE RIBBON ROOL REFIXED WORKING FINE		Vijayalakshmi. B. - Special Clinic	14/11/2022
		Comp. Dt. : 15/11/2022						
		Status : Completed						
2895	22110577	Reception	IN COUNTER 1 -SCANNER NOT WORKING	Selvam. D.	Driver reinstalled		Geetha. J. - Special Clinic - Reception	16/11/2022
2896	22110603	Reception	CHANGE BARCODE STICKER IN REVISIT COUNTER 6	Shafiullah. R.	REVISIT STICKER CHANGED		Vijayalakshmi. B. - Special Clinic	15/11/2022
		Comp. Dt. : 16/11/2022						
		Status : Completed						
2897	22110670	Reception	IN COUNTER 4-CHANGE BARCODE STICKER (NEED 2 NO'S)	Murugavel.R	2 BARCODE STICKER CHANGED		Vijayalakshmi. B. - Special Clinic	16/11/2022
		Comp. Dt. : 20/12/2022						
		Status : Completed						
2898	22120879	Reception	NEED TO CHANGE REVISIT STICKER IN COUNTER NO 6	Balachandar. A.	REVISIT STICKER CHANGED		Vijayalakshmi. B. - Special Clinic	20/12/2022
		Comp. Dt. : 23/12/2022						
		Status : Completed						
2899	22121049	Reception	NEED TO CHANGE REVISITE STICKER IN COUNTER NO 6	Jayaraj. J.	REVISITE STICKER CHANGED		Vijayalakshmi. B. - Special Clinic	23/12/2022

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHAL KUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 04/01/2023 Status : Completed								
2900	23010128	Reception	NEED TO CHANGE BARCODE STICKER IN COUNTER NO 4 & 5	Madhubalan. S.	new sticker changed		Vijayalakshmi. B. - Special Clinic	04/01/2023
Comp. Dt. : 05/01/2023 Status : Completed								
2901	23010216	Reception	IN COUNTER 6-BARCODE SCANNER NOT WORKING	Madhubalan. S.	scanner refixed..		Vijayalakshmi. B. - Special Clinic	13/01/2023
Comp. Dt. : 11/01/2023 Status : Completed								
2902	23010453	Dean (Academic) Office	SYSTEM NETWORK ISSUE	Selvam. D.	USB lan connector changed		Vijayalakshmi. B. - Special Clinic	11/01/2023
Comp. Dt. : 08/02/2023 Status : Completed								
2903	23020261	Reception	NEED TO CHANGE REVISITE STICKER IN COUNTER NO 6	Prakash. P.	REVISITE STICKER CHANGED		Vijayalakshmi. B. - Special Clinic	08/02/2023
Comp. Dt. : 25/04/2023 Status : Completed								
2904	23040779	Reception	MEDPLUS NOT WORKING IN COUNTER NO 6	Selvam. D.	INFORM TO PERSON SEND MAIL		Vijayalakshmi. B. - Special Clinic	25/04/2023
Comp. Dt. : 16/06/2023 Status : Completed								
2905	23060583	Reception	NEED TO CHANGE BARCODE STICKER IN COUNTER 4, 5 & 6	Shafiullah. R.	4&5 NEW STRICKER CHANGED		Vijayalakshmi. B. - Special Clinic	16/06/2023
2906	23060584	Reception	NEED TO CHANGE PRINTER RIBBON IN COUNTER NO 5	Shafiullah. R.	PRINTER WAX RIBBON CHANGED		Vijayalakshmi. B. - Special Clinic	16/06/2023
Dept Name : Special Clinic - Dialysis - Computer Department Comp. Dt. : 23/11/2022 Status : Completed								
2907	22110974	DIALYSIS NEW UNIT IN 1ST FLOOR	PRINTER NOT WORKING	Madhubalan. S.	SYSTEM RESTATED PRINTER WORKING FINE		Swathika. K. - Special Clinic - Dialysis	23/11/2022
Comp. Dt. : 16/12/2022 Status : Completed								
2908	22120741	DIALYSIS NEW UNIT IN 1ST FLOOR	SCANNER NOT WORKING	Shafiullah. R.	SCANNER SETTING CHANGE		Swathika. K. - Special Clinic - Dialysis	16/12/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 13/01/2023 Status : Completed								
2909	23010539	DIALYSIS NEW UNIT IN 1ST FLOOR	PRINTER NOT WORKING	Selvam. D.	PRINTER WORKING SCANNER CLEAN REFIX		Swathika. K. - Special Clinic - Dialysis	13/01/2023
Comp. Dt. : 04/02/2023 Status : Completed								
2910	23020141	DIALYSIS NEW UNIT IN 1ST FLOOR	PRINTER NOT WORKING	Selvam. D.	printer working fine		Swathika. K. - Special Clinic - Dialysis	06/02/2023
Comp. Dt. : 20/03/2023 Status : Completed								
2911	23030760	DIALYSIS NEW UNIT IN 1ST FLOOR	SYSTEM NOT WORKING	Selvam. D.	Motherboard replaced acer and system fixed..		Swathika. K. - Special Clinic - Dialysis	03/04/2023
Comp. Dt. : 23/03/2023 Status : Completed								
2912	23030982	DIALYSIS NEW UNIT IN 1ST FLOOR	SYSTEM NOT WORKING	Madhubalan. S.	power cable refixed		Swathika. K. - Special Clinic - Dialysis	24/03/2023
Comp. Dt. : 15/05/2023 Status : Completed								
2913	23050585	SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	COLOUR PRINTER POWER PROBLEM	Jayaraj. J.	POWER CABLE REFIXED		Swathika. K. - Special Clinic - Dialysis	15/05/2023
Dept Name : Special Clinic - Fever Clinic - Computer Department Comp. Dt. : 18/11/2022 Status : Completed								
2914	22110745	FEVER CLINIC	NEED TO CHANGE BARCODE STRICKER	Balachandar. A.	BARCODE STRICKER CHANGED		Thiyagarajan. K. - Special Clinic - Fever Clinic	18/11/2022
2915	22110788	Reception	NEED TO CHANGE BARCODE STICKER IN COUNTER NO 4	Madhubalan. S.	BARCODE STICKER CHANGED		Thiyagarajan. K. - Special Clinic - Fever Clinic	18/11/2022
Comp. Dt. : 26/11/2022 Status : Completed								
2916	22111145	Reception	CHANGE BARCODE STICKER IN COUNTER 5	Selvam. D.	New barcode sticker changed		Thiyagarajan. K. - Special Clinic - Fever Clinic	26/11/2022
Comp. Dt. : 01/12/2022 Status : Completed								
2917	22120020	FEVER CLINIC	NEED TO CHANGE TONER	Selvam. D.	TONER CHANGED		Thiyagarajan. K. - Special Clinic - Fever Clinic	01/12/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 03/12/2022 Status : Completed								
2918	22120139	Reception	NEED TO CHANGE BARCODE STRICKER IN COUNTER 4	Shafiullah. R.	NEW BARCODE STRICKER CHANGED		Thiyagarajan. K. - Special Clinic - Fever Clinic	03/12/2022
Comp. Dt. : 10/12/2022 Status : Completed								
2919	22120491	Reception	BARCODE PRINTER PROBLEM	Jayaraj. J.	PRINTER WORKING		Thiyagarajan. K. - Special Clinic - Fever Clinic	12/12/2022
Comp. Dt. : 21/12/2022 Status : Completed								
2920	22120948	Reception	NEED TO CHANGE BARCODE STICKER IN COUNTER 4	Balachandar. A.	COUNTER 4 NEW STICKER CHANGED		Thiyagarajan. K. - Special Clinic - Fever Clinic	21/12/2022
Comp. Dt. : 27/12/2022 Status : Completed								
2921	22121219	Reception	CHANGE BARCODE STICKER IN COUNTER 5	Shafiullah. R.	BARCODE STICKER CHANGED		Thiyagarajan. K. - Special Clinic - Fever Clinic	27/12/2022
Comp. Dt. : 30/12/2022 Status : Completed								
2922	22121366	Reception	IN COUNTER 7-SYSTEM MONITOR DISPLAY NOT WORKING	Balachandar. A.	Ram refixed and dust cleaned.		Thiyagarajan. K. - Special Clinic - Fever Clinic	02/01/2023
Comp. Dt. : 03/02/2023 Status : Completed								
2923	23020106	Reception	NEED TO CHANGE BARCODE STICKER IN COUNTER NO. 4	Selvam. D.	New barcode sticker changed		Thiyagarajan. K. - Special Clinic - Fever Clinic	04/02/2023
Comp. Dt. : 16/02/2023 Status : Completed								
2924	23020657	Reception	COUNTER NO-5,NEED TO CHANGE BARCODE STICKER	Balachandar. A.	BARCODE STICKER CHANGED		Thiyagarajan. K. - Special Clinic - Fever Clinic	16/02/2023
Comp. Dt. : 22/02/2023 Status : Completed								
2925	23020862	Reception	COUNTER NO-4,NEED TO CHANGE BARCODE CHANGE	Venkatesh. S.	New barcode sticker changed		Thiyagarajan. K. - Special Clinic - Fever Clinic	22/02/2023
Comp. Dt. : 28/02/2023								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
2926	23021047	Reception	COUNTER NO-5 ,NEED TO CHANGE BARCODE STICKER	Harikrishnan. R.	BARCODE STICKER CHANGED		Thiyagarajan. K. - Special Clinic - Fever Clinic	28/02/2023
Dept Name : Special Clinic - Office - Computer Department								
Comp. Dt. : 18/11/2022								
Status : Completed								
2927	22110799	SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	NEED TO CHANGE TONER	Madhubalan. S.	12A TONER CHANGED		Thamizhselvi. S. - Administration	18/11/2022
Comp. Dt. : 22/11/2022								
Status : Completed								
2928	22110932	SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	SCANER POWER - NO ON	Madhubalan. S.	POWER CABLE REFIXED WORKING FINE		Kabilan. R. - Special Clinic - Office	22/11/2022
Comp. Dt. : 23/11/2022								
Status : Completed								
2929	22110987	SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	CHANGE PRINTER TONER	Madhubalan. S.	PRINTER TONER CHANGED		Kalaivani. K. - Special Clinic - Office	23/11/2022
Comp. Dt. : 25/11/2022								
Status : Completed								
2930	22111108	SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	CHANGE PRINTER TONER	Shafiullah. R.	12A TONRE CHANGED		Monica Sales. D. - Special Clinic - Office	25/11/2022
Comp. Dt. : 01/12/2022								
Status : Completed								
2931	22120010	SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	NEED SOFTWARE INSTALLATION WORK	Balachandar. A.	SOFTWARE INSTALLED		Thamizhselvi. S. - Administration	01/12/2022
Comp. Dt. : 05/12/2022								
Status : Completed								
2932	22120146	SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	SYSTEM NOT WORKING [SENTHIL SIR SYSTEM]	Balachandar. A.	RAM PROBLEM,CALL LOCKED		Thamizhselvi. S. - Administration	05/12/2022
Comp. Dt. : 08/12/2022								
Status : Completed								
2933	22120352	SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	NEED TO CHANGE SCANNER	Madhubalan. S.	SCANER CHANGED AND CONNETED OTHER SYSTEM		Divya. K. - Special Clinic - Office	08/12/2022

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2934	22120353	SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	CHANGE PRINTER TONER	Madhubalan. S.	12A TONER CHANGED		Thamizhselvi. S. - Administration	08/12/2022
2935	22120379	SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	CHANGE PRINTER TONER	Balachandar. A.	PRINTER TONER CHANGED		Monica Sales. D. - Special Clinic - Office	08/12/2022
Comp. Dt. : 16/12/2022 Status : Completed								
2936	22120775	SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	PRINTER NOT WORKING	Shafiullah. R.	REFIX USB CABLE		Kalaivani. K. - Special Clinic - Office	16/12/2022
Comp. Dt. : 17/12/2022 Status : Completed								
2937	22120798	SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	PRINTER NOT WORKING	Balachandar. A.	printer shared.		Kaveri. R. - Special Clinic - Office	17/12/2022
Comp. Dt. : 19/12/2022 Status : Completed								
2938	22120843	SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	NEED TO CHANGE TONER	Jayaraj. J.	12A TONER CHANGED		Kalaivani. K. - Special Clinic - Office	19/12/2022
Comp. Dt. : 23/12/2022 Status : Completed								
2939	22121070	SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	NEED TO CHANGE TONER	Madhubalan. S.	12A TONER CHANGED		Monica Sales. D. - Special Clinic - Office	23/12/2022
Comp. Dt. : 26/12/2022 Status : Completed								
2940	22121183	SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	SCANNER INSTALL	Balachandar. A.	SCANNER INSTALLED		Thamizhselvi. S. - Administration	27/12/2022
Comp. Dt. : 28/12/2022 Status : Completed								
2941	22121275	SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	NEED TO CHANGE PRINTER TONER	Balachandar. A.	PRINTER TONER CHANGED		Divya. K. - Special Clinic - Office	28/12/2022
Comp. Dt. : 31/12/2022 Status : Completed								
2942	22121399	SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	CHANGE PRINTER TONER	Balachandar. A.	PRINTER TONER CHANGED		Thamizhselvi. S. - Administration	31/12/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 03/01/2023								
Status : Completed								
2943	23010102	SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	CHANGE PRINTER TONER	Jayaraj. J.	12A TONER CHANGED		Monica Sales. D. - Special Clinic - Office	03/01/2023
2944	23010107	SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	CHANGE PRINTER TONER	Selvam. D.	PRINTER TONER CHANGED		Kalaivani. K. - Special Clinic - Office	04/01/2023
Comp. Dt. : 07/01/2023								
Status : Completed								
2945	23010313	SPECIAL WARD A1-FOURTH FLOOR	CHANGE PRINTER TONER	Balachandar. A.	12A toner changed		Monica Sales. D. - Special Clinic - Office	07/01/2023
Comp. Dt. : 18/01/2023								
Status : Completed								
2946	23010622	SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	IN SYSTEM, WRONGLY DISPLAYING DATE - NEED TO CHANGE	Madhubalan. S.	TIME DATE CHANGED		Monica Sales. D. - Special Clinic - Office	18/01/2023
Comp. Dt. : 20/01/2023								
Status : Completed								
2947	23010711	SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	NEED TO CHANGE TONER	Madhubalan. S.	12A TONER CHANGED		Kaveri. R. - Special Clinic - Office	20/01/2023
2948	23010731	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	NEED TO CHANGE PRINTER TONER	Selvam. D.	12A toner changed		Monica Sales. D. - Special Clinic - Office	21/01/2023
Comp. Dt. : 21/01/2023								
Status : Completed								
2949	23010770	SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	NEED SOFTWARE INSTALLATION WORK	Balachandar. A.	scheme service problem		Kabilan. R. - Special Clinic - Office	04/02/2023
Comp. Dt. : 27/01/2023								
Status : Completed								
2950	23010973	SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	BIOMETRIC MACHINE NOT WORKING	Balachandar. A.	biometric installed		Kalaivani. K. - Special Clinic - Office	20/02/2023
Comp. Dt. : 28/01/2023								
Status : Completed								
2951	23011026	SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	NEED TO CHANGE TONER	Jayaraj. J.	12A TONER CHANGED		Monica Sales. D. - Special Clinic - Office	28/01/2023
Comp. Dt. : 01/02/2023								
Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2952	23020003	SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	NEED TO CHANGE TONER	Valamburi. R.	12A TONER CHANGED		Kabilan. R. - Special Clinic - Office	01/02/2023
	Comp. Dt. : 06/02/2023							
	Status : Completed							
2953	23020168	SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	NEED TO CHECK COLOUR PRINTER NOT WORKING	Selvam. D.	Ink pad reset done		Kaveri. R. - Special Clinic - Office	06/02/2023
	Comp. Dt. : 08/02/2023							
	Status : Completed							
2954	23020291	SPECIAL WARD - A1	NEED TO CHANGE PRINTER TONER	Balachandar. A.	PRINTER TONER CHANGED		Monica Sales. D. - Special Clinic - Office	08/02/2023
	Comp. Dt. : 09/02/2023							
	Status : Completed							
2955	23020353	SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	NEED TO CHANGE PRINTER TONER	Jayaraj. J.	12A TONER CHANGED		Kalaivani. K. - Special Clinic - Office	09/02/2023
	Comp. Dt. : 13/02/2023							
	Status : Completed							
2956	23020484	SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	NEED SOFTWARE INSTALATION WORK	Balachandar. A.	SOFTWARE INSTALLED		Kaveri. R. - Special Clinic - Office	20/02/2023
	Comp. Dt. : 17/02/2023							
	Status : Completed							
2957	23020669	SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	NEED TO CHANGE TONER	Shafiullah. R.	12A TONER CHANGED		Monica Sales. D. - Special Clinic - Office	17/02/2023
2958	23020707	SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	NEED TO CHANGE TONER	Selvam. D.	12A TONER CHANGED		Kabilan. R. - Special Clinic - Office	17/02/2023
	Comp. Dt. : 24/02/2023							
	Status : Completed							
2959	23020933	SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	NEED TO CHANGE TONER	Jayaraj. J.	12A TONER CHANGED		Thamizhselvi. S. - Administration	24/02/2023
	Comp. Dt. : 06/03/2023							
	Status : Completed							
2960	23030202	SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	NEED TO CHANGE TONER	Balachandar. A.	TONER CHANGED		Kalaivani. K. - Special Clinic - Office	06/03/2023
	Comp. Dt. : 08/03/2023							


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
2961	23030334	SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	NEED TO CHANGE TONER	Shafiullah. R.	H4-SP4 12A TONER CHANGED		Monica Sales. D. - Special Clinic - Office	08/03/2023
Comp. Dt. : 13/03/2023								
Status : Completed								
2962	23030500	SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	NEED TO CHANGE TONER	Harikrishnan. R.	12A TONER CHANGED		Monica Sales. D. - Special Clinic - Office	13/03/2023
Comp. Dt. : 14/03/2023								
Status : Completed								
2963	23030569	SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	NET SLOW PROBLEM	Madhubalan. S.	bsnl problem		Kaveri. R. - Special Clinic - Office	15/03/2023
Comp. Dt. : 22/03/2023								
Status : Completed								
2964	23030918	SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	NEED TO CHANGE TONER	Harikrishnan. R.	12A Toner Changed		Kalaivani. K. - Special Clinic - Office	22/03/2023
Comp. Dt. : 25/03/2023								
Status : Completed								
2965	23031081	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	PRINTER NOT WORKING	Shafiullah. R.	already the printer call locked and closed		Monica Sales. D. - Special Clinic - Office	25/03/2023
Comp. Dt. : 27/03/2023								
Status : Completed								
2966	23031090	SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	NEED TO CHECK NET CONNECTION - NOT WORKING [3 SYSTEMS]	Shafiullah. R.	network working		Murali. S. - Special Clinic - Office	27/03/2023
Comp. Dt. : 28/03/2023								
Status : Completed								
2967	23031180	SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	NEED SYSTEM CABLE CONNECTING	Balachandar. A.	cable connected		Thamizhselvi. S. - Administration	29/03/2023
2968	23031195	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	NEED TO CHANGE TONER	Venkatesh. S.	12a tonner changed		Sathiya. S. - Special Clinic - Office	29/03/2023
Comp. Dt. : 31/03/2023								
Status : Completed								
2969	23031339	SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	NEED TO REFIL COLOUR PRINTER INK	Jayaraj. J.	INK REFILED		Kaveri. R. - Special Clinic - Office	31/03/2023

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2970	23031360	SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	NEED TO CHANGE TONER	Jayaraj. J.	12A TONER CHANGED		Thamizhselvi. S. - Administration	31/03/2023
Comp. Dt. : 01/04/2023 Status : Completed								
2971	23040010	SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	PRINTER NOT WORKING	Shafiullah. R.	pending job cleared..		Kalaivani. K. - Special Clinic - Office	03/04/2023
Comp. Dt. : 04/04/2023 Status : Completed								
2972	23040133	SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	SCANNER NOT WORKING	Shafiullah. R.	SCANNER WORKING SETTING CHANGED		Divya. K. - Special Clinic - Office	04/04/2023
Comp. Dt. : 05/04/2023 Status : Completed								
2973	23040156	SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	NET - SLOW PROBLEM	Balachandar. A.	firewall restarted		Kalaivani. K. - Special Clinic - Office	06/04/2023
2974	23040163	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	NEED TO CHANGE BARCODE STRICKER	Shafiullah. R.	NEW BARCODE STICKER CHANGED		Krithika. J. - Special Clinic - Office	05/04/2023
Comp. Dt. : 11/04/2023 Status : Completed								
2975	23040292	SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	PROBLEM IN NET CONNECTION	Selvam. D.	Patch cable refix		Kalaivani. K. - Special Clinic - Office	11/04/2023
2976	23040315	SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	PRINTER NOT WORKING	Selvam. D.	printer working		Divya. K. - Special Clinic - Office	11/04/2023
2977	23040337	SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	NEED TO CHANGE TONER	Shafiullah. R.	12A TONER CHANGED		Kalaivani. K. - Special Clinic - Office	11/04/2023
2978	23040339	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	SYSTEM NOT WORKING	Shafiullah. R.	SYSTEM WORKING		Krithika. J. - Special Clinic - Office	11/04/2023
Comp. Dt. : 13/04/2023 Status : Completed								
2979	23040427	SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	NEED DIGITAL SIGNATURE INSTALLATION	Balachandar. A.	DIGITAL SIGNATURE INSTLLAED		Thamizhselvi. S. - Administration	17/04/2023
Comp. Dt. : 15/04/2023 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2980	23040440	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	NEED TO CHECK SYSTEM - NOT WORKING	Balachandar. A.	SYSTEM HDD HEALTH PROBLEM. HARD DISK CHANGED		Krithika. J. - Special Clinic - Office	24/04/2023
Comp. Dt. : 16/04/2023 Status : Completed								
2981	23040477	Reception	NEED TO CHANGE STRICKER FOR COUNTER NO 4 & 5	Shafiullah. R.	STRICKER CHANGED		Mageswaran. A. - Special Clinic - Office	17/04/2023
Comp. Dt. : 17/04/2023 Status : Completed								
2982	23040483	Reception	PROBLEM IN BARCODE PRINTER - - COUNTER NO 3	Shafiullah. R.	BARCODE STRICKER CHANGE		Sathiya. S. - Special Clinic - Office	17/04/2023
Comp. Dt. : 18/04/2023 Status : Completed								
2983	23040541	SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	NETWORK PROBLEM	Raja.B	bsnl problem		Divya. K. - Special Clinic - Office	18/04/2023
Comp. Dt. : 19/04/2023 Status : Completed								
2984	23040590	SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	NEED SOFTWARE INSTALLATION WORK	Jayaraj. J.	PDF CONVERTER AND PRINTER SHARING		Monica Sales. D. - Special Clinic - Office	19/04/2023
Comp. Dt. : 20/04/2023 Status : Completed								
2985	23040630	SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	KEY BOARD NOT WORKING	Jayaraj. J.	KEYBOARD CLEAN AND REFIXED		Monica Sales. D. - Special Clinic - Office	20/04/2023
Comp. Dt. : 22/04/2023 Status : Completed								
2986	23040709	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	SYSTEM NOT WORKING	Selvam. D.	New hard disk changed		Krithika. J. - Special Clinic - Office	24/04/2023
Comp. Dt. : 24/04/2023 Status : Completed								
2987	23040748	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	NEED TO CHANGE " NEW REGISTRATION BARCODE STRICKER "	Harikrishnan. R.	New barcode sticker changed		Krithika. J. - Special Clinic - Office	24/04/2023
Comp. Dt. : 25/04/2023 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2988	23040826	SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	NET WORK PROBLEM	Shafiullah. R.	BSNL NETWORK CHECKING		Monica Sales. D. - Special Clinic - Office	26/04/2023
Comp. Dt. : 26/04/2023 Status : Completed								
2989	23040835	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	PRINTER NOT WORKING	Jayaraj. J.	WORKING FINE		Krithika. J. - Special Clinic - Office	26/04/2023
2990	23040867	SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	PROBLEM IN MEDPLUS & NET	Selvam. D.	8 port switch restarts		Kalaivani. K. - Special Clinic - Office	26/04/2023
Comp. Dt. : 27/04/2023 Status : Completed								
2991	23040888	SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	NEED TO CHANGE SCANNER	Harikrishnan. R.	Scanner changed		Divya. K. - Special Clinic - Office	28/04/2023
2992	23040923	SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	NEED TO CHANGE TONER	Harikrishnan. R.	12A toner changed		Monica Sales. D. - Special Clinic - Office	28/04/2023
2993	23040936	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	SYSTEM NOT WORKING	Selvam. D.	CHECKED WORKING FINE		Krithika. J. - Special Clinic - Office	04/05/2023
Comp. Dt. : 29/04/2023 Status : Completed								
2994	23040991	SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	U P S NOT WORKING	Prakash. P.	lithium ups changed		Thamizhselvi. S. - Administration	24/05/2023
2995	23041000	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	PROBLEM IN BARCODE PRINTER	Prakash. P.	barcode switch changed		Krithika. J. - Special Clinic - Office	04/05/2023
Comp. Dt. : 02/05/2023 Status : Completed								
2996	23050017	SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	NEED TO CHANGE TONER	Shafiullah. R.	12A TONER CHANGED		Divya. K. - Special Clinic - Office	02/05/2023
Comp. Dt. : 03/05/2023 Status : Completed								
2997	23050082	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	PRINTER NOT WORKING	Shafiullah. R.	PRINTER WORKING FINE		Krithika. J. - Special Clinic - Office	03/05/2023
Comp. Dt. : 06/05/2023 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2998	23050246	SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	NEED TO REPLACE PRINTER CONNECTION	Shafiullah. R.	PRINTER REPLACE CONNECT		Thamizhselvi. S. - Administration	06/05/2023
Comp. Dt. : 09/05/2023 Status : Completed								
2999	23050370	SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	NEED TO CHANGE TONER	Balachandar. A.	TONER CHANGED		Thamizhselvi. S. - Administration	11/05/2023
Comp. Dt. : 11/05/2023 Status : Completed								
3000	23050421	SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	NEED TO CHANGE TONER	Valamburi. R.	TONER CHANGED		Monica Sales. D. - Special Clinic - Office	11/05/2023
Comp. Dt. : 12/05/2023 Status : Completed								
3001	23050471	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	MOUSE NOT WORKING	Jayaraj. J.	MOUSE REFIXED		Krithika. J. - Special Clinic - Office	12/05/2023
Comp. Dt. : 18/05/2023 Status : Completed								
3002	23050758	SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	NEED TO CHANGE TONER	Shafiullah. R.	12A TONER CHANGED		Divya. K. - Special Clinic - Office	18/05/2023
3003	23050765	SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	FAX MACHINE NOT WORKING	Shafiullah. R.	RESTRAT THE PACS SERVER		Monica Sales. D. - Special Clinic - Office	18/05/2023
Comp. Dt. : 20/05/2023 Status : Completed								
3004	23050829	SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	KEY BOARD NOT WORKING	Murugavel.R	one chips set keys are not working so change new keyboard		Divya. K. - Special Clinic - Office	20/05/2023
Comp. Dt. : 23/05/2023 Status : Completed								
3005	23050910	SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	NEED TO CHANGE TONER	Prakash. P.	TONER CHANGED		Monica Sales. D. - Special Clinic - Office	23/05/2023
Comp. Dt. : 26/05/2023 Status : Completed								
3006	23051060	SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	NEED TO CHECK NET CONNECTION - NOT WORKING	Prakash. P.	NET is Working		Kaveri. R. - Special Clinic - Office	26/05/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 29/05/2023								
Status : Completed								
3007	23051130	SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	SYSTEM NOT WORKING	Balachandar. A.	antivirus installed and scanned		Murali. S. - Special Clinic - Office	29/05/2023
Comp. Dt. : 01/06/2023								
Status : Completed								
3008	23060031	SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	NEED TO CHANGE TONER	Shafiullah. R.	12A TONER CHANGED		Kalaivani. K. - Special Clinic - Office	01/06/2023
Comp. Dt. : 05/06/2023								
Status : Completed								
3009	23060136	SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	NEED TO CHANGE TONER	Harikrishnan. R.	12A toner changed		Monica Sales. D. - Special Clinic - Office	06/06/2023
Comp. Dt. : 06/06/2023								
Status : Completed								
3010	23060194	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	PRINTER NOT WORKING	Selvam. D.	12A toner changed		Krithika. J. - Special Clinic - Office	06/06/2023
Comp. Dt. : 09/06/2023								
Status : Completed								
3011	23060315	SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	SYSTEM - NET CONNECTION PROBLEM	Shafiullah. R.	REFIX THE PATCH CARD		Monica Sales. D. - Special Clinic - Office	09/06/2023
3012	23060327	SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	NEED TO CHECK NET CONNECTION - PROBLEM [AGAIN]	Jayaraj. J.	LAN CABLE REFIXED		Monica Sales. D. - Special Clinic - Office	09/06/2023
Comp. Dt. : 10/06/2023								
Status : Completed								
3013	23060351	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	NEED TO CHANGE BARCODE STRICKER	Selvam. D.	New barcode sticker changed		Krithika. J. - Special Clinic - Office	10/06/2023
Comp. Dt. : 21/06/2023								
Status : Completed								
3014	23060744	SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	NEED TO CHANGE TONER	Madhubalan. S.	12A TONER CHANGED		Divya. K. - Special Clinic - Office	21/06/2023
Comp. Dt. : 26/06/2023								
Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
3015	23060929	SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	SYSTEM NOT WORKING	Selvam. D.	Restarts the system working fine		Murali. S. - Special Clinic - Office	26/06/2023
Dept Name : Special Clinic - Reception - Computer Department Comp. Dt. : 16/11/2022 Status : Completed								
3016	22110642	Reception	IN COUNTER 4-CHANGE PRINTER RIBBON AND BARCODE STICKER	Shafiullah. R.	WAX RIBBON AND BARCODE STICKER CHANGED		Baskar. G. - Special Clinic - Reception	16/11/2022
Comp. Dt. : 17/11/2022 Status : Completed								
3017	22110724	Reception	CHANGE BARCODE STICKER IN COUNTER 6	Selvam. D.	BARCODE STICKER CHANGED		Muthamizraja. M. - Special Clinic - Reception	18/11/2022
Comp. Dt. : 18/11/2022 Status : Completed								
3018	22110762	Reception	NEED TO CHECK NET CONNECTION FOR COUNTER NO 2	Balachandar. A.	system restarted..		Baskar. G. - Special Clinic - Reception	18/11/2022
Comp. Dt. : 19/11/2022 Status : Completed								
3019	22110803	Reception	NEED TO REFIX PRINTER RIBBON FOR COUNTER NO 5	Jayaraj. J.	BARCODE RIBBON REFIXED		Muthamizraja. M. - Special Clinic - Reception	19/11/2022
Comp. Dt. : 22/11/2022 Status : Completed								
3020	22110902	Reception	NEED TO CHANGE NEW REGISTRATION STRICKER FOR COUNTER NO 4 & 5	Madhubalan. S.	COUNTER 4 & 5 NEW STICKER CHANGED		Baskar. G. - Special Clinic - Reception	22/11/2022
Comp. Dt. : 23/11/2022 Status : Completed								
3021	22110972	Reception	NEED TO CHECK SYSTEM - NOT WORKING COUNTER NO 2	Balachandar. A.	POWER CABLE REFIXED		Baskar. G. - Special Clinic - Reception	23/11/2022
3022	22111011	Reception	CHANGE BARCODE STICKER IN COUNTER 3,4,5	Balachandar. A.	BARCODE STICKER CHANGED		Gughan. P. - Special Clinic - Reception	23/11/2022
3023	22111017	Reception	IN COUNTER 1-SCANNER NOT WORKING	Balachandar. A.	scanner dust cleaned		Ramya. R. - Special Clinic - Reception	25/11/2022
Comp. Dt. : 24/11/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
3024	22111021	Reception	IN COUNTER 4 CHANGE PRINTER RIBBON	Madhubalan. S.	BARCODE RIBBON CHANGED		Baskar. G. - Special Clinic - Reception	24/11/2022
	Comp. Dt. : 25/11/2022							
	Status : Completed							
3025	22111081	Reception	CHANGE BARCODE STICKER IN COUNTER 4 AND 5	Balachandar. A.	BARCODE STICKER CHANGED		Baskar. G. - Special Clinic - Reception	25/11/2022
3026	22111082	Reception	CHANGE PRINTER RIBBON IN COUNTER 4	Madhubalan. S.	PRINTER RIBBON CHANGED		Baskar. G. - Special Clinic - Reception	25/11/2022
	Comp. Dt. : 28/11/2022							
	Status : Completed							
3027	22111158	Reception	CHANGE BARCODE STICKER IN COUNTER 4 AND 5	Balachandar. A.	BARCODE STICKER CHANGED		Geetha. J. - Special Clinic - Reception	28/11/2022
	Comp. Dt. : 30/11/2022							
	Status : Completed							
3028	22111271	Reception	NEED CHANGE REVISIT STRICKER FOR COUNTER NO . 6	Shafiullah. R.	REVISIT STRICKER CHANGED		Baskar. G. - Special Clinic - Reception	30/11/2022
	Comp. Dt. : 01/12/2022							
	Status : Completed							
3029	22120003	Reception	NEED TO CHANGE BARCODE STRICKER FOR COUNTER NO 5	Shafiullah. R.	NEW BARCODE STRICKER CHANGED		Baskar. G. - Special Clinic - Reception	01/12/2022
3030	22120023	Reception	NEED TO CHANGE BARCODE FOR COUNTER NO 4 & 5	Shafiullah. R.	BARCODE STICKER CHANGED		Baskar. G. - Special Clinic - Reception	01/12/2022
3031	22120039	Reception	NEED TO CHANGE TONER FOR COUNTER NO. 8	Jayaraj. J.	12A TONER CHANGED		Baskar. G. - Special Clinic - Reception	02/12/2022
	Comp. Dt. : 02/12/2022							
	Status : Completed							
3032	22120076	Reception	NEED TO CHANGE BARCODE STRICKER FOR COUNTER NO. 4	Selvam. D.	BARCODE STRICKER CHANGED		Baskar. G. - Special Clinic - Reception	02/12/2022
3033	22120101	Reception	SCANNER NOT WORKING IN COUNTER NO 1	Selvam. D.	multiple complaint		Geetha. J. - Special Clinic - Reception	03/12/2022
	Comp. Dt. : 03/12/2022							
	Status : Completed							
3034	22120102	Reception	CPU NOT WORKING IN COUNTER NO 2	Selvam. D.	Power cable refixed		Geetha. J. - Special Clinic - Reception	03/12/2022
3035	22120107	Reception	SCANNER NOT WORKING IN COUNTER NO.1	Selvam. D.	Pick up roller and scanner unit problem. Part not available hence the scanner is contamination		Baskar. G. - Special Clinic - Reception	05/12/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
3036	22120142	Reception	SCANNER NOT WORKING IN COUNTER NO. 2	Shafiullah. R.	SCANNER WORKING		Geetha. J. - Special Clinic - Reception	03/12/2022
		Comp. Dt. : 05/12/2022 Status : Completed						
3037	22120164	Reception	NEED TO CHECK BARCODE PRINTER - STUCK - COUNTER NO 6	Selvam. D.	OLD STICKER REMOVED NEW STICKER CHANGED		Baskar. G. - Special Clinic - Reception	05/12/2022
3038	22120169	Reception	IN COUNTER 6-CHANGE REVISIT BARCODE STICKER	Selvam. D.	Revisit sticker changed		Geetha. J. - Special Clinic - Reception	05/12/2022
3039	22120196	Reception	IN COUNETR 1-SCANNER PROBLEM	Madhubalan. S.	SCANNER POWER CABLE REFIXED WORKING FINE		Geetha. J. - Special Clinic - Reception	06/12/2022
		Comp. Dt. : 07/12/2022 Status : Completed						
3040	22120281	Reception	IN COUNTER 2-CPU NO POWER ON	Madhubalan. S.	POWER CABLE REFIXED		Geetha. J. - Special Clinic - Reception	07/12/2022
3041	22120313	Reception	IN COUNTER 3 AND 4 -CHANGE BARCODE STICKER	Madhubalan. S.	COUNTER 4 AND 5 NEW STICKER CHANGED		Geetha. J. - Special Clinic - Reception	07/12/2022
3042	22120316	Reception	NEED TO CHANGE REVISIT STRICKER FOR COUNTER NO 6	Madhubalan. S.	COUNTER 6 REVISITE STICKER CHANGED		Baskar. G. - Special Clinic - Reception	07/12/2022
		Comp. Dt. : 08/12/2022 Status : Completed						
3043	22120345	Reception	NEED TO CHECK PRINTER & NET CONNECTION - NOT WORKING AT COUNTER NO 1	Balachandar. A.	NETWORK CABLE REFIXED AND PENDING JOB CLEARED		Baskar. G. - Special Clinic - Reception	08/12/2022
3044	22120368	Reception	IN COUNTER 3 AND 4-CHANGE BARCODE STICKER	Madhubalan. S.	COUNTER 4 AND 5 NEW STICKER CHANGED		Geetha. J. - Special Clinic - Reception	08/12/2022
		Comp. Dt. : 09/12/2022 Status : Completed						
3045	22120408	Reception	PRINTER NOT WORKING	Valamburi. R.	pending job cleared..		Baskar. G. - Special Clinic - Reception	10/12/2022
		Comp. Dt. : 10/12/2022 Status : Completed						
3046	22120453	Reception	SYSTEM NOT WORKING - COUNTER NO 2	Valamburi. R.	UPS LINE CHANGED		Baskar. G. - Special Clinic - Reception	10/12/2022
3047	22120479	Reception	CHANGE BARCODE STICKER IN COUNTER 3	Valamburi. R.	BARCODE STICKER CHANGED		Baskar. G. - Special Clinic - Reception	10/12/2022
		Comp. Dt. : 13/12/2022 Status : Completed						


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
3048	22120567	Reception	SYSTEM NOT WORKING COUNTER NO. 2	Shafiullah. R.	SMPS POWER DRY AND START THE COMPUTER		Baskar. G. - Special Clinic - Reception	13/12/2022
3049	22120609	Reception	NEED TO CHANGE STRICKER FOR COUNTER NO 3 & 4	Selvam. D.	New barcode sticker changed		Baskar. G. - Special Clinic - Reception	14/12/2022
Comp. Dt. : 14/12/2022 Status : Completed								
3050	22120619	Reception	SYSTEM NOT WORKING-COUNTER NO. 4	Jayaraj. J.	Stand by system fixed		Savitha. K. - Special Clinic - Reception	16/12/2022
Comp. Dt. : 15/12/2022 Status : Completed								
3051	22120691	Reception	CHANGE BARCODE STICKER IN COUNTER 3	Shafiullah. R.	BARCODE STICKER changed		Geetha. J. - Special Clinic - Reception	15/12/2022
Comp. Dt. : 16/12/2022 Status : Completed								
3052	22120742	Reception	SYSTEM NOT WORKING IN COUNTER 2	Selvam. D.	SYSTEM WORKING		Baskar. G. - Special Clinic - Reception	16/12/2022
3053	22120743	Reception	CHANGE BARCODE STICKER ION COUNTER 3 AND 4	Selvam. D.	BARCODE STICKER ION COUNTER 3 AND 4 CHNAGE		Baskar. G. - Special Clinic - Reception	16/12/2022
Comp. Dt. : 17/12/2022 Status : Completed								
3054	22120805	Reception	PRINTER NOT WORKING COUNTER NO 1	Jayaraj. J.	PRINTER WORKING FINE		Baskar. G. - Special Clinic - Reception	17/12/2022
3055	22120806	Reception	PRINTER NOT WORKING - COUNTER NO 1	Jayaraj. J.	PRINTER WORKING FINE		Baskar. G. - Special Clinic - Reception	17/12/2022
3056	22120809	Reception	NEED TO CHANGE BARCODE STRICKER FOR COUNTER NO 4	Jayaraj. J.	COUNTER 4 STICKER CHANGED		Baskar. G. - Special Clinic - Reception	17/12/2022
3057	22120814	Reception	IN COUNTER 6-BARCODE PRINTER NOT WORKING	Jayaraj. J.	PRINTER WORKING FINE		Gughan. P. - Special Clinic - Reception	17/12/2022
3058	22120816	Reception	CHANGE PRINTER RIBBON IN COUNTER 4	Jayaraj. J.	COUNTER 4 RIBBON CHANGED		Gughan. P. - Special Clinic - Reception	17/12/2022
3059	22120817	Reception	CHANGE BARCODE STICKER IN COUNTER 4	Jayaraj. J.	COUNTER 4 RIBBON CHANGED		Gughan. P. - Special Clinic - Reception	17/12/2022
3060	22120823	Reception	IN COUNTER 4-PRINTER RIBBON GOT STRUCKED	Jayaraj. J.	RIBBON CHANGED		Ramya. R. - Special Clinic - Reception	17/12/2022
Comp. Dt. : 19/12/2022 Status : Completed								
3061	22120835	Reception	PRINTER NOT WORKING IN COUNTER NO 1	Murugavel.R	PRINTER WORKING FINE		Geetha. J. - Special Clinic - Reception	19/12/2022
3062	22120868	Reception	NEED TO CHANGE BARCODE STICKER IN COUNTER NO. 3	Jayaraj. J.	BARCODE STICKER CHANGED		Baskar. G. - Special Clinic - Reception	20/12/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 21/12/2022								
Status : Completed								
3063	22120956	Reception	NEED TO CHANGE BARCODE STICKER IN COUNTER 5	Balachandar. A.	BARCODE STICKER CHANGED		Geetha. J. - Special Clinic - Reception	21/12/2022
Comp. Dt. : 22/12/2022								
Status : Completed								
3064	22121019	Reception	NEED TO CHANGE PRINTER TONER IN COUNTER 1	Balachandar. A.	PRINTER TONER CHANGED		Geetha. J. - Special Clinic - Reception	22/12/2022
3065	22121025	Reception	NEED TO CHANGE BARCODE STICKER IN COUNTER 3	Balachandar. A.	BARCODE STICKER CHANGED		Baskar. G. - Special Clinic - Reception	22/12/2022
Comp. Dt. : 24/12/2022								
Status : Completed								
3066	22121108	Reception	NEED TO CHANGE BARCODE STICKER IN COUNTER NO 4 & 5	Murugavel.R	NEW STICKER CHANGED		Baskar. G. - Special Clinic - Reception	24/12/2022
Comp. Dt. : 27/12/2022								
Status : Completed								
3067	22121221	Reception	SCANNER NOT WORKING	Jayaraj. J.	SCANNER REINSTALLED		Baskar. G. - Special Clinic - Reception	28/12/2022
Comp. Dt. : 28/12/2022								
Status : Completed								
3068	22121287	Reception	CHANGE BARCODE STICKER IN COUNTER 4	Balachandar. A.	BARCODE STICKER CHANGED		Geetha. J. - Special Clinic - Reception	28/12/2022
3069	22121305	Reception	CHANGE BARCODE STICKER IN COUNTER 5	Madhubalan. S.	BARCODE STICKER CHANGED		Baskar. G. - Special Clinic - Reception	29/12/2022
Comp. Dt. : 31/12/2022								
Status : Completed								
3070	22121404	Reception	CHANGE BARCODE STICKER IN COUNTER 3	Madhubalan. S.	NEW STICKER CHANGED		Baskar. G. - Special Clinic - Reception	31/12/2022
Comp. Dt. : 02/01/2023								
Status : Completed								
3071	23010051	Reception	CHANGE BARCODE STICKER IN COUNTER 4 AND 5	Madhubalan. S.	COUNTER 4 AND 5 NEW STICKER CHANGED		Geetha. J. - Special Clinic - Reception	02/01/2023
Comp. Dt. : 05/01/2023								
Status : Completed								
3072	23010229	Reception	CHANGE BARCODE STICKER IN COUNTER 3	Selvam. D.	New barcode sticker changed		Baskar. G. - Special Clinic - Reception	05/01/2023

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 06/01/2023								
Status : Completed								
3073	23010261	Reception	RECEPTION COUNTER NO 4, BARCODE PROBLEM	Shafiullah. R.	refix the barcode sticker		Savitha. K. - Special Clinic - Reception	06/01/2023
Comp. Dt. : 07/01/2023								
Status : Completed								
3074	23010311	Reception	CHANGE BARCODE STICKER AND PRINTER RIBBON IN COUNTER 4	Shafiullah. R.	BARCODE STICKER CHANGED		Geetha. J. - Special Clinic - Reception	09/01/2023
Comp. Dt. : 09/01/2023								
Status : Completed								
3075	23010329	Reception	SYSTEM NOT WORKING IN COUNTER NO 2	Valamburi. R.	POWER SOCKET PROBLEM FIXED ELECTRICAL		Geetha. J. - Special Clinic - Reception	09/01/2023
3076	23010330	Reception	NEED TO CHANGE PRINTER RIBBON IN COUNTER NO 3	Balachandar. A.	PRINTER RIBBON CHANGED		Geetha. J. - Special Clinic - Reception	09/01/2023
Comp. Dt. : 12/01/2023								
Status : Completed								
3077	23010523	Reception	CHANGE BARCODE STICKER IN COUNTER 5	Balachandar. A.	BARCODE STICKER CHANGED		Geetha. J. - Special Clinic - Reception	12/01/2023
Comp. Dt. : 14/01/2023								
Status : Completed								
3078	23010592	SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	PRINTER NOT WORKING	Balachandar. A.	printer reconfigured		Savitha. K. - Special Clinic - Reception	18/01/2023
3079	23010596	Reception	NEED TO CHANGE STRICKER FOR COUNTER NO. 3 & 4	Jayaraj. J.	STRICKER CHANGED		Baskar. G. - Special Clinic - Reception	18/01/2023
Comp. Dt. : 18/01/2023								
Status : Completed								
3080	23010613	Reception	NEED TO CHANGE REVISIT STRICKER FOR COUNTER NO 6	Balachandar. A.	REVISIT STRICKER CHANGED		Baskar. G. - Special Clinic - Reception	18/01/2023
3081	23010614	Reception	MEDPLUS SOFTWARE NOT WORKING COUNTER NO 3	Balachandar. A.	NETWOTK CABLE REFIXED		Baskar. G. - Special Clinic - Reception	18/01/2023
Comp. Dt. : 19/01/2023								
Status : Completed								
3082	23010671	Reception	NEED TO CHANGE BARCODE STRICKER FOR COUNTER NO 3 & 4	Madhubalan. S.	COUNTER 3 AND 4 NEW STICKER CHANGED		Baskar. G. - Special Clinic - Reception	19/01/2023
Comp. Dt. : 20/01/2023								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
3083	23010703	Reception	FINGER SENSOR NOT WORKING - COUNTER NO 1	Madhubalan. S.	USB CABLE REFIXED WORKING FINE		Baskar. G. - Special Clinic - Reception	20/01/2023
3084	23010720	Reception	BARCODE MACHINE NOT WORKING - COUNTER NO 3	Madhubalan. S.	BARCODE MACHINE WORKING FINE		Baskar. G. - Special Clinic - Reception	20/01/2023
3085	23010747	Reception	NEED TO CHANGE RIBBON FOR COUNTER NO 4	Madhubalan. S.	BARCODE RIBBON CHANGED		Baskar. G. - Special Clinic - Reception	20/01/2023
Comp. Dt. : 21/01/2023								
Status : Completed								
3086	23010772	Reception	NEED TO CHANGE BARCODE STRICKER FOR COUNTER NO 3 & 4	Madhubalan. S.	BARCODE STRICKER CHANGED		Baskar. G. - Special Clinic - Reception	21/01/2023
Comp. Dt. : 23/01/2023								
Status : Completed								
3087	23010795	Reception	NEED TO CHANGE STRICKER FOR COUNTER NO 3 & 4 & RIBBON FOR COUNTER NO 3	Madhubalan. S.	STRICKER CHANGED		Baskar. G. - Special Clinic - Reception	23/01/2023
3088	23010829	Reception	BARCODE STRICKER STUCK PROBELM - COUNTER NO 4	Selvam. D.	Barcode ribbon and sticker refixed		Baskar. G. - Special Clinic - Reception	23/01/2023
Comp. Dt. : 25/01/2023								
Status : Completed								
3089	23010898	Reception	NEED TO CHANGE BARCODE STRICKER FOR COUNTER NO 5	Shafiullah. R.	NEW BARCODER STRICKER CHANGED		Baskar. G. - Special Clinic - Reception	25/01/2023
3090	23010906	Reception	NEED TO CHANGE BARCODE STRICKER FOR COUNTER NO 6	Madhubalan. S.	COUNTER 6 REVISIT STICKER CHANGED		Baskar. G. - Special Clinic - Reception	25/01/2023
3091	23010939	Reception	NEED TO CHANGE TONER FOR COUNTER NO 8	Shafiullah. R.	12A TONER CHANGED		Baskar. G. - Special Clinic - Reception	25/01/2023
Comp. Dt. : 27/01/2023								
Status : Completed								
3092	23010941	Reception	NEED TO CHECK SYSTEM FOR COUNTER NO 1 NOT WORKING & CHANGE STRICKER FOR COUNTER NO 4 & 5	Madhubalan. S.	COUNTER 4 AND 5 NEW STICKER CHNAGED AND COUNTER 1 SYSTEM BIOS SETTING CHANGED WORKING FINE.		Baskar. G. - Special Clinic - Reception	27/01/2023
Comp. Dt. : 30/01/2023								
Status : Completed								
3093	23011033	Reception	SYSTEM NOT WORKING - COUNTER NO 1	Selvam. D.	POWER CADE REFIX		Baskar. G. - Special Clinic - Reception	30/01/2023

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 31/01/2023								
Status : Completed								
3094	23011084	Reception	NEED TO CHANGE BARCODE STRICKER FOR COUNTER NO 4 & 6	Madhubalan. S.	BARCODE STRICKER CHANGED		Baskar. G. - Special Clinic - Reception	31/01/2023
3095	23011089	Reception	PRINTER NOT WORKING - COUNTER NO 1	Valamburi. R.	PRINTER WORKING FINE		Baskar. G. - Special Clinic - Reception	01/02/2023
3096	23011090	Reception	BARCODE MACHINE NOT WORKING COUNTER NO 2 & 5	Selvam. D.	New barcode sticker changed		Baskar. G. - Special Clinic - Reception	31/01/2023
3097	23011093	Reception	NEED TO CHANGE STRICKER FOR COUNTER NO 6	Valamburi. R.	STRICKER CHANGED		Baskar. G. - Special Clinic - Reception	31/01/2023
3098	23011121	Reception	NEED TO CHANGE BARCODE STRICKER & PRINTER RIBBON FOR COUNTER NO 9	Selvam. D.	BARCODE STRICKER CHANGED		Baskar. G. - Special Clinic - Reception	01/02/2023
Comp. Dt. : 01/02/2023								
Status : Completed								
3099	23020028	Reception	NEED TO CHANGE PRINTER RIBBON FOR COUNTER NO 4	Madhubalan. S.	COUNTER 4 NEW SICKER AND RIBBON CHANGED		Baskar. G. - Special Clinic - Reception	01/02/2023
Comp. Dt. : 02/02/2023								
Status : Completed								
3100	23020054	Reception	NEED TO CHANGE BARCODE STICKER IN COUNTER NO. 3 & 4	Madhubalan. S.	COUNTER 3 AND 4 new sticker & ribbon changed		Baskar. G. - Special Clinic - Reception	02/02/2023
Comp. Dt. : 03/02/2023								
Status : Completed								
3101	23020078	Reception	PRINTER NOT WORKING COUNTER NO 1	Selvam. D.	Printer driver reinstalled		Baskar. G. - Special Clinic - Reception	04/02/2023
Comp. Dt. : 06/02/2023								
Status : Completed								
3102	23020199	Reception	NEED TO CHANGE PRINTER RIBBON IN COUNTER NO 3	Selvam. D.	Barcode ribbon changed		Geetha. J. - Special Clinic - Reception	06/02/2023
Comp. Dt. : 07/02/2023								
Status : Completed								
3103	23020212	Reception	NEED TO CHANGE BAR CODE STRICKER FOR COUNTER NO 4	Valamburi. R.	BAR CODE STRICKER CHANGED		Baskar. G. - Special Clinic - Reception	08/02/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
3104	23020229	Reception	NEED TO CHANGE BARCODE STRICKER FOR COUNTER NO 3 & BARCODE NOT WORKING IN COUNTER NO 6	Madhubalan. S.	COUNTER 3 BARCODE RIBBON CHANGED AND COUNTER 6 RIBBON REFIXED WORKING FINE.		Geetha. J. - Special Clinic - Reception	07/02/2023
3105	23020257	Reception	NEED TO CHANGE BARCODE STICKER IN COUNTER NO 4 & 5	Shafiullah. R.	new barcode sticker changed		Geetha. J. - Special Clinic - Reception	07/02/2023
Comp. Dt. : 08/02/2023 Status : Completed								
3106	23020307	Reception	NEED TO CHANGE BARCODE STICKER IN COUNTER NO. 3 & 4	Shafiullah. R.	BARCODE STICKER CHANGED		Baskar. G. - Special Clinic - Reception	08/02/2023
Comp. Dt. : 09/02/2023 Status : Completed								
3107	23020350	Reception	NEED TO CHANGE PRINTER TONER IN COUNTER NO 1	Balachandar. A.	12ATONER CHANGED		Geetha. J. - Special Clinic - Reception	09/02/2023
3108	23020351	Reception	NEED TO CHANGE BARCODE STICKER IN COUNTER NO 5	Balachandar. A.	BARCODE STICKER CHANGED		Geetha. J. - Special Clinic - Reception	09/02/2023
Comp. Dt. : 11/02/2023 Status : Completed								
3109	23020433	Reception	NEED TO CHECK BARCODE PRINTER MACHINE - RIBBON UNFIX COUNTER NO 4	Jayaraj. J.	barcode ribbon refixed		Baskar. G. - Special Clinic - Reception	11/02/2023
3110	23020434	Reception	SYSTEM NOT WORKING - COUNTER NO 5	Jayaraj. J.	New barcode sticker changed		Baskar. G. - Special Clinic - Reception	11/02/2023
3111	23020437	Reception	NEED TO CHANGE BARCODE STRICKER FOR COUNTER NO 4 & 5	Murugavel.R	New barcode sticker changed		Baskar. G. - Special Clinic - Reception	11/02/2023
Comp. Dt. : 13/02/2023 Status : Completed								
3112	23020468	Reception	NEED TO CHANGE REVISIT STRICKER FOR COUNTER NO 6	Shafiullah. R.	Revisit sticker changed		Baskar. G. - Special Clinic - Reception	13/02/2023
Comp. Dt. : 14/02/2023 Status : Completed								
3113	23020525	Reception	NEED TO CHANGE BARCODE STRICKER FOR COUNTER NO 4	Selvam. D.	NEW BARCODE STRICKER CHANGED		Baskar. G. - Special Clinic - Reception	14/02/2023
Comp. Dt. : 15/02/2023 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
3114	23020597	Reception	NEED TO CHANGE TONER FOR COUNTER NO 8	Prakash. P.	TONER CHANGED		Baskar. G. - Special Clinic - Reception	15/02/2023
Comp. Dt. : 17/02/2023 Status : Completed								
3115	23020668	Reception	BARCODE PRINTER NOT WORKING - COUNTER NO 6	Shafiullah. R.	BARCODE STICKER JAM CLEAR		Baskar. G. - Special Clinic - Reception	17/02/2023
3116	23020675	Reception	NEED TO CHANGE BARCODE STRICKER FOR COUNTER NO 3 & 4	Madhubalan. S.	COUNTER NO 3 & 4 NEW STICKER CHANGED		Baskar. G. - Special Clinic - Reception	17/02/2023
Comp. Dt. : 18/02/2023 Status : Completed								
3117	23020732	Reception	NEED TO CHANGE BARCODE STRICKER FOR COUNTER NO 3	Selvam. D.	New barcode sticker changed		Baskar. G. - Special Clinic - Reception	18/02/2023
Comp. Dt. : 20/02/2023 Status : Completed								
3118	23020738	Reception	NEED TO CHANGE REVISIT STRICKER FOR COUNTER NO 6	Balachandar. A.	REVISIT CHANGED		Baskar. G. - Special Clinic - Reception	20/02/2023
Comp. Dt. : 21/02/2023 Status : Completed								
3119	23020783	Reception	BARCODE PRINTER NOT WORKING AT REVISIT COUNTER	Selvam. D.	RESTART THE SYSTEM		Baskar. G. - Special Clinic - Reception	21/02/2023
3120	23020812	Reception	NEED TO CHANGE STRICKER FOR COUNTER NO 2 & 3	Venkatesh. S.	COUNTER 2 & 3 NEW STICKER CHANGED		Baskar. G. - Special Clinic - Reception	21/02/2023
3121	23020827	Reception	NEED TO CHANGE TONER FOR COUNTER NO 8	Harikrishnan. R.	12A TONER CHANGED		Baskar. G. - Special Clinic - Reception	21/02/2023
3122	23020830	Reception	NEED TO CHANGE STRICKER & RIBBON FOR COUNTER NO 9	Harikrishnan. R.	2 STRICKER CHANGED		Baskar. G. - Special Clinic - Reception	21/02/2023
Comp. Dt. : 23/02/2023 Status : Completed								
3123	23020902	Reception	MOUSE NOT WORKING - COUNTER NO 2	Balachandar. A.	PS/2 NEW MOUSE CHANGED		Baskar. G. - Special Clinic - Reception	23/02/2023
3124	23020909	Reception	NEED TO CHANGE TONER & STRICKER FOR COUNTER NO 9	Balachandar. A.	TONER and STICKER CHANGED		Baskar. G. - Special Clinic - Reception	23/02/2023
3125	23020910	Reception	NEED TO CHANGE NEW REGISTRATION BARCODE 2 NOS FOR COUNTER NO 3	Balachandar. A.	BARCODE STICKER CHANGED		Baskar. G. - Special Clinic - Reception	23/02/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 24/02/2023								
Status : Completed								
3126	23020915	Reception	NEED TO CHANGE STRICKER FOR COUNTER NO 6	Balachandar. A.	New barcode sticker changed		Baskar. G. - Special Clinic - Reception	24/02/2023
3127	23020924	Reception	NEED TO CHANGE BARCODE STRICKER AND RIBBON FOR COUNTER NO 3	Madhubalan. S.	New barcode sticker and ribbon changed		Baskar. G. - Special Clinic - Reception	24/02/2023
Comp. Dt. : 25/02/2023								
Status : Completed								
3128	23020988	Reception	NEED TO CHANGE BARCODE STRICKER FOR COUNTER NO 4	Madhubalan. S.	BARCODE STRICKER CHANGED		Baskar. G. - Special Clinic - Reception	25/02/2023
Comp. Dt. : 27/02/2023								
Status : Completed								
3129	23021020	Reception	NEED TO REFIX RIBBON FOR COUNTER NO 5	Madhubalan. S.	RIBBON REFIXED WORKING FINE		Baskar. G. - Special Clinic - Reception	27/02/2023
3130	23021028	Reception	NEED TO CHANGE BARCODE STRICKER FOR COUNTER NO 3 & 4	Selvam. D.	BARCODE STRICKER CHANGED		Baskar. G. - Special Clinic - Reception	27/02/2023
Comp. Dt. : 01/03/2023								
Status : Completed								
3131	23030031	Reception	NEED TO CHANGE STRICKER FOR COUNTER NO 2 & 3	Shafiullah. R.	2&3 new stricker changed		Baskar. G. - Special Clinic - Reception	01/03/2023
3132	23030053	Reception	PRINTER NOT WORKING - COUNTER NO 8	Jayaraj. J.	printer working fine		Baskar. G. - Special Clinic - Reception	02/03/2023
Comp. Dt. : 02/03/2023								
Status : Completed								
3133	23030062	Reception	NEED TO CHANGE RIBBON FOR COUNTER NO 6	Valamburi. R.	ribbon changed		Baskar. G. - Special Clinic - Reception	02/03/2023
3134	23030088	Reception	NEED TO CHANGE TONER FOR COUNTER NO 8	Shafiullah. R.	12A TONER CHANGED		Baskar. G. - Special Clinic - Reception	02/03/2023
3135	23030105	Reception	SYSTEM NOT WORKING COOUNTER NO 2	Madhubalan. S.	RESTART THE SYSTEM		Baskar. G. - Special Clinic - Reception	02/03/2023
Comp. Dt. : 07/03/2023								
Status : Completed								
3136	23030250	Reception	NEED TO REFIX BARCODE PRINTER RIBBON - PROBLEM - COUNTER NO 4	Shafiullah. R.	WAX RIBBON CHANGED AND 4,5&6 STRICKER CHANGED		Baskar. G. - Special Clinic - Reception	07/03/2023
Comp. Dt. : 09/03/2023								
Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
3137	23030362	Reception	NEED TO CHANGE BARCODE STRICKER FOR COUNTER NO 3 & 4	Selvam. D.	BARCODE STRICKER CHANGED		Baskar. G. - Special Clinic - Reception	09/03/2023
Comp. Dt. : 10/03/2023 Status : Completed								
3138	23030387	Reception	PRINTER PROBLEM IN COUNTER NO 4	Balachandar. A.	Barcocde sticker changed.		Baskar. G. - Special Clinic - Reception	10/03/2023
3139	23030388	Reception	NEED TO CHANGE BARCODE STRICKER FOR COUNTER NO 4 & 5	Selvam. D.	BARCODE STRICKER CHANGED		Baskar. G. - Special Clinic - Reception	10/03/2023
3140	23030395	Reception	NEED TO CHANGE BARCODE STRICKER FOR COUNTER NO 9	Selvam. D.	BARCODE STRICKER CHANGED		Baskar. G. - Special Clinic - Reception	10/03/2023
3141	23030428	Reception	ED TO CHANGE BARCODE STRICKER [2NOS] FOR COUNTER NO 9	Selvam. D.	New barcode sticker changed		Baskar. G. - Special Clinic - Reception	10/03/2023
Comp. Dt. : 13/03/2023 Status : Completed								
3142	23030484	Reception	BARCODE PRINTER NOT WORKING - COUNTER NO 4	Madhubalan. S.	COUNTER 4 BARCODE RIBBON CHANGED		Baskar. G. - Special Clinic - Reception	13/03/2023
3143	23030487	Reception	NEED TO CHANGE BARCODE STRICKER FOR CUNTER NO 4 & 5	Harikrishnan. R.	COUNTER 4 & 5 NEW STICKER CHANGED		Baskar. G. - Special Clinic - Reception	13/03/2023
3144	23030504	Reception	NEED TO CHANGE REVISIT STRICKER FOR COUNTER NO 6	Harikrishnan. R.	REVISIT STRICKER CHANGED		Baskar. G. - Special Clinic - Reception	13/03/2023
3145	23030508	Reception	PRINTER NOT WORKING COUNTER NO 9	Selvam. D.	pending job cleared..		Baskar. G. - Special Clinic - Reception	13/03/2023
Comp. Dt. : 14/03/2023 Status : Completed								
3146	23030553	Reception	NEED TO CHANGE BARCODE STRICKER FOR COUNTER NO 4 & 5	Balachandar. A.	COUNTER 4 AND 5 NEW STICKER CHANGED		Baskar. G. - Special Clinic - Reception	14/03/2023
3147	23030567	Reception	NEED TO CHANGE STRICKER & RIBBON FOR COUNTER NO 9	Shafiullah. R.	NEW STICKER AND BARCODE RIBBON CHANGED		Baskar. G. - Special Clinic - Reception	14/03/2023
Comp. Dt. : 15/03/2023 Status : Completed								
3148	23030575	Reception	NEED TO CHANGE STRICKER FOR COUNTER NO 4 & 5	Valamburi. R.	barcode sticker changed		Baskar. G. - Special Clinic - Reception	15/03/2023
3149	23030605	Reception	IN LAPTOP "F1" NOT WORKING	Shafiullah. R.	FUNCTION F1 WORKING		Baskar. G. - Special Clinic - Reception	15/03/2023
3150	23030608	Reception	PRINTER NOT WORKING COUNTER NO 5	Shafiullah. R.	REFIX WAX RIBBON		Baskar. G. - Special Clinic - Reception	15/03/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
3151	23030625	Reception	NEED TO CHANGE STRICKER FOR COUNTER NO 9	Balachandar. A.	STRICKER CHANGED.		Baskar. G. - Special Clinic - Reception	16/03/2023
Comp. Dt. :		17/03/2023						
Status :		Completed						
3152	23030684	Reception	MOUSE NOT WORKING COUNTER NO 2	Balachandar. A.	new usb mouse changed..		Baskar. G. - Special Clinic - Reception	17/03/2023
3153	23030696	Reception	NEED TO CHANGE BARCODE STICKER IN COUNTER NO. 3, 4, 5	Shafiullah. R.	BARCODE STICKER CHANGED		Baskar. G. - Special Clinic - Reception	17/03/2023
3154	23030697	Reception	PRINTER NOT WORKING IN COUNTER NO. 1	Shafiullah. R.	printer working		Baskar. G. - Special Clinic - Reception	17/03/2023
3155	23030732	Reception	NEED TO CHANGE STRICKER & RIBBON FOR COUNTER NO 9	Shafiullah. R.	2 NEWSTRICKER AND 1 WAX RIBBON		Baskar. G. - Special Clinic - Reception	17/03/2023
Comp. Dt. :		18/03/2023						
Status :		Completed						
3156	23030755	Reception	NEED TO CHANGE PRINTER RIBBON FOR COUNTER NO 5	Selvam. D.	Barcode ribbon changed		Baskar. G. - Special Clinic - Reception	18/03/2023
Comp. Dt. :		20/03/2023						
Status :		Completed						
3157	23030809	Reception	NEED TO CHANGE STRICKER FOR COUNTER NO 4 & 5	Harikrishnan. R.	New barcode sticker changed		Baskar. G. - Special Clinic - Reception	20/03/2023
Comp. Dt. :		21/03/2023						
Status :		Completed						
3158	23030836	Reception	BARCODE PRINTER NOT WORKING - COUNTER NO 6	Balachandar. A.	USB CABLE REFIXED		Baskar. G. - Special Clinic - Reception	21/03/2023
3159	23030878	Reception	NEED TO CHANGE BARCODE STRICKER FOR COUNTER NO 8	Madhubalan. S.	12A TONER CHANGED		Baskar. G. - Special Clinic - Reception	21/03/2023
3160	23030887	Reception	NEED TO CHANGE BARCODE STICKER	Harikrishnan. R.	BARCODE 4,5& 6 NEW STRICKER CHANGED		Baskar. G. - Special Clinic - Reception	21/03/2023
Comp. Dt. :		22/03/2023						
Status :		Completed						
3161	23030890	Reception	BARCODE PRINTER NOT WORKING - COUNTER NO 3	Valamburi. R.	printer power cable refix		Baskar. G. - Special Clinic - Reception	22/03/2023
Comp. Dt. :		23/03/2023						
Status :		Completed						


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
3162	23030961	Reception	NEED TO CHANGE BARCODE STICKER IN COUNTER NO. 4 & 5	Madhubalan. S.	COUNTER 4 & 5 NEW STICKER CHANGED		Geetha. J. - Special Clinic - Reception	23/03/2023
Comp. Dt. : 25/03/2023 Status : Completed								
3163	23031039	Reception	NEED TO CHANGE BARCODE STRICKER FOR COUNTER NO 4 & 5	Madhubalan. S.	counter 4 & 5 NEW STICKER CHANGED		Baskar. G. - Special Clinic - Reception	25/03/2023
Comp. Dt. : 27/03/2023 Status : Completed								
3164	23031094	Reception	NEED TO CHANGE STRICKER FOR COUNTER NO 3 & 4	Selvam. D.	New barcode sticker changed		Baskar. G. - Special Clinic - Reception	27/03/2023
3165	23031132	Reception	PRINTER NOT WORKING	Shafiullah. R.	counter 8 refix the toner		Baskar. G. - Special Clinic - Reception	27/03/2023
Comp. Dt. : 29/03/2023 Status : Completed								
3166	23031244	Reception	NEED TO CHANGE "NEW REGISTRATION STRICKER " FOR COUNTER NO 4 & 5	Venkatesh. S.	New barcode sticker changed		Baskar. G. - Special Clinic - Reception	30/03/2023
Comp. Dt. : 30/03/2023 Status : Completed								
3167	23031282	Reception	NEED TO CHANGE PRINTER RIBBON COUNTER NO 4	Venkatesh. S.	PRINTER RIBBON CHANGED.		Baskar. G. - Special Clinic - Reception	30/03/2023
3168	23031295	Reception	NEED TO CHANGE BARCODE IN COUNTER 4 & 5	Venkatesh. S.	BARCODE STICKER CHANGED.		Baskar. G. - Special Clinic - Reception	30/03/2023
Comp. Dt. : 31/03/2023 Status : Completed								
3169	23031357	Reception	IN COUNTER NO 9 MEDPLUS PROBLEM	Jayaraj. J.	medplus working		Baskar. G. - Special Clinic - Reception	31/03/2023
Comp. Dt. : 01/04/2023 Status : Completed								
3170	23040007	Reception	NEED TO CHANGE STRICKER FOR COUNTER NO 4 & 5	Shafiullah. R.	STRICKER CHANGED		Baskar. G. - Special Clinic - Reception	01/04/2023
3171	23040008	Reception	BARCODE PRINTER NOT WORKING COUNTER NO 6 & SYSTEM NOT WORKING COUNTER NO 7	Shafiullah. R.	POWER CABLE REFIXED		Baskar. G. - Special Clinic - Reception	01/04/2023
Comp. Dt. : 03/04/2023 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
3172	23040033	Special Ward - C	NEED TO CHANGE TONER	Selvam. D.	12A TONER CHANGED		Vijai. M. - Medical Records	03/04/2023
3173	23040075	Reception	PRINTER PROBLEM - COUNTER NO 9	Madhubalan. S.	12A TONER CHANGED		Baskar. G. - Special Clinic - Reception	03/04/2023
Comp. Dt. : 04/04/2023		Status : Completed						
3174	23040089	Reception	NEED TO CHANGE BARCODE STRICKER FOR COUNTER NO 4 & 5	Shafiullah. R.	NEW BARCODE STRICKER FOR COUNTER NO 4 & 5		Baskar. G. - Special Clinic - Reception	04/04/2023
3175	23040105	Reception	NEED TO CHANGE BARCODE STRICKER FOR COUNTER NO 4 & 5	Harikrishnan. R.	BARCODE STRICKER FOR COUNTER NO 4 & 5 changed		Baskar. G. - Special Clinic - Reception	04/04/2023
Comp. Dt. : 06/04/2023		Status : Completed						
3176	23040179	Reception	NEED TO CHANGE STRICKER FOR COUNTER NO 3 & 5	Harikrishnan. R.	STRICKER CHANGED		Baskar. G. - Special Clinic - Reception	06/04/2023
3177	23040186	Reception	NEED TO CHANGE STRICKER FOR COUNTER NO 4	Harikrishnan. R.	STRICKER CHANGED		Baskar. G. - Special Clinic - Reception	06/04/2023
Comp. Dt. : 08/04/2023		Status : Completed						
3178	23040221	Reception	NEED TO CHANGE PRINTER RIBBON FOR COUNTER NO 5	Valamburi. R.	Counter 5 barcode ribbon changed		Baskar. G. - Special Clinic - Reception	10/04/2023
Comp. Dt. : 10/04/2023		Status : Completed						
3179	23040283	Reception	NEED TO CHANGE BARCODE STRICKER FOR COUNTER NO 9	Shafiullah. R.	NEW BARCODE STRICKER CHANGED		Baskar. G. - Special Clinic - Reception	10/04/2023
3180	23040288	Reception	NEED TO CHANGE BARCODE STRICKER FOR COUNTER NO 4	Shafiullah. R.	NEW BARCODE STRICKER CHANGED		Baskar. G. - Special Clinic - Reception	10/04/2023
Comp. Dt. : 11/04/2023		Status : Completed						
3181	23040322	Reception	NEED TO CHANGE TONER COUNTER NO 1	Shafiullah. R.	12A TONER CHANGED		Baskar. G. - Special Clinic - Reception	11/04/2023
Comp. Dt. : 15/04/2023		Status : Completed						
3182	23040432	Reception	NEED TO CHANGE BARCODE STRICKER FOR COUNTER NO 4	Madhubalan. S.	COUNTER 4 AND 3 NEW STICKER CHANGED		Baskar. G. - Special Clinic - Reception	15/04/2023
3183	23040444	DIALYSIS NEW UNIT IN 1ST FLOOR	SCANNER NOT WORKING	Selvam. D.	usb cable refixed		Baskar. G. - Special Clinic - Reception	17/04/2023

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 17/04/2023 Status : Completed								
3184	23040519	DIALYSIS NEW UNIT IN 1ST FLOOR	NEED TO CHANGE TONER	Balachandar. A.	toner refixed		Baskar. G. - Special Clinic - Reception	18/04/2023
Comp. Dt. : 19/04/2023 Status : Completed								
3185	23040586	Reception	NEED TO CHANGE BARCODE STRICKER FOR COUNTER NO 4	Jayaraj. J.	BARCODE STRICKER CHANGED		Sudhagar. V. - Special Clinic - Reception	19/04/2023
Comp. Dt. : 20/04/2023 Status : Completed								
3186	23040619	Reception	NEED TO CHANGE STRICKER FOR COUNTER NO 3 & 4	Harikrishnan. R.	New Sticker Changed		Geetha. J. - Special Clinic - Reception	20/04/2023
Comp. Dt. : 25/04/2023 Status : Completed								
3187	23040780	Reception	NEED TO CHANGE BARCODE STRICKER FOR COUNTER NO 3 & 4	Harikrishnan. R.	New Sticker Changed		Geetha. J. - Special Clinic - Reception	25/04/2023
Comp. Dt. : 05/05/2023 Status : Completed								
3188	23050210	Reception	SYSTEM DISPLAY NOT WORKING - COUNTER NO 4	Selvam. D.	SMPS PROBLEM. SMPS CHANGED		Sudhagar. V. - Special Clinic - Reception	06/05/2023
Comp. Dt. : 06/05/2023 Status : Completed								
3189	23050253	DIALYSIS NEW UNIT IN 1ST FLOOR	NEED TO CHANGE TONER	Shafiullah. R.	PRINTER WORKING FINE		Baskar. G. - Special Clinic - Reception	06/05/2023
Comp. Dt. : 08/05/2023 Status : Completed								
3190	23050267	DIALYSIS NEW UNIT IN 1ST FLOOR	SCANNER NOT WORKING	Jayaraj. J.	logic board changed		Baskar. G. - Special Clinic - Reception	22/05/2023
Comp. Dt. : 09/05/2023 Status : Completed								
3191	23050352	SPECIAL CLINIC-1st FLOOR(above Room no. 100)	PRINTER NOT WORKING	Balachandar. A.	printer shared..		Savitha. K. - Special Clinic - Reception	09/05/2023
Comp. Dt. : 17/05/2023 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
3192	23050694	DIALYSIS NEW UNIT IN 1ST FLOOR	NEED TO SHIFT SCANNER FROM RECEPTION TO DIALYSIS I FLOOR	Shafiullah. R.	COUNTER 3 SCANNER REMOVED TO FIX DIALYSIS		Baskar. G. - Special Clinic - Reception	17/05/2023
Comp. Dt. : 19/05/2023 Status : Completed								
3193	23050780	Special Ward - C	PRINTER PAPER JAM & NEED TO CHANGE TONER	Shafiullah. R.	Paper sensor cleaned and refixed		Vijai. M. - Medical Records	22/05/2023
Comp. Dt. : 22/05/2023 Status : Completed								
3194	23050880	DIALYSIS NEW UNIT IN 1ST FLOOR	NEED TO CHANGE TONER	Selvam. D.	88A TONER CHANGED		Baskar. G. - Special Clinic - Reception	22/05/2023
Comp. Dt. : 23/05/2023 Status : Completed								
3195	23050897	DIALYSIS NEW UNIT IN 1ST FLOOR	PRINTER NOT WORKING	Selvam. D.	Replaced Scanner unit and belt drive gear		Baskar. G. - Special Clinic - Reception	13/06/2023
Comp. Dt. : 01/06/2023 Status : Completed								
3196	23060034	Special Ward - C	NEED TO CHANGE TONER	Shafiullah. R.	12A TONER CHANGED		Vijai. M. - Medical Records	01/06/2023
Comp. Dt. : 12/06/2023 Status : Completed								
3197	23060376	DIALYSIS NEW UNIT IN 1ST FLOOR	PROBLEM IN SYSTEM MONITOR	Selvam. D.	VGA cable refixed		Baskar. G. - Special Clinic - Reception	12/06/2023
Comp. Dt. : 15/06/2023 Status : Completed								
3198	23060548	Reception	COUNTER NO-2,NEED TO CHANGE PRINTER TONER	Harikrishnan. R.	12A Toner Changed.		Geetha. J. - Special Clinic - Reception	15/06/2023
Dept Name : Special OPD - Computer Department Comp. Dt. : 18/11/2022 Status : Completed								
3199	22110778	SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	NET CONNECTION PROBLEM	Balachandar. A.	system restarted.		Uma Maheswari. D. - Special OPD	18/11/2022
Comp. Dt. : 22/11/2022 Status : Completed								
3200	22110957	SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	NEED TO CHANGE TONER	Madhubalan. S.	12A TONER CHANGED		Uma Maheswari. D. - Special OPD	22/11/2022
Comp. Dt. : 29/11/2022								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
3201	22111249	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	CHANGE PRINTER TONER	Madhubalan. S.	PRINTER TONER CHANGED		Saranya. S. - Clinical Department	30/11/2022
Comp. Dt. : 07/12/2022								
Status : Completed								
3202	22120279	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	CHANGE BARCODE STICKER	Balachandar. A.	BARCODE STICKER CHANGED		Saranya. S. - Clinical Department	07/12/2022
Comp. Dt. : 16/12/2022								
Status : Completed								
3203	22120764	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	CHANGE PRINTER TONER	Shafiullah. R.	12A TONER CHANGED		Saranya. S. - Clinical Department	16/12/2022
Comp. Dt. : 29/12/2022								
Status : Completed								
3204	22121340	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	CHANGE PRINTER TONER	Balachandar. A.	PRINTER TONER CHANGED		Saranya. S. - Clinical Department	29/12/2022
Comp. Dt. : 07/01/2023								
Status : Completed								
3205	23010317	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	CHANGE BARCODE STICKER	Selvam. D.	BARCODE STICKER CHANGED		Saranya. S. - Clinical Department	09/01/2023
Comp. Dt. : 30/01/2023								
Status : Completed								
3206	23011040	SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	NEED TO CHECK NET CONNECTION - SYSTEM [1NO] NOT WORKING	Murugavel.R	NETWORK WORKING		Uma Maheswari. D. - Special OPD	30/01/2023
3207	23011068	SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	SYSTEM PROBLEM - AGAIN NOT WORKING	Madhubalan. S.	NETWORK CABLE REFIXED		Uma Maheswari. D. - Special OPD	30/01/2023
Comp. Dt. : 14/02/2023								
Status : Completed								
3208	23020523	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	NEED TO CHANGE TONER	Shafiullah. R.	12A TONRE CHANGED		Saranya. S. - Clinical Department	14/02/2023
Comp. Dt. : 14/03/2023								
Status : Completed								
3209	23030524	SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	NEED TO CHECK SYSTEM - PROBLEM	Madhubalan. S.	MONITER SETTING CHANGE		Uma Maheswari. D. - Special OPD	14/03/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 05/04/2023 Status : Completed								
3210	23040157	SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	NEED TO CHANGE TONER	Balachandar. A.	TONER CHANGED		Uma Maheswari. D. - Special OPD	05/04/2023
Comp. Dt. : 11/04/2023 Status : Completed								
3211	23040343	DIALYSIS NEW UNIT IN 1ST FLOOR	MOUSE NOT WORKING	Shafiullah. R.	MOUSE WORKING		Uma Maheswari. D. - Special OPD	18/04/2023
Comp. Dt. : 12/04/2023 Status : Completed								
3212	23040372	SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	NEED TO CHANGE TONER	Jayaraj. J.,Selvam. D.,Prakash. P.	scanner assembly cleaned and refixed		Uma Maheswari. D. - Special OPD	13/04/2023
Comp. Dt. : 15/04/2023 Status : Completed								
3213	23040436	Reception	NEED TO ADD MEDICAL INVENTORY - COUNTAR NO 2	Balachandar. A.	MEDICAL INVENTORY INSTALLED		Uma Maheswari. D. - Special OPD	17/04/2023
Comp. Dt. : 19/04/2023 Status : Completed								
3214	23040597	Reception	NEED TO CHANGE PRINTER RIBBON FOR COUNTER NO 6	Selvam. D.	Barcode ribbon changed		Uma Maheswari. D. - Special OPD	19/04/2023
Comp. Dt. : 20/04/2023 Status : Completed								
3215	23040664	Reception	NEED TO CHECK NET CONNECTION & MOUSE - NOT WORKING AT COUNTER NO 4	Shafiullah. R.	REFIX THE PATCH CARD AND MOUSE WORKING		Uma Maheswari. D. - Special OPD	20/04/2023
3216	23040671	Reception	NEED TO CHANGE STRICKER FOR COUNTER NO 9	Madhubalan. S.	NEW STICKER CHANGED		Uma Maheswari. D. - Special OPD	20/04/2023
Comp. Dt. : 22/04/2023 Status : Completed								
3217	23040692	Reception	NEED TO CHANGE PRINTER RIBBON FOR COUNTER NO 2	Harikrishnan. R.	COUNTER 2 BARCODE RIBBON CHANGED		Uma Maheswari. D. - Special OPD	22/04/2023
Comp. Dt. : 26/04/2023 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
3218	23040848	Reception	NEED TO CHANGE PRINTER RIBBON FOR COUNTER NO 5	Valamburi. R.	WAX RIBBON CHANGED		Uma Maheswari. D. - Special OPD	26/04/2023
3219	23040876	Reception	NEED TO CHANGE STRICKER FOR COUNTER NO 4 & 5	Shafiullah. R.	new stricker 4and5 changed		Uma Maheswari. D. - Special OPD	26/04/2023
Comp. Dt. : 27/04/2023 Status : Completed								
3220	23040906	Reception	NEED TO CHANGE BARCODE STRICKER FOR COUNTER NO 4 & 5	Harikrishnan. R.	New Sticker Changed		Uma Maheswari. D. - Special OPD	27/04/2023
3221	23040911	Reception	NEED TO CHANGE BARCODE FOR COUNTER NO 2	Harikrishnan. R.	New Sticker Change		Uma Maheswari. D. - Special OPD	27/04/2023
3222	23040912	Reception	SYSTEM NOT WORKING COUNTER NO 4	Prakash. P.	system working fine		Uma Maheswari. D. - Special OPD	28/04/2023
3223	23040920	Reception	NEED TO CHANGE TONER FOR COUNTER NO 8	Shafiullah. R.	12A TONER CHANGED		Uma Maheswari. D. - Special OPD	27/04/2023
Comp. Dt. : 28/04/2023 Status : Completed								
3224	23040944	Reception	SYSTEM PROBLEM - COUNTER NO 4	Selvam. D.	os reinstalled and barcode printer installed.		Uma Maheswari. D. - Special OPD	29/04/2023
3225	23040978	Reception	SYSTEM NOT WORKING COUNTER NO 8	Shafiullah. R.	SYSTEM WORKING FINE		Uma Maheswari. D. - Special OPD	29/04/2023
Comp. Dt. : 02/05/2023 Status : Completed								
3226	23050030	Reception	NEED TO CHANGE BARCODE STRICKER FOR COUNTER NO 3 & 4	Selvam. D.	New barcode sticker changed		Uma Maheswari. D. - Special OPD	02/05/2023
Comp. Dt. : 04/05/2023 Status : Completed								
3227	23050121	Reception	BARCODE SCANNER NOT WORKING - COUNTER NO 6	Shafiullah. R.	REFIX THE USB CABLE AND RESTART THE SYSTEM USB DEDICATE		Uma Maheswari. D. - Special OPD	04/05/2023
3228	23050171	Reception	BARCODE STRICKER STUCK - COUNTER NO 3	Valamburi. R.	STICKER CHANGED		Uma Maheswari. D. - Special OPD	04/05/2023
Comp. Dt. : 05/05/2023 Status : Completed								
3229	23050183	Reception	NEED TO CHANGE STRICKER FOR COUNTER NO 6	Prakash. P.	REVISIT STRICKER CHANGED		Uma Maheswari. D. - Special OPD	05/05/2023
3230	23050184	Reception	SYSTEM NOT WORKING COUNTER NO 1	Madhubalan. S.	System restarted working good.		Uma Maheswari. D. - Special OPD	05/05/2023
3231	23050206	Reception	MOUSE & KEYBOARD NOT WORKING - OUNTER NO 2	Shafiullah. R.	REFIXED USB KEYBOARD AND MOUSE NOW WORKING		Uma Maheswari. D. - Special OPD	05/05/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
3232	23050207	Reception	NEED TO CHANGE BARCODE STRICKER FOR COUNTER NO 4 & 5	Harikrishnan. R.	COUNTER 5 BARCODE STRICKER STRUCK AND BARCODE STRICKER CHANGED 4&5		Uma Maheswari. D. - Special OPD	05/05/2023
Comp. Dt. : 06/05/2023 Status : Completed								
3233	23050222	SPECIALITY OT	SYSTEM NOT WORKING - COUNTER NO 6	Selvam. D.	system working fine		Uma Maheswari. D. - Special OPD	06/05/2023
3234	23050230	Reception	PRINTER NOT WORKING COUNTER NO 1	Selvam. D.	SYSTEM RESTART		Uma Maheswari. D. - Special OPD	06/05/2023
3235	23050251	Reception	NEED TO CHANGE PRINTER RIBBON - STUCK - COUNTER NO 5	Shafiullah. R.	PRINTER RIBBON - STUCK REFIX		Uma Maheswari. D. - Special OPD	06/05/2023
3236	23050252	Reception	NEED TO CHANGE TONER FOR COUNTER NO 8	Shafiullah. R.	12A TONER CHANGED		Uma Maheswari. D. - Special OPD	06/05/2023
3237	23050257	Reception	NEED TO CHANGE BARCODE STRICKER FOR COUNTER NO 9	Shafiullah. R.	BARCODE STRICKER FOR COUNTER NO 9 CHANGED -2NOS		Uma Maheswari. D. - Special OPD	06/05/2023
Comp. Dt. : 08/05/2023 Status : Completed								
3238	23050293	Reception	BARCODE STRICKER STUCK - COUNTER NO 3	Harikrishnan. R.	Sticker placed properly.		Uma Maheswari. D. - Special OPD	08/05/2023
3239	23050324	Reception	NEED TO CHANGE BARCODE STRICKER " NEW REGISTRATION" FOR COUNTER NO 3 & 4	Jayaraj. J.	Sticker Changed		Uma Maheswari. D. - Special OPD	08/05/2023
3240	23050337	Reception	NEED TO CHANGE STRICKER FOR COUNTER NO 4	Jayaraj. J.	NEW BARCODE STRICKER CHANGED		Uma Maheswari. D. - Special OPD	08/05/2023
Comp. Dt. : 09/05/2023 Status : Completed								
3241	23050338	Reception	BARCODE STRICKER STUCK - COUNTER NO 5	Madhubalan. S.	NEW STICKER CHANGED		Uma Maheswari. D. - Special OPD	09/05/2023
3242	23050339	Reception	SYSTEM NOT WORKING COUNTER NO 4	Madhubalan. S.	POWER CABLE REFIXED WORKING FINE		Uma Maheswari. D. - Special OPD	09/05/2023
3243	23050346	Reception	NEED TO CHECK BARCODE STRICKER -- STUCK - COUNTER NO 5 [AGAIN]	Shafiullah. R.	REFIX WAXRIBBON		Uma Maheswari. D. - Special OPD	09/05/2023
3244	23050365	Reception	SYSTEM NOT WORKING COUNTER NO 4	Balachandar. A.	SYSTEM WORKING FINE		Uma Maheswari. D. - Special OPD	11/05/2023
3245	23050380	Reception	SYSTEM NOT WORKING COUNTER NO 4	Balachandar. A.	WORKING FINE		Uma Maheswari. D. - Special OPD	11/05/2023
Comp. Dt. : 11/05/2023 Status : Completed								
3246	23050418	Reception	NEED TO CHANGE STRICKER FOR COUNTER NO 4	Valamburi. R.	STRICKER CHANGED		Uma Maheswari. D. - Special OPD	11/05/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
3247	23050423	Reception	NEED TO CHANGE BARCODE STRICKER FOR COUNTER NO 4 & 5	Valamburi. R.	BARCODE STRICKER CHANGED		Uma Maheswari. D. - Special OPD	11/05/2023
3248	23050448	Reception	PRINTER NOT WORKING COUNTER NO 9	Valamburi. R.	usb cable refixed		Uma Maheswari. D. - Special OPD	11/05/2023
Comp. Dt. : 12/05/2023								
Status : Completed								
3249	23050467	Reception	NEED TO CHANGE BARCODE STRICKER & KEY BOARD NOT WORKING COUNTER NO 2	Jayaraj. J.	NEW BARCODE STICKER CHANGED		Uma Maheswari. D. - Special OPD	12/05/2023
3250	23050469	Reception	NEED TO CHANGE STRICKER FOR COUNTER NO 5	Jayaraj. J.	NEW BARCODE STICKER CHANGED		Uma Maheswari. D. - Special OPD	12/05/2023
3251	23050511	Reception	PRINTER NOT WORKING - COUNTER NO 9	Selvam. D.	USB CABLE REFIXED		Uma Maheswari. D. - Special OPD	12/05/2023
3252	23050524	Reception	STRICKER STUCK - COUNTER NO 4	Shafiullah. R.	WAX RIBBON CHANGED		Uma Maheswari. D. - Special OPD	12/05/2023
Comp. Dt. : 15/05/2023								
Status : Completed								
3253	23050557	Reception	NEED TO CHECK PRINTER RIBBON - STUCK COUNTER NO 4 & 5	Prakash. P.	NEW BARCODE STRICKER CHANGED		Uma Maheswari. D. - Special OPD	15/05/2023
3254	23050558	Reception	NEED TO CHANGE BARCODE STRICKER FOR COUNTER NO 4 & 5	Prakash. P.	COUNTER 6 BARCODE STRICKER CHANGED		Uma Maheswari. D. - Special OPD	15/05/2023
3255	23050568	Reception	BARCODE PRINTER PAPER JAM - COUNTER NO 4	Jayaraj. J.	BARCODE RIBBON REFIXED		Uma Maheswari. D. - Special OPD	15/05/2023
3256	23050600	Reception	NEED TO CHANGE TONER FOR COUNTER NO 8	Jayaraj. J.	12A TONER CHANGED		Uma Maheswari. D. - Special OPD	15/05/2023
Comp. Dt. : 16/05/2023								
Status : Completed								
3257	23050628	Reception	NEED TO CHANGE PRINTER RIBBON FOR COUNTER NO 5	Prakash. P.	Bar code Ribbon Changed		Uma Maheswari. D. - Special OPD	17/05/2023
3258	23050638	Reception	NEED TO CHANGE NEW REGISTRATION STRICKER FOR COUNTER NO 4 & 5	Madhubalan. S.	COUNTER 4 & 5 NEW STICKER CHANGED		Uma Maheswari. D. - Special OPD	16/05/2023
3259	23050660	Reception	NEED TO CHANGE BARCODE STRICKER FOR COUNTER NO 9	Selvam. D.	COUNTER NO 9 BARCODE STRICKER CHANGED		Uma Maheswari. D. - Special OPD	17/05/2023
Comp. Dt. : 17/05/2023								
Status : Completed								
3260	23050682	Reception	NEED TO CHANGE REVISIT STRICKER FOR COUNTER NO 6	Shafiullah. R.	REVISIT STRICKER CHANGE		Uma Maheswari. D. - Special OPD	17/05/2023

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
3261	23050683	Reception	NEED TO CHANGE BARCODE STRICKER FOR OUNTER NO 4 & 5	Shafiullah. R.	NEW BARCODE STRICKER COUNTER 5		Uma Maheswari. D. - Special OPD	17/05/2023
3262	23050701	Reception	LAP TOP CABLE NOT WORKING - CC COUNTER	Shafiullah. R.	CABLE REFIXED CHECKED WORKING FINE..		Uma Maheswari. D. - Special OPD	17/05/2023
Comp. Dt. : 18/05/2023 Status : Completed								
3263	23050746	Reception	NEED TO CHANGE PRINTER RIBBON FOR COUNTER NO 4	Shafiullah. R.	WAX RIBBON CHANGED		Uma Maheswari. D. - Special OPD	18/05/2023
3264	23050747	Reception	NEED TO CHANGE NEW REGISTRATION STRICKER FOR OUNTER NO 3 & 5	Shafiullah. R.	NEW STRICKER CHANGED 3&5		Uma Maheswari. D. - Special OPD	18/05/2023
3265	23050774	Reception	NEED TO CHANGE BARCODE STRICKER FOR COUNTER NO 9	Shafiullah. R.	NEW BAR CODE STRICKER 2 NOS GIVEN		Uma Maheswari. D. - Special OPD	18/05/2023
Comp. Dt. : 19/05/2023 Status : Completed								
3266	23050804	Reception	NEED TO CHANGE BARCODE STRICKER FOR COUNTER NO 3 & 5	Harikrishnan. R.	BARCODE STRICKER CHANGED		Uma Maheswari. D. - Special OPD	19/05/2023
3267	23050815	Reception	PRINTER PROBLEM - PAPER JAM AT COUNTER NO 2	Selvam. D.	COUNTER NO 2 PAPER JAM Clear		Uma Maheswari. D. - Special OPD	19/05/2023
Comp. Dt. : 20/05/2023 Status : Completed								
3268	23050843	Reception	DISPLAY PROBLEM IN MEDPLUS REPORT - COUNTER NO 3	Prakash. P.	MEDPLUS REPORT Open Working		Uma Maheswari. D. - Special OPD	20/05/2023
Comp. Dt. : 22/05/2023 Status : Completed								
3269	23050878	Reception	NEED TO CHANGE REVISIT STRICKER FOR COUNTER NO 6	Madhubalan. S.	REVISIT STRICKER 2 NOS		Uma Maheswari. D. - Special OPD	22/05/2023
3270	23050891	Reception	NEED TO CHANGE TONER FOR COUNTER NO 8 & 9	Harikrishnan. R.	12A TONER CHANGED		Uma Maheswari. D. - Special OPD	22/05/2023
Comp. Dt. : 23/05/2023 Status : Completed								
3271	23050904	Reception	NEED TO CHANGE NEW REGISTRATION STRICKER FOR COUNTER NO 2 & 4	Prakash. P.	NEW STRICKER CHANGED 2&4		Uma Maheswari. D. - Special OPD	23/05/2023
3272	23050913	Reception	PRINTER NOT WORKING COUNTER NO 8	Selvam. D.	PICKER ROLLER CHANGED		Uma Maheswari. D. - Special OPD	24/05/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 25/05/2023								
Status : Completed								
3273	23050984	Reception	NEED TO CHANGE RIBBON FOR COUNTER NO 4	Prakash. P.	WAX RIBBON CHANGED		Uma Maheswari. D. - Special OPD	25/05/2023
Comp. Dt. : 26/05/2023								
Status : Completed								
3274	23051044	Reception	NEED TO CHANGE STRICKER FOR COUNTER NO 4 & 5	Madhubalan. S.	COUNTER 4 AND 5 NEW STICKER CHANGED		Uma Maheswari. D. - Special OPD	26/05/2023
Comp. Dt. : 29/05/2023								
Status : Completed								
3275	23051138	Reception	NEED TO CHANGE TONER FOR COUNTER NO 8	Harikrishnan. R.	12A Toner Changed.		Uma Maheswari. D. - Special OPD	29/05/2023
Comp. Dt. : 30/05/2023								
Status : Completed								
3276	23051167	Reception	NEED TO CHANGE RIBBON & NEW REGISTRATION STRICKER FOR COUNTER NO 6	Shafiullah. R.	RIBBON AND STICKER CHANGED		Uma Maheswari. D. - Special OPD	30/05/2023
3277	23051173	Reception	NEED TO REFIX RIBBON - COUNTER NO 5	Shafiullah. R.	RIBBON REFIXED		Uma Maheswari. D. - Special OPD	30/05/2023
Comp. Dt. : 31/05/2023								
Status : Completed								
3278	23051221	Reception	NEED TO CHANGE NEW REGISTRATION STRICKER FOR COUNTER NO 3 & 4	Harikrishnan. R.	New Sticker Changed.		Uma Maheswari. D. - Special OPD	31/05/2023
Comp. Dt. : 01/06/2023								
Status : Completed								
3279	23060008	Reception	NEED TO CHANGE STRICKER FOR COUNTER NO 6	Harikrishnan. R.	Revist Sticker Changed.		Uma Maheswari. D. - Special OPD	01/06/2023
3280	23060048	Reception	NEED TO CHANGE NEW REGISTRATION STRICKER FOR COUNTER NO 4	Shafiullah. R.	NEW STRICKER CHANGED		Uma Maheswari. D. - Special OPD	01/06/2023
Comp. Dt. : 02/06/2023								
Status : Completed								
3281	23060071	Reception	NEED TO CHANGE STRICKER FOR COUNTER NO 5	Shafiullah. R.	NEW STRICKER CHANGED		Uma Maheswari. D. - Special OPD	02/06/2023
Comp. Dt. : 03/06/2023								
Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
3282	23060091	Reception	NEED TO CHANGE STRICKER FOR COUNTER NO 3	Harikrishnan. R.	New sticker Changed.		Uma Maheswari. D. - Special OPD	03/06/2023
Comp. Dt. : 05/06/2023 Status : Completed								
3283	23060154	Reception	SYSTEM PROBLEM - COUNTER NO 8	Shafiullah. R.	SOFTWARE PROBLEM WORKING FINE		Uma Maheswari. D. - Special OPD	05/06/2023
3284	23060160	Reception	NEED TO CHANGE TONER FOR COUNTER NO8	Shafiullah. R.	12A TONER CHANGED		Uma Maheswari. D. - Special OPD	05/06/2023
3285	23060161	Reception	NEED TO CHECK SYSTEM - WHATSUP WEB NOT OPENNED IN COUNTER NO 2	Shafiullah. R.	WHATAPP WEB WORKING		Uma Maheswari. D. - Special OPD	05/06/2023
Comp. Dt. : 06/06/2023 Status : Completed								
3286	23060201	Reception	NEED TO CHANGE NEW REGISTRATION STRICKER FOR COUNTER NO 4 & 5	Prakash. P.	NEW STRICKER FOR COUNTER NO 4 & 5		Uma Maheswari. D. - Special OPD	06/06/2023
Comp. Dt. : 07/06/2023 Status : Completed								
3287	23060234	Reception	NEED TO CHANGE NEW REGISTRATION STRICKER FOR COUNTER NO 4 & 5	Harikrishnan. R.	New Sticker Changed.		Uma Maheswari. D. - Special OPD	07/06/2023
3288	23060249	Reception	NEED TO CHANGE STRICKER FOR COUNTER NO 9	Harikrishnan. R.	NEW STRICEKR CHANGED 2NOS		Uma Maheswari. D. - Special OPD	07/06/2023
Comp. Dt. : 09/06/2023 Status : Completed								
3289	23060312	Reception	NEED TO ADJUST PRINTER RIBBON - STUCK COUNTER NO 5	Jayaraj. J.	BARCODE REFIX THE PRINTER RIBBON		Uma Maheswari. D. - Special OPD	09/06/2023
3290	23060323	Reception	NEED TO CHANGE NEW REGISTRATION STRICKER FOR COUNTER NO 4	Jayaraj. J.	NEW STRICKER CHANGED		Uma Maheswari. D. - Special OPD	09/06/2023
3291	23060337	Reception	SYSTEM NOT WORKING - COUNTER NO 8 & 9	Prakash. P.	COUNTER 9 REFIX THE PATHCARD AND NETWORK WORKING FINE		Uma Maheswari. D. - Special OPD	09/06/2023
Comp. Dt. : 12/06/2023 Status : Completed								
3292	23060384	Reception	NEED TO CHANGE " NEW REGISTRATION STRICKER " FOR COUNTER NO 3 , 4 & 5	Selvam. D.	COUNTER NO 3 , 4 & 5 NEW STRICKER CHANGED		Uma Maheswari. D. - Special OPD	12/06/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 13/06/2023								
Status : Completed								
3293	23060445	Reception	NEED TO CHANGE REVISIT STRICKER FOR COUNTER NO 6	Selvam. D.	REVISIT STRICKER CHANGED		Uma Maheswari. D. - Special OPD	13/06/2023
Comp. Dt. : 14/06/2023								
Status : Completed								
3294	23060500	Reception	NEED TO CHANGE BARCODE STRICKER FOR COUNTER NO 4 & 5	Shafiullah. R.	COUNTER 4&5 BARCODE STRICKER CHANGED		Uma Maheswari. D. - Special OPD	14/06/2023
Comp. Dt. : 15/06/2023								
Status : Completed								
3295	23060550	Reception	NEED TO CHANGE PRINTER RIBBON IN COUNTER NO 4	Shafiullah. R.	WAX BIBBON CHANGED		Uma Maheswari. D. - Special OPD	15/06/2023
Comp. Dt. : 19/06/2023								
Status : Completed								
3296	23060643	Reception	MOUSE NOT WORKING IN COUNTER NO 6	Selvam. D.	Mouse refixed		Uma Maheswari. D. - Special OPD	19/06/2023
3297	23060644	Reception	NEED TO CHANGE NEW REGISTRATION STRICKER FOR COUNTER NO 4 & 5	Selvam. D.	New barcode sticker changed		Uma Maheswari. D. - Special OPD	19/06/2023
Comp. Dt. : 20/06/2023								
Status : Completed								
3298	23060694	Reception	NEED TO CHANGE STRICKER & PRINTER RIBBON FOR COUNTER NO 4	Shafiullah. R.	WAX RIBBON CHANGED STRICKER NOT CHANGE		Uma Maheswari. D. - Special OPD	20/06/2023
Comp. Dt. : 21/06/2023								
Status : Completed								
3299	23060791	Reception	NEED TO CHANGE NEW REGISTRATION STRICKER FOR COUNTER NO 3 & 4	Harikrishnan. R.	New Sticker Changed.		Uma Maheswari. D. - Special OPD	21/06/2023
Comp. Dt. : 22/06/2023								
Status : Completed								
3300	23060801	Reception	NEED TO CHANGE " REVISIT STRICKER " FOR COUNTER NO 6	Prakash. P.	COUNTER 6 REVIST STICKER CHANGED		Uma Maheswari. D. - Special OPD	22/06/2023
3301	23060807	Reception	NEED TO CHANGE " NEW REGISTRATION STRICKER " FOR COUNTER NO 4 & 5	Madhubalan. S.	COUNTER 4 & 5 NEW STICKER CHANGED		Uma Maheswari. D. - Special OPD	22/06/2023
Comp. Dt. : 24/06/2023								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
3302	23060916	Reception	NEED TO CHANGE NEW REGISTRATION STRICKER FOR COUNTER NO 3 & 4	Shafiullah. R.	NEW STRICKER 3&4 CHANGED		Uma Maheswari. D. - Special OPD	24/06/2023
Comp. Dt. : 26/06/2023								
Status : Completed								
3303	23060970	Reception	NEED TO CHANGE BARCODE STRICKER FOR COUNTER NO 6	Balachandar. A.	BARCODE STRICKER CHANGED		Uma Maheswari. D. - Special OPD	26/06/2023
3304	23060979	Reception	NEED TO CHANGE REVISIT STRICKER FOR COUNTER NO 6 & " NEW REGISTRATION STRICKER " FOR COUNTER NO 4 &	Harikrishnan. R.	Sticker Changed		Uma Maheswari. D. - Special OPD	26/06/2023
Comp. Dt. : 27/06/2023								
Status : Completed								
3305	23060994	Reception	NEED TO CHANGE PRINTER RIBBON FOR COUNTER NO 6	Shafiullah. R.	REVISIT STRICKER AND WAX RIBBON CHANGED		Uma Maheswari. D. - Special OPD	27/06/2023
3306	23061003	Reception	NEED TO CHANGE " NEW REGISTRATION STRICKER" FOR COUNTER NO 4 & 5	Jayaraj. J.	New sticker changed		Uma Maheswari. D. - Special OPD	27/06/2023
Comp. Dt. : 28/06/2023								
Status : Completed								
3307	23061078	Reception	NEED TO CHANGE PRINTER RIBBON FOR COUNTER NO 3	Balachandar. A.	PRINTER RIBBON CHANGED		Uma Maheswari. D. - Special OPD	28/06/2023
Comp. Dt. : 30/06/2023								
Status : Completed								
3308	23061093	Reception	NEED TO CHANGE " NEW REGISTRATION" STRICKER FOR COUNTER NO 3 & 4	Shafiullah. R.	3&4 NEW STRICKER CHANGED		Uma Maheswari. D. - Special OPD	30/06/2023
3309	23061103	Reception	SYSTEM NOT WORKING - COUNTER NO 6	Shafiullah. R.	SMPS CHANGED		Uma Maheswari. D. - Special OPD	30/06/2023
3310	23061124	Reception	SYSTEM NOT WORKING - COUNTER NO 8	Prakash. P.	woking fine		Uma Maheswari. D. - Special OPD	30/06/2023
Dept Name : Special Ward - Computer Department								
Comp. Dt. : 02/05/2022								
Status : Completed								
3311	22050004	SPECIAL WARD - A1	SYSTEM NOT WORKING	Balachandar. A.	power cable refixed..		Prithika. V. - Special Ward	02/05/2022
Comp. Dt. : 04/05/2022								
Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
3312	22050066	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	NEED TO CHANGE BARCODE	Prakash. P.	Barcode new Stcker Changed		Elakkiya. S. - Special Ward	04/05/2022
3313	22050088	SPECIAL WARD - A1	SYSTEM NOT WORKING	Prakash. P.	Printer Paper jam clear		Manjula. R. - Special Ward	04/05/2022
3314	22050089	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	NEED TO CHANGE TONER	Jayaraj. J.	Toner Changed		Pushpa. K. - Special Ward	04/05/2022
3315	22050112	Special Ward - A	PRINTER NOT WORKING	Prakash. P.	Printer paper jam cleared		Manjula. R. - Special Ward	05/05/2022
Comp. Dt. : 05/05/2022								
Status : Completed								
3316	22050142	Reception	NEED TO CHANGE BARCODE FOR COUNTER NO 4	Shafiullah. R.	NEW BARCODE STRICKER CHANGED		Pushpa. K. - Special Ward	05/05/2022
Comp. Dt. : 10/05/2022								
Status : Completed								
3317	22050343	SPECIAL WARD - A1	SYSTEM NOT WORKING	Shafiullah. R.	Mother board changed		Kowsalya. A. - Special Ward	13/05/2022
Comp. Dt. : 11/05/2022								
Status : Completed								
3318	22050367	SPECIAL OPD	NEED TO CHANGE BARCODE STICKER	Madhubalan. S.	NEW BARCODE STICKER CHANGED		Elakkiya. S. - Special Ward	11/05/2022
3319	22050371	Special Ward - C	PRINTER NOT WORKING	Madhubalan. S.	PAPER JAM CLEARED		Vinidha. R. - Special Ward	12/05/2022
Comp. Dt. : 19/05/2022								
Status : Completed								
3320	22050720	Special Ward - A	NEED TO CHECK WI FI CONNECTION - NOT WORKING	Valamburi. R.	Device refixed working fine...		Kowsalya. A. - Special Ward	24/05/2022
Comp. Dt. : 30/05/2022								
Status : Completed								
3321	22051089	Special Ward - A	NEED TO CHECK WI FI CONNECTION - NOT WORKING	Selvam. D.	Wifi power reconnect. working fine		Revathi. S. - Special Ward	31/05/2022
3322	22051102	SPECIAL WARD - A1	SYSTEM NOT WORKING	Selvam. D.	System working fine		Manjula. R. - Special Ward	01/06/2022
Comp. Dt. : 31/05/2022								
Status : Completed								
3323	22051133	SPECIAL WARD - A1	PRINTER NOT WORKING	Selvam. D.	12A toner changed		Shalini. S. - Special Ward	01/06/2022
Comp. Dt. : 01/06/2022								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
3324	22060013	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	NEED TO CHANGE BARCODE STRICKER	Madhubalan. S.	BARCODE NEW STRICKER CHANGED		Pushpa. K. - Special Ward	01/06/2022
Comp. Dt. : 02/06/2022								
Status : Completed								
3325	22060065	Special Ward - A	NEED TO CHANGE TONER	Madhubalan. S.	12A TONER CHANGED		Bharathi. R. - Special Ward	02/06/2022
Comp. Dt. : 06/06/2022								
Status : Completed								
3326	22060204	Special Ward - C	PRINTER NOT WORKING	Madhubalan. S.	Toner refixed		Vinidha. R. - Special Ward	06/06/2022
Comp. Dt. : 07/06/2022								
Status : Completed								
3327	22060264	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	NEED TO CHANGE RIBBON & BARCODE	Jayaraj. J.	BARCODE RIBBON AND NEW STICKER CHANGED		Elakkiya. S. - Special Ward	07/06/2022
Comp. Dt. : 13/06/2022								
Status : Completed								
3328	22060436	Special Ward - A	SYSTEM NOT WORKING	Jayaraj. J.	LAN CABLE REFIXED		Ezhilarasi. P. - Special Ward	13/06/2022
Comp. Dt. : 15/06/2022								
Status : Completed								
3329	22060539	Special Ward - A	SYSTEM NOT WORKING	Prakash. P.	CHECKED PROBLEM SLOVED		Ezhilarasi. P. - Special Ward	15/06/2022
3330	22060559	Special Ward - C	U P S BACKUP PROBLEM	Selvam. D.	lithium battery changed		Gayathiri. V. - Special Ward	21/06/2022
3331	22060563	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	NEED TO CHANGE BARCODE STRICKER	Murugavel.R	BARCODE STRICKER CHANGED		Saranya. T. - Special Ward	15/06/2022
Comp. Dt. : 17/06/2022								
Status : Completed								
3332	22060660	Special Ward - A	KEYBOARD NOT WORKING	Selvam. D.	KEYBOARD CABLE REFIXED		Revathi. S. - Special Ward	18/06/2022
Comp. Dt. : 21/06/2022								
Status : Completed								
3333	22060736	Special Ward - A	SYSTEM NOT WORKING	Selvam. D.	Keyboard cleaned and refixed		Ezhilarasi. P. - Special Ward	21/06/2022
Comp. Dt. : 22/06/2022								
Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
3334	22060792	Special Ward - A	KEY BOARD NOT WORKING	Shafiullah. R.	USB REFIX KEYBOARD		Bharathi. R. - Special Ward	22/06/2022
	Comp. Dt. : 23/06/2022							
	Status : Completed							
3335	22060820	Special Ward - A	SYSTEM & KEYBOARD NOT WORKING	Balachandar. A.	New usb keyboard changed...		Revathi. S. - Special Ward	23/06/2022
	Comp. Dt. : 25/06/2022							
	Status : Completed							
3336	22060911	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	NEED TO CHANGE TONER	Selvam. D.	12A TONER CHANGED		Revathi. K. - Special Ward	25/06/2022
3337	22060923	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	NEED TO CHANGE BARCODE	Madhubalan. S.	NEW STICKER CHANGED		Elakkiya. S. - Special Ward	25/06/2022
	Comp. Dt. : 28/06/2022							
	Status : Completed							
3338	22060989	Special Ward - A	NEED TO CHECK WI FI CONNECTION - NOT WORKING	Murugavel.R	RESTART THAN WORKING PROBLEM SLOVED		Revathi. S. - Special Ward	28/06/2022
	Comp. Dt. : 04/07/2022							
	Status : Completed							
3339	22070091	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	NEED TO CHANGE BARCODE STRICKER	Prakash. P.	NEW BARCODE STRICKER		Pushpa. K. - Special Ward	04/07/2022
3340	22070111	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	NEED TO CHANGE PRINTER RIBBON	Selvam. D.	BARCODE RIBBON CHANGED		Pushpa. K. - Special Ward	04/07/2022
	Comp. Dt. : 05/07/2022							
	Status : Completed							
3341	22070142	Special Ward - C	SYSTEM NOT WORKING - FEMALE SIDE	Selvam. D.	UPS serviced and its working fine		Prithika. V. - Special Ward	07/07/2022
	Comp. Dt. : 06/07/2022							
	Status : Completed							
3342	22070209	SPECIAL WARD - A1	NEED TO CHANGE TONER	Shafiullah. R.	12A TONER CHANGED		Manjula. R. - Special Ward	06/07/2022
	Comp. Dt. : 09/07/2022							
	Status : Completed							
3343	22070385	SPECIAL WARD---B	PRINTER NOT WORKING	Madhubalan. S.	SYSTEM RESTATED PRINTER WORKING FINE		Ragavi. P. - Special Ward	09/07/2022
	Comp. Dt. : 11/07/2022							
	Status : Completed							


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
3344	22070426	Special Ward - C	NEED TO CHANGE TONER	Shafiullah. R.	COMPLAIND CLOSED TONER CHANED		Sangeetha. S. - Special Ward	12/07/2022
3345	22070433	SPECIAL WARD---B	PRINTER NOT WORKING	Selvam. D.	printer working		Ragavi. P. - Special Ward	12/07/2022
Comp. Dt. : 12/07/2022 Status : Completed								
3346	22070467	Special Ward - C	NEED TO CHANGE TONER	Shafiullah. R.	12A TONER CHANGED		Vinidha. R. - Special Ward	12/07/2022
Comp. Dt. : 13/07/2022 Status : Completed								
3347	22070489	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	SYSTEM NOT WORKING	Shafiullah. R.	System working fine		Sangeetha. C. - Special Ward	13/07/2022
3348	22070520	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	NEED TO CHANGE TONER	Shafiullah. R.	TONER CHANGED		Pushpa. K. - Special Ward	14/07/2022
Comp. Dt. : 18/07/2022 Status : Completed								
3349	22070644	SPECIAL WARD---B	PRINTER NOT WORKING	Balachandar. A.	Toner refixed		Kaviya. M. - Special Ward	18/07/2022
3350	22070678	SPECIAL WARD - A1	NEED TO CHANGE TONER	Valamburi. R.	PRINTER WORKING FINE		Ahilandeswari. B. - Special Ward	18/07/2022
Comp. Dt. : 29/07/2022 Status : Completed								
3351	22071061	Special Ward - C	PRINTER NOT WORKING	Jayaraj. J.	paper jam cleared.		Hemachandra. P. - Special Ward	29/07/2022
3352	22071064	Special Ward - C	NEED TO CHANGE TONER	Jayaraj. J.	Paper jam cleared and tested the printer working fine.		Shalini. S. - Special Ward	29/07/2022
Comp. Dt. : 01/08/2022 Status : Completed								
3353	22080008	SPECIAL WARD - A1	NEED TO CHANGE TONER	Murugavel.R	12 A C TONER CHANGED		Prithika. V. - Special Ward	01/08/2022
3354	22080028	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	NEED TO CHANGE BARCODE STRICKER	Valamburi. R.	NEW CHANGED CHANGED		Saranya. T. - Special Ward	01/08/2022
Comp. Dt. : 02/08/2022 Status : Completed								
3355	22080062	Special Ward - C	PRINTER NOT WORKING	Balachandar. A.	system restarted		Abirami. G. - Special Ward	02/08/2022
Comp. Dt. : 04/08/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
3356	22080179	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	NEED TO CHANGE TONER	Madhubalan. S.	12A TONER CHANGED		Saranya. T. - Special Ward	04/08/2022
Comp. Dt. :		08/08/2022						
Status :		Completed						
3357	22080272	SPECIAL WARD---B	PRINTER NOT WORKING	Madhubalan. S.	PRINTER WORKING FINE		Ragavi. P. - Special Ward	08/08/2022
3358	22080278	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	NEED TO CHANGE BARCODE STRICKER	Madhubalan. S.	NEW STICKER CHANGED		Saranya. T. - Special Ward	08/08/2022
Comp. Dt. :		09/08/2022						
Status :		Completed						
3359	22080327	Special Ward - C	NEED TO CHANGE TONER	Jayaraj. J.	12A TONER CHANGED		Sangeetha. S. - Special Ward	09/08/2022
Comp. Dt. :		17/08/2022						
Status :		Completed						
3360	22080533	SPECIAL WARD A1-FOURTH FLOOR	PRINTER NOT WORKING	Madhubalan. S.	PRINTER SETTING CHANGED		Manjula. R. - Special Ward	17/08/2022
3361	22080551	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	CHANGE BARCODE STICKER	Selvam. D.	new barcode sticker changed		Pushpa. K. - Special Ward	18/08/2022
Comp. Dt. :		20/08/2022						
Status :		Completed						
3362	22080655	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	NEED TO CHECK BARCODE PRINTER - STUCK - NEED URGENT SERVICE	Balachandar. A.	settings changed		Elakkiya. S. - Special Ward	20/08/2022
Comp. Dt. :		23/08/2022						
Status :		Completed						
3363	22080763	SPECIAL WARD - A1	NEED TO CHECK SYSTEM MONITOR - PROBLEM	Selvam. D.	System restarts and monitor setting done		Shalini. S. - Special Ward	23/08/2022
Comp. Dt. :		25/08/2022						
Status :		Completed						
3364	22080854	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	NEED TO CHANGE BARCODE STRICKER	Selvam. D.	BARCODE STRICKER CHANGED		Elakkiya. S. - Special Ward	25/08/2022
Comp. Dt. :		26/08/2022						
Status :		Completed						
3365	22080886	Special Ward - C	SYSTEM NOT WORKING [FEMALE SIDE]	Shafiullah. R.	UPS changed		Abirami. G. - Special Ward	13/10/2022
3366	22080890	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	NEED TO CHANGE RIBBON FOR BARCODE PRINTER	Shafiullah. R.	WAX BARCODE RIBBON CHANGED		Sangeetha. C. - Special Ward	26/08/2022

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHAL KUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 27/08/2022 Status : Completed								
3367	22080930	Special Ward - A	NEED TO CHANGE TONER	Balachandar. A.	TONER CHANGED		Bharathi. R. - Special Ward	27/08/2022
Comp. Dt. : 02/09/2022 Status : Completed								
3368	22090069	SPECIAL WARD---B	PRINTER NOT WORKING	Valamburi. R.	working fine		Hemachandra. P. - Special Ward	02/09/2022
Comp. Dt. : 06/09/2022 Status : Completed								
3369	22090223	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	NEED TO CHANGE BARCODE STRICKER	Selvam. D.	New barcode barcode sticker changed		Elakkiya. S. - Special Ward	06/09/2022
Comp. Dt. : 09/09/2022 Status : Completed								
3370	22090372	SPECIAL OPD	COMPUTER NOT WORKING	Valamburi. R.	power cable refixed		Pushpa. K. - Special Ward	12/09/2022
Comp. Dt. : 15/09/2022 Status : Completed								
3371	22090574	SPECIAL WARD---B	NEED TO PRIENT NOT WORKING	Selvam. D.	Toner top cover damaged by user.We are not received any letter from user end		Reena. N. - Special Ward	21/11/2022
3372	22090616	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	NEED TO CHANGE BARCODE STRICKER	Balachandar. A.	BARCODE STRICKER CHANGED		Pushpa. K. - Special Ward	15/09/2022
Comp. Dt. : 19/09/2022 Status : Completed								
3373	22090705	SPECIAL WARD - A1	NEED TO CHANGE TONER	Shafiullah. R.	12A TONER CHANGED		Manjula. R. - Special Ward	19/09/2022
Comp. Dt. : 22/09/2022 Status : Completed								
3374	22090859	Special Ward - A	SYSTEM PROBLEM - NETWORK FAILURE	Valamburi. R.	Network cable refixed		Kowsalya. A. - Special Ward	22/09/2022
Comp. Dt. : 23/09/2022 Status : Completed								
3375	22090915	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	NEED TO CHANGE BARCODE STRICKER	Valamburi. R.	BARCODE STRICKER CHANGED		Elakkiya. S. - Special Ward	23/09/2022
Comp. Dt. : 27/09/2022								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
3376	22091092	Special Ward - C	NEED TO CHANGE TONER	Jayaraj. J.	12a TONER CHANGED		Sangeetha. S. - Special Ward	27/09/2022
Comp. Dt. : 30/09/2022								
Status : Completed								
3377	22091195	Special Ward - C	PRINTER NOT WORKING	Selvam. D.	paper jam cleared		Archanadevi. A. - Special Ward	30/09/2022
Comp. Dt. : 03/10/2022								
Status : Completed								
3378	22100017	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	NEED TO CHANGE BARCODE STRICKER	Shafiullah. R.	MEW BARCODE STICKER CHANGED		Sangeetha. C. - Special Ward	03/10/2022
Comp. Dt. : 08/10/2022								
Status : Completed								
3379	22100188	SPECIAL WARD - A1	SYSTEM NOT WORKING	Jayaraj. J.	RAM CLEAN AND REFIXED		Ragavi. P. - Special Ward	08/10/2022
Comp. Dt. : 11/10/2022								
Status : Completed								
3380	22100267	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	NEED TO CHANGE TONER	Selvam. D.	TONER CHANGED		Elakkiya. S. - Special Ward	11/10/2022
Comp. Dt. : 12/10/2022								
Status : Completed								
3381	22100368	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	NEED TO CHANGE BARCODE STRICKER	Selvam. D.	New barcode sticker changed		Sangeetha. C. - Special Ward	12/10/2022
Comp. Dt. : 14/10/2022								
Status : Completed								
3382	22100463	SPECIAL WARD - A1	SYSTEM NOT WORKING	Shafiullah. R.	LITTUM UPS BATTERY CHANGED		Sivapriya. P. - Special Ward	14/10/2022
Comp. Dt. : 19/10/2022								
Status : Completed								
3383	22100652	SPECIAL WARD - A1	NEED TO CHANGE TONER	Shafiullah. R.	12A TONER CHANGED		Manjula. R. - Special Ward	20/10/2022
Comp. Dt. : 21/10/2022								
Status : Completed								
3384	22100710	Special Ward - C	MEDPLUS NOT WORKING	Prakash. P.	network issue solved..		Divya. M. - Special Ward	22/10/2022
Comp. Dt. : 22/10/2022								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
3385	22100761	SPECIAL WARD A1-FOURTH FLOOR	SYSTEM NOT WOKRING	Madhubalan. S.	POWER CABLE REFIXED		Manjula. R. - Special Ward	22/10/2022
Comp. Dt. : 27/10/2022								
Status : Completed								
3386	22100843	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	NEED TO CHANGE PRINTER RIBBON	Balachandar. A.	Barcode ribbon changed		Elakkiya. S. - Special Ward	27/10/2022
Comp. Dt. : 03/11/2022								
Status : Completed								
3387	22110111	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	CHANGE PRINTER TONER	Selvam. D.	PRINTER TONER CHANGED		Elakkiya. S. - Special Ward	04/11/2022
Comp. Dt. : 04/11/2022								
Status : Completed								
3388	22110157	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	CHANGE BARCODE STICKER	Balachandar. A.	BARCODE STICKER CHANGED		Sangeetha. C. - Special Ward	04/11/2022
Comp. Dt. : 11/11/2022								
Status : Completed								
3389	22110448	SPECIAL WARD A1-FOURTH FLOOR	SYSTEM NOT POWER ON	Shafiullah. R.	NO DISPLAY RAM CLEAN AND REFIXED		Manjula. R. - Special Ward	11/11/2022
3390	22110465	SPECIAL WARD A THIRD FLOOR	CHANGE PRINTER TONER	Madhubalan. S.	12A TONER CHANGED		Bharathi. R. - Special Ward	11/11/2022
Comp. Dt. : 15/11/2022								
Status : Completed								
3391	22110575	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	NEED TO CHANGE BARCODE STICKER	Jayaraj. J.	NEW BARCODE STRICKER CHANGED		Revathi. K. - Special Ward	15/11/2022
Comp. Dt. : 18/11/2022								
Status : Completed								
3392	22110761	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	NEED TO CHECK BAR CODE PRINTER MACHINE - NOT WORKING	Prakash. P.	power cable refixed		Elakkiya. S. - Special Ward	18/11/2022
Comp. Dt. : 21/11/2022								
Status : Completed								
3393	22110868	SPECIAL WARD A1-FOURTH FLOOR	CHANGE PRINTER TONER	Shafiullah. R.	12A toner changed		Prithika. V. - Special Ward	21/11/2022
Comp. Dt. : 22/11/2022								
Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
3394	22110951	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	NEED TO CHANGE BARCODE STICKER	Shafiullah. R.	NEW BARCODE STICKER CHANGED		Elakkiya. S. - Special Ward	22/11/2022
Comp. Dt. : 29/11/2022 Status : Completed								
3395	22111213	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	NEED TO CHANGE BARCODE STICKER	Balachandar. A.	BARCODE STICKER CHANGED		Elakkiya. S. - Special Ward	30/11/2022
Comp. Dt. : 03/12/2022 Status : Completed								
3396	22120144	SPECIAL WARD - A1	PRINTER NOT WORKING	Selvam. D.	PRINT QUE CLEARED		Manjula. R. - Special Ward	06/12/2022
Comp. Dt. : 05/12/2022 Status : Completed								
3397	22120214	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	BARCODE PRINTER PRINTING AUTOMATICALLY	Valamburi. R.	PRINT PENDIND CLEARED		Elakkiya. S. - Special Ward	05/12/2022
Comp. Dt. : 12/12/2022 Status : Completed								
3398	22120497	SPECIAL WARD---B	CPU NOT WORKING	Jayaraj. J.	STANDBY SYSTEM GIVEN		Reena. N. - Special Ward	22/12/2022
Comp. Dt. : 15/12/2022 Status : Completed								
3399	22120726	Special Ward - C	PRINTER NOT WORKING	Shafiullah. R.	PRINTER WORKING		Manjula. R. - Special Ward	22/12/2022
Comp. Dt. : 16/12/2022 Status : Completed								
3400	22120777	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	NEED TO CHANGE BARCODE	Prakash. P.	WAX RIBBON CHANGED		Elakkiya. S. - Special Ward	16/12/2022
3401	22120784	Special Ward - A	SYSTEM NOT WORKING	Shafiullah. R.	REFIX THE PATCH CARD		Bharathi. R. - Special Ward	16/12/2022
Comp. Dt. : 17/12/2022 Status : Completed								
3402	22120801	SPECIAL WARD A THIRD FLOOR	SYSTEM NOT WORKING	Madhubalan. S.	NETWORK CABLE REFIXED MEDPLUS WORKING FINE		Bharathi. R. - Special Ward	17/12/2022
Comp. Dt. : 22/12/2022 Status : Completed								
3403	22121001	Special Ward - C	NEED TO CHANGE TONER	Jayaraj. J.	12A TONER CHANGED		Abirami. G. - Special Ward	22/12/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
3404	22121003	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	NEED TO CHANGE BARCODE STICKER	Balachandar. A.	BARCODE STICKER CHANGED		Elakkiya. S. - Special Ward	22/12/2022
Comp. Dt. : 02/01/2023 Status : Completed								
3405	23010018	SPECIAL WARD -C IN FOURTH FLOOR	SYSTEM NEED TO BE REASSAMBLE	Shafiullah. R.	REFIX SYSTEM		Muthulakshmi. A. - Special Ward	02/01/2023
Comp. Dt. : 05/01/2023 Status : Completed								
3406	23010205	SPECIAL WARD A1-FOURTH FLOOR	SYSTEM NO POWER ON	Selvam. D.	Ram cleaned and refixed		Sivapriya. P. - Special Ward	05/01/2023
Comp. Dt. : 12/01/2023 Status : Completed								
3407	23010504	SPECIAL WARD---B	SYSTEM NETWORK FAILURE	Jayaraj. J.	SYSTEM RESTARED		Prithika. V. - Special Ward	12/01/2023
3408	23010510	SPECIAL WARD A THIRD FLOOR	CHANGE PRINTER TONER	Jayaraj. J.	12A TONER CHANGED		Gayathri. P. - Special Ward	12/01/2023
Comp. Dt. : 19/01/2023 Status : Completed								
3409	23010688	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	NEED TO CHANGE RIBBON FOR BARCODE PRINTER	Balachandar. A.	BARCODE PRINTER RIBBON CHANGED		Elakkiya. S. - Special Ward	20/01/2023
Comp. Dt. : 20/01/2023 Status : Completed								
3410	23010727	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	BARCODE MACHINE NOT WORKING	Madhubalan. S.	BARCODE RIBBON JAM. ROIBBON CLEAR		Elakkiya. S. - Special Ward	20/01/2023
Comp. Dt. : 23/01/2023 Status : Completed								
3411	23010843	SPECIAL OPD	NEED TO CHANGE TONER	Selvam. D.	12A TONER CHANGED		Pushpa. K. - Special Ward	23/01/2023
Comp. Dt. : 24/01/2023 Status : Completed								
3412	23010870	SPECIAL WARD - A1	SYSTEM NOT WORKING	Jayaraj. J.	WORKING FINE		Manjula. R. - Special Ward	24/01/2023
Comp. Dt. : 27/01/2023 Status : Completed								
3413	23010986	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	NEED TO CHANGE BARCODE STICKER	Shafiullah. R.	NEW BARCODE STICKER CHANGED		Sangeetha. C. - Special Ward	27/01/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 28/01/2023								
Status : Completed								
3414	23011000	SPECIAL WARD---B	NEED TO CHANGE TONER	Shafiullah. R.	12A TONER CHANGED		Sangeetha. S. - Special Ward	28/01/2023
Comp. Dt. : 06/02/2023								
Status : Completed								
3415	23020160	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	NEED TO CHANGE BARCODE STRICKER	Selvam. D.	New barcode sticker changed		Saranya. T. - Special Ward	06/02/2023
Comp. Dt. : 15/02/2023								
Status : Completed								
3416	23020566	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	NEED TO CHANGE BARCODE STRICKER	Madhubalan. S.	12A TONER CHANGED		Elakkiya. S. - Special Ward	15/02/2023
Comp. Dt. : 16/02/2023								
Status : Completed								
3417	23020655	Special Ward - A	SYSTEM NOT WORKING	Madhubalan. S.	System Working Fine		Ragavi. P. - Special Ward	16/02/2023
Comp. Dt. : 22/02/2023								
Status : Completed								
3418	23020876	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	NEED TO CHANGE BARCODE STICKER	Valamburi. R.	New barcode sticker changed		Saranya. T. - Special Ward	22/02/2023
Comp. Dt. : 02/03/2023								
Status : Completed								
3419	23030081	SPECIAL OPD	NEED TO CHANGE BARCODE STRICKER	Shafiullah. R.	NEW BARCODE STRICKER CHANGED		Revathi. K. - Special Ward	02/03/2023
Comp. Dt. : 06/03/2023								
Status : Completed								
3420	23030213	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	PROBLEM -IN BARCODE RIBBON	Shafiullah. R.	WAX RIBBON CHANGED		Revathi. K. - Special Ward	06/03/2023
3421	23030231	Special Ward - C	PRINTER PAPER JAM	Shafiullah. R.	paper jam clear		Abirami. G. - Special Ward	06/03/2023
Comp. Dt. : 10/03/2023								
Status : Completed								
3422	23030396	Paediatrics - Ward 310	SYSTEM NETWORK FAILURE	Selvam. D.	patch cable refixed		Abirami. G. - Special Ward	10/03/2023
3423	23030425	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	NEED TO CHANGE BARCODE STRICKER	Jayaraj. J.	New barcode sticker changed		Elakkiya. S. - Special Ward	10/03/2023

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
3424	23030437	Special Ward - A	NEED TO CHANGE TONER	Madhubalan. S.	12A TONER CHANGED		Gayathri. P. - Special Ward	10/03/2023
		Comp. Dt. : 16/03/2023 Status : Completed						
3425	23030634	SPECIAL WARD - A1	NEED TO CHANGE TONER	Balachandar. A.	TONER CHANGED		Manjula. R. - Special Ward	16/03/2023
3426	23030658	SPECIAL WARD - A1	SYSTEM NOT WORKING	Selvam. D.	ups reset done and fixed		Sivapriya. P. - Special Ward	17/03/2023
		Comp. Dt. : 18/03/2023 Status : Completed						
3427	23030754	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	NEED TO CHANGE BARCODE STRICKER	Selvam. D.	New barcode sticker changed		Sangeetha. C. - Special Ward	18/03/2023
		Comp. Dt. : 23/03/2023 Status : Completed						
3428	23030945	SPECIAL WARD - A1	SYSTEM NOT WORKING	Venkatesh. S.	MONITOR VGA CABLE REFIXED		Manjula. R. - Special Ward	23/03/2023
		Comp. Dt. : 27/03/2023 Status : Completed						
3429	23031108	Paediatrics - Ward 310	NEED TO CHANGE TONER	Shafiullah. R.	TONER NOT CHANGED		Ahilandeswari. B. - Special Ward	27/03/2023
		Comp. Dt. : 05/04/2023 Status : Completed						
3430	23040158	SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	NEED TO REPLACE SYSTEM FROM IN OFFICE TO OUT OFFICE	Balachandar. A.	12A TONER CHANGED		Dhatchayani.N. - Special Ward	05/04/2023
		Comp. Dt. : 06/04/2023 Status : Completed						
3431	23040173	Paediatrics - Ward 309	NEED TO CHANGE TONER	Harikrishnan. R.	12A Toner Change		Hemachandra. P. - Special Ward	06/04/2023
		Comp. Dt. : 08/04/2023 Status : Completed						
3432	23040228	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	NEED TO CHECK PRINTER TONER - PROBLEM	Balachandar. A.	12A TONER CHANGED		Elakkiya. S. - Special Ward	08/04/2023
		Comp. Dt. : 15/04/2023 Status : Completed						
3433	23040433	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	NEED TO CHANGE BARCODE STRICKER	Madhubalan. S.	NEW STICKER CHANGED		Elakkiya. S. - Special Ward	15/04/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 25/04/2023								
Status : Completed								
3434	23040797	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	BARCODE STRICKER STUCK	Shafiullah. R.	BARCODE PRINTER WORKING		Saranya. T. - Special Ward	25/04/2023
Comp. Dt. : 26/04/2023								
Status : Completed								
3435	23040836	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	SYSTEM NOT WORKING - PROBLEM IN CABLE CONNECTION	Jayaraj. J.	SYSTEM WORKING FINE		Elakkiya. S. - Special Ward	26/04/2023
3436	23040851	SPECIAL WARD - A1	SYSTEM NOT WORKING	Shafiullah. R.	REFIX THE NETWORK CABLE		Shalini. S. - Special Ward	26/04/2023
Comp. Dt. : 27/04/2023								
Status : Completed								
3437	23040889	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	PROBLEM IN BARCODE READER	Shafiullah. R.	BARCODE NEW STRICKER AND WAX RIBBON		Elakkiya. S. - Special Ward	27/04/2023
Comp. Dt. : 03/05/2023								
Status : Completed								
3438	23050077	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	SYSTEM NOT WORKING	Jayaraj. J.	system working fine		Elakkiya. S. - Special Ward	04/05/2023
Comp. Dt. : 12/05/2023								
Status : Completed								
3439	23050491	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	PRINTER NOT WORKING	Prakash. P.	Printer Paper Jam ,Printer Working		Elakkiya. S. - Special Ward	12/05/2023
3440	23050501	Special Ward - A	NEED TO CHANGE TONER	Shafiullah. R.	SOLINOD SWITCH SERVICED		Prithika. V. - Special Ward	12/05/2023
Comp. Dt. : 19/05/2023								
Status : Completed								
3441	23050806	Paediatrics - Ward 309	SYSTEM NOT WORKING - [MALE MEDICAL 309]	Prakash. P.	SYSTEM is Working		Bhuvaneswari. R. - Special Ward	19/05/2023
Comp. Dt. : 22/05/2023								
Status : Completed								
3442	23050888	Paediatrics - Ward 309	PRINTER NOT WORKING [MALE MEDICAL 309]	Jayaraj. J.	PAPER SENSOR CLEAN REFIXED		Hemachandra. P. - Special Ward	24/05/2023
Comp. Dt. : 23/05/2023								
Status : Completed								
3443	23050903	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	NEED TO CHANGE BARCODE STRICKER	Prakash. P.	BARCODE STRICKER CHANGED		Elakkiya. S. - Special Ward	23/05/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 24/05/2023 Status : Completed								
3444	23050966	Paediatrics - Ward 310	SYSTEM NOT WORKING [FEMALE MEDICAL 310]	Jayaraj. J.	UPS POWER CABLE REFIXED		Kaviya. M. - Special Ward	24/05/2023
Comp. Dt. : 25/05/2023 Status : Completed								
3445	23050994	Special Ward - A	PRINTER NOT WORKING	Madhubalan. S.	TONER REFIXED WORKING FINE		Bharathi. R. - Special Ward	25/05/2023
Comp. Dt. : 30/05/2023 Status : Completed								
3446	23051191	SPECIAL WARD - A1	NEED TO CHANGE TONER	Selvam. D.	12A toner changed		Manjula. R. - Special Ward	30/05/2023
Comp. Dt. : 31/05/2023 Status : Completed								
3447	23051235	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	NEED TO CHANGE BARCODE STRICKER	Selvam. D.	BARCODE STRICKER CHANGED		Elakkiya. S. - Special Ward	01/06/2023
Comp. Dt. : 05/06/2023 Status : Completed								
3448	23060130	SPECIAL WARD - A1	SYSTEM NOT WORKING	Harikrishnan. R.	UPS Check and Connected.		Manjula. R. - Special Ward	05/06/2023
Comp. Dt. : 20/06/2023 Status : Completed								
3449	23060701	Paediatrics - Ward 309	SYSTEM NOT WORKING [MALE MEDICAL 309]	Prakash. P.	power cable refixed		Hemachandra. P. - Special Ward	20/06/2023
3450	23060713	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	NEED TO CHANGE BARCODE STRICKER	Prakash. P.	New barcode sticker changed		Elakkiya. S. - Special Ward	20/06/2023
Comp. Dt. : 22/06/2023 Status : Completed								
3451	23060806	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	BARCODE STRICKER - STUCK	Prakash. P.	barcode Ribbon refixed		Elakkiya. S. - Special Ward	22/06/2023
Comp. Dt. : 23/06/2023 Status : Completed								
3452	23060843	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	NEED TO CHANGE BARCODE STRICKER	Balachandar. A.	New barcode sticker changed		Sangeetha. C. - Special Ward	23/06/2023
3453	23060878	SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	NEED C P U REPALCE [PLACE CHANGE]	Selvam. D.	SYSTEM REPLACED		Dhatchayani. N. - Special Ward	24/06/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 28/06/2023 Status : Completed								
3454	23061050	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	NEED TO CHANGE BAR CODE STRICKER	Selvam. D.,Shafiullah. R.,Prakash. P.	New barcode sticker changed		Elakkiya. S. - Special Ward	28/06/2023
Dept Name : Super Speciality OPD - Computer Department Comp. Dt. : 16/06/2023 Status : Completed								
3455	23060585	GASTROENTROLOGY OPD-2ND FLOOR	SYSTEM NOT WORKING	Balachandar. A.	power cable refixed		Kanchana. A. - Super Speciality OPD	19/06/2023
Dept Name : Surgical Oncology - Computer Department Comp. Dt. : 21/07/2022 Status : Completed								
3456	22070800	ONCOLOGY DEPT-2ND FLOOR-SPECIAL OPD	PRINTER NOT WORKING - PAPER JAM	Selvam. D.	printer working fine		Baghyalakshmi. M. - Surgical Oncology	21/07/2022
Comp. Dt. : 29/07/2022 Status : Completed								
3457	22071071	Orthopaedics - OPD	SYSTEM NOT WORKING	Jayaraj. J.	SYSTEM WORKING FINE		Dhivya Bharathi. P. - Surgical Oncology	29/07/2022
Comp. Dt. : 17/10/2022 Status : Completed								
3458	22100533	ONCOLOGY DEPT-2ND FLOOR-SPECIAL OPD	SYSTEM NOT WORKING	Shafiullah. R.	MED PLUS PROBLEM REFIX THE PATCH CARD AND ANOTHER SYSTEM MOUSE REFIX		Dhivya Bharathi. P. - Surgical Oncology	17/10/2022
Comp. Dt. : 18/10/2022 Status : Completed								
3459	22100578	ONCOLOGY DEPT-2ND FLOOR-SPECIAL OPD	MOUSE NOT WORKING	Balachandar. A.	SYSTEM RESTART MOUSE WORKING FINE		Dhivya Bharathi. P. - Surgical Oncology	18/10/2022
Comp. Dt. : 05/11/2022 Status : Completed								
3460	22110175	ONCOLOGY DEPT-2ND FLOOR-SPECIAL OPD	MEDPLUS SOFTWARE ISSUE	Selvam. D.	MEDPLUS SOFTWARE ISSUE INSTALLED		Dhivya Bharathi. P. - Surgical Oncology	07/11/2022
Comp. Dt. : 10/03/2023 Status : Completed								
3461	23030421	ONCOLOGY DEPT-2ND FLOOR-SPECIAL OPD	NEED TO CHANGE TONER	Selvam. D.	88A toner changed		Dhivya Bharathi. P. - Surgical Oncology	10/03/2023
Comp. Dt. : 12/04/2023								

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
3462	23040387	ONCOLOGY DEPT-2ND FLOOR-SPECIAL OPD	NEED TO CHANGE TONER	Selvam. D.	12a toner changed		Dhivya Bharathi. P. - Surgical Oncology	13/04/2023
Comp. Dt. : 07/06/2023								
Status : Completed								
3463	23060238	Oncology	SYSTEM NOT WORKING [OPD 212]	Shafiullah. R.	UPS CONNECT NOW WORKING FINE		Dhivya Bharathi. P. - Surgical Oncology	07/06/2023
Dept Name : TB & CHEST - Computer Department								
Comp. Dt. : 02/06/2022								
Status : Completed								
3464	22060086	TB & Chest OPD	NEED TO CHANGE TONER	Selvam. D.	802 cartridge changed		Kirubasankar. E. - TB & CHEST	02/06/2022
Comp. Dt. : 04/06/2022								
Status : Completed								
3465	22060169	TB & Chest OPD	SYSTEM NOT WORKING	Shafiullah. R.	SYSTEM WORKING FINE		Kirubasankar. E. - TB & CHEST	04/06/2022
Comp. Dt. : 30/08/2022								
Status : Completed								
3466	22081038	TB & Chest OPD	SYSTEM NOT WORKING	Balachandar. A.	Ram refixed and tested the system working		Kirubasankar. E. - TB & CHEST	01/09/2022
Comp. Dt. : 10/09/2022								
Status : Completed								
3467	22090398	TB & Chest OPD	SYSTEM NOT WORKING	Shafiullah. R.	H61 MOTHERBOARD CHANGED, SYSTEM WORKING FINE..		Kirubasankar. E. - TB & CHEST	12/09/2022
Comp. Dt. : 28/09/2022								
Status : Completed								
3468	22091126	TB & Chest OPD	NEED TO REFIL PRINTER INK	Balachandar. A.	PRINTER INK REFILED		Kirubasankar. E. - TB & CHEST	28/09/2022
Comp. Dt. : 06/10/2022								
Status : Completed								
3469	22100110	TB & Chest OPD	SYSTEM NOT WORKING	Selvam. D.	Old system problem,new acer system changed..		Vigneshwaran. S. - TB & CHEST	08/10/2022
Comp. Dt. : 03/11/2022								
Status : Completed								
3470	22110050	TB & Chest OPD	NEED TO CHANGE PRINTER CARTRIDGE	Jayaraj. J.	802 black cartridge changed		Kirubasankar. E. - TB & CHEST	03/11/2022
Comp. Dt. : 05/12/2022								

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
3471	22120186	TB & Chest OPD	SYSTEM PROBLEM	Shafiullah. R.	NEW SMPS CHANGED		Kirubasankar. E. - TB & CHEST	05/12/2022
Comp. Dt. : 02/01/2023								
Status : Completed								
3472	23010041	TB & Chest OPD	CHANGE PRINTER CATRIDGE	Madhubalan. S.	PRINTER CATRIDGE CHANGED		Kirubasankar. E. - TB & CHEST	02/01/2023
Comp. Dt. : 25/03/2023								
Status : Completed								
3473	23031079	TB & Chest OPD	SYSTEM NOT WORKING	Balachandar. A.	Ram refixed and dust cleaned		Kirubasankar. E. - TB & CHEST	28/03/2023
Comp. Dt. : 31/03/2023								
Status : Completed								
3474	23031352	TB & Chest OPD	SYSTEM NOT WORKING	Selvam. D.	antivirus installed		Kirubasankar. E. - TB & CHEST	03/04/2023
Comp. Dt. : 20/04/2023								
Status : Completed								
3475	23040662	TB & Chest OPD	NEED TO CHANGE TONER	Madhubalan. S.	802 Cartridge		Kirubasankar. E. - TB & CHEST	20/04/2023
Comp. Dt. : 24/05/2023								
Status : Completed								
3476	23050969	TB & Chest OPD	NEED TO CHANGE CARTRIDGE	Jayaraj. J.	802 colour cartridge changed		Kirubasankar. E. - TB & CHEST	24/05/2023
Comp. Dt. : 26/06/2023								
Status : Completed								
3477	23060977*	POW & SICU	PRINTER NOT WORKING	Selvam. D.	printer working fine		MUKESHRAJ. K. - TB & CHEST	28/06/2023
Dept Name : Tele Exchange - Computer Department								
Comp. Dt. : 15/11/2022								
Status : Completed								
3478	22110585	Tele Exchange	IN SYSTEM-SVMCH FILE SERVER NOT WORKING	Selvam. D.	fileserver reconfigured..		Vivek. A. - Tele Exchange	18/11/2022
Comp. Dt. : 06/01/2023								
Status : Completed								
3479	23010262	JR Quarters	CAMERA PROBLEM,NEED TO EDP HELP	Valamburi. R.	camera working fine		Vivek. A. - Tele Exchange	12/01/2023
Comp. Dt. : 10/01/2023								
Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
3480	23010402	TELEPHONE DEPARTMENT IN EDP(UNDERGROUND)	CAMERA TIME AND NAME CHANGE	Raja.B	TIME ZONE CHANGED		Padmanaban. G. - Tele Exchange	10/01/2023
Comp. Dt. : 11/04/2023 Status : Completed								
3481	23040334	EDP IN UNDERGROUND	NEED TO CHANGE H D M CABLE - RECEPTION NVR	Murugavel.R	HDMI PORT NOT WORING		Vivek. A. - Tele Exchange	12/04/2023
Comp. Dt. : 27/05/2023 Status : Completed								
3482	23051076	TELEPHONE DEPARTMENT IN EDP(UNDERGROUND)	SYSTEM NOT WORKING	Madhubalan. S.,Balachandar. A.,Selvam. D.	system checkdsk run,system working fine..		Vivek. A. - Tele Exchange	29/05/2023
Dept Name : Transport - Computer Department Comp. Dt. : 16/02/2023 Status : Completed								
3483	23020647	TRANSPORT DEPARTMENT IN COMMERCIAL COMPLEX	PRINTER PROBLEM	Balachandar. A.	sharing problem		Ashok Kumar. K. - Transport	02/03/2023
Dept Name : Work Shop - Computer Department Comp. Dt. : 12/10/2022 Status : Completed								
3484	22100319	Work Shop	CAMERA NEED TO BE FIXED	Murugavel.R	Workshop camera fixed.		Ganesan. A. - Work Shop	12/10/2022
Work Type : Printer Dept Name : Civil - Maintenance - Computer Department Comp. Dt. : 29/11/2022 Status : Completed								
3485	22111227	CIVIL MAINTENANCE OFFICE	Civil Maintenance office printer toner to be change	Shafiullah. R.	12A TONER CHANGED		Gurunathan. V. - Civil - Maintenance	01/12/2022
Work Type : Work Dept Name : Civil - Maintenance - Computer Department Comp. Dt. : 09/06/2022 Status : Completed								
3486	22060329	CIVIL MAINTENANCE OFFICE	Printer toner to be change	Madhubalan. S.	12A toner changed		Gurunathan. V. - Civil - Maintenance	09/06/2022
Comp. Dt. : 30/07/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
3487	22071093	MAINTANANCE ROOM IN COMMERCIAL COMPLEX	Maintenance office room - Printer toner to be change	Murugavel.R	12 A C TONER CHANGED		Gurunathan. V. - Civil - Maintenance	01/08/2022
Dept Name : Medical Records - Computer Department Comp. Dt. : 22/11/2022 Status : Completed								
3488	22110921	Medical Records	NEED TAMIL FONT INSTALATION FOR SYSTEM NO 2&7	Jayaraj. J.	tamil font installed		Iswin Joseph.M. - Medical Records	22/11/2022
College Name : SMVNC Work Type : Complaint Dept Name : Computer Department - Computer Department Comp. Dt. : 31/05/2022 Status : Completed								
3489	22051125	Nursing College	SHARE NOT WORKING IN III FLOOR CLASS ROOM	Prakash. P.	LECT 3 CLASS ROOM LAN PATCH CHANGED		RAJARAJESWARI - SMVNC	01/06/2022
Comp. Dt. : 21/06/2022 Status : Completed								
3490	22060752	Nursing College	NEED TO CHANGE TONER	Shafiullah. R.	12A toner changed		RAJARAJESWARI - SMVNC	21/06/2022
Comp. Dt. : 24/06/2022 Status : Completed								
3491	22060891	Nursing College	SYSTEM NOT WORKING - III FLOOR	Jayaraj. J.	working fine		RAJARAJESWARI - SMVNC	27/06/2022
Comp. Dt. : 05/07/2022 Status : Completed								
3492	22070155	Nursing College	SYSTEM [2NOS] NOT WORKING AT READING ROOM	Jayaraj. J.	updated antivirus		RAJARAJESWARI - SMVNC	07/07/2022
Comp. Dt. : 19/07/2022 Status : Completed								
3493	22070714	Nursing College	NEED TO CHANGE TONER	Selvam. D.	36A toner changed		JAYASEELAN - SMVNC	19/07/2022
Comp. Dt. : 25/07/2022 Status : Completed								
3494	22070888	Nursing College	SYSTEM NOT WORKING AT GROUND FLOOR CLASS ROOM	Jayaraj. J.	MOUSE AND KEYBOARD REFIXED		JAYASEELAN - SMVNC	26/07/2022
Comp. Dt. : 20/08/2022								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
3495	22080685	1st floor	OG SYSTEM NO POWER ON	Jayaraj. J.	NEW SMPS CHANGED		RAJALAKSHMI - SMVNC	20/08/2022
Comp. Dt. : 27/08/2022								
Status : Completed								
3496	22080933	Nursing College	NEED TO CHECK SYSTEM AT READING ROOM - NOT WORKING	Jayaraj. J.	checked working fine..		KIRUBHA - SMVNC	07/09/2022
Comp. Dt. : 10/09/2022								
Status : Completed								
3497	22090419	Nursing College	NEED TO CHANGE TONER FOR OFFICE ROOM PRINTER [LASERJET 1020]	Prakash. P.	12A TONER CHANGED		JAYASEELAN - SMVNC	12/09/2022
Comp. Dt. : 19/09/2022								
Status : Completed								
3498	22090734	Nursing College	SYSTEM NOT WORKING - GROUND FLOOR CLASS ROOM	Jayaraj. J.	RAM CLEAN AND REFIXED		DHANDAPANI - SMVNC	22/09/2022
3499	22090743	Nursing College	SYSTEM DISPLAY PROBLEM IN PRINCIPAL OFFICE	Selvam. D.	MONITOR CHANGED		RAJARAJESWARI - SMVNC	23/09/2022
Comp. Dt. : 29/09/2022								
Status : Completed								
3500	22091173	Nursing College	SYSTEM NOT WORKING - GROUND FLOOR LECTURE HALL	Selvam. D.	NEW SMPS CHANGED.		DHANDAPANI 9791281966 - SMVNC	07/10/2022
Comp. Dt. : 06/10/2022								
Status : Completed								
3501	22100112	Nursing College	NEED TO CHANGE TONER	Selvam. D.	TONER CHANGED		RAJARAJESWARI - SMVNC	06/10/2022
Comp. Dt. : 08/10/2022								
Status : Completed								
3502	22100193	Nursing College	INK REFILL	Shafiullah. R.	INK REFILLED		NARMADHA - SMVNC	08/10/2022
3503	22100195	Nursing College	PASSWORD NOT WORKING	Shafiullah. R.	PASSWORD RESET		NARMDHA - SMVNC	08/10/2022
3504	22100197	Nursing College	NEED TO CHANGE COLOUR PRINTER TONER	Shafiullah. R.	COLOUR INK REFILLED		JAYASHEELAN - SMVNC	08/10/2022
Comp. Dt. : 21/10/2022								
Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
3505	22100734	Nursing College	HP LASER PRINTER 1020-CHANGE PRINTER TONER	Jayaraj. J.	12A TONER CHANGED		RAJARAJESWARI - SMVNC	21/10/2022
Comp. Dt. : 07/11/2022 Status : Completed								
3506	22110194	Nursing College	CLASS ROOM SYSTEM NOT WORKING	Murugavel.R	NETWORK I/O CHANGED		DHANDAPANI - SMVNC	23/11/2022
3507	22110222	Nursing College	SYSTEM NOT WORKING IN CHILD HEATH DEPARTMENT	Balachandar. A.	MONITOR NOT WORKING, NEW AOC 18.5 MONITOR CHANGED		RAJARAJESWARI - SMVNC	08/11/2022
3508	22110234	Nursing College	SYSTEM NOT WORKING IN LIBRARY ROOM	Balachandar. A.	motherboard problem,new H61 motherboard changed.		KIRUBHA - SMVNC	08/11/2022
Comp. Dt. : 10/11/2022 Status : Completed								
3509	22110428	Nursing College	IN LIBRARY SYSTEM-INTERNET NOT CONNECTING	Jayaraj. J.	IP GIVEN INTERNET WORKING FINE..		KIRUBA - SMVNC	18/11/2022
Comp. Dt. : 26/11/2022 Status : Completed								
3510	22111128	Nursing College	IN 2ND FLOOR STUDENT CLASS ROOM-SYSTEM NOT WORKING	Balachandar. A.	OS reinstalled		KIRUBA - SMVNC	29/12/2022
Comp. Dt. : 02/12/2022 Status : Completed								
3511	22120092	Nursing College	NEED TO CHANGE TONER	Shafiullah. R.	12A TONER CHANGED		RAJARAJESWARI - SMVNC	02/12/2022
Comp. Dt. : 21/12/2022 Status : Completed								
3512	22120985	Nursing College	SYSTEM NOT WORKING IN GROUND FLOOR	Jayaraj. J.	POWER CABLE REFIXED		DHANDAPANI - SMVNC	02/01/2023
Comp. Dt. : 27/12/2022 Status : Completed								
3513	22121223	Nursing College	SYSTEM KEYBOARD NOT WORKING	Balachandar. A.	cable refixed		RAJARAJESWARI - SMVNC	29/12/2022
Comp. Dt. : 06/01/2023 Status : Completed								
3514	23010251	Nursing College	GROUND FLOOR AND FIRST FLOOR SYSTEM NOT WORKING	Prakash. P.	OS reinstalled		DHANDABANI - SMVNC	13/01/2023
Comp. Dt. : 11/01/2023								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
3515	23010462	Nursing College	PRINTER NOT WORKING	Balachandar. A.	TONER CHANGED		RAJARAJESWARI - SMVNC	13/01/2023
Comp. Dt. : 19/01/2023								
Status : Completed								
3516	23010654	Nursing College	SYSTEM NOT WORKING IN GROUND FLOOR CLASS ROOM	Jayaraj. J.	NEW OS INSTALLED		DHANDAPANI - SMVNC	28/01/2023
Comp. Dt. : 31/01/2023								
Status : Completed								
3517	23011117	Nursing College	PRINTER PROBLEM [SHARE PRINT NOT COMING]	Selvam. D.	shared the printer		RAJARAJESWARI - SMVNC	02/02/2023
Comp. Dt. : 13/02/2023								
Status : Completed								
3518	23020477	Nursing College	NEED TO CHECK LCD - NOT WORKING IN GROUND FLOOR CLASS ROOM	Prakash. P.	checked working fine		DHANDAPANI - SMVNC	17/02/2023
Comp. Dt. : 15/02/2023								
Status : Completed								
3519	23020568	Nursing College	NEED TO CHANGE TONER	Prakash. P.	12A toner changed		RAJARAJESWARI - SMVNC	15/02/2023
Comp. Dt. : 02/03/2023								
Status : Completed								
3520	23030113	Nursing College	SYSTEM NOT WORKING - I FLOOR	Shafiullah. R.	SYSTEM WORKING		DHANDAPANI - SMVNC	04/03/2023
Comp. Dt. : 15/03/2023								
Status : Completed								
3521	23030581	Nursing College	SYSTEM NOT WORKING - II FLOOR	Jayaraj. J.	sharing working fine		DHANDAPANI - SMVNC	17/03/2023
Comp. Dt. : 23/03/2023								
Status : Completed								
3522	23030964	Nursing College	NEED TO CHECK SYSTEM - HANGING PROBLEM - PSYCHIATRY DEPARTMENT	Jayaraj. J.	working system		DHANDAPANI - SMVNC	28/03/2023
Comp. Dt. : 29/03/2023								
Status : Completed								
3523	23031227	Nursing College	NEED TO CHANGE TONER [I FLOOR]	Venkatesh. S.	12A toner changed		DHANDAPANI - SMVNC	30/03/2023

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 20/04/2023 Status : Completed								
3524	23040653	Nursing College	NEED TO INSTALL CD DRIVE & U S G PORT NOT WORKING	Madhubalan. S.	WORKING FINE		KIRUBHA - SMVNC	24/04/2023
Comp. Dt. : 25/04/2023 Status : Completed								
3525	23040782	Nursing College	PRINTER NOT WORKING	Selvam. D.	FUSER ASSEMBLY REFIXED		DHANDAPANI - SMVNC	26/04/2023
Comp. Dt. : 27/04/2023 Status : Completed								
3526	23040904	Nursing College	PRINTER PROBLEM	Selvam. D.	Teflon sleeve and pressure roller changed		RAJALAKSHMI - SMVNC	28/04/2023
Comp. Dt. : 15/05/2023 Status : Completed								
3527	23050560	Nursing College	NEED TO CHANGE TONER	Prakash. P.	12A TONER CHANGED		RAJARAJESWARI - SMVNC	15/05/2023
Comp. Dt. : 12/06/2023 Status : Completed								
3528	23060430	Nursing College	PRINTER ISSUE - PAPER JAM	Selvam. D.	paper jam cleared		RAJARAJESWARI - SMVNC	13/06/2023
Comp. Dt. : 24/06/2023 Status : Completed								
3529	23060923	Nursing College	WIFI & SYSTEM NOT WORKING AT III FLOOR CLASS ROOM	Jayaraj. J.	system working fine		DHANDAPANI - SMVNC	28/06/2023


College Name : SMVPT

Work Type : Complaint

Dept Name : Computer Department - Computer Department

Comp. Dt. : 04/08/2022

Status : Completed

3530	22080157	Polytechnic college	PRINTER NOT WORKING	Selvam. D.	Printer driver reinstalled		kathiresan - SMVPT	06/08/2022
Comp. Dt. : 12/10/2022 Status : Completed								
3531	22100366	SMVPT	Printer problem	Selvam. D.	paper pick roller cleand and refixed		PADMANABAN - SMVPT	12/10/2022
3532	22100367	SMVPT	printer problem	Selvam. D.	Scanner assembly cleaned and refixed		PADMANABAN - SMVPT	12/10/2022

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 16/12/2022								
Status : Completed								
3533	22120752	Polytechnic college	IN OFFICE-PRINTER NOT CONNECTED TO THE SYSTEM	Selvam. D.	printer share connected		NATARAJAN - SMVPT	16/12/2022
College Name : VCE								
Work Type : Complaint								
Dept Name : Computer Department - Computer Department								
Comp. Dt. : 08/06/2022								
Status : Completed								
3534	22060291	B.ED COLLEGE	NEED TO CHANGE TONER FOR PRINCIPAL OFFICE	Selvam. D.	12A TONER CHANGED		SRIMAN - VCE	08/06/2022
Comp. Dt. : 16/06/2022								
Status : Completed								
3535	22060611	B.ED COLLEGE	SYSTEM NOT WORKING	Selvam. D.	motherboard problem unable to service the board. Hence returned without service		SRIMAN - VCE	27/06/2022
Comp. Dt. : 15/07/2022								
Status : Completed								
3536	22070589	B.ED COLLEGE	U P S NOT WORKING	Selvam. D.	New numeric ups changed		SRIMAN - VCE	16/07/2022
Comp. Dt. : 22/07/2022								
Status : Completed								
3537	22070826	B.ED COLLEGE	PRINTER NOT WORKING	Murugavel.R	88 A TONER CHANGED		SRIMAN - VCE	22/07/2022
Comp. Dt. : 18/10/2022								
Status : Completed								
3538	22100588	B.ED COLLEGE	SYSTEM NOT WORKING AT I FLOOR SEMINOR ROOM	Selvam. D.	RAM CLEAN REFIXED		SRIMAN - VCE	19/10/2022
Comp. Dt. : 03/04/2023								
Status : Completed								
3539	23040047	B.ED COLLEGE	NEED TO CHECK PENDRIVE SOCKET - DAMAGE - UNFIX	Selvam. D.	pendrive working		SRIMAN - VCE	04/04/2023

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.



Sri Manakula Vinayagar Medical College and Hospital

Complaint Status Report From 01-05-2022 To 30-06-2023

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
College Name : MIT								
Work Type : Complaint								
Dept Name : Electrical Maintenance - Electrical Maintenance								
Comp. Dt. : 04/05/2022								
Status : Completed								
1	22050084	JR Quarters	NEED TO CHANGE TUBELIGHT 3NOS FOR ROOM NO 102	Srinivasan. R.	36W TUBE LIGHT 2NO'S CHANG & 40W STARTER 1NO CHANGED		KIRTHIKA - MIT	05/05/2022
2	22050104	Mit ladies hostel	NEED TO CHANGE NIGHT LAMP FOR ROOM NO 14 & TUBELIGHT FOR III FLOOR CARITOR	Srinivasan. R.	36W TUBE LIGHT 1NO CHANG & 0.5W LED NIGHT LAMP 1NO CHANGED		AROKIAMARY - MIT	05/05/2022
3	22050107	JR Quarters	NEED TO CHANGE NIGHT LAMP FOR ROOM NO 92	Srinivasan. R.	0.5W LED NIGHT LAMP 1NO CHANGED		KIRTHIKA - MIT	05/05/2022
Comp. Dt. : 05/05/2022								
Status : Completed								
4	22050128	JR Quarters	NEED TO CHANGE REST ROOM TUBELIGHT FOR II & III FLOOR	Muthu. B.	36W TUBE LIGHT 1NO CHANG & 36W CHOKE 1NO CHANGED		KIRTHIKA - MIT	12/05/2022
Comp. Dt. : 01/07/2022								
Status : Completed								
5	22070031	Mit ladies hostel	NEED TO CHANGE TUBELIGHT FOR ROOM NO 5 [STAFF SIDE]	Lakshmanan.V.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		AROKIAMARY - MIT	02/07/2022
Comp. Dt. : 20/07/2022								
Status : Completed								
6	22070759	Mit ladies hostel	NEED TO REPLACE MAIN BOX & NIGHT LAMP FOR ROOM NO 86	Vijayaraghavan.B.	0.5W NIGHT LAMP 1NO CHANGED		AROKIAMARY - MIT	21/07/2022
Comp. Dt. : 26/07/2022								
Status : Completed								
7	22070950	Mit ladies hostel	NEED TO CHANGE TUBELIGHT FOR ROOM NO 62 & GROUND FLOOR RESRROOM [STAFF SIDE]	Dhakshinamoorthy. J	36W TUBE LIGHT 2NO'S CHANG & 40W STARTER 1NO CHANG & WATER HEATER 1NO RESET WORK PROBLEM SOLVED		AROKIAMARY - MIT	27/07/2022
Comp. Dt. : 29/07/2022								
Status : Completed								


Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
8	22071066	Mit ladies hostel	FAN NOT WORKING - ROOM NO 54	Lakshmanan.V.	CEILING FAN CAPACITOR 2.5MFT 1NO CHANGED		AROKIAMARY - MIT	30/07/2022
	Comp. Dt. : 30/07/2022							
	Status : Completed							
9	22071099	Mit ladies hostel	NEED TO CHANGE TUBELIGHT FOR RESTROOM I & III FLOOR	Lakshmanan.V.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		AROKIAMARY - MIT	01/08/2022
	Comp. Dt. : 04/08/2022							
	Status : Completed							
10	22080183	Mit ladies hostel	NEED TO CHANGE TUBELIGHT 2 NOS FOR ROOM NO 130	Muthu. B.	36W TUBE LIGHT 2NO'S CHANGED		AROKIAMARY - MIT	05/08/2022
	Comp. Dt. : 05/08/2022							
	Status : Completed							
11	22080191	Mit ladies hostel	ROOM NO 112 FAN NOT WORKING	Muthu. B.	CEILING FAN CAPACITOR 2.5MFT 1NO CHANGED		AROKIAMARY - MIT	06/08/2022
12	22080195	Mit ladies hostel	NEED TO CHANGE TUBELIGHT FOR III FLOOR RESTROOM	Muthu. B.	36W TUBE LIGHT 1NO CHANGED		AROKIAMARY - MIT	06/08/2022
	Comp. Dt. : 06/09/2022							
	Status : Completed							
13	22090230	Mit ladies hostel	NEED TO CHANGE TUBELIGHT 2 NOS FOR GROUND FLOOR CARITOR [STAFF SIDE]	Manimaran. P.	36W TUBE LIGHT 1NO CHANG & 36W CHOKE 1NO CHANGED		AROKIAMARY - MIT	07/09/2022
	Comp. Dt. : 21/09/2022							
	Status : Completed							
14	22090825	Mit ladies hostel	NEED TO CHANGE TUBELIGHT FOR II FLOOR [STAFF SIDE]	Manikandan. M.	36W TUBE LIGHT 1NO CHANGED		AROKIAMARY - MIT	28/09/2022
	Comp. Dt. : 20/12/2022							
	Status : Completed							
15	22120932	Mit ladies hostel	TUBE LIGHT NOT WORKING - STAFF SIDE	Lakshmanan.V.	36W TUBE LIGHT 1NO CHANGED		AMMU - MIT	23/12/2022
	Comp. Dt. : 26/12/2022							
	Status : Completed							
16	22121159	Mit ladies hostel	2NOS TUBELIGHT NOT WORKING IN GROUND FLOOR DINNING HALL	Muthu. B.	TUBE LIGHT 36W CHOKE 1NO CHANG & 40W STARTER 1NO CHANGED		AROKIAMARY - MIT	27/12/2022
	Comp. Dt. : 31/01/2023							
	Status : Completed							


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
17	23011111	Mit ladies hostel	NEED TO CHANGE TUBELIGHT & NIGHT LAMP FOR ROOM NO 14 [STAFF SIDE]	Lakshmanan.V.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANG & 0.5W NIGHT LAMP 1NO CHANGED		AROKIAMARY - MIT	01/02/2023
Comp. Dt. : 02/02/2023 Status : Completed								
18	23020042	Mit ladies hostel	NEED TO CHANGE TUBELIGHT FOR IV FLOOR REST ROOM & ROOM NO 4,37,75 & 98	Lakshmanan.V.	R.no.4 - Fan capacitor 2.5mfd 1no replaced. R.no.37,75 & 98 - Tube light changed.		AROKIAMARY - MIT	03/02/2023
19	23020043	Mit ladies hostel	FAN NOT WORKING ROOM NO 98	Lakshmanan.V.	Fan problem - solved.		AROKIAMARY - MIT	03/02/2023
Comp. Dt. : 08/02/2023 Status : Completed								
20	23020304	Mit ladies hostel	TUBELIGHT NOT WORKING IN ROOM NO. 11 & REST ROOM - STAFF NURSE SIDE	Manimaran. P.	TUBE LIGHT 40W STARTER 2NO'S CHANG & 0.5W NIGHT LAMP 1NO CHANGED		AROKIAMARY - MIT	09/02/2023
Comp. Dt. : 14/02/2023 Status : Completed								
21	23020546	Mit ladies hostel	NEED TO CHANGE REST ROOM TUBELIGHT FOR GROUND FLOOR [STAFF SIDE]	Dhakshinamoorthy. J	TUBE LIGHT 36W CHOKE 1NO CHANGED		AROKIAMARY - MIT	16/02/2023
Comp. Dt. : 27/03/2023 Status : Completed								
22	23031096	Mit ladies hostel	FAN NOT WORKING - WAITING HALL	Dhakshinamoorthy. J	Fan capaciotor 2.5mfd 1no changed.		AROKIAMARY - MIT	29/03/2023
23	23031097	Mit ladies hostel	NEED TO CHANGE TUBELIGHT - ROOM NO 47 [STAFF SIDE]	Srinivasan. R.	36W TUBE LIGHT 1NO CHANGED		AROKIAMARY - MIT	28/03/2023
24	23031098	Mit ladies hostel	NEED TO CHANGE TUBELIGHT - ROOM NO 4 [STAFF SIDE]	Srinivasan. R.	TUBE LIGHT 40W STARTER 1NO CHANGED		AROKIAMARY - MIT	28/03/2023
Comp. Dt. : 04/05/2023 Status : Completed								
25	23050153	STREET NEAR MIT BOYS HOSTEL	NEED TO CHANGE TUBELIGHT 2 NOS	Manikandan. M.	36W TUBE LIGHT FITTING 1NO CHANG & 36W TUBE LIGHT 1NO CHANGED		RAVI - MIT	12/05/2023
Comp. Dt. : 09/05/2023 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
26	23050351	Mit ladies hostel	NEED TO CHANGE TUBELIGHT 2 NOS [STAFF SIDE]	Lakshmanan.V.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 2NO'S CHANGED		AROKIAMARY - MIT	10/05/2023
Comp. Dt. : 06/06/2023 Status : Completed								
27	23060185	Mit ladies hostel	NEED TO CHANGE TUBELIGHT 2 NOS [GROUND FLOOR FOR STAFF SIDE]	Vijayaraghavan.B.	36W TUBE LIGHT 1NO CHANGED		AROKIAMARY - MIT	07/06/2023

College Name : Others

Work Type : Complaint

Dept Name : Electrical Maintenance - Electrical Maintenance

Comp. Dt. : 10/06/2022

Status : Completed

28	22060378	Ladies hostel Phase-II	IN 2ND FLOOR-(JR SIDE) CHANGE 1 TUBELIGHT AND PHASE 1 SIDE 1ST FLOOR-CHANGE 1 TUBELIGHT	Muthu. B.	Tube light starter 2no's changed.		LAKSHMI - Others	11/06/2022

Comp. Dt. : 19/08/2022

Status : Completed

29	22080614	J.R Quateres	GROUND FLOOR RESTROOM TUBELIGHT NOT WORKING	Dhakshinamoorthy. J	TUBE LIGHT 40W STARTER 1NO CHANGED		VIRGIN MARY - Others	22/08/2022

Comp. Dt. : 02/09/2022

Status : Completed

30	22090065	THIRUVENNAINALLUR HOSPITAL(SMVMCH)	WATER HEATER NOT WORKING	Dhakshinamoorthy. J	WATER HEATER NEW 2KW COIL 1NO CHANG & THERMO CUT 1NO CHANG & HEATER CHEKING PROBLEM SOLVED		KANAGASABAI - Others	03/09/2022

Comp. Dt. : 21/10/2022

Status : Completed

31	22100726	VILLUPURAM PHC	LED PLUB NOT WORKING	Dhakshinamoorthy. J	9W LED LIGHT 2NO'S CHANGED		SANKARI - Others	03/11/2022

Comp. Dt. : 28/11/2022

Status : Completed

32	22111171	Mit ladies hostel	IN GROUND FLOOR STAFF BATHROOM-WATER HEATER NOT WORKING	Lakshmanan.V.	WATER HEATER 1NO THREMO CUT 1NO CHANG & HEATER CHEKING WORK PROBLEM SOLVED		AROKIYAMARY - Others	01/12/2022

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 07/12/2022								
Status : Completed								
33	22120300	Ladies hostel Phase-II	IN ROOM NO.79 -1 TUBELIGHT NOT WORKING	Lakshmanan.V.	36W TUBE LIGHT 1NO CHANGED		AROKIYAMARY - Others	08/12/2022
34	22120301	Ladies hostel Phase-II	IN 2ND AND 3RD FLOOR CORRIDOR-2 NO'S TUBELIGHT NOT WORKING	Muthu. B.	36W TUBE LIGHT 2NO'S CHANG & 40W STARTER 2NO'S CHANGED		AROKIYAMARY - Others	09/12/2022
Comp. Dt. : 08/12/2022								
Status : Completed								
35	22120377	Ladies hostel Phase-II	IN ROOM NO.32-1 TUBELIGHT NOT WORKING	Muthu. B.	TUBE LIGHT 40W STARTER 1NO CHANGED		AROKIYAMARY - Others	09/12/2022
36	22120380	Ladies hostel Phase-II	IN 1ST FLOOR-COMMON TOILET-1 TUBELIGHT NOT WORKING	Muthu. B.	36W TUBE LIGHT 1NO CHANG & 40W CHOKE 1NO CHANGED		AROKIYAMARY - Others	09/12/2022
37	22120389	Ladies hostel Phase-II	IN ROOM NO.58-1 TUBELIGHT NOT WORKING	Muthu. B.	36W TUBE LIGHT CHANGED		AROKIYAMARY - Others	09/12/2022
Comp. Dt. : 10/12/2022								
Status : Completed								
38	22120482	Ladies hostel Phase-II	IN ROOM NO.16,20,25-NEED TO CHANGE TUBELIGHT	Muthu. B.	36W TUBE LIGHT 2NO'S CHANG & 40W STARTER 2NO'S CHANGED		AROKIYAMARY - Others	13/12/2022
39	22120483	Ladies hostel Phase-II	IN ROOM NO.2,8,9,10,12,14-NEED TO CHANGE NIGHT LAMP	Dhakshinamoorthy. J	0.5W NIGHT LAMP 15NO'S CHANGED		AROKIYAMARY - Others	13/12/2022
Comp. Dt. : 12/12/2022								
Status : Completed								
40	22120548	B.ED COLLEGE	IN LIBRARY BLOCK-15 NO'S TUBELIGHTS ARE NOT WOKRING	Manikandan. M.	36W TUBE LIGHT 5NO'S CHANG & 36W CHOKE 5NO'S CHANG & 40W STARTER 6NO'S CHANGED		SRIMAN - Others	15/12/2022

College Name : SMVMCH

Work Type : Complaint

Dept Name : BLOOD BANK - Electrical Maintenance

Comp. Dt. : 03/12/2022

Status : Completed

41 22120127 Blood Bank TV SETUP BOX NOT
WORKING

Vijayaraghavan.B.

TV SETUP BOX SETTING
RESET WORK PROBLEM
SOLVED

Thirumangai. S. -
BLOOD BANK

06/12/2022

Dept Name : Canteen - Boys Hostel - Electrical Maintenance

Comp. Dt. : 04/08/2022

Status : Completed

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
42	22080154	Boys hostel P.H-III	NIGHT LAMP NOT WORKING	Muthu. B.	0.5W NIGHT LAMP 1NO CHANGED		Sambasivam. K. - Canteen - Boys Hostel	05/08/2022
Comp. Dt. : 19/08/2022 Status : Completed								
43	22080630	Boys hostel PH-I	IN ROOM NO.50 CFL BULB NOT WORKING	Muthu. B.	9W LED LIGHT 1NO CHANGED		Sambasivam. K. - Canteen - Boys Hostel	20/08/2022
Comp. Dt. : 02/09/2022 Status : Completed								
44	22090087	Boys hostel P.H-III	ROOM NUMBER(17) TUBELIGHT NOT WORK	Lakshmanan.V.	T5 14W TUBE LIGHT 1NO CHANGED		Sambasivam. K. - Canteen - Boys Hostel	03/09/2022
Comp. Dt. : 20/10/2022 Status : Completed								
45	22100668	Boys hostel PH-I	IN ROOM NO:51 TUBELIGHT NOT WORKING	Lakshmanan.V.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Sambasivam. K. - Canteen - Boys Hostel	21/10/2022
Comp. Dt. : 27/10/2022 Status : Completed								
46	22100846	Boys hostel PH-I	NEED TO CHANGE TUBELIGHT IN ROOM NO 54	Dhakshinamoorthy. J	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Sambasivam. K. - Canteen - Boys Hostel	28/10/2022
Comp. Dt. : 28/10/2022 Status : Completed								
47	22100890	Boys hostel Phase-II	TUBELIGHT NOT WORKING IN ROOM NO. 34	Muthu. B.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Sambasivam. K. - Canteen - Boys Hostel	29/10/2022
Comp. Dt. : 02/11/2022 Status : Completed								
48	22110043	Mit boys hostel	FOCUS LIGHT WIRE CONNECTION NEED TO BE ARRANGE PROPERLY	Dhakshinamoorthy. J	FOCUS LIGHT WIRE REARRANGE WORK PROBLEM SOLVED		Sambasivam. K. - Canteen - Boys Hostel	08/11/2022
49	22110044	Boys hostel P.H-III	IN ROOM NO.43-WATER HEATER NOT WORKING	Lakshmanan.V.	WATER HEATER NEW COIL 2KW 1NO CHANG & HEATER REFIXING WORK PROBLEM SOLVED		Sambasivam. K. - Canteen - Boys Hostel	09/11/2022
Comp. Dt. : 03/11/2022 Status : Completed								
50	22110081	Kitchen - Boys Hostel	DINING HALL1-HOT AND COLD WATER MACHINE HEATER LINE NOT WORKING	Dhakshinamoorthy. J	WATER COOLER POWER CHEKING WORK PROBLEM SOLVED		Sambasivam. K. - Canteen - Boys Hostel	04/11/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
51	22110098	Boys hostel PH-I	IN ROOM NO.32 CHANGE 1 NIGHT LAMP AND 1 TUBELIGHT	Dhakshinamoorthy. J	36W TUBE LIGHT 1NO CHANG & 40W STARTER 3NO'S CHANG & 0.5W NIGHT LAMP 1NO CHANGED		Sambasivam. K. - Canteen - Boys Hostel	04/11/2022
Comp. Dt. : 04/11/2022 Status : Completed								
52	22110140	Boys hostel P.H-III	IN 3RD FLOOR- ALL ROOMS-UNWANTED PLUG POINTS ARE OPENED THERE,SO REQUEST TO CLOSE WITH SHEETS	Lakshmanan.V.	ALL OPEN PLUG POINT MICA SHEET CLOSING WORK PROBLEM SOLVED		Sambasivam. K. - Canteen - Boys Hostel	05/11/2022
Comp. Dt. : 05/11/2022 Status : Completed								
53	22110167	BOYS HOSTEL-DINING HALL	1 TUBELIGHT NOT WORKING	Manikandan. M.	Tube light starter 1no changed.		Sambasivam. K. - Canteen - Boys Hostel	07/11/2022
54	22110168	Kitchen - Boys Hostel	1 TUBELIGHT NOT WORKING	Vijayaraghavan.B.	Tube light starter 1no changed.		Sambasivam. K. - Canteen - Boys Hostel	07/11/2022
Comp. Dt. : 07/11/2022 Status : Completed								
55	22110213	Boys hostel PH-I	ROOM NO 17 TUBELIGHT NOT WORKING	Muthu. B.	36W TUBE LIGHT 1NO CHANGED		Sambasivam. K. - Canteen - Boys Hostel	08/11/2022
56	22110214	Boys hostel PH-I	ROOM NO 36 TUBELIGHT NOT WORKING	Muthu. B.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Sambasivam. K. - Canteen - Boys Hostel	09/11/2022
57	22110215	Boys hostel PH-I	ROOM NO 39 LED BULB IN BATHROOM AND LIGHT LAMP NOT WORKING	Muthu. B.	9W LED LIGHT 1NO CHANGED		Sambasivam. K. - Canteen - Boys Hostel	11/11/2022
58	22110216	Boys hostel PH-I	ROOM NO 32 TUBELIGHT NOT WORKING	Muthu. B.	36W TUBE LIGHT 1NO CHANGED		Sambasivam. K. - Canteen - Boys Hostel	11/11/2022
59	22110217	Boys hostel PH-I	ROOM NO 41 TUBELIGHT NOT WORKING	Muthu. B.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Sambasivam. K. - Canteen - Boys Hostel	08/11/2022
60	22110218	Boys hostel PH-I	ROOM NO 41 FAN REFIXING	Dhakshinamoorthy. J	NEW CEILING FAN 1NO FIXING & LINE CONNECTION WORK PROBLEM SOLVED		Sambasivam. K. - Canteen - Boys Hostel	21/11/2022
61	22110219	Boys hostel PH-I	ROOM NO 41 SWITCH BOARD PROBLEM	Muthu. B.	3M SWITCH BOARD REFIXING WORK PROBLEM SOLVED		Sambasivam. K. - Canteen - Boys Hostel	15/11/2022
62	22110255	Boys hostel P.H-III	IN ROOM NO.2 CFL BULB BLINKING PROBLEM	Muthu. B.	9W LED LIGHT 1NO CHANGED		Sambasivam. K. - Canteen - Boys Hostel	08/11/2022
Comp. Dt. : 08/11/2022								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
63	22110310	Boys hostel PH-I	TUBELIGHT NOT WORKING IN ROOM NO. 34 - 2 NOS	Muthu. B.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Sambasivam. K. - Canteen - Boys Hostel	09/11/2022
Comp. Dt. : 10/11/2022								
Status : Completed								
64	22110397	Boys hostel PH-I	IN ROOM NO.36 EXTRA REGULATOR NEED TO BE FIX	Muthu. B.	CEILING FAN REGULATOR 1NO CHANGED		Sambasivam. K. - Canteen - Boys Hostel	11/11/2022
65	22110398	Boys hostel PH-I	IN ROOM NO.35-3 PIN SOCKET NEED TO BE FIX FOR CHARGING POINT	Muthu. B.	6A SOCKET 1NO CHANGED		Sambasivam. K. - Canteen - Boys Hostel	11/11/2022
Comp. Dt. : 14/11/2022								
Status : Completed								
66	22110494	MEDICAL COLLEGE -- -BOYS HOSTEL	TUBELIGHT NOT WORKING IN KITCHEN	Vijayaraghavan.B.	36W TUBE LIGHT 2NO'S CHANG & 40W STARTER 1NO CHANGED		Mathubalan. M. - Canteen - Boys Hostel	16/11/2022
Comp. Dt. : 15/11/2022								
Status : Completed								
67	22110609	Boys hostel PH-I	IN ROOM NO.36 FAN REGULATOR NEED TO BE FIX	Lakshmanan.V.	CEILING FAN REGULATOR 1NO CHANGED		Sambasivam. K. - Canteen - Boys Hostel	16/11/2022
Comp. Dt. : 16/11/2022								
Status : Completed								
68	22110665	Boys hostel PH-I	IN ROOM NO.30 AND 25-CHANGE CFL BULB IN BATHROOM	Dhakshinamoorthy. J	9W LED LIGHT 2NO'S CHANGED		Sambasivam. K. - Canteen - Boys Hostel	17/11/2022
Comp. Dt. : 19/11/2022								
Status : Completed								
69	22110824	Boys hostel PH-I	IN ROOM NO.36-FAN REGULATOR NEED TO BE CHANGE	Dhakshinamoorthy. J	CEILING FAN REGULATOR 1NO CHANGED		Sambasivam. K. - Canteen - Boys Hostel	21/11/2022
Comp. Dt. : 21/11/2022								
Status : Completed								
70	22110853	BOYS HOSTEL-DINING HALL	DINING HALL 2-IN WASH BASIN AREA-1 TUBELIGHT NEED TO BE CHANGE	Dhakshinamoorthy. J	22W LED LIGHT 2NO'S CHANGED		Sambasivam. K. - Canteen - Boys Hostel	22/11/2022
71	22110855	Boys hostel PH-I	IN ROOM NO.36-FAN REGULATOR NOT WORKING	Dhakshinamoorthy. J	CEILING FAN REGULATOR 1NO CHANGED		Sambasivam. K. - Canteen - Boys Hostel	21/11/2022
Comp. Dt. : 24/11/2022								
Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
72	22111052	Boys hostel	IN MILK STORAGE ROOM-EXHAUST FAN NOT WORKING	Lakshmanan.V.	EXHAUST FAN 1NO REMOVING TO ELECTRICAL ROOM		Elumalai. M. - Canteen - Boys Hostel	26/11/2022
Comp. Dt. : 25/11/2022 Status : Completed								
73	22111090	Boys hostel P.H-III	IN ROOM NO.38 NEED TO CHANGE 2 NO'S CFL BULB	Lakshmanan.V.	CEILING FAN 1NO BEARING 2NO'S CHANG & 9W LED LIGHT 2NO'S CHANGED		Sambasivam. K. - Canteen - Boys Hostel	29/11/2022
74	22111091	Boys hostel PH-I	IN ROOM NO.32-FAN SOUND PROBLEM AND ROOM NO.33-1 TUBELIGHT NOT WORKING	Lakshmanan.V.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANG & CEILING FAN BEARING 2NO'S CHANG & FAN 1NO REFIXIN		Sambasivam. K. - Canteen - Boys Hostel	28/11/2022
Comp. Dt. : 29/11/2022 Status : Completed								
75	22111251	Boys hostel PH-I	IN ROOM NO.43-FAN SOUND PROBLEM	Muthu. B.	CEILING FAN BEARING 2NO'S CHANG & FAN REFIXING WORK PROBLEM SOLVED		Sambasivam. K. - Canteen - Boys Hostel	01/12/2022
Comp. Dt. : 03/12/2022 Status : Completed								
76	22120116	Boys hostel P.H-III	HEATER NOT WORKING IN ROOM NO. 15	Dhakshinamoorthy. J	WATER HEATER 1NO RESET WORK PROBLEM SOLVED		Sambasivam. K. - Canteen - Boys Hostel	06/12/2022
77	22120117	Boys hostel P.H-III	TUBELIGHT NOT WORKING IN ROOM NO. 25	Muthu. B.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Sambasivam. K. - Canteen - Boys Hostel	06/12/2022
78	22120118	Boys hostel PH-I	TUBELIGHT NOT WORKING IN ROOM NO. 45	Dhakshinamoorthy. J	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Sambasivam. K. - Canteen - Boys Hostel	06/12/2022
Comp. Dt. : 05/12/2022 Status : Completed								
79	22120173	Kitchen - Boys Hostel	GRINDER BELT NEED TO BE CHANGE	Dhakshinamoorthy. J	GRINDER BELT 1NO CHANGED		Elumalai. M. - Canteen - Boys Hostel	06/12/2022
Comp. Dt. : 06/12/2022 Status : Completed								
80	22120238	Kitchen - Boys Hostel	1 TUBELIGHT NOT WORKING	Vijayaraghavan.B.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Sambasivam. K. - Canteen - Boys Hostel	07/12/2022
81	22120258	Kitchen - Boys Hostel	VESSEL WASHING AREA-WATER HEATER NOT WORKING	Vijayaraghavan.B.	WATER HEATER THERMOCUT 1NO CHANG & HEATER CHEKING WORK PROBLEM SOLVED		Elumalai. M. - Canteen - Boys Hostel	09/12/2022


Dr. KAGNE. R.N.
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 08/12/2022 Status : Completed								
82	22120361	Boys hostel P.H-III	REQUEST FOR NEW STUDY LIGHT IN ROOM NO.1,2,5,11,22,26	Muthu. B.	9W LED TUBE LIGHT 2 FEET 8NO'S FIXING & LINE CONNECTION WORK PROBLEM SOLVED		Sambasivam. K. - Canteen - Boys Hostel	10/12/2022
83	22120363	BOYS HOSTEL-DINING HALL	2 NO'S PEST KILLER NOT WORKING	Lakshmanan.V.	WIRE LOOSE RECONNECTION WORK PROBLEM SOLVED		Sambasivam. K. - Canteen - Boys Hostel	13/12/2022
Comp. Dt. : 10/12/2022 Status : Completed								
84	22120493	Mit ladies hostel	IN STREET-FOCUS LIGHTS ARE NOT WORKING	Muthu. B.	MCB TRIP ON TO WORK PROBLEM SOLVED		Sambasivam. K. - Canteen - Boys Hostel	17/12/2022
Comp. Dt. : 19/12/2022 Status : Completed								
85	22120875	Boys hostel Phase-II	TUBELIGHT NOT WORKING IN ROOM NO. 2	Lakshmanan.V.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Sambasivam. K. - Canteen - Boys Hostel	20/12/2022
Comp. Dt. : 20/12/2022 Status : Completed								
86	22120892	BOYS HOSTEL MESS	NEED TO CHANGE GRINDER BELT	Lakshmanan.V.	GRINDER BELT:29 1NO CHANG & CHEKING WORK PROBLEM SOLVED		Elumalai. M. - Canteen - Boys Hostel	23/12/2022
Comp. Dt. : 21/12/2022 Status : Completed								
87	22120978	Boys hostel Phase-II	NEED TO CHANGE TUBELIGHT IN ROOM NO. 55	Lakshmanan.V.	36W TUBE LIGHT 1NO CHANGED		Sambasivam. K. - Canteen - Boys Hostel	23/12/2022
Comp. Dt. : 24/12/2022 Status : Completed								
88	22121122	Boys hostel P.H-III	IN ROOM NO.4-1NO.CFL BULB AND 1.NO TUBELIGHT NEED TO BE CHANGE	Dhakshinamoorthy. J	9W LED LIGHT 1NO CHANG & 20W LED TUBE LIGHT SET 1NO FIXING WORK PROBLEM SOLVED		Sambasivam. K. - Canteen - Boys Hostel	26/12/2022
89	22121123	Boys hostel PH-I	IN ROOM NO.18 1NO. CFL BULB HOLDER NEED TO BE REAPIR	Lakshmanan.V.	ANGLE HOLDER 1NO SCREW REFIXING WORK PROBLEM SOLVED		Sambasivam. K. - Canteen - Boys Hostel	26/12/2022
90	22121124	Boys hostel PH-I	IN ROOM NO.21 1 NO.CFL BULB NOT WORKING IN BATHROOM	Dhakshinamoorthy. J	9W LED LIGHT 1NO CHANGED		Sambasivam. K. - Canteen - Boys Hostel	26/12/2022
91	22121125	Boys hostel PH-I	IN 4TH FLOOR-COMMON BATHROOM-WATER HEATER NOT WORKING	Dhakshinamoorthy. J	NEW WATER HEATER COIL 2KW 1NO CHANG & HEATER CHEKING WORK PROBLEM SOLVED		Sambasivam. K. - Canteen - Boys Hostel	26/12/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
92	22121126	Boys hostel Phase-II	IN 2ND FLOOR-COMMON BATHROOM-WATER HEATER NOT WORKING(MIT SIDE)	Lakshmanan.V.	WATER HEATER RESET WORK PROBLEM SOLVED		Sambasivam. K. - Canteen - Boys Hostel	26/12/2022
Comp. Dt. : 26/12/2022 Status : Completed								
93	22121161	Boys hostel	CUTTING MACHINE BELT NOT WORKING	Dhakshinamoorthy. J	BELT NO:B 31 1CHANG & CHEKING WORK PROBLEM SOLVED		Kesavaraj. P. - Canteen - Boys Hostel	14/01/2023
94	22121185	Boys hostel Phase-II	3PIN SOCKETNOT WORKING IN ROOM NO 35	Dhakshinamoorthy. J	6A SOCKET 1NO CHANGED		Sambasivam. K. - Canteen - Boys Hostel	27/12/2022
Comp. Dt. : 27/12/2022 Status : Completed								
95	22121236	Boys hostel PH-I	IN ROOM NO.10 -1 TUBELIGHT NOT WORKING	Muthu. B.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Sambasivam. K. - Canteen - Boys Hostel	28/12/2022
Comp. Dt. : 30/12/2022 Status : Completed								
96	22121361	Boys hostel Phase-II	IN ROOM NO.55- 1 TUBELIGHT NOT WORKING	Muthu. B.	Choke wire problem, solved.		Mathubalan. M. - Canteen - Boys Hostel	31/12/2022
97	22121370	Boys hostel	1 TUBELIGHT NOT WORKING(NEAR GROUND)	Muthu. B.	36W TUBE LIGHT 1NO CHANGED		Sambasivam. K. - Canteen - Boys Hostel	02/01/2023
Comp. Dt. : 31/12/2022 Status : Completed								
98	22121407	Boys hostel Phase-II	IN ROOM NO.30-3 PIN SOCKET GETTING SPARK	Muthu. B.	6A SOCKET 3NO'S CHANGED		Sambasivam. K. - Canteen - Boys Hostel	02/01/2023
Comp. Dt. : 03/01/2023 Status : Completed								
99	23010104	Boys hostel PH-I	IN ROOM NO.43-TUBELIGHT SWITCH NOT WORKING	Srinivasan. R.	6A SWITCH 1NO CHANGED		Mathubalan. M. - Canteen - Boys Hostel	04/01/2023
100	23010105	Boys hostel PH-I	IN ROOM NO.47 AND 11-TUBELIGHT NOT WORKING,NEED TO CHANGE	Srinivasan. R.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Mathubalan. M. - Canteen - Boys Hostel	04/01/2023
Comp. Dt. : 07/01/2023 Status : Completed								
101	23010318	Boys hostel Phase-II	IN ROOM NO.30 FAN WORKING SLOWLY	Dhakshinamoorthy. J	CEILING FAN CAPACITOR 2.5MFT 1NO CHANGED		Sambasivam. K. - Canteen - Boys Hostel	09/01/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 10/01/2023								
Status : Completed								
102	23010395	Boys hostel PH-I	IN ROOM NO.41-1 TUBELIGHT NOT WORKING	Muthu. B.	TUBE LIGHT 36W CHOKE 1NO CHANGED		Sambasivam. K. - Canteen - Boys Hostel	11/01/2023
103	23010396	Boys hostel PH-I	IN ROOM NO.26-FAN REGULATOR NOT WORKING	Muthu. B.	FAN REGULATOR 1NO CHANGED		Sambasivam. K. - Canteen - Boys Hostel	12/01/2023
104	23010430	Boys hostel PH-I	IN ROOM NO.12-FAN NOT WORKING	Muthu. B.	CEILING FAN 1NO CHEKING WORK PROBLEM SOLVED		Sambasivam. K. - Canteen - Boys Hostel	11/01/2023
Comp. Dt. : 11/01/2023								
Status : Completed								
105	23010451	MEDICAL COLLEGE -- -BOYS HOSTEL	IN STORE ROOM-1 TUBELIGHT NOT WORKING	Lakshmanan.V.	36W TUBE LIGHT 1NO CHANGED		Anand. G. - Transport	12/01/2023
106	23010492	Boys hostel Phase-II	IN ROOM NO.44-1 TUBELIGHT NOT WORKING	Lakshmanan.V.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Sambasivam. K. - Canteen - Boys Hostel	12/01/2023
107	23010493	Boys hostel Phase-II	IN 2ND FLOOR COMMON BATHROOM-WATER HEATER NOT WORKING	Lakshmanan.V.	WATER HEATER 1NO RESET WORK PROBLEM SOLVED		Sambasivam. K. - Canteen - Boys Hostel	12/01/2023
Comp. Dt. : 21/01/2023								
Status : Completed								
108	23010784	Boys hostel PH-I	IN ROOM NO.28-1 TUBELIGHT NOT WORKING	Dhakshinamoorthy. J	36W TUBE LIGHT 1NO CHANG & 40W TUBE LIGHT 1NO CHANGED		Sambasivam. K. - Canteen - Boys Hostel	23/01/2023
109	23010786	Boys hostel PH-I	IN ROOM NO.36-1 TUBELIGHT NOT WORKING AND IN OPPOSITE CORRIDOR-1 TUBELIGHT NOT WORKING	Dhakshinamoorthy. J	36W TUBE LIGHT 2NO'S CHANG & 40W STARTER 2NO'S CHANGED		Sambasivam. K. - Canteen - Boys Hostel	23/01/2023
110	23010787	Boys hostel PH-I	IN ROOM NO.47-1 TUBELIGHT NOT WORKING	Dhakshinamoorthy. J	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Sambasivam. K. - Canteen - Boys Hostel	23/01/2023
Comp. Dt. : 06/02/2023								
Status : Completed								
111	23020180	Boys hostel	FOCUS LIGHT REFIXING WORK	Muthu. B.	120W LED FOCUS LIGHT 1NO REFIXING WORK PROBLEM SOLVED		Sambasivam. K. - Canteen - Boys Hostel	07/02/2023
Comp. Dt. : 10/02/2023								
Status : Completed								
112	23020382	Boys hostel	TUBELIGHT NOT WORKING IN COMPUTER ROOM	Muthu. B.	tube light 36w 1nos changed		Kesavaraj. P. - Canteen - Boys Hostel	11/02/2023
Comp. Dt. : 18/04/2023								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
113	23040562	Boys hostel PH-I	BOYS HOSTAL PHASE -I ROOM NO-32 TUBE LIGHT NOT WORKING	Manikandan. M.	TUBE LIGHT 40W STARTER 1NO CHANGED		Sambasivam. K. - Canteen - Boys Hostel	19/04/2023
Comp. Dt. : 15/06/2023								
Status : Completed								
114	23060546	Boys hostel PH-I	ROOM NO-32,NEED TO CHANGE ONE CFL BULP	Srinivasan. R.	9W LED LIGHT 1NO CHANGED		Sambasivam. K. - Canteen - Boys Hostel	16/06/2023
Dept Name : Canteen - Hospital - Electrical Maintenance								
Comp. Dt. : 17/05/2022								
Status : Completed								
115	22050583	DIET DEPARMENT	NEED CABLE CONNECTION WORK FOR GRINDER - NEED URGENT SERVICE	Muthu. B.	GRINDER LINE CONNECTION WORK PROBLEM SOLVED		Shaik Haja Mohideen. S.M. - Canteen - Hospital	17/05/2022
Dept Name : Canteen-Girls Hostel - Electrical Maintenance								
Comp. Dt. : 11/05/2022								
Status : Completed								
116	22050386	Ladies hostel Phase-II	3RD FLOOR-- STUDY HALL ONE FAN NOT WORKING AND CHANGE ONE TUBELIGHT IN CORRIDOR(3044)	Muthu. B.	36W TUBE LIGHT 2NO'S CHANG & 40W CHOKE 1NO CHANG & 40W STARTER 2NO'S CHANGED		Malliga. K. - Canteen-Girls Hostel	13/05/2022
Comp. Dt. : 12/05/2022								
Status : Completed								
117	22050423	Ladies hostel Phase-II	4TH FLOOR TV NOT WORKING PROPERLY	Muthu. B.,Dhakshinamoorth y. J,Vengadessaperuma I.K.	TV Fixed & Tested ok.		Malliga. K. - Canteen-Girls Hostel	06/06/2022
118	22050443	Ladies hostel Phase-I	IN ROOM NO.5 CHANGE 1 TUBELIGHT AND ROOM NO.4 FAN NOT WORKING	Muthu. B.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANG & CEILING FAN CAPACITOR 2.5MFT 1NO CHANGED		Revathy. N. - Canteen-Girls Hostel	13/05/2022
Comp. Dt. : 13/05/2022								
Status : Completed								
119	22050457	Ladies hostel Phase-I	(3045)MESS AREA -ONE FAN AND ONE TUBELIGHT ALSO NOT WORKING	Lakshmanan.V.	CEILING FAN BEARING 2NO'S CHANG & FAN 1NO REFIXING WORK & 36W TUBE LIGHT 1NO CHANGED		Revathy. N. - Canteen-Girls Hostel	20/05/2022
120	22050463	Ladies hostel Phase-II	IN 1ST FLOOR-COMMON BATHROOM-1 TUBELIGHT NOT WORKING	Muthu. B.	36W TUBE LIGHT CHOKE 1NO CHANGED		Malliga. K. - Canteen-Girls Hostel	14/05/2022

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHAL KUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
121	22050464	Ladies hostel Phase-II	IN 1ST FLOOR-ROOM NO.44 NIGHT LAMP NEED TO BE CHANGE	Muthu. B.	0.5W NIGHT LAMP 1NO CHANGED		Malliga. K. - Canteen-Girls Hostel	14/05/2022
Comp. Dt. : 01/06/2022 Status : Completed								
122	22060032	Ladies hostel Phase-I	FAN NOT WORKING ROOM NO 3	Vijayaraghavan.B.	CEILING FAN CAPACITOR 2.5MFT 1NO CHANGED		Revathy. N. - Canteen-Girls Hostel	02/06/2022
Comp. Dt. : 17/08/2022 Status : Completed								
123	22080525	Ladies hostel Phase-II	IN 2ND FLOOR-1.NO TUBELIGHT NOT WORKING	Lakshmanan.V.	R.no.32 tube light side holder problem - solved.		Malliga. K. - Canteen-Girls Hostel	18/08/2022
Comp. Dt. : 18/08/2022 Status : Completed								
124	22080571	Ladies hostel Phase-I	IN ROOM NO.12 1 TUBELIGHT NOT WORKING AND FAN SOUND PROBLEM	Lakshmanan.V.	CEILING FAN CAPACITOR 2.5MFT 1NO CHANG & 36W TUBE LIGHT 1NO CHANGED		Revathy. N. - Canteen-Girls Hostel	20/08/2022
125	22080580	Ladies hostel Phase-II	IN 3RD FLOOR COMMON BATHROOM-WATER HEATER NOT WORKING	Lakshmanan.V.	WATER HEATER NEW COIL 2KW 1NO CHANGED		Malliga. K. - Canteen-Girls Hostel	20/08/2022
126	22080581	Ladies hostel Phase-II	IN 2ND FLOOR-CORRIDOR-1 TUBELIGHT NOT WORKING	Lakshmanan.V.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Malliga. K. - Canteen-Girls Hostel	20/08/2022
Comp. Dt. : 19/08/2022 Status : Completed								
127	22080627	Hostel - Girls-II Phase	2ND, 3RD AND 4TH FLOOR TUBE LIGHT NOT WORKING - 4 NOS	Dhakshinamoorthy. J	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Malliga. K. - Canteen-Girls Hostel	22/08/2022
128	22080628	Hostel - Girls-II Phase	3RD FLOOR RESTROOM HEATER NOT WORKING	Lakshmanan.V.	NEW WATER HEATER COIL 2KW 1NO CHANGED		Malliga. K. - Canteen-Girls Hostel	20/08/2022
129	22080644	Ladies hostel Phase-I	IN ROOM NO.16 1 TUBELIGHT NOPT WORKING	Lakshmanan.V.	36W TUBE LIGHT 1NO CHANGED		Revathy. N. - Canteen-Girls Hostel	20/08/2022
130	22080650	Ladies hostel Phase-II	IN ROOM NO.81 1 TUBELIGHT NOT WORKING	Dhakshinamoorthy. J	36W TUBE LIGHT 1NO CHANGED		Malliga. K. - Canteen-Girls Hostel	22/08/2022
Comp. Dt. : 19/09/2022 Status : Completed								
131	22090724	Ladies hostel Phase-I	NEED TO CHANGE TUBELIGHT 2NOS FOR DINING HALL & MESS OUTSIDE	Lakshmanan.V.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Revathy. N. - Canteen-Girls Hostel	20/09/2022
Comp. Dt. : 26/10/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
132	22100800	J.R Quateres	GROUND FLOOR REST ROOM TUBE LIGHT NOT WORKING - 2 NOS	Lakshmanan.V.	TUBE LIGHT 40W STARTER 2NO'S CHANGED		Virgin Mary - Canteen-Girls Hostel	27/10/2022
133	22100819	Ladies hostel Phase-II	2 AND 3 FLOOR-CHANGE ONE TUBELIGHT3044	Lakshmanan.V.	36W TUBE LIGHT 2NO'S CHANGED		Virgin Mary - Canteen-Girls Hostel	27/10/2022
Comp. Dt. : 27/10/2022 Status : Completed								
134	22100847	JR Quarters	NEED TO CHANGE TUBE LIGHT IN 3RD FLOOR RESTROOM - 3 NOS	Muthu. B.	36W TUBE LIGHT 2NO'S CHANG & 40W STARTER 1NO CHANG & 40W CHOKE 1NO CHANGED		Virgin Mary - Canteen-Girls Hostel	29/10/2022
Comp. Dt. : 28/10/2022 Status : Completed								
135	22100893	J.R Quateres	ROOM NO.9,47,AND 48 TUBELIGHT NEED TO BE CHANGE	Lakshmanan.V.	36W TUBE LIGHT 3NO'S CHANG & 40W STARTER 3NO'S CHANG & 36W CHOKE 1NO CHANGED		Virgin Mary - Canteen-Girls Hostel	31/10/2022
136	22100894	J.R Quateres	IN 3RD FLOOR REST ROOM-TUBELIGHT NOT WORKING	Muthu. B.	36W TUBE LIGHT 2NO'S CHANG & 40W STARTER 1NO CHANG & 36W CHOKE 1NO CHANGED		Virgin Mary - Canteen-Girls Hostel	29/10/2022
Comp. Dt. : 29/10/2022 Status : Completed								
137	22100966	Ladies hostel Phase-II	TUBE LIGHT NOT WORKING IN ROOM NO. 115, 112(NEAR CORRIDOR)	Muthu. B.	36W TUBE LIGHT 2NO'S CHANG & 40W STARTER 1NO CHANG & 36W CHOKE 1NO CHANGED		Malliga. K. - Canteen-Girls Hostel	31/10/2022
138	22100967	Ladies hostel Phase-II	TUBE LIGHT NOT WORKING IN 2ND AND 3RD FLOOR RESTROOM	Muthu. B.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 2NO'S CHANGED		Malliga. K. - Canteen-Girls Hostel	31/10/2022
Comp. Dt. : 31/10/2022 Status : Completed								
139	22101000	Ladies hostel Phase-II	G.FLOOR AND 1ST FLOOR -NEED TO CHANGE ONE TUBELIGHT.ROOM NO-72,CHANGE ONE TUBELIGHT	Srinivasan. R.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 2NO'S CHANGED		Malliga. K. - Canteen-Girls Hostel	02/11/2022
Comp. Dt. : 02/11/2022 Status : Completed								
140	22110010	J.R Quateres	IN ROOM NO.42 1 TUBELIGHT NOT WORKING	Dhakshinamoorthy. J	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Virgin Mary - Canteen-Girls Hostel	03/11/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
141	22110017	Ladies hostel Phase-II	IN ROOM NO.115-NEED TO FIX FAN REGULATOR AND ROOM NO.47 CHANGE 1 TUBELIGHT	Dhakshinamoorthy. J	FAN REGULATOR 1NO CHANG & 36W TUBE LIGHT 2NO'S CHANG & 40W STARTER 2NO'S CHANGED		Malliga. K. - Canteen-Girls Hostel	03/11/2022
142	22110035	Ladies hostel Phase-I	IN ROOM NO.48 CHANGE SMALL TUBELIGHT IN BATHROOM	Dhakshinamoorthy. J	TUBE LIGHT 40W STARTER 1NO CHANGED		Malliga. K. - Canteen-Girls Hostel	03/11/2022
143	22110036	Ladies hostel Phase-I	IN 1 ST FLOOR AND ALSO IN WASHING AREA-CHANGE 2 NO'S TUBELIGHT	Dhakshinamoorthy. J	TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANG & SIDE HOLDER 2NO'S CHANGED		Malliga. K. - Canteen-Girls Hostel	04/11/2022
144	22110039	Ladies hostel Phase-I	IN ROOM NO.30 AND 50 CHANGE 2 NO'S TUBELIGHT	Dhakshinamoorthy. J	36W TUBE LIGHT 2NO'S CHANG & 40W STARTER 2NO'S CHANGED		Revathy. N. - Canteen-Girls Hostel	04/11/2022
Comp. Dt. : 04/11/2022 Status : Completed								
145	22110128	Ladies hostel Phase-II	IN 1ST FLOOR-STUDY HALL-1 TUBELIGHT NOT WORKING	Dhakshinamoorthy. J	TUBE LIGHT 40W STARTER 1NO CHANGED		Malliga. K. - Canteen-Girls Hostel	05/11/2022
146	22110129	Ladies hostel Phase-II	IN ROOM NO.37 AND 44 -2 NO'S TUBELIGHT NEED TO BE CHANGE	Dhakshinamoorthy. J	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Malliga. K. - Canteen-Girls Hostel	05/11/2022
147	22110132	J.R Quateres	IN 3RD FLOOR-COMMON BATHROOM(LEFT SIDE)WATER HEATER NOT WORKING	Dhakshinamoorthy. J	16A 3PIN TOP 1NO CHANG & 16A SOCKET 1NO CHANGED		Virgin Mary - Canteen-Girls Hostel	08/11/2022
148	22110154	Ladies hostel Phase-I	IN ROOM NO.58 CHANGE 1 TUBELIGHT AND ROOM NO.28 CHANGE 1 SMALL TUBELIGHT IN BATHROOM	Dhakshinamoorthy. J	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Revathy. N. - Canteen-Girls Hostel	05/11/2022
Comp. Dt. : 05/11/2022 Status : Completed								
149	22110184	Ladies hostel Phase-I	IN ROOM NO.14 CHANGE 1 SMALL TUBELIGHT IN BATHROOM	Dhakshinamoorthy. J	R.no.14 20W tube light 1no changed.		Revathy. N. - Canteen-Girls Hostel	07/11/2022
Comp. Dt. : 07/11/2022 Status : Completed								
150	22110191	J.R Quateres	TUBE LIGHT NOT WORKING IN ROOM NO. 1,2,42 - 4 NOS	Lakshmanan.V.	TUBE LIGHT 1NO CHANG & 40W STARTER 2NO'S CHANGED		Virgin Mary - Canteen-Girls Hostel	09/11/2022
151	22110249	Ladies hostel Phase-II	IN ROOM NO.87 1 TUBELIGHT NOT WORKING	Lakshmanan.V.	36W TUBE LIGHT 2NO'S CHANG & 36W CHOKE 1NO & 40W STARTER 2NO'S CHANGED		Malliga. K. - Canteen-Girls Hostel	09/11/2022
152	22110250	Ladies hostel Phase-II	IN 3RD FLOOR AND 4TH FLOOR-COMMON BATHROOM-2 NO'S TUBELIGHT NOT WORKING	Lakshmanan.V.	36W TUBE LIGHT 2NO'S CHANG & 36W CHOKE 1NO CHANG & 40W STARTER 2NO'S CHANGED		Malliga. K. - Canteen-Girls Hostel	09/11/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 09/11/2022								
Status : Completed								
153	22110346	J.R Quateres	IN 3RD FLOOR-NO POWER IN ALL ROOMS	Dhakshinamoorthy. J	MCB TRIP ON TO WORK PROBLEM SOLVED		Virgin Mary - Canteen-Girls Hostel	11/11/2022
154	22110373	Ladies hostel Phase-I	IN 3RD FLOOR-BATHROOM-1 TUBELIGHT NOT WORKING	Manikandan. M.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Malliga. K. - Canteen-Girls Hostel	14/11/2022
Comp. Dt. : 10/11/2022								
Status : Completed								
155	22110429	Ladies hostel Phase-I	IN ROOM NO.52 -1 TUBELIGHT NOT WORKING	Lakshmanan.V.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Malliga. K. - Canteen-Girls Hostel	11/11/2022
156	22110433	Ladies hostel Phase-I	IN ROOM NO.108- 1 TUBELIGHT NOT WORKING	Lakshmanan.V.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANG & 36W CHOKE 1NO CHANGED		Malliga. K. - Canteen-Girls Hostel	11/11/2022
Comp. Dt. : 11/11/2022								
Status : Completed								
157	22110473	Ladies hostel Phase-II	IN 3RD FLOOR COMMON BATHROOM-1 TUBELIGHT NOT WORKING	Muthu. B.	36W CHOKE 1NO CHANG & 36W TUBE LIGHT 1NO CHANGED		Revathy. N. - Canteen-Girls Hostel	15/11/2022
158	22110474	Ladies hostel Phase-II	IN STUDY HALL-1 TUBELIGHT NOT WORKING	Muthu. B.	36W TUBE LIGHT 1NO CHANGED		Revathy. N. - Canteen-Girls Hostel	15/11/2022
Comp. Dt. : 14/11/2022								
Status : Completed								
159	22110518	J.R Quateres	NEED TO CHANGE 2 NO'S TUBELIGHT IN GROUND FLOOR	Muthu. B.	TUBE LIGHT 40W STARTER 2NO'S CHANGED		Virgin Mary - Canteen-Girls Hostel	15/11/2022
160	22110559	Ladies hostel Phase-II	IN ROOM NO.78-1 TUBELIGHT NOT WORKING AND ROOM NO.115 FAN REGULATOR NOT WORKING	Muthu. B.	CEILING FAN REGULATOR 1NO CHANG & 36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Revathy. N. - Canteen-Girls Hostel	15/11/2022
161	22110560	Ladies hostel Phase-II	IN ROOM NO.93-WALL MOUNTED FAN NOT WORKING	Muthu. B.	WALLMOUNTING FAN SERVICE WORK PROBLEM SOLVED		Revathy. N. - Canteen-Girls Hostel	15/11/2022
Comp. Dt. : 15/11/2022								
Status : Completed								
162	22110580	Ladies hostel Phase-I	IN ROOM NO.40-1 TUBELIGHT NOT WORKING AND IN BATHROOM-1 TUBELIGHT NOT WORKING	Lakshmanan.V.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Revathy. N. - Canteen-Girls Hostel	18/11/2022
163	22110582	Ladies hostel Phase-II	IN ROOM NO.101-FAN REGULATOR NEED TO BE FIX NEWLY	Srinivasan. R.	CEILING FAN REGULATOR 1NO CHANGED		Malliga. K. - Canteen-Girls Hostel	17/11/2022

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
164	22110583	Ladies hostel Phase-I	IN 2ND FLOOR-CORRIDOR-1 TUBELIGHT NOT WORKING	Lakshmanan.V.	36W TUBE LIGHT 1NO CHANGED		Revathy. N. - Canteen-Girls Hostel	16/11/2022
165	22110584	Ladies hostel Phase-II	IN ROOM NO.82-1 TUBELIGHT NOT WORKING	Lakshmanan.V.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Malliga. K. - Canteen-Girls Hostel	16/11/2022
166	22110588	J.R Quateres	IN 3RD AND 4TH FLOOR-NO POWER SUPPLY	Srinivasan. R.	MCB TRIP ON TO WORK PROBLEM SOLVED		Virgin Mary - Canteen-Girls Hostel	17/11/2022
167	22110590	J.R Quateres	IN ROOM NO.92-1 TUBELIGHT NOT WORKING	Lakshmanan.V.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Virgin Mary - Canteen-Girls Hostel	16/11/2022
168	22110591	J.R Quateres	IN 3RD FLOOR-NEAR STEPS-TUBELIGHT NOT WORKING	Lakshmanan.V.	36W TUBE LIGHT 1NO CHANGED		Virgin Mary - Canteen-Girls Hostel	16/11/2022
169	22110592	J.R Quateres	IN ROOM NO.89-1 TUBELIGHT NOT WORKING	Srinivasan. R.	36W TUBE LIGHT 1NO CHANGED		Virgin Mary - Canteen-Girls Hostel	17/11/2022
Comp. Dt. : 16/11/2022 Status : Completed								
170	22110649	Ladies hostel Phase-II	IN ROOM NO.101-FAN CONDENSOR NEED TO BE CHANGE AND ROOM NO.98 -FAN REGULATOR NEED TO BE CHANGE	Srinivasan. R.	NEW CEILING FAN REGULATOR 1NO CHANGED		Malliga. K. - Canteen-Girls Hostel	17/11/2022
171	22110651	J.R Quateres	IN ROOM NO.89/90/96-ZERO WATTS BULB NEED TO BE CHANGE	Srinivasan. R.	0.5W NIGHT LAMP 2NO'S CHANGED		Virgin Mary - Canteen-Girls Hostel	17/11/2022
172	22110652	J.R Quateres	IN GROUND FLOOR CORRIDOR-1 TUBELIGHT NOT WORKING	Lakshmanan.V.	36W TUBE LIGHT 1NO CHANG & 36W CHOKE 1NO CHANGED		Virgin Mary - Canteen-Girls Hostel	18/11/2022
173	22110653	J.R Quateres	IN 4TH FLOOR NEAR STEPS-1 TUBELIGHT NOT WORKING	Lakshmanan.V.	36W TUBE LIGHT 1NO CHANG & 36W CHOKE 1NO CHANGED		Virgin Mary - Canteen-Girls Hostel	18/11/2022
174	22110654	J.R Quateres	IN 3RD FLOOR CORRIDOR-1 TUBELIGHT NOT WORKING	Lakshmanan.V.	36W TUBE LIGHT 1NO CHANG & 36W CHOKE 1NO CHANGED		Virgin Mary - Canteen-Girls Hostel	18/11/2022
Comp. Dt. : 17/11/2022 Status : Completed								
175	22110715	Ladies hostel Phase-II	IN ROOM NO.108-1 TUBELIGHT NOT WORKING AND ROOM NO.101-FAN RUNNING SLOWLY	Lakshmanan.V.	CEILING FAN CAPACITOR 2.5MFT 1NO CHANG & 36W TUBE LIGHT 1NO CHANGED		Malliga. K. - Canteen-Girls Hostel	18/11/2022
Comp. Dt. : 18/11/2022 Status : Completed								
176	22110787	Ladies hostel Phase-II	NEED TO PROVIDE REGULATOR FOR ROOM NO 98	Muthu. B.	CEILING FAN REGULATOR 1NO CHANGED		Malliga. K. - Canteen-Girls Hostel	19/11/2022
Comp. Dt. : 22/11/2022								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
177	22110934	Ladies hostel Phase-II	NEED TO CHANGE TUBELIGHT FOR III & IV FLOOR COMMON REST ROOM	Dhakshinamoorthy. J	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Malliga. K. - Canteen-Girls Hostel	25/11/2022
Comp. Dt. : 23/11/2022								
Status : Completed								
178	22110991	Ladies hostel Phase-II	IN 4TH FLOOR-GYM-2 NO'S TUBELIGHT NOT WORKING	Dhakshinamoorthy. J	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Malliga. K. - Canteen-Girls Hostel	25/11/2022
179	22110993	Ladies hostel Phase-II	IN GROUND FLOOR-SWITCH CONNECTION NEED TO BE SEPERATE(ONE SWITCH FOR 2 LIGHTS)	Dhakshinamoorthy. J	6A SWITCH 1NO CHANGED		Malliga. K. - Canteen-Girls Hostel	26/11/2022
180	22111020	Ladies hostel Phase-I	IN MESS-1 TUBELIGHT NOT WORKING	Dhakshinamoorthy. J	36W TUBE LGIHT 1NO CHANGED		Revathy. N. - Canteen-Girls Hostel	24/11/2022
Comp. Dt. : 25/11/2022								
Status : Completed								
181	22111106	Ladies hostel Phase-I	IN MESS-INSECT KILLER MACHINE LIGHT NOT WORKING	Dhakshinamoorthy. J	15W LIGHT 2NO'S CHANGED		Revathy. N. - Canteen-Girls Hostel	29/11/2022
Comp. Dt. : 26/11/2022								
Status : Completed								
182	22111126	Ladies hostel Phase-I	POWER TRIPPING WHEN USE GRINDER IN MESS	Dhakshinamoorthy. J	32A 3POLE MCB 1NO CHANGED		Revathy. N. - Canteen-Girls Hostel	28/11/2022
183	22111127	Ladies hostel Phase-I	IN MESS-1 TUBELIGHT NOT WORKING	Dhakshinamoorthy. J	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Revathy. N. - Canteen-Girls Hostel	28/11/2022
184	22111151	Ladies hostel Phase-II	IN 4TH FLOOR BATHROOM-1 NO'S TUBELIGHT NEED TO BE CHANGE	Muthu. B.	36W TUBE LIGHT 1NO CHANG & 36W CHOKE 1NO CHANGED		Revathy. N. - Canteen-Girls Hostel	28/11/2022
185	22111152	Ladies hostel Phase-II	IN ROOM NO.110-1 TUBELIGHT NEED TO BE CHANGE	Muthu. B.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Revathy. N. - Canteen-Girls Hostel	28/11/2022
186	22111153	Ladies hostel Phase-II	IN ROOM NO.58-1 NIGHT LAMP NEED TO BE CHANGE	Muthu. B.	0.5W NIGHT LAMP 1NO CHANGED		Revathy. N. - Canteen-Girls Hostel	28/11/2022
Comp. Dt. : 28/11/2022								
Status : Completed								
187	22111166	Ladies hostel Phase-I	NEED TO CHANGE 1 TUBELIGHT IN DINING HALL	Lakshmanan.V.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHNAGED		Revathy. N. - Canteen-Girls Hostel	30/11/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
188	22111167	Ladies hostel Phase-I	CHANGE 1 TUBELIGHT IN 2ND FLOOR CORRIDOR AND CHANGE 1 TUBELIGHT IN ROOM NO.41	Lakshmanan.V.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Revathy. N. - Canteen-Girls Hostel	30/11/2022
189	22111174	Ladies hostel Phase-II	IN ROOM NO.63 FAN RUNNING SLOWLY AND SOUND PROBLEM	Lakshmanan.V.	CEILING FAN BEARING 2NO'S CHANG & FNA 1NO REFIXING WORK PROBLEM SOLVED		Malliga. K. - Canteen-Girls Hostel	01/12/2022
Comp. Dt. : 30/11/2022 Status : Completed								
190	22111260	Ladies hostel Phase-I	POWER NOT SUPPLY	Rajan. R.	MCB TRIP ON TO WORK PROBLEM SOLVED		Revathy. N. - Canteen-Girls Hostel	01/12/2022
191	22111280	Ladies hostel Phase-II	NEED TO CHECK TUBELIGHT NOT WORKING	Muthu. B.	36W TUBE LIGHT 1NO CHANG & 410W STARTER 1NO CHANGED		Sumathi. B. - Canteen-Girls Hostel	01/12/2022
Comp. Dt. : 03/12/2022 Status : Completed								
192	22120129	LADIES HOSTEL MESS	TUBELIGHT NOT WORKING	Dhakshinamoorthy. J	36W TUBE LIGHT 1NO CHANGED		Revathy. N. - Canteen-Girls Hostel	06/12/2022
Comp. Dt. : 06/12/2022 Status : Completed								
193	22120232	Ladies hostel Phase-II	IN 3RD FLOOR AND 2ND FLOOR-2 NO'S TUBELIGHT NOT WORKING	Muthu. B.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 2NO'S CHANGED		Malliga. K. - Canteen-Girls Hostel	07/12/2022
194	22120233	Ladies hostel Phase-II	IN GROUND FLOOR CORRIDOR-1 TUBELIGHT NOT WORKING	Muthu. B.	36W TUBE LIGHT 1NO CHANGED		Malliga. K. - Canteen-Girls Hostel	09/12/2022
195	22120234	Ladies hostel Phase-I	IN GROUND FLOOR CORRIDOR-1 TUBELIGHT NOT WORKING	Muthu. B.	36W TUBE LIGHT 1NO CHANGED		Revathy. N. - Canteen-Girls Hostel	07/12/2022
196	22120235	Ladies hostel Phase-I	IN 3RD FLOOR-(NEAR COOLER)1 TUBELIGHT NOT WORKING	Muthu. B.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Revathy. N. - Canteen-Girls Hostel	10/12/2022
Comp. Dt. : 12/12/2022 Status : Completed								
197	22120512	Ladies hostel Phase-II	3RD FLOOR COMMON BATHROOM TUBELIGHT NOT WORKING	Dhakshinamoorthy. J	36W TUBE LIGHT 1NO CHANGED		Malliga. K. - Canteen-Girls Hostel	13/12/2022
198	22120513	Ladies hostel Phase-II	1ST FLOOR COMMON BATHROOM TUBELIGHT NOT WORKING	Dhakshinamoorthy. J	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Malliga. K. - Canteen-Girls Hostel	13/12/2022
199	22120514	Ladies hostel Phase-II	IN ROOM NO 78 TUBELIGHT NOT WORKING	Dhakshinamoorthy. J	TUBE LIGHT 40W STARTER 1NO CHANGED		Malliga. K. - Canteen-Girls Hostel	13/12/2022
200	22120515	Ladies hostel Phase-II	IN ROOM NO 42 TUBELIGHT NOT WORKING	Dhakshinamoorthy. J	36W TUBE LIGHT 1NO CHANGED		Malliga. K. - Canteen-Girls Hostel	14/12/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
201	22120543	Ladies hostel Phase-I	IN ROOM NO.25 OPP CORRIDOR-1 TUBELIGHT NOT WORKING	Dhakshinamoorthy. J	36W TUBE LIGHT 1NO CHANGED		Revathy. N. - Canteen-Girls Hostel	13/12/2022
Comp. Dt. : 16/12/2022 Status : Completed								
202	22120754	Ladies hostel Phase-II	IN ROOM NO.58-1 TUBELIGHT NOT WORKING	Dhakshinamoorthy. J	TUBE LIGHT 40W STARTER 1NO CHANGED		Malliga. K. - Canteen-Girls Hostel	17/12/2022
203	22120794	J.R Quateres	IN 1ST FLOOR CORRIDOR-1 TUBELIGHT NOT WORKING	Dhakshinamoorthy. J	36W TUBE LIGHT 1NO CHANGED		Virgin Mary - Canteen-Girls Hostel	17/12/2022
Comp. Dt. : 20/12/2022 Status : Completed								
204	22120886	J.R Quateres	LIGHT LAMP NOT WORKING IN ROOM NO 125	Lakshmanan.V.	0.5W NIGHT LAMP 1NO CHANGED		Virgin Mary - Canteen-Girls Hostel	23/12/2022
205	22120887	J.R Quateres	CORRIDOR TUBELIGHT NOT WORKING	Lakshmanan.V.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Virgin Mary - Canteen-Girls Hostel	23/12/2022
206	22120888	J.R Quateres	TUBELIGHT NOT WORKING IN ROOM NO 15	Lakshmanan.V.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Virgin Mary - Canteen-Girls Hostel	23/12/2022
207	22120895	Ladies hostel Phase-I	TUBELIGHT NOT WORKING IN ROOM NO 77 (REST ROOM)	Lakshmanan.V.	TUBE LIGHT SIDE HOLDER 2NO'S CHANGED		Revathy. N. - Canteen-Girls Hostel	24/12/2022
208	22120899	Ladies hostel Phase-I	TUBELIGHT NOT WORKING IN MESS - 2NOS	Muthu. B.	TUBE LIGHT 40W STARTER 2NO'S CHANGED		Revathy. N. - Canteen-Girls Hostel	21/12/2022
209	22120926	Ladies hostel Phase-II	ROOM NO 94 TUBE LIGHT NOT WORKING	Muthu. B.	36W TUBE LIGHT 1NO CHANG & 0.5W NIGHT LAMP 1NO CHANGED		Malliga. K. - Canteen-Girls Hostel	21/12/2022
210	22120927	Ladies hostel Phase-II	ROOM 32 FAN REGULATOR NOT WORKING	Muthu. B.	CEILING FAN REGULATOR 1NO CHANGED		Malliga. K. - Canteen-Girls Hostel	21/12/2022
Comp. Dt. : 21/12/2022 Status : Completed								
211	22120967	Ladies hostel Phase-II	FAN NOT WORKING IN ROOM NO. 90	Lakshmanan.V.	CEILING FAN 1NO COIL RESOLDRING WORK & FAN REFIXING WORK PROBLEM SOLVED		Malliga. K. - Canteen-Girls Hostel	24/12/2022
212	22120968	Ladies hostel Phase-II	NIGHT LAMP NOT WORKING IN ROOM NO. 14 AND GUEST ROOM	Srinivasan. R.	0.5W NIGHT LAMP 1NO CHANGED		Malliga. K. - Canteen-Girls Hostel	22/12/2022
213	22120969	Ladies hostel Phase-II	GROUND FLOOR TUBELIGHT NOT WORKING - 2 NOS	Lakshmanan.V.	36W TUBE LIGHT 2NO'S CHANG & 40W STARTER 4NO'S CHANGED		Malliga. K. - Canteen-Girls Hostel	23/12/2022
Comp. Dt. : 22/12/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
214	22121008	Ladies hostel Phase-II	TUBELIGHT NOT WORKING IN STUDY HALL	Lakshmanan.V.	36W TUBE LIGHT 2NO'S CHANG & 40W STARTER 5NO'S CHANGED		Malliga. K. - Canteen-Girls Hostel	23/12/2022
215	22121009	Ladies hostel Phase-II	TUBELIGHT NOT WORKING IN TV ROOM	Thillaikumar. R.	36W TUBE LIGHT 2NO'S CHANG & 40W STARTER 2NO'S CHANGED		Malliga. K. - Canteen-Girls Hostel	23/12/2022
216	22121011	Ladies hostel Phase-II	TUBELIGHT NOT WORKING IN ROOM NO. 97	Lakshmanan.V.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Malliga. K. - Canteen-Girls Hostel	23/12/2022
217	22121012	Ladies hostel Phase-II	TUBELIGHT NOT WORKING IN 3RD FLOOR CORRIDOR	Lakshmanan.V.	36W TUBE LIGHT 2NO'S CHANG & 40W STARTER 4NO'S CHANGED		Malliga. K. - Canteen-Girls Hostel	23/12/2022
Comp. Dt. : 23/12/2022								
Status : Completed								
218	22121086	Ladies hostel Phase-II	NEED TO CHANGE TUBELIGHT FOR 2ND FLOOR REST ROOM	Manimaran. P.	36W CHOKE 1NO CHANG & 40W STARTER 1NO CHANGED		Malliga. K. - Canteen-Girls Hostel	24/12/2022
219	22121089	Ladies hostel Phase-II	NEED TO CHANGE CORRIDOR TUBELIGHT CHOKE IN IV FLOOR	Dhakshinamoorthy. J	TUBE LIGHT 40W STARTER 1NO CHANGED		Malliga. K. - Canteen-Girls Hostel	24/12/2022
Comp. Dt. : 24/12/2022								
Status : Completed								
220	22121110	Ladies hostel Phase-II	TUBELIGHT NOT WORKING IN ROOM NO 5 & 16	Dhakshinamoorthy. J	36W TUBE LIGHT 1NO CHANG & 40W STARTER 2NO'S CHANGED		Malliga. K. - Canteen-Girls Hostel	26/12/2022
Comp. Dt. : 26/12/2022								
Status : Completed								
221	22121150	J.R Quateres	2 NOS TUBELIGHT NOT WORKING IN GROUND FLOOR STUDY HALL	Muthu. B.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Virgin Mary - Canteen-Girls Hostel	27/12/2022
222	22121151	J.R Quateres	2 NOS TUBELIGHT NOT WORKING IN 2ND FLOOR CORRIDOR	Muthu. B.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Virgin Mary - Canteen-Girls Hostel	27/12/2022
223	22121165	J.R Quateres	SWITCH BOARD PROBLEM IN GROUND FLOOR WARDEN ROOM	Muthu. B.	SWITCH BOARD CHEKING NO PROBLEM SOLVED		Virgin Mary - Canteen-Girls Hostel	28/12/2022
Comp. Dt. : 27/12/2022								
Status : Completed								
224	22121206	J.R Quateres	IN ROOM NO.11 AND 16 TUBELIGHT NOT WORKING	Muthu. B.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 2NO'S CHANGED		Virgin Mary - Canteen-Girls Hostel	28/12/2022
Comp. Dt. : 28/12/2022								
Status : Completed								
225	22121268	Ladies hostel Phase-II	TUBELIGHT NOT WORKING IN 3RD FLOOR REST ROOM	Dhakshinamoorthy. J	36W TUBE LIGHT 1NO CHANGED		Malliga. K. - Canteen-Girls Hostel	29/12/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
226	22121269	Ladies hostel Phase-II	FAN REGULATOR NOT WORKING IN ROOM NO, 21	Dhakshinamoorthy. J	CEILING FAN REGULATOR 1NO CHANG & LINE CONNECTION WORK PROBLEM SOLVED		Malliga. K. - Canteen-Girls Hostel	29/12/2022
227	22121270	Ladies hostel Phase-II	TUBELIGHT NOT WORKING IN ROOM NO. 20	Dhakshinamoorthy. J	36W TUBE LIGHT 1NO CHANGED		Malliga. K. - Canteen-Girls Hostel	29/12/2022
228	22121271	Ladies hostel Phase-II	STREET LIGHT NOT WORKING	Dhakshinamoorthy. J	TUBE LIGHT 40W STARTER 1NO CHANG & SIDE HOLDER 2NO'S CHANGED		Malliga. K. - Canteen-Girls Hostel	29/12/2022
229	22121302	Ladies hostel Phase-II	IN ROOM NO.40-NIGHT LAMP NEED TO BE CHANGE	Manimaran. P.	0.5W NIGHT LAMP 1NO CHANGED		Malliga. K. - Canteen-Girls Hostel	29/12/2022
230	22121303	Ladies hostel Phase-II	IN ROOM NO.84-1 TUBELIGHT NOT WORKING	Dhakshinamoorthy. J	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Malliga. K. - Canteen-Girls Hostel	29/12/2022
Comp. Dt. : 29/12/2022								
Status : Completed								
231	22121326	Ladies hostel Phase-II	IN ROOM NO.51-PLUG POINT NOT WORKING	Muthu. B.	16A socket changed.		Malliga. K. - Canteen-Girls Hostel	31/12/2022
232	22121327	Ladies hostel Phase-II	IN 2ND FLOOR-(JR SIDE) -WATER HEATER NOT WORKING IN COMMON BATHROOM	Muthu. B.,Manikandan. M.,Damodharan. V.	Water heater Element changed & 16A Socket, Top Changed - Tested OK.		Malliga. K. - Canteen-Girls Hostel	31/12/2022
233	22121328	Ladies hostel Phase-II	IN 4TH FLOOR STEPS-1 TUBELIGHT NOT WORKING	Muthu. B.	36W TUBE LIGHT 1NO CHANG & SIDE HOLDER 2NO'S CHANGED		Malliga. K. - Canteen-Girls Hostel	30/12/2022
Comp. Dt. : 30/12/2022								
Status : Completed								
234	22121363	Ladies hostel Phase-II	IN 3RD FLOOR COMMON BATHROOM-TUBELIGHT NOT WORKING	Muthu. B.	All lights checked - ok		Malliga. K. - Canteen-Girls Hostel	31/12/2022
235	22121364	Ladies hostel Phase-II	IN 4TH FLOOR COMMON BATHROOM-TUBELIGHT NOT WORKING	Muthu. B.	All lights checked - ok.		Malliga. K. - Canteen-Girls Hostel	31/12/2022
Comp. Dt. : 02/01/2023								
Status : Completed								
236	23010013	Ladies hostel Phase-I	IN MESS-1 TUBELIGHT NOT WORKING AND PLUG POINT NEED TO BE CHANGE	Muthu. B.	6A SOCKET 1NO CHANG & 6A SWITCH 2NO'S CHANG & 36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Revathy. N. - Canteen-Girls Hostel	03/01/2023
237	23010014	J.R Quateres	IN GROUND FLOOR CORRIDOR-2 NO'S TUBELIGHT NOT WORKING	Muthu. B.	9W LED LIGHT 1NO CHANG & 40W STARTER 2NO'S CHANG & 36W TUBE LIGHT 2NO'S CHANGED		Virgin Mary - Canteen-Girls Hostel	03/01/2023


Dr. KAGNE. R.N.
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
238	23010037	Ladies hostel Phase-II	IN GROUND FLOOR AND 3RD FLOOR COMMON BATHROOM-2 NO'S TUBELIGHT NOT WORKING AND ROOM NO.93-CHANGE 1 T	Lakshmanan.V.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 2NO'S CHANGED		Virgin Mary - Canteen-Girls Hostel	03/01/2023
Comp. Dt. : 05/01/2023 Status : Completed								
239	23010208	Ladies hostel Phase-II	IN ROOM NO.37 AND 15-TUBELIGHT NOT WORKING,NEED TO CHANGE	Dhakshinamoorthy. J	36W TUBE LIGHT 1NO CHANG & 40W STARTER 2NO'S CHANGED		Malliga. K. - Canteen-Girls Hostel	06/01/2023
240	23010209	Ladies hostel Phase-II	IN 3RD FLOOR-COMMON BATHROOM-1 TUBELIGHT NOT WORKING	Dhakshinamoorthy. J	36W TUBE LIGHT 1NO CHANGED		Malliga. K. - Canteen-Girls Hostel	06/01/2023
Comp. Dt. : 07/01/2023 Status : Completed								
241	23010325	Ladies hostel Phase-II	IN 2ND FLOOR CORRIDOR-1 TUBELIGHT NOT WORKING	Manikandan. M.	TUBE LIGHT FITTING WIRE LOOSE RECONNECTION WORK PROBLEM SOLVED		Malliga. K. - Canteen-Girls Hostel	09/01/2023
Comp. Dt. : 09/01/2023 Status : Completed								
242	23010348	J.R Quateres	IN 4TH FLOOR CORRIDOR-NEED NEW TUBELIGHT	Srinivasan. R.	36W TUBE LIGHT 1NO CHANG & TUBE LIGHT 2NO'S WIRE LOOSE RECONNECTION WORK PROBLEM SOLVED		Virgin Mary - Canteen-Girls Hostel	10/01/2023
243	23010352	J.R Quateres	IN 2ND FLOOR COMMON BATHROOM-5 NO'S TUBELIGHT NOT WORKING	Srinivasan. R.	36W TUBE LIGHT 2NO'S CHANGED		Virgin Mary - Canteen-Girls Hostel	10/01/2023
Comp. Dt. : 11/01/2023 Status : Completed								
244	23010445	J.R Quateres	IN 3RD FLOOR COMMON BATHROOM-HEATER SWITCH NEED TO BE CHANGE	Srinivasan. R.	16A SWITCH 1NO CHANGED		Virgin Mary - Canteen-Girls Hostel	13/01/2023
245	23010446	J.R Quateres	IN 4TH FLOOR CORRIDOR-1 TUBELIGHT NEED TO BE CHANGE	Srinivasan. R.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Virgin Mary - Canteen-Girls Hostel	13/01/2023
246	23010447	J.R Quateres	IN 2ND FLOOR COMMON BATHROOM RIGHT SIDE-1 TUBELIGHT NEED TO BE CHANGE	Srinivasan. R.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Virgin Mary - Canteen-Girls Hostel	13/01/2023
247	23010448	J.R Quateres	IN GROUND FLOOR-1 TUBELIGHT NOT WORKING	Srinivasan. R.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Virgin Mary - Canteen-Girls Hostel	13/01/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
248	23010456	Ladies hostel Phase-II	IN ROPOM NO.9 AND 24-FAN REGULATOR NOT WORKING	Srinivasan. R.	CEILING FAN REGULATOR 1NO CHANGED		Malliga. K. - Canteen-Girls Hostel	12/01/2023
249	23010457	Ladies hostel Phase-II	IN ROOM NO.95 WALL MOUNTED FAN NOT WORKING	Srinivasan. R.	WALLMOUNTING FAN 1.5MFT CAPACITOR 1NO CHANGED		Malliga. K. - Canteen-Girls Hostel	12/01/2023
Comp. Dt. : 12/01/2023 Status : Completed								
250	23010518	Ladies hostel Phase-II	IN 1ST FLOOR-COMMON BATHROOM-1 TUBELIGHT NOT WORKING	Srinivasan. R.	36W TUBE LIGHT 1NO CHANGED		Malliga. K. - Canteen-Girls Hostel	13/01/2023
251	23010519	Ladies hostel Phase-II	IN ROOM NO.104-1 TUBELIGHT NOT WORKING	Srinivasan. R.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Malliga. K. - Canteen-Girls Hostel	13/01/2023
252	23010521	Ladies hostel Phase-I	IN ROOM NO.63-1 TUBELIGHT NOT WORKING	Srinivasan. R.	TUBE LIGHT 40W STARTER 1NO CHANGED		Revathy. N. - Canteen-Girls Hostel	13/01/2023
Comp. Dt. : 13/01/2023 Status : Completed								
253	23010565	Ladies hostel Phase-II	FAN NOT WORKING IN ROOM NO 2 + TUBELIGHT NOT WORKING IN ROOM NO 75	Lakshmanan.V.	36W TUBE LIGHT 2NO'S CHANG & WALLMOUNTING FAN 1NO SERVICE WORK PROBLEM SOLVED		Malliga. K. - Canteen-Girls Hostel	18/01/2023
Comp. Dt. : 23/01/2023 Status : Completed								
254	23010810	Ladies hostel Phase-II	FAN NOT WORKING ROOM NO 115	Dhakshinamoorthy. J	CEILING FAN SWITCH WIRE LOOSE RECONNECTION WORK PROBLEM SOLVED		Malliga. K. - Canteen-Girls Hostel	24/01/2023
Comp. Dt. : 27/01/2023 Status : Completed								
255	23010965	Ladies hostel Phase-II	IN ROOM NO.47 AND 75 NEED TO CHANGE TUBELIGHT	Muthu. B.	36W TUBE LIGHT 1NO'S CHANG & 40W STARTER 3NO'S CHANGED		Malliga. K. - Canteen-Girls Hostel	30/01/2023
Comp. Dt. : 08/02/2023 Status : Completed								
256	23020281	Ladies hostel Phase-II	WATER HEATER NOT WORKING	Muthu. B.	WATER HEATER 1NO RESET WORK PROBLEM SOLVED		Malliga. K. - Canteen-Girls Hostel	13/02/2023
Comp. Dt. : 09/02/2023 Status : Completed								
257	23020336	Ladies hostel Phase-II	TUBELIGHT NOT WORKING IN ROOM NO 2,118 & WARDEN ROOM	Muthu. B.	36W TUBE LIGHT 2NO'S CHANG & 40W STARTER 1NO CHANGED		Malliga. K. - Canteen-Girls Hostel	13/02/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
258	23020337	Ladies hostel Phase-II	CEILING FAN NOT WORKING IN ROOM NO 17	Muthu. B.	CEILING FAN CAPACITOR 2.5MFT 1NO CHANGED		Malliga. K. - Canteen-Girls Hostel	14/02/2023
Comp. Dt. : 15/02/2023								
Status : Completed								
259	23020576	JR Quarters	NEED TO CHANGE TUBELIGHT FOR GROUND FLOOR STUDYHALL	Dhakshinamoorthy. J	TUBE LIGHT SIDE HOLDER 1NO CHANGED		Virgin Mary - Canteen-Girls Hostel	18/02/2023
Comp. Dt. : 16/02/2023								
Status : Completed								
260	23020611	JR Quarters	NEED TO CHANGE 5 TUBELIGHTS --2ND FLOOR	Dhakshinamoorthy. J	36W TUBE LIGHT 2NO'S CHANG & 40W STARTER 2NO'S CHANG & 36W CHOKE 1NO CHANGED		Virgin Mary - Canteen-Girls Hostel	18/02/2023
261	23020626	Ladies hostel Phase-II	ROOM NO-118 AND 79- -NEED TO CHANGE TUBELIGHTS	Dhakshinamoorthy. J	36W TUBE LIGHT 1NO CHANG & 40W STARTER 3NO'S CHANGED		Malliga. K. - Canteen-Girls Hostel	18/02/2023
Comp. Dt. : 22/02/2023								
Status : Completed								
262	23020850	Ladies hostel Phase-II	3RD FLOOR OPP.BATHROOM TUBELIGHT NOT WORKING	Srinivasan. R.	36W TUBE LIGHT 1NO CHANGED		Malliga. K. - Canteen-Girls Hostel	25/02/2023
263	23020853	JR Quarters	GROUND FLOOR VERANDA --ONE TUBELIGHT NOT WORKING AND ROOM NO-10,NEED TO CHANGE ONE TUBELIGHT	Lakshmanan.V.	Neet To 36W Tube Light 1 NO, Starter 1 NO Changed		Virgin Mary - Canteen-Girls Hostel	24/02/2023
Comp. Dt. : 28/02/2023								
Status : Completed								
264	23021056	Ladies hostel Phase-II	3RD FLOOR NEED TO CHANGE 2 TUBELIGHTS	Dhakshinamoorthy. J	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Malliga. K. - Canteen-Girls Hostel	02/03/2023
Comp. Dt. : 07/03/2023								
Status : Completed								
265	23030258	Ladies hostel Phase-II	ROOM NO. 15, 93 AND 1ST FLOOR VARANDA TUBELIGHT NOT WORKING	Srinivasan. R.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 2NO'S CHANGED		Malliga. K. - Canteen-Girls Hostel	08/03/2023
Comp. Dt. : 20/03/2023								
Status : Completed								
266	23030771	Ladies hostel Phase-II	TUBELIGHT NOT WORKING IN DINING HALL AND TV HALL - 4 NOS	Muthu. B.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Revathy. N. - Canteen-Girls Hostel	21/03/2023
267	23030772	Ladies hostel Phase-II	WATER HEATER NOT WORKING IN 4TH FLOOR	Muthu. B.	WATER HEATER 1NO RESET WORK PROBLEM SOLVED		Revathy. N. - Canteen-Girls Hostel	21/03/2023

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHAL KUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
268	23030773	Ladies hostel Phase-II	RESTROOM TUBELIGHT NOT WORKING IN ROOM NO. 78	Muthu. B.	20W TUBE LIGHT 1NO CHANGED		Revathy. N. - Canteen-Girls Hostel	21/03/2023
Comp. Dt. : 22/03/2023 Status : Completed								
269	23030931	Ladies hostel Phase-II	TUBELIGHT NOT WORKING IN ROOM NO. 67, 84	Dhakshinamoorthy. J	R.no.67 - 36W tube light 1no changed. R.no. 84 - Tube light starter 1no changed.		Malliga. K. - Canteen-Girls Hostel	23/03/2023
Comp. Dt. : 18/04/2023 Status : Completed								
270	23040555	Ladies hostel Phase-II	ROOM NO 25 TUBE LIGHT NOT WORKING , ROOM NO 6 FAN SLOWLY RUNING	Vijayaraghavan.B.	36W TUBE LIGHT 1NO CHANG & CEILING FAN CAPACIOTR 2.5MFT 1NO CHANGED		Malliga. K. - Canteen-Girls Hostel	19/04/2023
Comp. Dt. : 23/05/2023 Status : Completed								
271	23050922	Ladies hostel Phase-I	ROOM NO 12 AND 13 AC NOT WORKING	Muthu. B.	MCB TRIP ON TO WORK PROBLEM SOLVED		Revathy. N. - Canteen-Girls Hostel	24/05/2023
Comp. Dt. : 24/05/2023 Status : Completed								
272	23050961	Ladies hostel Phase-II	NEED TO CHANGE 2 FLOOR BATHROOM TIPLIGHT AND 4 FLOOR WATER HEATER	Rajan. R.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANG & HEATER 1NO RESET WORK PROBLEM SOLVED		Mallika. S. - Canteen-Girls Hostel	25/05/2023
Comp. Dt. : 15/06/2023 Status : Completed								
273	23060532	Ladies hostel Phase-I	ROOM NO-7 AND 74,NEED TO CHANGE TUBELIGHTS	Lakshmanan.V.	36W TUBE LIGHT 2NO'S CHANG & 40W STARTER 1NO CHANG & 20W TUBE LIGHT 1NO CHANGED		Revathy. N. - Canteen-Girls Hostel	16/06/2023
Comp. Dt. : 16/06/2023 Status : Completed								
274	23060586	Ladies hostel Phase-II	JR SIDE BATHROOM TUBELIGHT NOT WORKING	Suresh. V.	36W TUBE LIGHT 1NO CHANGED		Malliga. K. - Canteen-Girls Hostel	19/06/2023
Dept Name : CARDIOLOGY - Electrical Maintenance Comp. Dt. : 02/09/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
275	22090086	ECHO CARDIO GRAM	T M T BATTERY NOT WORKING	Vaithianathan.M	NEW BATTERY 12V,7AH 3NO'S CHANG & UPS CHEKING WORK PROBLEM SOLVED		Ramani Palanivel.P. - CARDIOLOGY	10/09/2022
Dept Name : Civil - Execution - Electrical Maintenance Comp. Dt. : 27/05/2023 Status : Completed								
276	23051089	COMMERCIAL BLOCK	TUBE LIGHT IS NOT WORKING IN PROJECT MANAGER ROOM	Rajan. R.	36W tube light 1no & starter 1no changed.		Pratheeshkumar. P. - Civil - Execution	27/05/2023
Dept Name : Civil - Maintenance - Electrical Maintenance Comp. Dt. : 26/07/2022 Status : Completed								
277	22070933	NEW STP	NEED TO CHECK EXHAUST FAN - ABNORMAL SOUND	Vijayaraghavan.B.	EXHAUST FAN 18" SCREW REFIXING WORK PROBLEM SOLVED		Ranganathan. K. - Civil - Maintenance	29/07/2022
Comp. Dt. : 03/09/2022 Status : Completed								
278	22090146	Ladies hostel Phase-I	NEED TO CHANGE TUBELIGHT FOR BACKSIDE OF LADIES HOSTEL PHASE- 1	Dhakshinamoorthy. J	TUBE LIGHT 40W STARTER 1NO CHANGED		Raja. V. - Civil - Maintenance	03/09/2022
Comp. Dt. : 06/12/2022 Status : Completed								
279	22120251	Animal House	1 TUBELIGHT NOT WORKING	Dhakshinamoorthy. J	TUBE LIGHT SIDE HOLDER 2NO'S CHANGED		Ranganathan. K. - Civil - Maintenance	08/12/2022
Comp. Dt. : 03/04/2023 Status : Completed								
280	23040043	Nursing College	NEED TO CHECK MOTOR SUPPLY WIRE CONNECTION IN RO PLANT AT NURSING COLLEGE	Srinivasan. R.	Wire problem - solved.		Agilan. P. - Civil - Maintenance	04/04/2023
Comp. Dt. : 06/06/2023 Status : Completed								
281	23060175	Boys hostel PH-I	VOLTAGE PROBLEM IN RO PLANT	Vijayaraghavan.B.	VOLTAGE CHEKING WORK PROBLEM SOLVED		Agilan. P. - Civil - Maintenance	07/06/2023
Dept Name : Clinical Department - Electrical Maintenance Comp. Dt. : 16/12/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
282	22120747	CLINICAL DEPARTMENT IN 3RD FLOOR	1 TUBELIGHT NOT WORKING	Vijayaraghavan.B.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Selvi. A. - Clinical Department	17/12/2022
Dept Name : Computer Department - Electrical Maintenance Comp. Dt. : 01/07/2022 Status : Completed								
283	22070047	MEDICINE	Light need fix for face finger print machine near medicine opd	Vijayaraghavan.B.	22W LED LIGTH 1NO REFIXING WORK PROBLEM SOLVED		Selvam. D. - Computer Department	05/07/2022
Comp. Dt. : 01/08/2022 Status : Completed								
284	22080012	GROUND FLOOR NEAR GENERAL MEDICINE OPD	tube light inter change for face machine	Manikandan. M.	22W LED TUBE LIGHT 1NO REFIXING WORK PROBLEM SOLVED		Selvam. D. - Computer Department	04/08/2022
Comp. Dt. : 24/08/2022 Status : Completed								
285	22080817	General Medicine - OPD	VGA and HDMI cable lay in Medicine Demo Room	Sathishkumar. R.,Lakshmanan.V.,D hakshinamoorthy. J	VGA & HDMI CABLE LAYING WORK PROBLEM SOLVED		Selvam. D. - Computer Department	20/09/2022
Comp. Dt. : 04/11/2022 Status : Completed								
286	22110159	GROUND FLOOR NEAR GENERAL MEDICINE OPD	5 amps socket need to fix in five different location for NMC	Dhakshinamoorthy. J	NMC MACHINE 6A SOCKET 3NO'S FIXING & LINE CONNECTION WORK 3NO'S NMC MACHINE FIXING WORK PROBLEM SOLV		Selvam. D. - Computer Department	10/11/2022
Comp. Dt. : 18/11/2022 Status : Completed								
287	22110744	Orthopaedics - OPD	NMC Finger print machine Relocate need power socket and lay network cable	Vijayaraghavan.B.	NMC MACHINE FIXING & LINE CONNECTION WORK PROBLEM SOLVED		Selvam. D. - Computer Department	19/11/2022
Comp. Dt. : 24/11/2022 Status : Completed								
288	22111024	EDP IN UNDERGROUND	Network cable lay	Vijayaraghavan.B.	EDP ROOM NET WORK CABLE LAYING & CASING REPER FIXING WORK PROBLEM SOLVED		Selvam. D. - Computer Department	04/02/2023
Comp. Dt. : 17/02/2023 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
289	23020663	OPHTHALMOLOGY	Changed the face machine echo to opthal opd	Thillaikumar. R.	OPHTHAL OPD ENTRANCE FACE MACHINE FIXING & LINE CONNECTION WORK PROBLEM SOLVED		Selvam. D. - Computer Department	20/02/2023
Comp. Dt. : 01/04/2023 Status : Completed								
290	23040028	EDP IN UNDERGROUND	Tubelight issue	Vengadessaperumal. K.	36W tube light 1no & stater 1no changed.		Raja.B - Computer Department	03/04/2023
Comp. Dt. : 10/04/2023 Status : Completed								
291	23040289	CLINICAL DEPARTMENT IN 3RD FLOOR	LCD POWER CABLE CHECK	Vijayaraghavan.B.	Wire problem - solved.		Valamburi. R. - Computer Department	11/04/2023
Dept Name : Derm,Pulmo,Psych Ward - Electrical Maintenance Comp. Dt. : 20/12/2022 Status : Completed								
292	22120937	PSYCHIATRY WARD	FAN SERVICE	Lakshmanan.V.	ALL CEILING FAN CEILING WORK PROBLEM SOLVED		Sarathkumar. R. - Derm,Pulmo,Psych Ward	21/12/2022
Comp. Dt. : 04/02/2023 Status : Completed								
293	23020128	Male Psychiatry - Ward 405	NEED TO CHANGE TUBELIGHT FOR CARITOR	Lakshmanan.V.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Sarathkumar. R. - Derm,Pulmo,Psych Ward	06/02/2023
Dept Name : EMERGENCY MEDICINE - Electrical Maintenance Comp. Dt. : 19/10/2022 Status : Completed								
294	22100646	Female Casualty	(1016) 2TUBELIGHTS NOT WORKING AND ONE FAN ALSO NOT WORKING	Lakshmanan.V.	FAN & LIGHT WIRE SHORT CIRCUIT NEW WIRING WORK LINE CONNECTION WORK PROBLEM SOLVED		Seethalakshmi. R. - EMERGENCY MEDICINE	21/10/2022
Comp. Dt. : 10/05/2023 Status : Completed								
295	23050407	Casualty	ROOM 28 LIGHT NOT WORKING	Lakshmanan.V.	36W TUBE LIGHT 1NO CHANGED		Devi. S - EMERGENCY MEDICINE	11/05/2023
296	23050408	MAIN CASUALTY	POWER NOT COME	Lakshmanan.V.	MCB TRIP ON TO WORK PROBLEM SOLVED		Kanimozhi. E. - EMERGENCY MEDICINE	11/05/2023
Dept Name : ENT & Ophthal Ward - Electrical Maintenance Comp. Dt. : 02/09/2022								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
297	22090104	ENT WARD-408	TUBELIGHT NOT WORKING	Lakshmanan.V.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Jayalakshmi. J. - ENT & Ophthal Ward	03/09/2022
Dept Name : Female Ortho Ward - Electrical Maintenance Comp. Dt. : 16/09/2022								
Status : Completed								
298	22090651	Female Ortho - Ward 402	NEED TO CHECK EXTN BOX SWITCH - NOT WORKING	Muthu. B.	ALL SWITCH BOARD CHEKING WORK NO COMPLAINT		Dhansulakshmi. K. - Female Ortho Ward	17/09/2022
Comp. Dt. : 18/04/2023								
Status : Completed								
299	23040556	Female ENT - Ward 402	DOCTOR ROOM FAN SOUND CAMEING	Manimaran. P.	CEILING FAN CUP SCREW REFIXING WORK PROBLEM SOLVED		Punithavathi. E. - Female Ortho Ward	20/04/2023
Dept Name : Guest House - Indian Bank - Electrical Maintenance Comp. Dt. : 02/11/2022								
Status : Completed								
300	22110046	Guest House - Indian Bank	2 NO'S TUBELIGHT NOT WOKRING IN RECEPTION AREA	Srinivasan. R.	36W TUBE LIGHT 2NO'S CHANG & 40W STARTER 2NO'S CHANG & 36W CHOKE 1NO CHANGED		John. H. - Guest House - Indian Bank	05/11/2022
Comp. Dt. : 09/11/2022								
Status : Completed								
301	22110361	Guest House - Indian Bank	IN STORE ROOM-2 NO'S LED BULB NEED TO BE CHANGE	Lakshmanan.V.	9W LED LIGHT 1NO CHANGED		John. H. - Guest House - Indian Bank	15/11/2022
Comp. Dt. : 22/11/2022								
Status : Completed								
302	22110928	Guest House - Indian Bank	NEED TO CHANGE 18WATTS TUBELIGHT 4NOS FOR REST ROOM & TUBELIGHT FOR "GUEST HOUSE NAME BOARD"	Rajan. R.	36W TUBE LIGHT 1NO CHANG & 36W CHOKE 1NO CHANGED		John. H. - Guest House - Indian Bank	15/12/2022
Comp. Dt. : 29/12/2022								
Status : Completed								
303	22121331	Guest House - Indian Bank	IN ROOM NO.105-CFL BULB NOT WORKING-REQUEST TO CHANGE IT AS A LED BULB WITH CHOKE	Rajan. R.	9W LED lamp 1no changed.		John. H. - Guest House - Indian Bank	31/12/2022
Comp. Dt. : 10/02/2023								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
304	23020404	Guest House - Indian Bank	ROOM NO 206 CFL CHANGED TO LED WITH CHOKE	Manikandan. M.	9W LED LIGHT 1NO CHANG & BABY HOLDER 1NO CHANGED		John. H. - Guest House - Indian Bank	14/02/2023
Comp. Dt. : 16/02/2023								
Status : Completed								
305	23020633	Guest House - Indian Bank	ROOM NO-102,NEED TO CHANGE LED BULP AND PORTICO TUBELIGHT ALSO CHANGE	Manikandan. M.	9W LED LIGHT 2NO'S CHANG & BABY HOLDER 2NO'S CHANGED		John. H. - Guest House - Indian Bank	17/02/2023
306	23020634	Guest House - Indian Bank	ROOM NO-104 AND 105,TUBELIGHTS NOT WORKING	Manikandan. M.	36W TUBE LIGHT 2NO'S CHANGED		John. H. - Guest House - Indian Bank	17/02/2023
Comp. Dt. : 22/02/2023								
Status : Completed								
307	23020864	Guest House - Indian Bank	ROOM NO-205,BED ROOM TOP LIGHT NOT WORKING	Manikandan. M.	18W CFL LIGHT 3NO'S CHANGED		John. H. - Guest House - Indian Bank	25/02/2023
308	23020865	Guest House - Indian Bank	REST ROOM CFL NOT WORKING.NEED TO CHANGE LED WITH CHOKE	Manikandan. M.	18W CFL LIGHT 3NO'S CHANGED		John. H. - Guest House - Indian Bank	25/02/2023
Comp. Dt. : 31/05/2023								
Status : Completed								
309	23051249	Guest House - Indian Bank	HEATER NOT WORKING ROOM NO 102	Vijayaraghavan.B.	NEW WATER HEATER 10LTR 1NO FIXING & LINE CONNECTION WORK PROBLEM SOLVED		John. H. - Guest House - Indian Bank	30/06/2023
Dept Name : Gynac Ward - Electrical Maintenance								
Comp. Dt. : 13/12/2022								
Status : Completed								
310	22120587	Obstetrics - Ward 208	HEATER NOT WORKING	Thillaikumar. R.	WATER HEATER NEW 2KW COIL 1NO CHANG & LINE CONNECTION WORK PROBLEM SOLVED		Amsavalli. S. - Gynac Ward	19/12/2022
Comp. Dt. : 24/12/2022								
Status : Completed								
311	22121107	Obstetrics - Ward 207	REST ROOM TUBELIGHT NOT WORKING	Dhakshinamoorthy. J	36W TUBE LIGHT 1NO CHANGED		Ashwini. V. - Gynac Ward	26/12/2022
Comp. Dt. : 12/05/2023								
Status : Completed								
312	23050466	Obstetrics - Ward 208	NEED TO CHECK FAN - SLOW PROBLEM	Damodharan. V.	Fan capacitor 2.5mfd 1no changed.		Dayana Supriya. A. - Gynac Ward	12/05/2023
Dept Name : Housekeeping - Electrical Maintenance								

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 07/11/2022 Status : Completed								
313	22110205	COMMERCIAL BLOCK	TUBELIGHT NOT WORKING IN 2ND FLOOR CORRIDOR	Manikandan. M.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Naresh. R - Housekeeping	10/11/2022
Comp. Dt. : 16/03/2023 Status : Completed								
314	23030662	HOUSEKEEPING DEPT	ROOT MACHINE HOLDER BROKEN NEED TO REFIX	Rajan. R.	16A 3PIN TOP 1NO CHANGED		Naresh. R - Housekeeping	16/03/2023
Comp. Dt. : 10/05/2023 Status : Completed								
315	23050406	Paediatrics - Ward 309	RESTROOM LIGHT PROBLEM	Dhakshinamoorthy. J	TUBE LIGHT SIDE HOLDR 2NO'S CHANGED		Vengadesan. K. - Housekeeping	11/05/2023
Dept Name : ICCU - Electrical Maintenance Comp. Dt. : 29/10/2022 Status : Completed								
316	22100954	Mit ladies hostel	STAFF SIDE HEATER NOT WORKING	Lakshmanan.V.	WATER HEATER 1NO RESET WORK PROBLEM SOLVED		Ammu. R. - ICCU	31/10/2022
Comp. Dt. : 14/11/2022 Status : Completed								
317	22110547	Mit ladies hostel	IN DINING HALL-1 TUBELIGHT NOT WORKING	Muthu. B.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 3NO'S CHANG & 36W CHOKE 1NO CHANGED		Ammu. R. - ICCU	15/11/2022
318	22110548	Mit ladies hostel	IN DINING HALL-FAN NOISE PROBLEM	Srinivasan. R.	CEILING FAN BEARING 2NO'S CHANGED		Ammu. R. - ICCU	18/11/2022
Comp. Dt. : 15/11/2022 Status : Completed								
319	22110579	Mit ladies hostel	IN GROUND FLOOR ROOM NO.11-STAFF ROOM-1 TUBELIGHT NOT WORKING	Srinivasan. R.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Ammu. R. - ICCU	17/11/2022
320	22110623	Mit ladies hostel	ROOM NO.10 FAN NOT WORKING AND ROOM NO.11 1 TUBELIGHT NOT ON STAFF SIDE	Srinivasan. R.	CEILING FAN 1NO REWINDING & BEARING 2NO'S CHANG & FAN REFIXING WORK PROBLEM SOLVED		Ammu. R. - ICCU	28/11/2022
321	22110624	Mit ladies hostel	WATER HEATER NOT WORKING ON GROUND FLOOR STAFF SIDE BATHROOM	Srinivasan. R.	WATER HEATER RESET WORK PROBLEM SOLVED		Ammu. R. - ICCU	17/11/2022
Comp. Dt. : 16/11/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
322	22110657	Mit ladies hostel	TV NOT WORKING IN STAFF SIDE	Lakshmanan.V.	TV SERVICE WORK PROBLEM SOLVED		Ammu. R. - ICCU	19/11/2022
Comp. Dt. : 19/11/2022 Status : Completed								
323	22110828	Mit ladies hostel	GROUND FLOOR-STAFF SIDE BATHROOM-WATER HEATER NOT WORKING	Muthu. B.	WATER HEATER RESET WORK PROBLEM SOLVED		Ammu. R. - ICCU	21/11/2022
Comp. Dt. : 26/12/2022 Status : Completed								
324	22121158	Mit ladies hostel	TUBELIGHT NOT WORKING IN STAFF NURSES ROOM	Muthu. B.	36W TUBE LIGHT 1NO CHANGED		Ammu. R. - ICCU	27/12/2022
Comp. Dt. : 10/01/2023 Status : Completed								
325	23010428	Mit ladies hostel	IN STAFF NURSE SIDE-GROUND FLOOR-ROOM NO.3 AND 4-1 TUBELIGHT NOT WORKING AND FAN SOUND PROBLEM IN RO	Srinivasan. R.	TUBE LIGHT 36W CHOKE 1NO CHANG & 40W STARTER 1NO CHANGED		Ammu. R. - ICCU	11/01/2023
Dept Name : Labour Ward - Electrical Maintenance Comp. Dt. : 17/12/2022 Status : Completed								
326	22120796	Labour Room	NEED TO CHANGE TUBELIGHT 2 NOS	Manikandan. M.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 2NO'S CHANGED		Brema. V. - Labour Ward	19/12/2022
Dept Name : Male Ortho Ward - Electrical Maintenance Comp. Dt. : 20/02/2023 Status : Completed								
327	23020767	Male Ortho - Ward 404	HEATER NOT WORKING	Vijayaraghavan.B.	WATER HEATER 1NO RESET WORK PROBLEM SOLVED		Gayathri. S. - Male Ortho Ward	21/02/2023
Dept Name : Male Surgery - Electrical Maintenance Comp. Dt. : 23/05/2023 Status : Completed								
328	23050923	Male Medical - Ward 303	NEED TO CHANGE FAN	Lakshmanan.V.	CEILING FAN CAPACITOR 2.5MFT 1NO CHANGED		Tharma. S. - Male Surgery	24/05/2023
Dept Name : Marketing Team - Electrical Maintenance Comp. Dt. : 16/03/2023 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
329	23030665	Special Ward - A	ROOM NO 5 TUBELIGHT NOT WORKING	Muthu. B.	36W 4pin CFL 1no changed.		Vijayalakshmi. V. - Marketing Team	18/03/2023
Dept Name : Medical Records - Electrical Maintenance Comp. Dt. : 23/09/2022 Status : Completed								
330	22090908	Medical Records	NEED TO CHANGE TUBELIGHT FOR MRD ENTRANCE	Muthu. B.	36W TUBE LIGHT 1NO CHANG & 36W CHOKE 1NO CHANGED		Martin Prabu.V. - Medical Records	23/09/2022
Dept Name : MS Office - Electrical Maintenance Comp. Dt. : 10/05/2023 Status : Completed								
331	23050405	CLINICAL DEPARTMENT IN 3RD FLOOR	POWER NOT COME	Thillaikumar. R.	MCB TRIP ON TO WORK PROBLEM SOLVED		Pushpa. V. - MS Office	10/05/2023
Dept Name : Nursing Office - Electrical Maintenance Comp. Dt. : 10/05/2023 Status : Completed								
332	23050411	PAEDIATRICS	NURSING STATION FAN PBOBLEM	Damodharan. V.	CEILING FAN 1NO REWINDING & BEARING CHANG & FAN REFIXING WORK PROBLEM SOLVED		Powlin.P. - Nursing Office	19/05/2023
Dept Name : OPD - Electrical Maintenance Comp. Dt. : 02/09/2022 Status : Completed								
333	22090057	Orthopaedics - OPD	need tube light change to room No-62	Muthu. B.	TUBE LIGHT 40W STARTER 1NO CHANGED		Durgadevi. J - OPD	03/09/2022
Comp. Dt. : 10/05/2023 Status : Completed								
334	23050415	MEDICINE	FAN NOT WORKING	Damodharan. V.	CEILING FAN CAPACITOR 2.5MFT 1NO CHANGED		Sivaranjani. P. - OPD	11/05/2023
Dept Name : Operation Theatre - Electrical Maintenance Comp. Dt. : 02/09/2022 Status : Completed								
335	22090085	Main OT	ELECTRICAL BOARD REPAIR	Srinivasan. R.	SWITCH BOARD SCREW REFIXING WORK PROBLEM SOLVED		Shankari. G. - Operation Theatre	05/09/2022
Comp. Dt. : 20/10/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
336	22100702	ORTHO OT	TUBELIGHTS NOT WORKING IN ORTHO OT ROOM NO:3 AND ORTHO OT FEMALE DRESS CHANGING ROOM	Muthu. B.	9W LED LIGHT 1NO CHANGED		Shankari. G. - Operation Theatre	22/10/2022
Dept Name : Pharmacy - Electrical Maintenance Comp. Dt. : 03/12/2022 Status : Completed								
337	22120138	Mit ladies hostel	WATER HEATER NOT WORKING IN STAFF REST ROOM	Dhakshinamoorthy. J	WATER HEATER 15LTR 1NO COIL SET CHANG & 2KW COIL 1NO CHANG & HEATER REFIXING WORK PROBLEM SOLVED		Gowsalya. V. - Pharmacy	02/01/2023
Dept Name : Power Laundry - Electrical Maintenance Comp. Dt. : 09/05/2023 Status : Completed								
338	23050354	Power Laundry	NO-1 DRYER WIRE BRUNS CHANGE THE WIRE	Damodharan. V.	DRYER IN COMING WIRE R-PHASE CUT RECONNECTION WORK PROBLEM SOLVED		Manikandan.M - Power Laundry	10/05/2023
Dept Name : Security - Stalwalt Security Servies - Electrical Maintenance Comp. Dt. : 17/12/2022 Status : Completed								
339	22120824	Labour Room	IN ENTRANCE -FLOOR AREA-1 TUBELIGHT NOT WORKING PROPERLY	Manikandan. M.	CEILING FAN CAPACITOR 2.5MFT 1NO CHANGED		Devi. K. - Security - Stalwalt Security Servies	19/12/2022
Dept Name : Special Ward - Electrical Maintenance Comp. Dt. : 28/11/2022 Status : Completed								
340	22111160	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	CEILING FAN NOT WORKING	Vijayaraghavan.B.	UPS LINE SINGLE POLE MCB TRIP ON TO WORK PROBLEM SOLVED		Elakkiya. S. - Special Ward	29/11/2022
Comp. Dt. : 20/12/2022 Status : Completed								
341	22120934	Special Ward - A	ROOM NO 7 CELLING LIGHT NOT WORKING	Muthu. B.	9W LED LIGHT 1NO CHANGED		Kowsalya. A. - Special Ward	21/12/2022
Comp. Dt. : 18/04/2023 Status : Completed								
342	23040545	Special Ward - A	NEED TO CHANGE TUBELIGHT ROOM NO 6 (BATH ROOM)	Manimaran. M.	9W LED LIGHT 1NO CHANGED		evathi. S. - Special Ward	19/04/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 10/05/2023 Status : Completed								
343	23050412	SPECIAL WARD A1-FOURTH FLOOR	FAN PROBLEM	Damodharan. V.	CEILING FAN CHEKING WORK NO COMPLAINT		Sangeetha. S. - Special Ward	11/05/2023
Dept Name : Tele Exchange - Electrical Maintenance Comp. Dt. : 23/12/2022 Status : Completed								
344	22121062	MEDICAL COLLEGE -- -BOYS HOSTEL	5 NO'S CAMERA FIXING WORK	Thillaikumar. R.	NEW CAMERA 5NO'S FIXING & WIRING WORK PROBLEM SOLVED		Vivek. A. - Tele Exchange	24/12/2022
345	22121063	MEDICAL COLLEGE -- -BOYS HOSTEL	EXTENSION BOX NEED TO BE FIXED	Thillaikumar. R.	18M SURFACE BOX 1NO,18M PLATE 1NO,6A SOCKET 8NO'S CHANG & 6A 3PIN TOP 1NO CHANGED		Vivek. A. - Tele Exchange	24/12/2022
346	22121064	Casualty	I CAMERA NEED TO BE FIXED	Manimaran. M.	NEW CAMERA 1NO FIXING WORK PROBLEM SOLVED		Vivek. A. - Tele Exchange	24/12/2022
Dept Name : Transport - Electrical Maintenance Comp. Dt. : 20/12/2022 Status : Completed								
347	22120931	TRANSPORT DEPARTMENT IN COMMERCIAL COMPLEX	TUBE LIGHT NOT WORKING - 1 NOS	Lakshmanan.V.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Sasikumar. P. - Transport	21/12/2022
Comp. Dt. : 10/01/2023 Status : Completed								
348	23010390	BUS SHED IN HOSPITAL CAMPUS	NEW MOTOR CONNECTION NEED TO GIVE	Lakshmanan.V.	3PHASE MOTOR LINE CONNECTION WORK PROBLEM SOLVED		Sasikumar. P. - Transport	11/01/2023
Dept Name : UHC Villupuram - Electrical Maintenance Comp. Dt. : 19/11/2022 Status : Completed								
349	22110804	VILLUPURAM PHC	NEED TO CHECK POWER - LEFT SIDE ELETRICAL ITEMS NOT WORKING	Dhakshinamoorthy. J	MCB TRIP ON TO WORK PROBLEM SOLVED		Sankari. J. - UHC Villupuram	21/11/2022
Work Type : Work Dept Name : Canteen-Girls Hostel - Electrical Maintenance Comp. Dt. : 09/11/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
350	22110375	Ladies hostel Phase-I	IN 4TH FLOOR-TOTAL 10 ROOMS-REQUEST TO GIVE NEW ELECTRICAL CONNECTION POINT FOR A/C FITTING PURPOSE	Lakshmanan.V.,Mani kandan. M.,Sathishkumar. R.	NEW A/C 25A SWITCH 10NO,25A SOCKET 10NO,2M SURFACE BOX 20NO'S,16A 3PIN TOP 10NO'S,20A SINGLE POLE MC		Malliga. K. - Canteen-Girls Hostel	29/11/2022
College Name : SMVMCH-COL								
Work Type : Complaint								
Dept Name : Canteen - Boys Hostel - Electrical Maintenance								
Comp. Dt. : 08/10/2022								
Status : Completed								
351	22100175	Boys hostel P.H-III	TUBE LIGHT NOT WORKING IN ROOM NO. 1	Vijayaraghavan.B.	36W TUBE LIGHT CHOKE 1NO CHNGED		Sambasivam. K. - Canteen - Boys Hostel	10/10/2022
352	22100176	Boys hostel P.H-III	LIFT DOOR REPAIR WORK AND LIFT DOOR NOT WORKING	Sathishkumar. R.	LIFT DOOR SERVICER WORK PROBLEM SOLVED		Sambasivam. K. - Canteen - Boys Hostel	10/10/2022
Dept Name : Canteen-Girls Hostel - Electrical Maintenance								
Comp. Dt. : 02/09/2022								
Status : Completed								
353	22090076	Ladies hostel Phase-I	TUBELIGHT NOT WORKING IN ROOM NO. 53	Manikandan. M.	20W TUBE LIGHT 1NO CHANGED		Revathy. N. - Canteen-Girls Hostel	03/09/2022
354	22090099	J.R Quateres	1ST AND 2ND FLOOR RESTROOM HEATER NOT WORKING	Manikandan. M.	WATER HEATER NEW 2KW COIL 1NO CHANG & THERMO CUT 1NO CHANG & THERMO START 1NO CHANGED & 2ND FLOOR WA		Virgin Mary - Canteen-Girls Hostel	03/09/2022
355	22090100	J.R Quateres	NEED SET TOP BOX ADAPTER IN FIRST FLOOR	Vengadessaperumal. K.	SETUP BOX ADAPTER 1NO CHANGED		Virgin Mary - Canteen-Girls Hostel	03/09/2022
356	22090109	Ladies hostel Phase-II	TUBE LIGHT AND HEATER NOT WORKING IN GROUND FLOOR	Manikandan. M.	WATER HEATER NEW 2KW COIL 1NO CHANG & HEATER CHEKING WORK PROBLEM SOLVED		Malliga. K. - Canteen-Girls Hostel	05/09/2022
Comp. Dt. : 17/09/2022								
Status : Completed								
357	22090668	J.R Quateres	ROOM NO.96 TUBE LIGHT NOT WORKING	Lakshmanan.V.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Virgin Mary - Canteen-Girls Hostel	19/09/2022
Comp. Dt. : 08/10/2022								
Status : Completed								
358	22100184	Ladies hostel Phase-I	TUBE LIGHT NOT WORKING	Muthu. B.	36W TUBE LIGHT 1NO CHANG & 36W CHOKE 1NO CHANGED		Revathy. N. - Canteen-Girls Hostel	10/10/2022

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 02/05/2023 Status : Completed								
359	23050033	JR Quarters	T V NOT WORKING	Muthu. B.	1+ TV DISPLAY PROBLEM SERVICE WORK		Virgin Mary - Canteen-Girls Hostel	05/05/2023
Dept Name : Computer Department - Electrical Maintenance Comp. Dt. : 01/07/2022 Status : Completed								
360	22070008	MEDICAL COLLEGE GROUND FLOOR	NEED BIOMETRIC FINGER PRINT ISTALLATION WORK AT READING HALL I	Manimaran. P.	BIOMETRIC FINGER PRINT MACHINE FIXING WORK PROBLEM SOLVED		Jayaraj. J. - Computer Department	02/07/2022
Comp. Dt. : 11/01/2023 Status : Completed								
361	23010486	MEDICAL COLLEGE	CAMERA FIXING WORK-NEED TO GIVE ELECTRICAL CONNECTION	Vijayaraghavan.B.	NEW CAMERA 1NO FIXING WORK PROBLEM SOLVED		Raja.B - Computer Department	12/01/2023
Comp. Dt. : 02/03/2023 Status : Completed								
362	23030059	DIRECTOR QUATERS	NEED PIPE FIXING WORK FOR CAMERA	Srinivasan. R.	NEW CAMERA FIXING WORK PROBLEM SOLVED		Prakash. P. - Computer Department	03/03/2023
Work Type : Network Cables Dept Name : Computer Department - Electrical Maintenance Comp. Dt. : 08/03/2023 Status : Completed								
363	23030305	COMMUNITY MEDICINE DEPT IN MEDICAL COLLEGE	NEED NET WORK CABLE LAYING WORK	Azhagappan. J.	Data cable layed. (Balamurugan)		Shafiullah. R. - Computer Department	10/04/2023
College Name : SMVMCH-HOS Work Type : Complaint Dept Name : Administration - Electrical Maintenance Comp. Dt. : 18/05/2022 Status : Completed								
364	22050673	General Stores[Linen]	NEED TO CHANGE TUBELIGHT	Muthu. B.	36W TUBE LIGHT 1NO CHANG & 36W CHOKE 1NO CHANGED		Arulkumaran. S. - Administration	20/05/2022
Comp. Dt. : 31/05/2022 Status : Completed								
365	22051141	AO Office	NEED TO CHANGE TUBELIGHT [2 NOS] FOR FEMALE RESTROOM	Dhakshinamoorthy. J	TUBE LIGHT 36W CHOKI 1NO CHANG & 40W STARTER 1NO CHANGED	 Dr. KAGNE. R.N DEAN SRI MANAKULA VINAYAGAR MEDICAL COLLEGE & HOSPITAL KALITHEERTHAL KUPPAM, PUDUCHERRY-605107.	mathy. K. - Administration	01/06/2022

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
366	22051143	General Stores[Linen]	NEED TO CHANGE TUBELIGHT	Dhakshinamoorthy. J	TUBE LIGHT 36W CHOKE 1NO CHANGED		Motheeswarar. R.S. - Administration	01/06/2022
	Comp. Dt. : 07/06/2022							
	Status : Completed							
367	22060273	AO Office	FAN SOUND PROBLEM	Muthu. B.	CEILING FAN CAPACITOR LOOSE SCREW REFIXING WORK PROBLEM SOLVED		Kavitha. P. - Administration	08/06/2022
	Comp. Dt. : 14/06/2022							
	Status : Completed							
368	22060499	AO Office	NEED TO CHANGE LED LIGHT [1 NO] FOR REGISTRAR OFFICE	Vengadessaperumal. K.	LED Driver connector problem - solved.		Kanimozhi. D. - Administration	14/06/2022
	Comp. Dt. : 30/06/2022							
	Status : Completed							
369	22061127	AO Office	NEED TO CHANGE TUBELIGHT FOR MALE REST ROOM	Muthu. B.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Karthik. K. - Administration	01/07/2022
	Comp. Dt. : 09/07/2022							
	Status : Completed							
370	22070382	General Stores[Linen]	NEED TO CHANGE TUBELIGHT NEAR ENTRANCE STEPS	Sathishkumar. R.	36W TUBE LIGHT 1NO CHANGED		Arul. E. - Administration	11/07/2022
	Comp. Dt. : 12/07/2022							
	Status : Completed							
371	22070466	General Stores[Linen]	NEED TO CHANGE TUBELIGHT	Rajan. R.	36W TUBE LIGHT 1NO CHANG & 36W CHOKE 1NO CHANGED		Arul. E. - Administration	12/07/2022
	Comp. Dt. : 03/08/2022							
	Status : Completed							
372	22080109	AO Office	NEED TO CHANGE CEILING LIGHT NEAR WASH BASIN	Lakshmanan.V.	18W LED ROUNT LIGHT 1NO CHANGED		Karthik. K. - Administration	04/08/2022
	Comp. Dt. : 03/09/2022							
	Status : Completed							
373	22090125	General Stores[Linen]	NEED TO CHANGE TUBELIGHT	Suresh. V.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Motheeswarar. R.S. - Administration	03/09/2022
374	22090137	AO Office	FAN SLOW & SOUND PROBLEM	Rajan. R.	PEDESTAL FAN SERVICE WORK PROBLEM SOLVED		Nitheeshkumar. D. - Administration	07/09/2022
	Comp. Dt. : 06/09/2022							
	Status : Completed							


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
375	22090211	Chairman Office	NEED TO CHANGE TUBELIGHT FOR DINNING HALL - NEED URGENT SERVICE	Rajan. R.	9W LED ROUNT LIGHT 1NO CHANGED		Sadhasivam. K. - Administration	06/09/2022
Comp. Dt. : 07/09/2022 Status : Completed								
376	22090293	AO Office	SYSTEM - EARTH PROBLEM	Lakshmanan.V.	VOLTAGE CHEKING WORK PROBLEM SOLVED		Kanimozhi. D. - Administration	09/09/2022
377	22090295	MEDICAL COLLEGE OPP FOUNTAIN	NEED TO CLOSE D B BOX - NEED URGENT SERVICE	Lakshmanan.V.	DB COVER 1NO REFIXING WORK PROBLEM SOLVED		Sathiyamoorthy. D. - Administration	08/09/2022
Comp. Dt. : 16/09/2022 Status : Completed								
378	22090629	General Stores[Linen]	NEED TO CHANGE TUBELIGHT	Muthu. B.	36W TUBE LIGHT 1NO CHANG & 36W CHOKE 1NO CHANGED		Arulkumaran. S. - Administration	16/09/2022
Comp. Dt. : 24/09/2022 Status : Completed								
379	22090959	MEDICAL STORE IN BASEMENT	NEED ALL FAN CLEANING WORK	Vijayaraghavan.B.	ALL CEILING FAN CLEANING WORK PROBLEM SOLVED		Sathiyamoorthy. D. - Administration	03/12/2022
Comp. Dt. : 13/10/2022 Status : Completed								
380	22100431	General Stores[Linen]	NEED TO CHANGE TUBELIGHT 3 NOS	Vijayaraghavan.B.	36W TUBE LIGHT 2NO'S CHANG & 40W STARTER 2NO'S CHANGED		Motheeswarar. R.S. - Administration	14/10/2022
Comp. Dt. : 14/10/2022 Status : Completed								
381	22100479	AO Office	NEED TO CHANGE TUBE LIGHT	Manikandan. M.	TUBE LIGHT CHEKING WORK NO COMPLAINT		Elumalai.K.A. - Administration	15/10/2022
Comp. Dt. : 21/10/2022 Status : Completed								
382	22100741	GENERAL STORE	FRIDGE NOT WORKING	Muthu. B.	FRIDGE CHEKING NO COMPLAINT A/C DEPT COMPLAINT		Manikandan. S. - Administration	22/10/2022
Comp. Dt. : 04/11/2022 Status : Completed								
383	22110144	AO Office	IN LADIES TOILET-2 NO'S TUBELIGHT NOT WORKING	Muthu. B.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 2NO'S CHANGED		Gomathy. K. - Administration	05/11/2022
Comp. Dt. : 09/11/2022								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
384	22110331	AO Office	LED LIGHT NOT WORKING	Manimaran. P.	15W ROUND LED LIGHT CHOKE 1NO CHANG & FITTING REFIXING WORK PROBLEM SOLVED		Karthik. K. - Administration	31/01/2023
Comp. Dt. : 28/11/2022								
Status : Completed								
385	22111177	GENERAL STORE	3 NO'S TUBELIGHT NOT WORKING	Manikandan. M.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 2NO'S CHANGED		Arulkumaran. S. - Administration	29/11/2022
Comp. Dt. : 29/11/2022								
Status : Completed								
386	22111247	GENERAL STORE	1 TUBELIGHT NOT WORKING	Manikandan. M.	36W tube light 1no & E.choke 1no changed.		Manikandan. S. - Administration	29/11/2022
Comp. Dt. : 09/12/2022								
Status : Completed								
387	22120445	AO Office	NEED TO CHECK TABLE FAN - SOUND PROBLEM	Dhakshinamoorthy. J	PEDESTAL FAN CHEKING WORK PROBLEM SOLVED		Nitheeskumar. D. - Administration	17/12/2022
Comp. Dt. : 14/12/2022								
Status : Completed								
388	22120657	AO Office	NEED TO CHANGE CEILING LIGHT FOR FEMALE RESTROOM OPPOSITE ROOM	Dhakshinamoorthy. J	9W LED LIGHT 1NO CHANGED		Gomathy. K. - Administration	15/12/2022
Comp. Dt. : 24/01/2023								
Status : Completed								
389	23010882	General Stores[Linen]	NEED TO CHANGE TUBELIGHT	Lakshmanan.V.	TUBE LIGHT 40W STARTER 1NO CHANGED		Motheeswarar. R.S. - Administration	25/01/2023
Comp. Dt. : 02/02/2023								
Status : Completed								
390	23020067	General Stores[Linen]	NEED ALL FAN CLEANING WORK	Vengadessaperumal. K.	ALL CEILING FAN CLEANING WORK PROBLEM SOLVED		Motheeswarar. R.S. - Administration	04/02/2023
Comp. Dt. : 03/02/2023								
Status : Completed								
391	23020089	General Stores[Linen]	NEED TO CHANGE TUBELIGHT	Manimaran. P.	TUBE LIGHT 40W STARTER 40W STARTER 1NO CHANGED		Arul. E. - Administration	04/02/2023
392	23020113	AO Office	NEED TO CHANGE CEILING LIGHT FOR RECORD ROOM	Manikandan. M.	LED 15W DRIVER 1NO CHANGED		Gunavathi. S. - Administration	04/02/2023
Comp. Dt. : 06/02/2023								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
393	23020207	General Stores[Linen]	NEED TO REFIX WALL FAN	Rajan. R.	WALLMOUNTING FAN CLEANING WORK & FAN REFIXING WORK PROBLEM SOLVED		Motheeswarar. R.S. - Administration	07/02/2023
Comp. Dt. : 10/02/2023								
Status : Completed								
394	23020386	AO Office	CEILING LIGHT NOT WORKING	Vijayaraghavan.B.	15w round led fitting 1 nos changed		Kavitha. P. - Administration	10/02/2023
Comp. Dt. : 03/03/2023								
Status : Completed								
395	23030142	AO Office	NEED TO CHANGE TUBELIGHT	Srinivasan. R.	TUBE LIGHT 36W CHOKE 1NO CHANGED		Karthik. K. - Administration	04/03/2023
Comp. Dt. : 06/03/2023								
Status : Completed								
396	23030222	General Stores[Linen]	NEED TO CHANGE TUBELIGHT --NEAR STEPS	Damodharan. V.	TUBE LIGHT 40W STARTER 1NO CHANGED		Arulkumaran. S. - Administration	07/03/2023
Comp. Dt. : 22/03/2023								
Status : Completed								
397	23030933	AO Office	NEED TO CHANGE TUBELIGHT [5 NOS]	Muthu. B.	36W tube light 3no's, E.choke 36W 1no & starter 1no changed.		Kadhiravan. C. - Administration	23/03/2023
Comp. Dt. : 29/03/2023								
Status : Completed								
398	23031260	General Stores[Linen]	NEED TO CHANGE LED LIGHT FOR INSIDE STORE & TUBELIGHT FOR NEAR STEPS	Thillaikumar. R.	9W LED lamp 1no changed & starter 1no changed.		Motheeswarar. R.S. - Administration	30/03/2023
Comp. Dt. : 12/04/2023								
Status : Completed								
399	23040376	General Stores[Linen]	NEED TO CHANGE TUBELIGHT	Manimaran. M.	36W tube light 1no & starter 1no changed.		Arulkumaran. S. - Administration	12/04/2023
Comp. Dt. : 04/05/2023								
Status : Completed								
400	23050146	AO Office	NEED TO CHANGE TUBELIGHT FOR RESTROOM	Rajan. R.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Siva. E. - Administration	09/05/2023
Comp. Dt. : 11/05/2023								
Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
401	23050450	AO Office	NEED TO CHANGE TUBELIGHT FOR MALE RESTROOM	Babu. D.	TUBE LIGHT 40W STARTER 1NO CHANGED		Karthik. K. - Administration	11/05/2023
Comp. Dt. : 05/06/2023 Status : Completed								
402	23060137	AO Office	NEED TO CHANGE REST ROOM ENTRANCE LIGHT [9WATT]	Lakshmanan.V.	9W LED LIGHT 1NO CHANGED		Karthik. K. - Administration	06/06/2023
Comp. Dt. : 14/06/2023 Status : Completed								
403	23060492	General Stores[Linen]	NEED TO CHANGE TUBELIGHT 2 NOS	Manimaran. M.	36W TUBE LIGHT 1NO CHANG & 36W CHOKE 1NO CHANG & 40W STARTER 1NO CHANGED		Arulkumaran. S. - Administration	16/06/2023
Comp. Dt. : 15/06/2023 Status : Completed								
404	23060544	Administration	(1137) ALL FANS CLEANING WORK	Vengadessaperumal. K.	Ceiling Fans are cleaned.		Karthik. K. - Administration	20/06/2023
Dept Name : Air Condition Department - Electrical Maintenance Comp. Dt. : 05/05/2022 Status : Completed								
405	22050148	General Medicine - OPD	AC BREAKER NOT WORKING IN DEMO ROOM	Rajan. R.	TWO POLE 20A MCB 1NO CHANGED		Thulasi Daran. R. - Air Condition Department	06/05/2022
Comp. Dt. : 02/06/2022 Status : Completed								
406	22060072	EMERGENCY OT NEAR CASUALTY	NEED TO FIX NEW TUBELIGHT SET [2 NOS] NEAR A H U ROOM	Sathishkumar. R.	36W TUBE LIGHT FITTING 2NO'S FIXING & 2M SURFACE BOX 1NO,6A SWITCH 2NO'S,1SQMM WIRE 10MTR, 3/4 PVC P		Babu. D. - Air Condition Department	08/06/2022
Comp. Dt. : 04/06/2022 Status : Completed								
407	22060167	labour ot	TRIP PROBLEM IN NDC BREAKER [LEFT SIDE]	Sridharan. R	40A 4POLE MCB 1NO CHANGED		Babu. D. - Air Condition Department	06/06/2022
Comp. Dt. : 13/06/2022 Status : Completed								
408	22060444	AHU Room-1ST FLOOR	NEED TO CHECK CONNECTER - PLUG FIRE	Dhakshinamoorthy. J	New connector changed.		anneer Selvam. P. - Air Condition Department	14/06/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 16/06/2022 Status : Completed								
409	22060595	OLD CHILLER	NEED TO CHECK - AC MAIN BREAKER BROKE	Dhakshinamoorthy. J	MAIN MCB PIN 1NO CHANGED		Manikandan. A. R. - Air Condition Department	11/07/2022
Comp. Dt. : 01/07/2022 Status : Completed								
410	22070010	Female Surgery - Ward 205	DUE TO FIXTATION OF AC MACHINE NEED TO REPLACE TUBELIGHT OTHER PLACE	Manimaran. P.	36W TUBE LIGHT LIGHT FITTING 1NO REFIXING WORK PROBLEM SOLVED		Babu. D. - Air Condition Department	02/07/2022
Comp. Dt. : 07/07/2022 Status : Completed								
411	22070245	Casualty	NEED A NEW POWER LINE CONNECTION FOR FIXING AC	Rajan. R.	NEW A/C 3NO'S WIRING WORK & LINE CONNECTION WORK PROBLEM SOLVED		Babu. D. - Air Condition Department	11/07/2022
Comp. Dt. : 05/09/2022 Status : Completed								
412	22090154	ALL WARD DEMO ROOM	DUE TO FIXING NEW AC FOR ALL DEMO ROOMS , NEED TO FIX POWER POINT FOR ALL DEMO ROOMS AT II & II	Rajan. R.	WORK IN PROGRASS EXPETED TO COMPLETE BEFOR		Babu. D. - Air Condition Department	12/10/2022
Comp. Dt. : 26/10/2022 Status : Completed								
413	22100797	AC DEPT	NEED SUPPLY FOR OLD CHILLER PUMP	Srinivasan. R.	OLD CHILLER MOTOR LINE CONNECTION WORK PROBLEM SOLVED		Thulasi Daran. R. - Air Condition Department	27/10/2022
Comp. Dt. : 14/11/2022 Status : Completed								
414	22110498	AC DEPT	TUBELIGHT NOT WORKING IN FIRST FLOOR AC DEPARTMENT	Dhakshinamoorthy. J	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Thulasi Daran. R. - Air Condition Department	15/11/2022
Comp. Dt. : 07/12/2022 Status : Completed								
415	22120302	OG-OPD	IN DEMO ROOM-ELECTRICAL POINT NEED TO GIVE FOR A/C CONNECTION	Rajan. R.	NEW A/C LINE CONNECTION WORK & CHEKING WORK PROBLEM SOLVED		Panneer Selvam. P. - Air Condition Department	13/12/2022
416	22120331	Special Ward - A	NEED TO CHECK AC SWITCH - NOT WORKING - ROOM NO 2 [VIP ROOM]	Lakshmanan.V.	25A SWITCH 1NO CHANG & CHEKING WORK PROBLEM SOLVED		Panneer Selvam. P. - Air Condition Department	08/12/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 17/12/2022								
Status : Completed								
417	22120815	OG OT	REQUEST TO PROVIDE NEW CONNECTION POINT FOR 6 NO'S A/C NEWLY	Muthu. B.	NEW A/C 4NO'S WIRING WORK & LINE CONNECTION WORK PROBLEM SOLVED		Panneer Selvam. P. - Air Condition Department	28/12/2022
Comp. Dt. : 23/12/2022								
Status : Completed								
418	22121088	labour ot	NEED TO FIX AC PLUG POINT - 6 NOS	Dhakshinamoorthy. J	NEW A/C 4NO'S DB FIXING & WIRING WORK A/C LINE CONNECTION WORK PROBLEM SOLVED		Panneer Selvam. P. - Air Condition Department	28/12/2022
Comp. Dt. : 13/01/2023								
Status : Completed								
419	23010540	AC DEPT	TUBELIGHT NOT WORKING - 2 NOS IN 1ST FLOOR DIALYSIS	Muthu. B.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANG & 40W CHOKE 1NO CHANGED		Pragash. P. - Air Condition Department	14/01/2023
Comp. Dt. : 30/01/2023								
Status : Completed								
420	23011065	labour ot	NEED TO FIX NEW ELECTRICAL POINTS [2NOS] FOR AC FIXING WORK	Rajan. R.	new a/c 2no's fixing & 25a socket 2no's 25a switch 2no's 25a 3pin top 2no's 25a single pole mcb 2no'		Panneer Selvam. P. - Air Condition Department	13/02/2023
Comp. Dt. : 06/02/2023								
Status : Completed								
421	23020170	Hospital	NEED TO CHECK CHILLER MOTOT 4 NOS	Muthu. B.	A/C CHILLER MOTOR 4NO'S CHEKING WORK PROBLEM SOLVED		Panneer Selvam. P. - Air Condition Department	07/02/2023
Comp. Dt. : 07/02/2023								
Status : Completed								
422	23020256	Orthopaedics - OPD	FIRE EXTINGUISHER HOSE PIPE NEED TO BE CLOSE	Azhagappan. J.	fire extinguisher pipe complain to workshop dept		Panneer Selvam. P. - Air Condition Department	09/02/2023
Comp. Dt. : 14/02/2023								
Status : Completed								
423	23020527	COMMERCIAL BLOCK	NEED TO FIX SWITCH BOX & LIGHT FITTING 2NOS FOR COMMERCIAL BLOCK MAINTENANCE ROOM	Srinivasan. R.	6A SWITCH 2NO'S,6A SOCKET 1NO,16 SOCKET 1NO,6M PLATE 1NO,6M SURFACE BOX 1NO,1.5SQ MM WIRE 5MTR FIXIN		Panneer Selvam. P. - Air Condition Department	25/02/2023

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
424	23020528	MRI	NEED LIGHT FITTING 2 NOS FOR MRI BACK SIDE	Vijayaraghavan.B.	36W TUBE LIGHT SET 2NO'S FIXING & 6A SWITCH 1NO,1M PLAT 1NO,2M SURFACE BOX 1NO,10MTR WIRE FIXING & L		Panneer Selvam. P. - Air Condition Department	20/02/2023
Comp. Dt. : 18/02/2023 Status : Completed								
425	23020716	COMMERCIAL BLOCK	NEED TO CHANGE LIGHT FITTING LOCATION & FIX A NEW JUNCTION BOX FOR MAINTENANCE ROOM	Srinivasan. R.	6A SWITCH 2NO'S,6A SOCKET 1NO,16A SOCKET 1NO,6M PLATE 1NO,6M SURFACE BOX 1NO, 1.5SQ MM WIRE 5MTR FIX		Panneer Selvam. P. - Air Condition Department	25/02/2023
Comp. Dt. : 21/02/2023 Status : Completed								
426	23020824	CHILLER IN HOSPITAL TERROUS	NEED BEARING WORK	Dhakshinamoorthy. J	A/C MOTOR BEARING 6203 2NO'S CHANG & MOTOR CHEKING WORK PROBLEM SOLVED		Panneer Selvam. P. - Air Condition Department	27/02/2023
Comp. Dt. : 22/02/2023 Status : Completed								
427	23020852	Air Condition	1ST FLOOR A/C-ROOM - -ONE TUBELIGHT NOT WORKING	Vijayaraghavan.B.	TUBE LIGHT 36W CHOKE 1NO CHANGED		Panneer Selvam. P. - Air Condition Department	23/02/2023
Comp. Dt. : 06/03/2023 Status : Completed								
428	23030227	HOSPITAL III FLOOR	AC ELECTRICAL POINT NOT WORKING - [III FLOOR DEMO ROOM] WARD NO 310	Muthu. B.	16A SWITCH 1NO CHANGED		Panneer Selvam. P. - Air Condition Department	07/03/2023
Comp. Dt. : 07/03/2023 Status : Completed								
429	23030292	UPS ROOM NEAR CHAIRMAN OFFICE	NEED TO CHANGE AC ELECTRICAL LINE	Azhagappan. J.	A/C LINE CONNECTION WORK PROBLEM SOLVED		Panneer Selvam. P. - Air Condition Department	08/03/2023
Comp. Dt. : 10/03/2023 Status : Completed								
430	23030394	HOSPITAL TERROUS	NEED ELECTRICAL CONNECTION WORK FOR CHILLER PUMP	Muthu. B.	3PHASE MOTOR LINE CONNECTION WORK PROBLEM SOLVED		Panneer Selvam. P. - Air Condition Department	11/03/2023
Comp. Dt. : 11/03/2023 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
431	23030472	labour ot	NEED TO CHECK A H MOTOR	Dhakshinamoorthy. J	AH MOTOR CHEKING WORK COIL FAULT		Pragash. P. - Air Condition Department	13/03/2023
Comp. Dt. : 15/03/2023 Status : Completed								
432	23030606	Blood Bank	NEED TO CHECK AC POWER	Srinivasan. R.	IN COMING VOLTAG 230V CHEKING WORK PROBLEM SOLVED		Panneer Selvam. P. - Air Condition Department	16/03/2023
Comp. Dt. : 28/03/2023 Status : Completed								
433	23031161	COMMERCIAL BLOCK	NEED TO CHECK AC LINE CONNECTION FOR COMMERCIAL FOOD COURT	Rajan. R.	A/C LINE CONNECTION WORK PROBLEM SOLVED		Panneer Selvam. P. - Air Condition Department	29/04/2023
Comp. Dt. : 05/04/2023 Status : Completed								
434	23040152	AHU Room-1ST FLOOR	NEED TO CHANGE TUBELIGHT - NOT WORKING	Dhakshinamoorthy. J	Tube light switch problem solved.		Vasanthakumar. V. - Air Condition Department	06/04/2023
Comp. Dt. : 11/04/2023 Status : Completed								
435	23040333	Post Operative	NEED TO FIX NEW ELECTRICAL POINT FOR AC - III FLOOR POST OPERATIVE - ROOM NO 1 - LEFT SIDE	Srinivasan. R.	AC wiring work done.		Panneer Selvam. P. - Air Condition Department	12/04/2023
Comp. Dt. : 05/06/2023 Status : Completed								
436	23060162	Ultra Sound	need to check power [room no 1]	Sathishkumar. R.	VOLT CHEKING WORK NO PROBLEM SOLVED		Panneer Selvam. P. - Air Condition Department	07/06/2023
Comp. Dt. : 30/06/2023 Status : Completed								
437	23061126	AHU Room	NEED TO CHANGE TUBELIGHT FOR ALL AHU ROOMS	Lakshmanan.V.	36W TUBE LIGHT 1NO CHANG & 36W STARTER 1NO CHANG & 36W CHOKE 1NO CHANGED		Panneer Selvam. P. - Air Condition Department	01/07/2023
Dept Name : Animal House - Electrical Maintenance Comp. Dt. : 28/01/2023 Status : Completed								
438	23011014	Animal House	FAN NOT WORKING	Lakshmanan.V.	CEILING FAN CAPACITOR 2.5MFT 1NO CHANGED		Imegalai. K. - Animal House	31/01/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Dept Name : BIOCHEMISTRY - Electrical Maintenance Comp. Dt. : 20/05/2022 Status : Completed								
439	22050749	COMMON FEMALE TOILET NEAR BIOCHEMISTRY	NEED TO CHECK POWER - SHOCK PROBLEM IN TOUCHING TAP	Muthu. B.	SWITCH BOARD CHEKING WORK NO COMPLAINT & 36W TUBE LIGHT 1NO CHANGED		Sangeetha. S. - BIOCHEMISTRY	21/05/2022
Comp. Dt. : 24/06/2022 Status : Completed								
440	22060867	Blood Collection Centre	NEED TO CHANGE TUBELIGHT	Muthu. B.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANG & 36W CHOKE 1NO CHANGED		Srinivasamurugan. V. - BIOCHEMISTRY	25/06/2022
Comp. Dt. : 26/07/2022 Status : Completed								
441	22070970	Blood Collection Centre	DUE TO POWER CUT PROBLEM - NEED TO CONNECT TUBELIGHT AS U P S CONNECTION -	Rajan. R.	36W TUBE LIGHT 1NO CHANGED		Srinivasamurugan. V. - BIOCHEMISTRY	29/07/2022
Comp. Dt. : 02/08/2022 Status : Completed								
442	22080055	lab report issuing counter 8 in reception	NEED TO CHANGE TUBELIGHT	Srinivasan. R.	15W LED DRIVER 1NO CHANGED		Srinivasamurugan. V. - BIOCHEMISTRY	03/08/2022
Comp. Dt. : 11/08/2022 Status : Completed								
443	22080396	BIOCHEMISTRY	NEED TO CHANGE TUBELIGHT	Rajan. R.	36W TUBE LIGHT SET 1NO REFIXING WORK PROBLEM SOLVED		Srinivasamurugan. V. - BIOCHEMISTRY	11/08/2022
Comp. Dt. : 20/08/2022 Status : Completed								
444	22080663	BIOCHEMISTRY	NEED TO CHANGE TUBELIGHT FOR ENTRANCE	Vijayaraghavan.B.	18W CFL 4PIN 4NO'S CHANG & 9W LED LIGHT 1NO CHANG & 40W STARTER 2NO'S CHANGED		Sivasankari. K. - BIOCHEMISTRY	22/08/2022
Comp. Dt. : 23/09/2022 Status : Completed								
445	22090936	Blood Collection Centre	NEED TO CHANGE TUBELIGHT	Manikandan. M.	TUBE LIGHT 40W STARTER 1NO CHANGED		Srinivasamurugan. V. - BIOCHEMISTRY	24/09/2022
Comp. Dt. : 25/10/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
446	22100780	Orthopaedics - OPD	X-RAY LOBBY NOT WORKING	Dhakshinamoorthy. J	6A 3PIN TOP 1NO CHANGED		Durga Devi. I. - BIOCHEMISTRY	27/10/2022
	Comp. Dt. : 03/11/2022							
	Status : Completed							
447	22110047	Biochemistry Lab-Hospital	TUBELIGHT NOT WORKING	Vengadessaperumal. K.	22W LED TUBE LIGHT 1NO REFIXING WORK PROBLEM SOLVED		Srinivasamurugan. V. - BIOCHEMISTRY	03/11/2022
	Comp. Dt. : 22/11/2022							
	Status : Completed							
448	22110943	Blood Collection Centre	TUBELIGHT NOT WORKING	Muthu. B.	TUBE LIGHT 36W CHOKE 1NO CHANGED		Srinivasamurugan. V. - BIOCHEMISTRY	23/11/2022
	Comp. Dt. : 28/12/2022							
	Status : Completed							
449	22121300	Biochemistry Lab-Hospital	TUBELIGHT NOT WORKING	Dhakshinamoorthy. J	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Srinivasamurugan. V. - BIOCHEMISTRY	29/12/2022
	Comp. Dt. : 30/12/2022							
	Status : Completed							
450	22121348	Blood Collection Centre	1 TUBELIGHT NOT WORKING	Lakshmanan.V.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Srinivasamurugan. V. - BIOCHEMISTRY	30/12/2022
	Comp. Dt. : 07/01/2023							
	Status : Completed							
451	23010294	Blood Collection Centre	NEED TO CHANGE 1 TUBELIGHT	Muthu. B.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Srinivasamurugan. V. - BIOCHEMISTRY	07/01/2023
	Comp. Dt. : 18/01/2023							
	Status : Completed							
452	23010608	Biochemistry Lab-Hospital	NEED TO CHANGE TUBELIGHT	Manimaran. P.	TUBE LIGHT 40W STARTER 1NO CHANGED		Srinivasamurugan. V. - BIOCHEMISTRY	18/01/2023
	Comp. Dt. : 06/02/2023							
	Status : Completed							
453	23020151	WASHING ROOM NEAR BLOOD COLLECTION	TUBELIGHT NOT WORKING	Srinivasan. R.	TUBE LIGHT 40W STARTER 1NO CHANGED		Srinivasamurugan. V. - BIOCHEMISTRY	06/02/2023
	Comp. Dt. : 14/02/2023							
	Status : Completed							
454	23020507	BIOCHEMISTRY	NEED TO CHANGE TUBELIGHT	Rajan. R.	TUBE LIGHT 40W STARTER 1NO CHANGED		Srinivasamurugan. V. - BIOCHEMISTRY	14/02/2023
	Comp. Dt. : 25/02/2023							

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
455	23020958	BIOCHEMISTRY	NEED TO REFIX PLUG POINT	Manimaran. M.	16A SOCKET 1NO CHANG & SOCKET 1NO UPS LINE CONNECTION WORK PROBLEM SOLVED		Srinivasamurugan. V. - BIOCHEMISTRY	01/03/2023
Comp. Dt. : 04/03/2023								
Status : Completed								
456	23030167	BIOCHEMISTRY	NEED REFIX SWITCH BOX - CABLE & SWITCH DAMAGE	Dhakshinamoorthy. J	SWITCH BOX REFIXING WORK PROBLEM SOLVED		Srinivasamurugan. V. - BIOCHEMISTRY	07/03/2023
Comp. Dt. : 13/03/2023								
Status : Completed								
457	23030483	Blood Collection Centre	NEED TO CHANGE TUBELIGHT - NOT WORKING	Manikandan. M.	NEW 22W LED LIGHT 1NO CHANGED		Srinivasamurugan. V. - BIOCHEMISTRY	14/03/2023
458	23030511	BIOCHEMISTRY	NEED TO CHANGE TUBELIGHT FOR COMMON RESTROOM NEAR STEPS	Manikandan. M.	22W LED LIGHT 1NO CHANGED		Vishnu Priya. B. - BIOCHEMISTRY	14/03/2023
Comp. Dt. : 08/04/2023								
Status : Completed								
459	23040226	BIOCHEMISTRY	NEED TO CHANGE TUBELIGHT	Manimaran. M.	36W E.choke 1no changed.		Ranjitha. M - BIOCHEMISTRY	08/04/2023
Comp. Dt. : 11/04/2023								
Status : Completed								
460	23040347	COMMON FEMALE TOILET NEAR BIOCHEMISTRY	NEED TO CHANGE TUBELIGHT	Manimaran. M.	36W tube light 1no changed.		Sangeetha. S. - BIOCHEMISTRY	12/04/2023
Comp. Dt. : 17/04/2023								
Status : Completed								
461	23040484	BIOCHEMISTRY	NEED TO CHANGE TUBELIGHT	Muthu. B.	TUBE LIGHT 40W STARTER 1NO CHANGED		Srinivasamurugan. V. - BIOCHEMISTRY	17/04/2023
Comp. Dt. : 28/04/2023								
Status : Completed								
462	23040966	Blood Collection Centre	NEED TO CHANGE TUBELIGHT	Vijayaraghavan.B.	36W TUBE LIGHT 1NO CHANGED		Srinivasamurugan. V. - BIOCHEMISTRY	03/05/2023
Comp. Dt. : 05/05/2023								
Status : Completed								
463	23050205	TOILET NEAR CLINICAL PATHOLOGY	NEED TO CHANGE TUBELIGHT FOR MALE RESTROOM	Lakshmanan.V.	36W TUBE LIGHT 2NO'S CHANG & 40W STARTER 2NO'S CHANG & 36W CHOKE 1NO CHANGED		Srinivasamurugan. V. - BIOCHEMISTRY	09/05/2023

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 10/06/2023								
Status : Completed								
464	23060356	BIOCHEMISTRY	NEED TO CHANGE HYDROLIC LIGHT FOR ENTRANCE	Lakshmanan.V.	LED light changed.		Nirmala.B. - BIOCHEMISTRY	12/06/2023
Comp. Dt. : 12/06/2023								
Status : Completed								
465	23060388	BIOCHEMISTRY	NEED TO CHANGE TUBELIGHT	Damodharan. V.	NEW LED 22W TUBE LIGHT 1NO CHANGED		Srinivasamurugan. V. - BIOCHEMISTRY	12/06/2023
Comp. Dt. : 16/06/2023								
Status : Completed								
466	23060570	Blood Collection Centre	ONE TUBELIGHT NOT WORKING	Muthu. B.	TUBE LIGHT 40W STARTER 1NO CHANGED		Srinivasamurugan. V. - BIOCHEMISTRY	17/06/2023
Comp. Dt. : 26/06/2023								
Status : Completed								
467	23060928	Blood Collection Centre	NEED TO CHANGE TUBELIGHT 2 NOS - NEED URGENT SERVICE	Vengadessaperumal. K.	36W TUBE LIGHT 2NO'S CHANG & 40W STARTER 2NO'S CHANGED		Srinivasamurugan. V. - BIOCHEMISTRY	27/06/2023
Dept Name : Biomedical - Electrical Maintenance								
Comp. Dt. : 30/03/2023								
Status : Completed								
468	23031274	Biomedical	NEED TO CHANGE TUBELIGHT -	Lakshmanan.V.	Old LED fitting replaced.		Sridhar. K. - Biomedical	31/03/2023
Comp. Dt. : 29/04/2023								
Status : Completed								
469	23040985	Biomedical	NEED TO CHANGE TUBELIGHT	Rajan. R.	22W LED LIGHT 1NO CHANGED		Sridhar. K. - Biomedical	02/05/2023
Dept Name : BLOOD BANK - Electrical Maintenance								
Comp. Dt. : 28/05/2022								
Status : Completed								
470	22051064	Blood Bank	NEED TO CHANGE C F L LIGHT FOR RECEPTION AREA	Srinivasan. R.	18W LED DRIVER 1NO CHANGED		Thirumangai. S. - BLOOD BANK	01/06/2022
Comp. Dt. : 28/06/2022								
Status : Completed								
471	22060984	Blood Bank	NEED TO CHANGE TUBELIGHT	Muthu. B.	36W TUBE LIGHT 1NO CHANGED		Balasankari. A. - BLOOD BANK	28/06/2022
Comp. Dt. : 27/07/2022								
Status : Completed								

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
472	22070989	Blood Bank	NEED TO CHANGE TUBELIGHT	Rajan. R.	TUBE LIGHT 40W STARTER 1NO CHANGED		Sivasankari.I. - BLOOD BANK	27/07/2022
Comp. Dt. : 17/08/2022 Status : Completed								
473	22080545	Blood Bank	1 TUBELIGHT NOT WORKING	Lakshmanan.V.	36W tube light 1no changed.		Ganesh. V. - BLOOD BANK	18/08/2022
Comp. Dt. : 01/09/2022 Status : Completed								
474	22090046	Blood Bank	NEED TO CHANGE TUBELIGHT	Manikandan. M.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Sangavi. S. - BLOOD BANK	02/09/2022
Comp. Dt. : 07/09/2022 Status : Completed								
475	22090287	Blood Bank	NEED TO CHANGE TUBELIGHT	Lakshmanan.V.	TUBE LIGHT 40W STARTER 1NO CHANGED		Balasankari. A. - BLOOD BANK	08/09/2022
Comp. Dt. : 27/09/2022 Status : Completed								
476	22091091	Blood Bank	NEED TO CHANGE TUBELIGHT	Lakshmanan.V.	TUBE LIGHT 40W STARTER 1NO CHANGED		Sangavi. S. - BLOOD BANK	28/09/2022
Comp. Dt. : 25/10/2022 Status : Completed								
477	22100770	Blood Bank	TV NOT WORKING	Muthu. B.	TV SETUP BOX CHEKING WORK SETTING PROBLEM SOLVED		Sangavi. S. - BLOOD BANK	26/10/2022
Comp. Dt. : 09/11/2022 Status : Completed								
478	22110337	Blood Bank	TUBELIGHT NOT WORKING	Lakshmanan.V.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Ganesh. V. - BLOOD BANK	10/11/2022
Comp. Dt. : 16/11/2022 Status : Completed								
479	22110636	Blood Bank	NO POWER SUPPLY IN SWITCH BOARD	Manikandan. M.	16A SWITCH 1NO CHANGED		Ganesh. V. - BLOOD BANK	17/11/2022
Comp. Dt. : 06/12/2022 Status : Completed								
480	22120270	Blood Bank	IN RECEPTION AREA-1 LED LIGHT NOT WORKING	Vijayaraghavan.B.	LED LIGHT 22W 2NO'S CHANGED		Thirumangai. S. - BLOOD BANK	07/12/2022
Comp. Dt. : 15/12/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
481	22120681	Blood Bank	NEED TO CHANGE TUBELIGHT FOR STORE ROOM	Vijayaraghavan.B.	36W TUBE LIGHT 1NO CHANGED		Thirumangai. S. - BLOOD BANK	16/12/2022
Comp. Dt. : 20/01/2023 Status : Completed								
482	23010725	Blood Bank	NEED TO CHANGE TUBELIGHT FOR COMPONENT ROOM	Dhakshinamoorthy. J	TUBE LIGHT 40W STARTER 1NO CHANGED		Thirumangai. S. - BLOOD BANK	21/01/2023
Comp. Dt. : 27/01/2023 Status : Completed								
483	23010975	Blood Bank	NEED TO CHANGE TUBELIGHT	Muthu. B.	36W TUBE LIGHT 1NO CHANGED		Ganesh. V. - BLOOD BANK	27/01/2023
Comp. Dt. : 07/02/2023 Status : Completed								
484	23020249	Blood Bank	NEED TO CHECK PLUG POINT - NOT WORKING	Muthu. B.	6A SOCKET 1NO CHANGED		Sangavi. S. - BLOOD BANK	07/02/2023
Comp. Dt. : 21/02/2023 Status : Completed								
485	23020794	Blood Bank	NEED TO CHANGE TUBELIGHT	Manikandan. M.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Lakshmi.K. - BLOOD BANK	22/02/2023
Comp. Dt. : 14/03/2023 Status : Completed								
486	23030538	Blood Bank	STABILIZER NOT WORKING	Srinivasan. R.	STABILIZER CHEKING WORK BIOMEDICAL DEPT COMPLAINT		Ganesh. V. - BLOOD BANK	16/03/2023
Comp. Dt. : 31/03/2023 Status : Completed								
487	23031328	Blood Bank	NEED TO CHANGE TUBELIGHT	Thillaikumar. R.	36W tube light 2no's changed.		Balasankari. A. - BLOOD BANK	31/03/2023
Comp. Dt. : 28/04/2023 Status : Completed								
488	23040943	Blood Bank	NEED TO CHANGE ENTRANCE CEILING LIGHT	Rajan. R.	22W ROUNT LED LIGHT 1NO CHANGED		Thirumangai. S. - BLOOD BANK	28/04/2023
Comp. Dt. : 08/06/2023 Status : Completed								
489	23060297	Blood Bank	CEILING LIGHT [UPS CONNECTION] NOT WORKING	Srinivasan. R.	LED CHOKE 1NO CHANGED		Thirumangai. S. - BLOOD BANK	10/06/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 19/06/2023								
Status : Completed								
490	23060657	Blood Bank	NEED TO PROVIDE A NEW PLUG POINT	Vengadessaperumal. K.	6A SOCKET 3NO'S 6ASWITCH 2NO'S 8M PLATE 1NO,8M SURFACE BOX 1NO FIXING & LINE CONNECTION WORK PROBLEM		Ganesh. V. - BLOOD BANK	23/06/2023
Comp. Dt. : 21/06/2023								
Status : Completed								
491	23060765	Blood Bank	NEED TO CHANGE TUBELIGHT	Vijayaraghavan.B.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Radhika. S. - BLOOD BANK	22/06/2023
Comp. Dt. : 23/06/2023								
Status : Completed								
492	23060857	Blood Bank	NEED TO CHENGE L E D LIGHT FOR "C" WING RECEPTION	Vengadessaperumal. K.	ROUNT LED LIGHT FITTING 1NO CHANGED		Thirumangai. S. - BLOOD BANK	27/06/2023
Dept Name : Blood Collection Centre - Electrical Maintenance								
Comp. Dt. : 24/11/2022								
Status : Completed								
493	22111022	lab report issuing counter 8 in reception	1 TUBELIGHT NOT WORKING	Dhakshinamoorthy. J	18W CHOKE 1NO CHANGED		Kasthuribai. J. - Blood Collection Centre	28/11/2022
Comp. Dt. : 15/12/2022								
Status : Completed								
494	22120721	Blood Collection Centre	NEED TO CHANGE TUBELIGHT FOR WASHING AREA	Vijayaraghavan.B.	36W TUBE LIGHT CHANG & 40W STARTER 1NO CHANGED		Suguna. K. - Blood Collection Centre	16/12/2022
Dept Name : Canteen - Boys Hostel - Electrical Maintenance								
Comp. Dt. : 02/05/2022								
Status : Completed								
495	22050053	Boys hostel Phase-II	FAN SLOW PROBLEM IN ROOM NO 57	Muthu. B.	CEILING FAN CAPACITOR 2.5MFT 1NO CHANGED		Sambasivam. K. - Canteen - Boys Hostel	05/05/2022
Comp. Dt. : 04/05/2022								
Status : Completed								
496	22050080	Boys hostel P.H-III	HEATER NOT WORKING - ROOM NO 39	Dhakshinamoorthy. J	16A 3PIN TOP 11NO CHANG & HEATER CHEKING WORK PROBLEM SOLVED		Sriram. TR. K. - Canteen - Boys Hostel	05/05/2022
Comp. Dt. : 05/05/2022								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
497	22050137	BOYS HOSTEL MESS	NEED TO CHANGE TUBELIGHT	Muthu. B.	40W STARTER 1NO CHANGED		Anand. G. - Transport	09/05/2022
498	22050145	Boys hostel P.H-III	NEED TO CHANGE RESTROOM TUBELIGHT & DRESS TABLE TUBELIGHT FOR ROOM NO 20 & 14	Lakshmanan.V.	BABY HOLDER 2NO'S CHANG & 9W LED LIGHT 2NO'S CHANGED		Sambasivam. K. - Canteen - Boys Hostel	12/05/2022
499	22050146	Boys hostel	NEED TO CHANGE CFL LIGHT FOR LIFT INSIDE	Muthu. B.	18W CFL 2PIN LIGHT 2NO'S CHANGED		Sambasivam. K. - Canteen - Boys Hostel	09/05/2022
Comp. Dt. : 06/05/2022								
Status : Completed								
500	22050203	Boys hostel Phase-II	NEED TO REFIX PEST KILLER LIGHT FOR DINING HALL	Muthu. B.	PEST KILLER LIGHT CHEKING WORK NOT WORK SHAFTING TO ELECTRICAL ROOM		Sambasivam. K. - Canteen - Boys Hostel	14/05/2022
501	22050204	Boys hostel Phase-II	NEED TO CHANGE TUBELIGHT [2NOS] FOR II FLOOR COMMON RESTROOM	Vijayaraghavan.B.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Sambasivam. K. - Canteen - Boys Hostel	12/05/2022
Comp. Dt. : 10/05/2022								
Status : Completed								
502	22050341	Boys hostel Phase-II	FAN SLOW PROBLEM - ROOM NO 36	Lakshmanan.V.	CEILING FAN CAPACITOR 2.5MFT 1NO CHANGED		Sambasivam. K. - Canteen - Boys Hostel	12/05/2022
503	22050342	Boys hostel PH-I	NEED TO CHANGE HEATER SWITCH FOR III FLOOR COMMON REST ROOM	Lakshmanan.V.	16A SWITCH 1NO CHANGED		Sambasivam. K. - Canteen - Boys Hostel	12/05/2022
Comp. Dt. : 13/05/2022								
Status : Completed								
504	22050473	Boys hostel PH-I	FAN NOT WORKING IN ROOM NO.54	Lakshmanan.V.	CEILING FAN CAPACITOR 2.5MFT 1NO CHANGED		Sambasivam. K. - Canteen - Boys Hostel	14/05/2022
Comp. Dt. : 16/05/2022								
Status : Completed								
505	22050582	Boys hostel P.H-III	HEATER NOT WORKING & WATER COMING SLOW - ELECTRICAL FAULT ROOM NO 48	Srinivasan. R.	WATER HEATER WATER CHEKING WORK PLUMING COMPLAINT		Sambasivam. K. - Canteen - Boys Hostel	18/05/2022
Comp. Dt. : 17/05/2022								
Status : Completed								
506	22050628	Boys hostel PH-I	NEED TO CHANGE RESTROOM LED LIGHT FOR ROOM NO 5	Srinivasan. R.	20W TUBE LIGHT 1NO CHANGED		Sambasivam. K. - Canteen - Boys Hostel	20/05/2022

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 18/05/2022								
Status : Completed								
507	22050679	BOYS HOSTEL MESS	GRINDER NOT WORKING - NEED TO CHECK URGENT	Lakshmanan.V.	GRINDER BELD B-33 1NO CHANG & CHEKING WORK PROBLEM SOLVED		Sambasivam. K. - Canteen - Boys Hostel	20/05/2022
Comp. Dt. : 20/05/2022								
Status : Completed								
508	22050775	Boys hostel PH-I	FAN SLOW PROBLEM ROOM NO 26	Lakshmanan.V.	CEILING FAN SPEED CHEKING WORK PROBLEM SOLVED		Sambasivam. K. - Canteen - Boys Hostel	21/05/2022
Comp. Dt. : 21/05/2022								
Status : Completed								
509	22050791	Boys hostel Phase-II	NEED TO CHANGE TUBELIGHT FOR ROOM NO 26	Lakshmanan.V.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Sambasivam. K. - Canteen - Boys Hostel	23/05/2022
510	22050792	Boys hostel PH-I	NEED TO CHANGE TUBELIGHT FOR ROOM NO 29 & 33	Manimaran. P.	36W TUBE LIGHT 2NO'S CHANG & 40W STARTER 2NO'S CHANGED		Sambasivam. K. - Canteen - Boys Hostel	23/05/2022
Comp. Dt. : 24/05/2022								
Status : Completed								
511	22050857	Boys hostel PH-I	NEED TO CHANGE TUBELIGHT - ROOM NO 28	Muthu. B.	TUBE LIGHT 40W STARTER 1NO CHANGED		Sambasivam. K. - Canteen - Boys Hostel	25/05/2022
512	22050858	Boys hostel P.H-III	NEED TO CHANGE TUBELIGHT - ROOM NO 10	Muthu. B.	22W LED LIGHT 1NO REFIXING WORK PROBLEM SOLVED		Sambasivam. K. - Canteen - Boys Hostel	25/05/2022
Comp. Dt. : 25/05/2022								
Status : Completed								
513	22050948	Boys hostel PH-I	NEED TO CHANGE TUBELIGHT FOR ROOM NO 33	Vijayaraghavan.B.	36W tube light 1no changed.		Sambasivam. K. - Canteen - Boys Hostel	26/05/2022
Comp. Dt. : 28/05/2022								
Status : Completed								
514	22051060	Boys hostel PH-I	NEED TO CHANGE 3 PIN SOCKET FOR WINDOW SIDE FOR ROOM NO 28	Dhakshinamoorthy. J	6A SOCKET PROBLEM & DOOR LOCK		Sambasivam. K. - Canteen - Boys Hostel	01/06/2022
Comp. Dt. : 30/05/2022								
Status : Completed								
515	22051073	Boys hostel PH-I	NEED TO REDUCE ADAPTER SMALL PIN FOR CABLE TV SETUP BOX FOR II FLOOR TV HALL	Sathishkumar. R.	SETUP BOX ADAPTER 5V,2A 1NO CHANGED		Sambasivam. K. - Canteen - Boys Hostel	31/05/2022

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 31/05/2022								
Status : Completed								
516	22051142	Boys hostel P.H-III	HEATER NOT WORKING - ROOM NO 6	Lakshmanan.V.	WATER HEATER RESET WORK PROBLEM SOLVED		Sambasivam. K. - Canteen - Boys Hostel	01/06/2022
Comp. Dt. : 02/06/2022								
Status : Completed								
517	22060073	Boys hostel Phase-II	FAN SLOW PROBLEM - ROOM NO 30	Dhakshinamoorthy. J	CEILING FAN CAPACITOR 2.5MFT 1NO CHANGED		Sambasivam. K. - Canteen - Boys Hostel	03/06/2022
Comp. Dt. : 03/06/2022								
Status : Completed								
518	22060131	Boys hostel P.H-III	NEED TO CHANGE RESTROOM LED LIGHT & STUDY TUBELIGHT FOR ROOM NO 18	Lakshmanan.V.	9W LED LIGHT 1NO CHANG & 36W TUBE LIGHT 1NO CHANGED		Sambasivam. K. - Canteen - Boys Hostel	04/06/2022
Comp. Dt. : 06/06/2022								
Status : Completed								
519	22060183	Boys hostel P.H-III	NEED TO CHECK FAN [2NOS] - SLOW PROBLEM - ROOM NO 32	Dhakshinamoorthy. J	CEILING FAN SPEED CHEKING WORK PROBLEM SOLVED		Sambasivam. K. - Canteen - Boys Hostel	07/06/2022
Comp. Dt. : 07/06/2022								
Status : Completed								
520	22060265	Boys hostel PH-I	FAN [2NOS] SLOW PROBLEM IN ROOM NO 12	Muthu. B.	CEILING FAN CAPACITOR 2.5MFT 2NO'S CHANGED		Sambasivam. K. - Canteen - Boys Hostel	08/06/2022
Comp. Dt. : 08/06/2022								
Status : Completed								
521	22060290	Boys hostel Phase-II	FAN SLOW PROBLEM - ROOM NO 63	Dhakshinamoorthy. J	CEILING FAN CAPACITOR 2.5MFT 1NO CHANGED		Sambasivam. K. - Canteen - Boys Hostel	09/06/2022
Comp. Dt. : 09/06/2022								
Status : Completed								
522	22060347	Boys hostel PH-I	NEED TO CHECK FAN [2NOS] & TUBELIGHT - NOT WORKING - ROOM NO 47	Srinivasan. R.	CEILING FAN 1NO REWINDING WORK & FAN BEARING 2NO'S CHANG & FQAN REFIXING WORK PROBLEM SOLVED		Sambasivam. K. - Canteen - Boys Hostel	21/06/2022
Comp. Dt. : 14/06/2022								
Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
523	22060504	MEDICAL COLLEGE -- -BOYS HOSTEL	NEED TO CHANGE TUBELIGHT 3 NOS	Srinivasan. R.	6A SWITCH 3NO'S CHANGED		Anand. G. - Transport	15/06/2022
524	22060506	Boys hostel PH-I	NEED TO CHANGE TUBELIGHT FOR ROOM NO 51	Srinivasan. R.	36W TUBE LIGHT 1NO CHANGED		Sambasivam. K. - Canteen - Boys Hostel	15/06/2022
Comp. Dt. :		15/06/2022						
Status :		Completed						
525	22060565	Boys hostel Phase-II	FAN SLOW PROBLEM - ROOM NO 31	Vijayaraghavan.B.	CEILING FAN CAPACITORR 2.5MFT 2NO'S CHANGED		Sambasivam. K. - Canteen - Boys Hostel	16/06/2022
526	22060566	Boys hostel P.H-III	NEED TO CHANGE STUDY TUBELIGHT FOR ROOM NO 10	Vijayaraghavan.B.	22W LED TUBE LIGHT 1NO REFIXING WORK PROBLEM SOLVED		Sambasivam. K. - Canteen - Boys Hostel	16/06/2022
527	22060567	Boys hostel PH-I	NEED TO CHANGE NIGHT LAMP FOR ROOM NO 47	Vijayaraghavan.B.	0.5W NIGHT LAMP 1NO CHANGED		Sambasivam. K. - Canteen - Boys Hostel	16/06/2022
Comp. Dt. :		17/06/2022						
Status :		Completed						
528	22060647	Boys hostel PH-I	FAN SLOW PROBLEM - ROOM NO 48	Muthu. B.	Fan capacitor 2.5mfd 1no changed.		Sambasivam. K. - Canteen - Boys Hostel	18/06/2022
Comp. Dt. :		20/06/2022						
Status :		Completed						
529	22060727	Boys hostel PH-I	3 PIN SOCKET [WINDOW SIDE] NOT WORKING & FAN SOUND PROBLEM & FAN REGULATOR NOT WORKING FOR ROOM 47	Muthu. B.	CEILING FAN BEARING 2NO'S CHANG & 3M PLATE 1NO,6A SOCKET 1NO,6A SWITCH 1NO CHANGED		Sambasivam. K. - Canteen - Boys Hostel	22/06/2022
Comp. Dt. :		22/06/2022						
Status :		Completed						
530	22060810	Boys hostel Phase-II	NEED TO CHANGE TUBELIGHT FOR III FLOOR COMMON RESTROOM	Vijayaraghavan.B.	36W TUBE LIGHT 2NO'S CHANG & 40W STARTER 1NO CHANGED		Sambasivam. K. - Canteen - Boys Hostel	23/06/2022
Comp. Dt. :		25/06/2022						
Status :		Completed						
531	22060916	Boys hostel PH-I	NEED TO CHANGE SWITCH BOARD PLATE FOR ROOM NO 8	Lakshmanan.V.	SWITCH BOARD PLATE 1NO REFIXING WORK PROBLEM SOLVED		Sambasivam. K. - Canteen - Boys Hostel	27/06/2022
Comp. Dt. :		28/06/2022						
Status :		Completed						
532	22061002	BOYS HOSTEL MESS	MIXIE NOT WORKING [ELECTRICAL FAULT]	Lakshmanan.V.	NEW CORBUN BUSH 2NO'S CHANG & CHEKING WORK PROBLEM SOLVED		esavaraj. P. - Canteen - Boys Hostel	30/06/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 02/07/2022 Status : Completed								
533	22070070	Boys hostel PH-I	NEED TO CHECK SWITCH - NOT WORKING ROOM NO 53	Dhakshinamoorthy. J	6A SWITCH 1NO CHANGED		Sambasivam. K. - Canteen - Boys Hostel	11/07/2022
Comp. Dt. : 04/07/2022 Status : Completed								
534	22070125	Boys hostel	NEED TO CHANGE TUBELIGHT FOR BOYS HOSTEL STORE ROOM	Dhakshinamoorthy. J	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Kesavaraj. P. - Canteen - Boys Hostel	05/07/2022
Comp. Dt. : 05/07/2022 Status : Completed								
535	22070156	Boys hostel PH-I	RESTROOM CFL LIGHT NOT WORKING - ROOM NO 22	Dhakshinamoorthy. J	9W LED Lamp 1no changed.		Sambasivam. K. - Canteen - Boys Hostel	07/07/2022
536	22070157	Boys hostel Phase-II	NEED TO CHANGE TUBELIGHT FOR ROOM NO 52	Dhakshinamoorthy. J	36W E.Choke 1no & tube light 1no changed.		Sambasivam. K. - Canteen - Boys Hostel	07/07/2022
Comp. Dt. : 06/07/2022 Status : Completed								
537	22070200	Boys hostel P.H-III	NEED TO CHANGE RESTROOM CFL LIGHT FOR ROOM NO 14	Vijayaraghavan.B.	9W LED lamp 1no changed.		Sambasivam. K. - Canteen - Boys Hostel	07/07/2022
Comp. Dt. : 08/07/2022 Status : Completed								
538	22070313	Boys hostel PH-I	NEED TO CHANGE CFL LIGHT FOR ROOM NO 44	Lakshmanan.V.	9W LED LIGHT 1NO CHANGED		Sambasivam. K. - Canteen - Boys Hostel	11/07/2022
539	22070314	Boys hostel P.H-III	FAN SLOW PROBLEM - ROOM NO 25	Lakshmanan.V.	CEILING FAN CAPACIOTR 2.5MFT 1NO CHANGED		Sambasivam. K. - Canteen - Boys Hostel	11/07/2022
Comp. Dt. : 14/07/2022 Status : Completed								
540	22070559	Boys hostel PH-I	NEED TO CHANGE C F L LIGHT FOR ROOM NO 1	Vijayaraghavan.B.	9W LED LIGHT 1NO CHANGED		Sambasivam. K. - Canteen - Boys Hostel	16/07/2022
Comp. Dt. : 15/07/2022 Status : Completed								
541	22070608	Boys hostel PH-I	NEED TO CHANGE WINDOW SIDE SOCKET - ROOM NO 8	Muthu. B.	6A SOCKET 1NO CHANG & 6A SWITCH 1NO CHANGED		Sambasivam. K. - Canteen - Boys Hostel	18/07/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
542	22070609	Boys hostel Phase-II	NEED TO CHANGE 3 PIN TOP FOR FIXING NEW AC - ROOM NO 29	Vijayaraghavan.B.	NEW A/C 16A 3PIN TOP 1NO CHANGED		Sambasivam. K. - Canteen - Boys Hostel	16/07/2022
Comp. Dt. : 18/07/2022 Status : Completed								
543	22070648	Boys hostel Phase-II	NEED TO CHANGE TUBELIGHT ROOM NO 26 & 37	Lakshmanan.V.	366W TUBE LIGHT 2NO'S CHANG & 40W STARTER 2NO'S CHANGED		Sambasivam. K. - Canteen - Boys Hostel	19/07/2022
544	22070649	Boys hostel P.H-III	NEED TO CHANGE MIRROR LIGHT & NIGHT LAMP - ROOM NO 3	Lakshmanan.V.	MIRROR LIGHT REMOVING TO ELECTRICAL ROOM		Sambasivam. K. - Canteen - Boys Hostel	21/07/2022
545	22070650	Boys hostel PH-I	FAN SLOW ,SOUND & PROBLEM ROOM NO 14 [2NOS] & 26	Lakshmanan.V.	CEILING FAN BEARING 2NO'S CHANG & CEILING FAN CAPACITOR2.5MFT 1NO CHANGED		Sambasivam. K. - Canteen - Boys Hostel	20/07/2022
546	22070679	Boys hostel Phase-II	FAN SLOW PROBLEM - ROOM NO 26	Lakshmanan.V.	CEILING FAN CAPACITOR 2.5MFT 1NO CHANGED		Sambasivam. K. - Canteen - Boys Hostel	19/07/2022
Comp. Dt. : 20/07/2022 Status : Completed								
547	22070742	Ladies hostel Phase-II	NEED TO CHANGE TUBELIGHT FOR ROOM NO 26	Vijayaraghavan.B.	36 TUBE LIGHT 1NO CHANGED		Sriram. TR. K. - Canteen - Boys Hostel	21/07/2022
Comp. Dt. : 23/07/2022 Status : Completed								
548	22070858	Boys hostel PH-I	NEED TO CHANGE TUBELIGHT FOR ROOM NO 47	Vijayaraghavan.B.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 2NO'S CHANGED		Sambasivam. K. - Canteen - Boys Hostel	25/07/2022
Comp. Dt. : 25/07/2022 Status : Completed								
549	22070925	Boys hostel	NEED TO CHECK GRINDER - SOUND PROBLEM	Dhakshinamoorthy. J	B-33 BELT 1NO CHANG & CHEKING WORK PROBLEM SOLVED		Anand. G. - Transport	27/07/2022
Comp. Dt. : 26/07/2022 Status : Completed								
550	22070944	Boys hostel PH-I	NEED TO CHANGE RESTROOM CFL BULB FOR ROOM NO 8	Dhakshinamoorthy. J	9W LED LIGHT 1NO CHANGED		Sambasivam. K. - Canteen - Boys Hostel	27/07/2022
Comp. Dt. : 27/07/2022 Status : Completed								
551	22071000	Boys hostel Phase-II	FAN SLOW PROBLEM ROOM NO 29	Dhakshinamoorthy. J	CEILING FAN CAPACITOR 2.5MFT 1NO CHANGED		Sriram. TR. K. - Canteen - Boys Hostel	29/07/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
552	22071001	Boys hostel P.H-III	FAN SLOW PROBLEM ROOM NO 48	Dhakshinamoorthy. J	CEILING FAN CAPACITOR 2.5MFT 1NO CHANGED		Sriram. TR. K. - Canteen - Boys Hostel	29/07/2022
553	22071013	Mit boys hostel	NEED TO CHANGE TUBELIGHT 2NOS FOR MIT BOYS HOSTEEL STREET SIDE	Dhakshinamoorthy. J	36W TUBE LIGHT 1NO CHANG & 36W CHOKE 1NO CHANG & 40W STARTER 1NO CHANGED		Sambasivam. K. - Canteen - Boys Hostel	29/07/2022
554	22071032	STAFF'S CANTEEN IN COMMERCIAL BLOCK	NEED TO CHANGE TUBELIGHT	Lakshmanan.V.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Anand. G. - Transport	29/07/2022
Comp. Dt. : 29/07/2022								
Status : Completed								
555	22071048	Boys hostel P.H-III	NEED TO CHANGE RESTROOM CFL BLUB FOR ROOM NO 8	Muthu. B.	9W LED LIGHT 1NO CHANGED		Sambasivam. K. - Canteen - Boys Hostel	30/07/2022
Comp. Dt. : 01/08/2022								
Status : Completed								
556	22080037	Boys hostel P.H-III	NEED TO CHANGE TUBELIGHT [2NOS] FOR ROOM NO 28	Vijayaraghavan.B.	22W TUBE LIGHT FITTING 1NO REFIXING WORK PROBLEM SOLVED		Sambasivam. K. - Canteen - Boys Hostel	02/08/2022
Comp. Dt. : 02/08/2022								
Status : Completed								
557	22080100	Boys hostel P.H-III	NEED TO CHANGE RESTROOM CFL LIGHT FOR ROOM NO 28	Srinivasan. R.	9W LED LIGHT 1NO CHANGED		Sambasivam. K. - Canteen - Boys Hostel	03/08/2022
Comp. Dt. : 03/08/2022								
Status : Completed								
558	22080136	Boys hostel PH-I	NEED TO CHANGE CFL LIGHT FOR RESTROOM - ROOM NO 3	Manikandan. M.	9W LED LIGHT 1NO CHANGED		Sambasivam. K. - Canteen - Boys Hostel	04/08/2022
Comp. Dt. : 08/08/2022								
Status : Completed								
559	22080259	Boys hostel PH-I	FAN SLOW PROBLEM - ROOM NO 14	Lakshmanan.V.	CEILING FAN CAPACITOR 2.5MFT 1NO CHANGED		Sambasivam. K. - Canteen - Boys Hostel	09/08/2022
560	22080260	Boys hostel P.H-III	NEED TO CHANGE RESTROOM CFL LIGHT FOR ROOM NO 41	Dhakshinamoorthy. J	9W LED LIGHT 1NO CHANGED		Sambasivam. K. - Canteen - Boys Hostel	09/08/2022
Comp. Dt. : 09/08/2022								
Status : Completed								
561	22080309	Boys hostel P.H-III	NEED TO CHANGE TUBELIGHT FOR ROOM NO 21	Dhakshinamoorthy. J	T5 LIGHT OLD LIGHT 1NO REFIXING WORK PROBLEM SOLVED		Sambasivam. K. - Canteen - Boys Hostel	11/08/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
562	22080341	Boys hostel PH-I	SOCKET NOT WORKING - ROOM NO 16	Dhakshinamoorthy. J	6A SOCKET 1NO CHANGED		Sambasivam. K. - Canteen - Boys Hostel	10/08/2022
Comp. Dt. : 10/08/2022 Status : Completed								
563	22080382	Boys hostel PH-I	NEED TO CHANGE TUBELIGHT - ROOM NO 31	Lakshmanan.V.	36W TUBE LIGHT 1NO CHANGED		Sambasivam. K. - Canteen - Boys Hostel	11/08/2022
564	22080387	PLAY GROUND COURT NEAR BOYS HOSTEL	NEED TO CHECK FOCUS LIGHT FOR BASKETBALL COURT, BADMINTON and VOLLEY BALL COURT	Dhakshinamoorthy. J	FOCUS LED LIGHT 100W 2NO'S CHANGED		Sambasivam. K. - Canteen - Boys Hostel	12/08/2022
Comp. Dt. : 22/08/2022 Status : Completed								
565	22080696	Boys hostel P.H-III	NEED TO CHANGE TUBELIGHT FOR III FLOOR - OPP TO ROOM NO 38	Muthu. B.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Sambasivam. K. - Canteen - Boys Hostel	23/08/2022
566	22080697	Boys hostel PH-I	NEED TO CHANGE TUBELIGHT FOR GROUND FLOOR STEPS NEAR & ROOM NO 36	Muthu. B.	36W TUBE LIGHT 1NO CHANGED		Sambasivam. K. - Canteen - Boys Hostel	23/08/2022
Comp. Dt. : 25/08/2022 Status : Completed								
567	22080858	Boys hostel P.H-III	HEATER NOT WORKING AT ROOM NO 47	Muthu. B.	WATER HEATER 1NO RESET WORK PROBLEM SOLVED		Sambasivam. K. - Canteen - Boys Hostel	26/08/2022
Comp. Dt. : 29/08/2022 Status : Completed								
568	22080992	Boys hostel PH-I	NEED TO CHANGE RESTROOM CFL LIGHT FOR ROOM NO 1	Muthu. B.	9W LED LIGHT 1NO CHANGED		Sambasivam. K. - Canteen - Boys Hostel	30/08/2022
Comp. Dt. : 01/09/2022 Status : Completed								
569	22090029	Boys hostel PH-I	NEED TO CHANGE TUBELIGHT FOR ROOM NO 57	Lakshmanan.V.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 2NO'S CHANGED		Sambasivam. K. - Canteen - Boys Hostel	02/09/2022
Comp. Dt. : 05/09/2022 Status : Completed								
570	22090168	Boys hostel P.H-III	NEED TO CHANGE TUBELIGHT FOR ROOM NO 21 & 40	Lakshmanan.V.	22W LED LIGHT 2NO'S CHANGED		Sambasivam. K. - Canteen - Boys Hostel	06/09/2022
Comp. Dt. : 06/09/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
571	22090225	Boys hostel PH-I	FAN [2NOS] SLOW PROBLEM - ROOM NO 46	Muthu. B.	CEILING FAN CAPACITOR 2.5MFT 2NO'S CHANGED		Sambasivam. K. - Canteen - Boys Hostel	07/09/2022
Comp. Dt. : 07/09/2022 Status : Completed								
572	22090265	Boys hostel PH-I	NEED TO CHANGE TUBELIGHT FOR ROOM NO 55	Lakshmanan.V.	36W TUBE LIGHT 1NO CHANGED		Mathubalan. M. - Canteen - Boys Hostel	08/09/2022
573	22090288	Boys hostel PH-I	FAN NOT WORKING - ROOM NO 53	Muthu. B.	CEILING FAN CAPACITOR 2.5MFT 1NO CHANGED		Mathubalan. M. - Canteen - Boys Hostel	08/09/2022
Comp. Dt. : 09/09/2022 Status : Completed								
574	22090380	Boys hostel P.H-III	NEED TO CHANGE RESTROOM CFL LIGHT FOR ROOM NO 46	Lakshmanan.V.	9W LED LIGHT 1NO CHANGED		Sambasivam. K. - Canteen - Boys Hostel	10/09/2022
575	22090381	Boys hostel Phase-II	NEED TO CHANGE RESTROOM TUBELIGHT [2NOS] FOR II FLOOR COMMON RESTROOM	Lakshmanan.V.	36W TUBE LIGHT 1NO CHANGED		Sambasivam. K. - Canteen - Boys Hostel	10/09/2022
Comp. Dt. : 10/09/2022 Status : Completed								
576	22090417	Boys hostel P.H-III	NEED TO CHANGE TUBELIGHT FOR ROOM NO 46	Muthu. B.	36W TUBE LIGHT 1NO CHANGED		Sambasivam. K. - Canteen - Boys Hostel	13/09/2022
Comp. Dt. : 12/09/2022 Status : Completed								
577	22090428	Boys hostel Phase-II	NEED TO CHANGE TUBELIGHT FOR IV FLOOR COMMON RESTROOM	Lakshmanan.V.	36W TUBE LIGHT 2NO'S CHANGED		Sambasivam. K. - Canteen - Boys Hostel	13/09/2022
Comp. Dt. : 13/09/2022 Status : Completed								
578	22090473	BOYS HOSTEL MESS	NEED TO REPLACE EXHAUST FAN - NOT WORKING	Srinivasan. R.	18" EXHAUST FAN 1NO REWINDING & BEARING CHANG & FAN REFIXNG & LINE CONNECTION WORK PROBLEM SOLVED		Elumalai. M. - Canteen - Boys Hostel	12/10/2022
579	22090481	boys hostel-gym	NEED TO CHECK TREADMILL CABLE & TUBELIGHT - NOT WORKING	Dhakshinamoorthy. J	TREADMILL WIRE CUT RECONNECTION WORK PROBLEM SOLVED		Sambasivam. K. - Canteen - Boys Hostel	14/09/2022
580	22090482	Boys hostel Phase-II	NEED TO CHECK SWITCH BOARD NOT WORKING IN ROOM NO 58	Dhakshinamoorthy. J	6A SWITCH 1NO CHANGED		Sambasivam. K. - Canteen - Boys Hostel	14/09/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
581	22090483	Boys hostel PH-I	NEED TO CHANGE TUBELIGHT FOR ROOM NO 28	Srinivasan. R.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Sambasivam. K. - Canteen - Boys Hostel	14/09/2022
Comp. Dt. : 14/09/2022 Status : Completed								
582	22090535	Boys hostel Phase-II	NEED TO CHANGE TUBELIGHT FOR ROOMNO 62	Manikandan. M.	36W TUBE LIGHT 1NO CHANGED		Sambasivam. K. - Canteen - Boys Hostel	15/09/2022
583	22090561	Boys hostel P.H-III	FAN NOT WORKING ROOM NO 49	Manikandan. M.	6A SWITCH 1NO CHANGED		Sambasivam. K. - Canteen - Boys Hostel	15/09/2022
Comp. Dt. : 17/09/2022 Status : Completed								
584	22090688	Boys hostel PH-I	NEED TO CHANGE CFL LIGHT FOR RESTROOM - ROOM NO 42 & TUBELIGHT FOR ROOM NO 7	Manikandan. M.	9W LED LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Sambasivam. K. - Canteen - Boys Hostel	19/09/2022
585	22090692	Boys hostel PH-I	NEED TO CHANGE SWITCH BOS - DAMAGE & BROKEN - ROOM NO 3	Manikandan. M.	4M SWITCH BOARD 1NO SCREW REFIXING WORK PROBLEM SOLVED		Sambasivam. K. - Canteen - Boys Hostel	19/09/2022
Comp. Dt. : 19/09/2022 Status : Completed								
586	22090697	Boys hostel	NEED TO CHANGE TUBELIGHT FOR COMPUTER ROOM	Manikandan. M.	TUBE LIGHT 40W STARTER 1NO CHANGED		Kesavaraj. P. - Canteen - Boys Hostel	20/09/2022
Comp. Dt. : 21/09/2022 Status : Completed								
587	22090856	Boys hostel Phase-II	HEATER NOT WORKING - II FLOOR COMMON RESTROOM	Lakshmanan.V.	WATER HEATER RESET WORK & HEATER CHEKING WORK PROBLEM SOLVED		Sambasivam. K. - Canteen - Boys Hostel	22/09/2022
Comp. Dt. : 22/09/2022 Status : Completed								
588	22090879	Boys hostel PH-I	NEED TO CHANGE CFL LIGHT FOR ROOM NO 51	Manikandan. M.	9W LED LIGHT 1NO CHANGED		Sambasivam. K. - Canteen - Boys Hostel	23/09/2022
Comp. Dt. : 28/09/2022 Status : Completed								
589	22091125	Boys hostel P.H-III	HEATER NOT WORKING - ROOM NO 16	Lakshmanan.V.	WATER HEATER 1NO RESET WORK PROBLEM SOLVED		Sambasivam. K. - Canteen - Boys Hostel	29/09/2022
Comp. Dt. : 29/09/2022								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
590	22091157	Boys hostel Phase-II	NEED TO CHANGE TUBELIGHT - ROOM NO 55	Lakshmanan.V.	36W TUBE LIGHT 3NO'S CHANG & 40W STARTER 3NO'S CHANGED		Sambasivam. K. - Canteen - Boys Hostel	30/09/2022
Comp. Dt. : 30/09/2022								
Status : Completed								
591	22091219	Boys hostel PH-I	NEED TO CHANGE TUBELIGHT FOR ROOM NO 54	Srinivasan. R.	TUBE LIGHT 40W STARTER 1NO CHANGED		Sambasivam. K. - Canteen - Boys Hostel	01/10/2022
592	22091230	Boys hostel P.H-III	NEED TO CHANGE RESTROOM CFL LIGHT FOR ROOM NO 7	Lakshmanan.V.	9W LED LIGHT 1NO CHANGED		Sambasivam. K. - Canteen - Boys Hostel	01/10/2022
593	22091231	BOYS HOSTEL-DINING HALL	NEED FAN CLEANING & SERVICE FOR RECEPTION & DINING HALL 1 & 2	Lakshmanan.V.	ALL CEILING FAN & WALLMOUNTING FAN CLEANING WORK PROBLEM SOLVED		Sambasivam. K. - Canteen - Boys Hostel	01/10/2022
Comp. Dt. : 06/10/2022								
Status : Completed								
594	22100096	Boys hostel PH-I	NEED TO CHANGE TUBELIGHT [3NOS] FOR ROOM NO 11	Vijayaraghavan.B.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 3NO'S CHANGED		Sambasivam. K. - Canteen - Boys Hostel	06/10/2022
595	22100118	Mit boys hostel	NEED TO REARRANGE FOCUS LIGHT CABLES	Dhakshinamoorthy. J	FOCUS LIGHT CABLE REARRANGE WORK PROBLEM SOLVED		Sambasivam. K. - Canteen - Boys Hostel	08/10/2022
596	22100122	Boys hostel Phase-II	COMMON HEATER NOT WORKING AT III FLOOR	Manimaran. P.	WATER HEATER 1NO RESET WORK PROBLEM SOLVED		Sambasivam. K. - Canteen - Boys Hostel	07/10/2022
Comp. Dt. : 07/10/2022								
Status : Completed								
597	22100152	Boys hostel PH-I	NEED TO CHANGE TUBELIGHT 2NOS FOR ROOM NO 23	Muthu. B.	TUBE LIGHT 40W STARTER 2NO'S CHANGED		Sambasivam. K. - Canteen - Boys Hostel	08/10/2022
Comp. Dt. : 11/10/2022								
Status : Completed								
598	22100279	Boys hostel PH-I	NEED TO CHECK FAN FOR ROOM NO 22 & TUBELIGHT FOR ROOM NO 30 - NOT WORKING	Dhakshinamoorthy. J	CEILING FAN CAPACITOR 2.5MFT 1NO CHANG & 36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Sambasivam. K. - Canteen - Boys Hostel	12/10/2022
599	22100280	Boys hostel Phase-II	NEED TO CHANGE TUBELIGHT FOR ROOM NO 55	Dhakshinamoorthy. J	TUBE LIGHT 40W STARTER 1NO CHANGED		Sambasivam. K. - Canteen - Boys Hostel	12/10/2022
600	22100281	Boys hostel P.H-III	NEED TO CHANGE RESTROOM CFL LIGHT - FOR ROOM NO 3	Dhakshinamoorthy. J	9W LED LIGHT 1NO CHANGED		Sambasivam. K. - Canteen - Boys Hostel	12/10/2022
Comp. Dt. : 13/10/2022								

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
601	22100398	Boys hostel PH-I	NEED TO CHANGE REST ROOM CFL LIGHT FOR ROOM NO 52	Vijayaraghavan.B.	9W LED LIGHT 1NO CHANGED		Sambasivam. K. - Canteen - Boys Hostel	14/10/2022
Comp. Dt. : 15/10/2022								
Status : Completed								
602	22100481	CANTEEN-COMMERCIAL COMPLEX	NEED TO CHANGE TUBELIGHT	Dhakshinamoorthy. J	36W TUBE LIGHT 2NO'S CHANG & 40W STARTER 3NO'S CHANGED		Anand. G. - Transport	17/10/2022
Comp. Dt. : 17/10/2022								
Status : Completed								
603	22100516	Boys hostel PH-I	NEED TO CHECK FAN SOUND PROBLEM - ROOM NO 22 & 47	Muthu. B.	CEILING FAN BEARING 4NO'S CHANG & FAN REFIXING WORK PROBLEM SOLVED		Sambasivam. K. - Canteen - Boys Hostel	03/11/2022
Comp. Dt. : 19/10/2022								
Status : Completed								
604	22100648	Boys hostel PH-I	IN ROOM NO-12,ONE TUBELIGHT NOT WORKING	Lakshmanan.V.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Mathubalan. M. - Canteen - Boys Hostel	20/10/2022
Comp. Dt. : 08/11/2022								
Status : Completed								
605	22110261	Boys hostel Phase-II	FAN REGULATOR NOT WORKING IN ROOM NO. 30	Muthu. B.	CEILING FAN REGULATOR 1NO CHANGED		Mathubalan. M. - Canteen - Boys Hostel	14/11/2022
Comp. Dt. : 10/11/2022								
Status : Completed								
606	22110400	Boys hostel PH-I	IN ROOM NO.30,37,38-NIGHT LAMP NOT WORKING	Muthu. B.	0.5W NIGHT LAMP 1NO CHANGED		Sambasivam. K. - Canteen - Boys Hostel	11/11/2022
Comp. Dt. : 15/11/2022								
Status : Completed								
607	22110608	Boys hostel PH-I	IN ROOM NO.47-1 TUBELIGHT NOT WORKING	Lakshmanan.V.	TUBE LIGHT 40W STARTER 1NO CHANGED		Sambasivam. K. - Canteen - Boys Hostel	16/11/2022
Comp. Dt. : 21/11/2022								
Status : Completed								
608	22110854	Boys hostel PH-I	IN ROOM NO.48-1 CFL BULB NEED TO BE CHANGE	Dhakshinamoorthy. J	9W LED LIGHT 1NO CHANGED		Sambasivam. K. - Canteen - Boys Hostel	21/11/2022
Comp. Dt. : 22/11/2022								

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
609	22110926	Boys hostel PH-I	NEED TO FIX NEW REGULATOR AND BLUE COLOUR NIGHT LAMP FOR ROOM NO 36	Dhakshinamoorthy. J	CEILING FAN REGULATOR 1NO CHANG & 0.5W NIGHT LAMP 1NO CHANGED		Mathubalan. M. - Canteen - Boys Hostel	25/11/2022
Comp. Dt. : 25/11/2022								
Status : Completed								
610	22111078	BOYS HOSTEL-DINING HALL	1 TUBELIGHT NOT WORKING	Lakshmanan.V.	20W LED TUBE LIGHT CHOKE 1NO CHANG & FITTING REFIXING WORK PROBLEM SOLVED		Kesavaraj. P. - Canteen - Boys Hostel	09/12/2022
Comp. Dt. : 29/11/2022								
Status : Completed								
611	22111218	Boys hostel P.H-III	NEED TO CHANGE CFL LIGHT FOR REST ROOM NO 4 & NIGHT LAMP FOR ROOM NO 9	Muthu. B.	9W LED LIGHT 1NO CHANG & 0.5W NIGHT LAMP 1NO CHANGED		Sambasivam. K. - Canteen - Boys Hostel	30/11/2022
612	22111219	Boys hostel PH-I	PLUG POINT NOT WORKING ROOM NO 19	Muthu. B.	PLUG PINT 1NO REFIXING WORK PROBLEM SOLVED		Sambasivam. K. - Canteen - Boys Hostel	30/11/2022
613	22111220	Boys hostel PH-I	FAN NOT WORKING ROOM NO 40	Muthu. B.	CEILING FAN BEARING 2NO'S CHANG & FAN 1NO REFIXING WORK PROBLEM SOLVED		Sambasivam. K. - Canteen - Boys Hostel	01/12/2022
Comp. Dt. : 30/11/2022								
Status : Completed								
614	22111266	Boys hostel P.H-III	TUBELIGHT NOT WORKING IN ROOM NO. 23	Srinivasan. R.	TUBE LIGHT 40W STARTER 1NO CHANGED		Sambasivam. K. - Canteen - Boys Hostel	01/12/2022
615	22111267	Boys hostel P.H-III	NIGHT LAMP NOT WORKING AT ROOM NO.12,20&26	Vijayaraghavan.B.	0.5W NIGHT LAMP 3NO'S CHANGED		Sambasivam. K. - Canteen - Boys Hostel	01/12/2022
Comp. Dt. : 05/12/2022								
Status : Completed								
616	22120160	Boys hostel P.H-III	NEED TO CHANGE CFL LIGHT FOR ROOM NO 4 & 26 & TUBELIGHT FOR STUDY ROOM FOR ROOM NO 4	Dhakshinamoorthy. J	9W LED LIGHT 2NO'S CHANG & 36W TUBE LIGHT 1NO CHANG & 40W CHOKE 1NO CHANGED		Sambasivam. K. - Canteen - Boys Hostel	06/12/2022
617	22120161	Boys hostel PH-I	NEED TO CHANGE NIGHT LAMP FOR ROOM NO 48	Dhakshinamoorthy. J	0.5W NIGHT LAMP 1NO CHANGED		Sambasivam. K. - Canteen - Boys Hostel	06/12/2022
618	22120162	Boys hostel Phase-II	NEED TO CHANGE TUBELIGHT FOR ROOM NO 52	Dhakshinamoorthy. J	369W TUBE LIGHT 1NO CHANG & 36W CHOKE 1NO CHANGED		Sambasivam. K. - Canteen - Boys Hostel	06/12/2022
Comp. Dt. : 06/12/2022								

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
619	22120219	Boys hostel Phase-II	NEED TO CHECK MAIN SWITCH & NIGHT LAMP - NOT WORKING - ROOM NO 55	Vijayaraghavan.B.	16A SWITCH 1NO CHANG & 0.5W NIGHT LAMP 1NO CHANGED		Mathubalan. M. - Canteen - Boys Hostel	07/12/2022
Comp. Dt. : 08/12/2022								
Status : Completed								
620	22120362	Boys hostel P.H-III	IN ROOM NO.3 NIGHT LAMP NEED TO CHANGE	Muthu. B.	ANGLE HOLDER 1NO CHANG & 0.5W NIGHT LAMP 1NO CHANGED		Sambasivam. K. - Canteen - Boys Hostel	10/12/2022
Comp. Dt. : 09/12/2022								
Status : Completed								
621	22120442	Boys hostel P.H-III	NEED TO CHECK HEATER TAP - SHOCK PROBLEM - ROOM NO 2 NEED URGENT SERVICE	Lakshmanan.V.	WATER HEATER CHEKING WORK PROBLEM SOLVED		Sambasivam. K. - Canteen - Boys Hostel	15/12/2022
622	22120443	Boys hostel P.H-III	NEED TO FIX NEW CFL LIGHT WITH HOLDER FOR ROOM NO 1 & 10 [OPPOSITE TO MIRROR SIDE]	Rajan. R.	AHGLE HOLDER 2NO'S CHANG & 9W LED LIGHT 2NO'S CHANGED		Sambasivam. K. - Canteen - Boys Hostel	10/12/2022
Comp. Dt. : 13/12/2022								
Status : Completed								
623	22120588	Boys hostel Phase-II	NEED TO CHANGE TUBEL;IGHT FOR ROOM NO 61 & CFL LIGHT FOR ROOM NO 37	Lakshmanan.V.	9W LED LIGHT 1NO CHANG & 36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Sambasivam. K. - Canteen - Boys Hostel	14/12/2022
624	22120589	Boys hostel Phase-II	HEATER NOT WORKING - ROOM NO 48	Lakshmanan.V.	WATER HEATER NEW THERMO CUT CHANG & LINE CONECTION WORK PROBLEM SOLVED		Sambasivam. K. - Canteen - Boys Hostel	20/12/2022
625	22120590	Boys hostel PH-I	NEED TO CHECK FAN - SLOW PROBLEM ROOM NO 3,8 & 20	Lakshmanan.V.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 3NO'S CHANGED		Sambasivam. K. - Canteen - Boys Hostel	14/12/2022
Comp. Dt. : 14/12/2022								
Status : Completed								
626	22120629	Boys hostel PH-I	TUBELIGHT NOT WORKING - ROOM NO 31	Dhakshinamoorthy. J	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Sambasivam. K. - Canteen - Boys Hostel	15/12/2022
627	22120630	Boys hostel P.H-III	NEED TO CHANGE LED TUBELIGHT [2NOS] FOR ROOM NO 24 & FAN NOT WORKING ROOM NO 32	Dhakshinamoorthy. J	9W LED LIGHT 2FEET 1NO CHANG & 36W TUBE LIGHT FITTING 1NO CHANGED		Sambasivam. K. - Canteen - Boys Hostel	15/12/2022
Comp. Dt. : 15/12/2022								
Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
628	22120716	Boys hostel Phase-II	NEED TO CHANGE TUBELIGHT 5 NOS FOR ROOM NO 27 , 32 & II FLOOR CARITOR	Dhakshinamoorthy. J	36W TUBE LIGHT 5NO'S CHANG & 40W STARTER 5NO'S CHANG & 36W CHOKE 1NO CHANGED		Sambasivam. K. - Canteen - Boys Hostel	16/12/2022
629	22120717	Boys hostel PH-I	3 PIN SOCKET NOT WORKING AT WINDOW SIDE FOR ROOM NO 47	Dhakshinamoorthy. J	MCB TRIP ON TO WORK PROBLEM SOLVED		Sambasivam. K. - Canteen - Boys Hostel	16/12/2022
630	22120722	Boys hostel Phase-II	NEED TO CHANGE TUBELIGHT 7 NOS FOR [III FLOOR COMMON REST ROOM 4NOS & ROOM NO 40,41 & 44]	Dhakshinamoorthy. J	36W CHOKE 1NO CHANG & 36W TUBE LIGHT 3NO'S CHANG & 40W STARTER 5NO'S CHANGED		Sambasivam. K. - Canteen - Boys Hostel	16/12/2022
631	22120723	Boys hostel Phase-II	NEED TO CHANGE NIGHT LAMP FOR ROOM NO 45 , 46 & 47	Dhakshinamoorthy. J	0.5W NIGHT LAMP 3NO'S CHANGED		Sambasivam. K. - Canteen - Boys Hostel	16/12/2022
632	22120739	Boys hostel PH-I	COMMON HEATER AT IV FLOOR NOT WORKING	Dhakshinamoorthy. J	WATER HEATER NEW 2KW COIL 1NO CHANG & LINE CONECTION WORK PROBLEM SOLVED		Sambasivam. K. - Canteen - Boys Hostel	20/12/2022
Comp. Dt. : 16/12/2022 Status : Completed								
633	22120768	Boys hostel P.H-III	HEATER NOT WORKING ROOM NO 41 & 44	Dhakshinamoorthy. J	MCB TRIP ON TO WORK PROBLEM SOLVED		Mathubalan. M. - Canteen - Boys Hostel	17/12/2022
634	22120769	Boys hostel Phase-II	NEED TO CHANGE TUBELIGHT FOR ROOM NO 55	Dhakshinamoorthy. J	TUBE LIGHT 1NO CHANG & 36W CHOKE 1NO CHANGED		Mathubalan. M. - Canteen - Boys Hostel	17/12/2022
635	22120795	Kitchen - Boys Hostel	GRINDER NOT WORKING	Dhakshinamoorthy. J	GRINDER BELT NO:33 1NO CHANGED		Anand. G. - Transport	17/12/2022
Comp. Dt. : 20/12/2022 Status : Completed								
636	22120909	Boys hostel PH-I	TUBELIGHT NOT WORKING IN ROOM NO 48 & 53	Lakshmanan.V.	36W TUBE LIGHT 2NO'S CHANG & 40W STARTER 1NO CHANGED		Sambasivam. K. - Canteen - Boys Hostel	21/12/2022
Comp. Dt. : 26/12/2022 Status : Completed								
637	22121184	Boys hostel PH-I	2NOS TUBELIGHT NOT WORKING IN ROOM NO 19	Dhakshinamoorthy. J	TUBE LIGHT 40W STARTER 2NO'S CHANGED		Sambasivam. K. - Canteen - Boys Hostel	27/12/2022
Comp. Dt. : 30/12/2022 Status : Completed								
638	22121358	Boys hostel PH-I	IN ROOM NO.33-MAIN SWITCH NOT WORKING	Muthu. B.	Wire problem, solved		Mathubalan. M. - Canteen - Boys Hostel	31/12/2022
Comp. Dt. : 31/12/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
639	22121406	Boys hostel Phase-II	IN 3RD FLOOR COMMON BATHROOM-WATER HEATER NOT WORKING	Muthu. B.	WATER HEATER RESET WORK PROBLEM SOLVED		Sambasivam. K. - Canteen - Boys Hostel	02/01/2023
	Comp. Dt. : 04/01/2023							
	Status : Completed							
640	23010154	Boys hostel	IN STORE ROOM-1 TUBELIGHT NOT WORKING	Lakshmanan.V.	TUBE LIGHT 36W 1NO CHANG & 40W STARTER 1NO CHANGED		Elumalai. M. - Canteen - Boys Hostel	05/01/2023
	Comp. Dt. : 05/01/2023							
	Status : Completed							
641	23010219	Boys hostel P.H-III	TUBELIGHT NOT WORKING IN ROOM NO.40	Dhakshinamoorthy. J	20W NEW LED LIGHT 1NO FIXING & LINE CONNECTION WORK PROBLEM SOLVED		Sambasivam. K. - Canteen - Boys Hostel	06/01/2023
	Comp. Dt. : 11/01/2023							
	Status : Completed							
642	23010442	Boys hostel PH-I	IN 4TH FLOOR-COMMON BATHROOM-WATER HEATER NOT WORKING	Muthu. B.	WATER HEATER SWITCH CHEKING WORK NO PROBLEM SOLVED		Sambasivam. K. - Canteen - Boys Hostel	13/01/2023
	Comp. Dt. : 19/01/2023							
	Status : Completed							
643	23010667	Boys hostel P.H-III	HEATER NOT WORKING - ROOM NO 43	Dhakshinamoorthy. J	NEW 15LTR WATER HEATER 1NO FIXING & LINE CONNECTION WORK PROBLEM SOLVED		Mathubalan. M. - Canteen - Boys Hostel	27/01/2023
644	23010687	Boys hostel	NEED TO CHECK STORE ROOM TUBELIGHT & KITCHEN HEATER - NOT WORKING	Dhakshinamoorthy. J	WATER HEATER CHEKING WORK PLUMING COMPLAINT & TUBE LIGHT 40W STARTER 1NO CHANGED		Elumalai. M. - Canteen - Boys Hostel	20/01/2023
	Comp. Dt. : 20/01/2023							
	Status : Completed							
645	23010744	Boys hostel P.H-III	NEED TO CHANGE REST ROM LIGHT FOR ROOM NO 12	Dhakshinamoorthy. J	9W LED LIGHT 1NO CHANGED		Mathubalan. M. - Canteen - Boys Hostel	21/01/2023
	Comp. Dt. : 21/01/2023							
	Status : Completed							
646	23010769	Boys hostel PH-I	NEED TO CHANGE RESTROOM LIGHT FOR ROOM NO 13	Dhakshinamoorthy. J	36W TUBE LIGHT 1NO CHANGED		Mathubalan. M. - Canteen - Boys Hostel	23/01/2023
647	23010779	Boys hostel	NEED TO CHECK GRINDER - NOT WORKING	Dhakshinamoorthy. J	GRINDER NEW BELT:33 1NO CHANG & GRINDER CHEKING WORK PROBLEM SOLVED		esavaraj. P. - Canteen - Boys Hostel	24/01/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 23/01/2023 Status : Completed								
648	23010818	Boys hostel P.H-III	NEED TO CHANGE RESTROOM CFL LIGHT FOR ROOM NO 32 & 40	Lakshmanan.V.	9W LED LIGHT 2NO'S CHANGED		Sambasivam. K. - Canteen - Boys Hostel	24/01/2023
649	23010819	BADMITTON COURT	NEED TO CHANGE FOCUS LIGHT FOR BADMITTON COURT	Srinivasan. R.	100W LED FOCUS LIGHT 1NO REFIXING WORK LINE CONNECTION WORK PROBLEM SOLVED		Sambasivam. K. - Canteen - Boys Hostel	02/02/2023
650	23010820	Boys hostel PH-I	NEED TO CHANGE TUBELIGHT FOR ROOM NO 6 & 44	Lakshmanan.V.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Sambasivam. K. - Canteen - Boys Hostel	24/01/2023
651	23010821	Boys hostel Phase-II	HEATER NOT WORKING AT II FLOOR COMMON RESTROOM	Lakshmanan.V.	WATER HEATER 1NO RESET WORK PROBLEM SOLVED		Sambasivam. K. - Canteen - Boys Hostel	24/01/2023
652	23010822	Boys hostel PH-I	FAN NOT WORKING ROOM NO 39	Lakshmanan.V.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Sambasivam. K. - Canteen - Boys Hostel	24/01/2023
Comp. Dt. : 28/01/2023 Status : Completed								
653	23011013	Boys hostel PH-I	NEED TO CHANGE TUBELIGHT 4 NOS	Lakshmanan.V.	36W TUBE LIGHT 3NO'S CHANG & 36W CHOKE 1NO CHANG & 40W STARTER 4NO'S CHANGED		Sambasivam. K. - Canteen - Boys Hostel	30/01/2023
Comp. Dt. : 30/01/2023 Status : Completed								
654	23011063	Boys hostel PH-I	NEED TO CHANGE TUBELIGHT 6 NOS FOR CARITOR	Muthu. B.	36W TUBE LIGHT 3NO'S CHANG & 40W STARTER 6NO'S CHNAG & SIDE HOLDER 2NO'S CHANG & FAN CAPACITOR 2.5MF		Sambasivam. K. - Canteen - Boys Hostel	31/01/2023
Comp. Dt. : 31/01/2023 Status : Completed								
655	23011106	Boys hostel	NEED TO CHECK SWITCH [2NOS] AT KITCHEN - NOT WORKING	Vijayaraghavan.B.	16A SWITCH 1NO CHANG & 6A SWITCH 1NO CHANGED		Sambasivam. K. - Canteen - Boys Hostel	31/01/2023
Comp. Dt. : 02/02/2023 Status : Completed								
656	23020051	Boys hostel P.H-III	NEED TO CHANGE TUBELIGHT FOR ROOM NO 3	Lakshmanan.V.	20W LED Tube light fitting- 1nos Fixed		Sambasivam. K. - Canteen - Boys Hostel	03/02/2023
Comp. Dt. : 04/02/2023 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
657	23020123	Boys hostel	NEED TO CHANGE TUBELIGHT FOR COMPUTER ROOM	Lakshmanan.V.	TUBE LIGHT SIDE HOLDER 2NO'S CHANGED		Anand. G. - Transport	06/02/2023
658	23020135	Boys hostel PH-I	NEED TO CHANGE TUBELIGHT FOR ROOM NO 49	Lakshmanan.V.	TUBE LIGHT 40W STARTER 1NO CHANGED		Sambasivam. K. - Canteen - Boys Hostel	06/02/2023
659	23020136	Boys hostel Phase-II	NEED TO CHANGE TUBELIGHT FOR ROOM NO 58	Muthu. B.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Sambasivam. K. - Canteen - Boys Hostel	06/02/2023
660	23020148	Boys hostel PH-I	NEED TO CHANGE TUBELIGHT FOR ROOM NO 34	Lakshmanan.V.	TUBE LIGHT 40W STARTER 2NO'S CHANGED		Mathubalan. M. - Canteen - Boys Hostel	06/02/2023
Comp. Dt. : 06/02/2023 Status : Completed								
661	23020164	Boys hostel P.H-III	NEED TO CHANGE CFL LIGHT FOR REST ROOM - ROOM NO 30	Dhakshinamoorthy. J	9W LED LIGHT 1NO CHANGED		Sambasivam. K. - Canteen - Boys Hostel	07/02/2023
Comp. Dt. : 07/02/2023 Status : Completed								
662	23020242	Boys hostel PH-I	NEED TO CHANGE TUBELIGHT FOR ROOM NO 52	Lakshmanan.V.	starter 1 nos and tube 1 nos changed		Sambasivam. K. - Canteen - Boys Hostel	08/02/2023
663	23020253	Boys hostel	TUBELIGHT & FAN NOT WORKING IN STAFF CANTEEN	Lakshmanan.V.	tube 1nos changed		Elumalai. M. - Canteen - Boys Hostel	08/02/2023
664	23020255	Kitchen - Boys Hostel	HEATER NOT WORKING	Lakshmanan.V.	kitchen heater mcb trip , trip on		Elumalai. M. - Canteen - Boys Hostel	08/02/2023
Comp. Dt. : 11/02/2023 Status : Completed								
665	23020428	Boys hostel PH-I	FAN SOUND PROBLEM IN ROOM NO 42 & 44	Dhakshinamoorthy. J	CEILING FAN BEARING 4NO'S CHANG & FAN 2NO'S REFIXING WORK & LINE CONNECTION WORK PROBLEM SOLVED		Sambasivam. K. - Canteen - Boys Hostel	15/02/2023
666	23020441	BOYS HOSTEL MESS	NEED TO CHECK KITCHEN VESSEL HEATER NOT WORKING	Lakshmanan.V.	WATER HEATER 1NO RESET WORK PROBLEM SOLVED		Elumalai. M. - Canteen - Boys Hostel	13/02/2023
Comp. Dt. : 13/02/2023 Status : Completed								
667	23020460	Boys hostel Phase-II	NEED TO CHANGE TUBELIGHT FOR ROOM NO 37	Dhakshinamoorthy. J	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Sambasivam. K. - Canteen - Boys Hostel	14/02/2023
668	23020461	Boys hostel P.H-III	NEED TO CHANGE TUBELIGHT FOR ROOM NO 40	Dhakshinamoorthy. J	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Sambasivam. K. - Canteen - Boys Hostel	14/02/2023


Dr. KAGNE. R.N.
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 14/02/2023								
Status : Completed								
669	23020517	Boys hostel PH-I	NEED TO CHANGE TUBELIGHT FOR ROOM NO 36	Vijayaraghavan.B.	36W TUBE LIGHT 1NO CHANGED		Sambasivam. K. - Canteen - Boys Hostel	15/02/2023
670	23020518	Boys hostel Phase-II	NEED TO CHANGE TUBELIGHT FOR ROOM NO 27	Vijayaraghavan.B.	36W TUBE LIGHT 1NO CHANGED		Sambasivam. K. - Canteen - Boys Hostel	15/02/2023
Comp. Dt. : 17/02/2023								
Status : Completed								
671	23020686	Boys hostel PH-I	FAN SOUND PROBLEM ROOM NO 42 & NEED TO CHANGE RESTROOM CFL LIGHT FOR ROOM NO 1	Dhakshinamoorthy. J	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO & 9W LED LIGHT 1NO CHANGED		Sambasivam. K. - Canteen - Boys Hostel	18/02/2023
Comp. Dt. : 18/02/2023								
Status : Completed								
672	23020734	Boys hostel PH-I	NEED TO CHANGE TUBELIGHT FOR ROOM NO 35	Dhakshinamoorthy. J	36W TUBE LIGHT 1NO CHANGED		Sambasivam. K. - Canteen - Boys Hostel	20/02/2023
Comp. Dt. : 20/02/2023								
Status : Completed								
673	23020770	Boys hostel Phase-II	BEED TO CHANGE TUBELIGHT - ROOM NO 43	Muthu. B.	TUBE LIGHT 40W STARTER 1NO CHANGED		Mathubalan. M. - Canteen - Boys Hostel	22/02/2023
674	23020772	Boys hostel PH-I	FAN SLOW PROBLEM ROOM NO 41	Muthu. B.	CEILING FAN CAPACITOR 2.5MFT 1NO CHANGED		Mathubalan. M. - Canteen - Boys Hostel	22/02/2023
Comp. Dt. : 21/02/2023								
Status : Completed								
675	23020786	COMMERCIAL BLOCK	NEED TO CHANGE TUBELIGHT NEAR STEPS	Srinivasan. R.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Anand. G. - Transport	22/02/2023
676	23020798	Boys hostel Phase-II	NEED TO CHANGE TUBELIGHT FOR ROOM NO 35	Muthu. B.	TUBE LIGHT 40W STARTER 1NO CHANGED		Sambasivam. K. - Canteen - Boys Hostel	22/02/2023
677	23020799	Boys hostel PH-I	NEED TO CHANGE TUBELIGHT FOR ROOM NO 47	Muthu. B.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Sambasivam. K. - Canteen - Boys Hostel	22/02/2023
Comp. Dt. : 24/02/2023								
Status : Completed								
678	23020929	Boys hostel PH-I	NEED TO FIX NEW TUBELIGHT FITTING FOR ROOM NO 46	Muthu. B.	36W TUBE LIGHT FITTING 1NO FIXING WORK PROBLEM SOLVED		Sambasivam. K. - Canteen - Boys Hostel	25/02/2023

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
679	23020930	Boys hostel P.H-III	NEED TO CHANGE RESTROOM CFL LIGHT FOR ROOM NO 17	Muthu. B.	9W LED LIGHT 1NO CHANGED		Sambasivam. K. - Canteen - Boys Hostel	25/02/2023
Comp. Dt. : 27/02/2023 Status : Completed								
680	23021019	Boys hostel P.H-III	NEED TO REFIX HEATER FOR III FLOOR COMMON RESTROOM	Dhakshinamoorthy. J	WATER HEATER SCREW REFIXING WORK PROBLEM SOLVED		Sambasivam. K. - Canteen - Boys Hostel	28/02/2023
681	23021034	Boys hostel	NEED TO CHANGE TUBELIGHT FOR STORE ROOM	Srinivasan. R.	TUBE LIGHT 40W STARTER 1NO CHANGED		Elumalai. M. - Canteen - Boys Hostel	01/03/2023
Comp. Dt. : 02/03/2023 Status : Completed								
682	23030068	Boys hostel P.H-III	NEED TO CHANGE TUBELIGHT FOR ROOM NO 16	Dhakshinamoorthy. J	22W LED LIGHT WIRE LOOSE SCREW REFIXING WORK PROBLEM SOLVED		Sambasivam. K. - Canteen - Boys Hostel	03/03/2023
Comp. Dt. : 07/03/2023 Status : Completed								
683	23030277	Boys hostel PH-I	NEED TO CHANGE TUBELIGHT FOR ROOM NO 41	Manikandan. M.	TUBE LIGHT 40W STARTER 1NO CHANGED		Sambasivam. K. - Canteen - Boys Hostel	08/03/2023
Comp. Dt. : 09/03/2023 Status : Completed								
684	23030370	Boys hostel PH-I	FAN SOUND PROBLEM - ROOM NO 41	Manimaran. P.	Fan sound problem rectified.		Sambasivam. K. - Canteen - Boys Hostel	10/03/2023
Comp. Dt. : 10/03/2023 Status : Completed								
685	23030414	Boys hostel	NEED TO CHANGE TUBELIGHT FOR KITCHEN AREA	Dhakshinamoorthy. J	TUBE LIGHT 40W STARTER 1NO CHANGED		Kesavaraj. P. - Canteen - Boys Hostel	11/03/2023
686	23030416	Boys hostel	HEATER NOT WORKING AT WASHING AREA	Dhakshinamoorthy. J	WATER HEATER 1NO RESET WORK PROBLEM SOLVED		Kesavaraj. P. - Canteen - Boys Hostel	11/03/2023
Comp. Dt. : 13/03/2023 Status : Completed								
687	23030494	Boys hostel PH-I	NEED TO CHANGE CFL LIGHT FOR RESTROOM	Muthu. B.	9W LED LIGHT 1NO CHANGED		Sambasivam. K. - Canteen - Boys Hostel	15/03/2023
688	23030495	Boys hostel PH-I	NEED TO CHECK FAN - NOT WORKING - ROOM NO 38 & 43	Muthu. B.	CEILING FAN CAPACIOTR 2.5MFT 1NO CHANG & FAN BEARING 2NO'S CHANG & FAN REFIXING WORK PROBLEM SOLVED		Sambasivam. K. - Canteen - Boys Hostel	16/03/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
689	23030496	Boys hostel PH-I	NEED TO CHECK SWITCH BOX NOT WORKING - ROOM NO 16	Muthu. B.	6M PLATE 1NO CHANGED		Sambasivam. K. - Canteen - Boys Hostel	15/03/2023
Comp. Dt. : 14/03/2023 Status : Completed								
690	23030542	Boys hostel PH-I	FAN SLOW PROBLEM ROOM NO 53	Muthu. B.	CEILING FAN CAPACIOTR 2.5MFT 1NO CHANGED		Sambasivam. K. - Canteen - Boys Hostel	15/03/2023
Comp. Dt. : 15/03/2023 Status : Completed								
691	23030596	Boys hostel P.H-III	NEED TO CHANGE RESTROOM CFL LIGHT FOR ROOM NO 19	Dhakshinamoorthy. J	9W LED LIGHT 1NO CHANGED		Sambasivam. K. - Canteen - Boys Hostel	16/03/2023
Comp. Dt. : 17/03/2023 Status : Completed								
692	23030713	Boys hostel P.H-III	NEED TO CHANGE TUBELIGHT FOR ROOM NO 33 & REST ROOM C F L LIGHT FOR ROOM NO 25	Vijayaraghavan.B.	R.no: 33 tube light fitting replaced. R.no: 25 9W LED lamp 1no changed.		Sambasivam. K. - Canteen - Boys Hostel	19/03/2023
Comp. Dt. : 20/03/2023 Status : Completed								
693	23030781	Boys hostel Phase-II	FAN SLOW PROBLEM - ROOM NO 43	Muthu. B.	CEILING FAN CAPACITOR 2.5MFT 1NO CHANGED		Mathubalan. M. - Canteen - Boys Hostel	21/03/2023
Comp. Dt. : 21/03/2023 Status : Completed								
694	23030856	Boys hostel Phase-II	FAN SLOW PROBLEM ROOM NO 58	Muthu. B.	CEILING FAN CAPACIOTR 2.5MFT 1NO CHANGED		Sambasivam. K. - Canteen - Boys Hostel	27/03/2023
Comp. Dt. : 23/03/2023 Status : Completed								
695	23030953	Boys hostel Phase-II	NEED TO CHECK FAN - SLOW PROBLEM ROOM NO 53 & 35	Muthu. B.	Fan capacitor 2.5mfd 2no's changed.		Mathubalan. M. - Canteen - Boys Hostel	23/03/2023
696	23030968	Boys hostel PH-I	NEED TO CHANGE RESTROOM C F L LIGHT ROOM NO 21	Lakshmanan.V.	9W LED lamp 1no changed.		Mathubalan. M. - Canteen - Boys Hostel	24/03/2023
697	23030969	Boys hostel Phase-II	NEED TO CHANGE TUBELIGHT FOR ROOM NO 60	Lakshmanan.V.	Tube light starter 1no changed.		Mathubalan. M. - Canteen - Boys Hostel	24/03/2023
698	23030970	Boys hostel P.H-III	NEED TO CHANGE RESTROOM C F L LIGHT FOR ROOM NO 49	Manikandan. M.	9W LED lamp 1no changed.		Mathubalan. M. - Canteen - Boys Hostel	25/03/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 24/03/2023								
Status : Completed								
699	23030994	Boys hostel Phase-II	FAN SLOW PROBLEM ROOM NO 41	Manikandan. M.	2.5mfd capacitor 1no changed.		Mathubalan. M. - Canteen - Boys Hostel	25/03/2023
700	23030995	Boys hostel Phase-II	FAN SLOW PROBLEM ROOM NO 37	Manikandan. M.	Fan checked - ok.		Mathubalan. M. - Canteen - Boys Hostel	25/03/2023
701	23031020	Boys hostel PH-I	NEED TO CHANGE TUBELIGHT FOR ROOM NO 54	Manikandan. M.	Tube light starter 1no changed.		Sambasivam. K. - Canteen - Boys Hostel	25/03/2023
702	23031030	Boys hostel Phase-II	HEATER [2NOS] NOT WORKING IN III FLOOR COMMON RESTROOM	Manikandan. M.	1no heater top refixed & 1no heater checked ok.		Sambasivam. K. - Canteen - Boys Hostel	25/03/2023
Comp. Dt. : 25/03/2023								
Status : Completed								
703	23031069	Boys hostel PH-I	3 PIN SOCKET NOT WORKING ROOM NO 44	Srinivasan. R.	6A SWITCH 1NO CHANGED		Sambasivam. K. - Canteen - Boys Hostel	27/03/2023
704	23031070	Boys hostel PH-I	NEED TO CHANGE RESTROOM TUBELIGHT 2 FEET ROOM NO 23	Srinivasan. R.	20W TUBE LIGHT 1NO CHANGED		Sambasivam. K. - Canteen - Boys Hostel	27/03/2023
705	23031071	Boys hostel P.H-III	NEED TO CHANGE TUBELIGHT 2 NOS FOR ROOM NO 10	Manikandan. M.	No complaint.		Sambasivam. K. - Canteen - Boys Hostel	29/03/2023
706	23031072	Boys hostel P.H-III	FAN SLOW PROBLEM & NEED TO CHANGE NIGHT LAMP FOR ROOM NO 19	Muthu. B.	Fan checked - ok & Night lamp 1no changed.		Sambasivam. K. - Canteen - Boys Hostel	04/04/2023
Comp. Dt. : 28/03/2023								
Status : Completed								
707	23031176	Boys hostel Phase-II	FAN SLOW PROBLEM - ROOM NO 58	Vijayaraghavan.B.	Fan capacitor 2.5mfd 1no changed.		Sambasivam. K. - Canteen - Boys Hostel	29/03/2023
Comp. Dt. : 30/03/2023								
Status : Completed								
708	23031320	Boys hostel PH-I	FAN SLOW PROBLEM - ROOM NO 45	Vijayaraghavan.B.	Fan capacitor 2.5mfd 1no changed.		Sambasivam. K. - Canteen - Boys Hostel	01/04/2023
Comp. Dt. : 31/03/2023								
Status : Completed								
709	23031334	CANTEEN-COMMERCIA L COMPLEX	NEED TO CHANGE TUBELIGHT	Vijayaraghavan.B.	Tube light starter 1no changed.		Anand. G. - Transport	01/04/2023
710	23031337	BOYS HOSTEL MESS	NEED TO CHECK GRINDER - SOUND PROBLEM	Dhakshinamoorthy. J	Mechanical problem.		Elumalai. M. - Canteen - Boys Hostel	03/04/2023

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 01/04/2023 Status : Completed								
711	23040014	CANTEEN-COMMERCE L COMPLEX	GRINDER NOT WORKING	Dhakshinamoorthy. J	Mechanical fault.		Anand. G. - Transport	03/04/2023
Comp. Dt. : 03/04/2023 Status : Completed								
712	23040082	Boys hostel Phase-II	NEED FAN REPAIRING WORK - ROOM NO 55	Muthu. B.	Fan checked - ok.		Sambasivam. K. - Canteen - Boys Hostel	04/04/2023
Comp. Dt. : 06/04/2023 Status : Completed								
713	23040205	BOYS HOSTEL MESS	MIXIE NOT WORKING	Vaithianathan.M	MIXIE SERVICE WORK CHEKING WORK PROBLEM SOLVED		Kesavaraj. P. - Canteen - Boys Hostel	09/05/2023
Comp. Dt. : 08/04/2023 Status : Completed								
714	23040237	Boys hostel P.H-III	NEED TO CHANGE TUBELIGHT - ROOM NO 21	Vijayaraghavan.B.	20W LED fitting replaced.		Sambasivam. K. - Canteen - Boys Hostel	10/04/2023
715	23040238	Boys hostel P.H-III	NEED TO CHANGE CFL LIGHT FOR MIRROR SIDE TOP - ROOM NO 10	Vijayaraghavan.B.	9W LED lamp replaced.		Sambasivam. K. - Canteen - Boys Hostel	10/04/2023
Comp. Dt. : 10/04/2023 Status : Completed								
716	23040284	Boys hostel	EXHAUST FAN NOT WORKING IN KITCHEN	Dhakshinamoorthy. J	18" EXHAUST FAN COIL REWINDING WORK & FAN FIXING & LINE CONNECTION WORK PROBLEM SOLVED		Elumalai. M. - Canteen - Boys Hostel	22/04/2023
717	23040285	Boys hostel	NEED TO CHANGE TUBELIGHT FOR KITCHEN	Vijayaraghavan.B.	36W tube light 1no changed.		Elumalai. M. - Canteen - Boys Hostel	11/04/2023
718	23040286	Boys hostel	NEED TO REFIX WEIGHT MACHINE CABLE - DAMAGE & NOT WORKING	Dhakshinamoorthy. J	Biomedical problem.		Elumalai. M. - Canteen - Boys Hostel	11/04/2023
Comp. Dt. : 11/04/2023 Status : Completed								
719	23040311	Boys hostel PH-I	NEED TO CHANGE SWITCH - NOT WORKING ROOM NO 44	Manikandan. M.	Switch checked - ok.		Sambasivam. K. - Canteen - Boys Hostel	11/04/2023
720	23040312	Boys hostel Phase-II	TUBELIGHT NOT WORKING ROOM NO 34	Manikandan. M.	36W tube light 1no changed.		Sambasivam. K. - Canteen - Boys Hostel	11/04/2023
Comp. Dt. : 12/04/2023								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
721	23040366	Boys hostel P,H-III	NEED TO CHANGE REST ROOM C F L LIGHT FOR ROOM NO 21	Srinivasan. R.	9W LED lamp 1no changed.		Sambasivam. K. - Canteen - Boys Hostel	13/04/2023
722	23040367	Boys hostel Phase-II	TRIP PROBLEM - NEED TO CHECK III FLOOR COMMON REST ROOM HEATER - [IF THE HEATER SWITCH ON , ALL	Srinivasan. R.,Manimaran. P.,Muthu. B.	Heating element problem. New Heating element 2KW changed and fixed.		Sambasivam. K. - Canteen - Boys Hostel	15/04/2023
723	23040371	BOYS HOSTEL MESS	NEED SERVICE FOR PEST KILLER 3 NOS	Manikandan. M.	Pest killer 3no's serviced.		Sambasivam. K. - Canteen - Boys Hostel	13/04/2023
Comp. Dt. : 17/04/2023								
Status : Completed								
724	23040505	Boys hostel P,H-III	NEED TO CHANGE TUBELIGHT [T5] FOR ROOM NO 28	Srinivasan. R.	NEW 22W LED LIGHT 1NO FIXING & LINE CONNECTION WORK PROBLEM SOLVED		Sambasivam. K. - Canteen - Boys Hostel	18/04/2023
Comp. Dt. : 19/04/2023								
Status : Completed								
725	23040607	Boys hostel Phase-II	NEED TO CHECK FAN SLOW PROBLEM - ROOM NO 57	Manikandan. M.	CEILING FAN CAPACITOR 2.5MFT 1NO CHANGED		Sambasivam. K. - Canteen - Boys Hostel	20/04/2023
Comp. Dt. : 20/04/2023								
Status : Completed								
726	23040643	Boys hostel PH-I	FAN SLOW PROBLEM - ROOM NO 25	Lakshmanan.V.	CEILING FAN CAPACIOT 2.5MFT 1NO CHANGED		Sambasivam. K. - Canteen - Boys Hostel	22/04/2023
727	23040674	Boys hostel PH-I	FAN SLOW PROBLEM - ROOM NO 20	Lakshmanan.V.	CEILING FAN CAPACIOTOR 2.5MFT 1NO CHANGED		Sambasivam. K. - Canteen - Boys Hostel	22/04/2023
Comp. Dt. : 24/04/2023								
Status : Completed								
728	23040746	Boys hostel P,H-III	NEED TO CHANGE RESTROOM CFL LIGHT FOR ROOM NO 21	Manimaran. P.	9W LED LIGHT 1NO CHANGED		Sambasivam. K. - Canteen - Boys Hostel	25/04/2023
729	23040766	Boys hostel P,H-III	NEED TO CHANGE TUBELIGHT FOR ROOM NO 3 [T5 SIZE]	Manimaran. P.	NEW 22W LED TUBE LIGHT 1NO CHANGED		Sambasivam. K. - Canteen - Boys Hostel	25/04/2023
Comp. Dt. : 25/04/2023								
Status : Completed								
730	23040794	BOY HOSTEL MESS	DEEP FREEZER PLUG POINT NOT WORKING IN DEEP FREEZER	Manikandan. M.	MCB TRIP ON TO WORK PROBLEM SOLVED		Kesavaraj. P. - Canteen - Boys Hostel	02/05/2023

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 27/04/2023								
Status : Completed								
731	23040916	Boys hostel Phase-II	NEED TO CHANGE TUBELIGHT FOR ROOM NO 34	Dhakshinamoorthy. J	36W TUBE LIGHT 1NO & 40W STARTER 1NO CHANGED		Sambasivam. K. - Canteen - Boys Hostel	28/04/2023
Comp. Dt. : 28/04/2023								
Status : Completed								
732	23040957	BOY HOSTEL MESS	EXHAUST FAN NOT WORKING	Muthu. B.	EXHAUST FAN 1NO SERVICE WORK & FAN REFIXING WORK PROBLEM SOLVED		Kesavaraj. P. - Canteen - Boys Hostel	03/05/2023
Comp. Dt. : 03/05/2023								
Status : Completed								
733	23050083	Boys hostel P.H-III	NEED TO CHANGE TUBELIGHT FOR ROOM NO 33 [T5 SIZE]	Rajan. R.	TUBE LIGHT CHEKING WORK NO COMPLAINT		Sambasivam. K. - Canteen - Boys Hostel	04/05/2023
Comp. Dt. : 04/05/2023								
Status : Completed								
734	23050136	BOYS HOSTEL MESS	NEED TO CHECK VEGITABLE CUTTING MACHINE - SHOCK PROBLEM	Dhakshinamoorthy. J	MOTOR SWITCH PROBLEM. Motor serviced and tested ok and new belt changed.		Kesavaraj. P. - Canteen - Boys Hostel	26/05/2023
Comp. Dt. : 08/05/2023								
Status : Completed								
735	23050290	Boys hostel	NEED TO CHANGE TUBELIGHT FOR SYSTEM ROOM	Manimaran. P.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Kesavaraj. P. - Canteen - Boys Hostel	09/05/2023
Comp. Dt. : 11/05/2023								
Status : Completed								
736	23050446	Boys hostel P.H-III	HEATER NOT WORKING - II FLOOR COMMON RESTROOM	Dhakshinamoorthy. J	WATER HEATER 1NO RESET WORK PROBLEM SOLVED		Mathubalan. M. - Canteen - Boys Hostel	12/05/2023
Comp. Dt. : 12/05/2023								
Status : Completed								
737	23050486	Boys hostel	NEED TO CHANGE TUBELIGHT FOR GYM 2NOS & III FLOOR COMMON RESTROOM [2NOS]	Lakshmanan.V.	36W TUBE LIGHT 4NO'S CHANG & 40W STARTER 5NO'S CHANGED		Sambasivam. K. - Canteen - Boys Hostel	13/05/2023
738	23050487	Boys hostel Phase-II	NEED TO CHANGE TUBELIGHT FOR ROOM NO 59	Lakshmanan.V.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Sambasivam. K. - Canteen - Boys Hostel	13/05/2023

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 13/05/2023								
Status : Completed								
739	23050539	Boys hostel Phase-II	TUBELIGHT [2NOS] & HEATER NOT WORKING AT IV FLOOR COMMON RESTROOM	Manikandan. M.	36W tube light 2no's & starter 2no's changed.		Sambasivam. K. - Canteen - Boys Hostel	15/05/2023
740	23050540	Boys hostel P.H-III	NEED TO CHANGE TUBELIGHT FOR ROOM NO 33	Manikandan. M.	Tube light starter 1no changed.		Sambasivam. K. - Canteen - Boys Hostel	15/05/2023
741	23050541	Boys hostel PH-I	NEED TO CHANGE RESTROOM TUBELIGHT [2FEET] 2 NOS	Manikandan. M.	36W tube light 1no, copper choke 1no & starter 1no changed.		Sambasivam. K. - Canteen - Boys Hostel	15/05/2023
742	23050542	Boys hostel PH-I	NEED TO CHANGE TUBELIGHT FOR ROOM NO 37	Manikandan. M.	20W tube light 1no changed.		Sambasivam. K. - Canteen - Boys Hostel	15/05/2023
743	23050543	Boys hostel PH-I	NEED FAN CLEANING WORK FOR DINNING HALL I & II AND RECEPTION AREA	Manikandan. M.	Fan cleaned.		Sambasivam. K. - Canteen - Boys Hostel	15/05/2023
744	23050544	Boys hostel PH-I	HEATER SWITCH NOT WORKING AT I FLOOR COMMON RESTROOM	Manikandan. M.	16A SWITCH 1NO CHANGED		Sambasivam. K. - Canteen - Boys Hostel	16/05/2023
Comp. Dt. : 15/05/2023								
Status : Completed								
745	23050590	Boys hostel PH-I	FAN SLOW PROBLEM - ROOM NO 37	Muthu. B.	CEILING FAN CAPACITOR 2.5MFT 1NO CHANGED		Sambasivam. K. - Canteen - Boys Hostel	16/05/2023
746	23050591	Boys hostel P.H-III	NEED TO FIX NEW CFL LIGHT SET FOR DRESSING TABLE OPPOSITE FOR ROOM NO 5	Muthu. B.	9W LED LIGHT 1NO CHANG & ANGLE HOLDER 1NO CHANGED		Sambasivam. K. - Canteen - Boys Hostel	16/05/2023
747	23050618	Boys hostel P.H-III	FAN SLOW PROBLEM - ROOM NO 43	Muthu. B.	CEILING FAN CAPACITOR 2.5MFT 1NO CHANGED		Sambasivam. K. - Canteen - Boys Hostel	16/05/2023
748	23050619	Boys hostel	FAN NOT WORKING AT RECEPTION SECURITY ROOM	Muthu. B.	WALLMOUNTING FAN 1NO REMOVING TO ELECTRICAL ROOM		Sambasivam. K. - Canteen - Boys Hostel	16/05/2023
Comp. Dt. : 16/05/2023								
Status : Completed								
749	23050661	Boys hostel P.H-III	NEED TO CHANGE TUBELIGHT FOR ROOM NO 33 [T5 SIZE]	Lakshmanan.V.	22W LED TUBE LIGHT 1NO FIXING WORK PROBLEM SOLVED		Sambasivam. K. - Canteen - Boys Hostel	16/05/2023
750	23050662	Boys hostel Phase-II	NEED TO CHANGE TUBELIGHT FOR NEAR II FLOOR STEPS	Dhakshinamoorthy. J	TUBE LIGHT 40W STARTER 1NO CHANGED		Sambasivam. K. - Canteen - Boys Hostel	17/05/2023
Comp. Dt. : 18/05/2023								
Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
751	23050763	Boys hostel Phase-II	NEED TO CHANGE TUBELIGHT FOR GROUND FLOOR LIFT OPPOSITE	Muthu. B.	TUBE LIGHT 40W STARTER 2NO'S CHANGED		Sambasivam. K. - Canteen - Boys Hostel	19/05/2023
Comp. Dt. : 19/05/2023 Status : Completed								
752	23050783	Boys hostel P,H-III	FAN [2NOS] SLOW PROBLEM - ROOM NO 28	Dhakshinamoorthy. J	CEILING FAN CAPACITOR 2.5MFT 1NO CHANGED		Sambasivam. K. - Canteen - Boys Hostel	20/05/2023
Comp. Dt. : 23/05/2023 Status : Completed								
753	23050934	Boys hostel Phase-II	NEED TO CHANGE TUBELIGHT FOR ROOM NO 28	Muthu. B.	TUBE LIGHT 40W STARTER 1NO CHANGED		Sambasivam. K. - Canteen - Boys Hostel	24/05/2023
Comp. Dt. : 24/05/2023 Status : Completed								
754	23050948	Boys hostel PH-I	NEED REPAIRING WORK FOR SWITCH [2NOS] NOT WORKING - ROOM NO 7	Lakshmanan.V.	6A SWITCH 2NO'S CHANGED		Sambasivam. K. - Canteen - Boys Hostel	25/05/2023
755	23050949	Boys hostel Phase-II	NEED TO CHECK " MAIN POWER STOP SWITCH" NOT WORKING - ROOM NO 52	Lakshmanan.V.	16A SWITCH 1NO CHANG & LINE CONNECTION WORK PROBLEM SOLVED		Sambasivam. K. - Canteen - Boys Hostel	25/05/2023
Comp. Dt. : 26/05/2023 Status : Completed								
756	23051018	Boys hostel P,H-III	NEED TO CHANGE TUBELIGHT FOR ROOM NO 32	Lakshmanan.V.	No complaint.		Mathubalan. M. - Canteen - Boys Hostel	27/05/2023
757	23051019	Boys hostel P,H-III	NEED TO CHANGE STUDY LIGHT FOR ROOM NO 33	Lakshmanan.V.	20W LED fitting 1no fixed.		Mathubalan. M. - Canteen - Boys Hostel	27/05/2023
Comp. Dt. : 29/05/2023 Status : Completed								
758	23051142	Boys hostel	NEED TO CHANGE EXHAUST FAN LINE CONNECTION	Thillaikumar. R.	EXHAUST FAN WIRE LOOSE RECONNECTION WORK PROBLEM SOLVED		Kesavaraj. P. - Canteen - Boys Hostel	30/05/2023
759	23051146	Boys hostel PH-I	NEED TO CHANGE TUBELIGHT FOR ROOM NO 12	Thillaikumar. R.	TUBE LIGHT 40W STARTER 1NO CHANGED		Sambasivam. K. - Canteen - Boys Hostel	30/05/2023
760	23051147	Boys hostel P,H-III	NEED TO CHANGE CFL LIGHT FOR RESTROOM - NO 14	Thillaikumar. R.	9W LED LIGHT 1NO CHANGED		Sambasivam. K. - Canteen - Boys Hostel	30/05/2023
Comp. Dt. : 02/06/2023 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
761	23060065	STAFF'S CANTEEN	NEED TO CHANGE TUBELIGHT FOR SUPPLY AREA	Muthu. B.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Kesavaraj. P. - Canteen - Boys Hostel	02/06/2023
762	23060066	Boys hostel P.H-III	NEED TO CHANGE TUBELIGHT & STUDY TUBELIGHT FOR ROOM NO 32 [T5 SIZE]	Lakshmanan.V.	22W TUBE LIGHT 1NO FIXING WORK PROBLEM SOLVED		Sambasivam. K. - Canteen - Boys Hostel	03/06/2023
Comp. Dt. : 05/06/2023 Status : Completed								
763	23060148	Boys hostel PH-I	NEED TO CHANGE TUBELIGHT FOR ROOM NO 27 & 33	Lakshmanan.V.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 2NO'S CHANGED		Sambasivam. K. - Canteen - Boys Hostel	06/06/2023
Comp. Dt. : 06/06/2023 Status : Completed								
764	23060198	Boys hostel PH-I	NEED TO CHANGE TUBELIGHT FOR ROOM NO 37	Muthu. B.	TUBE LIGHT 40W STARTER 1NO CHANGED		Sambasivam. K. - Canteen - Boys Hostel	07/06/2023
765	23060199	Boys hostel Phase-II	NEED TO CHANGE TUBELIGHT FOR II FLOOR COMMON WASHING AREA	Vijayaraghavan.B.	36W TUBE LIGHT 1NO CHANG & 40W CHOKE 1NO CHANGED		Sambasivam. K. - Canteen - Boys Hostel	07/06/2023
Comp. Dt. : 12/06/2023 Status : Completed								
766	23060409	Boys hostel	MIXIE JAR PROBLEM	Suresh. V.	copper bush, blade & coupler changed.		Anand. G. - Transport	20/06/2023
Comp. Dt. : 19/06/2023 Status : Completed								
767	23060647	Boys hostel Phase-II	NEED TO CHANGE TUBELIGHT FOR ROOM NO 30	Vijayaraghavan.B.	TUBE LIGHT 40W STARTER 1NO CHANGED		Mathubalan. M. - Canteen - Boys Hostel	20/06/2023
Comp. Dt. : 26/06/2023 Status : Completed								
768	23060986	Boys hostel PH-I	NEED TO CHANGE TUBELIGHT FOR ROOM NO 19	Muthu. B.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Sambasivam. K. - Canteen - Boys Hostel	27/06/2023
769	23060987	Boys hostel P.H-III	NEED TO CHANGE CFL LIGHT FOR RESTROOM - ROOM NO 20	Vijayaraghavan.B.	9w led 1nos changed		Sambasivam. K. - Canteen - Boys Hostel	28/06/2023
Comp. Dt. : 28/06/2023 Status : Completed								
770	23061070	Boys hostel PH-I	NEED TO CHANGE RESTROOM CFL LIGHT FOR ROOM NO 35	Vijayaraghavan.B.	9W LED LIGHT 1NO CHANGED		Mathubalan. M. - Canteen - Boys Hostel	30/06/2023

Dept Name : Canteen - Hospital - Electrical Maintenance

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 17/10/2022 Status : Completed								
771	22100548	DIET DEPARMENT	NEED TO CHANGE TUBELIGHT NEAR V FLOOR STEPS & EXHAUST FAN NOT WORKING	Srinivasan. R.	12" EXHAUST FAN 1NO REWINDING BEARING CHANG & FAN REFIXING WORK PROBLEM SOLVED		Sankar. M. - Canteen - Hospital	03/12/2022
Comp. Dt. : 07/11/2022 Status : Completed								
772	22110202	DIET DEPARMENT	TUBELIGHT NOT WORKING IN STORE	Vijayaraghavan.B.	E.choke 36W 1no & tube light 1no changed.		Sankar. M. - Canteen - Hospital	07/11/2022
Comp. Dt. : 05/06/2023 Status : Completed								
773	23060165	DIET DEPARMENT	NEED TO CHANGE BEARING FOR FLOUR MACHINE	Rajan. R.	FLOUR MACHINE GEER SIDE SOUNT PROBLEM SHIFTING TO SERVICE CENTER		Suriyaprakash. R. J. - Canteen - Hospital	07/06/2023
Dept Name : Canteen-Girls Hostel - Electrical Maintenance Comp. Dt. : 02/05/2022 Status : Completed								
774	22050006	Ladies hostel Phase-I	NEED TO CHECK PEST CONTROL LIGHT [2 NOS] IN MESS	Lakshmanan.V.,Mani maran. P.,Dhakshinamoorthy. J	PEST CONTROL LIGHT STARTER 1NO CHANG & WIRE CUT RECONNECTION WORK PROBLEM SOLVED		Revathy. N. - Canteen-Girls Hostel	09/05/2022
775	22050007	Ladies hostel Phase-I	NEED TO CHANGE TUBELIGHT FOR IV FLOOR STEPS & NIGHT LAMP FOR ROOM NO 50	Srinivasan. R.	0.5W LED NIGHT LAMP 1NO CHANG & 36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Revathy. N. - Canteen-Girls Hostel	05/05/2022
776	22050033	JR Quarters	NEED TO CHANGE NIGHT LAMP FOR ROOM NO 18	Srinivasan. R.	0.5W LED NIGHT LAMP 1NO CHANGED		Virgin Mary - Canteen-Girls Hostel	05/05/2022
Comp. Dt. : 04/05/2022 Status : Completed								
777	22050096	Ladies hostel Phase-I	NEED CABLE LINE CONNECTION FOR FIXING NEW AC - ROOM NO 9	Srinivasan. R.	NEW A/C LINE WIRING WORK 25A SOCKET 1NO, 25ASWITCH 1NO,2M SURFACE BOX 2NO'S 2.5SQ MM WIRE 15MTR FIXI		Revathy. N. - Canteen-Girls Hostel	09/05/2022
Comp. Dt. : 05/05/2022 Status : Completed								
778	22050124	Ladies hostel Phase-II	NEED TO CHANGE TUBELIGHT 3NOS FOR STUDY HALL & II & III FLOOR	Dhakshinamoorthy. J	36W TUBE LIGHT 2NO'S CHANG & 40W STARTER 1NO CHANGED		Malliga. K. - Canteen-Girls Hostel	09/05/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
779	22050126	JR Quarters	NEED TO CHECK PLUG POINT NOT WORKING IN ROOM NO 5 + NEED TO REFIX FAN FOR ROOM NO 18	Lakshmanan.V.	WALLMOUNTING FAN 1NO REFIXING WORK PROBLEM SOLVED		Virgin Mary - Canteen-Girls Hostel	09/05/2022
Comp. Dt. : 06/05/2022		Status : Completed						
780	22050192	Ladies hostel Phase-I	NEED TO CHANGE TUBELIGHT FOR ROOM NO 5 [2NOS]	Muthu. B.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Revathy. N. - Canteen-Girls Hostel	12/05/2022
Comp. Dt. : 07/05/2022		Status : Completed						
781	22050235	JR Quarters	FAN SLOW PROBLEM ROOM NO 58	Muthu. B.	CEILING FAN CAPACITOR 2.5MFT 1NO CHANGED		Virgin Mary - Canteen-Girls Hostel	09/05/2022
Comp. Dt. : 09/05/2022		Status : Completed						
782	22050251	Ladies hostel Phase-I	NEED NEW ELECTRICAL LINE CONNECTION FOR FIXING NEW AC FOR ROOM NO 9	Srinivasan. R.	NEW A/C LINE CONNECTION & WIRING WORK PROBLEM SOLVED		Revathy. N. - Canteen-Girls Hostel	12/05/2022
783	22050259	JR Quarters	NEED TO CHANGE TUBELIGHT FOR ROOM NO 9,17,19 & FAN SLOW PROBLEM IN ROOM NO 58	Muthu. B.	CEILIING FAN CAPACITOR 2.5MFT 1NO CHANG & 0.5W NIGHT LAMP 3NO'S CHANGED		Virgin Mary - Canteen-Girls Hostel	12/05/2022
784	22050272	Ladies hostel Phase-II	NEED TO CHANGE NIGHT LAMP FOR ROOM NO 79 & TUBELIGHT FOR ROOM NO 79 & I & III FLOOR RESTROOM	Muthu. B.	CEILING FAN CAPACITOR 2.5MFT 1NO CHANG & 0.5W NIGHT LAMP 1NO CHANG & 36W TUBE LIGHT 1NO CHANGED		Malliga. K. - Canteen-Girls Hostel	12/05/2022
785	22050299	LADIES HOSTEL MESS	NEED TO CHANGE TUBELIGHT	Dhakshinamoorthy. J	36W TUBE LIGHT 1NO CHANGED		Revathy. N. - Canteen-Girls Hostel	12/05/2022
786	22050312	Ladies hostel Phase-I	FAN NOT WORKING IN ROOM NO 4	Muthu. B.	CEILING FAN CAPACITOR 2.5MFT 1NO CHANGED		Revathy. N. - Canteen-Girls Hostel	13/05/2022
Comp. Dt. : 10/05/2022		Status : Completed						
787	22050323	JR Quarters	NEED TO REFIX FAN FOR ROOM NO 5	Muthu. B.	36W TUBE LIGHT 1NO CHANGED		Virgin Mary - Canteen-Girls Hostel	12/05/2022
788	22050325	Ladies hostel Phase-I	NEED TO CHANGE TUBELIGHT FOR ROOM NO 13 & 59	Muthu. B.	36W TUBE LIGHT 1NO CHANG & 40W STARTER		Revathy. N. - Canteen-Girls Hostel	12/05/2022
789	22050334	Ladies hostel Phase-II	NEED TO CHECK FAN SLOW PROBLEM - ROOM NO 89 ,70,42,36 & CHANGE NIGHT LAMP FOR ROOM NO 89	Dhakshinamoorthy. J	0.5W NIGHT LAMP 1NO CHANG & CEILING FAN CAPACITOR 2.5MFT 3NO'S CHANGED		Malliga. K. - Canteen-Girls Hostel	12/05/2022
Comp. Dt. : 16/05/2022								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
790	22050528	JR Quarters	NEED TO CHANGE SWITCH BOARD - NOT WORKING & SPARK COMING AT ROOM NO 68 - II FLOOR	Manimaran. P.	6A SOCKET 2NO'S CHANGED		Virgin Mary - Canteen-Girls Hostel	17/05/2022
791	22050529	JR Quarters	NEED TO CHANGE TUBELIGHT FOR II & GROUND FLOOR CARITOR	Manimaran. P.	36W TUBE LIGHT 2NO'S CHANG & 40W STARTER 1NO CHANGED		Virgin Mary - Canteen-Girls Hostel	17/05/2022
792	22050544	Ladies hostel Phase-II	NEED TO CLOSE SWITCH BOX [FIX CAP] FOR ROOM NO 31 & FAN SLOW PROBLEM IN ROOM NO 73	Manimaran. P.	FAN CAPACITOR 1NO CHANG & WALLMOUNTING FAN 1NO REFIXING WORK PROBLEM SOLVED		Malliga. K. - Canteen-Girls Hostel	17/05/2022
793	22050554	Ladies hostel Phase-II	NEED CABLE CONNECTION FOR TV HALL TV	Lakshmanan.V.	SETUP BOX CABLE CONNECTION WORK PROBLEM SOLVED		Revathy. N. - Canteen-Girls Hostel	21/05/2022
794	22050563	Ladies hostel Phase-I	NEED TO CHECK EXHAUST FAN AT KITCHEN - PROBLEM & BURNT	Vijayaraghavan.B.	18" EXHAUST FAN 1NO REFIXING WORK PROBLEM SOLVED		Revathy. N. - Canteen-Girls Hostel	20/05/2022
Comp. Dt. : 17/05/2022								
Status : Completed								
795	22050601	Ladies hostel Phase-II	FAN NOT WORKING ROOM NO 94 & NEED TO CHANGE TUBELIGHT FOR ROOM NO 44	Lakshmanan.V.	36W TUBE LIGHT 1NO CHANG & FAN CAPACITOR 2MFT 1NO CHANGED		Malliga. K. - Canteen-Girls Hostel	20/05/2022
796	22050602	Ladies hostel Phase-II	HEATER NOT WORKING IN IV FLOOR RESTROOM	Lakshmanan.V.	WATER HEATER NEW 2KW COIL 1NO CHANG & HEATER CHEKING WORK PROBLEM SOLVED		Malliga. K. - Canteen-Girls Hostel	20/05/2022
797	22050629	Ladies hostel Phase-I	FAN NOT WORKING - ROOM NO 1	Lakshmanan.V.	CEILING FAN CAPACITOR 2.5MFT 1NO CHANGED		Revathy. N. - Canteen-Girls Hostel	18/05/2022
Comp. Dt. : 18/05/2022								
Status : Completed								
798	22050650	Ladies hostel Phase-II	NEED TO CHANGE COIL FOR IV FLOOR HEATER	Lakshmanan.V.	WATER HEATER NEW 2KW COIL 1NO CHANG & HEATER CHEKING WORK PROBLEM SOLVED		Malliga. K. - Canteen-Girls Hostel	20/05/2022
Comp. Dt. : 20/05/2022								
Status : Completed								
799	22050766	Ladies hostel Phase-II	NEED TO CHANGE TUBELIGHT 2 NOS FOR I FLOOR REST ROOM [BOTH SIDES]	Lakshmanan.V.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Malliga. K. - Canteen-Girls Hostel	23/05/2022
Comp. Dt. : 21/05/2022								
Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
800	22050783	Ladies hostel Phase-II	NEED TO CHANGE TUBELIGHT FOR I FLOOR STUDY HALL	Lakshmanan.V.	36W TUBE LIGHT 1NO CHANG & 36W CHOKE 1NO CHANG & 36W STARTER 1NO CHANGED		Malliga. K. - Canteen-Girls Hostel	23/05/2022
Comp. Dt. : 23/05/2022 Status : Completed								
801	22050817	Ladies hostel Phase-I	NEED TO CHANGE TUBELIGHT FOR ROOM NO 41 & FAN NOT WORKING ROOM NO 52	Srinivasan. R.	36W TUBE LIGHT 40W STARTER 1NO CHANG & CEILING FAN CAPACITOR 2.5MFT 1NO CHANGED		Revathy. N. - Canteen-Girls Hostel	24/05/2022
802	22050827	Ladies hostel Phase-II	NEED TO CHANGE TUBELIGHT [2NOS] FOR IV FLOOR	Lakshmanan.V.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Malliga. K. - Canteen-Girls Hostel	25/05/2022
Comp. Dt. : 24/05/2022 Status : Completed								
803	22050865	Ladies hostel Phase-II	NEED TO CHANGE NIGHT LAMP FOR ROOM NO 115	Lakshmanan.V.	0.5 NIGHT LAMP 1NO CHANGED		Malliga. K. - Canteen-Girls Hostel	25/05/2022
804	22050899	Ladies hostel Phase-II	NEED TO CHANGE TUBELIGHT FOR I FLOOR CARITOR & REST ROOM & IV FLOOR RESTROOM	Lakshmanan.V.	40W CHOKE 2NO'S CHANG & 36W TUBE LIGHT 2NO'S CHANG & 40W STARTER 1NO CHANGED		Malliga. K. - Canteen-Girls Hostel	25/05/2022
Comp. Dt. : 26/05/2022 Status : Completed								
805	22050984	JR Quarters	NEED TO CHANGE RESTROOM TUBELIGHT [2 NOS] FOR GROUND FLOOR	Srinivasan. R.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Virgin Mary - Canteen-Girls Hostel	27/05/2022
Comp. Dt. : 28/05/2022 Status : Completed								
806	22051044	JR Quarters	NEED TO CHECK POWER - TUBELIGHT & FAN NOT WORKING FOR ROOM NO 11	Muthu. B.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Virgin Mary - Canteen-Girls Hostel	30/05/2022
807	22051053	Ladies hostel Phase-I	PROBLEM IN PLUG POINT - ROOM NO 53	Muthu. B.	SWITCH BOARD WIRE LOOSE RECONNECTION WORK PROBLEM SOLVED		Revathy. N. - Canteen-Girls Hostel	31/05/2022
Comp. Dt. : 30/05/2022 Status : Completed								
808	22051084	Ladies hostel Phase-I	NEED TO CHANGE TUBELIGHT FOR ROOM NO 49 & PLUG POINT FOR ROOM NO 53	Dhakshinamoorthy. J	36W TUBE LIGHT 1NO CHANG & 6A SOCKET WIRE CUT RECONNECTION WORK PROBLEM SOLVED		Revathy. N. - Canteen-Girls Hostel	31/05/2022
Comp. Dt. : 03/06/2022								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
809	22060130	JR Quarters	NEED TO REFIX FAN [9 NOS] FOR I FLOOR	Dhakshinamoorthy. J	WALLMOUNTING FAN 6NO'S REFIXING WORK PROBLEM SOLVED		Virgin Mary - Canteen-Girls Hostel	04/06/2022
Comp. Dt. : 04/06/2022								
Status : Completed								
810	22060151	Ladies hostel Phase-I	NEED TO CHANGE TUBELIGHT - ROOM NO 44	Lakshmanan.V.	36W TUBE LIGHT 1NO CHANGED		Revathy. N. - Canteen-Girls Hostel	06/06/2022
Comp. Dt. : 06/06/2022								
Status : Completed								
811	22060188	Ladies hostel Phase-I	NEED TO CHANGE TUBELIGHT FOR GROUND FLOOR & FAN SLOW PROBLEM IN ROOM NO 11	Muthu. B.	CEILING FAN 1NO BEARING CHANG & FAN REFIXING WORK PROBLEM SOLVED		Revathy. N. - Canteen-Girls Hostel	09/06/2022
812	22060211	Ladies hostel Phase-II	NEED TO CHANGE TUBELIGHT FOR ROOM NO 115	Muthu. B.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Malliga. K. - Canteen-Girls Hostel	07/06/2022
Comp. Dt. : 08/06/2022								
Status : Completed								
813	22060305	Ladies hostel Phase-II	NEED TO REPLACE FAN [7 NOS] FROM GROUND FLOOR TO III FLOOR	Dhakshinamoorthy. J	WALLMOUNTING FAN 3NO'S SERVICE WORK & FAN REFIXING WORK PROBLEM SOLVED		Malliga. K. - Canteen-Girls Hostel	29/06/2022
Comp. Dt. : 09/06/2022								
Status : Completed								
814	22060331	JR Quarters	NEED TO CHANGE TUBELIGHT FOR GROUND FLOOR RESTROOM	Muthu. B.	TUBE LIGHT SIDE HOLDER 1NO CHANGED		Virgin Mary - Canteen-Girls Hostel	10/06/2022
Comp. Dt. : 13/06/2022								
Status : Completed								
815	22060442	Ladies hostel Phase-II	NEED TO CHANGE TUBELIGHT FOR II FLOOR REST ROOM [2NOS] III FLOOR GIM + ROOM NO 81	Dhakshinamoorthy. J	36W Tube light 1no & starter 2no's changed.		Malliga. K. - Canteen-Girls Hostel	14/06/2022
Comp. Dt. : 14/06/2022								
Status : Completed								
816	22060502	Ladies hostel Phase-II	FAN SLOW PROBLEM IN ROOM NO 105	Lakshmanan.V.	CEILING FAN CAPACITOR 2.5MFT 1NO CHANGED		Malliga. K. - Canteen-Girls Hostel	15/06/2022
Comp. Dt. : 15/06/2022								
Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
817	22060557	JR Quarters	NEED TO CHANGE TUBELIGHT FOR ROOM NO 27 [2NOS] , 40,41 & 42 NIGHT LAMP FOR ROOM NO 26, 35 & 40	Dhakshinamoorthy. J	36W TUBE LIGHT 2NO'S CHANG & 40W STARTER 2NO'S CHANG & 36W CHOKE 1NO CHANG & 0.5W NIGHT LAMP 2NO'S C		Virgin Mary - Canteen-Girls Hostel	16/06/2022
Comp. Dt. : 16/06/2022 Status : Completed								
818	22060596	Ladies hostel Phase-II	NEED TO CHANGE RESTROOM TUBELIGHT FOR II & GROUND FLOOR	Dhakshinamoorthy. J	36W tube light 1no changed & side holder problem - solved.		Malliga. K. - Canteen-Girls Hostel	17/06/2022
819	22060606	Ladies hostel Phase-I	NEED A NEW ELECTRICAL LINE CONNECTION FOR NEW AC FIXING - ROOM NO 58	Dhakshinamoorthy. J	Power point arranged for A/C.		Revathy. N. - Canteen-Girls Hostel	18/06/2022
820	22060607	Ladies hostel Phase-I	NEED TO CHANGE TUBELIGHT FOR ROOM NO 19	Vijayaraghavan.B.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Revathy. N. - Canteen-Girls Hostel	21/06/2022
Comp. Dt. : 17/06/2022 Status : Completed								
821	22060645	Ladies hostel Phase-II	NEED TO CHANGE TUBELIGHT - ROOM NO 43	Vijayaraghavan.B.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Malliga. K. - Canteen-Girls Hostel	21/06/2022
822	22060654	Ladies hostel Phase-I	NEED TO CHANGE NIGHT LAMP FOR ROOM NO 29 & TUBELIGHT FOR ROOM NO 25	Vijayaraghavan.B.	0.5W NIGHT LAMP 1NO CHANG & 36W TUBE LIGHT 1NO CHANGED		Revathy. N. - Canteen-Girls Hostel	21/06/2022
823	22060661	Ladies hostel Phase-II	FAN NOT WORKING - ROOM NO 63	Vijayaraghavan.B.	CEILING FAN CAPACITOR 2.5MFT 1NO CHANGED		Malliga. K. - Canteen-Girls Hostel	22/06/2022
Comp. Dt. : 20/06/2022 Status : Completed								
824	22060702	Ladies hostel Phase-I	FAN NOT WORKING - ROOM NO 31 & FIX A NEW FAN FOR DINING ROOM	Vijayaraghavan.B.	CEILING FAN POINT CHEKING WORK		Revathy. N. - Canteen-Girls Hostel	29/06/2022
Comp. Dt. : 21/06/2022 Status : Completed								
825	22060750	Ladies hostel Phase-II	NEED TO CHANGE TUBELIGHT FOR ROOM NO 49 & FAN SLOW PROBLEM FOR ROOM NO 65	Vijayaraghavan.B.	36W TUBE LIGHT 1NO CHANG & CEILING FAN CAPACITOR 2.5MFT 1NO CHANGED		Malliga. K. - Canteen-Girls Hostel	22/06/2022
826	22060766	JR Quarters	NEED TO CHANGE TUBELIGHT FOR ROOM NO 75 + I FLOOR COMMON REST ROOM & FAN SLOW PROBLEM - ROOM N	Vijayaraghavan.B.	36W TUBE LIGHT 1NO CHANG & CEILING FAN CAPACITOR 2.5MFT 1NO CHANGED		Virgin Mary - Canteen-Girls Hostel	22/06/2022
827	22060768	JR Quarters	NEED TO FIX WALL FIXING FAN CLAMP FOR ROOM NO 21	Vijayaraghavan.B.	WALLMOUNTING FAN 1NO REFIXING WORK PROBLEM SOLVED		Virgin Mary - Canteen-Girls Hostel	23/06/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 22/06/2022 Status : Completed								
828	22060781	Ladies hostel Phase-I	NEED TO CHANGE TUBELIGHT FOR MESS & ROOM NO 10	Muthu. B.	36W TUBE LIGHT 2NO'S CHANG & 40W STARTER 2NO'S CHANGED		Revathy. N. - Canteen-Girls Hostel	24/06/2022
Comp. Dt. : 23/06/2022 Status : Completed								
829	22060835	Ladies hostel Phase-II	NEED TO CHANGE TUBELIGHT FOR ROOM NO 72	Muthu. B.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Virgin Mary - Canteen-Girls Hostel	24/06/2022
Comp. Dt. : 24/06/2022 Status : Completed								
830	22060890	Ladies hostel Phase-II	NEED TO CHANGE TUBELIGHT FOR ROOM NO 72	Muthu. B.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Malliga. K. - Canteen-Girls Hostel	25/06/2022
Comp. Dt. : 25/06/2022 Status : Completed								
831	22060908	Ladies hostel Phase-II	NEED TO CHECK PLUG POINT - NOT WORKING - ROOM NO 49	Muthu. B.	6A SWITCH 1NO CHANGED		Malliga. K. - Canteen-Girls Hostel	27/06/2022
Comp. Dt. : 27/06/2022 Status : Completed								
832	22060944	Ladies hostel Phase-II	NEED TO CHANGE REST ROOM TUBELIGHT FOR II & III FLOOR	Manimaran. P.	36W TUBE LIGHT 2NO'S CHANG & 36W CHOKE 1NO CHANG & 40W STARTRE 2NO'S CHANGED		Malliga. K. - Canteen-Girls Hostel	28/06/2022
Comp. Dt. : 28/06/2022 Status : Completed								
833	22060990	Ladies hostel Phase-II	FAN SOUND PROBLEM - ROOM NO 42 & CHANGE TUBELIGHT FOR ROOM NO 47	Manikandan. M.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANG & CEILING FAN BEARING 2NO'S CHANG & FAN REFIXING WO		Malliga. K. - Canteen-Girls Hostel	29/06/2022
Comp. Dt. : 29/06/2022 Status : Completed								
834	22061054	Ladies hostel Phase-I	PLUG POINT 2NOS NOT WORKING IN LADIES HOSTEL WARDEN ROOM	Lakshmanan.V.	8M PLATE 1NO CHANG & 6A SWITCH 1NO CHANGED		Revathy. N. - Canteen-Girls Hostel	30/06/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
835	22061066	Ladies hostel Phase-II	NEED TO CHANGE TUBELIGHT FOR I FLOOR CARITOR [2NOS] & ROOM NO 51	Lakshmanan.V.	36W TUBE LIGHT 3NO'S CHANG & 40W STARTER 3NO'S CHANGED		Malliga. K. - Canteen-Girls Hostel	30/06/2022
Comp. Dt. : 30/06/2022 Status : Completed								
836	22061104	JR Quarters	NEED TO CHECK TUBELIGHT NOT WORKING & FAN - NOT WORKING - SOUND & SLOW PROBLEM ROOM NO 62	Lakshmanan.V.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Virgin Mary - Canteen-Girls Hostel	01/07/2022
837	22061115	Ladies hostel Phase-II	NEED TO CHECK FAN [2] NOS - SOUND & SLOW PROBLEM ROOM NO 37	Lakshmanan.V.	CEILING FAN CAPACITOR 2.5MFT 2NO'S CHANGED		Malliga. K. - Canteen-Girls Hostel	01/07/2022
838	22061137	Ladies hostel Phase-I	NEED TO CHANGE TUBELIGHT FOR ROOM NO 22	Lakshmanan.V.	36W TUBE LIGHT 1NO CHANGED		Revathy. N. - Canteen-Girls Hostel	04/07/2022
Comp. Dt. : 01/07/2022 Status : Completed								
839	22070017	Ladies hostel Phase-II	NEED TO CHANGE TUBELIGHT - ROOM NO 81 + FAN NOT WORKING ROOM NO 92	Lakshmanan.V.	36W TUBE LIGHT 3NO'S CHANG & 40W STARTER 4NO'S CHANGED		Malliga. K. - Canteen-Girls Hostel	02/07/2022
840	22070042	JR Quarters	NEED TO CHANGE TUBELIGHT FOR GROUND FLOOR CARITOR	Lakshmanan.V.	36W TUBE LIGHT 1NO CHANG & 36W CHOKE 1NO CHANG & 40W STARTER 1NO CHANGED		Virgin Mary - Canteen-Girls Hostel	02/07/2022
Comp. Dt. : 04/07/2022 Status : Completed								
841	22070086	Ladies hostel Phase-I	NEED TO CHANGE TUBELIGHT FOR ROOM NO 25	Dhakshinamoorthy. J	36W TUBE LIGHT 1NO CHANGED		Revathy. N. - Canteen-Girls Hostel	11/07/2022
Comp. Dt. : 06/07/2022 Status : Completed								
842	22070191	Ladies hostel Phase-II	NEED TO CHANGE TUBELIGHT FOR STREET & REFIX FAN [3NOS] FOR GROUND FLOOR [2NOS] & ROOM NO 72	Vijayaraghavan.B.	3no's wallmounting fan refixed & Tube light starter 1no changed.		Malliga. K. - Canteen-Girls Hostel	07/07/2022
Comp. Dt. : 07/07/2022 Status : Completed								
843	22070258	JR Quarters	FAN NOT WORKING - I FLOOR ROOM NO 38	Muthu. B.	WALLMOUNTING FAN 1NO SERVICE WORK PROBLEM SOLVED		Virgin Mary - Canteen-Girls Hostel	13/07/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
844	22070267	Ladies hostel Phase-I	NEED TO CHANGE TUBELIGHT FOR ROOM NO 22 & RESTROOM TUBELIGHT FOR ROOM NO 53	Dhakshinamoorthy. J	R.no.22 36W tube light 1no changed. R.no.53 20W tube light 2feet 1no changed.		Revathy. N. - Canteen-Girls Hostel	08/07/2022
845	22070287	Ladies hostel Phase-II	FAN NOT WORKING ROOM NO 92	Dhakshinamoorthy. J	Wallmounting fan problem - Removed. Spare Wallmounting fan fixed.		Malliga. K. - Canteen-Girls Hostel	08/07/2022
Comp. Dt. : 09/07/2022 Status : Completed								
846	22070364	Ladies hostel Phase-I	FAN NOT WORKING ROOM NO 4	Srinivasan. R.	CEILING FAN BEARING 2NO'S CHANG & FAN REFIXING WORK PROBLEM SOLVED		Revathy. N. - Canteen-Girls Hostel	12/07/2022
847	22070365	LADIES HOSTEL MESS	TUBELIGHT [2 NOS] & SWITCH NOT WORKING	Muthu. B.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Revathy. N. - Canteen-Girls Hostel	12/07/2022
Comp. Dt. : 11/07/2022 Status : Completed								
848	22070414	JR Quarters	NEED TO CHANGE TUBELIGHT FOR ROOM NO 1 & 2 + GROUND FLOOR REST ROOM [STAFF SIDE]	Muthu. B.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 2NO'S CHANGED		Virgin Mary - Canteen-Girls Hostel	12/07/2022
Comp. Dt. : 14/07/2022 Status : Completed								
849	22070543	Ladies hostel Phase-II	NEED TO CHANGE TUBELIGHT FOR I & II FLOOR RESTROOM [3 NOS] & ROOM NO 70	Muthu. B.	36W TUBE LIGHT 2NO'S CHANG & 40W STARTER 3NO'S CHANGED		Malliga. K. - Canteen-Girls Hostel	16/07/2022
Comp. Dt. : 15/07/2022 Status : Completed								
850	22070599	Ladies hostel Phase-I	NEED TO CHANGE NIGHT LAMP FOR ROOM NO 44	Muthu. B.	0.5W NIGHT LAMP 1NO CHANGED		Revathy. N. - Canteen-Girls Hostel	18/07/2022
851	22070614	Ladies hostel Phase-II	NEED TO CHANGE TUBELIGHT FOR ROOM NO 54	Muthu. B.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Malliga. K. - Canteen-Girls Hostel	18/07/2022
Comp. Dt. : 16/07/2022 Status : Completed								
852	22070629	Ladies hostel Phase-II	NEED TO CHANGE TUBELIGHT - ROOM NO 56	Muthu. B.	36W TUBE LIGHT 1NO CHANGED		Malliga. K. - Canteen-Girls Hostel	18/07/2022
Comp. Dt. : 18/07/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
853	22070664	Ladies hostel Phase-II	NEED TO CHANGE TUBELIGHT FOR ROOM NO 39	Lakshmanan.V.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Malliga. K. - Canteen-Girls Hostel	20/07/2022
Comp. Dt. : 19/07/2022 Status : Completed								
854	22070695	LADIES HOSTEL MESS	NEED TO CHANGE PEST CONTROL MACHINE LIGHT	Dhakshinamoorthy. J	ANGLE HOLDER 1NO CHANGED		Revathy. N. - Canteen-Girls Hostel	21/07/2022
855	22070707	JR Quarters	NEED FAN SERVICE ROOM NO 24,34,37,38,42,,40,49,47, 46 & 45 + NIGHT LAMP FOR ROOM NO48 [RED] & 36 B	Lakshmanan.V.	WALLMOUNTING FAN 2NO'S FIXING WORK & 0.5W NIGHT LAMP 3NO'S CHANGED		Virgin Mary - Canteen-Girls Hostel	20/07/2022
856	22070709	Ladies hostel Phase-II	NEED TO CHECK MAIN [SWITCH] FOR ROOM NO 82	Lakshmanan.V.	16A SWITCH 1NO CHANGED		Malliga. K. - Canteen-Girls Hostel	20/07/2022
Comp. Dt. : 20/07/2022 Status : Completed								
857	22070743	JR Quarters	NEED TO CHECK FAN & NIGHT LAMP NOT WORKING ROOM NO 24,38,39,40 & 42	Vijayaraghavan.B.	0.5W NIGHT LAMP 2NO'S CHANG & HOLDER 1NO CHANGED		Virgin Mary - Canteen-Girls Hostel	21/07/2022
Comp. Dt. : 21/07/2022 Status : Completed								
858	22070783	Ladies hostel Phase-II	NEED TO CHANGE TUBELIGHT FOR ROOM NO 68,81 & II FLOOR & I FLOOR CARITOR [TOTAL 7 NOS]	Vijayaraghavan.B.	36W TUBE LIGHT 2NO'S CHANG & 40W STARTER 3NO'S CHANGED		Malliga. K. - Canteen-Girls Hostel	23/07/2022
Comp. Dt. : 23/07/2022 Status : Completed								
859	22070873	Ladies hostel Phase-II	NEED TO CHANGE TUBELIGHT FOR II FLOOR RESTROOM	Vijayaraghavan.B.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 3NO'S CHANG & 36W CHOKE 1NO CHANGED		Malliga. K. - Canteen-Girls Hostel	25/07/2022
Comp. Dt. : 25/07/2022 Status : Completed								
860	22070886	Ladies hostel Phase-I	NEED TO CHANGE TUBELIGHT FOR ROOM NO 43	Dhakshinamoorthy. J	36W TUBE LIGHT 1NO CHANGED		Revathy. N. - Canteen-Girls Hostel	26/07/2022
861	22070900	JR Quarters	NEED TO CHANGE TUBELIGHT FOR GROUND FLOOR , II FLOOR AND ROOM NO 24	Dhakshinamoorthy. J	36W TUBE LIGHT 1NO CHANG & 36W CHOKE 1NO CHANG & 40W STARTER 1NO CHANGED		Virgin Mary - Canteen-Girls Hostel	26/07/2022
862	22070901	JR Quarters	FAN SLOW PROBLEM IN ROOM NO 11	Dhakshinamoorthy. J	CEILING FAN CAPACITOR 2.5MFT 1NO CHANGED		Virgin Mary - Canteen-Girls Hostel	26/07/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
863	22070911	JR Quarters	NEED TO CHANGE TUBELIGHT FOR ROOM NO 75	Vijayaraghavan.B.	TUBE LIGHT 40W STARTER 1NO CHANGED		Virgin Mary - Canteen-Girls Hostel	25/07/2022
864	22070915	Ladies hostel Phase-II	NEED TO CHANGE TUBELIGHT FOR NEAR STEPS [I FLOOR - PHASE I SIDE] & ROOM NO 75	Dhakshinamoorthy. J	36W TUBE LIGHT 1NO CHANG & 40W STARTER 2NO'S CHANGED		Malliga. K. - Canteen-Girls Hostel	26/07/2022
Comp. Dt. : 26/07/2022 Status : Completed								
865	22070942	JR Quarters	NEED TO CHANGE TUBELIGHT FOR ROOM NO 44 & FAN NOT WORKING ROOM NO 43 & 44	Dhakshinamoorthy. J	36W TUBE LIGHT 3NO'S CHANG & 40W STARTER 3NO'S CHANGED		Virgin Mary - Canteen-Girls Hostel	27/07/2022
866	22070961	Ladies hostel Phase-II	NEED TO CHANGE TUBELIGHT FOR ROOM NO 47	Dhakshinamoorthy. J	TUBE LIGHT 40W STARTER 1NO CHANGED		Malliga. K. - Canteen-Girls Hostel	27/07/2022
Comp. Dt. : 27/07/2022 Status : Completed								
867	22071002	Ladies hostel Phase-II	NEED TO CHANGE TUBELIGHT FOR GROUND FLOOR RESTROOM	Dhakshinamoorthy. J	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Malliga. K. - Canteen-Girls Hostel	29/07/2022
868	22071024	LADIES HOSTEL MESS	NEED TO CHECK PEST KILLER MACHINE & TUBELIGHT NOT WORKING	Dhakshinamoorthy. J	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Revathy. N. - Canteen-Girls Hostel	29/07/2022
Comp. Dt. : 29/07/2022 Status : Completed								
869	22071060	JR Quarters	NEED TO CHANGE TUBELIGHT FOR II FLOOR RESTROOM & ROOM NO 43	Lakshmanan.V.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 2NO'S CHANGED		Virgin Mary - Canteen-Girls Hostel	30/07/2022
870	22071062	Ladies hostel Phase-II	NEED TO REPLACE TUBELIGHT FOR OPPOSITE WALL - ROOM NO 33	Lakshmanan.V.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Malliga. K. - Canteen-Girls Hostel	01/08/2022
871	22071083	LADIES HOSTEL MESS	GRINDER NOT WORKING	Lakshmanan.V.	GRINDER BELT NO-37 1NO CHANG & BELT NO-32 1NO CHANGED		Revathy. N. - Canteen-Girls Hostel	30/07/2022
Comp. Dt. : 30/07/2022 Status : Completed								
872	22071106	Ladies hostel Phase-II	NEED TO CHANGE TUBELIGHT FOR I & II FLOOR STUDY HALL	Lakshmanan.V.	36W TUBE LIGHT 2NO'S CHANG & 40W STARTER 1NO CHANGED		Malliga. K. - Canteen-Girls Hostel	01/08/2022
Comp. Dt. : 01/08/2022 Status : Completed								
873	22080013	JR Quarters	NEED TO UNTIE FAN - ROOM NO 54	Muthu. B.	TUBE LIGHT 40W STARTER 1NO CHANGED		Virgin Mary - Canteen-Girls Hostel	02/08/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
874	22080032	Ladies hostel Phase-II	NEED TO CHANGE RESTROOM TUBELIGHT FOR III FLOOR & NIGHT LAMP FOR ROOM NO 106	Muthu. B.	0.5W NIGHT LAMP 1NO CHANG & 36W TUBE LIGHT 1NO CHANG & SIDE HOLDER 2NO'S CHANGED		Malliga. K. - Canteen-Girls Hostel	02/08/2022
Comp. Dt. : 02/08/2022 Status : Completed								
875	22080075	Ladies hostel Phase-II	NEED TO CHANGE TUBELIGHT 7 NOS & NIGHT LAMP FOR ROOM NO 57	Manikandan. M.	0.5W NIGHT LAMP 1NO CHANG & 36W TUBE LIGHT 3NO'S CHANG & 40W STARTER 3NO'S CHANGED		Malliga. K. - Canteen-Girls Hostel	04/08/2022
Comp. Dt. : 05/08/2022 Status : Completed								
876	22080204	Ladies hostel Phase-II	NEED TO CHANGE TUBELIGHT FOR GROUND FLOOR WARDEN ROOM	Muthu. B.	TUBE LIGHT 40W STARTER 1NO CHANGED		Malliga. K. - Canteen-Girls Hostel	08/08/2022
Comp. Dt. : 08/08/2022 Status : Completed								
877	22080247	Ladies hostel Phase-I	NEED TO CHANGE TUBELIGHT & NIGHT LAMP & CHECK FAN - SOUND PROBLEM AT ROOM NO 40	Muthu. B.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANG & 0.5W NIGHT LAMP 1NO CHANG & CEILING FAN BEARING 2		Revathy. N. - Canteen-Girls Hostel	10/08/2022
878	22080248	Ladies hostel Phase-I	NEED TO CHANGE TUBELIGHT FOR MESS PESTKILLER MACHINE & LIFT	Manikandan. M.	36W TUBE LIGHT 1NO CHANG & 9W LED LIGHT 1NO CHANG & PESTKILLER WIRE LOOSE RECONNECTION WORK PROBLEM		Revathy. N. - Canteen-Girls Hostel	10/08/2022
879	22080265	Ladies hostel Phase-II	NEED TO CHANGE TUBELIGHT FOR III FLOOR REST ROOM & NEED TO CHANGE SWITCH CONNECTION INSTEAD OF ON	Muthu. B.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Malliga. K. - Canteen-Girls Hostel	09/08/2022
Comp. Dt. : 09/08/2022 Status : Completed								
880	22080323	Ladies hostel Phase-I	NEED TO CHANGE TUBELIGHT FOR ROOM NO 13	Manikandan. M.	36W TUBE LIGHT 1NO CHANGED		Revathy. N. - Canteen-Girls Hostel	10/08/2022
Comp. Dt. : 10/08/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
881	22080360	Ladies hostel Phase-II	NEED TO CHANGE TUBELIGHT FOR ROOM NO 78 & FIX A NEW SWITCH BOX FOR AC FOR ROOM NO 13	Manikandan. M.	NEW A/C WIRING WORK 25A SOCKET 1NO,25A SWITCH 1NO,16A 3PIN TOP 1NO,2M SURFACE BOX 1NO,3M SURFACE BOX		Malliga. K. - Canteen-Girls Hostel	11/08/2022
882	22080375	JR Quarters	NEED TO CHANGE TUBELIGHT FOR II FLOOR RESTROOM & I & GROUND FLOOR CARITOR	Manikandan. M.	36W TUBE LIGHT 2NO'S CHANG & 40W STARTER 2NO'D CHANGED		Virgin Mary - Canteen-Girls Hostel	11/08/2022
Comp. Dt. : 11/08/2022 Status : Completed								
883	22080405	Ladies hostel Phase-II	HEATER NOT WORKING AT III FLOOR	Srinivasan. R.	WATER HEATER 1NO RESET WORK PROBLEM SOLVED		Malliga. K. - Canteen-Girls Hostel	12/08/2022
Comp. Dt. : 12/08/2022 Status : Completed								
884	22080433	Ladies hostel Phase-II	NEED TO CHANGE TUBELIGHT FOR II & III FLOOR NEAR STEPS & III FLOOR REST ROOM	Vijayaraghavan.B.	36W tube light 1no & Starter 3no's changed.		Malliga. K. - Canteen-Girls Hostel	17/08/2022
Comp. Dt. : 18/08/2022 Status : Completed								
885	22080573	Ladies hostel Phase-I	IN MESS-PLUG POINT SOCKET NEED TO BE CHANGE	Dhakshinamoorthy. J	MCB TRIP ON TO WORK PROBLEM SOLVED		Revathy. N. - Canteen-Girls Hostel	22/08/2022
Comp. Dt. : 20/08/2022 Status : Completed								
886	22080684	Ladies hostel Phase-II	NEED TO CHANGE TUBELIGHT FOR GROUND FLOOR RESTROOM & II FLOOR CARITOR	Dhakshinamoorthy. J	36W TUBE LIGHT 1NO CHANGED		Malliga. K. - Canteen-Girls Hostel	22/08/2022
Comp. Dt. : 22/08/2022 Status : Completed								
887	22080690	Ladies hostel Phase-I	NEED TO CHANGE TUBELIGHT FOR ENTRANCE & HEATER NOT WORKING AT I FLOOR	Muthu. B.	WATER HEATER NEW 2KW COIL 1NO CHANG & 36W TUBE LIGHT 1NO CHANG & 36W TUBE LIGHT 1NO CHANGED		Revathy. N. - Canteen-Girls Hostel	23/08/2022
888	22080702	LADIES HOSTEL MESS	NEED TO CHANGE SWITCH BOARD	Dhakshinamoorthy. J	16A SOCKET 1NO CHANGED		Revathy. N. - Canteen-Girls Hostel	23/08/2022
889	22080718	Ladies hostel Phase-II	NEED TO CHANGE TUBELIGHT FOR II FLOOR STORE ROOM & ROOM NO 45	Dhakshinamoorthy. J	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Malliga. K. - Canteen-Girls Hostel	23/08/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 23/08/2022 Status : Completed								
890	22080742	JR Quarters	NEED TO CHANGE TUBELIGHT FOR I & GROUND FLOOR RESTROOM & ROOM NO 13	Muthu. B.	36W TUBE LIGHT 3NO'S CHANG & 40W STARTER 3NO'S CHANGED		Virgin Mary - Canteen-Girls Hostel	24/08/2022
Comp. Dt. : 24/08/2022 Status : Completed								
891	22080796	LADIES HOSTEL MESS	NEED TO REFIX GRINDER BELT AND OIL	Lakshmanan.V.	BELT NOI:B-37 1NO CHANG & OIL 2LTR CHANG & GRINDER CHEKING WORK PROBLEM SOLVED		Revathy. N. - Canteen-Girls Hostel	25/08/2022
892	22080806	JR Quarters	FAN NOT WORKING ROOM NO 40 + HEATER NOT WORKING AT III FLOOR	Lakshmanan.V.	CEILING FAN CAPACITOR 2.5MFT 1NO CHANG & 16A 3PIN TOP 1NO CHANGED		Virgin Mary - Canteen-Girls Hostel	25/08/2022
Comp. Dt. : 27/08/2022 Status : Completed								
893	22080935	Ladies hostel Phase-II	NEED TO CHANGE TUBELIGHT - ROOM NO 32	Muthu. B.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Malliga. K. - Canteen-Girls Hostel	30/08/2022
Comp. Dt. : 29/08/2022 Status : Completed								
894	22080976	Ladies hostel Phase-II	NEED TO CHANGE TUBELIGHT 4 NOS & NIGHT LAMP 1 NO	Muthu. B.	36W TUBE LIGHT 2NO'S CHANG & 40W STARTER 2NO'S CHANG & 0.5W NIGHT LAMP 1NO CHANGED		Virgin Mary - Canteen-Girls Hostel	30/08/2022
895	22080993	JR Quarters	NEED TO CHANGE TUBELIGHT FOR ROOM NO 33	Manikandan. M.	36W TUBE LIGHT 1NO CHANGED		Virgin Mary - Canteen-Girls Hostel	01/09/2022
896	22080998	Ladies hostel Phase-I	NEED TO CHANGE TUBELIGHT FOR ROOM NO 3 & 37	Muthu. B.	36W TUBE LIGHT 2NO'S CHANG & 40W STARTER 1NO CHANGED		Revathy. N. - Canteen-Girls Hostel	30/08/2022
Comp. Dt. : 30/08/2022 Status : Completed								
897	22081015	Ladies hostel Phase-II	NEED TO CHANGE TUBELIGHT FOR ROOM NO 89	Manikandan. M.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Malliga. K. - Canteen-Girls Hostel	01/09/2022
Comp. Dt. : 01/09/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
898	22090044	Ladies hostel Phase-II	NEED TO CHANGE TUBELIGHT FOR GROUND FLOOR STEPS , I FLOOR RESTROOM & NIGHT LAMP FOR ROOM NO 46	Manikandan. M.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 2NO'S CHANG & 0.5W NIGHT LAMP 1NO CHANGED		Malliga. K. - Canteen-Girls Hostel	02/09/2022
Comp. Dt. : 03/09/2022 Status : Completed								
899	22090117	JR Quarters	NEED TO CHANGE TUBELIGHT 2NOS FOR STUDY HALL	Dhakshinamoorthy. J	36W TUBE LIGHT 1NO CHANG & 36W CHOKE 1NO CHANG & 40W STARTER 1NO CHANGED		Virgin Mary - Canteen-Girls Hostel	03/09/2022
900	22090127	Ladies hostel Phase-II	SANITARY NAPKIN VENDING MACHINE NOT WORKING	Lakshmanan.V.	MCB TRIP ON TO WORK PROBLEM SOLVED		Malliga. K. - Canteen-Girls Hostel	05/09/2022
Comp. Dt. : 05/09/2022 Status : Completed								
901	22090163	Ladies hostel Phase-II	NEED TO CHECK SWITCH BOX FOR ROOM NO 77 & TUBELIGHT FOR III FLOOR REST ROOM & CHOKE FOR ROOM NO 88	Lakshmanan.V.	6A SWITCH 1NO CHANG & 36W TUBE LIGHT 3NO'S CHANG & 40W STARTER 2NO'S CHANGED		Malliga. K. - Canteen-Girls Hostel	06/09/2022
902	22090178	JR Quarters	NEED TO CHANGE TUBELIGHT FOR ROOM NO 6	Lakshmanan.V.	36W CHOKE 1NO CHANG & 40W STARTER 1NO CHANGED		Virgin Mary - Canteen-Girls Hostel	06/09/2022
Comp. Dt. : 06/09/2022 Status : Completed								
903	22090231	JR Quarters	HEATER NOT WORKING AT GROUND FLOOR	Lakshmanan.V.	WATER HEATER RESET WORK PROBLEM SOLVED		Virgin Mary - Canteen-Girls Hostel	07/09/2022
Comp. Dt. : 07/09/2022 Status : Completed								
904	22090268	Ladies hostel Phase-II	NEED TO CHANGE TUBELIGHT 4 NOS FOR I , II & III FLOOR	Lakshmanan.V.	36W TUBE LIGHT 2NO'S CHANG & 40W STARTER 2NO'S CHANG & 36W CHOKE 1NO CHANGED		Malliga. K. - Canteen-Girls Hostel	08/09/2022
Comp. Dt. : 08/09/2022 Status : Completed								
905	22090304	JR Quarters	NEED TO FIX TV AT II FLOOR	Vengadessaperumal. K.	SETUP BOX FIXING WORK PROBLEM SOLVED		Virgin Mary - Canteen-Girls Hostel	09/09/2022
906	22090305	JR Quarters	NEED TO CHANGE TUBELIGHT FOR ZIM ROOM & HEATER NOT WORKING AT I FLOOR	Lakshmanan.V.	WATER HEATER 2KW NEW COIL SET 1NO REFIXNG WORK & HEATER CHEKING WORK PROBLEM SOLVED		Virgin Mary - Canteen-Girls Hostel	05/10/2022
Comp. Dt. : 09/09/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
907	22090364	JR Quarters	NEED TO CHANGE TUBELIGHT FOR ROOM NO 19	Dhakshinamoorthy. J	36W TUBE LIGHT 1NO CHANGED		Virgin Mary - Canteen-Girls Hostel	13/09/2022
Comp. Dt. : 10/09/2022 Status : Completed								
908	22090401	Ladies hostel Phase-II	NEED TO CHANGE TUBELIGHT FOR ROOM NO 53 & 54	Lakshmanan.V.	36W TUBE LIGHT 2NO'S CHANG & 40W STARTER 2NO'S CHANGED		Malliga. K. - Canteen-Girls Hostel	13/09/2022
Comp. Dt. : 12/09/2022 Status : Completed								
909	22090423	JR Quarters	NEED TO CHANGE TUBELIGHT FOR GROUND FLOOR RESTROOM	Lakshmanan.V.	TUBE LIGHT 40W STARTER 1NO CHANGED		Virgin Mary - Canteen-Girls Hostel	13/09/2022
Comp. Dt. : 14/09/2022 Status : Completed								
910	22090522	Ladies hostel Phase-II	NEED TO CHANGE TUBELIGHT FOR I FLOOR RESTROOM & II FLOOR STUDY HALL	Dhakshinamoorthy. J	36W TUBE LIGHT 2NO'S CHANG & 40W STARTER 2NO'S CHANGED		Malliga. K. - Canteen-Girls Hostel	15/09/2022
911	22090547	Ladies hostel Phase-I	NEED TO CHANGE GUNDU BULB & SHORTER FOR LEFT & TUBELIGHT FOR I FLOOR - NEAR STEPS	Dhakshinamoorthy. J	36W TUBE LIGHT 2NO'S CHANG & 40W STARTER 1NO CHANGED		Revathy. N. - Canteen-Girls Hostel	15/09/2022
912	22090569	Ladies hostel Phase-II	NEED TO CHANGE TUBELIGHT FOR ROOM NO 92	Dhakshinamoorthy. J	36W TUBE LIGHT 1NO CHANG & 36W STARTER 1NO CHANGED		Malliga. K. - Canteen-Girls Hostel	15/09/2022
Comp. Dt. : 15/09/2022 Status : Completed								
913	22090597	Ladies hostel Phase-II	TV HALL - SWITCH NOT WORKING	Srinivasan. R.	6A SWITCH 1NO CHANGED		Malliga. K. - Canteen-Girls Hostel	16/09/2022
Comp. Dt. : 16/09/2022 Status : Completed								
914	22090634	Ladies hostel Phase-II	NEED TO CHANGE TUBELIGHT [2NOS] FOR GROUND FLOOR RESTROOM + FAN NOT WORKING GROUND FLOOR GUESTROOM &	Muthu. B.	TUBE LIGHT 40W STARTER 1NO CHANG & FAN WIRE LOOSE RECONNECTION WORK & SWITCH WIRE LOOSE SCREW REFIXI		Malliga. K. - Canteen-Girls Hostel	17/09/2022
Comp. Dt. : 19/09/2022 Status : Completed								
915	22090727	Ladies hostel Phase-II	NEED TO CHANGE TUBELIGHT FOR I FLOOR ENTRANCE	Lakshmanan.V.	TUBE LIGHT 40W STARTER 1NO CHANGED		Malliga. K. - Canteen-Girls Hostel	20/09/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
916	22090732	Ladies hostel Phase-I	NEED TO REFIX CABLES FOR I FLOOR	Lakshmanan.V.	DB CABLE REARRENGMENT WORK PROBLEM SOLVED		Revathy. N. - Canteen-Girls Hostel	21/09/2022
Comp. Dt. : 20/09/2022 Status : Completed								
917	22090761	JR Quarters	NEED TO CHANGE TUBELIGHT FOR I & GROUND FLOOR CARITOR	Manikandan. M.	TUBE LIGHT 40W STARTER 2NO'S CHANGED		Virgin Mary - Canteen-Girls Hostel	21/09/2022
Comp. Dt. : 24/09/2022 Status : Completed								
918	22090979	Ladies hostel Phase-II	NEED TO CHANGE TUBELIGHT FOR III FLOOR ROOM NO 95	Vijayaraghavan.B.	36W tube light 1no changed.		Malliga. K. - Canteen-Girls Hostel	26/09/2022
Comp. Dt. : 26/09/2022 Status : Completed								
919	22090996	JR Quarters	NEED TO REFIX HEATER & TUBELIGHT FOR GROUND FLOOR RESTROOM	Dhakshinamoorthy. J	WATER HEATER 1NO RESET WORK & 36W TUBE LIGHT 1NO CHANGED		Virgin Mary - Canteen-Girls Hostel	29/09/2022
920	22091008	Ladies hostel Phase-II	NEED TO CHECK TUBELIGHT & HEATER [BOTH SIDES] NOT WORKING AT GROUND FLOOR RESTROOM	Dhakshinamoorthy. J	36W TUBE LIGHT 2NO'S CHANG & 40W STARTER 2NO'S CHANG & 36W CHOKE 1NO CHANGED		Malliga. K. - Canteen-Girls Hostel	28/09/2022
921	22091011	LADIES HOSTEL MESS	NEED TO CHECK EMERGENCY LIGHT - NOT WORKING	Dhakshinamoorthy. J	10A SWITCH 1NO CHANGED		Revathy. N. - Canteen-Girls Hostel	29/09/2022
Comp. Dt. : 27/09/2022 Status : Completed								
922	22091054	Ladies hostel Phase-II	NEED TO CHANGE TUBELIGHT FOR ROOM NO68 & 101	Lakshmanan.V.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 2NO'S CHANGED		Malliga. K. - Canteen-Girls Hostel	28/09/2022
923	22091059	JR Quarters	FAN NOT WORKING ROOM NO 50	Lakshmanan.V.	WALLMOUNTING FAN 1NO ROOM SHIFTING TO R; NO 50 FIXING WORK PROBLEM SOLVED		Virgin Mary - Canteen-Girls Hostel	28/09/2022
924	22091086	JR Quarters	NEED TO CHANGE TUBELIGHT FOR ROOM NO 4	Lakshmanan.V.	36W TUBE LIGHT 1NO CHANGED		Virgin Mary - Canteen-Girls Hostel	29/09/2022
Comp. Dt. : 28/09/2022 Status : Completed								
925	22091099	JR Quarters	NEED TO CHANGE TUBELIGHT FOR ROOM NO 3 & 46	Lakshmanan.V.	36W TUBE LIGHT 1NO CHANG & SIDE HOLDER 1NO CHANG & 40W STARTER 1NO CHANGED		Virgin Mary - Canteen-Girls Hostel	29/09/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 29/09/2022 Status : Completed								
926	22091152	Ladies hostel Phase-II	NEED TO CHANGE TUBELIGHT FOR I FLOOR STEP SIDE	Lakshmanan.V.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANG & 36W CHOKE 1NO CHANGED		Malliga. K. - Canteen-Girls Hostel	30/09/2022
Comp. Dt. : 05/10/2022 Status : Completed								
927	22100080	Ladies hostel Phase-I	NEED TO CHANGE TUBELIGHT FOR MESS & MESS CARITOR & ROOM NO 16 & 45 [TOTA 4 NOS]	Dhakshinamoorthy. J	36W TUBE LIGHT 2NO'S CHANG & 40W STARTER 3NO'S CHANGED		Revathy. N. - Canteen-Girls Hostel	06/10/2022
Comp. Dt. : 06/10/2022 Status : Completed								
928	22100101	JR Quarters	NEED TO CHANGE TUBELIGHT FOR ROOM NO 12 & 32	Dhakshinamoorthy. J	36W TUBE LIGHT 2NO'S CHANG & 40W STARTER 2NO'S CHANGED		Virgin Mary - Canteen-Girls Hostel	07/10/2022
Comp. Dt. : 07/10/2022 Status : Completed								
929	22100155	Ladies hostel Phase-II	NEED TO CHANGE TUBELIGHT FOR ROOM NO 6	Muthu. B.	TUBE LIGHT 40W STARTER 1NO CHANGED		Malliga. K. - Canteen-Girls Hostel	08/10/2022
930	22100156	JR Quarters	NEED TO CHANGE TUBELIGHT 2NOS FOR ROOM NO 1 & 2	Muthu. B.	36W TUBE LIGHT 1NO CHANG & 36W CHOKE 1NO CHANGED		Virgin Mary - Canteen-Girls Hostel	10/10/2022
Comp. Dt. : 10/10/2022 Status : Completed								
931	22100210	Ladies hostel Phase-I	NEED TO CHANGE TUBELIGHT FOR I FLOOR DINING HALL NEAR STEPS	Dhakshinamoorthy. J	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Revathy. N. - Canteen-Girls Hostel	11/10/2022
932	22100256	Ladies hostel Phase-II	NEED TO REPLACE ENTERENCE SWITCH [ANOTHER PLACE]	Dhakshinamoorthy. J	SWITCH BOARD CHEKING WORK NO COMPLAINT		Malliga. K. - Canteen-Girls Hostel	12/10/2022
Comp. Dt. : 11/10/2022 Status : Completed								
933	22100297	Ladies hostel Phase-II	NEED TO CHANGE TUBELIGHT FOR ROOM NO 34	Dhakshinamoorthy. J	TUBE LIGHT 40W STARTER 1NO CHANGED		Malliga. K. - Canteen-Girls Hostel	12/10/2022
Comp. Dt. : 13/10/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
934	22100379	JR Quarters	NEED TO CHANGE TUBELIGHT FOR GROUND FLOOR RESTROOM	Muthu. B.	TUBE LIGHT 40W STARTER 1NO CHANGED		Virgin Mary - Canteen-Girls Hostel	14/10/2022
935	22100394	Ladies hostel Phase-I	NEED TO CHANGE TUBELIGHT FOR ROOM NO 6	Vijayaraghavan.B.	TUBE LIGHT 40W STARTER 1NO CHANGED		Revathy. N. - Canteen-Girls Hostel	14/10/2022
Comp. Dt. : 14/10/2022 Status : Completed								
936	22100457	Ladies hostel Phase-II	NEED TO CHANGE TUBELIGHT FOR III FLOOR RESTROOM [BOTH SIDES]	Srinivasan. R.	36W TUBE LIGHT 1NO CHANG & SIDE HOLDER 1NO CHANGED		Malliga. K. - Canteen-Girls Hostel	21/10/2022
Comp. Dt. : 17/10/2022 Status : Completed								
937	22100538	JR Quarters	NEED TO CHANGE TUBELIGHT FOR GROUND FLOOR STEPS & II FLOOR CARITOR	Lakshmanan.V.	36W TUBE LIGHT 3NO'S CHANG & 40W STARTER 1NO CHANGED		Virgin Mary - Canteen-Girls Hostel	18/10/2022
938	22100545	Ladies hostel Phase-I	NEED TO CHANGE TUBELIGHT FOR DINING HALL	Lakshmanan.V.	TUBE LIGHT 40W STARTER 1NO CHANGED		Revathy. N. - Canteen-Girls Hostel	18/10/2022
Comp. Dt. : 18/10/2022 Status : Completed								
939	22100569	Ladies hostel Phase-I	NEED TO CHANGE TUBELIGHT 2NOS FOR MESS	Lakshmanan.V.	TUBE LIGHT 40W STARTER 2NO'S CHANGED		Revathy. N. - Canteen-Girls Hostel	19/10/2022
Comp. Dt. : 09/11/2022 Status : Completed								
940	22110372	Ladies hostel Phase-I	IN ROOM NO.108-1 TUBELIGHT NOT WORKING	Lakshmanan.V.	36W TUBE LIGHT 1NO CHANGED		Malliga. K. - Canteen-Girls Hostel	11/11/2022
Comp. Dt. : 14/11/2022 Status : Completed								
941	22110514	Ladies hostel Phase-II	IN 1ST CORRIDOR-1 TUBELIGHT NOT WORKING AND NEAR STEPS-2 NO'S TUBELIGHT NOT WORKING	Muthu. B.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Revathy. N. - Canteen-Girls Hostel	15/11/2022
Comp. Dt. : 16/11/2022 Status : Completed								
942	22110650	Ladies hostel Phase-II	IN 4TH FLOOR-COMMON BATHROOM-WATER HEATER SWITCH PROBLEM	Srinivasan. R.	WATER HEATER SWITCH CHECKING WORK PROBLEM SOLVED		Malliga. K. - Canteen-Girls Hostel	18/11/2022
Comp. Dt. : 19/11/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
943	22110819	Ladies hostel Phase-I	IN ROOM NO.-NEED TO CHANGE TUBELIGHT IN REST ROOM	Dhakshinamoorthy. J	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Revathy. N. - Canteen-Girls Hostel	21/11/2022
Comp. Dt. : 22/11/2022 Status : Completed								
944	22110961	Ladies hostel Phase-II	NEED TO CHANGE TO TUBELIGHT FOR ROOM NO.40 AND 1ST FLOOR CARITOR	Dhakshinamoorthy. J	36W CHOKE 1NO CHANG & 40W STARTER 1NO CHANGED		Virgin Mary - Canteen-Girls Hostel	25/11/2022
Comp. Dt. : 24/11/2022 Status : Completed								
945	22111067	Ladies hostel Phase-I	IN ROOM NO.26-1 TUBELIGHT NOT WORKING	Dhakshinamoorthy. J	36W TUBE LIGHT 2NO'S CHANGED		Revathy. N. - Canteen-Girls Hostel	25/11/2022
Comp. Dt. : 26/11/2022 Status : Completed								
946	22111150	Ladies hostel Phase-II	IN 3RD FLOOR BATHROOM-2 NO'S TUBELIGHT NEED TO BE CHANGE	Muthu. B.	36W CHOKE 1NO & 36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Malliga. K. - Canteen-Girls Hostel	28/11/2022
Comp. Dt. : 29/11/2022 Status : Completed								
947	22111211	JR Quarters	HEATER NOT WORKING AT GROUND & I FLOOR	Muthu. B.	NEW WATER HEATER 15LTR 1NO FIXING & LINE CONNECTION WORK PROBLEM SOLVED		Virgin Mary - Canteen-Girls Hostel	23/12/2022
948	22111212	JR Quarters	NEED TO CHANGE TUBELIGHT FOR NEAR GROUND FLOOR STEPS	Lakshmanan.V.	36W TUBE LIGHT 1NO CHANGED		Virgin Mary - Canteen-Girls Hostel	03/12/2022
Comp. Dt. : 01/12/2022 Status : Completed								
949	22120014	Ladies hostel Phase-II	NEED TO CHANGE TUBELIGHT FOR ROOM NO 114	Srinivasan. R.	TUBE LIGHT 40W STARTER 2NO'S CHANGED		Malliga. K. - Canteen-Girls Hostel	02/12/2022
Comp. Dt. : 02/12/2022 Status : Completed								
950	22120063	Ladies hostel Phase-II	NEED TO CHANGE TUBELIGHT FOR ROOM NO. 43	Lakshmanan.V.	TUBE LIGHT 36W CHOKE 1NO CHANGED		Malliga. K. - Canteen-Girls Hostel	03/12/2022
951	22120072	Ladies hostel Phase-I	NEED TO CHANGE TUBELIGHT 6 NOS	Lakshmanan.V.	36W TUBE LIGHT 2NO'S CHANG & 40W STARTER 2NO'S CHANGED		Revathy. N. - Canteen-Girls Hostel	03/12/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
952	22120073	Ladies hostel Phase-I	NEED TO CHECK HEATER SWITCH - NOT WORKING AT II FLOOR COMMON RESTROOM	Lakshmanan.V.	WATER HEATER 16A SWITCH 1NO CHANGED		Revathy. N. - Canteen-Girls Hostel	03/12/2022
Comp. Dt. : 03/12/2022 Status : Completed								
953	22120136	Ladies hostel Phase-I	ROOM NO 74 FAN REGULATOR NOT WORKING	Srinivasan. R.	CEILING FAN REGULSTOR 2NO'S CHANG & 16A SWITCH 1NO CHANGED		Revathy. N. - Canteen-Girls Hostel	06/12/2022
Comp. Dt. : 05/12/2022 Status : Completed								
954	22120148	JR Quarters	HEATER NOT WORKING AT I FLOOR	Lakshmanan.V.	15LTR WATER HEATER 1NO SERVICE & HEATER REFIXNG WORK PROBLEM SOLVED		Virgin Mary - Canteen-Girls Hostel	08/12/2022
955	22120154	Ladies hostel Phase-I	NEED TO CHANGETUBELIGHT FOR ROOM NO 59 & CHECK PLUG POINT FOR ROOM NO 78	Muthu. B.	36W TUBE LIGHT 2NO'S CHANG & 40W STARTER 1NO CHANG & 6A SWITCH 1NO CHANGED		Revathy. N. - Canteen-Girls Hostel	06/12/2022
Comp. Dt. : 09/12/2022 Status : Completed								
956	22120411	JR Quarters	NEED TO CHANGE TUBELIGHT - I FLOOR ROOM NO 36	Muthu. B.	36W TUBE LIGHT 1NO CHANGED		Virgin Mary - Canteen-Girls Hostel	14/12/2022
Comp. Dt. : 12/12/2022 Status : Completed								
957	22120544	Ladies hostel Phase-I	IN ROOM NO.13-1 SMALL TUBELIGHT NEED TO BE CHNAGE	Vijayaraghavan.B.	20W TUBE LIGHT 1NO CHANGED		Revathy. N. - Canteen-Girls Hostel	15/12/2022
Comp. Dt. : 14/12/2022 Status : Completed								
958	22120624	Ladies hostel Phase-II	NEED TO CHANGE TUBELIGHT FOR ROOM NO 98 &100	Dhakshinamoorthy. J	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Malliga. K. - Canteen-Girls Hostel	15/12/2022
959	22120625	Ladies hostel Phase-II	FAN SLOW PROBLEM - ROOM NO 90	Dhakshinamoorthy. J	CEILING FAN BEARING 2NO'S CHANG & FAN REFIXING WORK PROBLEM SOLVED		Malliga. K. - Canteen-Girls Hostel	16/12/2022
Comp. Dt. : 15/12/2022 Status : Completed								
960	22120686	Ladies hostel Phase-II	NEED TO REFIX FAN FOR I FLOOR ROOM NO 28 & TUBELIGHT FOR II FLOOR ROOM NO 54	Dhakshinamoorthy. J	WALLMOUNTING FAN 1NO FIXING WORK & TUBE LIGHT 36W CHOKE 1NO CHANGED		Malliga. K. - Canteen-Girls Hostel	17/12/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 16/12/2022 Status : Completed								
961	22120765	Ladies hostel Phase-II	IN WARDEN REST ROOM-BULB NOT WORKING	Dhakshinamoorthy. J	9W LED LIGHT 1NO CHANGED		Malliga. K. - Canteen-Girls Hostel	17/12/2022
Comp. Dt. : 17/12/2022 Status : Completed								
962	22120807	JR Quarters	NEED TO CHANGE TUBELIGHT FOR ROOM NO 41 & II FLOOR CARITOR	Dhakshinamoorthy. J	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Virgin Mary - Canteen-Girls Hostel	19/12/2022
963	22120810	Ladies hostel Phase-II	NEED TO CHANGE TUBELIGHT FOR ROOM NO 33,34 56 & 56	Dhakshinamoorthy. J	36W TUBE LIGHT 1NO CHANG & 40W STARTER 3NO'S CHANGED		Malliga. K. - Canteen-Girls Hostel	19/12/2022
Comp. Dt. : 26/12/2022 Status : Completed								
964	22121153	Ladies hostel Phase-II	TUBELIGHT NOT WORKING IN ROOM NO 59	Muthu. B.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Malliga. K. - Canteen-Girls Hostel	27/12/2022
965	22121163	J.R Quateres	HEATER SWITCH BOARD PROBLEM IN 3RD FLOOR REST ROOM	Muthu. B.	16A SWITCH 1NO CHANGED		Virgin Mary - Canteen-Girls Hostel	28/12/2022
Comp. Dt. : 28/12/2022 Status : Completed								
966	22121278	J.R Quateres	TUBELIGHT NOT WORKING IN GROUND FLOOR REST ROOM	Dhakshinamoorthy. J	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANG & 36W CHOKE 1NO CHANGED		Virgin Mary - Canteen-Girls Hostel	29/12/2022
Comp. Dt. : 30/12/2022 Status : Completed								
967	22121362	Ladies hostel Phase-II	IN 1ST FLOOR COMMON BATHROOM-TUBELIGHT NOT WORKING	Muthu. B.	Tube light starter 1no changed.		Malliga. K. - Canteen-Girls Hostel	31/12/2022
Comp. Dt. : 03/01/2023 Status : Completed								
968	23010120	Ladies hostel Phase-I	2NOS TUBELIGHT NOT WORKING IN MESS	Lakshmanan.V.	TUBE LIGHT 40W STARTER 1NO CHANGED		Revathy. N. - Canteen-Girls Hostel	04/01/2023
Comp. Dt. : 07/01/2023 Status : Completed								
969	23010324	Ladies hostel Phase-II	IN 1STAND GROUND FLOOR COMMON BATHROOM-2 NO'S TUBELIGHT NOT WORKING	Srinivasan. R.	36W TUBE LIGHT WIRE LOOSE RECONNECTION WORK PROBLEM SOLVED		Malliga. K. - Canteen-Girls Hostel	10/01/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 09/01/2023 Status : Completed								
970	23010347	J.R Quateres	IN 2ND FLOOR STEPS-1 TUBELIGHT NOT WORKING	Srinivasan. R.	36W TUBE LIGHT 1NO CHANGED		Virgin Mary - Canteen-Girls Hostel	10/01/2023
Comp. Dt. : 11/01/2023 Status : Completed								
971	23010444	J.R Quateres	IN 3RD FLOOR-NEAR STEPS-SWITCH NEED TO BE CHANGE	Srinivasan. R.	2WAY SWITCH 1NO CHANGED		Virgin Mary - Canteen-Girls Hostel	19/01/2023
Comp. Dt. : 12/01/2023 Status : Completed								
972	23010517	Ladies hostel Phase-II	IN ROOM NO.19-NEW FAN REGULATOR SWITCH BOARD NEED TO FIX	Srinivasan. R.	2MSURFACE BOX 1NO,2M PLATE 1NO,FAN REGULATOR 1NO CHANG & LINE CONNECTION WORK PROBLEM SOLVED		Malliga. K. - Canteen-Girls Hostel	13/01/2023
Comp. Dt. : 13/01/2023 Status : Completed								
973	23010553	J.R Quateres	NEED TO FIX HEATER AT GROUND FLOOR COMMON REST ROOM	Muthu. B.	WATER HEATER HOSE LEAKE PLUMBING COMPLAINT		Virgin Mary - Canteen-Girls Hostel	19/01/2023
974	23010578	Ladies hostel Phase-I	HEATER NOT WORKING IN 2ND FLOOR	Lakshmanan.V.	WATER HEATER 1NO RESET WORK & HEATER CHEKING WORK PROBLEM SOLVED		Revathy. N. - Canteen-Girls Hostel	14/01/2023
Comp. Dt. : 18/01/2023 Status : Completed								
975	23010615	JR Quarters	NEED TO CHANGE TUBELIGHT [2NOS] FOR GROUND FLOOR RESTROOM	Srinivasan. R.	36W TUBE LIGHT 2NO'S CHANG & 40W STARTER 3NO'S CHANGED		Virgin Mary - Canteen-Girls Hostel	19/01/2023
976	23010619	Ladies hostel Phase-I	NEED TO CHANGE TUBELIGHT FOR ROOM NO 75 & ELECTRICAL ROOM	Srinivasan. R.	TUBE LIGHT 40W STARTER 1NO CHANG & WALLMOUNTING FAN SERVICE WORK PROBLEM SOLVED		Revathy. N. - Canteen-Girls Hostel	19/01/2023
Comp. Dt. : 19/01/2023 Status : Completed								
977	23010664	Ladies hostel Phase-II	WATER HEATER NOT WORKING IN IV FLOOR	Muthu. B.	WATER HEATER 2KW COIL 1NO CHANG & HEATER CHEKING WORK PROBLEM SOLVED		Malliga. K. - Canteen-Girls Hostel	20/01/2023
978	23010665	Ladies hostel Phase-II	NEED TO CHANGE TUBELIGHT [3NOS] FOR I & II FLOOR	Muthu. B.	36W TUBE LIGHT 2NO'S CHANG & 40W STARTER 2NO'S CHANGED		Malliga. K. - Canteen-Girls Hostel	20/01/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 20/01/2023								
Status : Completed								
979	23010705	Ladies hostel Phase-I	NEED TO CHANGE TUBELIGHT FOR ROOM NO 45 & 22	Dhakshinamoorthy. J	20W TUBE LIGHT 1NO CHANG & 20W STARTER 1NO CHANG & ROOM NO:45 TUBE LIGHT SIDE HOLDER 2NO'S CHANGED		Revathy. N. - Canteen-Girls Hostel	24/01/2023
980	23010707	Ladies hostel Phase-I	EMERGENCY LIGHT NOT WORKING AT GROUND FLOOR	Sathishkumar. R.	EMERGENGY LIGHT CHEKING WORK PROBLEM SOLVED		Revathy. N. - Canteen-Girls Hostel	23/01/2023
Comp. Dt. : 23/01/2023								
Status : Completed								
981	23010808	Ladies hostel Phase-II	HEATER NOT WORKING - II FLOOR JR SIDE	Dhakshinamoorthy. J	WATER HEATER 1NO RESET WORK PROBLEM SOLVED		Malliga. K. - Canteen-Girls Hostel	24/01/2023
982	23010809	Ladies hostel Phase-II	NEED TO CHANGE TUBELIGHT FOR III FLOOR RESTROOM	Dhakshinamoorthy. J	WATER HEATER 1NO RESET WORK PROBLEM SOLVED		Malliga. K. - Canteen-Girls Hostel	24/01/2023
983	23010811	Ladies hostel Phase-I	NEED FAN CLEANING WORK AT KITCHEN	Muthu. B.	36W TUBE LIGHT 6NO'S & CEILING FAN 5NO'S CLEANING WORK & REFIXING WORK PROBLEM SOLVED		Revathy. N. - Canteen-Girls Hostel	24/01/2023
984	23010814	JR Quarters	NEED TO CHANGE TUBELIGHT FOR ROOM NO 15 ,59 & CARITOR 2NOS [TOTAL 4 NOS]	Dhakshinamoorthy. J	36W TUBE LIGHT 1NO CHANG & 36W CHOKE 1NO CHANG & 40W STARTER 3NO'S CHANGED		Virgin Mary - Canteen-Girls Hostel	24/01/2023
985	23010815	JR Quarters	FAN REGULATOR NOT WORKING ROOM NO 35	Dhakshinamoorthy. J	CEILING FAN REGULATOR 1NO CHANG & CHEKING WORK PROBLEM SOLVED		Virgin Mary - Canteen-Girls Hostel	24/01/2023
Comp. Dt. : 24/01/2023								
Status : Completed								
986	23010853	Ladies hostel Phase-II	NEED TO CHANGE TUBELIGHT FOR III FLOOR CARITOR & FIX A NEW TUBELIGHT SET FOR GROUND FLOOR "CLOTHES	Lakshmanan.V.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Malliga. K. - Canteen-Girls Hostel	25/01/2023
987	23010859	Ladies hostel Phase-II	NEED TO FIX A NEW FOCUS LIGHT FOR BASEMENT WASHING AREA	Lakshmanan.V.	150W LED FOCUS LIGHT 1NO FIXING WORK PROBLEM SOLVED		Malliga. K. - Canteen-Girls Hostel	31/01/2023
988	23010873	JR Quarters	NEED TO CHANGE LED LIGHT FOR II FLOOR STEPS & TUBELIGHT FOR III FLOOR CARITOR & ROOM NO 17	Muthu. B.	36W TUBE LIGHT 1NO CHANG & 36W CHOKE 1NO CHANG & 40W STARTER 3NO'S CHANGED		Virgin Mary - Canteen-Girls Hostel	25/01/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
989	23010891	Ladies hostel Phase-II	NEED TO CHANGE TUBELIGHT FOR DINNING HALL & REST ROOM TUBELIGHT FOR ROOM NO 77	Lakshmanan.V.	20W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Malliga. K. - Canteen-Girls Hostel	25/01/2023
Comp. Dt. : 25/01/2023 Status : Completed								
990	23010909	Ladies hostel Phase-II	NEED TO CHANGE TUBELIGHT FOR ROOM NO 69 & 109	Dhakshinamoorthy. J	36W TUBE LIGHT 2NO'S CHANG & 40W STARTER 4NO'S CHANGED		Malliga. K. - Canteen-Girls Hostel	27/01/2023
991	23010936	JR Quarters	NEED TO CHANGE TUBELIGHT FOR ROOM NO 13 & 70	Dhakshinamoorthy. J	TUBE LIGHT 40W STARTER 1NO CHANG & 36W TUBE LIGHT 1NO CHANGED		Virgin Mary - Canteen-Girls Hostel	27/01/2023
Comp. Dt. : 27/01/2023 Status : Completed								
992	23010970	JR Quarters	NEED TO CHANGE TUBELIGHT FOR IV FLOOR CARITOR	Dhakshinamoorthy. J	36W TUBE LIGHT 1NO CHANGED		Virgin Mary - Canteen-Girls Hostel	28/01/2023
993	23010971	JR Quarters	NEED TO CHANGE TUBELIGHT FOR ROOM NO 124	Dhakshinamoorthy. J	TUBE LIGHT 40W STARTER 1NO CHANGED		Virgin Mary - Canteen-Girls Hostel	28/01/2023
994	23010991	Ladies hostel Phase-I	IN ROOM NO.63-FAN NOT WORKING	Muthu. B.	CEILING FAN CAPACITOR 2.5MFT 1NO CHANGED		Revathy. N. - Canteen-Girls Hostel	30/01/2023
Comp. Dt. : 28/01/2023 Status : Completed								
995	23011010	Ladies hostel Phase-II	NEED TO CHANGE NIGHT LAMP FOR ROOM NO 3 & TUBELIGHT FOR ROOM NO 4	Dhakshinamoorthy. J	0.5W NIGHT LAMP 1NO CHANG & TUBE LIGHT 40W STARTER 1NO CHANGED		Malliga. K. - Canteen-Girls Hostel	30/01/2023
996	23011011	Ladies hostel Phase-II	WATER HEATER NOT WORKING - II FLOOR RESTROOM	Dhakshinamoorthy. J	NEW WATER HEATER 2KWCOIL 1NO CHANG & LINE CONNECTION WORK PROBLEM SOLVED		Malliga. K. - Canteen-Girls Hostel	30/01/2023
Comp. Dt. : 30/01/2023 Status : Completed								
997	23011038	JR Quarters	NEED TO CHANGE TUBELIGHT FOR ROOM NO 26 [2NOS]	Lakshmanan.V.	36W TUBE LIGHT 2NO'S CHANG & 36W CHOKE 1NO CHANG & 40W STARTER 2NO'S CHANGED		Virgin Mary - Canteen-Girls Hostel	31/01/2023
Comp. Dt. : 31/01/2023 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
998	23011086	JR Quarters	FAN NOT WORKING ROOM NO 8 ,53 & TUBELIGHT NOT WORKING ROOM NO 61	Lakshmanan.V.	CEILING FAN CAPACITOR 2.5MFT 1NO CHANG & 36W TUBE LIGHT 1NO CHANGED		Virgin Mary - Canteen-Girls Hostel	01/02/2023
999	23011092	Ladies hostel Phase-I	HEATER NOT WORKING AT IV FLOOR	Lakshmanan.V.	WATER HEATER 1NO RESET WORK PROBLEM SOLVED		Revathy. N. - Canteen-Girls Hostel	01/02/2023
Comp. Dt. : 01/02/2023 Status : Completed								
1000	23020039	Ladies hostel Phase-II	NEED TO CHANGE TUBELIGHT FOR II CARITOR [1NO] & I & III FLOOR RESTROOM [3 NOS]	Muthu. B.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANG & 36W CHOKE 1NO CHANGED		Malliga. K. - Canteen-Girls Hostel	02/02/2023
Comp. Dt. : 03/02/2023 Status : Completed								
1001	23020114	Ladies hostel Phase-II	FAN SOUND PROBLEM ROOM NO 40 & NIGHT LAMP NOT WORKING ROOM NO 18	Manikandan. M.	CEILING FAN CAPACIOTR 2.5MFT 1NO CHANG & TUBE LIGHT 40W STARTER 2NO'S CHANG & 0.5W NIGHT LAMP 1NO CH		Malliga. K. - Canteen-Girls Hostel	04/02/2023
Comp. Dt. : 04/02/2023 Status : Completed								
1002	23020124	JR Quarters	NEED TO CHANGE TUBELIGHT 2NOS FOR GROUND FLOOR	Srinivasan. R.	TUBE LIGHT 40W STARTER 2NO'S CHANGED		Virgin Mary - Canteen-Girls Hostel	06/02/2023
1003	23020132	Ladies hostel Phase-II	NEED TO CHANGE TUBELIGHT FOR ROOM NO 83	Srinivasan. R.	36W TUBE LIGHT 1NO CHANGED		Malliga. K. - Canteen-Girls Hostel	06/02/2023
1004	23020133	Ladies hostel Phase-II	HEATER - TRIP PROBLEM - II FLOOR COMMON RESTROOM	Srinivasan. R.	WATER HEATER 1NO RESET WORK PROBLEM SOLVED		Malliga. K. - Canteen-Girls Hostel	06/02/2023
Comp. Dt. : 06/02/2023 Status : Completed								
1005	23020171	JR Quarters	NEED TO CHANGE TUBELIGHT 4 NOS FOR ROOM NO 14 , 25 & I FLOOR [TOTAL 4 NOS]	Muthu. B.	36W TUBE LIGHT 2NO'S CHNAG & 40W STARTER 2NO'S CHANG & SIDE HOLDR 2NO'S CHANGED		Virgin Mary - Canteen-Girls Hostel	07/02/2023
1006	23020185	Ladies hostel Phase-II	NEED TO CHANGE TUBELIGHT FOR GROUND FLOOR CARITOR	Muthu. B.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 3NO'S CHANGED		Malliga. K. - Canteen-Girls Hostel	07/02/2023
Comp. Dt. : 08/02/2023 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1007	23020265	Ladies hostel Phase-II	TUBELIGHT NOT WORKING IN 1ST FLOOR STUDY ROOM	Srinivasan. R.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Malliga. K. - Canteen-Girls Hostel	09/02/2023
Comp. Dt. : 15/02/2023 Status : Completed								
1008	23020577	JR Quarters	NEED TO CHANGE TUBELIGHT FOR II FLOOR REST ROOM & CORITOR	Dhakshinamoorthy. J	36W TUBE LIGHT 1NO CHANG & 36W CHOKE 1NO & 40W STARTER 2NO'S CHANGED		Virgin Mary - Canteen-Girls Hostel	18/02/2023
1009	23020600	LADIES HOSTEL MESS	NEED TO CHANGE TUBELIGHT FOR MESS	Dhakshinamoorthy. J	TUBE LIGHT 40W STARTER 1NO CHANGED		Revathy. N. - Canteen-Girls Hostel	16/02/2023
Comp. Dt. : 17/02/2023 Status : Completed								
1010	23020699	Ladies hostel Phase-II	NEED TO CHANGE TUBELIGHT FOR ROOM NO 110 & II FLOOR STUDY HALL	Dhakshinamoorthy. J	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Malliga. K. - Canteen-Girls Hostel	18/02/2023
Comp. Dt. : 21/02/2023 Status : Completed								
1011	23020816	Ladies hostel Phase-II	NEED TO CHANGE TUBELIGHT FOR I& II FLOOR STUDY ROOM & ROOM NO 55	Vijayaraghavan.B.	36W TUBE LIGHT 2NO 'S CHANG & 40W STARTER 3NO'S CHANGED		Malliga. K. - Canteen-Girls Hostel	22/02/2023
Comp. Dt. : 23/02/2023 Status : Completed								
1012	23020900	JR Quarters	NEED TO CHANGE TUBELIGHT FOR ROOM NO 4,10 , GROUND FLOOR & II FLOOR CARITOR [TOTAL 4 NOS]	Lakshmanan.V.	Neet To 36W Tube Light 2 NOS, Starter 2 NOS Changed		Virgin Mary - Canteen-Girls Hostel	24/02/2023
1013	23020904	Ladies hostel Phase-II	NEED WIRING WORK FOR TUBELIGHT AT I FLOOR STUDY HALL	Lakshmanan.V.	Neet 36W Starter 1NO Changed		Malliga. K. - Canteen-Girls Hostel	24/02/2023
Comp. Dt. : 24/02/2023 Status : Completed								
1014	23020927	Ladies hostel Phase-II	NED TO CHANGE TUBELIGHT FOR ROOM NO 23, 66 & 72	Srinivasan. R.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 4NO'S CHANGED		Malliga. K. - Canteen-Girls Hostel	25/02/2023
1015	23020928	Ladies hostel Phase-II	FAN NOT WORKING - GROUND FLOOR GUEST ROOM	Srinivasan. R.	CEILING FAN SWITCH 1NO CHANGED		Malliga. K. - Canteen-Girls Hostel	25/02/2023
Comp. Dt. : 25/02/2023 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1016	23020968	Ladies hostel Phase-II	NEED TO CHANGE TUBELIGHT FOR ROOM NO 16 & 89	Srinivasan. R.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 2NO'S CHANGED		Malliga. K. - Canteen-Girls Hostel	27/02/2023
Comp. Dt. : 27/02/2023 Status : Completed								
1017	23021009	Ladies hostel Phase-II	NEED TO CHANGE TUBELIGHT FOR ROOM NO 81	Dhakshinamoorthy. J	36W TUBE LIGHT 1NO CHANG & SIDE HOLDER 1NO CHANGED		Malliga. K. - Canteen-Girls Hostel	02/03/2023
Comp. Dt. : 01/03/2023 Status : Completed								
1018	23030018	Ladies hostel Phase-II	NEED TO CHANGE TUBELIGHT FOR ROOM NO 18, 52 & 53	Dhakshinamoorthy. J	36W TUBE LIGHT 1NO CHANG & 40W STARTER 2NO'S CHANGED		Malliga. K. - Canteen-Girls Hostel	02/03/2023
1019	23030023	JR Quarters	NEED TO CHANGE TUBELIGHT 2 NOS FOR ROOM NO 23	Dhakshinamoorthy. J	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Virgin Mary - Canteen-Girls Hostel	02/03/2023
Comp. Dt. : 06/03/2023 Status : Completed								
1020	23030206	JR Quarters	HEATER NOT WORKING - GROUND FLOOR [PHASE II SIDE]	Srinivasan. R.	WATER HEATER THERMO CUT 1NO CHANG & HEATER CHEKING WORK PROBLEM SOLVED		Virgin Mary - Canteen-Girls Hostel	09/03/2023
1021	23030207	JR Quarters	NEED TO CHANGE TUBELIGHT FOR STUDY HALL, I & III FLOOR RESTROOM & ROOM NO 84	Srinivasan. R.	36W TUBE LIGHT 2NO'S CHANG & 40W STARTER 3NO'S CHANGED		Virgin Mary - Canteen-Girls Hostel	07/03/2023
Comp. Dt. : 07/03/2023 Status : Completed								
1022	23030262	JR Quarters	NEED TO CHANGE TUBELIGHT FOR III FLOOR ROOM NO 83 & 84	Srinivasan. R.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Virgin Mary - Canteen-Girls Hostel	08/03/2023
1023	23030263	JR Quarters	FAN NOT WORKING ROOM NO 101	Srinivasan. R.	CEILING FAN CAPACITOR 2.5MFT 1NO CHANGED		Virgin Mary - Canteen-Girls Hostel	08/03/2023
1024	23030264	JR Quarters	HEATER NOT WORKING - GROUND FLOOR	Srinivasan. R.	WATER HEATER THERMO CUT 1NO CHANG & HEATER CHEKING WORK PROBLEM SOLVED		Virgin Mary - Canteen-Girls Hostel	09/03/2023
Comp. Dt. : 08/03/2023 Status : Completed								
1025	23030304	JR Quarters	NEED TO CHANGE TUBELIGHT FOR III & IV FLOOR RESTROOM	Damodharan. V.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Virgin Mary - Canteen-Girls Hostel	09/03/2023
1026	23030314	Ladies hostel Phase-II	NEED TO CHANGE TUBELIGHT FOR ROOM NO 85 ,115	Damodharan. V.	36W TUBE LIGHT 2NO'S CHANG & 40W STARTER 2NO'S CHANGED		Malliga. K. - Canteen-Girls Hostel	09/03/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1027	23030315	Ladies hostel Phase-II	FAN & REGULATOR PROBLEM ROOM NO 15 & 16	Srinivasan. R.	CEILING FAN REGULATOR 1NO CHANGED		Malliga. K. - Canteen-Girls Hostel	13/03/2023
Comp. Dt. : 09/03/2023 Status : Completed								
1028	23030359	JR Quarters	FAN NOT WORKING ROOM NO 101	Manimaran. P.	Fan capacitor 2.5mfd 1no changed.		Virgin Mary - Canteen-Girls Hostel	10/03/2023
1029	23030360	JR Quarters	NEED TO CHANGE REST ROOM TUBELIGHT FOR III FLOOR	Manimaran. P.	36W tube light 3no's, starter 3no's & E.choke 1no changed.		Virgin Mary - Canteen-Girls Hostel	10/03/2023
Comp. Dt. : 10/03/2023 Status : Completed								
1030	23030405	Ladies hostel Phase-II	TUBELIGHT NOT WORKING - ROOM NO 26	Muthu. B.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Malliga. K. - Canteen-Girls Hostel	11/03/2023
1031	23030412	Ladies hostel Phase-I	NEED TO CHANGE TUBELIGHT FOR DINING HALL	Muthu. B.	TUBE LIGHT 40W STARTER 1NO CHANGED		Revathy. N. - Canteen-Girls Hostel	11/03/2023
Comp. Dt. : 11/03/2023 Status : Completed								
1032	23030453	JR Quarters	NEED TO CHANGE TUBELIGHT FOR GROUND & III FLOOR RESTROOM	Dhakshinamoorthy. J	36W TUBE LIGHT 1NO CHANG & SIDE HOLDER 1NO CHANGED		Virgin Mary - Canteen-Girls Hostel	13/03/2023
1033	23030467	Ladies hostel Phase-II	NEED TO CHANGE TUBELIGHT FOR ROOM NO 63	Manikandan. M.	TUBE LIGHT 40W STARTER 1NO CHANGED		Malliga. K. - Canteen-Girls Hostel	15/03/2023
Comp. Dt. : 13/03/2023 Status : Completed								
1034	23030490	Ladies hostel Phase-II	NEED TO CHANGE TUBELIGHT 2NOS FOR ROOM NO 70 [DIM PROBLEM] AND FAN REGULATOR NOT WORKING	Manikandan. M.	CEILING FAN REGULATOR 1NO CHANG & 36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Malliga. K. - Canteen-Girls Hostel	15/03/2023
1035	23030491	Ladies hostel Phase-II	NEED TO CHANGE RESTROOM TUBELIGHT 2NOS FOR GROUND FLOOR	Manikandan. M.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Malliga. K. - Canteen-Girls Hostel	14/03/2023
Comp. Dt. : 14/03/2023 Status : Completed								
1036	23030571	Ladies hostel Phase-II	NEED TO CHANGE TUBELIGHT - ROOM NO 63 & 70 [2NOS] & FAN REGULATOR FOR ROOM NO 70	Manikandan. M.	CEILING FAN REGULATOR 1NO CHANG & 36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Malliga. K. - Canteen-Girls Hostel	15/03/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 15/03/2023 Status : Completed								
1037	23030612	Ladies hostel Phase-II	NEED TO CHANGE TUBELIGHT FOR ROOM NO 31 , GROUND FLOOR STEPS & I FLOOR CARITOR	Srinivasan. R.	TUBE LIGHT 40W STARTER 2NO'S CHANGED		Malliga. K. - Canteen-Girls Hostel	16/03/2023
Comp. Dt. : 17/03/2023 Status : Completed								
1038	23030689	JR Quarters	NEED TO CHANGE RESTROOM TUBELIGHT FOR GROUND FLOOR & FAN SLOW PROBLEM FOR ROOM NO 59	Rajan. R.	G.floor - 36W tube light 1no & 2nd floor corridor - 36W tube light 1no chang & ceiling fan capacitor		Virgin Mary - Canteen-Girls Hostel	20/03/2023
1039	23030698	Ladies hostel Phase-II	NEED TO CHANGE RESTROOM TUBELIGHT FOR GROUND FLOOR	Rajan. R.	Tube light starter 1no changed.		Malliga. K. - Canteen-Girls Hostel	18/03/2023
Comp. Dt. : 18/03/2023 Status : Completed								
1040	23030743	Ladies hostel Phase-I	TV NOT WORKING AT I FLOOR TV HALL	Srinivasan. R.	SETUP BOX RECHARGE WORK PROBLEM SOLVED		Revathy. N. - Canteen-Girls Hostel	20/03/2023
Comp. Dt. : 20/03/2023 Status : Completed								
1041	23030777	JR Quarters	NEED TO CHANGE TUBELIGHT FOR GROUND FLOOR RESTROOM 2 NOS	Muthu. B.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Virgin Mary - Canteen-Girls Hostel	21/03/2023
1042	23030778	JR Quarters	HEATER NOT WORKING AT GROUND FLOOR RESTROOM	Manimaran. P.	36W TUBE LIGHT 2NO'S CHANG & 40W STARTER 1NO CHANG & 36W CHOKE 1NO CHANGED		Virgin Mary - Canteen-Girls Hostel	21/03/2023
1043	23030779	JR Quarters	FAN SLOW PROBLEM - ROOM NO 59	Muthu. B.	CEILING FAN CAPACITOR 2.5MFT 1NO CHANGED		Virgin Mary - Canteen-Girls Hostel	27/03/2023
Comp. Dt. : 21/03/2023 Status : Completed								
1044	23030851	JR Quarters	NEED FAN CLEANING WORK - ROOM NO 1 & NEED TO CHANGE TUBELIGHT FOR ROOM NO 42	Dhakshinamoorthy. J	R.no.1 Wallmounting fan cleaned. R.no.42 Tube light starter 1no changed.		Virgin Mary - Canteen-Girls Hostel	23/03/2023
1045	23030852	Ladies hostel Phase-II	NEED TO CHANGE TUBELIGHT ROOM NO 23,30,&101 + FAN NOT WORKING ROOM NO 98	Dhakshinamoorthy. J	R.no.23 - Tube light starter 1no changed. R.no.98 - Fan capacitor 2.5mfd 1no changed.		Malliga. K. - Canteen-Girls Hostel	23/03/2023
1046	23030880	Ladies hostel Phase-II	TUBELIGHT NOT WORKING IN ROOM NO. 14	Srinivasan. R.	36W TUBE LIGHT 1NO CHANGED		Revathy. N. - Canteen-Girls Hostel	28/03/2023
1047	23030883	Ladies hostel Phase-I	NEED TO CHANGE PLUG POINT IN MESS	Dhakshinamoorthy. J	6A SWITCH 1NO CHANGED		Revathy. N. - Canteen-Girls Hostel	22/03/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 22/03/2023								
Status : Completed								
1048	23030900	JR Quarters	NEED TO CHECK FAN & TUBELIGHT - NOT WORKING - ROOM NO 10	Dhakshinamoorthy. J	36W tube light 1no & Fan capacitor 2.5mfd 1no changed.		Virgin Mary - Canteen-Girls Hostel	23/03/2023
Comp. Dt. : 23/03/2023								
Status : Completed								
1049	23030951	Ladies hostel Phase-II	FAN SOUND SLOW & REGULATOR PROBLEM IN ROOM NO 16,102	Muthu. B.	R.no.16 Fan regulator 1no changed. R.no. 102 - Fan capacitor 2.5mfd 1no changed.		Malliga. K. - Canteen-Girls Hostel	25/03/2023
1050	23030952	Ladies hostel Phase-II	NEED TO CHANGE TUBELIGHT FOR ROOM NO 4 & 67	Muthu. B.	Starter 1no & Fan capacitor 2.5mfd 1no changed.		Malliga. K. - Canteen-Girls Hostel	25/03/2023
1051	23030954	JR Quarters	NEED TO CLEAN & CHECK FAN - SLOW PROBLEM ROOM NO 59	Dhakshinamoorthy. J	Fan cleaned & Capacitor 2.5mfd 1no changed.		Virgin Mary - Canteen-Girls Hostel	29/03/2023
1052	23030955	JR Quarters	NEED TO CLEAN & CHECK FAN - SLOW & REGULATOR PROBLEM ROOM NO 9	Srinivasan. R.	CEILING FAN CAPACITOR 2.5MFT 1NO CHANGED		Virgin Mary - Canteen-Girls Hostel	28/03/2023
1053	23030956	JR Quarters	NEED TO CHANGE TUBELIGHT FOR GROUND FLOOR STUDY HALL	Muthu. B.	36W tube light 1no changed.		Virgin Mary - Canteen-Girls Hostel	23/03/2023
1054	23030957	Mit ladies hostel	NEED TO CHANGE TUBELIGHT FOR ROOM NO 90	Srinivasan. R.	TUBE LIGHT SIDE HOLDER 1NO CHANGED		Virgin Mary - Canteen-Girls Hostel	28/03/2023
Comp. Dt. : 24/03/2023								
Status : Completed								
1055	23031006	Ladies hostel Phase-II	FAN SLOW PROBLEM ROOM NO 38	Muthu. B.	Fan checked - ok.		Malliga. K. - Canteen-Girls Hostel	25/03/2023
1056	23031007	Ladies hostel Phase-II	FAN SLOW PROBLEM ROOM NO 4	Muthu. B.	Fan capacitor 2.5mfd 1no changed.		Malliga. K. - Canteen-Girls Hostel	25/03/2023
1057	23031016	JR Quarters	FAN REGULATOR NOT WORKING - ROOM NO 121 - [MIT STUDENT ROOM]	Manikandan. M.	Fan regulator 1no & capacitor 2.5mfd 1no changed.		Virgin Mary - Canteen-Girls Hostel	05/04/2023
Comp. Dt. : 25/03/2023								
Status : Completed								
1058	23031059	Ladies hostel Phase-I	NEED TO CHANGE TUBELIGHT FOR ROOM NOM 45	Dhakshinamoorthy. J	Tube light starter 1no changed.		Revathy. N. - Canteen-Girls Hostel	29/03/2023
1059	23031060	Ladies hostel Phase-I	NEED TO CHANGE TUBELIGHT FOR II FLOOR CARITOR STEPS	Muthu. B.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Revathy. N. - Canteen-Girls Hostel	27/03/2023
1060	23031061	Ladies hostel Phase-II	NEED TO CHANGE TUBELIGHT FOR MESS	Srinivasan. R.	MESS TUBE LIGHT CHEKING WORK NO COMPLAINT		Revathy. N. - Canteen-Girls Hostel	28/03/2023
1061	23031073	Ladies hostel Phase-II	NEED TO CHANGE TUBELIGHT FOR ROOM NO 73	Dhakshinamoorthy. J	Tube light starter 1no changed.		Malliga. K. - Canteen-Girls Hostel	29/03/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 27/03/2023								
Status : Completed								
1062	23031111	Ladies hostel Phase-II	NEED TO CHANGE TUBELIGHT FOR GROUND & I FLOOR CARITOR	Srinivasan. R.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Malliga. K. - Canteen-Girls Hostel	28/03/2023
1063	23031113	Ladies hostel Phase-II	NEED TO CHANGE NIGHT LIGHT - ROOM NO 18	Srinivasan. R.	0.5W NIGHT LAMP 1NO CHANGED		Malliga. K. - Canteen-Girls Hostel	28/03/2023
1064	23031114	Ladies hostel Phase-II	FAN NOT WORKING - ROOM NO 17	Srinivasan. R.	WALLMOUNTING FAN SERVICE WORK PROBLEM SOLVED		Malliga. K. - Canteen-Girls Hostel	28/03/2023
1065	23031116	Ladies hostel Phase-I	NEED TO CHANGE TUBELIGHT FOR ROOM NO 45	Dhakshinamoorthy. J	Light wire problem solved.		Revathy. N. - Canteen-Girls Hostel	29/03/2023
Comp. Dt. : 28/03/2023								
Status : Completed								
1066	23031148	JR Quarters	HEATER NOT WORKING AT GROUND FLOOR RESTROOM	Muthu. B.	Heater reset - OK		Virgin Mary - Canteen-Girls Hostel	01/04/2023
1067	23031149	JR Quarters	FAN NOT WORKING ROOM NO 15	Manikandan. M.	Fan capacitor 2.5mfd 1no changed.		Virgin Mary - Canteen-Girls Hostel	06/04/2023
1068	23031150	JR Quarters	FAN NOT WORKING ROOM NO 2	Dhakshinamoorthy. J	Fan capaciotor 2.5mfd 1no changed.		Virgin Mary - Canteen-Girls Hostel	29/03/2023
1069	23031188	Ladies hostel Phase-II	NEED TO CHANGE TUBELIGHT - ROOM NO 17	Dhakshinamoorthy. J	Tube light starter 1no changed.		Malliga. K. - Canteen-Girls Hostel	29/03/2023
1070	23031190	Ladies hostel Phase-II	FAN SLOW PROBLEM - ROOM NO 15	Dhakshinamoorthy. J	Fan capacitor 2.5mfd 1no changed.		Malliga. K. - Canteen-Girls Hostel	29/03/2023
1071	23031191	Ladies hostel Phase-II	NEED TO CHANGE TUBELIGHT FOR II FLOOR CARITOR & GROUND FLOOR RESTROOM	Lakshmanan.V.	36W tube light 1no & starter 1no changed.		Malliga. K. - Canteen-Girls Hostel	30/03/2023
1072	23031211	Ladies hostel Phase-I	NEED TO CHANGE TUBELIGHT FOR ROOM NO 20	Manikandan. M.	36W tube light 1no changed.		Revathy. N. - Canteen-Girls Hostel	04/04/2023
1073	23031212	Ladies hostel Phase-I	NEED TO CHANGE TUBELIGHT FOR ROOM NO 24	Dhakshinamoorthy. J	Tube light starter 1no changed.		Revathy. N. - Canteen-Girls Hostel	29/03/2023
Comp. Dt. : 29/03/2023								
Status : Completed								
1074	23031245	Ladies hostel Phase-I	NEED TO CHANGE TUBELIGHT FOR ROOM NO 45	Manikandan. M.	36W tube light 1no changed.		Revathy. N. - Canteen-Girls Hostel	04/04/2023
1075	23031246	Ladies hostel Phase-I	NEED TO CHANGE TUBELIGHT FOR ROOM NO 17	Lakshmanan.V.	36W tube light 1no & starter 1no changed.		Revathy. N. - Canteen-Girls Hostel	30/03/2023
1076	23031251	Ladies hostel Phase-II	FAN SLOW & SOUND PROBLEM ROOM NO 105	Lakshmanan.V.,Mani maran. P.,Manikandan. M.	Fan bearing problem - fan removed to power room. Spare ceiling fan fixed.		Malliga. K. - Canteen-Girls Hostel	04/04/2023

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1077	23031252	Ladies hostel Phase-II	NEED TO CHANGE TUBELIGHT FOR II & IV FLOOR CARITOR	Lakshmanan.V.	36W tube light 1no changed & starter 1no changed.		Malliga. K. - Canteen-Girls Hostel	30/03/2023
Comp. Dt. : 30/03/2023 Status : Completed								
1078	23031284	JR Quarters	NEED TO CHANGE TUBELIGHT 2 NOS FOR II FLOOR RESTROOM	Muthu. B.	Tube light starter 1no changed.		Virgin Mary - Canteen-Girls Hostel	01/04/2023
1079	23031286	JR Quarters	HEATER NOT WORKING AT GROUND FLOOR RESTROOM	Muthu. B.	Heater reset - OK.		Virgin Mary - Canteen-Girls Hostel	01/04/2023
1080	23031307	Ladies hostel Phase-II	NEED TO CHANGE TUBELIGHT FOR ROOM NO 5	Manimaran. P.	Tube light starter 1no changed.		Malliga. K. - Canteen-Girls Hostel	31/03/2023
1081	23031308	Ladies hostel Phase-II	NEED TO CHANGE TUBELIGHT FOR ROOM NO 111	Manimaran. P.	36W tube light 1no & starter 1no changed.		Malliga. K. - Canteen-Girls Hostel	31/03/2023
Comp. Dt. : 31/03/2023 Status : Completed								
1082	23031343	Ladies hostel Phase-II	NEED TO CHANGE TUBELIGHT FOR IV FLOOR RESTROOM	Manikandan. M.	36W tube light 1no & starter 1no changed.		Malliga. K. - Canteen-Girls Hostel	04/04/2023
Comp. Dt. : 03/04/2023 Status : Completed								
1083	23040052	Ladies hostel Phase-II	NEED TO CHANGE TUBELIGHT 2 NOS FOR GROUND FLOOR REST ROOM	Vengadessaperumal. K.	36W tube light 2no's changed.		Malliga. K. - Canteen-Girls Hostel	03/04/2023
1084	23040057	Ladies hostel Phase-I	NEED TO CHANGE RESTROOM TUBELIGHT - ROOM NO 13	Vengadessaperumal. K.	20W tube light 2feet 1no changed.		Revathy. N. - Canteen-Girls Hostel	03/04/2023
1085	23040059	Ladies hostel Phase-I	NEED TO CHECK FAN SWITCH - NOT WORKING AT MESS	Manikandan. M.	6A Roma switch 1no changed.		Revathy. N. - Canteen-Girls Hostel	04/04/2023
1086	23040073	LADIES HOSTEL STREET	NEED TO CHANGE STREET LIGHT - NOT WORKING - OPPOSITE TO PHASE I	Manikandan. M.	MCB trip - Trip ON.		Malliga. K. - Canteen-Girls Hostel	04/04/2023
Comp. Dt. : 04/04/2023 Status : Completed								
1087	23040094	JR Quarters	FAN NOT WORKING - ROOM NO 17	Manikandan. M.	Fan capacitor 2.5mfd 1no changed.		Virgin Mary - Canteen-Girls Hostel	05/04/2023
1088	23040098	Ladies hostel Phase-II	NEED TO CHANGE TUBELIGHT ROOM NO 41	Manikandan. M.	Tube light starter 1no changed.		Malliga. K. - Canteen-Girls Hostel	05/04/2023
1089	23040099	Ladies hostel Phase-II	NEED TO CHANGE TUBELIGHT ROOM NO 112	Manikandan. M.	Tube light starter 1no changed.		Malliga. K. - Canteen-Girls Hostel	05/04/2023


Dr. KAGNE. R.N.
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1090	23040101	Ladies hostel Phase-II	FAN & REGULATOR PROBLEM IN ROOM NO 98	Manikandan. M.	Fan regulator 1no & capacitor 2.5mfd 1no changed.		Malliga. K. - Canteen-Girls Hostel	05/04/2023
1091	23040117	Ladies hostel Phase-II	NEED TO FIX A NEW PLUG POINT FOR FIXING AC ROOM NO 98	Vijayaraghavan.B.,M animaran. M.,Babu. D.	AC power point wiring done.		Malliga. K. - Canteen-Girls Hostel	10/04/2023
1092	23040118	Ladies hostel Phase-II	NEED TO FIX A NEW PLUG POINT FOR FIXING AC ROOM NO 101	Vijayaraghavan.B.,B abu. D.,Srinivasan. R.	AC power point work done.		Malliga. K. - Canteen-Girls Hostel	11/04/2023
1093	23040119	Ladies hostel Phase-II	NEED TO FIX A NEW PLUG POINT FOR FIXING AC ROOM NO 110	Vijayaraghavan.B.,M animaran. M.,Babu. D.	AC power point wiring done.		Malliga. K. - Canteen-Girls Hostel	10/04/2023
1094	23040130	Ladies hostel Phase-I	FAN [2 NOS] & SWITCH [2NOS] NOT WORKING AT MESS	Manikandan. M.	Fan capacitor 2.5mfd 2no's & 6A Switch roma 2no's changed.		Revathy. N. - Canteen-Girls Hostel	05/04/2023
1095	23040132	Ladies hostel Phase-I	FAN NOT WORKING - ROOM NO 17	Manikandan. M.	Fan bearing problem. Spare fan fixed.		Revathy. N. - Canteen-Girls Hostel	06/04/2023
Comp. Dt. : 05/04/2023								
Status : Completed								
1096	23040147	Ladies hostel Phase-II	FAN SLOW PROBLEM - ROOM NO 110	Manikandan. M.	Fan capacitor 2.5mfd 1no changed.		Malliga. K. - Canteen-Girls Hostel	06/04/2023
1097	23040148	Ladies hostel Phase-II	NEED TO CHECK FAN - SOUND PROBLEM & CABLE BURNED - ROOM NO 52	Manikandan. M.,Manimaran. P.,Dhakshinamoorthy. J	Wallmounting fan problem - removed to power room. Wallmounting fan serviced.		Malliga. K. - Canteen-Girls Hostel	11/04/2023
1098	23040149	Ladies hostel Phase-II	NEED TO CHANGE TUBELIGHT FOR ROOM NO 6	Manikandan. M.	Tube light starter 1no changed.		Malliga. K. - Canteen-Girls Hostel	06/04/2023
1099	23040150	Ladies hostel Phase-II	NEED TO PROVIDE AC LINE FOR ROOM NO 111	Vijayaraghavan.B.	AC power point work done.		Malliga. K. - Canteen-Girls Hostel	11/04/2023
Comp. Dt. : 06/04/2023								
Status : Completed								
1100	23040194	JR Quarters	NEED TO REFIX T V [2NOS] & T V NOT WORKING IN I FLOOR	Vengadessaperumal. K.	HDMI cable connected - TV Problem solved.		Virgin Mary - Canteen-Girls Hostel	10/04/2023
1101	23040195	JR Quarters	NEED TO CHANGE TUBELIGHT [2NOS] FOR III FLOOR CARITOR	Dhakshinamoorthy. J	Tube light side holder 2no's changed.		Virgin Mary - Canteen-Girls Hostel	08/04/2023
1102	23040196	JR Quarters	NEED TO CHECK FAN REGULATOR & TUBELIGHT - FOR ROOM NO 59	Dhakshinamoorthy. J	Fan regulator 1no & starter 1no changed.		Virgin Mary - Canteen-Girls Hostel	08/04/2023
Comp. Dt. : 08/04/2023								
Status : Completed								
1103	23040252	Ladies hostel Phase-II	NEED TO CHANGE TUBELIGHT FOR ROOM NO 96	Dhakshinamoorthy. J	Tube light starter 1no changed.		Malliga. K. - Canteen-Girls Hostel	10/04/2023


Dr. KAGNE. R.N
 DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1104	23040253	Ladies hostel Phase-II	NEED TO CHANGE TUBELIGHT FOR ROOM NO 34	Dhakshinamoorthy. J	Tube light starter 1no changed.		Malliga. K. - Canteen-Girls Hostel	10/04/2023
Comp. Dt. : 10/04/2023 Status : Completed								
1105	23040261	JR Quarters	NEED TO CHECK HEATER - NOT WORKING AT GROUND FLOOR RESTROOM	Vijayaraghavan.B.	Heater reset - ok.		Virgin Mary - Canteen-Girls Hostel	11/04/2023
1106	23040262	JR Quarters	NEED TO CHANGE TUBELIGHT - NOT WORKING AT GROUND FLOOR RESTROOM	Vijayaraghavan.B.	Tube light starter 1no changed.		Virgin Mary - Canteen-Girls Hostel	11/04/2023
1107	23040271	Ladies hostel Phase-II	NEED TO CHANGE TUBELIGHT - ROOM NO 37	Vijayaraghavan.B.	36W tube light 2no's & E.choke 1no changed.		Malliga. K. - Canteen-Girls Hostel	11/04/2023
1108	23040272	Ladies hostel Phase-II	NEED TO CHECK SWITCH BOARD - POWER & SHOCK PROBLEM IN ROOM NO 89	Muthu. B.	6A socket 1no changed.		Malliga. K. - Canteen-Girls Hostel	12/04/2023
Comp. Dt. : 11/04/2023 Status : Completed								
1109	23040306	Ladies hostel Phase-II	FAN SLOW PROBLEM ROOM NO 5	Muthu. B.	Fan capacitor 2.5mfd 1no changed.		Malliga. K. - Canteen-Girls Hostel	12/04/2023
1110	23040307	Ladies hostel Phase-II	NEED TO CHANGE TUBELIGHT ROOM NO 22	Muthu. B.	Tube light starter 1no changed.		Malliga. K. - Canteen-Girls Hostel	12/04/2023
1111	23040308	Ladies hostel Phase-II	NEED TO CHANGE PLUG POINT - BRUNT ROOM NO 16	Muthu. B.	6A socket 1no changed.		Malliga. K. - Canteen-Girls Hostel	12/04/2023
Comp. Dt. : 13/04/2023 Status : Completed								
1112	23040407	JR Quarters	T V NOT WORKING - I & II FLOOR	Dhakshinamoorthy. J	1+ LED TV DISPLAY PRBLEM		Virgin Mary - Canteen-Girls Hostel	05/05/2023
Comp. Dt. : 17/04/2023 Status : Completed								
1113	23040509	Ladies hostel Phase-I	NEED TO CHANGE 3 PIN PLUG POINT 2 NOS FOR KITCHEN	Srinivasan. R.	6A 3PIN TOP 1NO CHANGED		Revathy. N. - Canteen-Girls Hostel	18/04/2023
Comp. Dt. : 19/04/2023 Status : Completed								
1114	23040585	Ladies hostel Phase-II	FAN SLOW PROBLEM - ROOM NO 33	Thillaikumar. R.	CEILING FAN CAPACITOR 2.5MFT 1NO CHANGED		Malliga. K. - Canteen-Girls Hostel	22/04/2023
Comp. Dt. : 20/04/2023 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1115	23040636	Ladies hostel Phase-II	FAN NOT WORKING - ROOM NO 94	Muthu. B.	6A SWITCH WIRE LOOSE RECONNECTION WORK PROBLEM SOLVED		Malliga. K. - Canteen-Girls Hostel	22/04/2023
1116	23040640	Ladies hostel Phase-I	NEED TO CHANGE TUBELIGHT FOR WARDEN ROOM	Muthu. B.	TUBE LIGHT 40W STARTER 1NO CHANGED		Revathy. N. - Canteen-Girls Hostel	22/04/2023
1117	23040654	JR Quarters	FAN NOT WORKING - IV FLOOR ROOM NO 101 ,103 & 104	Muthu. B.	MIT COLLEGE COMPLAIT'S		Virgin Mary - Canteen-Girls Hostel	22/04/2023
1118	23040679	Ladies hostel Phase-II	FAN NOT WORKING - ROOM NO 12	Muthu. B.	CEILING FAN CAPACITOR 2.5MFT 1NO CHANGED		Malliga. K. - Canteen-Girls Hostel	22/04/2023
Comp. Dt. : 22/04/2023 Status : Completed								
1119	23040699	JR Quarters	NEED TO CHANGE TUBELIGHT FOR I FLOOR CARITOR & GROUND FLOOR RESTROOM	Lakshmanan.V.	36W TUBE LIGHT 2NO'S CHANG & 40W STARTER 2NO'S CHANGED		Virgin Mary - Canteen-Girls Hostel	24/04/2023
1120	23040700	JR Quarters	NEED TO CHANGE TUBELIGHT FOR ROOM NO 12	Manikandan. M.	ROOM NO;12 DOOR LOCK		Virgin Mary - Canteen-Girls Hostel	25/04/2023
Comp. Dt. : 24/04/2023 Status : Completed								
1121	23040758	Ladies hostel Phase-II	NEED TO CHANGE FOCUS LIGHT FOR ENTRANCE & TUBELIGHT [2 NOS] FOR I FLOOR RESTROOM [BOTH SIDES]	Muthu. B.	36W TUBE LIGHT FITTING 1NO FIXING WORK PROBLEM SOLVED		Malliga. K. - Canteen-Girls Hostel	05/05/2023
1122	23040759	Ladies hostel Phase-II	NEED TO CHECK FAN - ROOM NO 92	Muthu. B.	CEILING FAN 1NO REWINDING BEARING CHANG & FAN REFIXING WORK PROBLEM SOLVED		Malliga. K. - Canteen-Girls Hostel	09/05/2023
Comp. Dt. : 25/04/2023 Status : Completed								
1123	23040783	JR Quarters	NEED TO CHECCK BASEMENT FOCUS LIGHT - NOT WORKING	Muthu. B.	100W LED FOCUS LIGHT 1NO FIXING & LINE CONNECTION WORK PROBLEM SOLVED		Virgin Mary - Canteen-Girls Hostel	25/05/2023
1124	23040814	Ladies hostel Phase-II	NEED TO CHANGE TUBELIGHT FOR ROOM NO 22	Lakshmanan.V.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Malliga. K. - Canteen-Girls Hostel	26/04/2023
1125	23040815	Ladies hostel Phase-II	NEED TO CHANGE TUBELIGHT FOR ROOM NO 15	Muthu. B.	36W TUBE LIGHT 1NO CHANGED		Malliga. K. - Canteen-Girls Hostel	28/04/2023
Comp. Dt. : 26/04/2023 Status : Completed								
1126	23040844	JR Quarters	NEED TO CHANGE TUBELIGHT 2 NOS FOR I FLOOR REST ROOM	Manikandan. M.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Virgin Mary - Canteen-Girls Hostel	03/05/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1127	23040846	JR Quarters	NEED TO CHECK SWITCH BOX - NOT WORKING ROOM NO 35	Muthu. B.	SWITCH BOARD SCREW REFIXING WORK PROBLEM SOLVED		Virgin Mary - Canteen-Girls Hostel	28/04/2023
1128	23040859	Ladies hostel Phase-II	FAN SLOW PROBLEM - ROOM NO 22	Muthu. B.	CEILING FAN CAPACITOR 2.5MFT 1NO CHANGED		Malliga. K. - Canteen-Girls Hostel	28/04/2023
1129	23040860	Ladies hostel Phase-II	FAN SLOW PROBLEM - ROOM NO 43	Muthu. B.	CEILING FAN CAPACITOR 2.5MFT 1NO CHANGED		Malliga. K. - Canteen-Girls Hostel	28/04/2023
1130	23040861	Ladies hostel Phase-II	NEED TO CHANGE TUBELIGHT FOR ROOM NO 15	Muthu. B.	36W TUBE LIGHT 1NO CHANGED		Malliga. K. - Canteen-Girls Hostel	28/04/2023
1131	23040862	Ladies hostel Phase-II	NEED TO CHANGE TUBELIGHT FOR ROOM NO 81	Muthu. B.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Malliga. K. - Canteen-Girls Hostel	28/04/2023
1132	23040874	Ladies hostel Phase-I	NEED TO CHANGE TUBELIGHT ROOM NO 70	Muthu. B.	36W TUBE LIGHT 1NO CHANGED		Revathy. N. - Canteen-Girls Hostel	05/05/2023
1133	23040875	Ladies hostel Phase-I	NEED TO CHANGE TUBELIGHT ROOM NO 45	Dhakshinamoorthy. J	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Revathy. N. - Canteen-Girls Hostel	29/04/2023
Comp. Dt. : 27/04/2023 Status : Completed								
1134	23040900	JR Quarters	ENTRANCE FAN NOT WORKING	Muthu. B.	CEILING FAN CAPACITOR 2.5MFT 1NO CHANGED		Virgin Mary - Canteen-Girls Hostel	28/04/2023
Comp. Dt. : 28/04/2023 Status : Completed								
1135	23040962	Ladies hostel Phase-II	NEED TO CHANGE TUBELIGHT FOR STUDY HALL	Rajan. R.	36W TUBE LIGHT 1NO CHANGED		Malliga. K. - Canteen-Girls Hostel	04/05/2023
1136	23040963	Ladies hostel Phase-II	NEED TO CHANGE TUBELIGHT FOR ROOM NO 4	Rajan. R.	36W TUBE LIGHT 1NO CHANGED		Malliga. K. - Canteen-Girls Hostel	04/05/2023
Comp. Dt. : 29/04/2023 Status : Completed								
1137	23041002	Ladies hostel Phase-II	NEED TO CHANGE TUBELIGHT FOR STUDY HALL & ROOM NO 5	Dhakshinamoorthy. J	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Malliga. K. - Canteen-Girls Hostel	03/05/2023
Comp. Dt. : 02/05/2023 Status : Completed								
1138	23050020	Ladies hostel Phase-I	NEED TO CHECK FAN & TUBELIGHT - NOT WORKING ROOM NO67	Muthu. B.	36W TUBE LIGHT 1NO CHANG & CEILING FAN CAPACITOR 2.5MFT 1NO CHANGED		Revathy. N. - Canteen-Girls Hostel	04/05/2023
1139	23050021	Ladies hostel Phase-I	NEED TO CHECK HEATER SWITCH - NOT WORKING AT I FLOOR	Rajan. R.	16A SWITCH 1NO CHANG & HEATER CHEKING WORK PROBLEM SOLVED		Revathy. N. - Canteen-Girls Hostel	04/05/2023
1140	23050031	JR Quarters	NEED TO CHANGE TUBELIGHT FOR ROOM NO 12	Muthu. B.	36W TUBE LIGHT 1NO CHANG & 36W CHOKE 1NO CHANGED		Virgin Mary - Canteen-Girls Hostel	04/05/2023


Dr. KAGNE. R.N.
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1141	23050034	JR Quarters	FAN NOT WORKING - ROOM NO 9	Muthu. B.	WALLMOUNTING FAN 1NO REFIXING WORK PROBLEM SOLVED		Virgin Mary - Canteen-Girls Hostel	04/05/2023
Comp. Dt. : 03/05/2023 Status : Completed								
1142	23050084	Ladies hostel Phase-II	FAN SLOW PROBLEM ROOM NO 33	Rajan. R.	CEILING FAN CAPACITOR 2.5MFT 1NO CHANGED		Malliga. K. - Canteen-Girls Hostel	04/05/2023
1143	23050085	Ladies hostel Phase-II	HEATER NOT WORKING - GROUND FLOOR	Muthu. B.	WATER HEATER THERMO CUT 1NO CHANG & LINE CONNECTION WORK HEATER CHEKING WORK PROBLEM SOLVED		Malliga. K. - Canteen-Girls Hostel	05/05/2023
1144	23050091	JR Quarters	NEED TO CHANGE TUBELIGHT ROOM NO 2	Muthu. B.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Virgin Mary - Canteen-Girls Hostel	05/05/2023
1145	23050092	JR Quarters	NEED TO CHANGE TUBELIGHT ROOM NO 7	Rajan. R.	36W TUBE LIGHT 1NO CHANG & 36W CHOKE 1NO CHANGED		Virgin Mary - Canteen-Girls Hostel	04/05/2023
1146	23050093	JR Quarters	FAN NOT WORKING ROOM NO 12 & FIT A FAN AT GROUND FLOOR CARITOR	Manimaran. P.	WALLMOUNTING FAN 1NO REFIXING WORK PROBLEM SOLVED		Virgin Mary - Canteen-Girls Hostel	04/05/2023
Comp. Dt. : 04/05/2023 Status : Completed								
1147	23050148	JR Quarters	FAN & REGULATOR NOT WORKING - ROOM NO 17	Muthu. B.	FAN REGULATOR 1NO CHANGED		Virgin Mary - Canteen-Girls Hostel	09/05/2023
Comp. Dt. : 05/05/2023 Status : Completed								
1148	23050191	Ladies hostel Phase-II	FAN SLOW PROBLEM ROOM NO 17	Muthu. B.	CEILING FAN CAPACITOR 2.5MFT 1NO CHANGED		Malliga. K. - Canteen-Girls Hostel	08/05/2023
1149	23050192	Ladies hostel Phase-II	FAN SLOW PROBLEM ROOM NO 18	Muthu. B.	CEILING FAN CAPACITOR 2.5MFT 1NO CHANGED		Malliga. K. - Canteen-Girls Hostel	08/05/2023
1150	23050193	Ladies hostel Phase-II	HEATER NOT WORKING AT II FLOOR	Manikandan. M.	WATER HEATER 1NO THERMOCUT 1NO CHANGED		Malliga. K. - Canteen-Girls Hostel	20/05/2023
Comp. Dt. : 06/05/2023 Status : Completed								
1151	23050244	Ladies hostel Phase-II	FAN SLOW PROBELM IN ROOM NO 4	Manimaran. P.	CEILING FAN CAPACITOR 2.5MFT 1NO CHANGED		Malliga. K. - Canteen-Girls Hostel	09/05/2023
Comp. Dt. : 08/05/2023 Status : Completed								
1152	23050266	JR Quarters	FAN NOT WORKING ROOM NO 3	Manimaran. P.	CEILING FAN CAPACITOR 2.5MFT 1NO CHANGED		Virgin Mary - Canteen-Girls Hostel	09/05/2023
1153	23050274	Ladies hostel Phase-I	FAN NOT WORKING ROOM NO 63	Manimaran. P.	1WEEK'S DOOR LOCK		Payathy. N. - Canteen-Girls Hostel	12/05/2023

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1154	23050276	Ladies hostel Phase-I	NEED TO CHANGE TUBELIGHT FOR II , III [2NOS] & IV FLOOR CARITORS	Manimaran. P.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 2NO'S CHANGED		Revathy. N. - Canteen-Girls Hostel	09/05/2023
1155	23050286	Ladies hostel Phase-II	FAN NOT WORKING SLOW PROBLEM - ROOM NO 4	Manimaran. P.	CEILING FAN CAPACITOR 2.5MFT 1NO CHANGED		Malliga. K. - Canteen-Girls Hostel	09/05/2023
1156	23050287	Ladies hostel Phase-II	NEED TO CHANGE TUBELIGHT FOR ROOM NO 5	Manimaran. P.	36W TUBE LIGHT 1NO CHANGED		Malliga. K. - Canteen-Girls Hostel	09/05/2023
1157	23050314	LADIES HOSTEL MESS	MIXIE JAR BROKEN	Vijayaraghavan.B.	Jar serviced.		Revathy. N. - Canteen-Girls Hostel	15/05/2023
Comp. Dt. : 09/05/2023								
Status : Completed								
1158	23050368	Ladies hostel Phase-II	STREET LIGHT NOT WORKING [PHASE -I OPPOSITE]	Lakshmanan.V.	MCB TRIP ON TO WORK PROBLEM SOLVED		Malliga. K. - Canteen-Girls Hostel	10/05/2023
Comp. Dt. : 11/05/2023								
Status : Completed								
1159	23050435	Ladies hostel Phase-II	NEED TO CHANGE TUBELIGHT FOR GROUND FLOOR RESTROOM & ROOM NO 2	Manimaran. P.	TUBE LIGHT 40W STARTER 1NO CHANGED		Malliga. K. - Canteen-Girls Hostel	12/05/2023
1160	23050436	Ladies hostel Phase-II	NEED TO CHANGE TUBELIGHT FOR ROOM NO 25	Manimaran. P.	TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANG & 36W CHOKE 1NO CHANGED		Malliga. K. - Canteen-Girls Hostel	12/05/2023
1161	23050437	Ladies hostel Phase-II	NEED TO CHANGE TUBELIGHT FOR ROOM NO 49	Manimaran. P.	TUBE LIGHT 40W STARTER 1NO CHANGED		Malliga. K. - Canteen-Girls Hostel	12/05/2023
1162	23050455	Ladies hostel Phase-I	NEED TO CHANGE TUBELIGHT FOR ROOM NO 7	Manimaran. P.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Revathy. N. - Canteen-Girls Hostel	12/05/2023
1163	23050456	Ladies hostel Phase-I	FAN NOT WORKING ROOM NO 63	Thillaikumar. R.	Fan capacitor 2.5mfd 1no changed.		Revathy. N. - Canteen-Girls Hostel	15/05/2023
Comp. Dt. : 15/05/2023								
Status : Completed								
1164	23050570	Ladies hostel Phase-I	NEED TO CHANGE TUBELIGHT FOR MESS & II FLOOR	Dhakshinamoorthy. J	39W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Revathy. N. - Canteen-Girls Hostel	16/05/2023
1165	23050579	Ladies hostel Phase-II	NEED TO CHANGE TUBELIGHT FOR ROOM NO 23	Dhakshinamoorthy. J	36W TUBE LIGHT 1NO CHANGED		Malliga. K. - Canteen-Girls Hostel	16/05/2023
1166	23050580	Ladies hostel Phase-II	FAN SLOW PROBLEM ROOM NO 24	Dhakshinamoorthy. J	CEILING FAN CAPACIOTR 2.5MFT 1NO CHAGED		Malliga. K. - Canteen-Girls Hostel	16/05/2023
1167	23050581	Ladies hostel Phase-II	FAN SLOW PROBLEM ROOM NO 7	Dhakshinamoorthy. J	CEILING FAN CAPACITOR 1NO CHANGED		Malliga. K. - Canteen-Girls Hostel	16/05/2023
Comp. Dt. : 16/05/2023								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
1168	23050634	JR Quarters	NEED TO CHANGE TUBELIGHT FOR GOUND FLOOR WARDEN ROOM	Dhakshinamoorthy. J	TUBE LIGHT 40W STARTER 1NO CHANGED		Virgin Mary - Canteen-Girls Hostel	17/05/2023
1169	23050635	JR Quarters	FAN NOT WORKING - ROOM NO 38	Dhakshinamoorthy. J	WALLMOUNTING FAN NOT WORK FAN REMOVING WORK		Virgin Mary - Canteen-Girls Hostel	17/05/2023
1170	23050645	Ladies hostel Phase-II	NEED TO CHECK FAN & TUBELIGHT - NOT WORKING ROOM NO 47	Dhakshinamoorthy. J	TUBE LIGHT 40W STARTER 2NO'S CHANGED		Malliga. K. - Canteen-Girls Hostel	17/05/2023
1171	23050646	Ladies hostel Phase-II	NEED TO CHANGE TUBELIGHT FOR III FLOOR STUDY HALL	Dhakshinamoorthy. J	TUBE LIGHT 40W STARTER 1NO CHANGED		Malliga. K. - Canteen-Girls Hostel	17/05/2023
1172	23050653	Ladies hostel Phase-I	NEED TO CHANGE TUBELIGHT FOR ROOM NO 4	Dhakshinamoorthy. J	TUBE LIGHT 40W STARTER 1NO CHANGED		Revathy. N. - Canteen-Girls Hostel	17/05/2023
Comp. Dt. : 17/05/2023								
Status : Completed								
1173	23050687	Ladies hostel Phase-II	FAN NOT WORKING ROOM NO 117	Dhakshinamoorthy. J	CEILING FAN CAPACIOTR 2.5MFT 1NO CHANGED		Malliga. K. - Canteen-Girls Hostel	18/05/2023
1174	23050721	JR Quarters	NEED TO CHECK FAN & TUBELIGHT - ROOM NO 43	Dhakshinamoorthy. J	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Virgin Mary - Canteen-Girls Hostel	18/05/2023
Comp. Dt. : 18/05/2023								
Status : Completed								
1175	23050734	Ladies hostel Phase-II	FAN SLOW PROBLEM ROOM NO 22	Dhakshinamoorthy. J	CEILING FAN CAPACITOR 2.5MFT 1NO CHANGED		Malliga. K. - Canteen-Girls Hostel	19/05/2023
1176	23050735	Ladies hostel Phase-II	FAN SLOW PROBLEM ROOM NO 94	Dhakshinamoorthy. J	CEILING FAN 1NO CAPACITOR 2.5MFT 1NO CHANGED		Malliga. K. - Canteen-Girls Hostel	19/05/2023
1177	23050736	Ladies hostel Phase-II	FAN SLOW PROBLEM ROOM NO 104	Dhakshinamoorthy. J	CEILING FAN WIRE LOOS & WIRE RECONNECTION WORK PROBLEM SOLVED		Malliga. K. - Canteen-Girls Hostel	19/05/2023
1178	23050737	Ladies hostel Phase-II	FAN SLOW PROBLEM ROOM NO 114	Dhakshinamoorthy. J	CEILING FAN CAPACITOR 2.5MFT 1NO CHANGED		Malliga. K. - Canteen-Girls Hostel	19/05/2023
Comp. Dt. : 19/05/2023								
Status : Completed								
1179	23050789	Ladies hostel Phase-II	HEATER NOTWORKING AT IV FLOOR	Dhakshinamoorthy. J	WATER HEATER 1NO RESET WORK PROBLEM SOLVED		Malliga. K. - Canteen-Girls Hostel	20/05/2023
1180	23050790	Ladies hostel Phase-II	NEED TO CHANGE TUBELIGHT ROOM NO 81	Dhakshinamoorthy. J	36W TUBE LIGHT 1NO CHANGED		Malliga. K. - Canteen-Girls Hostel	20/05/2023
1181	23050799	Ladies hostel Phase-I	PESTKILLER NOT WORKING	Manimaran. M.	PESTKILLER WIRE CUT RECONNECTION WORK PROBLEM SOLVED		Revathy. N. - Canteen-Girls Hostel	23/05/2023
Comp. Dt. : 20/05/2023								
Status : Completed								


Dr. KAGNE. R.N.
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1182	23050849	Ladies hostel Phase-II	NEED TO CHANGE TUBELIGHT FOR ROOM NO 25	Muthu. B.	36W TUBE LIGHT 2NO'S CHANG & 40W STARTER 4NO'S CHANGED		Malliga. K. - Canteen-Girls Hostel	24/05/2023
Comp. Dt. : 23/05/2023 Status : Completed								
1183	23050931	Ladies hostel Phase-I	NEED TO CHANGE TUBELIGHT FOR I , II & III FLOOR CARITORS [3 NOS]	Muthu. B.	36W TUBE LIGHT 2NO'S CHANG & 40W STARTER 2NO'S CHANGED		Revathy. N. - Canteen-Girls Hostel	24/05/2023
Comp. Dt. : 24/05/2023 Status : Completed								
1184	23050954	Ladies hostel Phase-I	NEED TO CHANGE TUBELIGHT FOR ROOM NO 59	Rajan. R.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Revathy. N. - Canteen-Girls Hostel	25/05/2023
Comp. Dt. : 29/05/2023 Status : Completed								
1185	23051156	JR Quarters	NEED TO CHANGE TUBELIGHT FOR ROOM NO 27	Thillaikumar. R.	TUBE LIGHT 40W STARTER 1NO CHANGED		Virgin Mary - Canteen-Girls Hostel	30/05/2023
Comp. Dt. : 31/05/2023 Status : Completed								
1186	23051230	Ladies hostel Phase-II	NEED TO EXTEND CABLE FOR TV & SETUP BOX	Thillaikumar. R.	NEW HDMI CABLE 1NO CHANG & TV CHEKING WORK PROBLEM SOLVED		Malliga. K. - Canteen-Girls Hostel	02/06/2023
Comp. Dt. : 02/06/2023 Status : Completed								
1187	23060063	Ladies hostel Phase-I	NEED TO CHANGE TUBELIGHT FOR ROOM NO 67	Srinivasan. R.	36W TUBE LIGHT 1NO CHANGED		Revathy. N. - Canteen-Girls Hostel	05/06/2023
1188	23060064	Ladies hostel Phase-I	NEED TO CHANGE TUBELIGHT FOR DINING HALL	Srinivasan. R.	TUBE LIGHT 36W CHOKE 1NO CHANGED		Revathy. N. - Canteen-Girls Hostel	05/06/2023
Comp. Dt. : 05/06/2023 Status : Completed								
1189	23060123	JR Quarters	NEED TO CHANGE TUBELIGHT 5NOS FOR GROUND FLOOR RESTROOM	Lakshmanan.V.	LDB TRIP ON OT WORK & TUBE LIGHT 40W STARTER 1NO CHANGED		Virgin Mary - Canteen-Girls Hostel	06/06/2023
Comp. Dt. : 06/06/2023 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1190	23060190	Ladies hostel Phase-II	NEED TO CHANGE TUBELIGHT 2 NOS FOR COMMON RESTROOM & ROOM NO 6	Vijayaraghavan.B.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Malliga. K. - Canteen-Girls Hostel	07/06/2023
1191	23060204	LADIES HOSTEL MESS	NEED TO CHANGE TUBELIGHT 2 NOS	Vijayaraghavan.B.	36W TUBE LIGHT 1NO CHANG & SIDE HOLDER 1NO CHANGED		Revathy. N. - Canteen-Girls Hostel	08/06/2023
Comp. Dt. : 07/06/2023 Status : Completed								
1192	23060227	Ladies hostel Phase-II	NEED TO CHANGE TUBELIGHT FOR ROOM NO 21	Lakshmanan.V.	TUBE LIGHT 40W STARTER 1NO CHANGED		Malliga. K. - Canteen-Girls Hostel	10/06/2023
Comp. Dt. : 08/06/2023 Status : Completed								
1193	23060278	Ladies hostel Phase-II	NEED TO CHANGE TUBELIGHT FOR IV & GROUND FLOOR CARITOR & ROOM NO 101	Dhakshinamoorthy. J	36W TUBE LIGHT 1NO CHANG & 40W STARTER 2NO'S CHANG & SIDE HOLDER 1NO CHANGED		Malliga. K. - Canteen-Girls Hostel	10/06/2023
1194	23060279	Ladies hostel Phase-II	HEATER NOT WORKING AT IV FLOOR	Dhakshinamoorthy. J	WATER HEATER 1NO RESET WORK PROBLEM SOLVED		Malliga. K. - Canteen-Girls Hostel	10/06/2023
1195	23060280	Ladies hostel Phase-II	NEED TO CHANGE FAN CABLE - BURNT - AT GROUND FLOOR ROOM NO 23	Lakshmanan.V.	36W TUBE LIGHT 1NO CHANGED		Malliga. K. - Canteen-Girls Hostel	10/06/2023
Comp. Dt. : 09/06/2023 Status : Completed								
1196	23060325	Ladies hostel Phase-II	NEED TO REFIX FAN CAPACITOR - FAN SLOW PROBLEM - ROOM NO 23	Dhakshinamoorthy. J	CEILING FAN CAPACITOR 2.5MFT 1NO CHANGED		Malliga. K. - Canteen-Girls Hostel	10/06/2023
Comp. Dt. : 10/06/2023 Status : Completed								
1197	23060370	Ladies hostel Phase-II	NEED TO CHANGE TUBELIGHT FOR ROOM NO 91	Dhakshinamoorthy. J	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Malliga. K. - Canteen-Girls Hostel	13/06/2023
Comp. Dt. : 12/06/2023 Status : Completed								
1198	23060392	JR Quarters	NEED TO CHANGE TUBELIGHT 6 NOS FOR IV FLOOR CARITOR, II FLOOR STEPS [2NOS] , GROUND FLOOR 2 NOS & R	Dhakshinamoorthy. J	36W TUBE LIGHT 4NO'S CHANG & 40W STARTER 6NO'S CHANGED		Virgin Mary - Canteen-Girls Hostel	13/06/2023
1199	23060397	Ladies hostel Phase-II	NEED TO CHANGE TUBELIGHT FOR IV FLOOR CARITOR & ROOM NO 15	Dhakshinamoorthy. J	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Malliga. K. - Canteen-Girls Hostel	13/06/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1200	23060398	Ladies hostel Phase-II	NEEDTCHANGE TUBELIGHT FOR ROOM NO 98	Dhakshinamoorthy. J	36W TUBE LIGHT 1NO CHANGED		Malliga. K. - Canteen-Girls Hostel	13/06/2023
1201	23060399	Ladies hostel Phase-II	FOCUS LIGHT NOT WORKING - GROUND FLOOR	Dhakshinamoorthy. J	FOCUS LIGHT CHEKING WORK NO COMPLAINT PROBLEM SOLVED		Malliga. K. - Canteen-Girls Hostel	13/06/2023
Comp. Dt. : 13/06/2023 Status : Completed								
1202	23060443	Ladies hostel Phase-II	MAIN ENTRANCE SWITCH NOT WORKING - ROOM NO 11	Thillaikumar. R.	16A SWITCH WIRE LOOSE RECONNECTION WORK PROBLEM SOLVED		Malliga. K. - Canteen-Girls Hostel	15/06/2023
1203	23060444	JR Quarters	NEED TO CHANGE TUBELIGHT FOR GROUND FLOOR CARITOR	Lakshmanan.V.	TUBE LIGHT 40W STARTER 1NO CHANGED		Virgin Mary - Canteen-Girls Hostel	15/06/2023
Comp. Dt. : 14/06/2023 Status : Completed								
1204	23060480	Ladies hostel Phase-II	HEATER NOT WORKING - IV FLOOR	Thillaikumar. R.	WATER HEATER 1NO RESET WORK PROBLEM SOLVED		Malliga. K. - Canteen-Girls Hostel	15/06/2023
1205	23060482	Ladies hostel Phase-II	NEED TO CHANGE TUBELIGHT - ROOM NO 110	Thillaikumar. R.	TUBE LIGHT 40W STARTER 1NO CHANGED		Malliga. K. - Canteen-Girls Hostel	15/06/2023
1206	23060484	Ladies hostel Phase-II	NEED TO CHANGE TUBELIGHT - ROOM NO 91	Thillaikumar. R.	TUBE LIGHT 40W STARTER 1NO CHANGED		Malliga. K. - Canteen-Girls Hostel	15/06/2023
1207	23060485	Ladies hostel Phase-II	FAN NOT WORKING ROOM NO 23	Thillaikumar. R.	6A 3PIN TOP 1NO CHANGED		Malliga. K. - Canteen-Girls Hostel	15/06/2023
1208	23060505	JR Quarters	NEED TO CHANGE TUBELIGHT FOR GROUND FLOOR CARITOR & ROOM NO 14	Lakshmanan.V.	TUBE LIGHT 40W STARTER 2NO'S CHANGED		Virgin Mary - Canteen-Girls Hostel	15/06/2023
Comp. Dt. : 17/06/2023 Status : Completed								
1209	23060625	JR Quarters	NEED TO CHANGE TUBELIGHT 2 NOS FOR ROOM NO 42	Lakshmanan.V.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Virgin Mary - Canteen-Girls Hostel	21/06/2023
Comp. Dt. : 19/06/2023 Status : Completed								
1210	23060663	Ladies hostel Phase-II	NEED TO CHANGE TUBELIGHT FOR ROOM NO 4 [GROUND FLOOR]	Suresh. V.	TUBE LIGHT 40W STARTER 1NO CHANGED		Malliga. K. - Canteen-Girls Hostel	19/06/2023
1211	23060681	Ladies hostel Phase-II	NEED TO CHANGE FAN CABLE - BURNT - ROOM NO 12	Suresh. V.	6A 3PIN TOP 1NO CHANGED		Malliga. K. - Canteen-Girls Hostel	19/06/2023
Comp. Dt. : 20/06/2023 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1212	23060729	JR Quarters	NEED TO CHANGE TUBELIGHT [2NOS] FOR ROOM NO 45	Lakshmanan.V.	36W TUBE LIGHT 1NO CHANG & 36W STARTER 1NO CHANGED		Virgin Mary - Canteen-Girls Hostel	21/06/2023
Comp. Dt. : 21/06/2023 Status : Completed								
1213	23060745	Ladies hostel Phase-I	FAN [7NOS] SLOW PROBLEM AT CANTEEN [MESS HALL]	Srinivasan. R.	CEILING FAN CAPACITOR 2.5MFT 7NO'S CHANGED		Revathy. N. - Canteen-Girls Hostel	22/06/2023
1214	23060746	Ladies hostel Phase-I	NEED TO CHANGE TUBELIGHT FOR I & IV FLOOR CARITOR [3NOS]	Srinivasan. R.	36W TUBE LIGHT 3NO'S CHANG & 40W STARTER 3NO'S CHANGED		Revathy. N. - Canteen-Girls Hostel	22/06/2023
1215	23060747	Ladies hostel Phase-I	NEED TO REFIT FELL DOWN HEATER AT III FLOOR	Srinivasan. R.	WATER HETARE NEW COIL 2KW 1NO CHANG & LINE CONNECTION WORK & HEATER CHEKING WORK PROBLEM SOLVED		Revathy. N. - Canteen-Girls Hostel	22/06/2023
Comp. Dt. : 22/06/2023 Status : Completed								
1216	23060802	Ladies hostel Phase-I	NEED TO CHANGE TUBELIGHT FOR GROUND FLOOR CARITOR & KITCHEN 2NOS [TOTAL 3 NOS]	Lakshmanan.V.	36W TUBE LIGHT 2NO'S CHANGED		Revathy. N. - Canteen-Girls Hostel	23/06/2023
Comp. Dt. : 23/06/2023 Status : Completed								
1217	23060868	Ladies hostel Phase-II	NEED TO CHANGE TUBELIGHT FOR I FLOOR CARITOR & III & IV FLOOR RESTROOM [TOTAL 3NOS]	Srinivasan. R.	TUBE LIGHT 36W CHOKE 1NO CHANG & 40W STARTER 3NO'S CHANGED		Malliga. K. - Canteen-Girls Hostel	24/06/2023
1218	23060869	Ladies hostel Phase-II	NEED TO CHANGE TUBELIGHT FOR ROOM NO 43 - I FLOOR	Srinivasan. R.	TUBE LIGHT 40W STARTER 1NO CHANGED		Malliga. K. - Canteen-Girls Hostel	24/06/2023
1219	23060870	Ladies hostel Phase-II	NEED TO CHANGE TUBELIGHT FOR ROOM NO 32 I FLOOR	Manimaran. P.	TUBE LIGHT 36W CHOKE 1NO CHANG & 40W STARTER 1NO CHANGED		Malliga. K. - Canteen-Girls Hostel	26/06/2023
Comp. Dt. : 24/06/2023 Status : Completed								
1220	23060913	Ladies hostel Phase-II	HEATER NOT WORKING - IV FLOOR	Manimaran. P.	WATER HEATER 1NO RESET WORK PROBLEM SOLVED		Malliga. K. - Canteen-Girls Hostel	26/06/2023
1221	23060914	Ladies hostel Phase-II	NEED TO CHANGE TUBELIGHT FOR ROOM NO 32	Manimaran. P.	TUBE LIGHT 36W CHOKE 1NO CHANG & 40W STARTER 1NO CHANGED		Malliga. K. - Canteen-Girls Hostel	26/06/2023
Comp. Dt. : 26/06/2023 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1222	23060945	Ladies hostel Phase-II	HEATER NOT WORKING - I & IV FLOOR	Vijayaraghavan.B.	thermo cut 1nos changed		Malliga. K. - Canteen-Girls Hostel	28/06/2023
1223	23060946	Ladies hostel Phase-II	NEED TO CHECK TUBELIGHT - NOT WORKING - ROOM NO 24 & GROUND FLOOR RESTROOM	Vijayaraghavan.B.	6A 3PIN TOP 1NO CHANG & TUBE LIGHT 36W CHOKE 1NO CHANGED		Malliga. K. - Canteen-Girls Hostel	30/06/2023
1224	23060947	Ladies hostel Phase-II	FAN NOT WORKING - ROOM NO 23	Vijayaraghavan.B.	6a plug top 1 nos changed		Malliga. K. - Canteen-Girls Hostel	28/06/2023
1225	23060976	JR Quarters	NEED TO CHANGE TUBELIGHT - ROOM NO 25 [I FLOOR]	Vijayaraghavan.B.	TUBE LIGHT 40W STARTER 1NO CHANGED		Virgin Mary - Canteen-Girls Hostel	27/06/2023
Comp. Dt. : 27/06/2023								
Status : Completed								
1226	23061004	Ladies hostel Phase-II	FAN NOT WORKING - ROOM NO 101	Vijayaraghavan.B.	ceilling fan line connection work		Malliga. K. - Canteen-Girls Hostel	28/06/2023
1227	23061017	JR Quarters	NEED TO CHANGE TUBELIGHT & CFL LIGHT FOR ROOM NO 84	Vijayaraghavan.B.	9W LED LIGHT 1NO CHANGED		Virgin Mary - Canteen-Girls Hostel	30/06/2023
Comp. Dt. : 28/06/2023								
Status : Completed								
1228	23061053	Ladies hostel Phase-II	TRIP PROBLEM AT III FLOOR - COOLER PROBLEM	Lakshmanan.V.	MCB TRIP ON TO WORK PROBLEM SOLVED		Malliga. K. - Canteen-Girls Hostel	03/07/2023
1229	23061055	Ladies hostel Phase-II	NEED TO CHANGE TUBELIGHT FOR II FLOOR COMMON RESTROOM & III FLOOR CARITOR	Lakshmanan.V.,Dam odharan. V.,Dhakshinamoorth y. J	TUBE LIGHT STARTER 2NO'S CHANGED		Malliga. K. - Canteen-Girls Hostel	01/07/2023
1230	23061056	Ladies hostel Phase-II	NEED TO CHANGE TUBELIGHT FOR ROOM NO 44	Lakshmanan.V.	TUBE LIGHT 40W STARTER 1NO CHANGED		Malliga. K. - Canteen-Girls Hostel	01/07/2023
Comp. Dt. : 30/06/2023								
Status : Completed								
1231	23061096	Ladies hostel Phase-II	NEED TO REFIX FAN REGULATOR FOR ROOM NO 49	Lakshmanan.V.	CEILING FAN REGULAATOR 1NO CHANGED		Mallika. S. - Canteen-Girls Hostel	01/07/2023
1232	23061097	Ladies hostel Phase-II	FAN NOT WORKING ROOM NO 89	Lakshmanan.V.	CEILING FAN WIRE LINE CONNECTION WORK PROBLEM SOLVED		Malliga. K. - Canteen-Girls Hostel	01/07/2023
1233	23061098	Ladies hostel Phase-II	NEED TO CHANGE TUBELIGHT FOR ROOM NO 84	Lakshmanan.V.	TUBE LIGHT 40W STARTER 1NO CHANGED		Malliga. K. - Canteen-Girls Hostel	01/07/2023
1234	23061099	JR Quarters	NEED TO CHANGE TUBELIGHT FOR GROUND FLOOR COMMON RESTROOM & ROOM NO 3	Lakshmanan.V.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Virgin Mary - Canteen-Girls Hostel	01/07/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Dept Name : CARDIOLOGY - Electrical Maintenance Comp. Dt. : 20/05/2022 Status : Completed								
1235	22050755	ECHO CARDIO GRAM	NEED TO CHANGE TUBELIGHT	Muthu. B.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Ramani Palanivel.P. - CARDIOLOGY	23/05/2022
Comp. Dt. : 26/05/2022 Status : Completed								
1236	22050995	ECHO CARDIO GRAM	NEED TO CHANGE LED LIGHT	Manimaran. P.	9W LED lamp 1no changed.		Ramani Palanivel.P. - CARDIOLOGY	26/05/2022
Comp. Dt. : 28/05/2022 Status : Completed								
1237	22051038	Cath Lab	NEED TO CHANGE CFL LIGHT [2NOS] - NOT WORKING	Suresh. V.	18W 2PIN CFL LIGHT 3NO'S CHANGED		Deva Arul Selva Sagayaraj. A. - CARDIOLOGY	30/05/2022
Comp. Dt. : 29/06/2022 Status : Completed								
1238	22061075	Cath Lab	NEED TO CHANGE TUBELIGHT	Manimaran. P.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Deva Arul Selva Sagayaraj. A. - CARDIOLOGY	30/06/2022
Comp. Dt. : 23/07/2022 Status : Completed								
1239	22070851	Cath Lab	NEED TO CHANGE CFL LIGHT [3NOS]	Rajan. R.	36W 4PIN CFL LIGHT 2NO'S CHANGED		Padmapriya. D. - CARDIOLOGY	25/07/2022
Comp. Dt. : 05/10/2022 Status : Completed								
1240	22100042	ECHO CARDIO GRAM	NEED TO CHANGE FALSE CEILING LIGHT - NOT WORKING	Srinivasan. R.	30W LED LIGHT FITTING 1NO REFIXING WORK PROBLEM SOLVED		Ramani Palanivel.P. - CARDIOLOGY	11/10/2022
Comp. Dt. : 14/10/2022 Status : Completed								
1241	22100454	ECHO CARDIO GRAM	NEED TO CHECK UPS NOT WORKING AT T M T ROOM [ELECTRICAL FAULT]	Manimaran. M.	0.5KVA UPS CHEKING WORK PROBLEM SOLVED		Ramani Palanivel.P. - CARDIOLOGY	15/10/2022
Comp. Dt. : 10/11/2022 Status : Completed								
1242	22110392	Cath Lab	X-RAY LOBBY NOT WORKING	Manimaran. P.	9W LED LIGHT 1NO CHANG & BABY HOLDER 1NO CHANGED		Deva Arul Selva Sagayaraj. A. - CARDIOLOGY	14/11/2022
Comp. Dt. : 19/01/2023								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
1243	23010658	ECHO CARDIO GRAM	NEED TO CHANGE TUBELIGHT FOR T M T ROOM	Srinivasan. R.	TUBE LIGHT 40W STARTER 1NO CHANGED		Ramani Palanivel.P. - CARDIOLOGY	20/01/2023
Comp. Dt. : 10/04/2023								
Status : Completed								
1244	23040265	ECHO CARDIO GRAM	NEED TO CHANGE TUBELIGHT FOR T M T ROOM	Manikandan. M.	36W tube light 1no & starter 1no changed.		Ramani Palanivel.P. - CARDIOLOGY	10/04/2023
Comp. Dt. : 12/05/2023								
Status : Completed								
1245	23050480	ECHO CARDIO GRAM	NEED TO CHANGE TUBELIGHT	Manimaran. P.	36W 4PIN CFL LIGHT 1NO CHANGED		Ramani Palanivel.P. - CARDIOLOGY	13/05/2023
Dept Name : Cardiothoracic ICU - Electrical Maintenance								
Comp. Dt. : 09/05/2022								
Status : Completed								
1246	22050284	CT-ICU ROOM-NEAR ORTHO OT RECOVERY ROOM	NEED TO CHANGE TUBELIGHT 4 NOS	Muthu. B.	9W LED LIGHT 4NO'S CHANGED		Aswani. J. - Cardiothoracic ICU	12/05/2022
Comp. Dt. : 28/05/2022								
Status : Completed								
1247	22051055	CT POW -SPECIAL WARD B	HEATER NOT WORKING - [MALE PRE OPP ROOM]	Lakshmanan.V.	WATER HEATER 1NO RESET WORK PROBLEM SOLVED		Nilavu. K. - Cardiothoracic POW	30/05/2022
Comp. Dt. : 20/06/2022								
Status : Completed								
1248	22060712	CT-ICU ROOM-NEAR ORTHO OT RECOVERY ROOM	NEED TO CHECK SWITCH & LED LIGHT - NOT WORKING	Srinivasan. R.	9W LED LIGHT 1NO CHANGED		Aswani. J. - Cardiothoracic ICU	22/06/2022
Comp. Dt. : 27/06/2022								
Status : Completed								
1249	22060962	CT-ICU ROOM-NEAR ORTHO OT RECOVERY ROOM	NEED TO CHECK EXTENTION BOX PLUG & CABLES	Vijayaraghavan.B.	6A 3PIN TOP 1NO CHANGED		Thamizhselvi. A. - Cardiothoracic ICU	30/06/2022
Comp. Dt. : 18/07/2022								
Status : Completed								
1250	22070674	CT-ICU ROOM-NEAR ORTHO OT RECOVERY ROOM	NEED TO CHANGE LED LIGHT	Rajan. R.	9W LED LIGHT 1NO CHANGED		Aswani. J. - Cardiothoracic ICU	19/07/2022
Comp. Dt. : 07/09/2022								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
1251	22090281	CT-ICU ROOM-NEAR ORTHO OT RECOVERY ROOM	KETTLE NOT WORKING	Lakshmanan.V.	KETTLE SERVICE WORK PROBLEM SOLVED		Saroja. P. - Cardiothoracic ICU	09/09/2022
Comp. Dt. : 27/09/2022								
Status : Completed								
1252	22091042	CT-ICU ROOM-NEAR ORTHO OT RECOVERY ROOM	NEED TO CHANGE CEILING LIGHT	Lakshmanan.V.	9W LED LIGHT 2NO'S CHANGED		Thamizhselvi. A. - Cardiothoracic ICU	29/09/2022
Comp. Dt. : 10/10/2022								
Status : Completed								
1253	22100203	CT-ICU ROOM-NEAR ORTHO OT RECOVERY ROOM	NEED TO CHANGE LED LIGHT 5 NOS - NOT WORKING	Muthu. B.	CEILING FAN 3NO'S CHANG & 40W TUBE LIGHT SET 5NO'S REFIXING WORK PROBLEM SOLVED		Aswani. J. - Cardiothoracic ICU	11/10/2022
Comp. Dt. : 08/11/2022								
Status : Completed								
1254	22110295	CT-ICU ROOM-NEAR ORTHO OT RECOVERY ROOM	4NO'S LED LIGHT NOT WORKING	Manimaran. P.	BABY HOLDER 2NO'S CHANG & 9W LED LIGHT 3NO'S CHANGED		Sangeetha. M. - Cardiothoracic ICU	09/11/2022
Comp. Dt. : 14/11/2022								
Status : Completed								
1255	22110557	CT-ICU ROOM-NEAR ORTHO OT RECOVERY ROOM	PEDESTAL FAN LEAF GOT BEND	Thillaikumar. R.	PEDESTAL FAN 1NO SERVICE WORK PROBLEM SOLVED		Thamizhselvi. A. - Cardiothoracic ICU	16/11/2022
Comp. Dt. : 22/11/2022								
Status : Completed								
1256	22110946	CTVS INSIDE ORTHO OT	NEED TO CHANGE LED LIGHT 2 NOS	Muthu. B.	9W LED LIGHT 2NO'S CHANGED		Thamizhselvi. A. - Cardiothoracic ICU	23/11/2022
Comp. Dt. : 03/12/2022								
Status : Completed								
1257	22120109	CT-ICU ROOM-NEAR ORTHO OT RECOVERY ROOM	LED LIGHT NOT WORKING	Vijayaraghavan.B.	18W LED LIGHT REFIXING WORK PROBLEM SOLVED		Aswani. J. - Cardiothoracic ICU	06/12/2022
Comp. Dt. : 09/01/2023								
Status : Completed								
1258	23010357	CT-ICU ROOM-NEAR ORTHO OT RECOVERY ROOM	EXTENSION BOX NOT WORKING	Damodharan. V.	1.5SQ MM WIRE 3CORE 5TR CHANG & 6A 3PIN TOP 1NO CHANGED		Sadham Husain. S. - Cardiothoracic ICU	09/01/2023
Comp. Dt. : 22/02/2023								

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
1259	23020860	CT POW -SPECIAL WARD B	HEATER NOT WORKINGH	Manikandan. M.	WATER HEATER 1NO RESET WORK PROBLEM SOLVED		Rosaria Baska Rani - Cardiothoracic ICU	23/02/2023
Comp. Dt. : 24/02/2023								
Status : Completed								
1260	23020925	CT-POST OPERATIVE WARD IN 4TH FLOOR	HEATER NOT WORKING - IST ROOM	Muthu. B.	WATER HEATER 1NO RESET WORK PROBLEM SOLVED		Rosaria Baska Rani - Cardiothoracic ICU	27/02/2023
Comp. Dt. : 09/05/2023								
Status : Completed								
1261	23050361	CTVS - MALE PRE-OP ROOM INSIDE SPECIAL WARD B	HEATER NOT WORKING PRE-OP ROOM INSIDE SPECIAL WARD B & LUNG ROOM	Muthu. B.	WATER HEATER 1NO RESET WORK PROBLEM SOLVED		Rosaria Baska Rani - Cardiothoracic ICU	10/05/2023
Comp. Dt. : 27/05/2023								
Status : Completed								
1262	23051080	CT-ICU ROOM-NEAR ORTHO OT RECOVERY ROOM	NEED TO CHECK POWER	Vijayaraghavan.B.	MCB trip - Trip ON.		Sadham Husain. S. - Cardiothoracic ICU	27/05/2023
Comp. Dt. : 31/05/2023								
Status : Completed								
1263	23051262	CT-POST OPERATIVE WARD IN 4TH FLOOR	NEED TO CHECK AC - POWER PROBLEM - [MALE PRE OPP]	Dhakshinamoorthy. J	AC power point cheaked ok		Rosaria Baska Rani - Cardiothoracic ICU	01/06/2023
Comp. Dt. : 01/06/2023								
Status : Completed								
1264	23060041	CT-POST OPERATIVE WARD IN 4TH FLOOR	HEATER NOT WORKING ROOM NO B1 - B2	Manikandan. M.	WATER HEATER 1NO RESET WORK PROBLEM SOLVED		Aswani. J. - Cardiothoracic ICU	02/06/2023
Dept Name : Cardiothoracic POW - Electrical Maintenance								
Comp. Dt. : 13/06/2022								
Status : Completed								
1265	22060438	CT POW -SPECIAL WARD B	HEATER NOT WORKING - MALE PRE OPP RESTROOM	Dhakshinamoorthy. J	Heater reset - OK.		Jenifer Mary. P. - Cardiothoracic POW	14/06/2022
Comp. Dt. : 04/07/2022								
Status : Completed								
1266	22070079	CT-POST OPERATIVE WARD IN 4TH FLOOR	NEED TO CHANGE TUBELIGHT NOT WORKING IN POST OPP ROOM	Vijayaraghavan.B.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Jenifer Mary. P. - Cardiothoracic POW	04/07/2022
Comp. Dt. : 09/09/2022								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
1267	22090358	CT POW -SPECIAL WARD B	NEED TO REARRANGE SWITCH BOXS 2NOS - DAMAGE & BROKEN	Lakshmanan.V.	3M SWITCH BOARD SCREW REFIXING WORK PROBLEM SOLVED		Jenifer Mary. P. - Cardiothoracic POW	10/09/2022
Comp. Dt. : 17/09/2022								
Status : Completed								
1268	22090683	SPECIAL WARD---B	NEED TO CHECK ELECTRICAL ITEMS - FAN SLOW PROBLEM FOR ALL ROOMS	Manimaran. P.	FAN WIRE CUT RECONNECTION WORK & ALL ELECTRICAL ITEMS CHEKING WORK PROBLEM SOLVED		Jenifer Mary. P. - Cardiothoracic POW	19/09/2022
Comp. Dt. : 13/10/2022								
Status : Completed								
1269	22100377	CT POW -SPECIAL WARD B	HEATER [3NOS] NOT WORKING AT MALE & FEMALE PRE OPE ROOM & LUNG ROOM	Muthu. B.	WATER HEATER 5NO'S CHEKING WORK PROBLEM SOLVED		Jenifer Mary. P. - Cardiothoracic POW	13/10/2022
Comp. Dt. : 02/11/2022								
Status : Completed								
1270	22110011	CTVS-FEMALE PRE-OP ROOM INSIDE SPECIAL WARD B	1 TUBELIGHT NOT WORKING	Manikandan. M.	TUBE LIGHT 40W STARTER 1NO CHANGED		Srimathi. V. - Cardiothoracic POW	03/11/2022
Comp. Dt. : 27/12/2022								
Status : Completed								
1271	22121212	CT-ICU ROOM-NEAR ORTHO OT RECOVERY ROOM	-X-RAY LOBY WIRE GOT DAMAGED	Vengadessaperumal. K.	6A 3PIN TOP 1NO CHANGED		Nilavu. K. - Cardiothoracic POW	28/12/2022
Comp. Dt. : 05/01/2023								
Status : Completed								
1272	23010203	CT POW -SPECIAL WARD B	HEARER NOT WORKING	Dhakshinamoorthy. J	WATER HEATER 1NO RESET WORK PROBLEM SOLVED		Srimathi. V. - Cardiothoracic POW	06/01/2023
Comp. Dt. : 14/02/2023								
Status : Completed								
1273	23020520	CT-ICU ROOM-NEAR ORTHO OT RECOVERY ROOM	NEED TO CHECK SWITCH BOX - NOT WORKING	Lakshmanan.V.	6A SOCKET 1NO CHANGED		Nilavu. K. - Cardiothoracic POW	15/02/2023
Comp. Dt. : 16/02/2023								
Status : Completed								
1274	23020658	CT POW -SPECIAL WARD B	(1459) HEATER NOT WORKING	Lakshmanan.V.	WATER HEATER 1NO RESET WORK PROBLEM SOLVED		Sethiavani. A. - Cardiothoracic POW	17/02/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 20/02/2023 Status : Completed								
1275	23020763	CTVS	HEATER NOT WORKING	Vijayaraghavan.B.	WATER HEATER 1NO RESET WORK PROBLEM SOLVED		Srimathi. V. - Cardiothoracic POW	21/02/2023
Comp. Dt. : 13/05/2023 Status : Completed								
1276	23050529	CT-POST OPERATIVE WARD IN 4TH FLOOR	NEED CABLE ARRANGEMENTS	Damodharan. V.	Telephone dept complaint.		Srimathi. V. - Cardiothoracic POW	15/05/2023
Comp. Dt. : 06/06/2023 Status : Completed								
1277	23060181	CT POW -SPECIAL WARD B	HEATER NOT WORKING	Muthu. B.	WATER HEATER 1NO RESET WORK PROBLEM SOLVED		Praveena. M. - Cardiothoracic POW	07/06/2023
Comp. Dt. : 19/06/2023 Status : Completed								
1278	23060653	CT-POST OPERATIVE WARD IN 4TH FLOOR	HEATER NOT WORKING - NEED URGENT SERVICE	Suresh. V.	WATER HEATER NEW COIL 2KW 1NO CHANG & HEATER CHEKING WORK PROBLEM SOLVED		Praveena. M. - Cardiothoracic POW	19/06/2023
Dept Name : Cath Lab - Electrical Maintenance Comp. Dt. : 06/06/2022 Status : Completed								
1279	22060209	Cath Lab	NEED TO CHANGE TUBELIGHT	Vijayaraghavan.B.	TUBE LIGHT 40W STARTER 1NO CHANGED		Muthukumaran. S. - Cath Lab	07/06/2022
Comp. Dt. : 06/08/2022 Status : Completed								
1280	22080222	Cath Lab	NEED TO CHANGE TUBELIGHT	Manikandan. M.	18W 2PIN CFL LIGHT 2NO'S CHANGED		Muthukumaran. S. - Cath Lab	08/08/2022
Comp. Dt. : 25/05/2023 Status : Completed								
1281	23051015	Cath Lab	SEALING MACHINE NOT WORKING	Muthu. B.	NEW SEALING MACHINE COIL 1NO CHANG & CHEKING WORK PROBLEM SOLVED		Muthukumaran. S. - Cath Lab	25/05/2023
Dept Name : Civil - Execution - Electrical Maintenance Comp. Dt. : 26/05/2022 Status : Completed								
1282	22050997	Post Operative	NEED TO FIX FAN REGULATOR FOR III FLOOR POST OPERATIVE	Manikandan. M.	No complaints.		Sankala. P. - Civil - Execution	26/05/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 07/06/2022 Status : Completed								
1283	22060239	TAMILNADU MOTOR	Need to give 3 phase supply to run the motor	Vijayaraghavan.B.	SINGLE PHASE WIRE CUT REJOINTING WORK & MOTOR CHEKING WORK PROBLEM SOLVED		Murugan.N. - Civil - Execution	07/06/2022
Comp. Dt. : 23/06/2022 Status : Completed								
1284	22060858	Civil - Maintenance	NEED TO CHANGE TUBELIGHT [2 NOS]	Manimaran. P.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Surendhiran. R. - Civil - Execution	24/06/2022
Comp. Dt. : 20/07/2022 Status : Completed								
1285	22070735	Civil - Execution	NEED TO CHANGE TUBELIGHT FOR MURUGAN SIR ROOM	Lakshmanan.V.	36W TUBE LIGHT 1NO CHANGED		Surendhiran. R. - Civil - Execution	21/07/2022
Comp. Dt. : 29/10/2022 Status : Completed								
1286	22100947	COMMERCIAL BLOCK	GROUND FLOOR COMMON RESTROOM TUBELIGHT NOT WORKING	Srinivasan. R.	36W TUBE LIGHT 2NO'S CHANG & 40W STARTER 1NO CHANED		Surendhiran. R. - Civil - Execution	31/10/2022
Comp. Dt. : 14/02/2023 Status : Completed								
1287	23020526	Civil - Execution	NEED TO CHANGE TUBELIGHT	Rajan. R.	36W TUBE LIGHT 1NO CHANGED		Murugan.N. - Civil - Execution	14/02/2023
1288	23020539	COMMERCIAL BLOCK	TUBE LIGHT NOT WORKING AT 1ST FLOOR STAFF CANTEEN	Rajan. R.	36W TUBE LIGHT 1NO CHANGED		Surendhiran. R. - Civil - Execution	14/02/2023
Dept Name : Civil - Maintenance - Electrical Maintenance Comp. Dt. : 02/05/2022 Status : Completed								
1289	22050005	Female Medical - Ward 307	NED TO CHANGE TUBELIGHT FOR RESTROOM	Muthu. B.	36W TUBE LIGHT 1NO CHANGED		Prakash. V. - Civil - Maintenance	09/05/2022
1290	22050010	OLD STP PLANT	NEED CONNECTION WORK FOR 7.5 HB MOTOR CABLE	Srinivasan. R.	7.5HP MOTOR LINE CONNECTION WORK PROBLEM SOLVED		Ranganathan. K. - Civil - Maintenance	05/05/2022
Comp. Dt. : 10/05/2022 Status : Completed								
1291	22050319	NEW STP	LOW VOLTAGE 370	Srinivasan. R.	SETTING CHANG & CHEKING WORK PROBLEM SOLVED		Ranganathan. K. - Civil - Maintenance	12/05/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 16/05/2022								
Status : Completed								
1292	22050538	NEW STP	TUBELIGHT & FOCUS LIGHT [LED] 3NOS NOT WORKING	Srinivasan. R.	36W TUBE LIGHT FITTING 2NO'S FIXING WORK PROBLEM SOLVED		Ranganathan. K. - Civil - Maintenance	20/05/2022
1293	22050545	Animal House	NEED MOTOR CONNECTION WORK	Muthu. B.	1HP MOTOR LINE CONNECTION WORK PROBLEM SOLVED		Gurunathan. V. - Civil - Maintenance	16/05/2022
Comp. Dt. : 17/05/2022								
Status : Completed								
1294	22050621	NEW STP	NEED TO DISCONNECT MOTOR FROM NEW STP & RECONNECTED TO OLD ANIMAL HOUSE	Muthu. B.	2HP MOTOR LINE DISCONNECTION WORK & ANIMAL HOUSE LINE CONNECTION WORK PROBLEM SOLVED		Gurunathan. V. - Civil - Maintenance	17/05/2022
Comp. Dt. : 21/05/2022								
Status : Completed								
1295	22050786	NEW STP	NEED 2 HB MOTOR CABLE CONNECTION	Lakshmanan.V.	2HP MOTOR LINE CONNECTION WORK PROBLEM SOLVED		Ranganathan. K. - Civil - Maintenance	23/05/2022
Comp. Dt. : 31/05/2022								
Status : Completed								
1296	22051117	OLD STP PLANT	NEED TO CHANGE TUBELIGHT 2NOS	Dhakshinamoorthy. J	36W TUBE LIGHT 2NO'S CHANG & 40W STARTER 1NO CHANGED		Ranganathan. K. - Civil - Maintenance	01/06/2022
Comp. Dt. : 22/06/2022								
Status : Completed								
1297	22060798	Boys hostel	NEED TO CHANGE TUBELIGHT FOR AURO WATER PLANT	Vijayaraghavan.B.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Sankar. V. - Civil - Maintenance	23/06/2022
1298	22060802	Boys hostel	CABLE BURNED AT BOYS HOSTEL BACK SIDE	Vijayaraghavan.B.	CABLE SINGLE PHASE CUT RECONNECTION WORK PROBLEM SOLVED		Raja. V. - Civil - Maintenance	23/06/2022
Comp. Dt. : 02/07/2022								
Status : Completed								
1299	22070051	NEW STP	SEWAGE PUMP MOTOR CABLE DAMAGE	Dhakshinamoorthy. J	SEWAGE PUMP MOTOR CABLE RECONNECTION WORK PROBLEM SOLVED		Ranganathan. K. - Civil - Maintenance	05/07/2022
Comp. Dt. : 04/07/2022								
Status : Completed								
1300	22070077	NEW STP	SEWAGE PUMP 7.5 Hp MOTOR NOT WORKING	Dhakshinamoorthy. J	Coil Lead wire problem Problem solved - Motor checked ok.		Ranganathan. K. - Civil - Maintenance	07/07/2022

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHAL KUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1301	22070093	Civil - Maintenance	NEED SWITCH BOX & 10 MM 3 CORE WIRE BOX	Vengadessaperumal. K.	3M EXECTION BOX SET 1NO & 6MTR WIRE,6A 3PIN TOP 1NO CHANGED		Prakash. V. - Civil - Maintenance	04/07/2022
Comp. Dt. : 07/07/2022 Status : Completed								
1302	22070260	NEW STP	TORCH LIGHT NOT WORKING	Sridharan. R	Torch light serviced - Ok		Ranganathan. K. - Civil - Maintenance	08/07/2022
Comp. Dt. : 08/07/2022 Status : Completed								
1303	22070348	NEW STP	NEED - SEWAGE PUMP MOTOR CONNECTION	Dhakshinamoorthy. J	7.5HP MOTOR LINE CONNECTION WORK PROBLEM SOLVED		Ranganathan. K. - Civil - Maintenance	11/07/2022
Comp. Dt. : 15/07/2022 Status : Completed								
1304	22070615	OLD STP PLANT	PROBLEM IN SEWAGE PUMP 10 HP MOTOR - TRIPPED	Muthu. B.	10HP MOTOR CHEKING WORK BEARING SOUND & PUMP SIDE PROBLEM		Ranganathan. K. - Civil - Maintenance	18/07/2022
Comp. Dt. : 01/08/2022 Status : Completed								
1305	22080015	Hospital	MOTOR NOT WORKING	Dhakshinamoorthy. J	STARTER SERVICE WORK & CHEKING WORK PROBLEM SOLVED		Raja. V. - Civil - Maintenance	02/08/2022
Comp. Dt. : 08/08/2022 Status : Completed								
1306	22080287	NEW STP	NEED - SEWAGE PUMP 7.5 HP CABLE DISCONNECT	Lakshmanan.V.	7.5HP MOTOR LINE DISCONNECT WORK PROBLEM SOLVED		Ranganathan. K. - Civil - Maintenance	09/08/2022
Comp. Dt. : 26/08/2022 Status : Completed								
1307	22080909	NEW STP	NEED TO CHANGE TUBELIGHT	Muthu. B.	TUBE LIGHT 40W STARTER 1NO CHANGED		Ranganathan. K. - Civil - Maintenance	29/08/2022
Comp. Dt. : 30/08/2022 Status : Completed								
1308	22081042	NEW STP	NEED CONNECTION WORK FOR 7.5 HP SEWAGE PUMP	Lakshmanan.V.	7.5HP MOTOR LINE CONNECTION WORK PROBLEM SOLVED		Ranganathan. K. - Civil - Maintenance	02/09/2022
Comp. Dt. : 20/09/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1309	22090791	Hospital	NEED TO CHANGE TUBELIGHT FOR SUMP HOUSE BACK SIDE , BOYS HOSTEL BACKSIDE &PHASE I BACK SIDE TOTAL 3	Lakshmanan.V.	TUBE LIGHT SIDE HOLDER 2NO'S CHANG & 40W STARTER 1NO CHANGED		Raja. V. - Civil - Maintenance	21/09/2022
		Comp. Dt. : 22/09/2022 Status : Completed						
1310	22090904	OLD STP PLANT	PROBLEM IN 10 HP MOTOR	Lakshmanan.V.	UNSIZE FAN AVAILAIBLE NEW FAN ORDERED		Ranganathan. K. - Civil - Maintenance	11/10/2022
		Comp. Dt. : 27/09/2022 Status : Completed						
1311	22091082	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	NEED TO CHECK MOTOR - TRIP PROBLEM AT SPECIAL CLINIC OPPOSITE DINING HALL	Lakshmanan.V.	1HP MOTOR SERVICE & CLEANING WORK PROBLEM SOLVED		Prakash. V. - Civil - Maintenance	29/09/2022
		Comp. Dt. : 11/10/2022 Status : Completed						
1312	22100304	Animal House	NEED 2 HP MOTOR CABLE CONNECTION WORK - ANIMAL HOUSE AREA	Dhakshinamoorthy. J	2HP MOTOR LINE CONNECTION WORK PROBLEM SOLVED		Ranganathan. K. - Civil - Maintenance	12/10/2022
		Comp. Dt. : 19/10/2022 Status : Completed						
1313	22100647	A- QUARTERS	MOTOR NOT WORKING	Lakshmanan.V.	MOTOR CHEKING WORK PROBLEM SOLVED		Murugan. R. - Civil - Maintenance	20/10/2022
		Comp. Dt. : 25/10/2022 Status : Completed						
1314	22100765	Animal House	MOTOR NOT WORKING	Muthu. B.	2HP MOTOR LINE CONNECTION WORK PROBLEM SOLVED		Kaliyamoorthy. A. - Civil - Maintenance	25/10/2022
		Comp. Dt. : 27/10/2022 Status : Completed						
1315	22100873	OLD STP PLANT	1 TUBELIGHT NOT WORKING	Muthu. B.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Kaliyamoorthy. A. - Civil - Maintenance	29/10/2022
		Comp. Dt. : 10/11/2022 Status : Completed						
1316	22110394	Male Surgery - Ward 201	WATER HEATER TEMPERATURE NOT WORKING	Muthu. B.	WATER HEATER 1NO SERVICE WORK & HEATER REFIXING WORK PROBLEM SOLVED		Manikandan. S. - Civil - Maintenance	22/11/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 16/11/2022								
Status : Completed								
1317	22110690	GARDEN STORE ROOM	1 TUBELIGHT NOT WORKING	Thillaikumar. R.	TUBW LIGHT 40W STARTER 1NO CHANGED		Kumar. V. - Civil - Maintenance	17/11/2022
Comp. Dt. : 01/12/2022								
Status : Completed								
1318	22120027	JR Quarters	NEED TO CHANGE TUBELIGHT 2 NOS FOR GROUND FLOOR	Lakshmanan.V.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Raja. V. - Civil - Maintenance	03/12/2022
1319	22120028	HOSPITAL SHUMP	NEED TO CHANGE TUBELIGHT 1 NO	Muthu. B.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Raja. V. - Civil - Maintenance	02/12/2022
Comp. Dt. : 07/12/2022								
Status : Completed								
1320	22120297	NEW STP	FILTER FEED PUMP MOTOR PROBLEM	Dhakshinamoorthy. J	FEED PUMP MOTOR WIRE LOOSE RECONNECTION WORK PROBLEM SOLVED		Ranganathan. K. - Civil - Maintenance	08/12/2022
Comp. Dt. : 09/12/2022								
Status : Completed								
1321	22120436	GARDEN STORE ROOM	NEED TO CHANGE TUBELIGHT	Rajan. R.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Kumar. V. - Civil - Maintenance	10/12/2022
Comp. Dt. : 10/12/2022								
Status : Completed								
1322	22120472	HOSPITAL SHUMP	NEED TO CHECK POWER	Rajan. R.	POWER LINE CHEKING WORK NO PROBLEM		Prakash. V. - Civil - Maintenance	13/12/2022
Comp. Dt. : 14/12/2022								
Status : Completed								
1323	22120656	B-QUARTERS	R O MOTOR NOT WORKING	Manikandan. M.	RO MOTOR SEAIL CAPACITOR & BACK COVER & LEATH WORK MOTOR CHEKING WORK PROBLEM SOLVED		Sankar. R - Civil - Maintenance	03/01/2023
Comp. Dt. : 20/12/2022								
Status : Completed								
1324	22120902	OLD STP PLANT	2HB WATER CABLE DAMAGE NEED TO REFIX	Lakshmanan.V.	2HP MOTOR LINE CONNECTION WORK PROBLEM SOLVED		Ranganathan. K. - Civil - Maintenance	21/12/2022
Comp. Dt. : 26/12/2022								
Status : Completed								
1325	22121171	NEW STP	EXHAUST FAN NOT WORKING	Muthu. B.	EXHAUST FAN SERVICE WORK PROBLEM SOLVED		Kaliyamoorthy. A. - Civil - Maintenance	27/12/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 07/01/2023 Status : Completed								
1326	23010306	OLD STP PLANT	2HP MOTOR CABLE GOT DISCONNECTED	Muthu. B.	2HP MOTOR LINE DISCONNECTED WORK PROBLEM SOLVED		Ranganathan. K. - Civil - Maintenance	07/01/2023
Comp. Dt. : 09/01/2023 Status : Completed								
1327	23010368	NEW STP	7.5 HP MOTOR CABLE CONNECTION WORK	Srinivasan. R.	7.5HP MOTOR LINE CONNECTION WORK PROBLEM SOLVED		Ranganathan. K. - Civil - Maintenance	10/01/2023
Comp. Dt. : 12/01/2023 Status : Completed								
1328	23010538	NEW STP	2HD MOTOR CABLE CONNECTION REFIX	Muthu. B.	2HP MOTOR LINE CONNECTION WORK PROBLEM SOLVED		Ranganathan. K. - Civil - Maintenance	13/01/2023
Comp. Dt. : 25/01/2023 Status : Completed								
1329	23010895	NEW STP	TRIP PROBLEM - NEED TO CHECK GARDEN PUMP	Dhakshinamoorthy. J	7.5HP MOTOR LINE DISCONNECTION WORK PROBLEM SOLVED		Ranganathan. K. - Civil - Maintenance	30/01/2023
Comp. Dt. : 27/01/2023 Status : Completed								
1330	23010988	NEW STP	7.5 HP MOTOR CABLE CONNECTION WORK NEED TO DO	Muthu. B.	7.5HP MOTOR LINE CONNECTION WORK PROBLEM SOLVED		Ranganathan. K. - Civil - Maintenance	30/01/2023
Comp. Dt. : 31/01/2023 Status : Completed								
1331	23011118	NEW STP	TREATED MOTOR PUM - TRIP PROBLEM	Muthu. B.	STARTER RELAY SETTING CHANGE & MOTOR CHECKING WORK PROBLEM SOLVED		Ranganathan. K. - Civil - Maintenance	01/02/2023
Comp. Dt. : 07/02/2023 Status : Completed								
1332	23020246	SPECIAL WARD---B	FAN NOT WORKING - B1-B2 - B3	Vijayaraghavan.B.	CEILING FAN CAPACITOR 2.5MFT 1NO CHANGED		Lester. Rodgers - Civil - Maintenance	07/02/2023
1333	23020251	LIFT 5	DUE TO HANDLING PUMP - NEAR ROOM FOR LIFT NO 5 NEED TO FIX LED LIGHT	Muthu. B.	9W LED LIGHT 1NO CHANGED		Kannan. V. - Civil - Maintenance	13/02/2023
Comp. Dt. : 24/02/2023 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1334	23020934	OSD	NEED TO CHANGE PLUG POINT - OSD OFFICE ROOM	Vengadessaperumal. K.	Need To 6/16A Soket and 3pin Top 6A Changed		Lester. Rodgers - Civil - Maintenance	24/02/2023
		Comp. Dt. : 28/02/2023 Status : Completed						
1335	23021058	NEW STP	SLUDGE PUMP TERMINAL BOX PROBLEM	Dhakshinamoorthy. J	NEW CONECTOR 1NO CHANG & LINE CONNECTION WORK PROBLEM SOLVED		Ranganathan. K. - Civil - Maintenance	09/03/2023
		Comp. Dt. : 10/03/2023 Status : Completed						
1336	23030411	NEW STP	NEED MOTOR CABLE CONNECTION WORK FOR SEWAGE PUMP 7.5 HB	Muthu. B.	3PHASE 7.5HP MOTOR LINE CONNECTION WORK PROBLEM SOLVED		Ranganathan. K. - Civil - Maintenance	11/03/2023
		Comp. Dt. : 24/03/2023 Status : Completed						
1337	23030999	NEW STP	NEED 5 HP SLUDGE PUMP WATER CONNECTION	Dhakshinamoorthy. J	Motor line connected.		Ranganathan. K. - Civil - Maintenance	24/03/2023
		Comp. Dt. : 03/04/2023 Status : Completed						
1338	23040036	Civil - Maintenance	NEED TO CHANGE TUBELIGHT	Manimaran. M.	36W tube light 1no changed.		Lester. Rodgers - Civil - Maintenance	04/04/2023
1339	23040038	RO Plant	NEED TO CHECK MOTOR WIRE CONNECTION AT OLD RO PLANT.	Dhakshinamoorthy. J	RO Motor line connected.		Gurunathan. V. - Civil - Maintenance	04/04/2023
		Comp. Dt. : 04/04/2023 Status : Completed						
1340	23040139	NEW STP	TREATED WATER MOTOR PUMP TRIP	Srinivasan. R.	starter problem. Starter kit serviced - tested ok.		Ranganathan. K. - Civil - Maintenance	08/04/2023
		Comp. Dt. : 15/04/2023 Status : Completed						
1341	23040437	NEW STP	SLUDGE MOTOR TRIP	Dhakshinamoorthy. J	5HP MOTOR 1NO REWINDING WORK & MOTOR LINE CONNECTION WORK PROBLEM SOLVED		Ranganathan. K. - Civil - Maintenance	04/05/2023
		Comp. Dt. : 27/04/2023 Status : Completed						
1342	23040897	NEW STP	NEED TO CHANGE TUBELIGHT 3 NOS FOR OLD & NEW STP	Manimaran. P.	36W TUBE LIGHT 2NO'S CHANG & 40W STARTER 2NO'S CHANGED		Ranganathan. K. - Civil - Maintenance	03/05/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 05/05/2023 Status : Completed								
1343	23050185	NEW STP	NEED 5 HP FLANGE MOTOR CONNECTION WORK	Muthu. B.	5HP MOTOR LINE CONNECTION WORK PROBLEM SOLVED		Ranganathan. K. - Civil - Maintenance	08/05/2023
Comp. Dt. : 06/05/2023 Status : Completed								
1344	23050250	NEW STP	IN FIRE EXTINGUISHER CYLINDER, SCREW LOOSE - NEED TO REFIT	Muthu. B.	FIRE EXTINGUISHER CYLINDER CLAMP 1NO REFIXING WORK PROBLEM SOLVED		Ranganathan. K. - Civil - Maintenance	09/05/2023
Comp. Dt. : 12/05/2023 Status : Completed								
1345	23050520	OLD STP PLANT	NEED TO CHECK FAN-BEARING SOUND, SLOW PROBLEM	Dhakshinamoorthy. J	Clamp problem - New clamp fixed.		Ranganathan. K. - Civil - Maintenance	15/05/2023
Comp. Dt. : 26/05/2023 Status : Completed								
1346	23051061	NEW STP	EXHAUST FAN NOT WORKING	Muthu. B.	EXHAUST FAN 1NO COIL FAULT REMOVING TO ELECTRICAL ROOM		Ranganathan. K. - Civil - Maintenance	29/05/2023
Comp. Dt. : 27/05/2023 Status : Completed								
1347	23051073	OLD STP PLANT	NEED 7.5 HP SEWAGE MOTOR CABLE CONNECTION	Vijayaraghavan.B.	Motor line connected.		Ranganathan. K. - Civil - Maintenance	27/05/2023
Comp. Dt. : 13/06/2023 Status : Completed								
1348	23060433	OLD STP PLANT	SEWAGE PUMP 10 HP MOTOR - PROBLEM	Dhakshinamoorthy. J	10HP MOTOR REWINDING WORK & BEARING 2NO'S CHANG & MOTOR LINE CONNECTION WORK PROBLEM SOLVED		Ranganathan. K. - Civil - Maintenance	05/07/2023
Comp. Dt. : 21/06/2023 Status : Completed								
1349	23060758	NEW STP	PROBLEM IN WATER FLOW METER STABILIZER - NOT WORKING	Vengadessaperumal. K.	.5kva ups battery 12V 7AH changed.		Ranganathan. K. - Civil - Maintenance	15/07/2023
Comp. Dt. : 22/06/2023 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1350	23060823	Animal House	NEED TO CHECK TUBELIGHT AT SEWAGE PUMPING AREA NEAR ANIMAL HOUSE	Lakshmanan.V.	36W TUBE LIGHT 1NO CHANGED		Ranganathan. K. - Civil - Maintenance	23/06/2023
Comp. Dt. : 24/06/2023 Status : Completed								
1351	23060909	TAMILNADU MOTOR	NEED TO CHANGE TUBELIGHT FOR ENTRANCE	Manimaran. P.	36W TUBE LIGHT 1NO CHANG & SIDE HOLDER 2NO'S CHANGED		Raja. V. - Civil - Maintenance	26/06/2023
Comp. Dt. : 26/06/2023 Status : Completed								
1352	23060955	NEW STP	2 H B MOTOR CABLE DAMAGE	Dhakshinamoorthy. J	2HP MOTOR WIRE CUT RECONNECTION WORK PROBLEM SOLVED		Ranganathan. K. - Civil - Maintenance	27/06/2023
Comp. Dt. : 27/06/2023 Status : Completed								
1353	23061038	NEW STP	TREATED WATER MOTOR UBNORMAL SOUND	Lakshmanan.V.	TREATED WATER MOTOR SOUND CHEKING WORK NO PROBLEM		Ranganathan. K. - Civil - Maintenance	30/06/2023
Comp. Dt. : 28/06/2023 Status : Completed								
1354	23061064	NEW STP	5 PIN HOLDER [2 NOS] & ON -OFF LIGHTING SWITCH 4NOS NOT WORKING	Suresh. V.	6A SWITCH 2NO'S CHANGED		Ranganathan. K. - Civil - Maintenance	30/06/2023
1355	23061086	NEW STP	SEWAGE PUMP 7.5 MOTOR CABLE CONNECTION	Suresh. V.	7.5HP MOTOR LINE DISCONNECTION WORK PROBLEM SOLVED		Ranganathan. K. - Civil - Maintenance	30/06/2023
Dept Name : Clinical Department - Electrical Maintenance Comp. Dt. : 02/05/2022 Status : Completed								
1356	22050041	CLINICAL DEPARTMENT IN 4th FLOOR	FAN NOT WORKING IN OPHTHAL HOD ROOM NO 6	Vijayaraghavan.B.	CEILING FAN CAPACITOR 2.5MFT 1NO CHANGED		Patchammal. K. - Clinical Department	12/05/2022
Comp. Dt. : 10/05/2022 Status : Completed								
1357	22050326	CLINICAL DEPARTMENT IN 2ND FLOOR	NEED TO CHANGE TUBELIGHT FOR SEMINOR ROOM	Muthu. B.	T5 14W LIGHT 2NO'S CHANGED		Vidhyavathi. S. - Clinical Department	12/05/2022
Comp. Dt. : 16/05/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1358	22050556	CLINICAL DEPARTMENT IN 3RD FLOOR	NEED TO CHANGE TUBELIGHT FOR ROOM NO 5	Muthu. B.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Balakrishnan. S. - BIOCHEMISTRY	17/05/2022
	Comp. Dt. :	25/05/2022						
	Status :	Completed						
1359	22050927	CLINICAL DEPARTMENT IN 3RD FLOOR	NEED TO CHANGE TUBELIGHT FOR CARITOR	Manimaran. P.	36W Tube light 1no changed.		Manimegalai. M. - Clinical Department	26/05/2022
	Comp. Dt. :	06/06/2022						
	Status :	Completed						
1360	22060219	CLINICAL DEPARTMENT IN 2ND FLOOR	NEED TO CHANGE C F L LIGHT FOR RESTROOM - ROOM NO 5	Vijayaraghavan.B.	9W LED LIGHT 1NO CHANGED		Kheerthikaa. V. - Clinical Department	07/06/2022
	Comp. Dt. :	07/06/2022						
	Status :	Completed						
1361	22060238	CLINICAL DEPARTMENT IN 4th FLOOR	NEED SEPARATE CONNECTION FOR LIGHT & PLUGPOINT	Rajan. R.	6A SWITCH 1NO CHANGED		Vimal. P. - Clinical Department	07/06/2022
	Comp. Dt. :	15/06/2022						
	Status :	Completed						
1362	22060561	CLINICAL DEPARTMENT IN 2ND FLOOR	NEED TO CHANGE LED LIGHT FOR SEMINOR ROOM	Manikandan. M.	T5 14W TUBE LIGHT 2NO'S CHANGED		Vidhyavathi. S. - Clinical Department	15/06/2022
	Comp. Dt. :	22/06/2022						
	Status :	Completed						
1363	22060776	CLINICAL DEPARTMENT IN 2ND FLOOR	NEED TO CHANGE TUBELIGHT - ROOM NO 3 RIGHT SIDE	Suresh. V.	36W TUBE LIGHT 1NO CHANGED		Kheerthikaa. V. - Clinical Department	22/06/2022
	Comp. Dt. :	28/06/2022						
	Status :	Completed						
1364	22061028	CLINICAL DEPARTMENT IN 2ND FLOOR	NEED TO CHANGE TUBELIGHT FOR DEAN ACADEMIC OFFICE SEMINOR ROOM	Rajan. R.	T5 14W LIGHT 2NO'S CHANGED		Vidhyavathi. S. - Clinical Department	29/06/2022
	Comp. Dt. :	08/07/2022						
	Status :	Completed						
1365	22070317	CLINICAL DEPARTMENT IN 2ND FLOOR	NEED TO CHECK SWITCH - SPARK - ROOM NO 3	Manimaran. P.	6A SWITCH WIRE LOOSE RECONNECTION WORK PROBLEM SOLVED		Vidhyavathi. S. - Clinical Department	11/07/2022
	Comp. Dt. :	20/07/2022						
	Status :	Completed						


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1366	22070740	CLINICAL DEPARTMENT IN 2ND FLOOR	NEED TO CHANGE TUBELIGHT FOR DEAN ACADEMIC SIR ROOM [LEFT SIDE ROOM NO 3] & SEMINOR ROOM [SMA	Rajan. R.	T5 14W LIGHT 3NO'S CHANGED		Kheerthikaa. V. - Clinical Department	21/07/2022
Comp. Dt. : 23/07/2022 Status : Completed								
1367	22070876	CLINICAL DEPARTMENT IN 2ND FLOOR	NEED TO CHECK POWER	Vijayaraghavan.B.	T5 14W LIGHT 2NO'S CHANGED		Kheerthikaa. V. - Clinical Department	26/07/2022
Comp. Dt. : 05/08/2022 Status : Completed								
1368	22080205	CLINICAL DEPARTMENT IN 4th FLOOR	NEED TO CHANGE RESTROOM [KUNDU BULB] FOR ROOM NO 3	Suresh. V.	9W LED LIGHT 1NO CHANGED		Patchammal. K. - Clinical Department	08/08/2022
Comp. Dt. : 09/09/2022 Status : Completed								
1369	22090363	CLINICAL DEPARTMENT IN 2ND FLOOR	NEED TO CHANGE TUBELIGHT FOR RECEPTION	Lakshmanan.V.	36W TUBE LIGHT 1NO CHANGED		Vidhyavathi. S. - Clinical Department	10/09/2022
Comp. Dt. : 08/10/2022 Status : Completed								
1370	22100183	CLINICAL DEPARTMENT IN 4th FLOOR	SWITCH BOARD NOT WORKING	Muthu. B.	SWITCH BOARD SCREW LOOSE REFIXING WORK PROBLEM SOLVED		Patchammal. K. - Clinical Department	10/10/2022
Comp. Dt. : 26/10/2022 Status : Completed								
1371	22100817	CLINICAL DEPARTMENT IN 2ND FLOOR	ROOM NO-6,PLUG POINT NOT WORKING	Lakshmanan.V.	MCB TRIP ON TO WORK PROBLEM SOLVED		Kheerthikaa. V. - Clinical Department	27/10/2022
Comp. Dt. : 28/10/2022 Status : Completed								
1372	22100916	CLINICAL DEPARTMENT IN 2ND FLOOR	IN ROOM NO.7 CHANGE 1 LED BULB AND ROOM NO.3 CHANGE 1 TUBELIGHT	Dhakshinamoorthy. J	9W LED LIGHT 1NO CHANG & 36W TUBE LIGHT 1NO CHANGED		Kheerthikaa. V. - Clinical Department	31/10/2022
Comp. Dt. : 04/11/2022 Status : Completed								
1373	22110123	CLINICAL DEPARTMENT IN 2ND FLOOR	IN LEFT SIDE-1 TUBELIGHT NOT WORKING	Srinivasan. R.	TUBE LIGHT 40W STARTER 1NO CHANGED		Vidhyavathi. S. - Clinical Department	05/11/2022
Comp. Dt. : 29/11/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1374	22111244	CLINICAL DEPARTMENT IN 2ND FLOOR	IN ROOM NO.4 PLUG POINT NEED TO BE FIX NEWLY	Muthu. B.	PLUG POINT CHEKING WORK PROBLEM SOLVED		Kheerthikaa. V. - Clinical Department	01/12/2022
Comp. Dt. : 01/12/2022 Status : Completed								
1375	22120041	CLINICAL DEPARTMENT IN 2ND FLOOR	NEED TO CHECK PLUG POINT - NOT WORKING AT ROOM NO. 6 (RIGHT SIDE)	Vijayaraghavan.B.	PLUG POINT SCREW REFIXING WORK PROBLEM SOLVED		Kheerthikaa. V. - Clinical Department	03/12/2022
Comp. Dt. : 12/12/2022 Status : Completed								
1376	22120520	PSYCHIATRY OPD	1 TUBELIGHT NOT WORKING	Muthu. B.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Parasuraman. R. - Medical Records	13/12/2022
Comp. Dt. : 02/01/2023 Status : Completed								
1377	23010038	CLINICAL DEPARTMENT IN 2ND FLOOR	IN ROOM NO.3 AND SEMINAR ROOM-TUBELIGHT NEED TO BE CHANGE	Muthu. B.	TUBE LIGHT 40W STARTER 1NO CHANGED		Kheerthikaa. V. - Clinical Department	03/01/2023
Comp. Dt. : 24/02/2023 Status : Completed								
1378	23020938	CLINICAL DEPARTMENT IN 4th FLOOR	NEED TO REFIX SWITCH BOARD - ROOM NO 7	Vijayaraghavan.B.	SWITCH BOARD SCREW REFIXING WORK PROBLEM SOLVED		Vimal. P. - Clinical Department	28/02/2023
Comp. Dt. : 01/03/2023 Status : Completed								
1379	23030015	CLINICAL DEPARTMENT IN 2ND FLOOR	CORRIDOR TUBELIGHT NOT WORKING	Vijayaraghavan.B.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Vijayalakshmi.N - Clinical Department	02/03/2023
Comp. Dt. : 02/03/2023 Status : Completed								
1380	23030065	CLINICAL DEPARTMENT IN 4th FLOOR	POWER SOCKET NOT WORKING	Srinivasan. R.	6A SOCKET 1NO CHANGED		Sasireka. A. - Clinical Department	04/03/2023
Comp. Dt. : 06/03/2023 Status : Completed								
1381	23030195	CLINICAL DEPARTMENT IN 2ND FLOOR	NEED TO CHANGE TUBELIGHT FOR CARITOR	Damodharan. V.	36W TUBE LIGHT 1NO CHANGED		Vijayalakshmi.N - Clinical Department	07/03/2023
Comp. Dt. : 08/03/2023 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1382	23030330	CLINICAL DEPARTMENT IN 2ND FLOOR	NEED TO CHANGE TUBELIGHT FOR ENTRANCE	Manimaran. P.	36W tube light 1no & starter 1no changed.		Vidhyavathi. S. - Clinical Department	10/03/2023
Comp. Dt. : 14/03/2023 Status : Completed								
1383	23030530	CLINICAL DEPARTMENT IN 2ND FLOOR	NEED TO CHANGE TUBELIGHT 2NOS FOR ROOM NO 3 & 6	Rajan. R.	TUBE LIGHT 40W STARTER 2NO'S CHANGED		Vidhyavathi. S. - Clinical Department	15/03/2023
Comp. Dt. : 16/04/2023 Status : Completed								
1384	23040472	CLINICAL DEPARTMENT IN 2ND FLOOR	NEED TO CHANGE CEILING LIGHT - ROOM NO 1	Muthu. B.	36W CFL LIGHT FITTING 1NO CHANGED		Vidhyavathi. S. - Clinical Department	17/04/2023
Comp. Dt. : 19/04/2023 Status : Completed								
1385	23040594	CLINICAL DEPARTMENT IN 2ND FLOOR	FAN SLOW PROBLEM AT RECEPTION	Dhakshinamoorthy. J	CEILING FAN CAPACITOR 2.5MFT 1NO CHANGED		Vijayalakshmi.N - Clinical Department	20/04/2023
Comp. Dt. : 25/04/2023 Status : Completed								
1386	23040824	CLINICAL DEPARTMENT IN 3RD FLOOR	FAN NOT WORKING - ROOM NO 3 RIGHT SIDE	Rajan. R.	CEILING FAN CAPACITOR 2.5MFT 1NO CHANGED		Manimegalai. M. - Clinical Department	27/04/2023
Comp. Dt. : 27/04/2023 Status : Completed								
1387	23040901	CLINICAL DEPARTMENT IN 3RD FLOOR	NEED TO CHANGE TUBELIGHT FOR ROOM NO 3 [RIGHT SIDE]	Rajan. R.	36W TUBE LIGHT 1NO CANGED		Bhuvana.M. - Clinical Department	28/04/2023
Comp. Dt. : 29/04/2023 Status : Completed								
1388	23040994	CLINICAL DEPARTMENT IN 3RD FLOOR	TRIP PROBLEM	Vijayaraghavan.B.	MCB TRIP ON TO WORK PROBLEM SOLVED		Sangeetha. C. - Clinical Department	02/05/2023
Comp. Dt. : 05/05/2023 Status : Completed								
1389	23050204	CLINICAL DEPARTMENT IN 2ND FLOOR	TRIP PROBLEM - AC NOT WORKING IN SEMINOR ROOM	Rajan. R.	MCB TRIP ON TO WORK PROBLEM SOLVED		Shuruthi. B. - Clinical Department	06/05/2023
Comp. Dt. : 08/05/2023 Status : Completed								
1390	23050299	CLINICAL DEPARTMENT IN 3RD FLOOR	NEED TO CHANGE TUBELIGHT FOR ROOM NO 7	Rajan. R.	TUBE LIGHT 40W STARTER 1NO CHANGED		Vidhyavathi. S. - Clinical Department	09/05/2023

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 23/05/2023 Status : Completed								
1391	23050925	CLINICAL DEPARTMENT IN 3RD FLOOR	FAN NOT WORKING - ROOM NO 2	Vijayaraghavan.B.	CEILING FAN CAPACITOR 2.5MFT 1NO CHANGED		Bhuvana.M. - Clinical Department	24/05/2023
Comp. Dt. : 24/05/2023 Status : Completed								
1392	23050956	CLINICAL DEPARTMENT IN 4th FLOOR	FAN SLOW PROBLEM AT RECEPTION	Manimaran. P.	CEILING FAN CAPACITOR 2.5MFT 1NO CHANGED		Sasireka. A. - Clinical Department	25/05/2023
Comp. Dt. : 21/06/2023 Status : Completed								
1393	23060780	CLINICAL DEPARTMENT IN 3RD FLOOR	FAN NOT WORKING -ROOM NO 5	Vengadessaperumal. K.	CEILING FAN CAPACITOR 2.5MFT 1NO CHANGED		Selvi. A. - Clinical Department	22/06/2023
Dept Name : CLINICAL PATHOLOGY - Electrical Maintenance Comp. Dt. : 09/05/2022 Status : Completed								
1394	22050247	Clinical Pathology	NEED TO CHANGE TUBE LIGHT	Muthu. B.	36W TUBE LIGHT SET 1NO REFIXING WORK PROBLEM SOLVED		Vinod Gnana Kumar. D. - CLINICAL PATHOLOGY	12/05/2022
Comp. Dt. : 08/06/2022 Status : Completed								
1395	22060281	Clinical Pathology	NEED TO CHANGE TUBELIGHT	Suresh. V.	TUBE LIGHT 36W CHOKE 1NO CHANGED		Arulvizhi. K. - CLINICAL PATHOLOGY	08/06/2022
Comp. Dt. : 19/07/2022 Status : Completed								
1396	22070685	Clinical Pathology	NEED TO CHANGE TUBELIGHT	Suresh. V.	TUBE LIGHT 40W STARTER 1NO CHANGED		Valli. G. - CLINICAL PATHOLOGY	19/07/2022
Comp. Dt. : 30/07/2022 Status : Completed								
1397	22071086	Clinical Pathology	NEED TO CHANGE TUBELIGHT	Muthu. B.	TUBE LIGHT 36W CHOKE 1NO CHANGED		Gowri. S. - CLINICAL PATHOLOGY	01/08/2022
Comp. Dt. : 02/08/2022 Status : Completed								
1398	22080071	Clinical Pathology	NEED TO CHANGE TUBELIGHT	Srinivasan. R.	36W TUBE LIGHT 1NO CHANGED		Sivasakthi. D. - CLINICAL PATHOLOGY	03/08/2022
Comp. Dt. : 05/09/2022 Status : Completed								
1399	22090190	Clinical Pathology	NEED TO CHANGE TUBELIGHT	Manimaran. P.	36W TUBE LIGHT 1NO CHANGED		Valli. G. - CLINICAL PATHOLOGY	06/09/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 15/09/2022 Status : Completed								
1400	22090613	Clinical Pathology	NEED TO CHECK POWER - PROBLEM	Muthu. B.	MCB TRIP ON TO WORK PROBLEM SOLVED		Malathi. M. - CLINICAL PATHOLOGY	16/09/2022
Comp. Dt. : 12/10/2022 Status : Completed								
1401	22100349	Clinical Pathology	NEED TO PROVIDE A NEW EXTN. BOX	Suresh. V.	SWITCH BOARD CHEKING WORK POINT OK		Vinod Gnana Kumar. D. - CLINICAL PATHOLOGY	22/10/2022
Comp. Dt. : 15/11/2022 Status : Completed								
1402	22110562	Pathology Lab	TUBELIGHT NOT WORKING	Manikandan. M.	36W TUBE LIGHT 1NO CHANG & 36W CHOKE 1NO CHANGED		Arulvizhi. K. - CLINICAL PATHOLOGY	15/11/2022
Comp. Dt. : 07/12/2022 Status : Completed								
1403	22120277	Pathology Lab	1 TUBELIGHT NOT WORKING	Srinivasan. R.	36W TUBE LIGHT 1NO CHANGED		Vinod Gnana Kumar. D. - CLINICAL PATHOLOGY	08/12/2022
Comp. Dt. : 29/12/2022 Status : Completed								
1404	22121307	Clinical Pathology	POWER SUPPLY PROBLEM	Rajan. R.	MCB TRIP ON TO WORK PROBLEM SOLVED		Vinod Gnana Kumar. D. - CLINICAL PATHOLOGY	29/12/2022
Comp. Dt. : 18/01/2023 Status : Completed								
1405	23010602	Clinical Pathology	NEED TO CHANGE TUBELIGHT	Damodharan. V.	TUBE LIGHT 40W STARTER 1NO CHANGED		Vinod Gnana Kumar. D. - CLINICAL PATHOLOGY	18/01/2023
Comp. Dt. : 21/01/2023 Status : Completed								
1406	23010757	Clinical Pathology	NEED TO CHANGE TUBELIGHT	Damodharan. V.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Vinod Gnana Kumar. D. - CLINICAL PATHOLOGY	23/01/2023
Comp. Dt. : 02/02/2023 Status : Completed								
1407	23020046	Clinical Pathology	NEED TO CHECK POWER	Vengadessaperumal. K.,Damodharan. V.,Sathishkumar. R.	15KVA UPS INCOMER MCB TRIP ON TO WORK PROBLEM SOLVED		Vinod Gnana Kumar. D. - CLINICAL PATHOLOGY	02/02/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 22/02/2023								
Status : Completed								
1408	23020836	Clinical Pathology	TUBELIGHT NOT WORKING	Damodharan. V.	TUBE LIGHT WIRE LOOSE RECONNECTION WORK PROBLEM SOLVED		Vinod Gnana Kumar. D. - CLINICAL PATHOLOGY	23/02/2023
Comp. Dt. : 27/02/2023								
Status : Completed								
1409	23021026	Clinical Pathology	NEED TO CHECK PLUG POINT - NOT WORKING	Manimaran. M.	MCB TRIP ON TO WORK PROBLEM SOLVED		Vinod Gnana Kumar. D. - CLINICAL PATHOLOGY	01/03/2023
Comp. Dt. : 06/04/2023								
Status : Completed								
1410	23040193	Clinical Pathology	NEED TO CHECK POWER SUPPLY	Azhagappan. J.	MCB trip - trip ON.		Vinod Gnana Kumar. D. - CLINICAL PATHOLOGY	06/04/2023
Comp. Dt. : 10/04/2023								
Status : Completed								
1411	23040281	Clinical Pathology	NEED TO CHECK SWITCH BOX - NOT WORKING	Vijayaraghavan.B.	Biomedical problem.		Vinothini. R. - CLINICAL PATHOLOGY	10/04/2023
Comp. Dt. : 22/04/2023								
Status : Completed								
1412	23040686	Clinical Pathology	NEED TO CHANGE TUBELIGHT	Srinivasan. R.	36W TUBE LIGHT 1NO CHANGED		Vinod Gnana Kumar. D. - CLINICAL PATHOLOGY	22/04/2023
Comp. Dt. : 29/05/2023								
Status : Completed								
1413	23051105	Clinical Pathology	NEED TO CHECK POWER	Suresh. V.	MCB TRIP ON TO WORK PROBLEM SOLVED		Malathi. M. - CLINICAL PATHOLOGY	30/05/2023
Comp. Dt. : 26/06/2023								
Status : Completed								
1414	23060927	Clinical Pathology	NEED TO CHANGE TUBELIGHT	Vengadessaperumal. K.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Vinod Gnana Kumar. D. - CLINICAL PATHOLOGY	27/06/2023
Dept Name : Computer Department - Electrical Maintenance								
Comp. Dt. : 02/05/2022								
Status : Completed								
1415	22050012	EDP IN UNDERGROUND	UPS SOUND PROBLEM - NEED URGENT SERVICE	Vaithianathan.M	15KVA UPS SERVICE WORK & UPS CHEKING WORK PROBLEM SOLVED		Prakash. P. - Computer Department	05/05/2022

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 25/05/2022 Status : Completed								
1416	22050937	MEDICAL COLLEGE	NEED TO FIX CCTV CAMERA 2 NOS	Manikandan. M.	CCTV CAMERA 2NO'S FIXING WORK PROBLEM SOLVED		Raja.B - Computer Department	25/05/2022
Comp. Dt. : 31/05/2022 Status : Completed								
1417	22051115	Lecture Hall1	NEED CABLE LAYING WORK FOR FIXING C C T V CAMERA AT LECTURER HALL I	Rajan. R.	15MTR CAMERA CABLE LAYING WORK PROBLEM SOLVED		Valamburi. R. - Computer Department	01/06/2022
1418	22051118	LECTURE HALL V	NEED TO PUT HOLES [2 NOS] FOR FIXING SCREWS	Rajan. R.	2M METEL BOX 2NO'S FIXING WORK PROBLEM SOLVED		Raja.B - Computer Department	01/06/2022
Comp. Dt. : 03/06/2022 Status : Completed								
1419	22060138	EDP IN UNDERGROUND	NEED 20 AMP BREAKER SWITCH & POWER POINT SOCKET	Rajan. R.	20A SINGLE POLE MCB 1NO CHANGED		Raja.B - Computer Department	06/06/2022
Comp. Dt. : 21/06/2022 Status : Completed								
1420	22060737	EDP IN UNDERGROUND	NEED TO CHANGE TUBELIGHT FOR ENTRANCE	Srinivasan. R.	36W TUBE LIGHT 1NO CHANGED		Selvam. D. - Computer Department	21/06/2022
Comp. Dt. : 01/07/2022 Status : Completed								
1421	22070030	ORTHO OT	NEED TO PROVIDE 5 AMP SOCKET FOR UPS LINE FITTING AT OLD ORTHO OT	Rajan. R.	6A SOCKET 2NO'S CHANG & 2M PLATE 2NO'S CHANG& &2M SURFACE BOX 2NO'S CHANG & 1.5SQMM WIRE 10MTR FIXI		Raja.B - Computer Department	18/07/2022
Comp. Dt. : 15/07/2022 Status : Completed								
1422	22070567	Free Pharmacy	POWER ISSUE FOR BIO METRIC MACHINE	Lakshmanan.V.	12V DC DRIVER 1NO CHANGED		Raja.B - Computer Department	16/07/2022
Comp. Dt. : 27/07/2022 Status : Completed								
1423	22071003	EDP IN UNDERGROUND	NEED TO PROVIDE POWER FOR POWER RACK AT SERVER ROOM	Rajan. R.	SWITCH RACK WRING 2.5SQ MM WIRE 30MTR, 1" PVC PIPE 4NO'S, 1" PVC BUND 5NO'S, FIXING WORK PROBLEM SOL	 Dr. KAGNE. R.N DEAN SRI MANAKULA VINAYAGAR MEDICAL COLLEGE & HOSPITAL KALITHEERTHALKUPPAM, PUDUCHERRY-605107.	Raja.B - Computer Department	22/08/2022

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 03/08/2022 Status : Completed								
1424	22080112	EDP IN UNDERGROUND	NEED TO CHANGE TUBELIGHT	Lakshmanan.V.	36W TUBE LIGHT 1NO CHANG & 36W CHOKE 1NO CHANGED		Selvam. D. - Computer Department	03/08/2022
Comp. Dt. : 09/08/2022 Status : Completed								
1425	22080328	EDP IN UNDERGROUND	NEED TO PROVIDE POWER FOR POWER RACK AT SERVER ROOM	Suresh. V.	8M SWITCH BOX 2NO'S FIXING & LINE CONNECTION WORK PROBLEM SOLVED		Raja.B - Computer Department	28/09/2022
Comp. Dt. : 26/08/2022 Status : Completed								
1426	22080899	EDP IN UNDERGROUND	NEED TO CHANGE TUBELIGHT	Dhakshinamoorthy. J	36W TUBE LIGHT 1NO CHANGED		Prakash. P. - Computer Department	27/08/2022
Comp. Dt. : 22/09/2022 Status : Completed								
1427	22090861	ECHO CARDIO GRAM	NEED ELECTRICIAN HELP FOR NEW FACE MACHINE INSTALATION WORK - NEAR ECHO CARDIO GRAM ROOM	Vijayaraghavan.B.	FACE MACHINE 1NO FIXING WORK & WIRING WORK PROBLEM SOLVED		Selvam. D. - Computer Department	23/09/2022
Comp. Dt. : 23/09/2022 Status : Completed								
1428	22090916	EDP IN UNDERGROUND	NEED TO CHANGE TUBELIGHT FOR INSIDE EDP	Muthu. B.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Murugavel.R - Computer Department	23/09/2022
Comp. Dt. : 12/10/2022 Status : Completed								
1429	22100318	Work Shop	CAMERA WIRE CABLE NEED TO BE LAYED	Rajan. R.	CAMERA WIRE LAYING WORK PROBLEM SOLVED		Murugavel.R - Computer Department	12/10/2022
Comp. Dt. : 20/10/2022 Status : Completed								
1430	22100676	RADIOLOGY	NETWORK CABLE NOT WORKING IN RADIOLOGY DEMO ROOM	Vaithianathan.M	NETWORK CABLE LAYING WORK PROBLEM SOLVED		Prakash. P. - Computer Department	28/10/2022
Comp. Dt. : 28/10/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1431	22100886	PHYSIOTHERAPY ROOM IN 4TH FLOOR	NETWORK CABLE LAYING IN 402,403	Srinivasan. R.	NETWORK CABLE LAYING WORK PROBLEM SOLVED		Balachandar. A. - Computer Department	31/10/2022
	Comp. Dt. : 29/10/2022							
	Status : Completed							
1432	22100962	B.ED COLLEGE	INTERCABLE RELAYING WORK IN COMPUTER LAB	Suresh. V.	NETWORK CABLE LAYING WORK PROBLEM SOLVED		Jayaraj. J. - Computer Department	10/11/2022
	Comp. Dt. : 23/12/2022							
	Status : Completed							
1433	22121047	Boys hostel	SWITCH RACK POWER NEED TO GIVE IN 2ND FLOOR & GROUND FLOOR	Thillaikumar. R.	6A SOCKET 2NO'S,2M SURFACE BOX 2NO'S,2M PLATE 2NO'S,1.5SQ MM WIRE 30MTR WIRING WORK & LINE CONNECTIO		Selvam. D. - Computer Department	23/12/2022
	Comp. Dt. : 28/12/2022							
	Status : Completed							
1434	22121256	EDP IN UNDERGROUND	LIGHT NOT WORKING IN SERVER ROOM	Vengadessaperumal. K.	TUBE LIGHT 40W STARTER 1NO CHANGED		Selvam. D. - Computer Department	28/12/2022
	Comp. Dt. : 13/01/2023							
	Status : Completed							
1435	23010541	EDP IN UNDERGROUND	NEED TO CHANGE TUBELIGHT IN STORE ROOM AND SERVER ROOM - 2 NOS	Damodharan. V.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 2NO'S CHANGED		Jayaraj. J. - Computer Department	18/01/2023
	Comp. Dt. : 19/01/2023							
	Status : Completed							
1436	23010655	EDP IN UNDERGROUND	NEED TO CHANGE TUBELIGHT FOR SERVER ROOM	Srinivasan. R.	TUBE LIGHT 40W STARTER 1NO CHANGED		Raja.B - Computer Department	20/01/2023
	Comp. Dt. : 10/02/2023							
	Status : Completed							
1437	23020372	MEDICAL COLLEGE	FACE BIOMETRIC MACHINE BATTERY POWER ADAPTER PROBLEM	Rajan. R.	6A SOCKET 1NO CHANGED		Madhubalan. S. - Computer Department	13/02/2023
	Comp. Dt. : 24/02/2023							
	Status : Completed							
1438	23020948	MIT PRINCIPAL QUATERS	NEED TO REROUTE WIFI CABLE FOR MIT PRINCIPAL HOUSE	Thillaikumar. R.	NEW WIFI CABLE LAYING WORK PROBLEM SOLVED		Shafiullah. R. - Computer Department	10/03/2023

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1439	23020949	DEAN HOUSE	NEED TO REROUTE WIFI CABLE FOR DEAN SIR HOUSE	Thillaikumar. R.	NEW WIFI CABLE LAYING WORK PROBLEM SOLVED		Shafiullah. R. - Computer Department	10/03/2023
Comp. Dt. : 13/03/2023 Status : Completed								
1440	23030497	Hospital	NEED TO PUT HOLES FOR CC TV CAMERA FIXING WORK AT BOYS HOSTEL & LADIES HOSTEL	Thillaikumar. R.	CC TV CAMERA FIXING WORK PROBLEM SOLVED		Prakash. P. - Computer Department	16/03/2023
Comp. Dt. : 15/03/2023 Status : Completed								
1441	23030577	professor quarters	NEED CABLE LAYING WORK	Azhagappan. J.	Data cable layed. (Srinivasa Electricals)		Prakash. P. - Computer Department	18/03/2023
1442	23030614	BASEMENT	NEED CABLE LAYING WORK FROM EDP TO RADIOLOGY	Damodharan. V.	CAMERA CABLE LAYING WORK PROBLEM SOLVED		Murugavel.R - Computer Department	16/03/2023
1443	23030616	professor quarters	NEED NETWORK CABLE LAYING WORK FOR VICE CHANCELLOR HOUSE	Azhagappan. J.	Data cable layed. (Srinivasa Electricals)		Prakash. P. - Computer Department	18/03/2023
Comp. Dt. : 21/03/2023 Status : Completed								
1444	23030886	J.R Quateres	SWITCH BOX POWER SUPPLY PROBLEM	Rajan. R.	Power line checked - ok.		Balachandar. A. - Computer Department	23/03/2023
Comp. Dt. : 10/04/2023 Status : Completed								
1445	23040282	boys hostel-gym	NEED POWER CABLE LAYING WORK FOR FINGER PRINT FOR BOYS HOSTEL GYM DOOR	Manikandan. M.,Manimaran. M.,Vijayaraghavan.B.	FINGER & PRINT MACHINE WIREING WORK PROBLEM SOLVED		Prakash. P. - Computer Department	22/04/2023
Comp. Dt. : 29/04/2023 Status : Completed								
1446	23040993	EDP IN UNDERGROUND	U P S POWER PROBLEM	Vijayaraghavan.B.	MCB TRIP ON TO WORK PROBLEM SOLVED		Shafiullah. R. - Computer Department	09/05/2023
Comp. Dt. : 04/05/2023 Status : Completed								
1447	23050128	EDP IN UNDERGROUND	NEED TO CHANGE TUBELIGHT FOR SERVER ROOM	Muthu. B.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Murugavel.R - Computer Department	05/05/2023
Comp. Dt. : 15/05/2023 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1448	23050587	General Stores[Linen]	NEED TO CHANGE TUBELIGHT FOR STORES OPPOSITE STEPS	Srinivasan. R.	36W tube light 1no changed.		Shafiullah. R. - Computer Department	15/05/2023
1449	23050617	EDP IN UNDERGROUND	NEED TO CHANGE TUBELIGHT FOR SERVER ROOM	Srinivasan. R.	36W E.choke 1no changed.		Jayaraj. J. - Computer Department	15/05/2023
Comp. Dt. : 16/05/2023 Status : Completed								
1450	23050665	Boys hostel	NEED TO CHECK POWER - PROBLEM IN ELECTRICAL ROOM POWER SWITCH RACK	Muthu. B.	POWER CHEKING WORK NO PROBLEM SOLVED		Prakash. P. - Computer Department	18/05/2023
Comp. Dt. : 18/05/2023 Status : Completed								
1451	23050726	Boys hostel	NEED TO FIX WIRELESS DEVICE	Srinivasan. R.	WIRELESS DEVICE FIXING WORK		Prakash. P. - Computer Department	22/05/2023
Comp. Dt. : 23/05/2023 Status : Completed								
1452	23050909	Printing Press	NEED TO FIX HOLES	Vijayaraghavan.B.	OLD DIVES FIXING WORK PROBLM SOLVED		Prakash. P. - Computer Department	25/05/2023
Comp. Dt. : 25/05/2023 Status : Completed								
1453	23051017	Chairman Office	NEED CABLE LAYING WORK FROM I FLOOR CHAIRMAN OFFICE TO OPHTHAL OPD	Rajan. R.	NEW NETWORK CABLE LAYING WORK CHARMAN OFFICE TO OPHTHAL OPD WORK COMPLETED		Selvam. D. - Computer Department	10/06/2023
Comp. Dt. : 30/05/2023 Status : Completed								
1454	23051177	EDP IN UNDERGROUND	NEED FINGERPRINT MACHINE INSTALLATION	Srinivasan. R.	FINGERPRINT MACHINE FIXING WORK PROBLEM SOLVED		Murugavel.R - Computer Department	10/06/2023
Comp. Dt. : 02/06/2023 Status : Completed								
1455	23060080	EDP IN UNDERGROUND	NEED TO CHECK SERVICE TABE SWITCH	Manikandan. M.	6A SWITCH 1NO CHANGED		Selvam. D. - Computer Department	05/06/2023
Comp. Dt. : 22/06/2023 Status : Completed								
1456	23060839	Reception	TRIPPER NOT WORKING - RECEPTION T V -	Vengadessaperumal. K.	MCB TRIP ON TO WORK PROBLEM SOLVED		Jayaraj. J. - Computer Department	24/06/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 26/06/2023 Status : Completed								
1457	23060932	Nursing College	NEED TO CHECK POWER - U P S LINE PROBLEM	Lakshmanan.V.	UPS TRIP ON TO WORK PROBLEM SOLVED		Prakash. P. - Computer Department	27/06/2023
Dept Name : COVID Control Room - Electrical Maintenance Comp. Dt. : 02/05/2022 Status : Completed								
1458	22050046	Casualty	TORCH LIGHT 2NOS NOT WORKING	Sathishkumar. R.	TORCH LIGHT 2NO'S SERVICE WORK PROBLEM SOLVED		Kanimozhi. E. - EMERGENCY MEDICINE	09/05/2022
Comp. Dt. : 09/05/2022 Status : Completed								
1459	22050300	Casualty	NEED TO CHANGE TUBELIGHT	Vijayaraghavan.B.	36W TUBE LIGHT SET 1NO REFIXING WORK PROBLEM SOLVED		Kanimozhi. E. - EMERGENCY MEDICINE	12/05/2022
Comp. Dt. : 21/05/2022 Status : Completed								
1460	22050803	Casualty	NEED TO CHANGE TUBELIGHT	Vijayaraghavan.B.	36W TUBE LIGHT CHOKE 1NO CHANGED		Kanimozhi. E. - EMERGENCY MEDICINE	23/05/2022
Comp. Dt. : 30/05/2022 Status : Completed								
1461	22051098	Casualty	NEED TO CHANGE TUBELIGHT	Vijayaraghavan.B.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANG & 36W TUBE LIGHT SET 1NO REFIXING WORK PROBLEM SOLV		Kanimozhi. E. - EMERGENCY MEDICINE	31/05/2022
Dept Name : COVID Ward - Electrical Maintenance Comp. Dt. : 14/05/2022 Status : Completed								
1462	22050504	Female Ortho - Ward 401	FAN NOT WORKING	Lakshmanan.V.	CEILING FAN CAPACITOR 2.5MFT 1NO CHANGED		Girija. G. - Female Ortho Ward	20/05/2022
Comp. Dt. : 30/05/2022 Status : Completed								
1463	22051070	Female Ortho - Ward 401	HEATER NOT WORKING IN PATIENT RESTROOM	Srinivasan. R.,Babu. D.,Muthu. B.	WATER HEATER 1NO RESET WORK PROBLEM SOLVED		Girija. G. - Female Ortho Ward	31/05/2022
1464	22051071	Female Ortho - Ward 401	NEED TO CHANGE TUBELIGHT	Muthu. B.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Girija. G. - Female Ortho Ward	31/05/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1465	22051088	Female Ortho - Ward 402	FAN NOT WORKING	Muthu. B.	CEILING FAN CAPACITOR 2.5MFT 1NO CHANGED		Punithavathi. E. - Female Ortho Ward	31/05/2022
	Comp. Dt. : 03/06/2022							
	Status : Completed							
1466	22060125	Female Ortho - Ward 401	NEED TO CHANGE X RAY LOBBY LIGHT - NOT WORKING	Vijayaraghavan.B.	9W 2PIN CFL LIGHT 1NO CHANGED		Girija. G. - Female Ortho Ward	04/06/2022
	Comp. Dt. : 13/06/2022							
	Status : Completed							
1467	22060462	Female Ortho - Ward 401	NEED TO FIX NEW TUBELIGHT SET FOR RESTROOM	Muthu. B.	36W E.choke 1no changed & LED fitting 1no fixed.		Girija. G. - Female Ortho Ward	14/06/2022
	Comp. Dt. : 16/06/2022							
	Status : Completed							
1468	22060603	Female Ortho - Ward 401	FAN NOT WORKING	Vijayaraghavan.B.	CEILING FAN REWINDING WORK BEARING 2NO'S CHANG & FAN REFXING WORK PROBLEM SOLVED		Girija. G. - Female Ortho Ward	25/06/2022
	Comp. Dt. : 29/06/2022							
	Status : Completed							
1469	22061063	WARD-406	REST ROOM HEATER NOT WORKING	Lakshmanan.V.	WATER HEATER 1NO RESET WORK PROBLEM SOLVED		Kavitha. S. - Derm,Pulmo,Psych Ward	30/06/2022
	Comp. Dt. : 30/06/2022							
	Status : Completed							
1470	22061097	Female Ortho Ward	NEED TO FIX NEW PLUG POINTS 3 NOS & PLUG POINT NOT WORKING 1 NO - WARD NO 401 & 402	Vijayaraghavan.B.	3M PLATE 1NO,6A SOCKET 1NO,6A SWITCH 1NO CHANG & LINE CONNECTION WORK PROBLEM SOLVED		Girija. G. - Female Ortho Ward	13/07/2022
	Comp. Dt. : 11/07/2022							
	Status : Completed							
1471	22070446	Female Ortho - Ward 402	POWER SUPPLY PROBLEM	Muthu. B.	MCB TRIP ON TO WORK PROBLEM SOLVED		Girija. G. - Female Ortho Ward	12/07/2022
	Comp. Dt. : 12/07/2022							
	Status : Completed							
1472	22070449	Male Medical - Ward 301	NEED TO CHANGE TUBELIGHT 3 NOS	Manikandan. M.	36W TUBE LIGHT 3NO'S CHANG & 40W STARTER 1NO CHANGED		Karthikeyan. I. - Male Medical Ward	12/07/2022
	Comp. Dt. : 16/07/2022							

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
1473	22070624	Male Medical - Ward 303	HEATER NOT WORKING	Manimaran. P.	NEW WATER HEATER 2KW COIL 1NO CHANG & CHEKING WORK PROBLEM SOLVED		Karthikeyan. I. - Male Medical Ward	19/07/2022
Dept Name : CSSD - Electrical Maintenance								
Comp. Dt. : 09/05/2022								
Status : Completed								
1474	22050264	CSSD	NEED TO CHANGE TUBELIGHT FOR STERILE AREA	Manikandan. M.	40W STARTER 1NO CHANGED		Vinnarasi. R - CSSD	09/05/2022
Comp. Dt. : 19/05/2022								
Status : Completed								
1475	22050696	CSSD	NEED TO CHANGE TUBELIGHT FOR PACKING AREA	Lakshmanan.V.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Vinnarasi. R - CSSD	20/05/2022
Comp. Dt. : 30/05/2022								
Status : Completed								
1476	22051093	CSSD	NEED TO CHANGE TUBELIGHT FOR STERILE AREA	Vijayaraghavan.B.	TUBE LIGHT 40W STARTER 1NO CHANGED		Vinnarasi. R - CSSD	31/05/2022
Comp. Dt. : 31/05/2022								
Status : Completed								
1477	22051116	CSSD	NEED TO CHANGE TUBELIGHT	Srinivasan. R.	TUBE LIGHT 40W STARTER 1NO CHANGED		Vengateswari. R. - CSSD	01/06/2022
Comp. Dt. : 23/06/2022								
Status : Completed								
1478	22060831	CSSD	EXHAUST FAN & TUBELIGHT NOT WORKING	Manimaran. P.	36W TUBE LIGHT 2NO'S CHANG & 40W STARTER 5NO'S CHANG & SIDE HOLDER 1NO CHANGED		Pazhanivel.S. - CSSD	24/06/2022
Comp. Dt. : 24/06/2022								
Status : Completed								
1479	22060905	TB & Chest OPD	NEED TO CHECK SWITCH BOARD - SHOCK PROBLEM - NEED URGENT SERVICE	Manimaran. P.	16A SWITCH 1NO CHANG & 6A SWITCH 1NO CHANGED		Jothi.R. - OPD	27/06/2022
Comp. Dt. : 06/07/2022								
Status : Completed								
1480	22070217	TB & Chest OPD	NEED TO CHECK DIGITAL CLOCK - TIME DISPLAYING WRONG	Rajan. R.	DIGITAL CLOCK SETTING CHANGED		Jothi.R. - OPD	12/07/2022

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 25/07/2022 Status : Completed								
1481	22070899	CSSD	NEED TO CHECK FAN - SLOW PROBLEM	Manimaran. P.	CEILING FAN CAPACITOR 2.5MFT 1NO CHANGED		Vinnarasi. R - CSSD	26/07/2022
Comp. Dt. : 01/08/2022 Status : Completed								
1482	22080024	CSSD	NEED TO CHANGE TUBELIGHT	Muthu. B.	TUBE LIGHT 40W STARTER 1NO CHANGED		Pazhanivel.S. - CSSD	02/08/2022
Comp. Dt. : 29/08/2022 Status : Completed								
1483	22080962	CSSD	NEED TO CHANGE TUBELIGHT FOR WASHING AREA	Manimaran. P.	TUBE LIGHT 40W STARTER 1NO CHANGED		Vinnarasi. R - CSSD	29/08/2022
Comp. Dt. : 01/09/2022 Status : Completed								
1484	22090035	CSSD	NEED TO CHECK WATER HEATER - LEAKAGE	Lakshmanan.V.	TUBE LIGHT 40W STARTER 1NO CHANGED		Vinnarasi. R - CSSD	03/09/2022
Comp. Dt. : 02/09/2022 Status : Completed								
1485	22090110	CSSD	TUBE LIGHT NOT WORKING	Lakshmanan.V.	36W TUBE LIGHT 40W STARTER 1NO CHANGED		Vinnarasi. R - CSSD	03/09/2022
Comp. Dt. : 13/10/2022 Status : Completed								
1486	22100408	CSSD	SEALING MACHINE NOT WORKING	Sridharan. R	SEALING MACHINE BOARD PROBLEM		Sumithra. S. - CSSD	22/10/2022
Comp. Dt. : 18/10/2022 Status : Completed								
1487	22100592	CSSD	PEDAL STAND FAN NOT WORKING	Muthu. B.	PEDESTAL FAN SERVICE WORK PROBLEM SOLVED		Pazhanivel.S. - CSSD	19/10/2022
Comp. Dt. : 16/11/2022 Status : Completed								
1488	22110681	CSSD	SEALING MACHINE NOT WORKING	Dhakshinamoorthy. J	SEALING MACHINE SERVICE WORK PROBLEM SOLVED		Pazhanivel.S. - CSSD	21/11/2022
Comp. Dt. : 19/11/2022 Status : Completed								
1489	22110805	CSSD	SEALING MACHINE NOT WORKING	Dhakshinamoorthy. J	SEALING MACHINE SERVICE WORK PROBLEM SOLVED		Pazhanivel.S. - CSSD	21/11/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 22/11/2022								
Status : Completed								
1490	22110931	CSSD	NEED TO CHECK PLUG POINT NOT WORKING	Muthu. B.	16A 3PIN TOP 1NO CHANGED		Vinnarasi. R - CSSD	23/11/2022
Comp. Dt. : 09/12/2022								
Status : Completed								
1491	22120431	CSSD	NEED TO CHANGE TUBELIGHT 2 NOS	Manimaran. P.	TUBE LIGHT 40W STARTER 2NO'S CHANGED		Vengateswari. R. - CSSD	10/12/2022
Comp. Dt. : 28/12/2022								
Status : Completed								
1492	22121264	CSSD	FAN NOT WORKING IN PACKING AREA	Lakshmanan.V.	CEILING FAN CAPACITOR 2.5MFT 1NO CHANGED		Vinnarasi. R - CSSD	28/12/2022
1493	22121265	CSSD	TUBE LIGHT NOT WORKING IN AUTOCLAVE MACHINE AREA	Lakshmanan.V.	36W TUBE LIGHT FITTING 1NO CHANG & LINE CONNECTION WORK PROBLEM SOLVED		Vinnarasi. R - CSSD	28/12/2022
Comp. Dt. : 04/01/2023								
Status : Completed								
1494	23010176	CSSD	IN STERILE AREA-1 TUBELIGHT NOT WORKING	Lakshmanan.V.	TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Vinnarasi. R - CSSD	05/01/2023
Comp. Dt. : 14/01/2023								
Status : Completed								
1495	23010593	CSSD	SEALING MACHINE NOT WORKING	Vijayaraghavan.B.	6A 3PIN TOP 1NO CHANGED		Sumithra. S. - CSSD	14/01/2023
Comp. Dt. : 24/01/2023								
Status : Completed								
1496	23010847	CSSD	NEED TO CHANGE TUBELIGHT FOR ENTRANCE	Muthu. B.	TUBE LIGHT 40W STARTER 1NO CHANGED		Rajakumari. M. - CSSD	24/01/2023
Comp. Dt. : 30/01/2023								
Status : Completed								
1497	23011036	CSSD	NEED TO CHANGE TUBELIGHT	Manimaran. M.	TUBE LIGHT 40W STARTER 1NO CHANGED		Pazhanivel.S. - CSSD	30/01/2023
Comp. Dt. : 01/02/2023								
Status : Completed								
1498	23020007	CSSD	FAN NOT WORKING	Muthu. B.	Wall mounting Fan Wire rejoined and cleaning service		Rajakumari. M. - CSSD	03/02/2023
Comp. Dt. : 14/02/2023								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
1499	23020509	CSSD	NEED TO CHECK TUBELIGHT - NOT WORKING & FAN SOUND PROBLEM	Vengadessaperumal. K.,Rajan. R.,Sathishkumar. R.	CEILING FAN CHEKING NO COMPLAINT & TUBE LIGHT 40W STARTER 1NO CHANGED		Pazhanivel.S. - CSSD	14/02/2023
Comp. Dt. : 04/03/2023								
Status : Completed								
1500	23030163	CSSD	NEED TO CHANGE TUBELIGHT FOR WASHING AREA	Muthu. B.	36W TUBE LIGHT 1NO CHANG & SIDE HOLDER 1NO CHANGED		Vinnarasi. R - CSSD	06/03/2023
Comp. Dt. : 27/03/2023								
Status : Completed								
1501	23031109	CSSD	NEED TO CHANGE TUBELIGHT	Manimaran. P.	TUBE LIGHT 40W STARTER 1NO CHANGED		Pazhanivel.S. - CSSD	28/03/2023
Comp. Dt. : 28/04/2023								
Status : Completed								
1502	23040946	CSSD	NEED TO CHANGE TUBELIGHT FOR DELIVERY ROOM	Rajan. R.	TUBE LIGHT 40W STARTER 1NO CHANGED		Vinnarasi. R - CSSD	28/04/2023
Comp. Dt. : 06/05/2023								
Status : Completed								
1503	23050238	CSSD	NEED TO CHANGE TUBELIGHT 2 NOS FOR STORE ROOM & ETO ROOM	Muthu. B.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Vinnarasi. R - CSSD	08/05/2023
1504	23050239	CSSD	SEALING MACHINE NOT WORKING	Dhakshinamoorthy. J	Ground wire problem - wire changed.		Vinnarasi. R - CSSD	15/05/2023
Comp. Dt. : 12/05/2023								
Status : Completed								
1505	23050473	CSSD	EXHAUST FAN NOT WORKING	Damodharan. V.,Babu. D.,Vijayaraghavan.B.	coil problem. Exhaust fan head 2no's changed and exhaust fan 2no's fixed.		Vinnarasi. R - CSSD	26/05/2023
Comp. Dt. : 18/05/2023								
Status : Completed								
1506	23050744	CSSD	NEED TO CHECK FAN - SOUND PROBLEM	Thillaikumar. R.	CEILING FAN CHEKING WORK BEARING SOUND PROBLEM SOLVED		Mangalakshmi. J - CSSD	19/05/2023
Comp. Dt. : 25/05/2023								
Status : Completed								
1507	23050986	CSSD	SEALING MACHINE NOT WORKING	Damodharan. V.	SEALING MACHINE BOARD PROBLEM		Pazhanivel.S. - CSSD	16/06/2023

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 30/05/2023 Status : Completed								
1508	23051208	CSSD	STANDING FAN NOT WORKING	Rajan. R.	3PIN TOP WIRE CUT RECONNECTION WORK PROBLEM SOLVED		Pazhanivel.S. - CSSD	31/05/2023
Comp. Dt. : 01/06/2023 Status : Completed								
1509	23060003	CSSD	EXHAUST FAN NOT WORKING IN AUTOGLAVE ROOM	Manikandan. M.	NEW EXHAUST FAN MOTOR 1NO CHANG & LINE CONNECTION WORK PROBLEM SOLVED		Vinnarasi. R - CSSD	02/06/2023
Comp. Dt. : 05/06/2023 Status : Completed								
1510	23060118	CSSD	NEED TO CHANGE TUBELIGHT [2 NOS]	Manimaran. P.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Rajakumari. M. - CSSD	05/06/2023
Comp. Dt. : 13/06/2023 Status : Completed								
1511	23060455	CSSD	CEILING FAN NOT WORKING	Muthu. B.	CEILING FAN 1NO REWINDING BEARING 2NO'S CHANG & FAN REFIXING WORK PROBLEM SOLVED		Vinnarasi. R - CSSD	20/06/2023
Dept Name : Derm,Pulmo,Psych Ward - Electrical Maintenance Comp. Dt. : 10/05/2022 Status : Completed								
1512	22050361	DERMATOLOGY WARD 406	NEED TO CHANGE TUBELIGHT FOR DOCTOR'S ROOM	Muthu. B.	36W TUBE LIGHT 1NO CHANGED		Sarathkumar. R. - Derm,Pulmo,Psych Ward	12/05/2022
Comp. Dt. : 18/05/2022 Status : Completed								
1513	22050664	Female Psychiatry - Ward 406	HEATER NOT WORKING	Srinivasan. R.	WATER HEATER RESET WORK PROBLEM SOLVED		Sarathkumar. R. - Derm,Pulmo,Psych Ward	20/05/2022
Comp. Dt. : 31/05/2022 Status : Completed								
1514	22051138	TB AND CHEST WARD-405	NEED TO CHANGE C F L LIGHT FOR ECG ROOM	Dhakshinamoorthy. J	9W LED LIGHT 1NO CHANGED		Sarathkumar. R. - Derm,Pulmo,Psych Ward	01/06/2022
Comp. Dt. : 02/06/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1515	22060070	TB AND CHEST WARD-405	T V NOT WORKING	Srinivasan. R.	TV & SETUP BOX CHEKING WORK PROBLEM SOLVED		Sarathkumar. R. - Derm,Pulmo,Psych Ward	02/06/2022
	Comp. Dt. : 20/06/2022							
	Status : Completed							
1516	22060723	TB AND CHEST WARD-405	NEED TO CHANGE TUBELIGHT FOR DOCTOR'S REST ROOM	Srinivasan. R.	9W LED LIGHT 2NO'S CHANGED		Bharathi. A - Derm,Pulmo,Psych Ward	23/06/2022
	Comp. Dt. : 21/06/2022							
	Status : Completed							
1517	22060739	TB AND CHEST WARD-405	FAN NOT WORKING	Srinivasan. R.	CEILING FAN REWINDING WORK & BEARING 2NO'S CHANG & FAN REFIXING WORK PROBLEM SOLVED		Sarathkumar. R. - Derm,Pulmo,Psych Ward	23/06/2022
	Comp. Dt. : 22/06/2022							
	Status : Completed							
1518	22060778	TB AND CHEST WARD-405	NEED ALL FAN SERVICE & FAN SLOW PROBLEM [10 NOS]	Lakshmanan.V.	CEILING FAN CAPACIOTR 2.5MFT 4NO'S CHANG & FAN 5NO'S WIRE LOOSE SCREW REFIXING WORK PROBLEM SOLVED		Sarathkumar. R. - Derm,Pulmo,Psych Ward	23/06/2022
	Comp. Dt. : 04/07/2022							
	Status : Completed							
1519	22070080	Male Ortho Ward	NEED TO CHECK POWER - WARD NO 403 & 404	Vijayaraghavan.B.	MCB TRIP ON TO WORK PROBLEM SOLVED		Manjula. P. - Male Ortho Ward	04/07/2022
	Comp. Dt. : 15/07/2022							
	Status : Completed							
1520	22070600	PSYCHIATRY WARD	FAN 3NOS NOT WORKING WARD NO 405	Muthu. B.	20A SINGLE POLE MCB 1NO CHANGED		Sarathkumar. R. - Derm,Pulmo,Psych Ward	16/07/2022
	Comp. Dt. : 01/08/2022							
	Status : Completed							
1521	22080031	Female Psychiatry - Ward 406	FAN SOUND PROBELM	Dhakshinamoorthy. J	CEILING FAN BEARING 2NO'S CHANG & FAN REFIXING WORK PROBLEM SOLVED		Sarathkumar. R. - Derm,Pulmo,Psych Ward	03/08/2022
1522	22080050	PSYCHIATRY WARD	NEED TO FIX EMERGENCY LIGHT WITH UPS CONNECTION FOR WARD NO 405	Muthu. B.	EMERGENCY LIGHT 9W LED LIGHT 1NO FIXING & WIRING WORK LINE CONNECTION WORK PROBLEM SOLVED		Sarathkumar. R. - Derm,Pulmo,Psych Ward	04/08/2022
	Comp. Dt. : 08/08/2022							


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
1523	22080256	PSYCHIATRY WARD	NEED TO FIX FAN REGULATOR FOR ECG ROOM	Muthu. B.	CEILING FAN REGULATOR 1NO CHANGED		Sarathkumar. R. - Derm,Pulmo,Psych Ward	09/08/2022
Comp. Dt. : 22/08/2022								
Status : Completed								
1524	22080724	Female Psychiatry - Ward 406	NEED TO CHANGE TUBELIGHT & FAN SOUND PROBLEM IN ISOLATION ROOM	Dhakshinamoorthy. J	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO & CEILING FAN BEARING 2NO'S CHANG & FAN REFIXING WORK PRO		Sarathkumar. R. - Derm,Pulmo,Psych Ward	23/08/2022
Comp. Dt. : 30/08/2022								
Status : Completed								
1525	22081002	Female Psychiatry - Ward 406	FAN [4 NOS] NOT WORKING - SLOW PROBLEM	Manikandan. M.	CEILING FAN CAPACITOR 2.5MFT 4NO'S CHANGED		Sarathkumar. R. - Derm,Pulmo,Psych Ward	01/09/2022
Comp. Dt. : 01/09/2022								
Status : Completed								
1526	22090022	PSYCHIATRY WARD	NEED TO CHANGE TUBELIGHT FOR CARITOR & FAN SLOW PROBLEM IN NURSE'S CABIN	Suresh. V.	36W TUBE LIGHT 1NO CHANG & 36W CHOKE 1NO CHANG & CEILING FAN CAPACITOR 2.5MFT 1NO CHANGED		Sarathkumar. R. - Derm,Pulmo,Psych Ward	02/09/2022
1527	22090042	PSYCHIATRY WARD	NEED TO REFIX FIRE EXTN BOX	Manikandan. M.	NO COMPLAINT		Sarathkumar. R. - Derm,Pulmo,Psych Ward	03/09/2022
Comp. Dt. : 26/09/2022								
Status : Completed								
1528	22090990	PSYCHIATRY WARD	NEED TO CHECK POWER FOR ECG ROOM LIGHT FAN NOT WORKING	Vijayaraghavan.B.	MCB Trip - Trip On.		Sarathkumar. R. - Derm,Pulmo,Psych Ward	26/09/2022
1529	22091015	PSYCHIATRY OPD	NEED TO CHECK CEILING LIGHT - NOT WORKING AT ECG ROOM	Lakshmanan.V.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANG & 36W CHOKE 1NO CHANGED		Sarathkumar. R. - Derm,Pulmo,Psych Ward	29/09/2022
Comp. Dt. : 05/10/2022								
Status : Completed								
1530	22100041	PSYCHIATRY WARD	HEATER NOT WORKING - FEMALE SIDE RESTROOM	Rajan. R.	WATER HEATER NEW COIL 2KW 1NO CHANG & HEATER 1NO REFIXING WORK PROBLEM SOLVED		Sarathkumar. R. - Derm,Pulmo,Psych Ward	08/10/2022
Comp. Dt. : 11/10/2022								
Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1531	22100262	PSYCHIATRY WARD	FAN SLOW PROBLEM AT NURSE'S CABIN	Suresh. V.	CEILING FAN CAPACITOR 2.5MFT 1NO CHANGED		Sarathkumar. R. - Derm,Pulmo,Psych Ward	11/10/2022
		Comp. Dt. : 18/10/2022 Status : Completed						
1532	22100573	TB AND CHEST WARD-405	NEED TO CHANGE TUBELIGHT FOR MALE TB CHEST WARD	Lakshmanan.V.	TUBE LIGHT 40W STARTER 1NO CHANGED		Sarathkumar. R. - Derm,Pulmo,Psych Ward	19/10/2022
1533	22100608	TB AND CHEST WARD-405	ELECTRICAL TRIPER PROBLEM(1411)	Lakshmanan.V.	MCB TRIP ON TO WORK PROBLEM SOLVED		Sarathkumar. R. - Derm,Pulmo,Psych Ward	19/10/2022
		Comp. Dt. : 26/10/2022 Status : Completed						
1534	22100793	TB AND CHEST WARD-405	FAN NOT WORKING	Srinivasan. R.	ALL FAN CHEKING WORK NO PROBLEM SOLVED		Sarathkumar. R. - Derm,Pulmo,Psych Ward	27/10/2022
		Comp. Dt. : 29/10/2022 Status : Completed						
1535	22100964	PSYCHIATRY WARD	NEED TO CHECK POWER SUPPLY AND SWITCH BOX REFIXING WORK	Muthu. B.	SWITCH BOARD REFIXING WORK PROBLEM SOLVED		Sarathkumar. R. - Derm,Pulmo,Psych Ward	31/10/2022
1536	22100979	PSYCHIATRY WARD	TUBELIGHT NOT WORKING	Muthu. B.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Sarathkumar. R. - Derm,Pulmo,Psych Ward	31/10/2022
		Comp. Dt. : 31/10/2022 Status : Completed						
1537	22101016	TB AND CHEST WARD-405	ONE TUBELIGHT NOT WORKING	Lakshmanan.V.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Sarathkumar. R. - Derm,Pulmo,Psych Ward	02/11/2022
		Comp. Dt. : 14/11/2022 Status : Completed						
1538	22110561	Female Dermatoloty - Ward 406	1 TUBELIGHT NOT WORKING	Vijayaraghavan.B.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Sarathkumar. R. - Derm,Pulmo,Psych Ward	15/11/2022
		Comp. Dt. : 22/11/2022 Status : Completed						
1539	22110937	PSYCHIATRY WARD	NEED TO CHANGE TUBELIGHT FOR DEADDING ROOM	Lakshmanan.V.	TUBE LIGHT 40W STARTER 1NO CHANGED		Sarathkumar. R. - Derm,Pulmo,Psych Ward	23/11/2022
1540	22110938	PSYCHIATRY WARD	HEATER NOT WORKING - MALE PATIENT RESTROOM	Lakshmanan.V.	WATER HEATER 1NO MCB TRIP ON TO WORK PRONLEM SOLVED		Sarathkumar. R. - Derm,Pulmo,Psych Ward	23/11/2022
		Comp. Dt. : 01/12/2022						


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
1541	22120019	Male Psychiatry - Ward 405	RESTROOM HEATER NOT WORKING	Muthu. B.	WATER HEATER OLD COIL 2KW 1NO CHANG & LINE CONNECTION WORK PROBLEM SOLVED		Sarathkumar. R. - Derm,Pulmo,Psych Ward	13/12/2022
Comp. Dt. : 07/12/2022								
Status : Completed								
1542	22120315	TB AND CHEST WARD-405	HEATER NOT WORKING	Lakshmanan.V.	WATER HEATER NEW 2KW COIL 1NO CHANG & HEATER CHEKING WORK PROBLEM SOLVED		Saranya. M. - Derm,Pulmo,Psych Ward	21/12/2022
Comp. Dt. : 08/12/2022								
Status : Completed								
1543	22120395	PSYCHIATRY WARD	IN FEMALE SIDE-PATIENT REST ROOM-1 TUBELIGHT NOT WORKING	Dhakshinamoorthy. J	36W TUBE LIGHT 1NO CHANGED		Sarathkumar. R. - Derm,Pulmo,Psych Ward	09/12/2022
Comp. Dt. : 26/12/2022								
Status : Completed								
1544	22121170	Male Psychiatry - Ward 405	HEATER NOT WORKING	Muthu. B.	WATER HEATER RESET WORK PROBLEM SOLVED		Sarathkumar. R. - Derm,Pulmo,Psych Ward	27/12/2022
1545	22121180	Male Psychiatry - Ward 405	TV SET TOP BOX NOT WORKING	Vengadessaperumal. K.	SETUP BOX NEW ADAPTER 1NO CHANG & TV CHEKING WORK PROBLEM SOLVED		Kavitha. S. - Derm,Pulmo,Psych Ward	05/01/2023
Comp. Dt. : 29/12/2022								
Status : Completed								
1546	22121318	PSYCHIATRY WARD	X-RAY LOBY PLUG POINT PROBLEM	Damodharan. V.	6A 3PIN TOP 1NO CHANGED		Sarathkumar. R. - Derm,Pulmo,Psych Ward	29/12/2022
Comp. Dt. : 09/01/2023								
Status : Completed								
1547	23010342	TB AND CHEST WARD-405	IN ECT ROOM-A/C NOT WORKING	Srinivasan. R.	A/C POWER CHEKING WORK PROBLEM SOLVED		Sarathkumar. R. - Derm,Pulmo,Psych Ward	10/01/2023
1548	23010343	TB AND CHEST WARD-405	IN TV ROOM-SETTOP BOX NOT WORKING	Srinivasan. R.	TV & SETUP BOX CHEKING WORK PROBLEM SOLVED		Sarathkumar. R. - Derm,Pulmo,Psych Ward	10/01/2023
Comp. Dt. : 20/01/2023								
Status : Completed								
1549	23010690	Male Psychiatry - Ward 405	NEED FAN SERVICE [13 NOS]	Damodharan. V.	ALL CEILING FAN CLEANING WORK PROBLEM SOLVED		Sarathkumar. R. - Derm,Pulmo,Psych Ward	23/01/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 21/01/2023 Status : Completed								
1550	23010756	Male Psychiatry - Ward 405	NEED TO CHECK POWER - MULTIPARA MONITOR SHOCK PROBLEM	Damodharan. V.	MCB TRIP ON TO WORK PROBLEM SOLVED		Kavitha. S. - Derm,Pulmo,Psych Ward	23/01/2023
Comp. Dt. : 23/01/2023 Status : Completed								
1551	23010841	Male Psychiatry - Ward 405	NEED TO CHECK TUBELIGHT 2NOS & FAN 1 NO - NOT WORKING	Srinivasan. R.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Sarathkumar. R. - Derm,Pulmo,Psych Ward	24/01/2023
Comp. Dt. : 25/01/2023 Status : Completed								
1552	23010911	TB AND CHEST WARD-405	FEMALE RESTROOM TUBELIGHT NOT WORKING	Dhakshinamoorthy. J	TUBE LIGHT 40W STARTER 1NO CHANGED		Bharathi. A - Derm,Pulmo,Psych Ward	27/01/2023
Comp. Dt. : 08/02/2023 Status : Completed								
1553	23020294	PSYCHIATRY WARD	TV THREE PIN WIRE FAULT IN COUNSELLING ROOM	Srinivasan. R.	LED TV MAIN BOARD CHANG & TV CHEKING WORK & TV REFIXING WORK PROBLEM SOLVED		Sarathkumar. R. - Derm,Pulmo,Psych Ward	18/02/2023
Comp. Dt. : 25/02/2023 Status : Completed								
1554	23020962	TB AND CHEST WARD-405	NEED TO CHANGE TUBELIGHT	Muthu. B.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Bharathi. A - Derm,Pulmo,Psych Ward	27/02/2023
Comp. Dt. : 10/03/2023 Status : Completed								
1555	23030389	Male Psychiatry - Ward 405	FAN [2NOS] NOT WORKING	Srinivasan. R.	CEILING FAN CAPACITOR 2.5MFT 1NO CHANGED		Sarathkumar. R. - Derm,Pulmo,Psych Ward	13/03/2023
Comp. Dt. : 18/03/2023 Status : Completed								
1556	23030734	Male Psychiatry - Ward 405	FAN SLOW PROBLEM AT NURSE'S CABIN	Srinivasan. R.	Fan capacitor 2.5mfd 1no changed.		Sarathkumar. R. - Derm,Pulmo,Psych Ward	18/03/2023
Comp. Dt. : 20/03/2023 Status : Completed								
1557	23030824	ANS DRESS CHANGING ROOM	NEED TO CHANGE TUBELIGHT FOR III FLOOR ANS DRESS CHANGING ROOM	Rajan. R.	TUBE LIGHT 36W CHOKE 1NO CHANGED		Sarathkumar. R. - Derm,Pulmo,Psych Ward	20/03/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 24/03/2023 Status : Completed								
1558	23031004	TB AND CHEST WARD-405	NEED TO CHANGE TUBELIGHT	Thillaikumar. R.	36W E.choke 1no changed.		Bharathi. A - Derm,Pulmo,Psych Ward	24/03/2023
Comp. Dt. : 28/03/2023 Status : Completed								
1559	23031168	Male Psychiatry - Ward 405	NEED TO CHANGE TUBELIGHT FOR COUNSELLING ROOM	Vijayaraghavan.B.	36W tube light 1no & starter 1no changed.		Sarathkumar. R. - Derm,Pulmo,Psych Ward	29/03/2023
1560	23031169	Male Psychiatry - Ward 405	NEED TO CHECK FAN - SLOW PROBLEM AT COUNSELLING ROOM	Vijayaraghavan.B.	Fan capacitor 2.5mfd 1no changed.		Sarathkumar. R. - Derm,Pulmo,Psych Ward	29/03/2023
Comp. Dt. : 04/05/2023 Status : Completed								
1561	23050122	TB AND CHEST WARD-405	FAN NOT WORKING & NEED TO CHANGE TUBELIGHT FOR PANTRY ROOM	Rajan. R.	36W TUBE LIGHT 1NO CHANG & CEILING FAN CAPACITOR 2.5MFT 1NO CHANGED		Preethi. R. - Derm,Pulmo,Psych Ward	05/05/2023
Comp. Dt. : 09/05/2023 Status : Completed								
1562	23050375	Male Psychiatry - Ward 405	NEED TO CHANGE TUBELIGHT FOR PANDARY ROOM	Dhakshinamoorthy. J	TUBE LIGHT 40W STARTER 1NO CHANG & 36W CHOKE 1NO CHANGED		Sarathkumar. R. - Derm,Pulmo,Psych Ward	10/05/2023
Comp. Dt. : 22/05/2023 Status : Completed								
1563	23050865	Male Psychiatry - Ward 405	NEED TO CHANGE TUBELIGHT FOR RESTROOM	Rajan. R.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANG & CEILING FAN CAPACITOR 2.5MFT 1NO CHANGED		Prammadevan. P. - Derm,Pulmo,Psych Ward	23/05/2023
Comp. Dt. : 29/05/2023 Status : Completed								
1564	23051144	Male Psychiatry - Ward 405	NEED TO CHECK TV - VOLUME PROBLEM	Thillaikumar. R.	TV CHEKING WORK PROBLEM SOLVED		Sarathkumar. R. - Derm,Pulmo,Psych Ward	30/05/2023
1565	23051145	Male Dermatology - Ward 405	NEED TO CHANGE TUBELIGHT	Thillaikumar. R.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 2NO'S CHANGED		Sarathkumar. R. - Derm,Pulmo,Psych Ward	30/05/2023
Comp. Dt. : 16/06/2023 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1566	23060615	PSYCHIATRY WARD	ONE TUBELIGHT NOT WORKING	Lakshmanan.V.	36W TUBE LIGHT 2NO'S CHANGED		Sarathkumar. R. - Derm,Pulmo,Psych Ward	17/06/2023
Comp. Dt. : 21/06/2023 Status : Completed								
1567	23060752	Male Psychiatry - Ward 405	NEED TO CHANGE TUBELIGHT FOR CARITOR	Vengadessaperumal. K.	36W TUBE LIGHT 1NO CHANGED		Sarathkumar. R. - Derm,Pulmo,Psych Ward	22/06/2023
Comp. Dt. : 30/06/2023 Status : Completed								
1568	23061117	Male Medical Ward	NEED FAN CLEANING WORK FOR WARD NO 303 & 304	Muthu. B.	MALE MEDICAL WARD 304 ALL CEILING FAN CLEANING WORK PROBLEM SOLVED		Vijay. V. - Derm,Pulmo,Psych Ward	01/07/2023
Dept Name : Dermatology & Vener. - Electrical Maintenance Comp. Dt. : 09/05/2022 Status : Completed								
1569	22050306	DERMATOLOGY OPD	NEED TO CHANGE TUBELIGHT - ROOM NO 72	Muthu. B.	36W TUBE LIGHT 1NO CHANGED		Jayachandran. M. - Dermatology & Vener.	12/05/2022
Comp. Dt. : 16/05/2022 Status : Completed								
1570	22050537	DERMATOLOGY OPD	FAN SLOW PROBLEM IN ROOM NO 72	Sathishkumar. R.	CEILING FAN CAPACITOR 2.5MFT 2NO'S CHANGED		Jayachandran. M. - Dermatology & Vener.	16/05/2022
Comp. Dt. : 09/06/2022 Status : Completed								
1571	22060328	DERMATOLOGY OPD	NEED TO CHANGE TUBELIGHT	Muthu. B.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Jayachandran. M. - Dermatology & Vener.	10/06/2022
Comp. Dt. : 10/06/2022 Status : Completed								
1572	22060397	DERMATOLOGY OPD	IN ROOM NO.73 FAN NOT WORKLING	Suresh. V.	Fan capacitor 2.5mfd 1no changed.		Jayachandran. M. - Dermatology & Vener.	11/06/2022
Comp. Dt. : 11/07/2022 Status : Completed								
1573	22070420	DERMATOLOGY OPD	NEED TO CHANGE TUBELIGHT	Dhakshinamoorthy. J	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Jayachandran. M. - Dermatology & Vener.	11/07/2022
Comp. Dt. : 18/07/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1574	22070670	DERMATOLOGY OPD	NEED TO CHECK EXTENSION BOX PLUG POINT - NOT WORKING	Srinivasan. R.	6A 3PIN TOP 1NO CHANGED		Jayachandran. M. - Dermatology & Vener.	19/07/2022
Comp. Dt. : 03/09/2022 Status : Completed								
1575	22090135	DERMATOLOGY OPD	FAN SLOW PROBLEM - OPP TO ROOM NO 87	Rajan. R.	CEILING FAN CAPACITOR 2.5MFT 1NO CHANGED		Jayachandran. M. - Dermatology & Vener.	03/09/2022
Comp. Dt. : 23/09/2022 Status : Completed								
1576	22090940	DERMATOLOGY OPD	NEED TO CHECK INVENTORY POWER POINT	Manikandan. M.	6A SWITCH 1NO CHANGED		Jayachandran. M. - Dermatology & Vener.	30/09/2022
Comp. Dt. : 10/10/2022 Status : Completed								
1577	22100201	DERMATOLOGY OPD	NEED TO CHANGE TUBELIGHT - ROOM NO 73 OPPOSITE	Manikandan. M.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Jayachandran. M. - Dermatology & Vener.	11/10/2022
Comp. Dt. : 21/11/2022 Status : Completed								
1578	22110885	DERMATOLOGY OPD	IN OPD WING-1 TUBELIGHT NOT WORKING	Suresh. V.	TUBE LIGHT 40W STARTER 1NO CHANGED		Jayachandran. M. - Dermatology & Vener.	22/11/2022
Comp. Dt. : 28/11/2022 Status : Completed								
1579	22111178	DERMATOLOGY OPD	IN HOD ROOM-1 TUBELIGHT NOT WORKING	Lakshmanan.V.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Jayachandran. M. - Dermatology & Vener.	29/11/2022
Comp. Dt. : 07/12/2022 Status : Completed								
1580	22120309	DERMATOLOGY OPD	IN ROOM NO.72-1 TUBELIGHT NOT WORKING	Rajan. R.	TUBE LIGHT 40W STARTER 1NO CHANGED		Jayachandran. M. - Dermatology & Vener.	08/12/2022
Comp. Dt. : 14/12/2022 Status : Completed								
1581	22120668	DERMATOLOGY OPD	NEED TO CHANGE TUBELIGHT ROOM NO 71	Dhakshinamoorthy. J	TUBE LIGHT 40W STARTER 1NO CHANGED		Jayachandran. M. - Dermatology & Vener.	15/12/2022
Comp. Dt. : 09/01/2023 Status : Completed								
1582	23010358	DERMATOLOGY OPD	IN ROOM NO.71-NO POWER SUPPLY FROM PLUGPOINT	Rajan. R.	MCB TRIP ON TO WORK PROBLEM SOLVED		Jayachandran. M. - Dermatology & Vener.	09/01/2023
Comp. Dt. : 10/01/2023								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
1583	23010384	DERMATOLOGY OPD	IN ROOM NO.72-1 TUBELIGHT NOT WORKING	Rajan. R.	TUBE LIGHT 40W STARTER 1NO CHANGED		Jayachandran. M. - Dermatology & Vener.	11/01/2023
Comp. Dt. : 30/01/2023								
Status : Completed								
1584	23011064	DERMATOLOGY OPD	NEED TO CHANGE TUBELIGHT FOR ROOM NO 74	Lakshmanan.V.	TUBE LIGHT 40W STARTER 1NO CHANGED		Jayachandran. M. - Dermatology & Vener.	31/01/2023
Comp. Dt. : 17/02/2023								
Status : Completed								
1585	23020703	DERMATOLOGY OPD	NED TO CHECK POWER - STERLIZER NOT WORKING AT PUVA THERAPY	Muthu. B.	POWER CHEKING WORK NO COMPLAINT PROBLEM SOLVED		Jayachandran. M. - Dermatology & Vener.	18/02/2023
Comp. Dt. : 27/03/2023								
Status : Completed								
1586	23031103	DERMATOLOGY OPD	FAN NOT WORKING ROOM NO 72	Lakshmanan.V.	Fan capacitor 2.5mfd 1no changed.		Jayachandran. M. - Dermatology & Vener.	30/03/2023
Dept Name : Dialysis - Electrical Maintenance								
Comp. Dt. : 12/07/2022								
Status : Completed								
1587	22070483	DIALYSIS IN 2ND FLOOR	NEED TO CHANGE TUBELIGHT FOR AURO WATER PLANT	Muthu. B.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 2NO'S CHANGED		Kalaimani. P. - Dialysis	13/07/2022
Comp. Dt. : 15/07/2022								
Status : Completed								
1588	22070580	DIALYSIS NEW UNIT IN 1ST FLOOR	NEED TABLE FAN SERVICE	Muthu. B.	PSDESTAL FAN CHEKING WORK PROBLEM SOLVED		Sarathambal. R. - Dialysis	18/07/2022
Comp. Dt. : 29/07/2022								
Status : Completed								
1589	22071076	DIALYSIS NEW UNIT IN 1ST FLOOR	PLUG POINT FOR TABLE FAN - NOT WORKING	Vijayaraghavan.B.	6A 3PIN TOP 1NO CHANGED		Malathy. M. - Dialysis	30/07/2022
Comp. Dt. : 15/11/2022								
Status : Completed								
1590	22110566	DIALYSIS IN 2ND FLOOR	3 NO'S TUBELIGHT NOT WORKING	Lakshmanan.V.	36W TUBE LIGHT 2NO'S CHANGED		Monika. A. - Dialysis	16/11/2022
Comp. Dt. : 12/12/2022								
Status : Completed								
1591	22120563	DIALYSIS IN 2ND FLOOR	SWITCH BOARD NOT IN USE-UNWANTED WIRES NEED TO BE REMOVE	Lakshmanan.V.	SWITCH BOARD CHEKING WORK PROBLEM SOLVED		Agathi. D. - Dialysis	23/12/2022

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 05/01/2023 Status : Completed								
1592	23010233	DIALYSIS IN 2ND FLOOR	2NO'S PLUG POINT NOT WORKING	Dhakshinamoorthy. J	16A SWITCH WIRE LOOSE SCREW REFIXING WORK PROBLEM SOLVED		Kalaimani. P. - Dialysis	06/01/2023
Comp. Dt. : 21/06/2023 Status : Completed								
1593	23060776	DIALYSIS NEW UNIT IN 1ST FLOOR	NEED TO CHECK PLUG POINT - NOT WORKING	Vengadessaperumal. K.	SWITCH BOARD WIRE LOOSE CONNECTION & WIRE RECONNECTION WORK PROBLEM SOLVED		Vikneswari. K. - Dialysis	23/06/2023
Dept Name : Director Office - Electrical Maintenance Comp. Dt. : 05/05/2022 Status : Completed								
1594	22050153	professor quarters	NEED TO FIX LED LIGHT INFRONT OF PROF QUARTERS	Srinivasan. R.	50W LED LIGHT 1NO FIXING WORK PROBLEM SOLVED		Mani. A. - Director Office	09/05/2022
Comp. Dt. : 04/11/2022 Status : Completed								
1595	22110149	ASSOCIATIVE PROFESSOR QUARTERS	IN GROUND FLOOR-CORRIDOR-1 TUBELIGHT NOT WORKING	Vijayaraghavan.B.	36W tube light 1no & starter 2no's changed.		Mani. A. - Director Office	07/11/2022
Comp. Dt. : 17/03/2023 Status : Completed								
1596	23030702	professor quarters	NEED TO CHANGE TUBELIGHT 1 NO & LED LIGHT 2 NOS FOR QUARTERS NO 8 [SMVEC DR.]	Muthu. B.	36W tube light 1no, starter 1no and 9W LED lamp 2no's changed.		Mani. A. - Director Office	18/03/2023
Dept Name : Dressing - Electrical Maintenance Comp. Dt. : 10/05/2022 Status : Completed								
1597	22050348	Male Surgery	NEED TO CHANGE TUBELIGHT 3 NOS - DOCTOR'S ROOM TREATMENT ROOM & PANTRY ROOM	Dhakshinamoorthy. J	MCB TRIP ON TO WORK PROBLEM SOLVED		Palanivel. D. - Dressing	12/05/2022
Comp. Dt. : 16/05/2022 Status : Completed								

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1598	22050526	Male Surgery - Ward 202	NEED TO CHANGE TUBELIGHT 3 NOS	Muthu. B.	36W TUBE LIGHT 2NO'S CHANG & 36W CHOKE 1NO CHANG & 40W STRTER 5NO'S CHANGED		Palanivel. D. - Dressing	16/05/2022
Comp. Dt. : 08/09/2022 Status : Completed								
1599	22090335	CSSD	FAN NOT WORKING	Suresh. V.	3PIN TOP 1NO CHANGED		Palanivel. D. - Dressing	09/09/2022
Comp. Dt. : 24/09/2022 Status : Completed								
1600	22090976	Male Surgery	NEED TO CHANGE RESTROOM TUBELIGHT FOR DOCTOR'S ROOM AT SURGERY WARD 201 & 202	Rajan. R.	9W LED lamp 1no changed.		Dhachinamoorthy.R. - Dressing	26/09/2022
Comp. Dt. : 16/12/2022 Status : Completed								
1601	22120774	CSSD	NEED TO CHANGE TUBELIGHT 2NOS	Babu. D.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Vijayasethu. I. - Dressing	17/12/2022
Comp. Dt. : 30/12/2022 Status : Completed								
1602	22121369	Male Surgery - Ward 202	IN PANTRY ROOM-1 TUBELIGHT NOT WORKING	Vijayaraghavan.B.	Tube light starter 1no changed.		Palanivel. D. - Dressing	31/12/2022
Comp. Dt. : 04/01/2023 Status : Completed								
1603	23010152	Male Surgery - Ward 202	IN TREATMENT ROOM-2 NO'S TUBELIGHT NOT WORKING	Lakshmanan.V.	TUBE LIGHT 40W STARTER 2NO'S CHANGED		Palanivel. D. - Dressing	05/01/2023
Comp. Dt. : 08/04/2023 Status : Completed								
1604	23040218	Male Surgery - Ward 202	NEED TO CHECK STERLIZER & PLUG POINT - NOT WORKING	Srinivasan. R.	16A Top 1no & 6A Socket 1no changed.		Dhachinamoorthy.R. - Dressing	08/04/2023
Comp. Dt. : 28/04/2023 Status : Completed								
1605	23040971	Male Surgery - Ward 201	FAN SOUND PROBLEM	Muthu. B.	CEILING FAN BEARING CHANG & FAN REFIXING WORK PROBLEM SOLVED		Dhachinamoorthy.R. - Dressing	09/05/2023
1606	23040972	Male Surgery - Ward 202	NEED TO CHANGE TUBELIGHT 2 NOS FOR DRESSING ROOM	Muthu. B.	TUBE LIGHT 40W STARTER 2NO'S CHANG & 6A SWITCH 1NO CHANGED		Dhachinamoorthy.R. - Dressing	29/04/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 08/05/2023 Status : Completed								
1607	23050278	Male Surgery - Ward 202	FAN NOT WORKING - AT NURSE'S CABIN	Muthu. B.	CEILING FAN WIRE LOOSE CONNECTION & WIRE RECONNECTION WORK PROBLEM SOLVED		Dhachinamoorthy.R. - Dressing	12/05/2023
Comp. Dt. : 07/06/2023 Status : Completed								
1608	23060246	CSSD	FAN NOT WORKING [STANDING FAN]	Rajan. R.	PEDESTAL FAN 1NO WIRE CUT RECONNECTION WORK PROBLEM SOLVED		Vijayasethu. I. - Dressing	09/06/2023
Comp. Dt. : 16/06/2023 Status : Completed								
1609	23060607	Male Surgery - Ward 202	FAN GOING SLOW FROM DRESSING ROOM	Manimaran. P.	CEILING FAN CAPACITOR 2.5MFT 1NO CHANGED		Dhachinamoorthy.R. - Dressing	17/06/2023
Comp. Dt. : 17/06/2023 Status : Completed								
1610	23060638	CSSD	NEED TO CHECK FAN - SOUND PROBLEM	Muthu. B.	WALLMOUNTING FAN 1NO SERVICE WORK PROBLEM SOLVED		Shankar. A. - Dressing	19/06/2023
Comp. Dt. : 19/06/2023 Status : Completed								
1611	23060649	CSSD	NEED TO CHANGE TUBELIGHT	Lakshmanan.V.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Shankar. A. - Dressing	20/06/2023
Comp. Dt. : 24/06/2023 Status : Completed								
1612	23060902	CSSD	WATER LEAKAGE IN HEATER - NEED TO CHECK	Manimaran. P.	WATER HEATER 1NO CHEKING WORK NO COMPLAINT		Shankar. A. - Dressing	26/06/2023
Dept Name : EMERGENCY MEDICINE - Electrical Maintenance Comp. Dt. : 13/05/2022 Status : Completed								
1613	22050461	Casualty	LED LIGHT NOT WORKING	Lakshmanan.V.	36W TUBE LIGHT SET 1NO REFIXING WORK PROBLEM SOLVED		Sasirekha. K. - EMERGENCY MEDICINE	14/05/2022
Comp. Dt. : 20/05/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1614	22050743	Casualty	FAN NOT WORKING AT ENTRANCE I CABIN	Manikandan. M.,Vijayaraghavan.B.,Manimaran. P.	CEILING FAN 1NO COIL PROBLEM REMOVING TO ELECTRICAL ROOM. Spare Fan fixed.		Rajipriya. K. - EMERGENCY MEDICINE	26/05/2022
		Comp. Dt. : 26/05/2022 Status : Completed						
1615	22050999	Casualty	FAN NOT WORKING	Manimaran. P.	Ceiling fan refixed.		Rajipriya. K. - EMERGENCY MEDICINE	26/05/2022
		Comp. Dt. : 07/06/2022 Status : Completed						
1616	22060249	Female Casulaty	NEED TO CHANGE TUBELIGHT	Vijayaraghavan.B.	22W LED LIGHT 1NO CHANGED		Devi. S - EMERGENCY MEDICINE	07/06/2022
		Comp. Dt. : 09/06/2022 Status : Completed						
1617	22060356	Casualty	NEED TO CHECK & CHANGE PLUG POINT - DAMAGE	Srinivasan. R.	16A SOCKET 1NO REFIXING WORK PROBLEM SOLVED		Kazhagamani. V. - EMERGENCY MEDICINE	10/06/2022
		Comp. Dt. : 13/06/2022 Status : Completed						
1618	22060475	Casualty	NEED TO CHANGE TUBELIGHT - NOT WORKING	Muthu. B.	36W tube light 1no changed.		Bhuvaneswari. M. - ENT & Ophthal Ward	14/06/2022
		Comp. Dt. : 24/06/2022 Status : Completed						
1619	22060864	Female Casulaty	X RAY LOBBY NOT WORKING	Sridharan. R	X RAY LABY WIRE CUT RECONNECTION WORK PROBLEM SOLVED		Devi. S - EMERGENCY MEDICINE	25/06/2022
1620	22060895	Female Casulaty	NEED TO CHECK SWITCH BOARD	Manimaran. P.	MCB TRIP ON TO WORK PROBLEM SOLVED		Vinasri. R. - EMERGENCY MEDICINE	27/06/2022
		Comp. Dt. : 08/07/2022 Status : Completed						
1621	22070311	Casualty	NEED TO FIX NEW TUBELIGHT [2NOS] FOR DUTY DOCTOR'S ROOM	Muthu. B.	36W TUBE LIGHT 1NO CHANGED		Kanimozhi. E. - EMERGENCY MEDICINE	11/07/2022
1622	22070319	Female Casulaty	NEED TO REMOVE EXHAUST FAN	Vijayaraghavan.B.	18" EXHAUST FAN 1NO REMOVING TO ELECTRICAL ROOM		Kanimozhi. E. - EMERGENCY MEDICINE	11/07/2022
		Comp. Dt. : 09/07/2022 Status : Completed						


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1623	22070396	marchuary	NEED TO CHECK POWER - PROBLEM	Dhakshinamoorthy. J	6M PLATE 1NO,6A SWITCH 4NO'S,6A SOCKET 1NO CHANG & LINE CONNECTION WORK PROBLEM SOLVED		Kanimozhi. E. - EMERGENCY MEDICINE	12/07/2022
Comp. Dt. : 19/07/2022 Status : Completed								
1624	22070700	Casualty	NEED TO CHECK POWER FOR PLUGPOINT AT PRIORITY ROOM NO 1	Srinivasan. R.	SWITCH BOARD WIRE LOOSE SCREW REFIXING WORK PROBLEM SOLVED		Kazhagamani. V. - EMERGENCY MEDICINE	20/07/2022
Comp. Dt. : 22/07/2022 Status : Completed								
1625	22070838	Casualty	X-RAY MACHINE SHOCK COMING	Vijayaraghavan.B.	X-RAY MACHINE CHEKING WORK BIOMEDICAL COMPLAINT		Veeramani. D. - EMERGENCY MEDICINE	23/07/2022
Comp. Dt. : 23/07/2022 Status : Completed								
1626	22070879	Casualty	FAN & TUBELIGHT NOT WORKING	Vijayaraghavan.B.	MCB TRIP ON TO WORK PROBLEM SOLVED		Kanimozhi. E. - EMERGENCY MEDICINE	25/07/2022
Comp. Dt. : 26/07/2022 Status : Completed								
1627	22070984	Female Casulaty	NEED TO CHANGE TUBELIGHT FOR ENTRANCE	Muthu. B.	TUBE LIGHT 40W STARTER 1NO CHANGED		Seethalakshmi. R. - EMERGENCY MEDICINE	27/07/2022
Comp. Dt. : 30/07/2022 Status : Completed								
1628	22071090	Casualty	NEED DIRECT CONNECTION FOR FRIDGE	Vijayaraghavan.B.	16A SWITCH 1NO CHANG & 16A SOCKET 1NO CHANGED		Kanimozhi. E. - EMERGENCY MEDICINE	01/08/2022
Comp. Dt. : 05/08/2022 Status : Completed								
1629	22080199	Casualty	FAN NOT WORKING - FEMALE P G ROOM	Manimaran. P.	CEILING FAN REGULATOR 1NO CHANGED		Kalaivani. N. - EMERGENCY MEDICINE	06/08/2022
Comp. Dt. : 10/08/2022 Status : Completed								
1630	22080358	Casualty	NEED TO CHANGE TUBELIGHT FOR DOCTOR'S RESTROOM	Rajan. R.	9W LED LIGHT 1NO CHANGED		Kanimozhi. E. - EMERGENCY MEDICINE	11/08/2022
Comp. Dt. : 11/08/2022								

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
1631	22080404	Casualty	NEED TO CHANGE TUBELIGHT FOR ROOM NO 39	Rajan. R.	9W LED LIGHT 1NO CHANGED		Kazhagamani. V. - EMERGENCY MEDICINE	11/08/2022
Comp. Dt. : 20/08/2022								
Status : Completed								
1632	22080675	Casualty	FAN NOT WORKING IN [A P] DOCTOR'S ROOM	Muthu. B.	CEILING FAN CAPACITOR 2.5MFT 1NO CHANGED		Kanimozhi. E. - EMERGENCY MEDICINE	22/08/2022
Comp. Dt. : 27/08/2022								
Status : Completed								
1633	22080940	Casualty	NEED TO CHANGE TUBELIGHT FOR FEMALE ROOM [3NOS]	Vengadessaperumal. K.	36W TUBE LIGHT 2NO'S CHANG & 40W STARTER 1NO CHANGED		Kanimozhi. E. - EMERGENCY MEDICINE	27/08/2022
Comp. Dt. : 30/08/2022								
Status : Completed								
1634	22081011	Casualty	NEED TO CHECK ALL PLUGPOINT - DAMAGE & NOT WORKING	Suresh. V.	3M PLATE 1NO CHANGED		Sasirekha. K. - EMERGENCY MEDICINE	02/09/2022
1635	22081045	Casualty	NEED TO CHANGE TUBELIGHT	Manimaran. P.	36W TUBE LIGHT 1NO CHANGED		Kalaivani. N. - EMERGENCY MEDICINE	01/09/2022
Comp. Dt. : 01/09/2022								
Status : Completed								
1636	22090025	Casualty	FAN SOUND PROBLEM IN FEMALE P.G. DOCTORS'S ROOM	Muthu. B.,Lakshmanan.V.,Manimaran. P.	CEILING FAN BEARING 2NO'S CHAMNG & FAN 1NO REFIXNG WORK PROBLEM SOLVED		Rajipriya. K. - EMERGENCY MEDICINE	02/09/2022
Comp. Dt. : 02/09/2022								
Status : Completed								
1637	22090072	Casualty	TUBE LIGHT NOT WORKING IN DOCTORS AND PATIENTS RESTROOM	Muthu. B.	36W TUBE LIGHT 1NO CHANGED		Devi. S - EMERGENCY MEDICINE	02/09/2022
Comp. Dt. : 06/09/2022								
Status : Completed								
1638	22090216	Casualty	NEED TO CHANGE TUBELIGHT FOR DOCTOR'S RESTROOM	Manikandan. M.	TUBE LIGHT 40W STARTER 1NO CHANGED		Kanimozhi. E. - EMERGENCY MEDICINE	07/09/2022
Comp. Dt. : 09/09/2022								
Status : Completed								
1639	22090356	Female Casualty	TUBE LIGHT NOT WORKING	Muthu. B.	TUBE LIGHT 40W STARTER 1NO CHANGED		Seethalakshmi. R. - EMERGENCY MEDICINE	10/09/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 14/09/2022 Status : Completed								
1640	22090533	Casualty	NEED TO CHECK EXTN BOX - NOT WORKING PROBLEM FOR X RAY MACHINE	Suresh. V.	6A 3PIN TOP 1NO CHANG & 16A SOCKET 1NO CHANG & 8M PLATE 1NO CHANGED		Rajipriya. K. - EMERGENCY MEDICINE	15/09/2022
Comp. Dt. : 22/09/2022 Status : Completed								
1641	22090902	Casualty	NEED TO CHECK PLUG POINT - NOT WORKING	Rajan. R.	MCB TRIP ON TO WORK PROBLEM SOLVED		Rajipriya. K. - EMERGENCY MEDICINE	23/09/2022
Comp. Dt. : 24/09/2022 Status : Completed								
1642	22090978	Casualty	NEED TO CHECK EXTN BOX - NOT WORKING	Vijayaraghavan.B.	Wire problem - solved.		Kanimozhi. E. - EMERGENCY MEDICINE	26/09/2022
Comp. Dt. : 27/09/2022 Status : Completed								
1643	22091083	Casualty	NEED TO CHANGE TUBELIGHT	Lakshmanan.V.	36W TUBE LIGHT 1NO CHANGED		Seethalakshmi. R. - EMERGENCY MEDICINE	28/09/2022
Comp. Dt. : 28/09/2022 Status : Completed								
1644	22091101	Female Casulaty	NEED TO CHANGE TUBELIGHT 2 NOS	Manikandan. M.	36W TUBE LIGHT FITTING 1NO CHANG & 40W STARTER 1NO CHANG & 36W TUBE LIGHT 1NO CHANGED		Devi. S - EMERGENCY MEDICINE	28/09/2022
Comp. Dt. : 30/09/2022 Status : Completed								
1645	22091221	Casualty	NEED TO CHECK FAN & TUBELIGHT 2 NOS NOT WORKING	Lakshmanan.V.	TUBE LIGHT 40W STARTER 1NO CHANGED		Seethalakshmi. R. - EMERGENCY MEDICINE	01/10/2022
Comp. Dt. : 14/10/2022 Status : Completed								
1646	22100480	Female Casulaty	NEED TO CHECK FAN & LIGHT - NOT WORKING	Manikandan. M.	DB WIRE CUT RECONNECTION WOEK PROBLEM SOLVED		Jasmin. G. - EMERGENCY MEDICINE	15/10/2022
Comp. Dt. : 18/10/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1647	22100601	Casualty	TUBELIGHT 2 NOS NOT WORKING	Muthu. B.	36W TUBE LIGHT 2NO'S CHANGED		Seethalakshmi. R. - EMERGENCY MEDICINE	19/10/2022
Comp. Dt. : 22/10/2022		Status : Completed						
1648	22100756	Casualty	ALL FANS CLEANING WORK	Lakshmanan.V.	ALL CEILING FAN CLEANING WORK PROBLEM SOLVED		Kanimozhi. E. - EMERGENCY MEDICINE	25/10/2022
Comp. Dt. : 17/11/2022		Status : Completed						
1649	22110738	Casualty	STERLIZER NOT WORKING	Dhakshinamoorthy. J	STERLIZER 2KW COIL 1NO CHANGED		Kanimozhi. E. - EMERGENCY MEDICINE	18/11/2022
Comp. Dt. : 25/11/2022		Status : Completed						
1650	22111118	Casualty	IN DOCTOR'S ROOM-LED BULB NOT WORKING	Muthu. B.	20W TUBE LIGHT FITTING FIXING & LINE CONNECTION WORK PROBLEM SOLVED		Veeramani. D. - EMERGENCY MEDICINE	28/11/2022
Comp. Dt. : 07/12/2022		Status : Completed						
1651	22120337	Casualty	FAN NOT WORKING - DOCTOR'S ROOM	Dhakshinamoorthy. J	6A SWITCH 1NO CHANGED		Kanimozhi. E. - EMERGENCY MEDICINE	08/12/2022
Comp. Dt. : 19/12/2022		Status : Completed						
1652	22120846	Casualty	TUBELIGHT NOT WORKING - 1 NOS	Damodharan. V.	36W TUBE LIGHT LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Sasirekha. K. - EMERGENCY MEDICINE	19/12/2022
Comp. Dt. : 21/01/2023		Status : Completed						
1653	23010759	Female Casulaty	NEED ALL FAN CLEANING WORK	Muthu. B.	ALL CEILING FAN CLEANING WORK PROBLEM SOLVED		Sowmiya. S. - EMERGENCY MEDICINE	23/01/2023
1654	23010781	Casualty	TORCH LIGHT [2NOS] NOT WORKING	Sathishkumar. R.	TORCH LIGHT CHEKING WORK BOARD PROBLEM		Kanimozhi. E. - EMERGENCY MEDICINE	23/01/2023
Comp. Dt. : 24/01/2023		Status : Completed						
1655	23010863	Casualty	TORCH LIGHT NOT WORKING	Sathishkumar. R.	TORCH LIGHT 3NO'S SERVICE WORK CHEKING WORK PROBLEM SOLVED		Kanimozhi. E. - EMERGENCY MEDICINE	31/01/2023

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 30/01/2023								
Status : Completed								
1656	23011057	Casualty	NEED TO CHANGE TUBELIGHT FOR PG RESTROOM	Lakshmanan.V.	TUBE LIGHT 20W CHOKE 1NO CHANGED		Kanimozhi. E. - EMERGENCY MEDICINE	31/01/2023
Comp. Dt. : 28/02/2023								
Status : Completed								
1657	23021080	Female Casulaty	XRAY MACHINE WIRE PROBLEM	Muthu. B.	16A 3PIN TOP 1NO CHANGED		Sowmiya. S. - EMERGENCY MEDICINE	01/03/2023
1658	23021087	Casualty	2 TUBELIGHTS NOT WORKING	Muthu. B.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 2NO'S CHANGED		Sasirekha. K. - EMERGENCY MEDICINE	01/03/2023
Comp. Dt. : 06/03/2023								
Status : Completed								
1659	23030217	Casualty	NEED TO CHANGE TUBELIGHT FOR FEMALE DOCTOR'S ROOM	Muthu. B.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Kanimozhi. E. - EMERGENCY MEDICINE	08/03/2023
Comp. Dt. : 08/03/2023								
Status : Completed								
1660	23030309	Casualty	NEED TO REFIX SWITCH BOX	Rajan. R.	6A SOCKET 1NO REFIXING WORK PROBLEM SOLVED		Kanimozhi. E. - EMERGENCY MEDICINE	09/03/2023
Comp. Dt. : 10/03/2023								
Status : Completed								
1661	23030429	Casualty	NEED TO CHECK FAN & TUBELIGHT - NOT WORKING	Muthu. B.	MCB TRIP ON TO WORK PROBLEM SOLVED		Kanimozhi. E. - EMERGENCY MEDICINE	11/03/2023
Comp. Dt. : 17/03/2023								
Status : Completed								
1662	23030683	Casualty	FAN NOT WORKING NEED URGENT SERVICE	Vijayaraghavan.B.	Fan capacitor 2.5mfd 1no changed.		Sasirekha. K. - EMERGENCY MEDICINE	18/03/2023
Comp. Dt. : 23/03/2023								
Status : Completed								
1663	23030984	Casualty	NEED TO CHANGE TUBELIGHT 2 NOS	Lakshmanan.V.	R.no.33 - 36W tube light 1no, starter 2no's & Side holder 1no changed.		Kanimozhi. E. - EMERGENCY MEDICINE	24/03/2023
Comp. Dt. : 29/03/2023								
Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1664	23031264	Casualty	NEED TO CHANGE TUBELIGHT FOR PATIENT RESTROOM	Vijayaraghavan.B.	36W E.choke 1no changed.		Kanimozhi. E. - EMERGENCY MEDICINE	30/03/2023
		Comp. Dt. : 05/04/2023 Status : Completed						
1665	23040142	Casualty	NEED TO CHECK SWITCH BOARD - PRIORITY RED SWITCH NOT WORKING	Rajan. R.	MCB trip - Trip ON.		Raja. A. - EMERGENCY MEDICINE	05/04/2023
		Comp. Dt. : 08/04/2023 Status : Completed						
1666	23040220	Casualty	NEED TO CHANGE TUBELIGHT	Srinivasan. R.	36W tube light 1no & starter 1no changed.		Sasirekha. K. - EMERGENCY MEDICINE	08/04/2023
1667	23040232	FEVER CLINIC	FAN NOT WORKING	Manikandan. M.	Wire problem - solved.		Sasirekha. K. - EMERGENCY MEDICINE	10/04/2023
		Comp. Dt. : 11/04/2023 Status : Completed						
1668	23040316	Casualty	NEED TO CHANGE TUBELIGHT FOR DOCTOR'S ROOM	Muthu. B.	Tube light starter 1no changed.		Sasirekha. K. - EMERGENCY MEDICINE	11/04/2023
		Comp. Dt. : 15/04/2023 Status : Completed						
1669	23040443	Casualty	NEED TO CHANGE TUBELIGHT 2 NOS	Muthu. B.	36W TUBE LIGHT 40W STARTER 2NO'S CHANGED		Raja. A. - EMERGENCY MEDICINE	16/04/2023
		Comp. Dt. : 17/04/2023 Status : Completed						
1670	23040533	Casualty	SOUND PROBLEM IN EXHAUST FAN	Srinivasan. R.	EXHAUST FAN SCREW REFIXING WORK PROBLEM SOLVED		Kazhagamani. V. - EMERGENCY MEDICINE	18/04/2023
		Comp. Dt. : 02/05/2023 Status : Completed						
1671	23050067	Casualty	NEED TO CHANGE TUBELIGHT	Vijayaraghavan.B.	36W TUBE LIGHT 1NO CHANGED		Anbarasan. A. - EMERGENCY MEDICINE	03/05/2023
		Comp. Dt. : 09/05/2023 Status : Completed						
1672	23050391	Male Surgery - Ward 201	FAN NOT WORKING	Dhakshinamoorthy. J	CEILING FAN CAPACITOR 2.5MFT 1NO CHANGED		Kanimozhi. E. - EMERGENCY MEDICINE	10/05/2023

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 20/05/2023 Status : Completed								
1673	23050832	Casualty	NEED TO CHANGE TUBELIGHT FOR PREORITY NO 3	Srinivasan. R.	9W LED LIGHT 1NO CHANGED		Dhanalakshmi. M. - EMERGENCY MEDICINE	20/05/2023
Comp. Dt. : 22/05/2023 Status : Completed								
1674	23050858	FEVER CLINIC	FAN NOT WORKING	Rajan. R.	PEDESTAL FAN WIRE CUT RECONNECTION WORK PROBLEM SOLVED		Kazhagamani. V. - EMERGENCY MEDICINE	23/05/2023
Comp. Dt. : 24/05/2023 Status : Completed								
1675	23050942	FEVER CLINIC	NEED TO CHECK FAN - NOT WORKING	Vijayaraghavan.B.	6A 3PIN TOP 1NO FIXING WORK PROBLEM SOLVED		Sasirekha. K. - EMERGENCY MEDICINE	24/05/2023
Comp. Dt. : 29/05/2023 Status : Completed								
1676	23051117	Casualty	PLUG POINT 2 NOS NOT WORKING	Srinivasan. R.	MCB TRIP ON TO WORK PROBLEM SOLVED		Kanimozhi. E. - EMERGENCY MEDICINE	29/05/2023
Comp. Dt. : 02/06/2023 Status : Completed								
1677	23060049	Male Surgery - Ward 204	FAN NOT WORKING	Muthu. B.	CEILING FAN CAPACITOR 2.5MFT 1NO CHANGED		Priyadharshini. K. - Gynac Ward	02/06/2023
1678	23060055	Casualty	FAN SLOW PROBLEM AT PROCEDURE ROOM	Muthu. B.	CEILING FAN CAPACITOR 2.5MFT 1NO CHANGED		Kanimozhi. E. - EMERGENCY MEDICINE	02/06/2023
Comp. Dt. : 08/06/2023 Status : Completed								
1679	23060256	Casualty	NEED TO CHANGE TUBELIGHT	Lakshmanan.V.	TUBE LIGHT 40W STARTER 1NO CHANGED		Kanimozhi. E. - EMERGENCY MEDICINE	09/06/2023
1680	23060266	Male Medical - Ward 301	NEED TO CHANGE TUBELIGHT FOR DOCTOR'S ROOM	Vijayaraghavan.B.	36W TUBE LIGHT 1NO CHANGED		Sumithradevi. S. - EMERGENCY MEDICINE	09/06/2023
Comp. Dt. : 15/06/2023 Status : Completed								
1681	23060521	Casualty	PLUG POINT POWER PROBLEM	Vijayaraghavan.B.	MCB TRIP ON TO WORK PROBLEM SOLVED		Racida. R. - EMERGENCY MEDICINE	16/06/2023
Comp. Dt. : 19/06/2023 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1682	23060654	Casualty	NEED TO CLEAN ALL FANS	Vijayaraghavan.B.	ALL CEILING FAN CLEANING WORK PROBLEM SOLVED		Sasirekha. K. - EMERGENCY MEDICINE	21/06/2023
Comp. Dt. : 22/06/2023 Status : Completed								
1683	23060804	Casualty	NEED CLEANING WORK FOR FRIDGE NEAR POWERCART, EXHAUST FAN & FANS	Vijayaraghavan.B.	ALL CEILING FAN & ALL EXHAUST FAN CLEANING WORK PROBLEM SOLVED		Sasirekha. K. - EMERGENCY MEDICINE	23/06/2023
Dept Name : Endoscopy - Electrical Maintenance Comp. Dt. : 08/11/2022 Status : Completed								
1684	22110300	Injection Room - OPD	TUBELIGHT NOT WORKING	Rajan. R.	TUBE LIGHT 40W STARTER 1NO CHANGED		Ananthi. S. - P.H.C. - Tiruvonnainallur	09/11/2022
Comp. Dt. : 18/11/2022 Status : Completed								
1685	22110779	Endoscopy	NEED FAN SERVICE	Muthu. B.	CEILING FAN CLEANING WORK PROBLEM SOLVED		Vijayalakshmi. G. - Endoscopy	21/11/2022
Comp. Dt. : 19/11/2022 Status : Completed								
1686	22110821	Endoscopy	FAN DUST NEED TO BE CLEAN	Muthu. B.	CEILING FAN CLEANING WORK PROBLEM SOLVED		Vijayalakshmi. G. - Endoscopy	21/11/2022
Comp. Dt. : 30/01/2023 Status : Completed								
1687	23011035	Endoscopy	NEED TO CHECK POWER	Rajan. R.	MCB TRIP ON TO WORK PROBLEM SOLVED		Vijayalakshmi. G. - Endoscopy	30/01/2023
Comp. Dt. : 11/05/2023 Status : Completed								
1688	23050452	Injection Room - OPD	NEED TO CHANGE TUBELIGHT	Damodharan. V.	TUBE LIGHT 40W STARTER 1NO CHANGED		Tamilselvi. E. - Endoscopy	11/05/2023
Comp. Dt. : 20/06/2023 Status : Completed								
1689	23060693	TB & Chest OPD	NEED TO CHANGE TUBELIGHT	Vengadessaperumal. K.	TUBE LIGHT WIRE LOOSE RECONNECTION WORK PROBLEM SOLVED		Vijayalakshmi. G. - Endoscopy	20/06/2023
Dept Name : ENT & Ophthal Ward - Electrical Maintenance Comp. Dt. : 10/08/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1690	22080373	ENT WARD-408	NEED TO REFIX PLUG POINT - DAMAGE AND UNFIX	Lakshmanan.V.	PLUG POINT SCREW REFIXING WORK PROBLEM SOLVED		Jayalakshmi. J. - ENT & Ophthal Ward	11/08/2022
Comp. Dt. : 26/08/2022 Status : Completed								
1691	22080882	Female Medical - Ward 305	NEED TO REPLACE SWITCH BOX [ANOTHER PLACE]	Srinivasan. R.	SWITCH BOX CHEKING WORK NO COMPLAINT PROBLEM SOLVED		Bhuvaneswari. M. - ENT & Ophthal Ward	29/08/2022
Comp. Dt. : 06/09/2022 Status : Completed								
1692	22090234	Female Medical Ward	NEED TO CHANGE TUBELIGHT FOR ENTRANCE WAY BETWEEN WARD NO 305 & 306	Lakshmanan.V.	36W TUBE LIGHT 1NO CHANGED		Bhuvaneswari. M. - ENT & Ophthal Ward	07/09/2022
Comp. Dt. : 15/09/2022 Status : Completed								
1693	22090601	ENT WARD-407	NEED TO CHECK X RAY MACHINE SWITCH - NOT WORKING	Manimaran. P.	X RAY LABY 6A TOP 1NO CHANGED		Jayalakshmi. J. - ENT & Ophthal Ward	16/09/2022
Comp. Dt. : 16/09/2022 Status : Completed								
1694	22090635	ENT WARD-407	NEED TO CHECK AND CHANGE X RAY LOBBY SWITCH - NOT WORKING	Rajan. R.	9W LED LIGHT 1NO CHANG & BABY HOLDER 1NO CHANGED		Jayalakshmi. J. - ENT & Ophthal Ward	16/09/2022
Comp. Dt. : 20/09/2022 Status : Completed								
1695	22090786	ENT WARD-407	SWITCH BOARD NOT WOKRING	Muthu. B.	SWITCH BOARD CHEKING WORK NO PROBLEM SOLVED		Jayalakshmi. J. - ENT & Ophthal Ward	21/09/2022
Comp. Dt. : 05/10/2022 Status : Completed								
1696	22100032	Ophthalmology Ward	NEED TO CHANGE TUBELIGHT FOR WARD NO 408	Rajan. R.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Jayalakshmi. J. - ENT & Ophthal Ward	06/10/2022
1697	22100079	ENT WARD-407	NEED TO REFIX SWITCH BOX [2NOS] DAMAGE & NOT WORKING	Dhakshinamoorthy. J	3M PLATE-1NO,6A SOCKET-1NO,6A SWITCH-1NO CHANG & LINE CONNECTION WORK PROBLEM SOLVED		Jayalakshmi. J. - ENT & Ophthal Ward	06/10/2022
Comp. Dt. : 06/10/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1698	22100102	Ophthalmology Ward	NEED TO CHECK X RAY LOBBY PLUG POINT CABLE - DAMAGE & NOT WORKING - WARD NO 408	Rajan. R.	6A SOCKET 1NO CHANGED		Jayalakshmi. J. - ENT & Ophthal Ward	07/10/2022
		Comp. Dt. : 12/10/2022 Status : Completed						
1699	22100326	ENT WARD-407	NEED TO BE CHANGE X RAY LOBBY WIRE	Suresh. V.	3MTR WIRE CHANG & LINE CONNECTION WORK PROBLEM SOLVED		Jayalakshmi. J. - ENT & Ophthal Ward	12/10/2022
		Comp. Dt. : 14/10/2022 Status : Completed						
1700	22100442	ENT WARD-407	NEED TO REFIX SWITCH BOARD - DAMAGE	Lakshmanan.V.	6A SWITCH 2NO'S CHANGED		Jayalakshmi. J. - ENT & Ophthal Ward	15/10/2022
1701	22100459	Female Medical - Ward 305	NEED TO CHECK PLUG POINT AT PANTRY ROOM	Muthu. B.	SWITCH BOARD SCREW REFIXING WORK PROBLEM SOLVED		Bhuvaneswari. M. - ENT & Ophthal Ward	15/10/2022
		Comp. Dt. : 15/10/2022 Status : Completed						
1702	22100498	ENT WARD-407	NEED TO REFIX SCREW FOR SWITCH BOX	Dhakshinamoorthy. J	SWITCH BOARD SCREW REFIXING WORK PROBLEM SOLVED		Jayalakshmi. J. - ENT & Ophthal Ward	17/10/2022
		Comp. Dt. : 18/10/2022 Status : Completed						
1703	22100557	Female Medical Ward	NEED TO CHECK & SERVICE [CLEANING] ALL FANS - NOT WORKING AT WARD NO 305 & 306	Thillaikumar. R.	ALL CEILING FAN CLEANING WORK PROBLEM SOLVED		Bhuvaneswari. M. - ENT & Ophthal Ward	25/10/2022
1704	22100583	ENT WARD-407	NEED TO REFIX SWITCH BOARD - BROKEN	Lakshmanan.V.	SWITCH BOARD SCREW REFIXING WORK PROBLEM SOLVED		Jayalakshmi. J. - ENT & Ophthal Ward	19/10/2022
		Comp. Dt. : 31/10/2022 Status : Completed						
1705	22100983	Female Medical - Ward 305	FAN NOT WORKING	Muthu. B.	Fan capacitor 2.5mgd 1no changed.		Bhuvaneswari. M. - ENT & Ophthal Ward	31/10/2022
		Comp. Dt. : 16/11/2022 Status : Completed						
1706	22110639	ENT WARD-407	IN TREATMENT ROOM-1 TUBELIGHT NOT WORKING	Dhakshinamoorthy. J	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Jayalakshmi. J. - ENT & Ophthal Ward	17/11/2022
		Comp. Dt. : 22/11/2022 Status : Completed						


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1707	22110898	Female Ophthalmology - Ward 408	NEED TO CHANGE TUBELIGHT	Lakshmanan.V.	36W TUBE LIGHT 2NO'S CHANG & CHOKE 1NO CHANG & 40W STARTER 2NO'S CHANGED		Jayalakshmi. J. - ENT & Ophthal Ward	23/11/2022
1708	22110964	Female Ophthalmology - Ward 408	NEED TO CHECK PLUG POINT - NOT WORKING	Lakshmanan.V.	ALL SWITCH BOARD CHEKING WORK PROBLEM SOLVED		Jayalakshmi. J. - ENT & Ophthal Ward	24/11/2022
Comp. Dt. : 12/12/2022 Status : Completed								
1709	22120534	ENT WARD-407	IN PATIENT BATHROOM-1 TUBELIGHT NOT WORKING	Muthu. B.	36W TUBE LIGHT 1NO CHANGED		Jayalakshmi. J. - ENT & Ophthal Ward	13/12/2022
Comp. Dt. : 22/12/2022 Status : Completed								
1710	22121038	ENT WARD-408	NEED TO CHECK SWITCH BOARD - SWITCH BOARD PROBLEM	Muthu. B.	MCB TRIP ON TO WORK PROBLEM SOLVED		Jayalakshmi. J. - ENT & Ophthal Ward	23/12/2022
Comp. Dt. : 23/12/2022 Status : Completed								
1711	22121092	Female Ophthalmology - Ward 408	NEED TO CHECK SWITCH BOX POWER SUPPLY PROBLEM	Dhakshinamoorthy. J	6A SOCKET WIRE LOOSE SCREW REFIXING WORK PROBLEM SOLVED		Jayalakshmi. J. - ENT & Ophthal Ward	24/12/2022
Comp. Dt. : 13/01/2023 Status : Completed								
1712	23010581	ENT WARD-407	SWITCH BOARD NOT WORKING	Lakshmanan.V.	MCB TRIP ON TO WORK PROBLEM SOLVED		Madhiveni. M. - ENT & Ophthal Ward	14/01/2023
Comp. Dt. : 19/01/2023 Status : Completed								
1713	23010679	Female Medical Ward	NEED SERVICE FOR ALL FANS & SWITCH BOXES AT WARD NO 305 & 306	Manikandan. M.	ALL CEILING FAN CLANING WORK & ALL SWITCH BOARD CHEING WORK PROBLEM SOLVED		Bhuvaneswari. M. - ENT & Ophthal Ward	23/01/2023
Comp. Dt. : 28/01/2023 Status : Completed								
1714	23011021	Male Ortho - Ward 403	NEED FAN CLEANING WORK	Srinivasan. R.	ALL CEILING FAN CLEANING WORK PROBLEM SOLVED		Vijayakumar. G. - ENT & Ophthal Ward	06/02/2023
Comp. Dt. : 09/02/2023 Status : Completed								
1715	23020317	Female Medical - Ward 305	FAN CLEANING WORK	Srinivasan. R.	ALL CEILING FAN CLEANING WORK PROBLEM SOLVED		Bhuvaneswari. M. - ENT & Ophthal Ward	16/02/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 16/02/2023								
Status : Completed								
1716	23020630	Female Medical - Ward 305	WARD NOS-305 AND 306- -ALL FANS CLEANING WORK	Lakshmanan.V.	36W TUBE LIGHT 2NO'S CHANG & 40W STARTER 2NO'S CHANG & CEILING FAN CAPACITOR 2.5MFT 1NO CHANGED		Bhuvaneswari. M. - ENT & Ophthal Ward	17/02/2023
Comp. Dt. : 27/02/2023								
Status : Completed								
1717	23020995	ENT WARD-407	NEED TO REFIX SWITCH BOARD - NOT WORKING	Muthu. B.	6A SWITCH 2NO'S CHANG & SWITCH BOARD SCREW 1NO REFIXING WORK PROBLEM SOLVED		Jayalakshmi. J. - ENT & Ophthal Ward	28/02/2023
Comp. Dt. : 07/03/2023								
Status : Completed								
1718	23030268	ENT WARD	NEED FAN CLEANING WORK WARD NO 307 & 308	Vijayaraghavan.B.	ALL CELING FAN CLEANING WORK PROBLEM SOLVED		Madhiveni. M. - ENT & Ophthal Ward	13/03/2023
1719	23030291	ENT WARD-407	NEED TO REFIX SWITCH BOARD	Vijayaraghavan.B.	SWITCH BOARD SCREW REFIXING WORK PROBLEM SOLVED		Jayalakshmi. J. - ENT & Ophthal Ward	08/03/2023
Comp. Dt. : 09/03/2023								
Status : Completed								
1720	23030345	Female Medical - Ward 305	NEED TO CHECK PLUG POINT NOT WORKING AT TREATMENT ROOM	Manimaran. P.	Switch problem - solved.		Bhuvaneswari. M. - ENT & Ophthal Ward	10/03/2023
Comp. Dt. : 23/03/2023								
Status : Completed								
1721	23030979	ENT WARD-407	NEED TO REARRANGE ELECTRICAL WIRE AT ENTRANCE	Lakshmanan.V.	Wire rearranged.		Jayalakshmi. J. - ENT & Ophthal Ward	24/03/2023
Comp. Dt. : 25/03/2023								
Status : Completed								
1722	23031056	ICU	NEED TO CHANGE TUBELIGHT 3 NOS	Azhagappan. J.	36W tube light 1no & starter 3no's changed.		Maheswaran. D. - ENT & Ophthal Ward	25/03/2023
Comp. Dt. : 27/03/2023								
Status : Completed								
1723	23031092	Female Medical - Ward 305	NEED TO CHANGE TUBELIGHT 3 NOS	Manikandan. M.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 2NO'S CHANGED		Bhuvaneswari. M. - ENT & Ophthal Ward	28/03/2023
Comp. Dt. : 03/04/2023								

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
1724	23040030	ENT WARD-408	NEED TO CHECK SWITCH BOARD [2 NOS] - NOT WORKING	Dhakshinamoorthy. J	Switch board screw fixed.		Madhiveni. M. - ENT & Ophthal Ward	03/04/2023
Comp. Dt. : 11/04/2023								
Status : Completed								
1725	23040331	Male Medical - Ward 303	NEED TO CHECK POWER - PLUG POINT NOT WORKING	Manimaran. M.	Power point checked - ok.		Bhuvaneswari. M. - ENT & Ophthal Ward	11/04/2023
Comp. Dt. : 01/06/2023								
Status : Completed								
1726	23060005	ENT WARD-407	NEED TO CHECK POWER - ISSUE	Muthu. B.	MCB TRIP ON TO WORK PROBLEM SOLVED		Agila. V. - ENT & Ophthal Ward	02/06/2023
Comp. Dt. : 08/06/2023								
Status : Completed								
1727	23060273	ENT WARD-407	NEED FAN CLEANING WORK	Muthu. B.	ALL CEILING FAN CLEANING WORK PROBLEM SOLVED		Agila. V. - ENT & Ophthal Ward	10/06/2023
Comp. Dt. : 19/06/2023								
Status : Completed								
1728	23060673	ENT WARD-407	NEED TO CHANGE TUBELIGHT FOR RESTROOM	Vijayaraghavan.B.	TUBE LIGHT 40W STARTER 1NO CHANGED		Samundeeswari. E. - ENT & Ophthal Ward	20/06/2023
Comp. Dt. : 23/06/2023								
Status : Completed								
1729	23060888	Female Medical Ward	DUE TO BROKEN AND DAMAGE - NEED TO REFIX SWITCH BOX & PLUGS FOR PANTRY ROOM , EXAM ROOM & DOCTOR'S	Lakshmanan.V.	6M PLATE 1NO CHANG & ALL SWITCH BOARD CHEKING WORK PROBLEM SOLVED		Bhuvaneswari. M. - ENT & Ophthal Ward	24/06/2023
1730	23060889	Female Medical - Ward 306	NEED TO CHANGE TUBELIGHT FOR DOCTOR'S ROOM	Lakshmanan.V.	20W TUBE LIGHT 1NO CHANGED		Bhuvaneswari. M. - ENT & Ophthal Ward	24/06/2023
Dept Name : Female Medical Ward - Electrical Maintenance								
Comp. Dt. : 02/05/2022								
Status : Completed								
1731	22050049	Female Medical - Ward 306	NEED TO CHANGE TUBELIGHT	Muthu. B.	36W TUBE LIGHT 1NO CHANGED		Gnanasoundari. G - Female Medical Ward	05/05/2022
Comp. Dt. : 25/05/2022								
Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1732	22050965	Female Medical - Ward 305	NEED TO CHANGE TUBELIGHT 2 NOS	Lakshmanan.V.	36W tube light 2no's, starter 2no's & Side Holder 2no's changed.		Gnanasoundari. G - Female Medical Ward	26/05/2022
Comp. Dt. :		21/06/2022						
Status :		Completed						
1733	22060747	Female Medical - Ward 305	FAN NOT WORKING IN DOCTOR'S ROOM	Srinivasan. R.	CEILING FAN COIL RESOLDRING WORK & BEARING 2NO'S CHANG & FAN REFIXING WORK PROBLEM SOLVED		Gnanasoundari. G - Female Medical Ward	25/06/2022
Comp. Dt. :		01/07/2022						
Status :		Completed						
1734	22070038	Female Medical - Ward 305	NEED TO CHANGE TUBELIGHT FOR CARITOR	Lakshmanan.V.	36W TUBE LIGHT 1NO CHANGED		Gnanasoundari. G - Female Medical Ward	02/07/2022
Comp. Dt. :		13/07/2022						
Status :		Completed						
1735	22070521	Female Medical - Ward 305	NEED A NEW CONNECTION OR EXTN BOX FOR NEW FRIDGE FIXATION AT H I C C	Manikandan. M.	NEW SWITCH BOX LINE CHEKING WORK PROBLEM SOLVED		Saranya. S. - Hospital Infection Control	26/07/2022
Comp. Dt. :		05/08/2022						
Status :		Completed						
1736	22080220	Female Medical - Ward 306	NEED TO CHANGE TUBELIGHT 2 NOS	Vijayaraghavan.B.	36W TUBE LIGHT 3NO'S CHANG & 40W STARTER 3NO'S CHANGED		Vaitheeswari. A. - Female Medical Ward	06/08/2022
Comp. Dt. :		01/09/2022						
Status :		Completed						
1737	22090032	Female Medical - Ward 305	NEED TO REPLACE [OTHER PLACE] SWITCH BOX	Manikandan. M.	8M SWITCH BOARD 1NO REFIXING WORK PROBLEM SOLVED		Gnanasoundari. G - Female Medical Ward	02/09/2022
Comp. Dt. :		02/12/2022						
Status :		Completed						
1738	22120099	Female Medical - Ward 305	NEED TO CHANGE TUBELIGHT	Lakshmanan.V.	36W TUBE LIGHT 1NO CHANGED		Gomathy. G. - Female Medical Ward	03/12/2022
Comp. Dt. :		09/02/2023						
Status :		Completed						
1739	23020316	Female Medical - Ward 305	3 NOS FAN & TUBELIGHT NOT WORKING	Srinivasan. R.	Choke 2 nos changed. 2nos fan fixing capacitor 1nos changed		Gomathy. G. - Female Medical Ward	10/02/2023
Comp. Dt. :		11/05/2023						
Status :		Completed						


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1740	23050460	Female Medical - Ward 305	NEED TO CHANGE TUBELIGHT 3 NOS - NOT WORKING	Lakshmanan.V.	TUBE LIGHT 40W STARTER 4NO'S CHANGED		Gomathy. G. - Female Medical Ward	12/05/2023
Comp. Dt. : 13/06/2023 Status : Completed								
1741	23060436	Male Medical - Ward 301	POWER PROBLEM IN SWITCH BOARD - NOT WORKING	Muthu. B.	SWITCH BOARD WIRE CUT RECONNECTION WORK PROBLEM SOLVED		Gnanasoundari. G - Female Medical Ward	14/06/2023
Comp. Dt. : 14/06/2023 Status : Completed								
1742	23060487	Female Medical - Ward 306	NEED TO CHANGE TUBELIGHT 2 NOS	Srinivasan. R.	36W TUBE LIGHT 2NO'S CHANG & 40W STARTER 1NO CHANGED		Gnanasoundari. G - Female Medical Ward	16/06/2023
Comp. Dt. : 30/06/2023 Status : Completed								
1743	23061129	Female Medical - Ward 306	FAN NOT WORKING	Muthu. B.	CEILING FAN 1NO REWINDING WORK & BEARING 2NO'S CHANG & FAN REFIXNG WORK PROBLEM SOLVED		Gnanasoundari. G - Female Medical Ward	07/07/2023
Dept Name : Female Ortho Ward - Electrical Maintenance Comp. Dt. : 02/06/2022 Status : Completed								
1744	22060045	Injection Room - OPD	FAN NOT WORKING - OPD NO 54	Srinivasan. R.	CEILING FAN CAPACITOR 2.5MFT 1NO CHANGED		Badmasri. P. - OPD	02/06/2022
Comp. Dt. : 16/06/2022 Status : Completed								
1745	22060604	Female Ortho - Ward 402	FAN SOUND PROBLEM	Lakshmanan.V.	CEILING BEARING 2NO'S CHANG & FAN REFIXING WORK PROBLEM SOLVED		Dhansulakshmi. K. - Female Ortho Ward	25/06/2022
Comp. Dt. : 02/08/2022 Status : Completed								
1746	22080103	Female Ortho Ward	NEED TO CHANGE TUBELIGHT [3NOS] FOR ENTRANCE WARD NO 401 & 402	Srinivasan. R.	36W TUBE LIGHT 2NO'S CHANG & 40W STARTER 1NO CHANGED		Anbuselvi. P. - Female Ortho Ward	03/08/2022
Comp. Dt. : 08/08/2022 Status : Completed								
1747	22080266	Female Ortho - Ward 402	NEED TO CHECK SWITCH BOARD - NOT WORKING AT PATIENT SIDE - NEED URGENT SERVICE	Suresh. V.	6A SOCKET 1NO CHANGED		Anbuselvi. P. - Female Ortho Ward	08/08/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 22/09/2022 Status : Completed								
1748	22090898	Female Ortho - Ward 401	NEED TO CHANGE TUBELIGHT 2NOS	Lakshmanan.V.	36W TUBE LIGHT 2NO'S CHANG & 40W STARTER 2NO'S CHANGED		Punithavathi. E. - Female Ortho Ward	23/09/2022
Comp. Dt. : 27/09/2022 Status : Completed								
1749	22091045	Female Ortho - Ward 402	NEED TO CHECK PLUG POINT NOT WORKING	Lakshmanan.V.	6A SOCKET 1NO CHANGED		Punithavathi. E. - Female Ortho Ward	29/09/2022
Comp. Dt. : 29/09/2022 Status : Completed								
1750	22091160	Female Ortho Ward	NEED TO CHANGE TUBELIGHT FOR PATIENT RESTROOM FOR 403 & TREATMENT ROOM FOR404	Suresh. V.	36W TUBE LIGHT 1NO CHANGED		Girija. G. - Female Ortho Ward	30/09/2022
Comp. Dt. : 07/10/2022 Status : Completed								
1751	22100128	Female Ortho - Ward 402	SWITCH BOARD NOT WORKING	Thillaikumar. R.	6A SOCKET 1NO CHANGED		Anbuselvi. P. - Female Ortho Ward	07/10/2022
Comp. Dt. : 13/10/2022 Status : Completed								
1752	22100426	Female Ortho - Ward 401	FAN NOT WORKING	Lakshmanan.V.	CEILING FAN 1NO REMOVING TO ELECTRICAL ROOM		Vani. M. - Female Ortho Ward	14/10/2022
Comp. Dt. : 19/10/2022 Status : Completed								
1753	22100639	Female Ortho - Ward 402	ALL FANS CLEANING WORK	Manikandan. M.	ALL CEILING FAN CLEANING WORK PROBLEM SOLVED		Dhansulakshmi. K. - Female Ortho Ward	20/10/2022
Comp. Dt. : 21/10/2022 Status : Completed								
1754	22100730	Female Ortho - Ward 402	FAN NOT WORKING	Muthu. B.	CEILING FAN 1NO REWINDING & BEARING CHANG FAN REFIXING WORK PROBLEM SOLVED		Girija. G. - Female Ortho Ward	03/11/2022
Comp. Dt. : 31/10/2022 Status : Completed								
1755	22101009	Female ENT - Ward 402	(1414) 3 NOS TUBELIGHT NOT WORKING(ONE IN WARD AND TWO IN VERANDAH)	Lakshmanan.V.	36W TUBE LIGHT 1NO'S CHANG & 40W STARTER 1NO CHANGED		Girija. G. - Female Ortho Ward	02/11/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 08/11/2022 Status : Completed								
1756	22110274	Female Ortho - Ward 401	FAN NOT WORKING	Muthu. B.	CEILING FAN CAPACITOR 2.5MFT 1NO CHANGED		Girija. G. - Female Ortho Ward	09/11/2022
Comp. Dt. : 11/11/2022 Status : Completed								
1757	22110488	Female Ortho - Ward 402	IN DOCTOR'S REST ROOM-1 TUBELIGHT NOT WORKING	Vijayaraghavan.B.	9W LED LIGHT 1NO CHANGED		Girija. G. - Female Ortho Ward	15/11/2022
Comp. Dt. : 14/11/2022 Status : Completed								
1758	22110540	Female Ortho - Ward 401	1 CEILING FAN NOT WORKING	Vijayaraghavan.B.	CEILING FAN 1NO REWINDING WORK & BEARING CHANG & FAN REFIXING WORK PROBLEM SOLVED		Vani. M. - Female Ortho Ward	22/11/2022
Comp. Dt. : 23/11/2022 Status : Completed								
1759	22111015	Female Ortho - Ward 401	IN PATIENT REST ROOM-1 TUBELIGHT NOT WORKING	Muthu. B.	36W TUBE LIGHT FITTING 1NO FIXING WORK PROBLEM SOLVED		Girija. G. - Female Ortho Ward	25/11/2022
1760	22111016	Female Ortho - Ward 402	IN DOCTOR'S ROOM-1 TUBELIGHT NOT WORKING	Lakshmanan.V.	9W LED LIGHT 1NO CHANGED		Girija. G. - Female Ortho Ward	24/11/2022
Comp. Dt. : 12/12/2022 Status : Completed								
1761	22120535	Female Ortho - Ward 401	PLUG POINT BROKEN ,NEED TO BE SERVICE	Muthu. B.	MICA SHEET REFIXNG & 36W TUBE LIGHT 1NO CHANG & 36W CHOKE 1NO CHANGED		Vani. M. - Female Ortho Ward	13/12/2022
Comp. Dt. : 29/12/2022 Status : Completed								
1762	22121310	Female Ortho - Ward 402	PLUG POINT NOT WORKING	Rajan. R.	6A SOCKET 1NO CHANGED		Punithavathi. E. - Female Ortho Ward	29/12/2022
Comp. Dt. : 06/02/2023 Status : Completed								
1763	23020186	Female Ortho - Ward 402	NEED TO REFIX PLUG POINT	Srinivasan. R.	SWITCH BOARD SCREW REFIXNG WORK PROBLEM SOLVED		Girija. G. - Female Ortho Ward	07/02/2023
Comp. Dt. : 15/02/2023 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1764	23020578	Female Ortho - Ward 402	TUBELIGHT & FAN NOT WORKING [FAN SOUND PROBLEM]	Vengadessaperumal. K.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANG & CEILING FAN CUP SCREW REFIXING WORK PROBLEM SOLVE		Girija. G. - Female Ortho Ward	15/02/2023
Comp. Dt. : 15/03/2023								
Status : Completed								
1765	23030584	Female Ortho - Ward 402	FAN NOT WORKING - SLOW PROBLEM IN NURSE'S CABIN	Dhakshinamoorthy. J	CEILING FAN CAPACIOTR 2.5MFT 1NO CHANGED		Anbuselvi. P. - Female Ortho Ward	16/03/2023
Comp. Dt. : 21/03/2023								
Status : Completed								
1766	23030839	Female Ortho - Ward 402	NEED TO CHANGE TUBELIGHT NOT WORKING	Rajan. R.	36W TUBE LIGHT 1NO CHANGED		Anbuselvi. P. - Female Ortho Ward	22/03/2023
Comp. Dt. : 23/03/2023								
Status : Completed								
1767	23030985	Female Ortho - Ward 402	NEED TO CHANGE RESTROOM TUBELIGHT	Lakshmanan.V.	36W tube light 1no & E.choke 1no changed.		Dhansulakshmi. K. - Female Ortho Ward	24/03/2023
Comp. Dt. : 28/03/2023								
Status : Completed								
1768	23031184	Female Ortho - Ward 401	NURSE'S CABIN FAN NOT WORKING	Vijayaraghavan.B.	Fan capacitor 2.5mfd 1no changed.		Dhansulakshmi. K. - Female Ortho Ward	29/03/2023
Comp. Dt. : 01/04/2023								
Status : Completed								
1769	23040018	Female Ortho - Ward 402	NEED TO REFIX PLUG BOARD FOR DOCTOR'S ROOM	Vijayaraghavan.B.	6M Plate refixed.		Dhansulakshmi. K. - Female Ortho Ward	03/04/2023
Comp. Dt. : 19/04/2023								
Status : Completed								
1770	23040603	Female Ortho - Ward 402	FAN NOT WORKING AT DOCTOR'S ROOM	Manikandan. M.	CEILING FAN CAPACITOR 2.5MFT 1NO CHANGED		Anbuselvi. P. - Female Ortho Ward	20/04/2023
Comp. Dt. : 22/04/2023								
Status : Completed								
1771	23040696	Female Ortho - Ward 401	KETTLE NOT WORKING	Dhakshinamoorthy. J	KETTLE ON/OFF SWITCH PROBLEM		Girija. G. - Female Ortho Ward	03/05/2023
Comp. Dt. : 27/04/2023								
Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1772	23040891	Female Ortho - Ward 402	FAN SOUND PROBLEM	Vijayaraghavan.B.	CEILING FAN 1NO BEARING 2NO'S CHANG & FAN 1NO REFIXING WORK PROBLEM SOLVED		Anbuselvi. P. - Female Ortho Ward	09/05/2023
Comp. Dt. : 12/05/2023 Status : Completed								
1773	23050512	Female Ortho - Ward 402	FAN SLOW , SOUND PROBLEM IN PATIENT SIDE & DOCTOR'S ROOM	Dhakshinamoorthy. J,Manimaran. P.,Muthu. B.	CEILING FAN 1NO REMOVING TO ELECTRICAL ROOM. Spare ceiling fan fixed.		Girija. G. - Female Ortho Ward	15/05/2023
Comp. Dt. : 16/05/2023 Status : Completed								
1774	23050667	Female Ortho - Ward 402	FAN SLOW PROBLEM [2NOS]	Muthu. B.	CEILING FAN CAPACITOR 2.5MFT 2NO'S CHANGED		Dhansulakshmi. K. - Female Ortho Ward	17/05/2023
Comp. Dt. : 19/05/2023 Status : Completed								
1775	23050800	Female Ortho - Ward 402	FAN SOUND PROBLEM AT DOCTOR'S ROOM	Dhakshinamoorthy. J	CEILING FAN BEARING 2NO'S CHANG & FAN 1NO REFIXING WORK PROBLEM SOLVED		Punithavathi. E. - Female Ortho Ward	22/05/2023
Comp. Dt. : 22/05/2023 Status : Completed								
1776	23050883	Female Ortho - Ward 402	NEED TO CHECK FAN - SOUND PROBLEM AT DOCTOR'S ROOM	Rajan. R.	CEILING FAN 1NO SERVICE WORK & FAN REFIXING WORK PROBLEM SOLVED		Anbuselvi. P. - Female Ortho Ward	24/05/2023
Dept Name : Female Surgery - Electrical Maintenance Comp. Dt. : 16/05/2022 Status : Completed								
1777	22050522	Male Surgery - Ward 203	HEATER NOT WORKING	Srinivasan. R.	WATER HEAEETR 1NO RESET WORK PROBLEM SOLVED		Ezhilarasi. E. - Male Surgery	17/05/2022
Comp. Dt. : 18/05/2022 Status : Completed								
1778	22050644	Male Surgery - Ward 204	NEED TO CHECK POWER - LEFT SIDE FAN , LIGHT NOT WORKING	Sathishkumar. R.	MCB TRIP ON TO WORK PROBLEM SOLVED		Kanimozhi. A. - Male Surgery	20/05/2022
Comp. Dt. : 27/06/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1779	22060947	Male Surgery - Ward 204	WATER LEAKAGE IN STERILIZER	Manikandan. M.	NEW STERILIZER COIL 2KW 1NO CHANG & CHEKING WORK PROBLEM SOLVED		Raveena. K. - Male Surgery	29/06/2022
Comp. Dt. : 04/07/2022 Status : Completed								
1780	22070114	POW & SICU	NEED TO CHECK POWER - FRIDGE NOT WORKING	Dhakshinamoorthy. J	MCB TRIP ON TO WORK PROBLEM SOLVED		Priya. A. - Female Surgery	05/07/2022
Comp. Dt. : 25/07/2022 Status : Completed								
1781	22070890	Female Surgery - Ward 206	FAN NOT WORKING	Rajan. R.	MCB TRIP ON TO WORK PROBLEM SOLVED		Vinodhini. K. - Female Surgery	25/07/2022
Comp. Dt. : 30/07/2022 Status : Completed								
1782	22071097	Female Surgery - Ward 206	NEED TO CHECK POWER - TUBELIGHT , FAN NOT WORKING	Manimaran. P.	MCB TRIP ON TO WORK PROBLEM SOLVED		Vaidegi. S. - Female Surgery	03/08/2022
Comp. Dt. : 17/08/2022 Status : Completed								
1783	22080543	Male Surgery - Ward 203	IN DOCTOR'S ROOM,PANTRY ROOM,EXAMINATION ROOM LIGHTS ARE NOT WOKRING	Lakshmanan.V.	MCB trip - Trip ON.		Priyanka. V. - Female Surgery	18/08/2022
Comp. Dt. : 16/09/2022 Status : Completed								
1784	22090631	Male Surgery	NEED TO CHECK FAN & TUBELIGHT - NOT WORKING WARD NO 203 & 204	Manikandan. M.	WATER HEATER NEW 2KW COIL 1NO CHANG & HEATER CHEKING WORK PROBLEM SOLVED		Vaidegi. S. - Female Surgery	17/09/2022
Comp. Dt. : 19/09/2022 Status : Completed								
1785	22090704	Male Surgery - Ward 204	HEATER NOT WORKING	Suresh. V.	HEATER THERMO START 1NO CHANG & HEATER CHEKING WORK PROBLEM SOLVED		Suseela. R. - ICU	20/09/2022
Comp. Dt. : 06/10/2022 Status : Completed								
1786	22100099	Male Surgery - Ward 204	NEED TO REFIX SWITCH BOX - DAMAGE & BROKEN AT DOCTOR'S ROOM	Thillaikumar. R.	SWITCH BOARD CHEKING WORK NO COMPLAINT		Priyanka. V. - Female Surgery	07/10/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 18/10/2022								
Status : Completed								
1787	22100556	Male Surgery - Ward 201	NEED TO CHANGE TUBELIGHT FOR PATIENT REST ROOM	Lakshmanan.V.	TUBE LIGHT 40W STARTER 1NO CHANGED		Vaidegi. S. - Female Surgery	19/10/2022
Comp. Dt. : 24/01/2023								
Status : Completed								
1788	23010864	Female Surgery - Ward 205	NEED TO CHANGE TUBELIGHT	Srinivasan. R.	36W TUBE LIGHT 40W STARTER 1NO CHANGED		Vaidegi. S. - Female Surgery	25/01/2023
Comp. Dt. : 02/02/2023								
Status : Completed								
1789	23020049	DENTAL OPD -2ND FLOOR	NEED TO CHECK AC PLUG POINT - NOT WORKING	Sathishkumar. R.	25A 3PIN TOP 1NO CHANGED		Jayasree. S. - TB & Chest / Psychiatry	02/02/2023
Comp. Dt. : 14/02/2023								
Status : Completed								
1790	23020562	Female Surgery - Ward 205	TUBELIGHT NOT WORKING IN PATIENTS RESTROOM	Vijayaraghavan.B.	36W TUBE LIGHT 1NO CHANGED		Vaidegi. S. - Female Surgery	15/02/2023
Comp. Dt. : 21/02/2023								
Status : Completed								
1791	23020795	Male Surgery - Ward 204	NEED TO CHANGE TUBELIGHT	Vengadessaperumal. K.	TUBE LIGHT 40W STARTER 2NO'S CHANGED		Poovizhi. A. - Female Surgery	22/02/2023
Comp. Dt. : 15/03/2023								
Status : Completed								
1792	23030615	Female Surgery - Ward 205	STERILIZER NOT WORKING	Rajan. R.	STERILIZER CHEKING WORK WORKSH DEPT COMPLAINT		Vaidegi. S. - Female Surgery	16/03/2023
Comp. Dt. : 20/04/2023								
Status : Completed								
1793	23040635	Male Surgery - Ward 203	EARTH PROBLEM IN HEATER SWITCH - NEED URGENT SERVICE	Dhakshinamoorthy. J	EARTH CHEKIN GWORK WATER HEATER NEW 2KW COIL 1NO CHANGED		Saranya. V. - Female Surgery	22/04/2023
Comp. Dt. : 27/04/2023								
Status : Completed								
1794	23040914	Male Surgery - Ward 203	HEATER NOT WORKING	Manimaran. M.	WATER HEATER 1NO RESET WORK PROBLEM SOLVED		Poovizhi. A. - Female Surgery	28/04/2023
Comp. Dt. : 16/05/2023								
Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1795	23050640	Male Surgery - Ward 203	NEED TO CHANGE TUBELIGHT 3 NOS	Muthu. B.	36W TUBE LIGHT 3NO'S CHANG & 36W CHOKE 1NO CHANG & 40W STARTER 3NO'S CHANGED		Subashini. D. - Gynac Ward	17/05/2023
1796	23050641	Male Surgery - Ward 203	HEATER NOT WORKING	Muthu. B.	WATER HEATER 1NO RESET WORK PROBLEM SOLVED		Subashini. D. - Gynac Ward	17/05/2023
Comp. Dt. : 05/06/2023 Status : Completed								
1797	23060164	Male Surgery	FAN 2 NOS NOT WORKING - WARD NO 203 & 204	Muthu. B.	CEILING FAN CAPACITOR 2.5MFT 1NO CHANG & CEILING FAN 1NO REWINDING BEARING 2NO'S CHANG & CPACITOR 2.		Subashini. D. - Gynac Ward	08/06/2023
Comp. Dt. : 06/06/2023 Status : Completed								
1798	23060211	Female Surgery - Ward 205	HEATER NOT WORKING AT PATIENT RESTROOM	Muthu. B.	WATER HEATER 1NO SERVICE WORK & HEATER LINE CONNECTION WORK PROBLEM SOLVED		Vaidegi. S. - Female Surgery	26/06/2023
Dept Name : Gas Power Plant - Electrical Maintenance Comp. Dt. : 05/05/2022 Status : Completed								
1799	22050163	NEW GAS PLANT	NEED TO FIX LIGHT AND PROVIDE CONNECTION FOR STREET LIGHT	Muthu. B.,Babu. D.,Sathishkumar. R.	50W LED FOCUS LIGHT 2NO'S FIXING & LINE ONNECTION WORK PROBLEM		Mahi Mohan Ram.S. - Gas Power Plant	17/05/2022
Comp. Dt. : 06/05/2022 Status : Completed								
1800	22050201	NEW GAS PLANT	NEED TO FIX EARTH PLATE FOR NEW GAS PLANT LIQUID TANK AREA	Vaithianathan.M	Forward to mr.Sivagnanam PM		Mahi Mohan Ram.S. - Gas Power Plant	26/05/2022
Comp. Dt. : 19/05/2022 Status : Completed								
1801	22050704	Gas Power Plant	NEED TO CHECK EXHAUST FAN - COIL FAILURE	Muthu. B.	18" EXHAUST FAN REWINDING WORK & BEARING 2NO'S CHANG & FAN REFIXING WORK PROBLEM SOLVED		Mahi Mohan Ram.S. - Gas Power Plant	25/05/2022
Comp. Dt. : 26/05/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1802	22050971	Gas Power Plant	PROBLEM IN VACUUM PUMP MOTOR - NEED TO CHECK	Dhakshinamoorthy. J	VACUUM PUMP MOTOR CHEKING WORK PROBLEM SOLVED		Mahi Mohan Ram.S. - Gas Power Plant	31/05/2022
	Comp. Dt. : 04/06/2022 Status : Completed							
1803	22060154	PRESS	BREAKER NOT WORKING	Srinivasan. R.	UPS SERVICE WORK & UPS CHEKING WORK PROBLEM SOLVED		Mahi Mohan Ram.S. - Gas Power Plant	09/06/2022
	Comp. Dt. : 07/06/2022 Status : Completed							
1804	22060243	Gas Power Plant	NEED TO CHECK POWER - SUPPLY PROBLEM IN COMPRESSOR	Rajan. R.	32A 3POLE MCB 1NO CHANGED		Mahi Mohan Ram.S. - Gas Power Plant	07/06/2022
	Comp. Dt. : 08/06/2022 Status : Completed							
1805	22060299	Printing Press	NEED TO CHECK POWER - MACHINE NOT WORKING	Rajan. R.	MCB TRIP ON TO WORK PROBLEM SOLVED		Mahi Mohan Ram.S. - Gas Power Plant	09/06/2022
	Comp. Dt. : 08/07/2022 Status : Completed							
1806	22070295	LAUNDRY	NEED TO FIX NEW TUBELIGHT SET NEAR LAUNDRY	Muthu. B.	36W TUBE LIGHT FITTING 1NO FIXING WORK & LINE CONNECTION WORK PROBLEM SOLVED		Mahi Mohan Ram.S. - Gas Power Plant	12/07/2022
	Comp. Dt. : 29/07/2022 Status : Completed							
1807	22071077	Printing Press	FOCUS LIGHT NOT WORKING	Manimaran. P.	50W FOCUS LIGHT 1NO REFIXING WORK PROBLEM SOLVED		Mahi Mohan Ram.S. - Gas Power Plant	04/08/2022
	Comp. Dt. : 10/08/2022 Status : Completed							
1808	22080376	Printing Press	PROBLEM IN PRINTING MACHINE	Muthu. B.	MCB TRIP ON TO WORK PROBLEM SOLVED		Mahi Mohan Ram.S. - Gas Power Plant	11/08/2022
	Comp. Dt. : 11/10/2022 Status : Completed							
1809	22100301	Gas Power Plant	ELECTRICAL LINE FAULT	Rajan. R.	25A 2POLE MCB 1NO CHANGED		Mahi Mohan Ram.S. - Gas Power Plant	12/10/2022
	Comp. Dt. : 19/10/2022 Status : Completed							
1810	22100625	Gas Power Plant	TUBE LIGHT NOT WORKING	Lakshmanan.V.	TUBE LIGHT CHEKING WORK NO COMPLAINT		Mahi Mohan Ram.S. - Gas Power Plant	21/10/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 02/11/2022 Status : Completed								
1811	22110004	Gas Power Plant	IN TERROUS FOCUS LIGHT NOT WORKING	Muthu. B.	FOCUS LIGHT WIRING CHEKING WORK NO PROBLEM SOLVED		Mahi Mohan Ram.S. - Gas Power Plant	05/11/2022
Comp. Dt. : 07/12/2022 Status : Completed								
1812	22120330	Printing Press	NEED TO CHANGE TUBELIGHT 2NOS FOR DESIGNER ROOM	Thillaikumar. R.	TUBE LIGHT 40W STARTER 2NO'S CHANGED		Mahi Mohan Ram.S. - Gas Power Plant	09/12/2022
Comp. Dt. : 23/12/2022 Status : Completed								
1813	22121065	COW SHED	TUBELIGHT NOT WORKING	Manimaran. P.	36W TUBE LIGHT 3NO'S CHANG & 40W STARTER 3NO'S CHANGED		Mahi Mohan Ram.S. - Gas Power Plant	24/12/2022
Comp. Dt. : 04/01/2023 Status : Completed								
1814	23010156	Printing Press	REQUEST TO FIX NEW PLUG POINT CONNECTION	Manimaran. M.	SWITCH BOARD SCREW REFIXING WORK PROBLEM SOLVED		Mahi Mohan Ram.S. - Gas Power Plant	05/01/2023
Comp. Dt. : 10/01/2023 Status : Completed								
1815	23010406	Gas Power Plant	REQUEST FOR NEW TEMPORARY ELECTRICAL CONNECTION	Sathishkumar. R.	NEW POWER LINE CHEKING WORK PROBLEM SOLVED		Mahi Mohan Ram.S. - Gas Power Plant	12/01/2023
Comp. Dt. : 11/02/2023 Status : Completed								
1816	23020438	Printing Press	POWER MACHINE NOT WORKING	Vengadessaperumal. K.	MCCHINE LINE CONNECTION WORK PROBLEM SOLVED		Mahi Mohan Ram.S. - Gas Power Plant	15/02/2023
Comp. Dt. : 08/03/2023 Status : Completed								
1817	23030316	Gas Power Plant	FAN NOT WORKING [2NOS]	Rajan. R.	CEILING FAN CAPACITOR 2.5MFT 2NO'S CHANGED		Kandan. M. - Gas Power Plant	09/03/2023
1818	23030333	Gas Power Plant	NEED TO FIX PLUG POINT	Sathishkumar. R.	6A SWITCH 1NO,6A SOCKET 1NO,3M PLAT 1NO,3MSURFACE BOX 1NO, WIRE 3MTR 2.5SQ MM FIXING & LINE CONNECTI		Mahi Mohan Ram.S. - Gas Power Plant	11/03/2023
Comp. Dt. : 17/03/2023								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
1819	23030728	PRESS	NEED TO CHANGE TUBELIGHT FOR ENTRANCE	Vijayaraghavan.B.	36W tube light 1no & starter 1no changed.		Mahi Mohan Ram.S. - Gas Power Plant	18/03/2023
Comp. Dt. : 20/05/2023								
Status : Completed								
1820	23050824	Gas Power Plant	FAN NOT WORKING	Srinivasan. R.	6A SWITCH 1NO CHANGED		Prabu. V. - Gas Power Plant	20/05/2023
Comp. Dt. : 07/06/2023								
Status : Completed								
1821	23060222	Gas Power Plant	NEED TO FIX EXHAUST FAN	Rajan. R.	ALL EXHAUST FAN CHEKING WORK NO COMPLAINT		Mahi Mohan Ram.S. - Gas Power Plant	20/06/2023
Comp. Dt. : 16/06/2023								
Status : Completed								
1822	23060573	Printing Press	BATHROOM TUBELIGHT NOT WORKING	Manimaran. P.	20W TUBE LIGHT 1NO CHANGED		Mahi Mohan Ram.S. - Gas Power Plant	17/06/2023
Comp. Dt. : 22/06/2023								
Status : Completed								
1823	23060809	Printing Press	NEED TO CHECK SPINNING MACHINE - HEAT PROBLEM	Babu. D.	SPINNING MACHINE HEAT CHEKING WORK NO COMPLAINT PROBLEM SOLVED		Mahi Mohan Ram.S. - Gas Power Plant	01/07/2023
Comp. Dt. : 26/06/2023								
Status : Completed								
1824	23060933	Gas Power Plant	NEED SERVICE FOR SHORTER	Vijayaraghavan.B.	MOTOR DOL STARTER SERVICE WORK PROBLEM SOLVED		Kumaran. T. - Gas Power Plant	30/06/2023
Dept Name : GENERAL MEDICINE - Electrical Maintenance								
Comp. Dt. : 08/03/2023								
Status : Completed								
1825	23030327	General Medicine - OPD	NEED TO CHANGE TUBELIGHT FOR ECG ROOM	Vengadessaperumal. K.	TUBE LIGHT 36W CHOKE 1NO CHANGED		Rohini. B. - General Medicine	09/03/2023
Comp. Dt. : 09/03/2023								
Status : Completed								
1826	23030347	General Medicine - OPD	NEED TO CHANGE TUBELIGHT FOR ECG ROOM	Vengadessaperumal. K.	TUBE LIGHT 36W CHOKE 1NO CHANGED		Rohini. B. - General Medicine	09/03/2023
Comp. Dt. : 10/04/2023								

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
1827	23040275	CLINICAL DEPARTMENT IN 3RD FLOOR	NEED TO CHECK POWER - EARTH PROBLEM - ROOM NO 5 [LEFTSIDE]	Muthu. B.	Power checked - ok.		Sathiyarayanan. J. - General Medicine	10/04/2023
Dept Name : Guest House - Indian Bank - Electrical Maintenance								
Comp. Dt. : 19/05/2022								
Status : Completed								
1828	22050714	Guest House - Indian Bank	NEED TO CHECK POWER - SUPPLY PROBLEM IN ROOM NO 104 & 105	Dhakshinamoorthy. J	MCB TRIP ON TO WORK PROBLEM SOLVED		John. H. - Guest House - Indian Bank	21/05/2022
Comp. Dt. : 20/05/2022								
Status : Completed								
1829	22050763	Guest House - Indian Bank	NEED TO CHECK POWER - TRIP & SHOCK - ROOM NO 203	Lakshmanan.V.	MCB TRIP ON TO WORK PROBLEM SOLVED		John. H. - Guest House - Indian Bank	25/05/2022
Comp. Dt. : 03/06/2022								
Status : Completed								
1830	22060119	Guest House - Indian Bank	NEED TO CHANGE LED LIGHT 5 NOS - [FOR STORE ROOM 3NOS & I FLOOR CARITOR 2 NOS]	Muthu. B.	9W LED LIGHT 3NO'S CHANGED		John. H. - Guest House - Indian Bank	06/06/2022
Comp. Dt. : 25/06/2022								
Status : Completed								
1831	22060936	Guest House - Indian Bank	HEATER NOT WORKING - ROOM NO 203 & 204	Lakshmanan.V.	NEW 10LTR WATER HEATER 1NO FIXING WORK & LINE CONNECTION WORK PROBLEM SOLVED		John. H. - Guest House - Indian Bank	16/07/2022
Comp. Dt. : 30/06/2022								
Status : Completed								
1832	22061132	Guest House - Indian Bank	DUE TO FOREIGNERS VISIT - NEED TO CHECK ALL ELECTRICAL RELATED ITEMS FOR ALL ROOMS	Dhakshinamoorthy. J	ALL ELECTRICAL ITEMS CHECKING WORK NO COMPLAIN'TS PROBLEM SOLVED		John. H. - Guest House - Indian Bank	05/07/2022
Comp. Dt. : 03/09/2022								
Status : Completed								
1833	22090138	Guest House - Indian Bank	NEED TO CHANGE TUBELIGHT FOR GROUND & I FLOOR RECEPTION [2NOS]	Rajan. R.	36W TUBE LIGHT 2NO'S CHANG & 40W STARTER 2NO'S CHANGED		John. H. - Guest House - Indian Bank	05/09/2022
Comp. Dt. : 10/09/2022								
Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1834	22090410	Guest House - Indian Bank	NEED TO CHANGE TUBELIGHT 2 NOS FOR RECEPTION & I FLOOR	Lakshmanan.V.	36W TUBE LIGHT 2NO'S CHANG & 40W STARTER 1NO CHANGED		John. H. - Guest House - Indian Bank	13/09/2022
Comp. Dt. : 05/10/2022 Status : Completed								
1835	22100060	Guest House - Indian Bank	NEED TO CHANGE TUBELIGHT FOR II FLOOR CARITOR	Dhakshinamoorthy. J	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		John. H. - Guest House - Indian Bank	07/10/2022
1836	22100077	Guest House - Indian Bank	NEED TO REFIX SWITCH BOX FOR ROOM NO 102 [RESTROOM]	Dhakshinamoorthy. J	6M METEL BOX 1NO CHANG & 6M PLATE 1NO CHANGED		John. H. - Guest House - Indian Bank	07/10/2022
Comp. Dt. : 07/10/2022 Status : Completed								
1837	22100135	Guest House - Indian Bank	NEED TO CHANGE TUBELIGHT FOR ENTRANCE	Muthu. B.	36W TUBE LIGHT SET 1NO FIXING WORK PROBLEM SOLVED		John. H. - Guest House - Indian Bank	10/10/2022
Comp. Dt. : 11/11/2022 Status : Completed								
1838	22110467	Guest House - Indian Bank	IN ROOM NO.203 WATER HEATER WATER LEAKAGING PROBLEM	Lakshmanan.V.	WATER HEATER CONDEMENT NEW HEATER REPLACED		John. H. - Guest House - Indian Bank	22/11/2022
Comp. Dt. : 29/11/2022 Status : Completed								
1839	22111231	Guest House - Indian Bank	NEED TO CHANGE LED LIGHT -NOT WORKING AT I FLOOR & ROOM NO 206	Rajan. R.	9W LED LIGHT 1NO CHANG & BABY HOLDER 1NO CHANGED		John. H. - Guest House - Indian Bank	15/12/2022
Comp. Dt. : 01/12/2022 Status : Completed								
1840	22120024	Guest House - Indian Bank	NEED TO CHANGE 10 LED LIGHT & 10 HOLDERS FOR GUEST HOUSE	Rajan. R.	9W LED LIGHT 5NO'S CHANG & BABY HOLDER 5NO'S CHANGED		John. H. - Guest House - Indian Bank	15/12/2022
Comp. Dt. : 09/12/2022 Status : Completed								
1841	22120439	Guest House - Indian Bank	NEED TO CHANGE LED LIGHT 10NOS FOR ROOMS & I & II FLOOR	Rajan. R.	9W LED LIGHT 2NO'S CHANGED		John. H. - Guest House - Indian Bank	15/12/2022
Comp. Dt. : 31/01/2023 Status : Completed								
1842	23011110	Guest House - Indian Bank	NEED TO CHANGE LED WITH CHOKE FOR ROOM NO 202	Vijayaraghavan.B.	holder -2 nos and 9w led lamp -2nos changed		John. H. - Guest House - Indian Bank	03/02/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 10/02/2023 Status : Completed								
1843	23020405	Guest House - Indian Bank	WALL MOUNTING FAN NOT WORKING IN RECEPTION	Manikandan. M.	WALLMOUNTING FAN NEW MOTOR CHANG & LINE CONNECTION WORK PROBLEM SOLVED		John. H. - Guest House - Indian Bank	23/02/2023
Comp. Dt. : 03/03/2023 Status : Completed								
1844	23030145	Guest House - Indian Bank	EXTN - BOX NOT WORKING IN RECEPTION	Rajan. R.	SWITCH BOARD WIRE CUT RECONNECTION WORK PROBLEM SOLVED		John. H. - Guest House - Indian Bank	20/03/2023
1845	23030146	Guest House - Indian Bank	TV ADAPTER NOT WORKING	Rajan. R.	TV ADAPTER CHEKING NO COMPLAINT PROBLEM SOLVED		John. H. - Guest House - Indian Bank	20/03/2023
Comp. Dt. : 05/04/2023 Status : Completed								
1846	23040153	Guest House - Indian Bank	NEED TO REPLACE LED LIGHT INSTEAD OF CFL FOR ROOM NO 102 RESTROOM	Manikandan. M.	9W LED lamp 1no changed.		John. H. - Guest House - Indian Bank	05/04/2023
Comp. Dt. : 31/05/2023 Status : Completed								
1847	23051250	Guest House - Indian Bank	GENSET NOT WORKING	Thillaikumar. R.	battery distilled water refilled. dg run and battery voltage cheaked ok		John. H. - Guest House - Indian Bank	01/06/2023
Comp. Dt. : 03/06/2023 Status : Completed								
1848	23060100	Guest House - Indian Bank	NEED TO CHANGE CFL LIGHT FOR ROOM NO 101 , 104 & 106	Muthu. B.	9W LED LIGHT 2NO'S CHANG & BABY HOLDER 2NO'S CHANGED		John. H. - Guest House - Indian Bank	17/06/2023
Comp. Dt. : 13/06/2023 Status : Completed								
1849	23060462	Guest House - Indian Bank	NEED TO CHANGE LED LIGHT FOR ROOM NO 101	Muthu. B.	9W LED LIGHT 1NO CHANGED		John. H. - Guest House - Indian Bank	17/06/2023
Dept Name : Gynac Ward - Electrical Maintenance Comp. Dt. : 08/06/2022 Status : Completed								
1850	22060311	Obstetrics - Ward 207	NEED TO CHANGE TUBELIGHT FOR TREATMENT ROOM	Dhakshinamoorthy. J	36W TUBE LIGHT 1NO CHANG & 40W STARTER 2NO'S CHANGED		Sangeetha. J. - Gynac Ward	09/06/2022
Comp. Dt. : 24/06/2022								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
1851	22060874	Obstetrics - Ward 208	NEED TO CHANGE TUBELIGHT	Muthu. B.	20W TUBE LIGHT 1NO CHANG & 36W TUBE LIGHT 2NO'S CHANG & 40W CHOKE 1NO CHANG & 40W STARTER 1NO CHANGE		Ananth Prabakaran. A. - Gynac Ward	25/06/2022
Comp. Dt. : 30/06/2022								
Status : Completed								
1852	22061114	Obstetrics - Ward 207	NEED TO CHANGE TUBELIGHT FOR CARITOR	Dhakshinamoorthy. J	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Ashwini. V. - Gynac Ward	01/07/2022
Comp. Dt. : 19/08/2022								
Status : Completed								
1853	22080613	Obstetrics - Ward 208	TWO SWITCH BOARD NOT WORKING (POWER NOT COMING)	Lakshmanan.V.	MCB TRIP ON TO WORK PROBLEM SOLVED		Amsavalli. S. - Gynac Ward	20/08/2022
Comp. Dt. : 25/08/2022								
Status : Completed								
1854	22080826	Obstetrics - Ward 207	NEED TO CHANGE TUBELIGHT 4 NOS	Dhakshinamoorthy. J	36W TUBE LIGHT 2NO'S CHANG & 40W STARTER 2NO'S CHANGED		Divya. K. - Gynac Ward	25/08/2022
1855	22080848	Obstetrics - Ward 208	NEED TO CHANGE RESTROOM TUBELIGHT	Dhakshinamoorthy. J	36W TUBE LIGHT 1NO CHANGED		Ashwini. V. - Gynac Ward	25/08/2022
Comp. Dt. : 26/08/2022								
Status : Completed								
1856	22080869	Obstetrics - Ward 208	NEED TO CHECK TORCH LIGHT & TUBELIGHT [2NOS] - NOT WORKING	Lakshmanan.V.	36W TUBE LIGHT 1NO CHANG & MCB TRIP ON TO WORK PROBLEM SOLVED		Ashwini. V. - Gynac Ward	27/08/2022
Comp. Dt. : 30/08/2022								
Status : Completed								
1857	22081005	Obstetrics - Ward 207	NEED TO CHANGE TUBELIGHT	Manikandan. M.	36W TUBE LIGHT 1NO CHANGED		Sangeetha. J. - Gynac Ward	01/09/2022
Comp. Dt. : 06/09/2022								
Status : Completed								
1858	22090215	Obstetrics - Ward 208	NEED TO CHECK X RAY LOBBY SWITCH - NOT WORKING	Manikandan. M.	6A SWITCH 1NO CHANGED		Kalaivani. J. - Operation Theatre	07/09/2022
Comp. Dt. : 13/09/2022								
Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1859	22090513	Obstetrics - Ward 208	TRIP PROBLEM FOR HEATER SWITCH - NEED TO CHECK HEATER - DUE TO TRIP POWER SUPPLY DROPE TRIP PROBLEM	Srinivasan. R.	OLD WATER HEATER COIL 2KW 1NO CHANG & HEATER CHEKING WORK PROBLEM SOLVED		Sangeetha. J. - Gynac Ward	14/09/2022
Comp. Dt. : 14/09/2022 Status : Completed								
1860	22090514	Obstetrics - Ward 207	FAN SLOW PROBLEM	Suresh. V.	CEILING FAN BEARING 2NO'S CHANG & FAN 1NO REFIXNG WORK PROBLEM SOLVED		Ashwini. V. - Gynac Ward	15/09/2022
1861	22090524	Obstetrics & Gynecology	NEED TO CHANGE TUBELIGHT 2NOS FOR WARD 208 ENTRANCE	Babu. D.	36W TUBE LIGHT 3NO'S CHANG & 36W CHOKE 1NO CHANG & 40W STARTRE 1NO CHANGED		Ashwini. V. - Gynac Ward	15/09/2022
Comp. Dt. : 19/10/2022 Status : Completed								
1862	22100653	Obstetrics - Ward 207	TUBE LIGHT NOT WORKING	Dhakshinamoorthy. J	36W TUBE LIGHT 1NO CHANGED		Ashwini. V. - Gynac Ward	21/10/2022
Comp. Dt. : 10/11/2022 Status : Completed								
1863	22110441	Obstetrics - Ward 208	ABOVE NURSES CABIN-1 CEILING FAN NOT WORKING AND 1 NO. FAN NOT WORKING	Rajan. R.	36W TUBE LIGHT 2NO'S CHANG & 40W STARTER 1NO CHANGED		Ashwini. V. - Gynac Ward	14/11/2022
Comp. Dt. : 11/11/2022 Status : Completed								
1864	22110455	Obstetrics - Ward 208	3 NO'S TUBELIGHT NOT WORKING INSIDEWARD	Lakshmanan.V.	MCB TRIP ON TO WORK PROBLEM SOLVED		Ashwini. V. - Gynac Ward	14/11/2022
1865	22110456	Obstetrics - Ward 208	3 NO'S TUBELIGHT NOT WORKING IN CORRIDOR	Muthu. B.	MCB TRIP ON TO WORK PROBLEM SOLVED		Ashwini. V. - Gynac Ward	14/11/2022
Comp. Dt. : 17/11/2022 Status : Completed								
1866	22110716	Female Surgery - Ward 206	REQUESTTO CHECK WHETHER ALL LIGHTS AND FAN'S ARE IN WORKING CONDITION FOR UNIVERSITY EXAM PURPOSE(FS	Vijayaraghavan.B.	CEILING FAN BEARING 2NO'S CHANG & FAN REFIXING WORK PROBLEM SOLVED		Ashwini. V. - Gynac Ward	19/11/2022
Comp. Dt. : 12/12/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1867	22120546	Obstetrics - Ward 208	WATER HEATER NOT WORKING IN PATIENT BATHROOM	Thillaikumar. R.	WATER HEATER NEW 2KW COIL 1NO CHANG & HEATER LINE CONNECTION WORK PROBLEM SOLVED		Sangeetha. J. - Gynac Ward	19/12/2022
Comp. Dt. : 16/12/2022 Status : Completed								
1868	22120744	Obstetrics - Ward 208	WATER HEATER NOT WORKING IN PATIENT REST ROOM	Thillaikumar. R.	WATER HEATER NEW 2KW COIL 1NO CHANG & LINE CONNECTION WORK PROBLEM SOLVED		Sangeetha. J. - Gynac Ward	19/12/2022
Comp. Dt. : 19/12/2022 Status : Completed								
1869	22120856	Obstetrics - Ward 207	TUBELIGHT NOT WORKING IN PATIENTS RESTROOM	Lakshmanan.V.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Ashwini. V. - Gynac Ward	20/12/2022
Comp. Dt. : 04/01/2023 Status : Completed								
1870	23010148	Obstetrics - Ward 208	REQUEST TO CLEAN ALL FAN DUST	Muthu. B.	CEILING FAN CHEKING WORK & CLEANING WORK PROBLEM SOLVED		Sangeetha. J. - Gynac Ward	06/01/2023
Comp. Dt. : 12/01/2023 Status : Completed								
1871	23010528	Male Surgery - Ward 201	WATER HEATER NOT WORKING IN PATIENT REST ROOM	Muthu. B.	WATER HEATER 1NO RESET WORK PROBLEM SOLVED		Amsavalli. S. - Gynac Ward	13/01/2023
Comp. Dt. : 02/02/2023 Status : Completed								
1872	23020066	Obstetrics - Ward 208	NEED TO CHECK PLUG POINT - NOT WORKING	Lakshmanan.V.	MCB TRIP ON TO WORK PROBLEM SOLVED		Dayana Supriya. A. - Gynac Ward	04/02/2023
Comp. Dt. : 27/02/2023 Status : Completed								
1873	23021005	Obstetrics - Ward 207	NEED TO CHANGE RESTROOM TUBELIGHT	Muthu. B.	36W TUBE LIGHT 1NO CHANG & 36W CHOKE 1NOCHANG & 40W STARTER 1NO CHANGED		Sangeetha. J. - Gynac Ward	28/02/2023
Comp. Dt. : 15/04/2023 Status : Completed								
1874	23040450	Obstetrics - Ward 208	NEED TO CHANGE TUBELIGHT FOR PATIENT RESTROOM	Muthu. B.	36W TUBE LIGHT 1NO CHANG & 36W CHOKE 2NO'S CHANGED		Ashwini. V. - Gynac Ward	16/04/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 24/04/2023								
Status : Completed								
1875	23040777	Obstetrics - Ward 208	NEED TO CHECK POWER - SUPPLY PROBLEM	Manimaran. P.	MCB TRIP ON TO WORK PROBLEM SOLVED		Subasri. G. - Gynac Ward	25/04/2023
Comp. Dt. : 27/04/2023								
Status : Completed								
1876	23040903	Obstetrics - Ward 208	NEED TO CHANGE TUBELIGHT FOR TREATMENT ROOM	Vijayaraghavan.B.	36W TUBE LIGHT 1NO CHANGED		Sangeetha. J. - Gynac Ward	28/04/2023
Comp. Dt. : 09/05/2023								
Status : Completed								
1877	23050379	Obstetrics - Ward 207	HEATER NOT WORKING	Dhakshinamoorthy. J	WATER HEATER 1NO RESET WORK PROBLEM SOLVED		Kalaivani. J. - Operation Theatre	10/05/2023
Comp. Dt. : 10/05/2023								
Status : Completed								
1878	23050416	Obstetrics - Ward 207	POWER NOT COME	Lakshmanan.V.	MCB TRIP ON TO WORK PROBLEM SOLVED		Kalaivani. J. - Operation Theatre	11/05/2023
Comp. Dt. : 17/05/2023								
Status : Completed								
1879	23050693	Obstetrics - Ward 207	HEATER NOT WORKING	Muthu. B.	WATER HEATER NEW COIL 2KW 1NO CHANGED		Nanthini. M. - Gynac Ward	18/05/2023
Comp. Dt. : 30/05/2023								
Status : Completed								
1880	23051196	Obstetrics & Gynecology	NEED TO CHANGE TUBELIGHT & FAN CLEANING WORK FOR WARD NO 207 & 208	Dhakshinamoorthy. J	ALL CEILING FAN CLEANING WORK PROBLEM SOLVED		Ashwini. V. - Gynac Ward	01/06/2023
Comp. Dt. : 31/05/2023								
Status : Completed								
1881	23051254	Obstetrics - Ward 208	NEED TO CHANGE TUBELIGHT	Lakshmanan.V.	36 w tube - 1nos changed		Subasri. G. - Gynac Ward	01/06/2023
Comp. Dt. : 03/06/2023								
Status : Completed								
1882	23060085	Obstetrics - Ward 208	FAN NOT WORKING	Srinivasan. R.	CEILING FAN CAPACITOR 2.5MFT 1NO CHANGED		Subasri. G. - Gynac Ward	05/06/2023
Dept Name : Hospital Infection Control - Electrical Maintenance								
Comp. Dt. : 10/10/2022								
Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1883	22100233	PHYSIOTHERAPY ROOM IN 4TH FLOOR	NEED TO FIX TUBELIGHT SET 5 NOS & FAN 3 NOS	Srinivasan. R.	CEILING FAN 3NO'S CHANG & 40W TUBE LIGHT FITTING 5NO'S CHANG & LINE CONNECTION WORK PROBLEM SOLVED		Mohana. M. - Hospital Infection Control	11/10/2022
Comp. Dt. : 12/10/2022 Status : Completed								
1884	22100340	Male Surgery - Ward 201	FAN NEED TO BE CLEANED	Lakshmanan.V.	201 WARD ALL CEILING FAN CLEANING WORK PROBLEM SOLVED		Mohana. M. - Hospital Infection Control	13/10/2022
Comp. Dt. : 28/10/2022 Status : Completed								
1885	22100918	HICC ROOM IN 4TH FLOOR-403	1 FAN NOT WORKING	Dhakshinamoorthy. J	CEILING FAN 1NO REFIXING WORK PROBLEM SOLVED		Anitha. N. - Hospital Infection Control	31/10/2022
Comp. Dt. : 22/11/2022 Status : Completed								
1886	22110915	Infection Control	NEED TO CHANGE TUBELIGHT	Muthu. B.	36W TUBE LIGHT 1NO CHANGED		Anitha. N. - Hospital Infection Control	23/11/2022
Comp. Dt. : 28/01/2023 Status : Completed								
1887	23011002	ICU	NEED TO CHANGE TUBELIGHT	Dhakshinamoorthy. J	TUBE LIGHT 40W STARTER 1NO CHANGED		Anitha. N. - Hospital Infection Control	30/01/2023
Dept Name : Housekeeping - Electrical Maintenance Comp. Dt. : 12/05/2022 Status : Completed								
1888	22050446	DRESS CHANGING ROOM NEAR POW WARD-3RD FLOOR	ATTENDER DRESS CHANGE ROOM-1 TUBELIGHT NOT WOKRING	Muthu. B.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Naresh. R - Housekeeping	13/05/2022
Comp. Dt. : 14/05/2022 Status : Completed								
1889	22050493	STAFF'S CANTEEN IN COMMERCIAL BLOCK	ONE TUBELIGHT NOT WORKING AND 2 SWITCHS ALSO NOT WORKING	Srinivasan. R.	6A SWITCH 1NO CHANG & 36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Sankar.R. - Housekeeping	14/05/2022
Comp. Dt. : 16/05/2022 Status : Completed								
1890	22050552	Reception	NEED TO CHECK MAIN DOOR [GLASS DOOR] AT RECEPTION	Vaithianathan.M	MAIN DOOR STOPER SCREW LOOSE REFIXING WORK PROBLEM SOLVED		langchezhiyan. R. - Housekeeping	01/06/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 10/06/2022								
Status : Completed								
1891	22060389	Male Surgery - Ward 203	2 NO'S TUBELIGHT NOT WORKING	Dhakshinamoorthy. J	36W tube light 1no & starter 1no changed.		Balasubramaniyam. G. - Housekeeping	11/06/2022
1892	22060390	COMMON TOILET NEAR OPHTAL OPD	1 TUBELIGHT NOT WORKING	Vijayaraghavan.B.	36W tube light 1no & E.choke 1no changed.		Balasubramaniyam. G. - Housekeeping	11/06/2022
Comp. Dt. : 15/06/2022								
Status : Completed								
1893	22060564	Male Surgery - Ward 203	NEED TO CHANGE TUBELIGHT FOR STORE ROOM AT WARD END HOUSE KEEPING ROOM	Manikandan. M.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Naresh. R - Housekeeping	15/06/2022
Comp. Dt. : 23/06/2022								
Status : Completed								
1894	22060838	LIFT 1	NEED TO CHANGE CEILING LIGHT FOR LIFT NO 1 NEAR CARITOR	Lakshmanan.V.	18W LED DRIVER 1NO CHANGED		Elangchezhiyan. R. - Housekeeping	24/06/2022
Comp. Dt. : 28/06/2022								
Status : Completed								
1895	22061010	Male Surgery - Ward 201	HEATER NOT WORKING	Manimaran. P.	WATER HEATER CHEKING WORK HOUSE PROBLEM		Balasubramaniyam. G. - Housekeeping	29/06/2022
Comp. Dt. : 01/07/2022								
Status : Completed								
1896	22070028	Reception	NEED ALL FAN CLEANING & SERVICE	Vijayaraghavan.B.	ALL WALLMOUNTING FAN CLEANING WORK PROBLEM SOLVED		Elangchezhiyan. R. - Housekeeping	02/07/2022
Comp. Dt. : 12/07/2022								
Status : Completed								
1897	22070485	SPECIAL WARD---B	NEED TO CHANGE TUBELIGHT FOR COMMON RESTROOM	Rajan. R.	36W TUBE LIGHT 2NO'S CHANG & 40W STARTER 1NO CHANGED		Ayyappan. K. - Housekeeping	14/07/2022
Comp. Dt. : 20/07/2022								
Status : Completed								
1898	22070768	BIOMEDICAL WASTAGE ROOM - BACKSIDE OF ORTHO OPD	NEED TO CHECK POWER - NO POWER	Vijayaraghavan.B.	INCOMING WIRE RECONNECTION WORK PROBLEM SOLVED		Elangchezhiyan. R. - Housekeeping	21/07/2022
Comp. Dt. : 27/07/2022								
Status : Completed								
1899	22071016	Male Surgery - Ward 202	NEED TO CHANGE TUBELIGHT FOR RESTROOM	Dhakshinamoorthy. J	MCB TRIP ON TO WORK PROBLEM SOLVED		Balasubramaniyam. G. - Housekeeping	29/07/2022

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 13/08/2022								
Status : Completed								
1900	22080481	COMMON TOILET NEAR MEDICINE OPD	NEED TO CHANGE TUBELIGHT 2NOS	Vijayaraghavan.B.	18W CFL 3no's changed.		Balasubramaniyam. G. - Housekeeping	17/08/2022
Comp. Dt. : 24/08/2022								
Status : Completed								
1901	22080803	Obstetrics - Ward 208	NEED TO CHANGE TUBELIGHT FOR COMMON RESTROOM	Lakshmanan.V.	MCB TRIP ON TO WORK PROBLEM SOLVED		Balasubramaniyam. G. - Housekeeping	24/08/2022
Comp. Dt. : 14/09/2022								
Status : Completed								
1902	22090546	Female Medical - Ward 306	NEED TO CHANGE TUBELIGHT FOR COMMON RESTROOM	Dhakshinamoorthy. J	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Naresh. R - Housekeeping	15/09/2022
Comp. Dt. : 19/09/2022								
Status : Completed								
1903	22090735	Male Surgery - Ward 201	HEATER LINE PROBLEM - NEED TO CHECK	Muthu. B.	MCB TRIP ON TO WORK PROBLEM SOLVED		Balasubramaniyam. G. - Housekeeping	20/09/2022
Comp. Dt. : 20/09/2022								
Status : Completed								
1904	22090770	ALL WARDS IN HOSPITAL	NEED FAN CLEANING WORK FOR ALL WARDS	Lakshmanan.V.	ALL CEILING FAN CLEANING WORK & WALLMOUNTING FAN CLEANING WORK PROBLEM SOLVED		Elangchezhiyan. R. - Housekeeping	21/09/2022
Comp. Dt. : 26/09/2022								
Status : Completed								
1905	22091028	SPECIAL WARD---B	HEATER & TUBELIGHT NOT WORKING - ROOM NO 1	Muthu. B.	WATER HEATER 1NO RESET WORK PROBLEM SOLVED & 36W TUBE LIGHT 1NO CHANGED		Ayyappan. K. - Housekeeping	28/09/2022
1906	22091029	ENT WARD-408	NEED TO CHANGE TUBELIGHT FOR PATIENT COMMON RESTROOM	Lakshmanan.V.	36W TUBE LIGHT 1NO CHANG & 36W CHOKE 1NO CHANGED		Ayyappan. K. - Housekeeping	28/09/2022
Comp. Dt. : 03/11/2022								
Status : Completed								
1907	22110094	Obstetrics - Ward 208	2 NO'S TUBELIGHT NOT WORKING IN BATHROOM	Muthu. B.	36W TUBE LIGHT 2NO'S CHANG & 40W STARTER 1NO CHANGED		Balasubramaniyam. G. - Housekeeping	03/11/2022
Comp. Dt. : 11/11/2022								
Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1908	22110470	Male Surgery - Ward 201	1 TUBELIGHT NOT WORKING IN BATHROOM	Lakshmanan.V.	36W TUBE LIGHT 1NO CHANG & 36W CHOKE 1NO CHANG & 40W STARTER 1NO CHANGED		Balasubramaniyam. G. - Housekeeping	14/11/2022
1909	22110471	Male Surgery - Ward 202	1 TUBELIGHT NOT WORKING IN BATHROOM	Muthu. B.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Balasubramaniyam. G. - Housekeeping	14/11/2022
Comp. Dt. : 29/11/2022 Status : Completed								
1910	22111236	Civil - Maintenance	1 TUBELIGHT NOT IN OFFICE	Lakshmanan.V.	36W TUBE LIGHT 1NO CHANG & CEILING FAN SWITCH WIRE CUT RECONNECTION WORK PROBLEM SOLVED		Naresh. R - Housekeeping	03/12/2022
1911	22111237	COMMERCIAL BLOCK	IN REST ROOM-1 TUBELIGHT NOT WORKING	Muthu. B.	TUBE LIGHT 40W STARTER 1NO CHANGED		Naresh. R - Housekeeping	30/11/2022
1912	22111245	ENT WARD-407	1 TUBELIGHT NOT WORKING IN COMMON REST ROOM	Muthu. B.	36W TUBE LIGHT SET 1NO REFIXING WORK PROBLEM SOLVED		Ayyappan. K. - Housekeeping	30/11/2022
Comp. Dt. : 01/12/2022 Status : Completed								
1913	22120036	COMMON TOILET NEAR MEDICINE OPD	NEED TO CHANGE TUBELIGHT FOR MALE RESTROOM	Muthu. B.	TUBE LIGHT 40W STARTER 1NO CHANGED		Naresh. R - Housekeeping	02/12/2022
Comp. Dt. : 08/12/2022 Status : Completed								
1914	22120392	COMMON TOILET NEAR MEDICINE OPD	IN FEMALE TOILET-1 TUBELIGHT NOT WORKING	Manimaran. P.,Babu. D.,Thillaikumar. R.	36W TUBE LIGHT 2NO'S CHANG & 40W STARTER 3NO'S CHANGED		Elangchezhiyan. R. - Housekeeping	10/12/2022
Comp. Dt. : 13/12/2022 Status : Completed								
1915	22120600	BIOMEDICAL WASTAGE ROOM - BACKSIDE OF ORTHO OPD	NEED TO PROVIDE NEW EXHAUST FAN FOR FOOD PROCESSING AREA	Vijayaraghavan.B.	NEW 12" EXHAUST FAN 1NO REFIXING WORK LINE CONNECTION WORK PROBLEM SOLVED		Elangchezhiyan. R. - Housekeeping	14/12/2022
1916	22120614	ICU	NEED TO CHANGE TUBELIGHT FOR RESTROOM	Vijayaraghavan.B.	9W LED LIGHT 1NO CHANGED		Elangchezhiyan. R. - Housekeeping	14/12/2022
Comp. Dt. : 15/12/2022 Status : Completed								
1917	22120720	BIOMEDICAL WASTAGE ROOM - BACKSIDE OF ORTHO OPD	NEED TO CHANGE TUBELIGHT	Manimaran. P.	NEW 12" EXHAUST FAN 1NO FIXING & LINE CONNECTION WORK & 36W TUBE LIGHT 1NO CHANG & 36W CHOKE 1NO CH	 Dr. KAGNE. R.N DEAN SRI MANAKULA VINAYAGAR MEDICAL COLLEGE & HOSPITAL KALITHEERTHALKUPPAM, PUDUCHERRY-605107.	Naresh. R - Housekeeping	16/12/2022

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 27/12/2022 Status : Completed								
1918	22121216	COMMON MALE TOILET NEAR BIOCHEMISTRY	2 NO'S TUBELIGHT NOT WORKING	Vengadessaperumal. K.	36W TUBE LIGHT 1NO CHANG & 36W CHOKE 1NO CHANG & 36W TUBE LIGHT FITTING 1NO CHANGED		Elangchezhiyan. R. - Housekeeping	28/12/2022
Comp. Dt. : 03/01/2023 Status : Completed								
1919	23010101	Male Surgery - Ward 201	IN PATIENT REST ROOM-1 TUBELIGHT NOT WORKING	Lakshmanan.V.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Balasubramaniyam. G. - Housekeeping	04/01/2023
Comp. Dt. : 04/01/2023 Status : Completed								
1920	23010159	Female Medical ward 307	1 TUBELIGHT NOT WORKING IN PATIENT BATHROOM	Suresh. V.,Manikandan. M.,Lakshmanan.V.	TUBE LIGHT 40W STARTER 1NO CHANGED		Ayyappan. K. - Housekeeping	05/01/2023
Comp. Dt. : 11/01/2023 Status : Completed								
1921	23010473	Male Ortho - Ward 403	IN ENTRANCE-TUBELIGHT NOT WORKING	Manimaran. P.	TUBE LIGHT 40W STARTER 2NO'S CHANG & SIDE HOLDER 4NO'S CHANGED		Elangchezhiyan. R. - Housekeeping	12/01/2023
Comp. Dt. : 13/01/2023 Status : Completed								
1922	23010573	Paediatrics - Ward 310	NEED TO CHANGE TUBELIGHT	Manimaran. P.	36W TUBE LIGHT 1NO CHANG & SIDE HOLDER 2NO'S CHANGED		Ayyappan. K. - Housekeeping	14/01/2023
Comp. Dt. : 18/01/2023 Status : Completed								
1923	23010641	COMMON TOILET NEAR MEDICINE OPD	NEED TO CHANGE TUBELIGHT FOR MALE RESTROOM	Srinivasan. R.	TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Ayyappan. K. - Housekeeping	18/01/2023
Comp. Dt. : 20/01/2023 Status : Completed								
1924	23010734	Female Medical - Ward 305	REST ROOM TUBELIGHT NOT WORKING	Muthu. B.	MCB TRIP ON TO WORK PROBLEM SOLVED		Ayyappan. K. - Housekeeping	21/01/2023
Comp. Dt. : 02/02/2023 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1925	23020048	Female Medical Ward	NEED TO CHANGE TUBELIGHT FOR 305 RESTROOM & 306 WARD	Sathishkumar. R.	RESET ROOM MCB TRIP ON TO WORK & BET NO:10 TUBE LIGHT 40W STARTER 1NO CHANGED		Ayyappan. K. - Housekeeping	02/02/2023
Comp. Dt. : 11/02/2023 Status : Completed								
1926	23020435	BIOMEDICAL WASTAGE ROOM - BACKSIDE OF ORTHO OPD	NEED TO REFIX EXHAUST FAN CABLE - DAMAGE	Vengadessaperumal. K.	12" EXHAUST FAN 1NO WIRE CUT RECONNECTION WORK PROBLEM SOLVED		Naresh. R - Housekeeping	15/02/2023
Comp. Dt. : 14/02/2023 Status : Completed								
1927	23020530	COMMON TOILET NEAR MEDICINE OPD	NEED TO CHANGE TUBELIGHT FOR RESTROOM ENTRANCE	Lakshmanan.V.	TUBE LIGHT 40W STARTER 1NO CHANGED		Ayyappan. K. - Housekeeping	14/02/2023
1928	23020532	General Stores[Linen]	NEED TO CHANGE TUBELIGHT FOR STORE ENTRANCE STEPS	Lakshmanan.V.	36W TUBE LIGHT 1NO CHANGED		Ayyappan. K. - Housekeeping	14/02/2023
1929	23020557	BIOMEDICAL WASTAGE ROOM - BACKSIDE OF ORTHO OPD	EXHAUST FAN NOT WORKING	Vijayaraghavan.B.	EXHAUST FAN CAPACITOR 4MFT 1NO CHANGED		Balasubramaniyam. G. - Housekeeping	15/02/2023
Comp. Dt. : 16/02/2023 Status : Completed								
1930	23020642	Male Surgery - Ward 202	REST ROOM -ONE TUBELIGHT NOT WORKING	Lakshmanan.V.	TUBE LIGHT 40W STARTER 1NO CHANGED		Ayyappan. K. - Housekeeping	17/02/2023
Comp. Dt. : 17/02/2023 Status : Completed								
1931	23020677	COMMON MALE TOILET NEAR ORTHO OPD	NEED TO CHANGE TUBELIGHT	Muthu. B.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Naresh. R - Housekeeping	18/02/2023
Comp. Dt. : 06/03/2023 Status : Completed								
1932	23030236	BIOMEDICAL WASTAGE ROOM - BACKSIDE OF ORTHO OPD	NEED TO CHECK WEIGHT MACHINE PLUG POINT - PLUG NOT WORKING	Dhakshinamoorthy. J	6A 3PIN TOP 1NO CHANGED		Elangchezhiyan. R. - Housekeeping	07/03/2023
Comp. Dt. : 20/03/2023 Status : Completed								
1933	23030794	Male Psychiatry - Ward 405	HEATER NOT WORKING	Rajan. R.	WATER HEATER 1NO COIL SET SERIVES WORK & HEATER REFIXING WORK PROBLEM SOLVED		Elangchezhiyan. R. - Housekeeping	16/05/2023
Comp. Dt. : 05/04/2023 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
1934	23040165	Paediatrics - OPD	NEED TO CHANGE TUBELIGHT FOR RESTROOM - NOT WORKING	Vijayaraghavan.B.	36W tube light 2no's & starter 1no changed.		Balasubramaniyam. G. - Housekeeping	05/04/2023
1935	23040166	General Medicine - OPD	NEED TO CHANGE TUBELIGHT FOR DOCTOR'S ROOM	Vijayaraghavan.B.	Tube light starter 1no changed.		Balasubramaniyam. G. - Housekeeping	05/04/2023
Comp. Dt. : 10/04/2023								
Status : Completed								
1936	23040278	COMMON TOILET NEAR BLOOD BANK	NEED TO CHANGE TUBELIGHT	Manimaran. M.	Tube light starter 1no changed.		Balasubramaniyam. G. - Housekeeping	12/04/2023
1937	23040279	Paediatrics - OPD	NEED TO CHANGE TUBELIGHT FOR RESTROOM	Manikandan. M.	2feet Tube light 1no changed.		Balasubramaniyam. G. - Housekeeping	13/04/2023
Comp. Dt. : 22/04/2023								
Status : Completed								
1938	23040708	COMMON TOILET NEAR MEDICINE OPD	NEED TO CHANGE TUBELIGHT 2 NOS FOR MALE RESTROOM	Muthu. B.	TUBE LIGHT 40W STARTER 2NO'S CHANGED		Ayyappan. K. - Housekeeping	22/04/2023
Comp. Dt. : 24/04/2023								
Status : Completed								
1939	23040723	BIOMEDICAL WASTAGE ROOM - BACKSIDE OF ORTHO OPD	EXHAUST FAN NOT WORKING	Rajan. R.	EXHAUST FAN 18" 1NO REFIXIING WORK & LING CONNECTION WORK PROBLEM SOLVED		Vengadesan. K. - Housekeeping	10/05/2023
1940	23040770	Male Medical - Ward 303	NEED TO CHANGE TUBELIGHT [3NOS] FOR RESTROOM & PATIENT SIDE	Manimaran. P.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Ayyappan. K. - Housekeeping	25/04/2023
1941	23040771	Male Surgery	NEED TO CHANGE TUBELIGHT FOR 203 & 204 CARITOR	Muthu. B.	36W TUBE LIGHT 2NO'S CHANG & 40W STARTER 2NO'S CHANGED		Ayyappan. K. - Housekeeping	25/04/2023
1942	23040772	Female Medical Ward	NEED TO CHANGE TUBELIGHT FOR 305 & 306 CARITOR	Manimaran. P.	TUBE LIGHT 40W STARTER 1NO CHANGED		Ayyappan. K. - Housekeeping	25/04/2023
Comp. Dt. : 25/04/2023								
Status : Completed								
1943	23040810	COMMON TOILET NEAR MEDICINE OPD	NEED TO CHANGE LED LIGHT FOR RESTROOM CARITOR	Rajan. R.	22W LED TUBE LIGHT 1NO CHANGED		Balasubramaniyam. G. - Housekeeping	27/04/2023
Comp. Dt. : 06/05/2023								
Status : Completed								
1944	23050255	Male Medical Ward	NEED TO CHANGE TUBELIGHT FOR RESTROOM - WARD NO 302 & 303	Manikandan. M.	36W TUBE LIGHT 2NO'S CHANG & 40W STARTER 2NO'S CHANGED		Ayyappan. K. - Housekeeping	08/05/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 08/05/2023 Status : Completed								
1945	23050309	COMMON FEMALE TOILET NEAR BIOCHEMISTRY	NEED TO CHANGE TUBELIGHT	Rajan. R.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Balasubramaniyam. G. - Housekeeping	09/05/2023
1946	23050310	COMMON MALE TOILET NEAR ORTHO OPD	NEED TO CHANGE TUBELIGHT	Muthu. B.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Balasubramaniyam. G. - Housekeeping	09/05/2023
Comp. Dt. : 09/05/2023 Status : Completed								
1947	23050386	COMMON TOILET NEAR OPHTAL OPD	NEED TO CHANGE TUBELIGHT FOR BOTH MALE & FEMALE RESTROOM	Lakshmanan.V.	36W TUBE LIGHT 1NO CHANGED		Balasubramaniyam. G. - Housekeeping	11/05/2023
Comp. Dt. : 13/05/2023 Status : Completed								
1948	23050551	Male Surgery	NEED TO CHANGE TUBELIGHT FOR REST ROOM - WARD NO 203 & 204	Muthu. B.	36W tube light 1no, E.choke 1no & starter 1no changed.		Ayyappan. K. - Housekeeping	15/05/2023
Comp. Dt. : 27/05/2023 Status : Completed								
1949	23051094	COMMON MALE TOILET NEAR BIOCHEMISTRY	NEED TO CHANGE TUBELIGHT	Muthu. B.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 5NO'S CHANGED		Ayyappan. K. - Housekeeping	29/05/2023
Comp. Dt. : 31/05/2023 Status : Completed								
1950	23051212	ENT WARD-407	NEED TO CHANGE TUBELIGHT FOR WARD ENTRANCE	Rajan. R.	36 w tube -2nos changed starter -1 nos changed		Elangchezhiyan. R. - Housekeeping	01/06/2023
Comp. Dt. : 03/06/2023 Status : Completed								
1951	23060111	Male Ortho - Ward 403	NEED TO CHANGE TUBELIGHT FOR RESTROOM	Lakshmanan.V.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Ayyappan. K. - Housekeeping	05/06/2023
Comp. Dt. : 20/06/2023 Status : Completed								
1952	23060714	ENT WARD-408	NEED TO CHANGE TUBELIGHT FOR COMMOM RESTROOM	Vijayaraghavan.B.	TUBE LIGHT 36W CHOKE 1NO CHANGED		Elangchezhiyan. R. - Housekeeping	21/06/2023
Comp. Dt. : 22/06/2023								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
1953	23060836	Male Psychiatry - Ward 405	NEED TO CHANGE TUBELIGHT FOR COMMON RESTROOM	Vijayaraghavan.B.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Elangchezhiyan. R. - Housekeeping	23/06/2023
Comp. Dt. : 23/06/2023								
Status : Completed								
1954	23060861	Male Ortho - Ward 404	PLUG POINT BROKEN - NEED TO CHANGE	Vengadessaperumal. K.	6A SOCKET 1NO CHANGED		Elangchezhiyan. R. - Housekeeping	24/06/2023
Dept Name : ICCU - Electrical Maintenance								
Comp. Dt. : 16/05/2022								
Status : Completed								
1955	22050565	Mit ladies hostel	NEED TO CHANGE TUBELIGHT FOR GROUND FLOOR REST ROOM [STAFF SIDE]	Lakshmanan.V.	36W TUBE LIGHT CHOKE 1NO CHANGED		Ammu. R. - ICCU	20/05/2022
Comp. Dt. : 25/05/2022								
Status : Completed								
1956	22050952	Mit ladies hostel	NEED TO CHANGE REST ROOM TUBELIGHT [STAFF SIDE]	Lakshmanan.V.	36W E.choke 1no changed.		Ammu. R. - ICCU	26/05/2022
Comp. Dt. : 27/05/2022								
Status : Completed								
1957	22051033	Mit ladies hostel	HEATER NOT WORKING - STAFF SIDE	Lakshmanan.V.	WATER HEATER 1NO RESET WORK PROBLEM SOLVED		Ammu. R. - ICCU	28/05/2022
Comp. Dt. : 07/07/2022								
Status : Completed								
1958	22070292	Mit ladies hostel	NEED TO CHANGE RESTROOM TUBELIGHT FOR GROUND FLOOR RESTROOM [STAFF SIDE]	Dhakshinamoorthy. J	36W tube light 1no & starter 1no changed.		Ammu. R. - ICCU	08/07/2022
Comp. Dt. : 12/07/2022								
Status : Completed								
1959	22070447	ICCU	NEED TO CHANGE TUBELIGHT	Manikandan. M.	36W TUBE LIGHT 2NO'S CHANGED		Ammu. R. - ICCU	12/07/2022
Comp. Dt. : 14/07/2022								
Status : Completed								
1960	22070523	ICCU	NEED TO CHANGE TUBELIGHT	Dhakshinamoorthy. J	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANG & SIDE HOLDER 2NO'S CHANGED		Ammu. R. - ICCU	14/07/2022

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 25/07/2022								
Status : Completed								
1961	22070897	Mit ladies hostel	HEATER NOT WORKING [STAFF SIDE]	Vijayaraghavan.B.	WATER HEATER 1NO RESET WORK PROBLEM SOLVED		Ammu. R. - ICCU	25/07/2022
Comp. Dt. : 22/08/2022								
Status : Completed								
1962	22080717	ICCU	NEED TO FIX SWITCH BOARD	Vijayaraghavan.B.	SWITCH BOARD REFIXING WORK PROBLEM SOLVED		Ammu. R. - ICCU	23/08/2022
Comp. Dt. : 01/09/2022								
Status : Completed								
1963	22090050	Mit ladies hostel	HEATER NOT WORKING - STAFF SIDE	Manikandan. M.	WATER HEATER 1NO RESET WORK PROBLEM SOLVED		Ammu. R. - ICCU	02/09/2022
Comp. Dt. : 02/09/2022								
Status : Completed								
1964	22090091	ICCU	FAN NOT WORKING	Vengadessaperumal. K.	6A 3PIN TOP 1NO CHANGED		Ammu. R. - ICCU	03/09/2022
Comp. Dt. : 10/09/2022								
Status : Completed								
1965	22090383	ICCU	NEED TO CHANGE TUBELIGHT	Vengadessaperumal. K.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Suriyakala. A. - ICCU	10/09/2022
Comp. Dt. : 19/09/2022								
Status : Completed								
1966	22090721	Mit ladies hostel	NEED TO CHANGE TUBELIGHT FOR GROUND FLOOR & DINNING HALL [2NOS] & FAN SOUND PROBLEM AT STAFF SIDE	Lakshmanan.V.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Ammu. R. - ICCU	21/09/2022
Comp. Dt. : 22/09/2022								
Status : Completed								
1967	22090857	ICCU	NEED TO CHECK & REFIX SWITCH BOX & TUBELIGHT - NOT WORKING	Rajan. R.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANG & 6M PLATER 2NO'S REFIXING WORK PROBLEM SOLVED		Saradha. G. - ICCU	23/09/2022
1968	22090869	Mit ladies hostel	HEATER NOT WORKING - GROUND FLOOR REST ROOM [STAFF SIDE]	Manikandan. M.	WATER HEATER RESET WORK PROBLEM SOLVED		Ammu. R. - ICCU	24/09/2022
Comp. Dt. : 12/10/2022								

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
1969	22100365	Mit ladies hostel	HEATER NOT WORKING AT GROUND FLOOR STAFF SIDE - MIT LADIES HOSTEL	Vijayaraghavan.B.	WATER HEATER 1NO RESET WORK PROBLEM SOLVED		Ammu. R. - ICCU	14/10/2022
Comp. Dt. : 20/10/2022								
Status : Completed								
1970	22100683	ICCU	BATHROOM TUBELIGHT NOT WORKING	Dhakshinamoorthy. J	9W LED LIGHT 1NO CHANG & 36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO & 36W CHOKE 1NO CHANGED		Ammu. R. - ICCU	21/10/2022
Comp. Dt. : 22/11/2022								
Status : Completed								
1971	22110920	ICCU	NEED FAN SERVICE	Lakshmanan.V.	WALLMOUNTING FAN CLEANING WORK PROBLEM SOLVED		Ammu. R. - ICCU	23/11/2022
Comp. Dt. : 24/11/2022								
Status : Completed								
1972	22111064	ICCU	1 TUBELIGHT NOT WORKING	Lakshmanan.V.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Ammu. R. - ICCU	25/11/2022
1973	22111065	Mit ladies hostel	IN GROUND FLOOR-STAFF SIDE-WATER HEATER NOT WORKING IN BATHROOM	Dhakshinamoorthy. J	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Ammu. R. - ICCU	25/11/2022
Comp. Dt. : 15/12/2022								
Status : Completed								
1974	22120702	Mit ladies hostel	HEATER NOT WORKING - STAFF SIDE	Dhakshinamoorthy. J	WATER HEATER 1NO RESET WORK PROBLEM SOLVED		Ammu. R. - ICCU	16/12/2022
1975	22120703	Mit ladies hostel	NEED TO CHANGE TUBELIGHT 2 NOS FOR DINNING HALL	Dhakshinamoorthy. J	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Ammu. R. - ICCU	16/12/2022
Comp. Dt. : 20/12/2022								
Status : Completed								
1976	22120906	Mit ladies hostel	TUBELIGHT NOT WORKING IN ROOM NO 7 & 11	Lakshmanan.V.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 2NO'S CHANGED		Ammu. R. - ICCU	23/12/2022
Comp. Dt. : 27/01/2023								
Status : Completed								
1977	23010979	Mit ladies hostel	NEED TO CHANGE TUBELIGHT FOR ROOM NO 7 [STAFF SIDE]	Dhakshinamoorthy. J	TUBE LIGHT 40W STARTER 1NO CHANGED		Ammu. R. - ICCU	28/01/2023

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 28/01/2023 Status : Completed								
1978	23011020	ICCU	NEED TO CHANGE TUBELIGHT	Dhakshinamoorthy. J	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Saradha. G. - ICCU	30/01/2023
Comp. Dt. : 31/01/2023 Status : Completed								
1979	23011103	ICCU	NEED FAN REPAIRING & CLEANING WORK	Muthu. B.	WALLMOUNTING WIRE CUT REJOINT WORK & FAN CLEANING WORK PROBLEM SOLVED		Saradha. G. - ICCU	01/02/2023
Comp. Dt. : 21/02/2023 Status : Completed								
1980	23020807	Mit ladies hostel	NEED TO CHANGE TUBELIGHT FOR GROUND FLOOR CARITOR [STAFF SIDE	Srinivasan. R.	36W TUBE LIGHT 2NO'S CHANG & 36W CHOKE 1NO CHANGED		Ammu. R. - ICCU	25/02/2023
Comp. Dt. : 02/03/2023 Status : Completed								
1981	23030054	Mit ladies hostel	FAN NOT WORKING ROOM NO 7 [STAFF SIDE]	Srinivasan. R.	CEILING FAN REGULATOR CHANGED		Ammu. R. - ICCU	03/03/2023
Comp. Dt. : 24/03/2023 Status : Completed								
1982	23031011	Mit ladies hostel	NEED TO CHANGE TUBELIGHT FOR GROUND FLOOR ROOM NO 4 [STAFFSIDE]	Srinivasan. R.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Ammu. R. - ICCU	28/03/2023
Comp. Dt. : 29/03/2023 Status : Completed								
1983	23031266	Mit ladies hostel	T V NOT WORKING [STAFF SIDE T V HALL]	Manikandan. M.	TV problem shifted to power room. Spare TV fixed.		Ammu. R. - ICCU	06/04/2023
Comp. Dt. : 08/04/2023 Status : Completed								
1984	23040227	Mit ladies hostel	NEED TO CHANGE TUBELIGHT FOR GROUND FLOOR RESTROOM & ROOM NO 7 [STAFF SIDE]	Vijayaraghavan.B.	36W tube light 2no's, starter 2no's & capacitor 2no's changed.		Ammu. R. - ICCU	10/04/2023
Comp. Dt. : 24/04/2023 Status : Completed								
1985	23040760	Mit ladies hostel	FAN SLOW PROBLEM - ROOM NO 3 [STAFF SIDE]	Manimaran. P.	CEILING FAN CAPACITOR 2.5MFT 1NO CHANGED		Ammu. R. - ICCU	25/04/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 28/04/2023 Status : Completed								
1986	23040947	ICCU	NEED TO REFIX FAN	Rajan. R.	WALLMOUNTING FAN 1NO REFIXING WORK PROBLEM SOLVED		Ammu. R. - ICCU	28/04/2023
Comp. Dt. : 12/05/2023 Status : Completed								
1987	23050509	Mit ladies hostel	TV NOT WORKING - STAFF SIDE	Lakshmanan.V.	TV SERVICE WORK & TV CHEKING WORK PROBLEM SOLVED		Ammu. R. - ICCU	20/05/2023
Comp. Dt. : 14/06/2023 Status : Completed								
1988	23060516	Mit ladies hostel	NEED TO CHANGE TUBELIGHT FOR ROOM NO 6 [SMVMCH STAFF SIDE]	Suresh. V.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Ammu. R. - ICCU	19/06/2023
Dept Name : ICU - Electrical Maintenance Comp. Dt. : 28/05/2022 Status : Completed								
1989	22051051	ICU	FAN NOT WORKING IN NURSE'S CABIN	Dhakshinamoorthy. J	WALLMOUNTING FAN SERVICE WORK PROBLEM SOLVED		Latha. K. - ICU	30/05/2022
Comp. Dt. : 07/07/2022 Status : Completed								
1990	22070231	ICU	NEED FAN SERVICE - DUST	Dhakshinamoorthy. J	All Wallmounting fans are serviced & cleaned.		Latha. K. - ICU	08/07/2022
Comp. Dt. : 23/07/2022 Status : Completed								
1991	22070870	ICU	NEED TO CHANGE TUBELIGHT FOR DRESS CHANGING ROOM	Vijayaraghavan.B.	9W LED LIGHT 1NO CHANGED		Regina Mary. S. - ICU	25/07/2022
Comp. Dt. : 10/08/2022 Status : Completed								
1992	22080381	ICU	NEED TO CHECK FAN PLUG POINT [NURSE'S CABIN NEAR] & TUBELIGHT - NOT WORKING	Dhakshinamoorthy. J	36W TUBE LIGHT 1NO CHANG & 6A SWITCH 2NO'S CHANGED		Chandra. S. - ICU	11/08/2022
Comp. Dt. : 17/08/2022 Status : Completed								
1993	22080513	ICU	FAN DUST NEED TO BE CLEAN	Manikandan. M.	Wallmounting fan cleaned.		Regina Mary. S. - ICU	18/08/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 06/09/2022 Status : Completed								
1994	22090218	ICU	FAN [2NOS] CABLE DAMAGE - NEED TO CHANGE	Manikandan. M.	6A 2PIN TOP 2NO'S CHANGED		Regina Mary. S. - ICU	07/09/2022
Comp. Dt. : 05/10/2022 Status : Completed								
1995	22100064	ICU	TUBELIGHT NOT WORKING IN STAFF REST ROOM	Rajan. R.	9W LED LIGHT 1NO CHANGED		Regina Mary. S. - ICU	06/10/2022
Comp. Dt. : 25/10/2022 Status : Completed								
1996	22100767	ICU	PLUG POINT WIRE NOT WORKING	Muthu. B.	6A SOCKET 1NO CHANG & SWITCH BOARD 2NO'S SCREW REFIXING WORK PROBLEM SOLVED		Regina Mary. S. - ICU	26/10/2022
Comp. Dt. : 28/10/2022 Status : Completed								
1997	22100924	ICU	FAN PLUG POINT NEED TO BE CHANGE	Dhakshinamoorthy. J	MCB TRIP ON TO WORK PROBLEM SOLVED		Regina Mary. S. - ICU	29/10/2022
Comp. Dt. : 31/10/2022 Status : Completed								
1998	22101004	ICU	ONE TUBELIGHT NOT WORKING	Vijayaraghavan.B.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Regina Mary. S. - ICU	02/11/2022
Comp. Dt. : 08/11/2022 Status : Completed								
1999	22110265	ICU	NEED TO CHECK ELECTRICAL BOARD	Manimaran. P.	SWITCH BOARD 2NO'S RFIXING WORK PROBLEM SOLVED		Regina Mary. S. - ICU	09/11/2022
Comp. Dt. : 05/01/2023 Status : Completed								
2000	23010210	ICU	INSECT KILLER NOT WORKING	Muthu. B.	PEST KILLER CHEKING WORK WIRE CUT RECONNECTION WORK PROBLEM SOLVED		Regina Mary. S. - ICU	06/01/2023
Comp. Dt. : 03/02/2023 Status : Completed								
2001	23020099	ICU	NEED TO CHECK POWER - PLUG POINT & SWITCH BOARD NOT WORKING	Manimaran. M.	MCB trip - Trip ON.		Latha. K. - ICU	03/02/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 24/02/2023 Status : Completed								
2002	23020946	ICU	NEED TO CHECK PLUG POINT - NOT WORKING	Manikandan. M.	Neen To Power Supply Checked OK		Regina Mary. S. - ICU	24/02/2023
Comp. Dt. : 08/03/2023 Status : Completed								
2003	23030324	SPECIAL WARD---B	HEATER NOT WORKING	Manikandan. M.	WATER HEATER 1NO RESET WORK PROBLEM SOLVED		Gogul. M. - ICU	09/03/2023
Comp. Dt. : 11/03/2023 Status : Completed								
2004	23030452	Female Surgery - Ward 205	NEED TO CHANGE TUBELIGHT FOR TREATMENT ROOM	Muthu. B.	TUBE LIGHT CHEKING WORK NO COMPLAINT		Suseela. R. - ICU	13/03/2023
Comp. Dt. : 13/03/2023 Status : Completed								
2005	23030482	ICU	EXTNTION BOX NOT WORKING	Muthu. B.	SWITCH BOX WIRE CUT RECONNECTION WORK PROBLEM SOLVED		Regina Mary. S. - ICU	14/03/2023
Comp. Dt. : 28/03/2023 Status : Completed								
2006	23031152	ICU	NEED TO CHANGE TUBELIGHT 2 NOS - ROOM NO 103	Muthu. B.	36W tube light 3no's changed.		Latha. K. - ICU	29/03/2023
Comp. Dt. : 31/03/2023 Status : Completed								
2007	23031331	ICU	NEED TO CHANGE TUBELIGHT 2 NOS [PATIENT SIDE]	Vijayaraghavan.B.	36W tube light 2no's changed.		Latha. K. - ICU	01/04/2023
Comp. Dt. : 04/04/2023 Status : Completed								
2008	23040121	ICU	NEED TO CHANGE TUBELIGHT	Manikandan. M.	18W CFL 4pin 1no & starter 2no's changed.		Regina Mary. S. - ICU	05/04/2023
Comp. Dt. : 16/04/2023 Status : Completed								
2009	23040482	ICU	NEED TO REFIX X RAY LOBBY FRAME - DAMAGE	Lakshmanan.V.	20W CHOKE 1NO CHANGED		Latha. K. - ICU	17/04/2023
Comp. Dt. : 12/05/2023 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2010	23050483	ICU	NEED TO CHANGE TUBELIGHT 2 NOS	Manimaran. P.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 3NO'S CHANGED		Regina Mary. S. - ICU	13/05/2023
Comp. Dt. : 23/05/2023 Status : Completed								
2011	23050917	ICU	NEED TO REFIX PLUG POINT - NEAR BED NO 6	Manimaran. P.	SWITCH BOARD REFIXING WORK PROBLEM SOLVED		Latha. K. - ICU	24/05/2023
Comp. Dt. : 05/06/2023 Status : Completed								
2012	23060120	ICU	FAN [2NOS] NOT WORKING - SOUND & SLOW PROBLEM AT ICU II	Thillaikumar. R.	WALLMOUNTING FAN 1NO SERVICE WORK PROBLEM SOLVED		Latha. K. - ICU	09/06/2023
Comp. Dt. : 17/06/2023 Status : Completed								
2013	23060640	SICU	NEED TO CHECK SWITCH BOARD - NOT WORKING	Muthu. B.	MCB TRIP ON TO WORK PROBLEM SOLVED		Gogul. M. - ICU	19/06/2023
Comp. Dt. : 28/06/2023 Status : Completed								
2014	23061067	ICU	ELECTRIC KETTLE NOT WORKING	Srinivasan. R.,Manimaran. P.,Vengadessaperum al.K.	ON/OFF SWITCH 1NO FAULT. New ON/OFF switch changed.		Regina Mary. S. - ICU	12/07/2023
Dept Name : Labour Ward - Electrical Maintenance Comp. Dt. : 10/05/2022 Status : Completed								
2015	22050316	Labour Room	NEED TO CHANGE TUBELIGHT FOR WAITING ROOM	Muthu. B.	36W TUBE LIGHT 4NO'S CHANGED		Usharani. A. - Labour Ward	12/05/2022
Comp. Dt. : 20/05/2022 Status : Completed								
2016	22050757	Labour Room	NEED TO CHANGE TUBELIGHT 2 NOS	Manikandan. M.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 3NO'S CHANG & SIDE HOLDER 1NO CHANGED		Sathiyavathi. S. - Labour Ward	21/05/2022
Comp. Dt. : 30/05/2022 Status : Completed								
2017	22051107	labour room -pow	NEED TO CHANGE TUBELIGHT	Vijayaraghavan.B.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 3NO'S CHANGED		henmozhi. J. - Labour Ward	31/05/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 01/06/2022								
Status : Completed								
2018	22060008	Labour Room	NEED TO CHANGE TUBELIGHT [3NOS]	Lakshmanan.V.	36W TUBE LIGHT 1NO CHANG & 36W CHOKE 1NO CHANG & 40W STARTER 1NO CHANGED		Brema. V. - Labour Ward	02/06/2022
Comp. Dt. : 02/06/2022								
Status : Completed								
2019	22060055	Labour Room	NEED TO CHANGE TUBELIGHT FOR ANAESTHESIA ROOM	Srinivasan. R.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Sathiyavathi. S. - Labour Ward	02/06/2022
2020	22060061	Labour Room	NEED TO CHANGE TUBELIGHT FOR DOCTOR'S ROOM	Srinivasan. R.	36W TUBE LIGHT 1NO CHANG & 36W CHOKE 1NO CHANGED		Kodhai. T. - Labour Ward	02/06/2022
Comp. Dt. : 09/06/2022								
Status : Completed								
2021	22060334	Labour Room	NEED TO CHECK EXTN BOX - NOT WORKING	Srinivasan. R.	6A 3PIN TOP WIRE CUT RECONNECTION WORK PROBLEM SOLVED		Sathiyavathi. S. - Labour Ward	10/06/2022
Comp. Dt. : 21/06/2022								
Status : Completed								
2022	22060756	labour room -pow	NEED TO CHANGE TUBELIGHT [3 NOS] FOR LABOUR ROOM & LABOUR POW	Muthu. B.	SWITCH BOARD WIRE LOOSE SCREW REFIXING WORK PROBLEM SOLVED		Sathiyavathi. S. - Labour Ward	22/06/2022
Comp. Dt. : 05/07/2022								
Status : Completed								
2023	22070145	Labour Room	NEED FAN SERVICE - DUST	Lakshmanan.V.	All Fans are cleaned.		Aruldevi. M. - Labour Ward	07/07/2022
Comp. Dt. : 07/07/2022								
Status : Completed								
2024	22070238	Labour Room	NEED TO CHANGE TUBELIGHT	Dhakshinamoorthy. J	36W E.choke 1no & tube light 1no changed.		Sathiyavathi. S. - Labour Ward	08/07/2022
Comp. Dt. : 18/07/2022								
Status : Completed								
2025	22070636	Labour Room	NEED TO CHANGE TUBELIGHT 3NOS	Srinivasan. R.	36W TUBE LIGHT 3NO'S CHANG & 40W STARTER 1NO CHANG & 6A SWITCH 1NO CHANGED		Sathiyavathi. S. - Labour Ward	19/07/2022
Comp. Dt. : 21/07/2022								
Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2026	22070784	labour room -pow	NEED TO CHANGE TUBELIGHT 3 NOS	Muthu. B.	36W TUBE LIGHT 5NO'S CHANG & 36W CHOKE 2NO'S CHANG & 40W STARTER 4NO'S CHANGED		Thenmozhi. J. - Labour Ward	21/07/2022
Comp. Dt. : 26/07/2022 Status : Completed								
2027	22070940	labour room -pow	NEED TO CHANGE TUBELIGHT 3 NOS	Muthu. B.	36W TUBE LIGHT 1NO CHANG & 36W CHOKE 1NO CHANG & 40W STARTER 1NO CHANGED		Thenmozhi. J. - Labour Ward	27/07/2022
Comp. Dt. : 27/07/2022 Status : Completed								
2028	22070990	Labour Room	FAN NOT WORKING - SEPTIC WARD	Lakshmanan.V.	CEILING FAN BEARING 2NO'S CHANG & FAN REFIXING WORK PROBLEM SOLVED		Usharani. A. - Labour Ward	02/08/2022
Comp. Dt. : 08/08/2022 Status : Completed								
2029	22080267	Labour Room	STERILIZER NOT WORKING	Suresh. V.	16A SOCKET 1NO,16A SWITCH 1NO,3M PLATE 1NO,16A 3PIN TOP 1NO FIXING & LINE CONNECTION WORK PROBLEM SO		Sathiyavathi. S. - Labour Ward	09/08/2022
Comp. Dt. : 19/08/2022 Status : Completed								
2030	22080611	Labour Room	TUBE LIGHT NOT WORKING - 3 NOS	Lakshmanan.V.	36W TUBE LIGHT 2NO'S CHANG & 40W STARTER 2NO'S CHANGED		Krishnadevi. D. - Labour Ward	20/08/2022
Comp. Dt. : 29/08/2022 Status : Completed								
2031	22080961	labour room -pow	NEED TO CHANGE TUBELIGHT 2 NOS	Muthu. B.	TUBE LIGHT 1NO CHANG & 40W STARTER 2NO'S CHANG & SIDE HOLDR 2NO'S CHANGED		Thenmozhi. J. - Labour Ward	29/08/2022
Comp. Dt. : 01/09/2022 Status : Completed								
2032	22090008	Labour Room	NEED TO CHANGE TUBELIGHT 3 NOS	Suresh. V.	MCB TRIP ON TO WORK PROBLEM SOLVED		Aruldevi. M. - Labour Ward	02/09/2022
Comp. Dt. : 19/09/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2033	22090711	labour room -pow	NEED TO CHECK FAN - NOT WORKING	Duraikannu. D.	PEDESTAL FAN 1NO SERVICE WORK PROBLEM SOLVED		Priyanka. R. - Labour Ward	20/09/2022
	Comp. Dt. : 05/10/2022							
	Status : Completed							
2034	22100029	Labour Room	NEED TO CHECK PLUG POINT NOT WORKING IN WAITING AREA	Rajan. R.	6A SOCKET WIRE LOOSE RECONNECTION WORK PROBLEM SOLVED		Sathiyavathi. S. - Labour Ward	06/10/2022
	Comp. Dt. : 14/10/2022							
	Status : Completed							
2035	22100438	Labour Room	NEED TO CHANGE TUBELIGHT	Lakshmanan.V.	TUBE LIGHT 40W STARTER 1NO CHANGED		Brema. V. - Labour Ward	15/10/2022
	Comp. Dt. : 02/11/2022							
	Status : Completed							
2036	22110024	Labour Room	TUBELIGHT NOT WORKING IN DOCTOR'S ROOM	Dhakshinamoorthy. J	TUBE LIGHT 40W STARTER 1NO CHANGED		Sathiyavathi. S. - Labour Ward	03/11/2022
	Comp. Dt. : 09/11/2022							
	Status : Completed							
2037	22110328	Labour Room	TUBELIGHT NOT WORKING	Manimaran. P.	36W TUBE 3NO'S CHANG & 36W CHOKE 2NO'S CHANG & 40W STARTER 3NO'S CHANGED		Krishnadevi. D. - Labour Ward	10/11/2022
2038	22110357	labour room -pow	NO POWER SUPPLY ON ONE SIDE-1126	Manimaran. M.	MCB TRIP ON TO WORK PROBLEM SOLVED		Sevvanthi. T. - Labour Ward	10/11/2022
	Comp. Dt. : 11/11/2022							
	Status : Completed							
2039	22110443	Labour Room	1 TUBELIGHT NOT WORKING IN STAFF TOILET	Vijayaraghavan.B.	36W TUBE LIGHT 2NO'S CHANG & 40W STARTER 2NO'S CHANGED		Usharani. A. - Labour Ward	14/11/2022
	Comp. Dt. : 23/11/2022							
	Status : Completed							
2040	22110983	Labour Room	IN DOCTOR'S REST ROOM-1 TUBELIGHT NOT WORKING	Suresh. V.	36W TUBE LIGHT 1NO CHANGED		Kanimozhi. S. - Labour Ward	24/11/2022
	Comp. Dt. : 02/12/2022							
	Status : Completed							
2041	22120068	Labour Room	NEED TO CHANGE TUBELIGHT FOR DUTY DOCTOR'S ROOM	Lakshmanan.V.	36W TUBE LIGHT & 40W STARTER 1NO CHANGED		Usharani. A. - Labour Ward	03/12/2022
	Comp. Dt. : 05/12/2022							
	Status : Completed							


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2042	22120184	labour room -pow	WATER HEATER NOT WORKING IN PATIENT REST ROOM	Lakshmanan.V.	WATER HEATER OLD COIL 2KW 1NO CHANG & LINE CONNECTION WORK PROBLEM SOLVED		Brema. V. - Labour Ward	13/12/2022
		Comp. Dt. : 08/12/2022 Status : Completed						
2043	22120385	MANAGEMENT BLOCK-1ST FLOOR	IN ENTRANCE AREA- 1 TUBELIGHT NOT WORKING	Muthu. B.	36W TUBE LIGHT 1NO CHANGED		Krishnadevi. D. - Labour Ward	13/12/2022
		Comp. Dt. : 09/12/2022 Status : Completed						
2044	22120447	Labour Room	HEATER NOT WORKING	Muthu. B.	WATER HEATER RESET WORK PROBLEM SOLVED		Sathiyavathi. S. - Labour Ward	19/12/2022
		Comp. Dt. : 17/12/2022 Status : Completed						
2045	22120825	Labour Room	IN PATIENT WAITING ROOM-1 FAN NOT WORKING	Dhakshinamoorthy. J	36W TUBE LIGHT 2NO'S CHANG & 36W CHOKE 2NO'S CHANG & 40W STARTER 1NO CHANGED		Sathiyavathi. S. - Labour Ward	19/12/2022
		Comp. Dt. : 27/12/2022 Status : Completed						
2046	22121235	Labour Room	IN OT PATIENT WAITING ROOM-CEILING FAN NOT WORKING	Muthu. B.	CEILING FAN CAPACITOR 2.5MFT 1NO CHANGED		Usharani. A. - Labour Ward	28/12/2022
		Comp. Dt. : 30/12/2022 Status : Completed						
2047	22121368	Labour Room	1 TUBELIGHT NOT WORKING	Vijayaraghavan.B.	36W tube light 2no's & Starter 1no changed.		Aruldevi. M. - Labour Ward	31/12/2022
		Comp. Dt. : 03/01/2023 Status : Completed						
2048	23010095	Labour Room	SWITCH BOARD UNPLUGED,NEED TO BE REFIX	Muthu. B.	SWITCH BOARD SCREW REFIXING WORK PROBLEM SOLVED		Kodhai. T. - Labour Ward	03/01/2023
		Comp. Dt. : 06/01/2023 Status : Completed						
2049	23010271	Labour Room	NEED TO CHANGE ONE TUBELIGHT	Muthu. B.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Kodhai. T. - Labour Ward	07/01/2023
		Comp. Dt. : 24/01/2023 Status : Completed						


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2050	23010851	Labour Room	NEED TO CHANGE TUBELIGHT FOR ENTRANCE	Srinivasan. R.	36W TUBE LIGHT 1NO CHANG & SIDE HOLDER 1NO CHANGED		Santhiya. A. - Labour Ward	25/01/2023
		Comp. Dt. : 25/01/2023 Status : Completed						
2051	23010913	Labour Room	NEED TO RECONNECT EXTN BOX CABLE - DAMAGE - NOT WORKING	Manimaran. M.	EXECTION BOX 1NO SWITCH CHANGED		Usharani. A. - Labour Ward	28/01/2023
2052	23010917	Labour Room	STERILIZER NOT WORKING	Manimaran. M.	STERILIZER TANK WATER LEAK SHIFTING TO WORKSHOP DEPT		Sathiyavathi. S. - Labour Ward	27/01/2023
		Comp. Dt. : 09/02/2023 Status : Completed						
2053	23020323	labour room -pow	TUBELIGHT NOT WORKING	Muthu. B.	tube light 1 nos changed		Brema. V. - Labour Ward	10/02/2023
		Comp. Dt. : 13/02/2023 Status : Completed						
2054	23020453	Labour Room	NEED TO CHANGE TUBELIGHT 2 NOS	Rajan. R.	tube light 40w starter 2no's chang & 36w choke 1no changed		Krishnadevi. D. - Labour Ward	14/02/2023
		Comp. Dt. : 21/02/2023 Status : Completed						
2055	23020813	labour room -pow	NEED TO CHANGE TUBELIGHT	Vengadessaperumal. K.	36W CHOKE 1NO CHANGED		Brema. V. - Labour Ward	22/02/2023
		Comp. Dt. : 09/03/2023 Status : Completed						
2056	23030381	Labour Room	NEED TO CHANGE TUBELIGHT 2 NOS	Manimaran. P.	36W E.choke 1no, starter 1no & 2.5mfd fan capacitor 1no changed.		Krishnadevi. D. - Labour Ward	10/03/2023
		Comp. Dt. : 10/03/2023 Status : Completed						
2057	23030439	Labour Room	FAN NOT WORKING	Manikandan. M.	CEILING FAN CAPACITOR 2.5MFT 1NO CHANGED		Krishnadevi. D. - Labour Ward	13/03/2023
		Comp. Dt. : 17/03/2023 Status : Completed						
2058	23030677	Labour Room	TUBELIGHT NOT WORKING	Vijayaraghavan.B.	36W tube light 1no changed.		Krishnadevi. D. - Labour Ward	18/03/2023
		Comp. Dt. : 18/03/2023 Status : Completed						


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2059	23030751	Labour Room	NEED TO CHECK FAN & TUBELIGHT - NOT WORKING	Manikandan. M.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Kanimozhi. S. - Labour Ward	20/03/2023
		Comp. Dt. : 22/03/2023 Status : Completed						
2060	23030907	Labour Room	FAN NOT WORKING AT WAITING ROOM	Lakshmanan.V.	CEILING FAN BEARING 2NO'S CHANG & FAN REFIXING WORK PROBLEM SOLVED		Santhiya. A. - Labour Ward	27/03/2023
		Comp. Dt. : 24/03/2023 Status : Completed						
2061	23030989	Labour Room	NEED TO CHANGE TUBELIGHT	Thillaikumar. R.	Tube light starter 1no changed.		Bakkiyalakshmi. V. - Labour Ward	24/03/2023
		Comp. Dt. : 28/03/2023 Status : Completed						
2062	23031217	Labour Room	NEED TO CHANGE TUBELIGHT	Vijayaraghavan.B.	Tube light starter 1no changed.		Krishnadevi. D. - Labour Ward	29/03/2023
		Comp. Dt. : 27/04/2023 Status : Completed						
2063	23040885	labour room -pow	NEEED TO CHANGE TUBELIGHT	Vijayaraghavan.B.	36W TUBE LIGHT 1NO CHANGED		Iyshwariya. M. - Labour Ward	28/04/2023
		Comp. Dt. : 03/05/2023 Status : Completed						
2064	23050113	labour room -pow	NEED TO CHANGE TUBELIGHT	Lakshmanan.V.	36W TUBE LIGHT 1NO CHANG & 36W CHOKE 1NO CHANGED		Iyshwariya. M. - Labour Ward	09/05/2023
		Comp. Dt. : 23/05/2023 Status : Completed						
2065	23050896	Labour Room	NEED TO CHANGE TUBELIGHT FOR RESTROOM	Senthil Murugan. A.	TUBE LIGHT 40W STARTER 2NO'S CHANGED		Santhiya. A. - Labour Ward	23/05/2023
		Comp. Dt. : 29/05/2023 Status : Completed						
2066	23051114	Labour Room	NEED TO CHECK FAN & RESTROOM TUBELIGHT - NOT WORKING	Thillaikumar. R.	TUBE LIGHT SIDE HOLDER 1NO CHANG & WALLMOUNTING FAN 1NO SERVICE WORK PROBLEM SOLVED		Kanimozhi. S. - Labour Ward	30/05/2023
		Comp. Dt. : 30/05/2023 Status : Completed						


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2067	23051176	Labour Room	NEED TO CHANGE TUBELIGHT FOR DUTY DOCTOR'S ROOM 1 NO & PATINET SIDE 1 NO	Muthu. B.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 2NO'S CHANGED		Krishnadevi. D. - Labour Ward	31/05/2023
Comp. Dt. : 01/06/2023 Status : Completed								
2068	23060023	Labour Room	NEED TO CHECK FIRE EXTINGUISHER - EXPIRY DATE TODAY [01.06.2023]	Babu. D.	FIRE EXTINGUISHER 1NO CHANGED		Sathiyavathi. S. - Labour Ward	02/06/2023
Comp. Dt. : 05/06/2023 Status : Completed								
2069	23060119	Labour Room	NEED TO CHANGE TUBELIGHT FOR WAITING ROOM	Thillaikumar. R.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Usharani. A. - Labour Ward	06/06/2023
Comp. Dt. : 16/06/2023 Status : Completed								
2070	23060609	Labour Room	ENTRANCE TUBELIGHT NOT WORKING	Muthu. B.	TUBE LIGHT 40W STARTER 1NO CHANGED		Santhiya. A. - Labour Ward	17/06/2023
Comp. Dt. : 20/06/2023 Status : Completed								
2071	23060706	Labour Room	NEED TO REFIX SWITCH BOX & PLUG POINT - DAMAGE	Vengadessaperumal. K.	8M PLATE 1NO REFIXING WORK PROBLEM SOLVED		Santhiya. A. - Labour Ward	22/06/2023
Comp. Dt. : 26/06/2023 Status : Completed								
2072	23060950	Female Medical - Ward 305	DUE TO WATER LEAKAGE FROM CEILING , ELECTRIC CABLES & SWITCH , PLUG POINTS SHOCK PROBLEM - N	Thillaikumar. R.	MCB TRIP ON TO WORK PROBLEM SOLVED		Lavanya. E. - Labour Ward	27/06/2023
Dept Name : Male Medical Ward - Electrical Maintenance Comp. Dt. : 06/05/2022 Status : Completed								
2073	22050195	Male Medical - Ward 301	FAN SLOW PROBLEM	Manikandan. M.	CEILING FAN CAPACITOR 2.5MFT 1NO CHANGED		Nirmalraj. R. - Male Medical Ward	09/05/2022
Comp. Dt. : 09/05/2022 Status : Completed								
2074	22050256	Male Medical - Ward 301	FAN SLOW PROBLEM	Manikandan. M.	36W TUBE LIGHT 1NO CHANG & 36W CHOKE 1NO CHANG & CEILING FAN CAPACITOR 2.5MFT 1NO CHANGED		Kanmani. R. - Male Medical Ward	09/05/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 10/05/2022 Status : Completed								
2075	22050364	Male Medical - Ward 303	NEED TO CHANGE TUBELIGHT [2NOS]	Lakshmanan.V.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Vijayalakshmi. S. - Male Medical Ward	12/05/2022
Comp. Dt. : 11/05/2022 Status : Completed								
2076	22050369	Male Medical - Ward 303	XRAY LOBBY NOT WORKING(1315)	Lakshmanan.V.	3PIN TOP WIRE LOOSE RECONNECTION WORK PROBLEM SOLVED		Vijayalakshmi. S. - Male Medical Ward	12/05/2022
Comp. Dt. : 14/05/2022 Status : Completed								
2077	22050497	Male Medical - Ward 302	FAN NOT WORKING	Manimaran. P.	CEILING FAN CAPACIOTR 2.5MFT 1NO CHANGED		Soniya Gandhi. A. - Male Medical Ward	17/05/2022
Comp. Dt. : 17/05/2022 Status : Completed								
2078	22050634	Male Medical - Ward 304	X RAY LOBBY NOT WORKING	Babu. D.	18W 2PIN CFL LIGHT 1NO CHANGED		Vijayalakshmi. S. - Male Medical Ward	20/05/2022
2079	22050635	Male Medical - Ward 302	NEED TO ADJUST FAN HEIGHT AT NURSE'S STATION	Sathishkumar. R.	CEILING FAN CHEKING WORK NO COMPLAINT		Daniel Joseph - POW & SICU	20/05/2022
Comp. Dt. : 20/05/2022 Status : Completed								
2080	22050771	Male Medical - Ward 304	NEED TO CHANGE SWITCH - BROKEND	Manikandan. M.	6A SWITCH 1NO CHANG & 6A SOCKET 1NO CHANGED		Vijayalakshmi. S. - Male Medical Ward	21/05/2022
Comp. Dt. : 24/05/2022 Status : Completed								
2081	22050886	Male Medical Ward	NEED FAN CLEANNING WORK [ALL FANS] - WARD NO 303 & 304	Vijayaraghavan.B.	Ceiling fan cleaned.		Vijayalakshmi. S. - Male Medical Ward	26/05/2022
Comp. Dt. : 30/05/2022 Status : Completed								
2082	22051079	Male Medical Ward	NEED TO CHECK POWER - SYSTEM NOT WORKING BOTH SIDE [WARD 301 & 302]	Srinivasan. R.	MCB TRIP ON TO WORK PROBLEM SOLVED		Soniya Gandhi. A. - Male Medical Ward	31/05/2022
Comp. Dt. : 11/06/2022 Status : Completed								
2083	22060416	Male Medical - Ward 302	NEED TO CHANGE TUBELIGHT 5 NOS	Muthu. B.	36W tube light 2no's & Starter 5no's changed.		Soniya Gandhi. A. - Male Medical Ward	11/06/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 13/06/2022 Status : Completed								
2084	22060435	Male Medical - Ward 302	NEED TO CHANGE RESTROOM TUBELIGHT [2NOS]	Dhakshinamoorthy. J	Tube light starter 1no & side holder 1no changed.		Aravind. M. - Male Medical Ward	14/06/2022
Comp. Dt. : 22/06/2022 Status : Completed								
2085	22060818	Male Medical - Ward 304	FAN [2 NOS] NOT WORKING	Lakshmanan.V.	CEILING FAN CAPACITOR 2.5MFT 1NO CHANG & FAN 1NO WIRE LOOSE RECONNECTION WORK PROBLEM SOLVED		Vijayalakshmi. S. - Male Medical Ward	23/06/2022
Comp. Dt. : 24/06/2022 Status : Completed								
2086	22060862	Male Medical - Ward 301	NEED TO CHECK FAN - SLOW PROBLEM AT NURSE'S STATION	Manimaran. P.	CEILING FAN CAPACITOR 2.5MFT 1NO CHANGED		Daniel Joseph - POW & SICU	24/06/2022
Comp. Dt. : 27/06/2022 Status : Completed								
2087	22060955	Male Medical - Ward 301	INDUCTION STOVE NOT WORKING	Sridharan. R	INDUCTION STOVE SWITCH 1NO CHANGED		Daniel Joseph - POW & SICU	02/07/2022
Comp. Dt. : 05/07/2022 Status : Completed								
2088	22070178	Male Medical - Ward 301	NEED TO CHANGE TUBELIGHT 2 NOS	Srinivasan. R.	36W tube light 1no & Starter 1no changed.		Soniya Gandhi. A. - Male Medical Ward	07/07/2022
Comp. Dt. : 06/07/2022 Status : Completed								
2089	22070194	Male Medical - Ward 303	NEED TO FIX FAN REGULATOR	Vijayaraghavan.B.	Fan regulator 1no changed.		Vijayalakshmi. S. - Male Medical Ward	07/07/2022
Comp. Dt. : 07/07/2022 Status : Completed								
2090	22070261	Male Medical Ward	HEATER NOT WORKING - WARD NO 301 & 302	Muthu. B.	Heater Reset - Ok.		Nirmalraj. R. - Male Medical Ward	08/07/2022
Comp. Dt. : 09/07/2022 Status : Completed								
2091	22070383	Male Medical - Ward 303	PLUG POINT NOT WORKING	Dhakshinamoorthy. J	6A SWITCH 2NO'S CHANG & 6A SOCKET 1NO CHANGED		Soniya Gandhi. A. - Male Medical Ward	11/07/2022
Comp. Dt. : 11/07/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2092	22070445	Male Medical - Ward 304	X RAY LOBBY NOT WORKING	Rajan. R.	BABY HOLDER 1NO CHANG & 9W LED LIGHT 1NO CHANGED		Anusuya. V. - Male Medical Ward	12/07/2022
	Comp. Dt. : 15/07/2022							
	Status : Completed							
2093	22070612	Male Medical - Ward 302	NEED TO CHANGE TUBELIGHT	Srinivasan. R.	36W TUBE LIGHT 1NO CHANGED		Soniya Gandhi. A. - Male Medical Ward	16/07/2022
	Comp. Dt. : 19/07/2022							
	Status : Completed							
2094	22070694	Male Medical - Ward 302	INDUCTION STOVE NOT WORKING	Sridharan. R	INDUCTION STOVE CHEKING WORK NO COMPLAINT		Daniel Joseph - POW & SICU	20/07/2022
	Comp. Dt. : 22/07/2022							
	Status : Completed							
2095	22070835	Male Medical - Ward 304	NEED TO CHANGE TUBELIGHT	Manikandan. M.	36W TUBE LIGHT 1NO CHANGED		Karthikeyan. I. - Male Medical Ward	23/07/2022
	Comp. Dt. : 23/07/2022							
	Status : Completed							
2096	22070852	Male Medical - Ward 302	INDUCTION STOVE NOT WORKING	Sridharan. R	INDUCTION STOVE WIRE CUT RECONNECTION WORK PROBLEM SOLVED		Daniel Joseph - POW & SICU	26/07/2022
	Comp. Dt. : 29/07/2022							
	Status : Completed							
2097	22071044	Male Medical - Ward 301	FAN NOT WORKING	Muthu. B.	CEILING FAN CAPACITOR 2.5MFT 1NO CHANGED		Karthika. S. - Female Surgery	30/07/2022
	Comp. Dt. : 09/08/2022							
	Status : Completed							
2098	22080300	Male Medical Ward	FAN NOT WORKING IN WARD NO 301 & NEED TO CHANGE TUBELIGHT FOR WARD NO 302	Manikandan. M.	CEILING FAN 1NO REWINDING & BEARING 2NO'S CHANG & FAN REFIXING WORK PROBLEM SOLVED		Soniya Gandhi. A. - Male Medical Ward	05/09/2022
	Comp. Dt. : 22/08/2022							
	Status : Completed							
2099	22080729	Male Medical - Ward 301	HEATER NOT WORKING	Vijayaraghavan.B.	WATER HEATER 1NO RESET WORK PROBLEM SOLVED		Soniya Gandhi. A. - Male Medical Ward	23/08/2022
	Comp. Dt. : 26/08/2022							
	Status : Completed							


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2100	22080896	Male Medical - Ward 301	NEED TO REFIX REMOVED FAN	Vengadessaperumal. K.	CEILING FAN REWINDING & BEARING 2NO'S CHANG & FAN 1NO REFIXING WORK PROBLEM SOLVED		Vijayalakshmi. S. - Male Medical Ward	05/09/2022
Comp. Dt. : 08/09/2022 Status : Completed								
2101	22090341	Male Medical - Ward 301	NEED TO CHANGE TUBELIGHT NOT WORKING	Lakshmanan.V.	36W TUBE LIGHT 2NO'S CHANG & 40W STARTER 1NO CHANGED		Karthika. S. - Female Surgery	09/09/2022
Comp. Dt. : 12/09/2022 Status : Completed								
2102	22090448	Male Medical - Ward 302	NEED TO CHANGE TUBELIGHT	Lakshmanan.V.	6A SWITCH 1NO CHANGED		Soniya Gandhi. A. - Male Medical Ward	13/09/2022
Comp. Dt. : 23/09/2022 Status : Completed								
2103	22090943	Male Medical - Ward 302	NEED TO CHECK INDUCTION STOVE - NOT WORKING	Sridharan. R	INDUCTION STOVE SERVICE WORK PROBLEM SOLVED		Vijayalakshmi. S. - Male Medical Ward	06/10/2022
Comp. Dt. : 08/10/2022 Status : Completed								
2104	22100167	Male Medical - Ward 301	TUBE LIGHT NOT WORKING	Muthu. B.	36W TUBE LIGHT 1NO CHANGED		Soniya Gandhi. A. - Male Medical Ward	10/10/2022
Comp. Dt. : 22/10/2022 Status : Completed								
2105	22100762	NICU - Ward 1	TUBE LIGHT NOT WORKING	Manimaran. M.	36W TUBE LIGHT 1NO CHANGED		Ananthi. P. - Male Medical Ward	25/10/2022
Comp. Dt. : 14/11/2022 Status : Completed								
2106	22110537	Male Medical - Ward 301	WATER HEATER NOT WORKING	Vijayaraghavan.B.	CEILING FAN BEARING CHANG & FAN REFIXING WORK PROBLEM SOLVED		Soniya Gandhi. A. - Male Medical Ward	18/11/2022
Comp. Dt. : 16/11/2022 Status : Completed								
2107	22110672	Male Medical - Ward 301	WATER HEATER NOT WORKING IN PATIENT REST ROOM	Manikandan. M.	WATER HEATER RESET WORK PROBLEM SOLVED		Vijayalakshmi. S. - Male Medical Ward	17/11/2022
Comp. Dt. : 30/11/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2108	22111263	Male Medical - Ward 302	SWITCH BOARD BROKEN	Muthu. B.	SWITCH BOARD REFIXING WORK PROBLEM SOLVED		Vijayalakshmi. S. - Male Medical Ward	02/12/2022
2109	22111291	Male Medical - Ward 301	WATER HEATER NOT WORKING IN REST ROOM	Lakshmanan.V.	WATER HEATER 1NO RESET WORK PROBLEM SOLVED		Soniya Gandhi. A. - Male Medical Ward	01/12/2022
Comp. Dt. : 02/12/2022 Status : Completed								
2110	22120084	Male Medical - Ward 301	NEED SERVICE FOR HEATER	Lakshmanan.V.	16A SWITCH 1NO CHANGED		Vijayalakshmi. S. - Male Medical Ward	03/12/2022
Comp. Dt. : 05/12/2022 Status : Completed								
2111	22120176	Male Medical - Ward 301	INDUCTION NOT WORKING	Dhakshinamoorthy. J	INDUCTION ON/OFF SWITCH 1NO CHANG & CHEKING WORK PROBLEM SOLVED		Geedhanjali. I - Male Medical Ward	24/01/2023
Comp. Dt. : 06/12/2022 Status : Completed								
2112	22120259	Male Medical - Ward 301	2 NO'S TUBELIGHT IN ENTRANCE AND 1 NO. TUBELIGHT IN PATIENT REST ROOM NOT WORKING	Muthu. B.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Soniya Gandhi. A. - Male Medical Ward	07/12/2022
Comp. Dt. : 07/12/2022 Status : Completed								
2113	22120324	RICU	NEED TO CHANGE TUBELIGHT FOR RESTROOM ENTRANCE	Rajan. R.	9W LED LIGHT 1NO CHANGED		Nirmalraj. R. - Male Medical Ward	08/12/2022
Comp. Dt. : 12/12/2022 Status : Completed								
2114	22120526	Male Medical - Ward 303	SWITCH BOARD BRO KEN	Muthu. B.	SWITCH BOARD SCREW REFIXING WORK PROBLEM SOLVED		Vijayalakshmi. S. - Male Medical Ward	13/12/2022
Comp. Dt. : 21/12/2022 Status : Completed								
2115	22120942	Male Medical - Ward 301	PLUG POINT NOT WORKING	Lakshmanan.V.	MCB TRIP ON TO WORK PROBLEM SOLVED		Soniya Gandhi. A. - Male Medical Ward	22/12/2022
2116	22120971	Male Medical - Ward 301	FAN NOISE PROBLEM	Lakshmanan.V.	CEILING FAN BEARING 2NO'S CHANG & FAN REFIXING WORK PROBLEM SOLVED		Aravind. M. - Male Medical Ward	23/12/2022
Comp. Dt. : 05/01/2023 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2117	23010196	Male Medical - Ward 301	NEED TO CHANGE SWITCH BOARD BROKEN	Lakshmanan.V.	6A SWITCH 1NO CHANG & 6A SOCKET 1NO CHANG & 3M PLATE 1NO CHANGED		Karthikeyan. I. - Male Medical Ward	05/01/2023
	Comp. Dt. : 20/01/2023							
	Status : Completed							
2118	23010692	Male Medical - Ward 301	HEATER NOT WORKING	Muthu. B.	WATER HEATER CHEKING WORK PLUMBING COMPLAINT		Soniya Gandhi. A. - Male Medical Ward	23/01/2023
	Comp. Dt. : 23/01/2023							
	Status : Completed							
2119	23010804	Male Medical - Ward 301	NEED TO CHANGE TUBELIGHT	Manikandan. M.	TUBE LIGHT 40W STARTER 2NO'S CHANGED		Soniya Gandhi. A. - Male Medical Ward	24/01/2023
2120	23010832	Male Medical - Ward 301	NEED TO CHANGE TUBELIGHT	Manikandan. M.	TUBE LIGHT 40W STARTER 2NO'S CHANGED		Soniya Gandhi. A. - Male Medical Ward	24/01/2023
	Comp. Dt. : 02/02/2023							
	Status : Completed							
2121	23020045	Male Medical - Ward 301	NEED TO CHANGE TUBELIGHT 3 NOS	Sathishkumar. R.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 3NO'S CHANGED		Geedhanjali. I - Male Medical Ward	02/02/2023
	Comp. Dt. : 25/02/2023							
	Status : Completed							
2122	23020981	Male Medical - Ward 301	RESTROOM HEATER NOT WORKING	Muthu. B.	WATER HEATER 1NO RESET WORK PROBLEM SOLVED		Geedhanjali. I - Male Medical Ward	27/02/2023
	Comp. Dt. : 28/03/2023							
	Status : Completed							
2123	23031187	Ladies hostel Phase-II	NEED TO CHECK SWITCH BOARD - BURNT - ROOM NO 16	Lakshmanan.V.	Switch board problem - rectified.		Vijayalakshmi. S. - Male Medical Ward	30/03/2023
	Comp. Dt. : 31/03/2023							
	Status : Completed							
2124	23031332	Male Medical - Ward 301	NEED TO CHECK & CHANGE X RAY LOBBY PLUG POINT - PLUG DAMAGE & BURNT	Muthu. B.	MCB trip - trip on.		Daniel Joseph - POW & SICU	01/04/2023
2125	23031349	Male Medical - Ward 301	HEATER NOT WORKING	Muthu. B.	Thermostat 1no changed - Heater tested ok.		Karthikeyan. I. - Male Medical Ward	01/04/2023
	Comp. Dt. : 03/04/2023							
	Status : Completed							


Dr. KAGNE. R.N.
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2126	23040076	Male Medical - Ward 301	NEED TO CHECK & CHANGE PLUG POINT FOR X LOBBY - BURNT	Manimaran. M.	6A 3pin top 1no changed.		Soniya Gandhi. A. - Male Medical Ward	05/04/2023
Comp. Dt. : 12/04/2023 Status : Completed								
2127	23040354	Male Medical - Ward 302	NEED TO CHANGE TUBELIGHT FOR BED SIDE	Manimaran. M.	36W tube light 1no & E.choke 1no changed.		Soniya Gandhi. A. - Male Medical Ward	12/04/2023
Comp. Dt. : 17/04/2023 Status : Completed								
2128	23040488	Male Medical - Ward 301	NEED TO CHANGE TUBELIGHT	Vijayaraghavan.B.	36W TUBE LIGHT 1NO CHANGED		Soniya Gandhi. A. - Male Medical Ward	17/04/2023
Comp. Dt. : 27/04/2023 Status : Completed								
2129	23040933	Male Medical - Ward 303	NEED TO CHANGE TUBELIGHT 4 NOS	Muthu. B.	36W TUBE LIGHT 2NO'S CHANG & 40W STARTER 1NO CHANG & 6A SWITCH 1NO CHANGED		Ananthi. P. - Male Medical Ward	28/04/2023
Comp. Dt. : 12/05/2023 Status : Completed								
2130	23050500	Female Surgery - Ward 205	FAN NOT WORKING - NEED URGENT SERVICE	Manimaran. M.	CEILING FAN CAPACITOR 2.5MFT 1NO CHANGED		Karthika. S. - Female Surgery	13/05/2023
Comp. Dt. : 19/05/2023 Status : Completed								
2131	23050786	Male Medical - Ward 301	HEATER SWITCH NOT WORKING	Vijayaraghavan.B.	16A SWITCH 1NO CHANGED		Soniya Gandhi. A. - Male Medical Ward	22/05/2023
Comp. Dt. : 20/05/2023 Status : Completed								
2132	23050826	Female Medical - Ward 306	NEED TO CHANGE TUBELIGHT	Srinivasan. R.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Sujitha. G. - Male Medical Ward	20/05/2023
Comp. Dt. : 22/05/2023 Status : Completed								
2133	23050887	Male Ortho - Ward 404	WATER NOT COMING - NEED TO CHECK PIPELINE	Manikandan. M.	WATER HEATER 1NO RESET WORK HEATER CHEKING WORK PROBLEM SOLVED		Ahamadh Meeran. A. - Male Medical Ward	23/05/2023
Comp. Dt. : 07/06/2023 Status : Completed								
2134	23060251	Male Medical - Ward 301	FAN SLOW PROBLEM	Vijayaraghavan.B.	CEILING FAN CAPACITOR 2.5MFT 1NO CHANGED		Seedhanjali. I - Male Medical Ward	08/06/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 13/06/2023 Status : Completed								
2135	23060464	Male Ortho - Ward 404	TRIP PROBLEM	Srinivasan. R.	MCB TRIP ON TO WORK PROBLEM SOLVED		Ahamadh Meeran. A. - Male Medical Ward	15/06/2023
Comp. Dt. : 28/06/2023 Status : Completed								
2136	23061047	Male Medical - Ward 301	NEED TO CHANGE NEBULIZER PLUG POINT - BROKEN	Manimaran. M.	6A Top 1no changed.		Karthikeyan. I. - Male Medical Ward	28/06/2023
Dept Name : Male Ortho Ward - Electrical Maintenance Comp. Dt. : 15/06/2022 Status : Completed								
2137	22060555	Male Ortho - Ward 404	NEED TO CHANGE LED LIGHT FOR DOCTOR'S RESTROOM	Manikandan. M.	9W LED LIGHT 1NO CHANGED		Rajasree. R. - Male Ortho Ward	15/06/2022
2138	22060586	Male Ortho - Ward 404	FAN NOT WORKING	Vijayaraghavan.B.	CEILING FAN 1NO BEARING 2NO'S CHANG & FAN REFIXING WORK PROBLEM SOLVED		Rajasree. R. - Male Ortho Ward	25/06/2022
Comp. Dt. : 15/07/2022 Status : Completed								
2139	22070583	Male Ortho - Ward 403	NEED TO CHANGE TUBELIGHT FOR PATIENT RESTROOM	Muthu. B.,Manikandan. M.,Manimaran. P.	36W TUBE LIGHT 2NO'S CHANG & 40W STARTER 3NO'S CHANGED		Rajasree. R. - Male Ortho Ward	16/07/2022
Comp. Dt. : 21/07/2022 Status : Completed								
2140	22070774	Male Ortho Ward	NEED TO CHECK X RAY LOBBY PLUG POINT NOT WORKING	Muthu. B.	6A 3PIN TOP 1NO CHANGED		Manjula. P. - Male Ortho Ward	21/07/2022
Comp. Dt. : 25/07/2022 Status : Completed								
2141	22070889	Male Ortho - Ward 403	NEED TO CHANGE TUBELIGHT [SMALL SIZE] FOR DOCTOR'S ROOM - RESTROOM	Vijayaraghavan.B.	9W LED LIGHT 1NO CHANGED		Vanitha. P. - Male Ortho Ward	26/07/2022
Comp. Dt. : 01/08/2022 Status : Completed								
2142	22080004	Male Ortho Ward	NEED TO CHECK POWER	Dhakshinamoorthy. J	MCB TRIP ON TO WORK PROBLEM SOLVED		Manjula. P. - Male Ortho Ward	02/08/2022
Comp. Dt. : 02/08/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2143	22080102	Male Ortho - Ward 404	NEED TO CHANGE TUBELIGHT	Srinivasan. R.	36W TUBE LIGHT 1NO CHANGED		Vanitha. P. - Male Ortho Ward	03/08/2022
	Comp. Dt. : 22/08/2022							
	Status : Completed							
2144	22080700	Male Ortho Ward	NEED TO CHECK POWER - WARD NO 403 & 404	Manimaran. P.	MCB TRIP ON TO WORK PROBLEM SOLVED		Manjula. P. - Male Ortho Ward	23/08/2022
	Comp. Dt. : 29/08/2022							
	Status : Completed							
2145	22080991	Male Ortho - Ward 403	NEED TO CHANGE TUBELIGHT	Dhakshinamoorthy. J	TUBE LIGHT 40W STARTER 1NO CHANGED		Vanitha. P. - Male Ortho Ward	30/08/2022
	Comp. Dt. : 15/09/2022							
	Status : Completed							
2146	22090611	Male Ortho - Ward 403	NEED TO CHANGE TUBELIGHT	Srinivasan. R.	TUBE LIGHT 40W STARTER 2NO'S CHANGED		Rajasree. R. - Male Ortho Ward	16/09/2022
	Comp. Dt. : 08/10/2022							
	Status : Completed							
2147	22100170	Male Surgery - Ward 204	X-RAY LOBBY NOT WORKING	Vijayaraghavan.B.	6A 3PIN TOP 1NO CHANGED		Vanitha. P. - Male Ortho Ward	10/10/2022
	Comp. Dt. : 13/10/2022							
	Status : Completed							
2148	22100409	Male Ortho - Ward 403	FAN NOT WORKING	Lakshmanan.V.	CEILING FAN REWINDING & BEARING CHANG & FAN REFIXING WORK PROBLEM SOLVED		Rajasree. R. - Male Ortho Ward	03/11/2022
	Comp. Dt. : 14/10/2022							
	Status : Completed							
2149	22100467	Male Ortho - Ward 404	NEED TO CHANGE RESTROOM CFL LIGHT FOR DOCTOR'S RESTROOM	Muthu. B.	9W LED LIGHT 1NO CHANGED		Rajasree. R. - Male Ortho Ward	15/10/2022
	Comp. Dt. : 28/10/2022							
	Status : Completed							
2150	22100920	Male Ortho - Ward 403	1 TUBELIGHT NOT WORKING	Muthu. B.	TUBE LIGHT 36W CHOKE 1NO CHANGED		Manikandan. V. - Male Ortho Ward	29/10/2022
	Comp. Dt. : 10/11/2022							
	Status : Completed							
2151	22110406	Male Ortho - Ward 403	STERILIZER NOT WORKING	Muthu. B.	2KW STRLIZER COIL 1NO CHANGED		Rajasree. R. - Male Ortho Ward	11/11/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 24/11/2022								
Status : Completed								
2152	22111072	Male Surgery - Ward 203	REQUEST TO EXTERN THE X-RAY LOBE WIRE	Lakshmanan.V.	1SQ MM WIRE 1MTR CHANGED		Vanitha. P. - Male Ortho Ward	25/11/2022
Comp. Dt. : 28/11/2022								
Status : Completed								
2153	22111190	Male Ortho - Ward 404	1 TUBELIGHT NOT WORKING	Lakshmanan.V.	9W LED LIGHT 1NO CHANGED		Rajasree. R. - Male Ortho Ward	30/11/2022
Comp. Dt. : 07/12/2022								
Status : Completed								
2154	22120292	DENTAL OPD -2ND FLOOR	FAN DUST NEED TO BE CLEAN	Manikandan. M.	CREATE USER NAME ENTERED WRONGLY		Vanitha. P. - Male Ortho Ward	07/12/2022
2155	22120294	Male Surgery - Ward 203	SWITCH BOARD ARE UNPLUGED,REFIXED IT	Rajan. R.	SWITCH BOARD SCREW REFIXING WORK PROBLEM SOLVED		Vanitha. P. - Male Ortho Ward	08/12/2022
Comp. Dt. : 08/12/2022								
Status : Completed								
2156	22120393	Male Surgery - Ward 203	IN DOCTOR'S REST ROOM-SMALL TUBELIGHT NOT WORKING ON BOTH 203 AND 204 WARD	Manimaran. P.	9W LED LIGHT 2NO'S CHANGED		Vanitha. P. - Male Ortho Ward	10/12/2022
Comp. Dt. : 09/12/2022								
Status : Completed								
2157	22120425	Female Surgery - Ward 205	HEATER NOT WORKING	Manimaran. P.	WATER HEATER RESET WORK PROBLEM SOLVED		Vanitha. P. - Male Ortho Ward	13/12/2022
Comp. Dt. : 12/12/2022								
Status : Completed								
2158	22120549	Male Ortho - Ward 403	IN WHOLE WARD-FAN DUST AND AROUND WARD DUST NEED TO BE CLEAN	Muthu. B.	ALL CEILING FAN CLEANING WORK PROBLEM SOLVED		Rajasree. R. - Male Ortho Ward	24/12/2022
Comp. Dt. : 15/12/2022								
Status : Completed								
2159	22120677	Female Surgery - Ward 205	HEATER NOT WORKING	Lakshmanan.V.	MCB TRIP ON TO WORK PROBLEM SOLVED		Vanitha. P. - Male Ortho Ward	19/12/2022
2160	22120678	Female Surgery - Ward 205	NEED TO CHANGE TUBELIGHT FOR NURSE'S DRESS CHANGING ROOM	Manimaran. P.	WATER HEATER CHEKING WORK PROBLEM SOLVED		Vanitha. P. - Male Ortho Ward	17/12/2022
Comp. Dt. : 22/12/2022								
Status : Completed								
2161	22121031	Male Ortho - Ward 404	FAN NOT WORKING	Thillaikumar. R.	CEILING FAN CAPACITOR 2.5MFT 1NO CHANGED		Manjula. P. - Male Ortho Ward	23/12/2022

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 26/12/2022								
Status : Completed								
2162	22121149	Male Ortho - Ward 403	TUBELIGHT NOT WORKING	Vengadessaperumal. K.	36W TUBE LIGHT 1NO CHANGED		Manjula. P. - Male Ortho Ward	26/12/2022
Comp. Dt. : 05/01/2023								
Status : Completed								
2163	23010248	Male Surgery - Ward 204	IN BOTH 203 AND 204-IN DOCTOR'S REST ROOM-2 NO'S LED BULB GOT FUSE	Sathishkumar. R.,Rajan. R.,Thillaikumar. R.	9W LED LIGHT 2NO'S CHANGED		Vanitha. P. - Male Ortho Ward	06/01/2023
2164	23010249	Male Surgery - Ward 204	2 NO'S TUBELIGHT NOT WORKING IN PATIENT REST ROOM	Sathishkumar. R.,Rajan. R.,Thillaikumar. R.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Vanitha. P. - Male Ortho Ward	06/01/2023
Comp. Dt. : 06/01/2023								
Status : Completed								
2165	23010283	Male Ortho - Ward 403	CORRIDOR-3 TUBELIGHTS NOT WORKING	Muthu. B.	36W TUBE LIGHT 2NO'S CHANG & 40W STARTER 2NO'S CHANGED		Rajasree. R. - Male Ortho Ward	07/01/2023
Comp. Dt. : 31/01/2023								
Status : Completed								
2166	23011126	Male Ortho - Ward 403	NEED TO CHANGE RESTROOM TUBELIGHT	Vijayaraghavan.B.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Manjula. P. - Male Ortho Ward	31/01/2023
Comp. Dt. : 15/02/2023								
Status : Completed								
2167	23020598	Male Surgery - Ward 204	FAN NOT WORKING	Srinivasan. R.	CEILING FAN CAPACIOTR 2.5MFT 1NO CHANGED		Vanitha. P. - Male Ortho Ward	16/02/2023
Comp. Dt. : 06/03/2023								
Status : Completed								
2168	23030198	Male Ortho - Ward 404	NEED TO REFIX ELECTRICAL CABLE - SWITCH BOX AT TREATMENT ROOM	Damodharan. V.	SWITCH BOARD SCREW REFIXING WORK PROBLEM SOLVED		Rajasree. R. - Male Ortho Ward	07/03/2023
Comp. Dt. : 08/03/2023								
Status : Completed								
2169	23030321	Male Ortho - Ward 403	NEED TO CHECK SWITCH BOX NOT WORKING AT TREATMENT ROOM	Manimaran. P.	SWITCH BOARD SCREW REFIXING WORK PROBLEM SOLVED		Rajasree. R. - Male Ortho Ward	16/03/2023
Comp. Dt. : 13/03/2023								
Status : Completed								
2170	23030477	Male Surgery - Ward 204	NEED TO CHECK X RAY LOBBY NOT WORKING AT DEMO ROOM	Damodharan. V.	6A 3PIN TOP 1NO CHANGED		Vanitha. P. - Male Ortho Ward	15/03/2023

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHAL KUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2171	23030505	Female Surgery - Ward 205	NEED TO CHECK PLUG POINT 3 NOS - NOT WORKING	Rajan. R.	SWITCH BOARD POWER CHEKING WORK PROBLEM SOLVED		Vanitha. P. - Male Ortho Ward	14/03/2023
		Comp. Dt. : 23/03/2023 Status : Completed						
2172	23030974	Male Medical - Ward 302	NEED TO CHANGE TUBELIGHT 2 NOS	Lakshmanan.V.	36W tube light 2no's & Starter 2no's changed.		Gayathri. R. - Male Ortho Ward	24/03/2023
		Comp. Dt. : 28/03/2023 Status : Completed						
2173	23031146	Male Ortho Ward	NEED TO CHECK POWER - ELECTRICAL ITEMS NOT WORKING - WARD NO 403 & 404	Muthu. B.	MCB trip - trip ON		Gayathri. S. - Male Ortho Ward	29/03/2023
		Comp. Dt. : 29/03/2023 Status : Completed						
2174	23031236	Male Ortho Ward	NEED TO CHECK PLUG POINT - POWER SUPPLY PROBLEM	Vijayaraghavan.B.	MCB trip - Trip ON.		Manikandan. V. - Male Ortho Ward	30/03/2023
		Comp. Dt. : 16/04/2023 Status : Completed						
2175	23040465	Male Ortho - Ward 404	NEED TO CHECK X RAY LOBBY LIGHT - DIM -	Manimaran. M.	20W TUBE LIGHT 1NO CHANGED		Rajasree. R. - Male Ortho Ward	18/04/2023
		Comp. Dt. : 20/04/2023 Status : Completed						
2176	23040678	Male Ortho - Ward 404	NEED TO CHANGE TUBELIGHT 2NOS FOR NURSE'S CABIN	Lakshmanan.V.	36W TUBE LIGHT 2NO'S CHANG & 40W STARTER 2NO'S CHANGED		Rajasree. R. - Male Ortho Ward	22/04/2023
		Comp. Dt. : 26/04/2023 Status : Completed						
2177	23040841	Male Ortho - Ward 404	HEATER NOT WORKING	Dhakshinamoorthy. J	WATER HEATER 1NO RESET WORK PROBLEM SOLVED		Maheswari. J. - Male Ortho Ward	27/04/2023
		Comp. Dt. : 09/05/2023 Status : Completed						
2178	23050374	Male Surgery - Ward 203	HEATER NOT WORKING	Dhakshinamoorthy. J	WATER HEATER 1NO RESET WORK PROBLEM SOLVED		Vanitha. P. - Male Ortho Ward	11/05/2023
		Comp. Dt. : 11/05/2023 Status : Completed						


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2179	23050419	Male Ortho - Ward 403	NEED TO CHANGE TUBELIGHT 3 NOS [COMPLETED]	Manimaran. P.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANG & 36W CHOKE 1NO CHANGED		Manjula. P. - Male Ortho Ward	11/05/2023
Comp. Dt. : 12/05/2023 Status : Completed								
2180	23050513	Male Ortho - Ward 404	HEATER NOT WORKING	Dhakshinamoorthy. J	WATER HEATER 1NO RESET WORK PROBLEM SOLVED		Rajasree. R. - Male Ortho Ward	13/05/2023
Comp. Dt. : 29/05/2023 Status : Completed								
2181	23051110	Male Ortho - Ward 403	NEED TO CHECK SEITCH BOARD NOT WORKING	Thillaikumar. R.	MCB TRIP ON TO WORK PROBLEM SOLVED		Manikandan. V. - Male Ortho Ward	30/05/2023
Comp. Dt. : 12/06/2023 Status : Completed								
2182	23060407	Male Ortho - Ward 403	HEATER NOTWORKING	Damodharan. V.	WATER HEATER 1NO RESET WORK PROBLEM SOLVED		Rajasree. R. - Male Ortho Ward	12/06/2023
Dept Name : Male Surgery - Electrical Maintenance Comp. Dt. : 04/05/2022 Status : Completed								
2183	22050109	Female Surgery - Ward 205	NEED TO CHANGE PLUG POINT FOR PATIENT BED SIDE [BROKEN & NOT WORKING]	Dhakshinamoorthy. J	MCB TRIP ON TO WORK PROBLEM SOLVED		Suseela. R. - ICU	05/05/2022
Comp. Dt. : 18/05/2022 Status : Completed								
2184	22050641	Female Surgery - Ward 206	NEED TO CHANGE TUBELIGHT & LED LIGHT FOR DOCTOR'S REST ROOM	Lakshmanan.V.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANG & 9W LED LIGHT 1NO CHANGED		Vaidegi. S. - Female Surgery	20/05/2022
Comp. Dt. : 19/05/2022 Status : Completed								
2185	22050726	Female Surgery - Ward 206	NEED TO CHECK POWER - SUPPLY PROBLEM - SYSTEM & ELECTRICAL ITEMS NOT WORKING IN DEMO ROOM	Lakshmanan.V.	MCB TRIP ON TO WORK PROBLEM SOLVED		Suseela. R. - ICU	21/05/2022
Comp. Dt. : 04/06/2022 Status : Completed								
2186	22060153	Male Surgery - Ward 201	FAN NOT WORKING [2NOS]	Rajan. R.	CEILING FAN CAPACITOR 2.5MFT 2NO'S CHANGED		Kanimozhi. N - Male Surgery	06/06/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 11/06/2022 Status : Completed								
2187	22060420	Female Surgery	STERILIZER NOT WORKING WORD NO 205 & 206	Muthu. B.	Sterlizer scrap.		Subashini. D. - Gynac Ward	14/06/2022
Comp. Dt. : 13/06/2022 Status : Completed								
2188	22060465	Female Surgery - Ward 205	NEED TO CHECK PLUG POINT - BURNED	Dhakshinamoorthy. J	Power point checked - ok, MCB Trip - trip ON.		Vaidegi. S. - Female Surgery	14/06/2022
Comp. Dt. : 14/06/2022 Status : Completed								
2189	22060493	Female Surgery - Ward 206	NEED TO CHANGE TUBELIGHT FOR PATIENT REST ROOM	Vengadessaperumal. K.	36W tube light 2no's & starter 2no's changed.		Vinodhini. K. - Female Surgery	14/06/2022
2190	22060520	Female Surgery - Ward 205	NEED TO CHANGE TUBELIGHT FOR DEMO ROOM	Srinivasan. R.	36W TUBE LIGHT 1NO CHANG & 6A SWITCH 1NO CHANGED		Priyanka. V. - Female Surgery	15/06/2022
Comp. Dt. : 29/08/2022 Status : Completed								
2191	22080963	Male Surgery - Ward 201	NEED TO CHECK POWER - PLUGPOINT & RESTROOM SIDE ELECTRICAL ITEMS ARE NOT WORKING	Muthu. B.	MCB TRIP ON TO WORK & 36W TUBE LIGHT 2NO'S CHANG & 40W STARTER 1NO CHANGED		Kanimozhi. N - Male Surgery	29/08/2022
Comp. Dt. : 30/08/2022 Status : Completed								
2192	22081040	Male Surgery - Ward 201	NEED TO CHECK POWER - PLUG POINT NOT WORKING	Manikandan. M.	MCB TRIP ON TO WORK PROBLEM SOLVED		Kanimozhi. N - Male Surgery	01/09/2022
Comp. Dt. : 14/09/2022 Status : Completed								
2193	22090570	Male Surgery - Ward 202	NEED TO CHANGE TUBELIGHT	Srinivasan. R.	36W TUBE LIGHT SET 1NO REFIXING WORK PROBLEM SOLVED		Sasikala. A. - Male Surgery	15/09/2022
Comp. Dt. : 26/09/2022 Status : Completed								
2194	22091010	Male Surgery - Ward 204	NEED TO CHANGE TUBELIGHT FOR PATIENT RESTROOM	Vijayaraghavan.B.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Sangeedha. M. - Male Surgery	28/09/2022
Comp. Dt. : 30/09/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2195	22091212	Male Surgery	NEED TO CHANGE REST ROOM TUBELIGHT - WARD NO 201 & 202	Dhakshinamoorthy. J	MCB TRIP ON TO WORK PROBLEM SOLVED		Sugumari. M. - Male Surgery	01/10/2022
2196	22091215	Male Surgery - Ward 201	NEED TO CHECK POWER - PROBLEM IN SYSTEM SIDE	Lakshmanan.V.	MCB TRIP ON TO WORK PROBLEM SOLVED		Sugumari. M. - Male Surgery	01/10/2022
Comp. Dt. : 10/10/2022 Status : Completed								
2197	22100258	Male Surgery - Ward 203	NEED TO CHANGE TUBELIGHT FOR DOCTOR'S ROOM	Dhakshinamoorthy. J	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Sugumari. M. - Male Surgery	11/10/2022
Comp. Dt. : 14/10/2022 Status : Completed								
2198	22100449	Male Surgery - Ward 201	STERILIZER NOT WORKING	Lakshmanan.V.	MCB TRIP ON TO WORK PROBLEM SOLVED		Sugumari. M. - Male Surgery	17/10/2022
Comp. Dt. : 27/10/2022 Status : Completed								
2199	22100864	Male Surgery - Ward 201	2 NO'S TUBELIGHT NOT WORKING IN BATHROOM	Vijayaraghavan.B.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Girija. S. - Male Surgery	28/10/2022
Comp. Dt. : 31/10/2022 Status : Completed								
2200	22100986	Obstetrics - Ward 208	NURSE CABIN FAN NOT WORKING	Muthu. B.	CEILING FAN CAPACITOR 2.5MFT 1NO CHANG & 6A SWITCH 1NO CHANGED		Sivasankari. T. - Male Surgery	04/11/2022
2201	22100997	Male Surgery - Ward 201	ONE TUBELIGHT BROKEN.NEED TO CHNAGE	Lakshmanan.V.	36W TUBE LIGHT 1NO CHANGED		Girija. S. - Male Surgery	02/11/2022
Comp. Dt. : 03/11/2022 Status : Completed								
2202	22110106	Male Surgery - Ward 202	3 NO'S TUBELIGHT NOT WORKING IN PATIENT'S BATHROOM	Dhakshinamoorthy. J	MCB TRIP ON TO WORK PROBLEM SOLVED		Ananthi. S. - Male Surgery	04/11/2022
Comp. Dt. : 16/11/2022 Status : Completed								
2203	22110663	Female Medical ward 307	POWER SUPPLY PROBLEM	Rajan. R.	MCB TRIP ON TO WORK PROBLEM SOLVED		Ananthi. S. - Male Surgery	17/11/2022
Comp. Dt. : 19/11/2022 Status : Completed								
2204	22110808	Male Surgery - Ward 201	NEED TO CHECK PLUG POINT NOT WORKING AT PATIENT SIDE	Thillaikumar. R.	6A SWITCH 1NO CHANGED		Sugumari. M. - Male Surgery	21/11/2022
Comp. Dt. : 22/11/2022								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
2205	22110927	Female Surgery - Ward 205	FOR EXAM PURPOSE NEED TO CHECK ALL PLUG POINT	Muthu. B.	ALL PLUG POINT CHEKING WORK PROBLEM SOLVED		Sugumari. M. - Male Surgery	23/11/2022
Comp. Dt. : 30/11/2022								
Status : Completed								
2206	22111288	Male Surgery - Ward 201	WATER HEATER NOT WORKING IN BATHROOM	Muthu. B.	PLMBING DEPT COMPLAINT PENDING		Girija. S. - Male Surgery	03/12/2022
Comp. Dt. : 12/12/2022								
Status : Completed								
2207	22120500	Female Surgery - Ward 205	X-RAY LOBBY NOT WORKING	Vijayaraghavan.B.	6A 3PIN TOP 1NO CHANGED		Ezhilarasi. E. - Male Surgery	14/12/2022
Comp. Dt. : 13/12/2022								
Status : Completed								
2208	22120570	Female Surgery - Ward 205	3 NO'S TUBELIGHT NOT WORKING	Vijayaraghavan.B.	36W TUBE LIGHT 1NO'S CHANG & 40W STARTER 2NO'S CHANGED		Archana. G. - Male Surgery	14/12/2022
Comp. Dt. : 21/12/2022								
Status : Completed								
2209	22120949	Male Surgery - Ward 201	TUBE LIGHT NOT WORKING - 2 NOS	Thillaikumar. R.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 4NO'S CHANGED		Kanimozhi. N - Male Surgery	23/12/2022
2210	22120950	Male Surgery - Ward 201	HEATER NOT WORKING	Dhakshinamoorthy. J	NEW WATER HEATER 15LTR 1NO FIXING WORK & LINE CONNECTION WORK PROBLEM SOLVED		Kanimozhi. N - Male Surgery	26/12/2022
Comp. Dt. : 05/01/2023								
Status : Completed								
2211	23010231	Male Surgery - Ward 201	IN PATIENT BATHROOM-WATER HEATER NOT WORKING	Dhakshinamoorthy. J	16A SWITCH 1NO CHANG & HEATER CHEKING WORK PROBLEM SOLVED		Kanimozhi. N - Male Surgery	06/01/2023
Comp. Dt. : 14/01/2023								
Status : Completed								
2212	23010595	Male Surgery - Ward 203	HEATER NOT WORKING IN PATIENT RESTROOM	Lakshmanan.V.	WATER HEATER 1NO RESET WORK PROBLEM SOLVED		Sasikala. A. - Male Surgery	18/01/2023
Comp. Dt. : 17/02/2023								
Status : Completed								
2213	23020693	Male Surgery - Ward 202	NEED TO CHANGE TUBELIGHT	Manikandan. M.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Kanimozhi. N - Male Surgery	18/02/2023

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 28/02/2023								
Status : Completed								
2214	23021070	Male Surgery - Ward 201	ONE FAN AND 2 TUBELIGHTS NOT WORKING	Srinivasan. R.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANG & CEILING FAN CAPACITOR 2.5MFT 1NO CHANGED		Malathy. S - Male Surgery	01/03/2023
Comp. Dt. : 06/03/2023								
Status : Completed								
2215	23030209	Female Surgery - Ward 205	NEED TO CHANGE TUBELIGHT FOR CARITOR	Damodharan. V.	36W TUBE LIGHT 1NO CHANGED		Raveena. K. - Male Surgery	07/03/2023
2216	23030239	Female Surgery - Ward 205	FAN NOT WORKING	Srinivasan. R., Damodharan. V., Dhakshinamoorthy. J	Fan coil problem removed to power room. Spare Fan fixed.		Sivasankari. T. - Male Surgery	06/04/2023
Comp. Dt. : 11/03/2023								
Status : Completed								
2217	23030455	Male Surgery - Ward 201	FAN NOT WORKING	Srinivasan. R.	CEILING FAN CAPACITOR 2.5MFT 1NO CHANGED		Kanimozhi. N - Male Surgery	16/03/2023
Comp. Dt. : 30/03/2023								
Status : Completed								
2218	23031322	Male Surgery - Ward 201	HEATER NOT WORKING	Vijayaraghavan.B.	Heater reset - OK.		Kanimozhi. N - Male Surgery	01/04/2023
Comp. Dt. : 31/03/2023								
Status : Completed								
2219	23031365	Male Surgery - Ward 202	NEED TO CHANGE TUBELIGHT	Muthu. B.	Tube light starter 1no changed.		Sasikala. A. - Male Surgery	01/04/2023
Comp. Dt. : 04/04/2023								
Status : Completed								
2220	23040110	Male Surgery - Ward 201	NEED TO CHANGE RESTROOM TUBELIGHT	Manimaran. M.	36W Tube light 1no & E.choke 1no changed.		Sasikala. A. - Male Surgery	04/04/2023
Comp. Dt. : 06/04/2023								
Status : Completed								
2221	23040180	Male Surgery - Ward 204	NEED TO REFIX ELECTRICAL BOARD AT EXAM ROOM	Muthu. B.	Switch board refixed.		Ezhilarasi. E. - Male Surgery	08/04/2023
2222	23040181	Male Surgery - Ward 204	WATER LEAKAGE IN STEBULIZER	Muthu. B.	sterlizer checked - ok		Ezhilarasi. E. - Male Surgery	08/04/2023
Comp. Dt. : 16/04/2023								
Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2223	23040479	Male Surgery - Ward 202	NEED REPAIRING WORK FOR PLUG POINT SWITCH - BROKEN	Srinivasan. R.	MCB TRIP ON TO WORK PROBLEM SOLVED		Kanimozhi. N - Male Surgery	17/04/2023
Comp. Dt. :		20/04/2023						
Status :		Completed						
2224	23040626	Male Surgery - Ward 201	STERILIZER NOT WORKING	Dhakshinamoorthy. J	NEW STERILIZER 2KW COIL 1NO CHANG & CHEKING WORK PROBLEM SOLVED		Sarmila. M. - Female Surgery	20/04/2023
Comp. Dt. :		26/04/2023						
Status :		Completed						
2225	23040880	Male Surgery - Ward 202	SWITCH BOARD NOT WORKING	Vijayaraghavan.B.	MCB TRIP ON TO WORK PROBLEM SOLVED		Kanimozhi. N - Male Surgery	28/04/2023
2226	23040881	Male Surgery - Ward 202	NEED TO CHANGE LED LIGHT FOR DOCTOR'S RESTROOM	Dhakshinamoorthy. J	36W TUBE LIGHT 1NO CHANG & 40W STARTER 2NO'S CHANGED		Kanimozhi. N - Male Surgery	27/04/2023
2227	23040883	Male Surgery - Ward 202	NEED TO CHANGE TUBELIGHT FOR REST ROOM	Dhakshinamoorthy. J	9W LED LIGHT 1NO CHANGED		Kanimozhi. N - Male Surgery	27/04/2023
Comp. Dt. :		02/05/2023						
Status :		Completed						
2228	23050061	Male Surgery - Ward 202	FAN NOT WORKING	Rajan. R.	CEILING FAN CAPACIOTR 2.5MFT 1NO CHANGED		Sasikala. A. - Male Surgery	03/05/2023
Comp. Dt. :		11/05/2023						
Status :		Completed						
2229	23050425	Male Surgery - Ward 202	FAN NOT WORKING	Manimaran. P.	CEILING FAN CAPACITOR 2.5MFT 1NO CHANGED		Sasikala. A. - Male Surgery	11/05/2023
Comp. Dt. :		26/05/2023						
Status :		Completed						
2230	23051026	Male Surgery - Ward 201	NEED TO CHANGE TUBELIGHT	Vijayaraghavan.B.	Tube light starter 1no changed.		Malathy. S - Male Surgery	26/05/2023
Comp. Dt. :		29/05/2023						
Status :		Completed						
2231	23051120	Male Surgery - Ward 202	NEED TO CHANGE TUBELIGHT FOR STAFF RESTROOM	Thillaikumar. R.	9W LED LIGHT 1NO CHANGED		Malathy. S - Male Surgery	30/05/2023
Comp. Dt. :		01/06/2023						
Status :		Completed						
2232	23060006	Male Surgery - Ward 202	NEED TO REFIX FAN - FAN FELL DOWN	Muthu. B.	NEW CEILING FAN 1NO REFIXING WORK PROBLEM SOLVED		Kanimozhi. N - Male Surgery	02/06/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 05/06/2023								
Status : Completed								
2233	23060133	Male Ortho - Ward 404	POWER ISSUE - NEED TO CHECK	Manimaran. P.	elcb trip . power on		Santhiya. N. - Male Surgery	05/06/2023
Comp. Dt. : 08/06/2023								
Status : Completed								
2234	23060257	Male Surgery - Ward 201	NEED TO REFIT TUBELIGHT - DUE TO CLEANING WORK REMOVED	Rajan. R.	36W TUBE LIGHT FITTING 1NO REFIXING WORK PROBLEM SOLVED		Kanimozhi. N - Male Surgery	09/06/2023
2235	23060291	Female Surgery - Ward 206	FAN NOT WORKING AT TREATMENT ROOM	Dhakshinamoorthy. J	6A SWITCH 1NO CHANGED		Sarmila. M. - Female Surgery	09/06/2023
Comp. Dt. : 16/06/2023								
Status : Completed								
2236	23060574	Male Surgery - Ward 201	ONE TUBRLIGHT FIX THE CEILING	Muthu. B.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Kanimozhi. N - Male Surgery	17/06/2023
Comp. Dt. : 23/06/2023								
Status : Completed								
2237	23060892	Male Surgery - Ward 201	NEED TO CHANGE TUBELIGHT 3 NOS	Lakshmanan.V.	TUBE LIGHT 40W STARTER 2NO'S CHANGED		Kanimozhi. N - Male Surgery	24/06/2023
Comp. Dt. : 28/06/2023								
Status : Completed								
2238	23061077	Male Surgery - Ward 201	NEED TO CHECK TUBELIGHT AT DEMO ROOM & SUCTION APPARATUS PLUG - NOT WORKING	Manimaran. M.	6A top 1no changed.		Kanimozhi. N - Male Surgery	28/06/2023
2239	23061079	Male Surgery - Ward 202	TUBE LIGHT NOT WORKING 1 NOS & NEED TO CHECK ALL TUBELIGHT CONNECTIONS	Vijayaraghavan.B.	TUBE LIGHT 36W CHOKE 1NO CHANGED		Sangeedha. M. - Male Surgery	30/06/2023
Dept Name : Marketing Team - Electrical Maintenance								
Comp. Dt. : 02/05/2022								
Status : Completed								
2240	22050001	IVF ART CLINIC-INSIDE OF OG OPD(NO.68)	NEED TO CHECK POWER FOR RECEPTION AREA - LIGHT & FAN NOT WORKING	Lakshmanan.V.	UPS TRIP ON TO WORK PROBLEM SOLVED		Sathiya. M. - Marketing Team	05/05/2022
Comp. Dt. : 24/05/2022								
Status : Completed								

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2241	22050903	SPECIAL WARD - A1	TV NOT WORKING ROOM NO 5	Lakshmanan.V.	MCB TRIP ON TO WORK PROBLEM SOLVED		Sathiya Priya. J. - Marketing Team	25/05/2022
	Comp. Dt. : 13/06/2022							
	Status : Completed							
2242	22060434	Special Ward - A	T V NOT WORKING IN ROOM NO 9	Lakshmanan.V.	TV mode changed - ok		Gokulraj. K. - Marketing Team	14/06/2022
	Comp. Dt. : 22/06/2022							
	Status : Completed							
2243	22060795	FEVER CLINIC	NEED TO REFIX FAN CABLE	Srinivasan. R.	WIRE CUT RECONNECTION WORK PROBLEM SOLVED		Amirtharaj. A. - Marketing Team	23/06/2022
	Comp. Dt. : 30/06/2022							
	Status : Completed							
2244	22061100	IVF ART CLINIC-INSIDE OF OG OPD(NO.68)	NEED TO FIX A NEW PLUG POINT 2 NOS	Rajan. R.	PLUG POINT CHEKING NO COMPLAINT PROBLEM SOLVED		Sathiya. M. - Marketing Team	12/07/2022
	Comp. Dt. : 01/07/2022							
	Status : Completed							
2245	22070014	SPECIAL WARD---B	NEED TO CHANGE TUBELIGHT [2NOS] FOR ROOM NO B7-8-9	Muthu. B.	36W TUBE LIGHT 3NO'S CHANG & 40W STARTER 4NO'S CHANGED		Prithivi. G. - Marketing Team	02/07/2022
	Comp. Dt. : 27/07/2022							
	Status : Completed							
2246	22070994	Special Ward - A	HEATER NOT WORKING - ROOM NO 8	Srinivasan. R.	WATER HEATER 1NO RESET WORK PROBLEM SOLVED		Dhanalakshmi. D. - Marketing Team	29/07/2022
	Comp. Dt. : 01/08/2022							
	Status : Completed							
2247	22080019	SPECIAL WARD - A1	FAN SOUND PROBLEM - ROOM NO 8 & TV NOT WORKING ROOM NO 4	Vijayaraghavan.B.	SETUP BOX 1NO CHANGED		Shameena Begum. A. - Marketing Team	02/08/2022
2248	22080021	SPECIAL WARD---B	NEED TO CHECK FAN - SOUND PROBLEM ROOM NO B 22	Dhakshinamoorthy. J	CEILING FAN BEARING 2NO'S CHANG & FAN REFIXING WORK PROBLEM SOLVED		Shameena Begum. A. - Marketing Team	03/08/2022
	Comp. Dt. : 22/08/2022							
	Status : Completed							
2249	22080706	SPECIAL WARD---B	NEED TO CHANGE TUBELIGHT FOR ROOM NO 13	Vijayaraghavan.B.	36W TUBE LIGHT 1NO CHANGED		Shameena Begum. A. - Marketing Team	23/08/2022
	Comp. Dt. : 14/09/2022							


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
2250	22090566	Special Ward - C	FAN NOT WORKING - FEMALE SIDE ROOM NO 3	Dhakshinamoorthy. J	CEILING FAN CAPACITOR 2.5MFT 1NO CHANGED		Vijayalakshmi. V. - Marketing Team	15/09/2022
Comp. Dt. : 19/09/2022								
Status : Completed								
2251	22090714	SPECIAL WARD---B	FAN SLOW PROBLEM ROOM NO B7-B8	Lakshmanan.V.	CEILING FAN CAPACITOR 2.5MFT 1NO CHANGED		Gokulraj. K. - Marketing Team	20/09/2022
Comp. Dt. : 24/09/2022								
Status : Completed								
2252	22090977	LIFT 5	SENSOR PROBLEM - NEED TO CHECK LIFT NO 5	Azhagappan. J.	lift problem solved.		Dhanalakshmi. D. - Marketing Team	24/09/2022
Comp. Dt. : 13/10/2022								
Status : Completed								
2253	22100403	SPECIAL WARD - A1	NEED TO CHANGE CFL LIGHT FOR RESTROOM - ROOM NO 1	Srinivasan. R.	18W CFL 2PIN 2NO'S CHANGED		Shameena Begum. A. - Marketing Team	14/10/2022
Comp. Dt. : 19/10/2022								
Status : Completed								
2254	22100618	SPECIAL WARD - A1	IN ROOM NO:9 TV NOT WORKING	Lakshmanan.V.	TV CHEKING WORK PROBLEM SOLVED		Bhuvaneshwari. M. - Marketing Team	20/10/2022
Comp. Dt. : 26/10/2022								
Status : Completed								
2255	22100809	Chairman Office	NEED TO CHANGE FAN ROD	Vaithianathan.M	Fan condomed.		Priya. A. - Marketing Team	07/11/2022
Comp. Dt. : 03/11/2022								
Status : Completed								
2256	22110070	SPECIAL WARD -B IN FOURTH FLOOR	IN ROOM NO.19/20/21-WATER HEATER NOT WORKING	Lakshmanan.V.	WATER HEATER RESET WORK PROBLEM SOLVED		Prithivi. G. - Marketing Team	04/11/2022
Comp. Dt. : 15/11/2022								
Status : Completed								
2257	22110630	SPECIAL WARD A1-FOURTH FLOOR	IN ROOM NO.10 TV NOT WORKING	Vijayaraghavan.B.	TV SETUP BOX RESET WORK PROBLEM SOLVED		Prithivi. G. - Marketing Team	16/11/2022
Comp. Dt. : 17/12/2022								
Status : Completed								
2258	22120797	CUSTOMER CARE EXECUTIVE-RECEPTIO N	PEDESTAL FAN SOUND PROBLEM	Dhakshinamoorthy. J	WALLMOUNTING FAN SERVICE WORK PROBLEM SOLVED		Sathiya Priya. J. - Marketing Team	19/12/2022
Comp. Dt. : 21/12/2022								

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
2259	22120962	Chairman Office	PLUG POINT NOT WORKING - POWER SUPPLY PROBLEM	Manimaran. M.	MCB TRIP ON TO WORK PROBLEM SOLVED		Priya. A. - Marketing Team	21/12/2022
Comp. Dt. : 05/01/2023								
Status : Completed								
2260	23010224	CUSTOMER CARE EXECUTIVE-RECEPTION	WALL MOUNTED FAN SOUND PROBLEM	Vijayaraghavan.B.	WALLMOUNTING FAN 1NO SERVICE WORK PROBLEM SOLVED		Sathiya Priya. J. - Marketing Team	06/01/2023
Comp. Dt. : 25/02/2023								
Status : Completed								
2261	23020976	SPECIAL WARD - A1	TV NOT WORKING - ROOM NO 2	Vengadessaperumal. K.	TV SETUP BOX RESET WORK PROBLEM SOLVED		Shameena Begum. A. - Marketing Team	27/02/2023
Comp. Dt. : 17/04/2023								
Status : Completed								
2262	23040498	Reception	NEED TO CHECK ROTATING FAN - NOT ROTATING	Srinivasan. R.	WALLMOUNTING FAN CHEKING WORK NO COPMLAINT		Sathiya Priya. J. - Marketing Team	18/04/2023
Comp. Dt. : 15/06/2023								
Status : Completed								
2263	23060533	Special Ward - A	ROOM NO-8,TV PICTURE NOT COMING	Srinivasan. R.	TV SETUP BOX 1NO RESET WORK PROBLEM SOLVED		Ramya. C. - Marketing Team	16/06/2023
Comp. Dt. : 20/06/2023								
Status : Completed								
2264	23060712	IVF ART CLINIC-INSIDE OF OG OPD(NO.68)	FIRE FIRE EXTINGUISHER - DISPLAY EXPIRY DATE	Babu. D.	FIRE EXTINGUISHER CYLENDER 1NO CHANGED		Sathiya. M. - Marketing Team	21/06/2023
Dept Name : Medical Records - Electrical Maintenance								
Comp. Dt. : 02/05/2022								
Status : Completed								
2265	22050058	Medical Records	NEED FAN FIXING WORK	Muthu. B.	CEILING FAN CAPACIOTR 2.5MFT 1NO CHANGED		Martin Prabu.V. - Medical Records	20/05/2022
Comp. Dt. : 05/05/2022								
Status : Completed								
2266	22050166	Medical Records	FAN NOT WORKING	Manimaran. P.	CEILING FAN CAPACITOR 2.5MFT 1NO CHANGED		Martin Prabu.V. - Medical Records	09/05/2022
Comp. Dt. : 06/05/2022								
Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2267	22050173	Medical Records	NEED TO CHANGE TUBELIGHT 3 NOS	Muthu. B.	36W TUBE LIGHT 2NO'S CHANG & 40W STARTER 1NO CHANG & 36W CHOKE 1NO CHANGED		Iswin Joseph.M. - Medical Records	12/05/2022
Comp. Dt. : 12/05/2022 Status : Completed								
2268	22050406	CASHCOUNTER IN RECEPTION	ELECTRICAL WIRE INSIDE WORK	Muthu. B.	ELECTRICAL WIRE & SWITCH BOARD REFIXING WORK PROBLEM SOLVED		Iyyanar. D. - Medical Records	13/05/2022
Comp. Dt. : 24/05/2022 Status : Completed								
2269	22050895	Medical Records	NEED TO CHANGE TUBELIGHT	Manimaran. P.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Martin Prabu.V. - Medical Records	25/05/2022
Comp. Dt. : 28/05/2022 Status : Completed								
2270	22051034	Medical Records	NEED TO FIX TUBELIGHT SET	Srinivasan. R.	36W TUBE LIGHT SET 1NO REFIXING WORK PROBLEM SOLVED		Martin Prabu.V. - Medical Records	31/05/2022
Comp. Dt. : 15/06/2022 Status : Completed								
2271	22060550	Medical Records	NEED TO CHANGE TUBELIGHT	Manikandan. M.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Martin Prabu.V. - Medical Records	15/06/2022
Comp. Dt. : 21/06/2022 Status : Completed								
2272	22060775	Medical Records	NEED NEW PLUG POINTS 2 NOS	Muthu. B.	6A SWITCH 1NO CHANGED		Martin Prabu.V. - Medical Records	01/07/2022
Comp. Dt. : 27/06/2022 Status : Completed								
2273	22060969	Medical Records	NEED TO CHECK PLUG POINTS 2 NOS - NOT WORKING	Muthu. B.	6A SWITCH 1NO CHANGED		Iswin Joseph.M. - Medical Records	28/06/2022
Comp. Dt. : 28/06/2022 Status : Completed								
2274	22060993	Medical Records	NEED TO CHANGE TUBELIGHT 3NOS & SWITCH 2 NOS	Muthu. B.	36W TUBE LIGHT 2NO'S CHANG & 40W STARTER 2NO'S CHANG & SIDE HOLDER 1NO CHANGED		Martin Prabu.V. - Medical Records	28/06/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2275	22061021	COMMON TOILET NEAR OPHTAL OPD	NEED TO CHANGE TUBELIGHT FOR COMMON TOILET NEAR OPHTAL OPD ENTRANCE	Srinivasan. R.	TUBE LIGHT 40W STARTER 1NO CHANGED		Sukanya. S. - Medical Records	29/06/2022
Comp. Dt. : 08/07/2022 Status : Completed								
2276	22070330	Male Medical - Ward 304	NEED TO CHECK PLUG POINT AT NURSE'S STATION	Dhakshinamoorthy. J	MCB TRIP ON TO WORK PROBLEM SOLVED		Mohanapriya. A. - Medical Records	11/07/2022
Comp. Dt. : 12/07/2022 Status : Completed								
2277	22070461	Medical Records	NEED TO CHANGE TUBELIGHT - NOT WORKING	Rajan. R.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Martin Prabu.V. - Medical Records	12/07/2022
Comp. Dt. : 13/07/2022 Status : Completed								
2278	22070498	Medical Records	NEED TO CHANGE TUBELIGHT	Rajan. R.	TUBE LIGHT 36W CHOKE 1NO CHANGED		Martin Prabu.V. - Medical Records	14/07/2022
Comp. Dt. : 26/07/2022 Status : Completed								
2279	22070967	Male Medical - Ward 302	NEED TO CHECK POWER - SYSTEM NOT WORKING	Muthu. B.	MCB TRIP ON TO WORK PROBLEM SOLVED		Mohanapriya. A. - Medical Records	27/07/2022
Comp. Dt. : 27/07/2022 Status : Completed								
2280	22070985	COMMON TOILET NEAR OPHTAL OPD	NEED TO CHANGE TUBELIGHT FOR RESTROOM ENTRANCE -	Manimaran. P.	36W TUBE LIGHT 1NO CHANGED		Sukanya. S. - Medical Records	27/07/2022
Comp. Dt. : 30/07/2022 Status : Completed								
2281	22071085	COMMON TOILET NEAR OPHTAL OPD	NEED TO CHANGE TUBELIGHT FOR INSIDE FEMALE RESTROOM	Dhakshinamoorthy. J	6A SWITCH 1NO CHANGED		Sukanya. S. - Medical Records	02/08/2022
Comp. Dt. : 30/08/2022 Status : Completed								
2282	22081014	Obstetrics - Ward 207	NEED TO CHECK POWER - ELECTRICAL ITEMS NOT WORKING	Manikandan. M.	SINGLE POLE MCB 1NO TRIP ON TO WORK PROBLEM SOLVED		Jerina. M. - Medical Records	01/09/2022
Comp. Dt. : 06/09/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2283	22090200	Medical Records	NEED TO ADJUST FAN ROD - DIE TO INSUFFICIENT AIR AT ENTRANCE FAN	Manikandan. M.	COMPLAINT CHEKING WORK NO COMPLAINT		Martin Prabu.V. - Medical Records	07/09/2022
Comp. Dt. : 13/09/2022 Status : Completed								
2284	22090474	Obstetrics - Ward 208	NEED TO CHECK POWER - SUPPLY PROBLEM 1/2 HOUR	Rajan. R.	MCB TRIP ON TO WORK PROBLEM SOLVED		Jerina. M. - Medical Records	13/09/2022
Comp. Dt. : 14/09/2022 Status : Completed								
2285	22090543	EDP IN UNDERGROUND	NEED TO CHANGE TUBELIGHT FOR ENTRANCE	Suresh. V.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Martin Prabu.V. - Medical Records	15/09/2022
Comp. Dt. : 27/09/2022 Status : Completed								
2286	22091067	Medical Records	NEED TO CHANGE TUBELIGHT	Manikandan. M.	36W TUBE LIGHT 3NO'S CHANG & 36W CHOKE 1NO CHANG & 40W STARTER 1NO CHANGED		Martin Prabu.V. - Medical Records	28/09/2022
Comp. Dt. : 30/09/2022 Status : Completed								
2287	22091223	SUPER SPECILAITY OPD IN 2ND FLOOR	NEED TO PROVIDE ELECTRICAL ITEMS TUBELIGHT , FAN & PLUGPOINT FOR WARD SECRETARY ROOM	Srinivasan. R.	PLUG POINT FIXING WORK & LINE CONNECTION WORK PROBLEM SOLVED		Martin Prabu.V. - Medical Records	06/10/2022
Comp. Dt. : 22/10/2022 Status : Completed								
2288	22100743	Medical Records	NEED TO CHANGE TUBE LIGHT - 2 NOS	Muthu. B.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Murugan. J. - Medical Records	25/10/2022
Comp. Dt. : 28/10/2022 Status : Completed								
2289	22100912	Medical Records	REQUEST TO GET DOWN CEILING FAN WITH EXTENSION ROD	Lakshmanan.V.	CEILING FAN ROD EXTENSION WORK PROBLEM SOLVED		Martin Prabu.V. - Medical Records	29/10/2022
Comp. Dt. : 10/11/2022 Status : Completed								
2290	22110388	Medical Records	2 NO'S TUBELIGHT NOT WORKING	Lakshmanan.V.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 2NO'S CHANGED		Martin Prabu.V. - Medical Records	14/11/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 17/11/2022								
Status : Completed								
2291	22110695	Medical Records	1 TUBELIGHT NOT WORKING	Manikandan. M.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Martin Prabu.V. - Medical Records	18/11/2022
Comp. Dt. : 29/11/2022								
Status : Completed								
2292	22111206	Paediatrics - Ward 308	FAN NOT WORKING	Lakshmanan.V.	CEILING FAN BEARING 2NO'S CHANG & FAN REFIXING WORK PROBLEM SOLVED		Deepa. S. - Medical Records	02/12/2022
Comp. Dt. : 07/12/2022								
Status : Completed								
2293	22120310	Medical Records	1 TUBELIGHT NOT WORKING	Rajan. R.	36W TUBE LIGHT 2NO'S CHANGED		Raj Kumar. K. - Medical Records	08/12/2022
Comp. Dt. : 19/12/2022								
Status : Completed								
2294	22120842	Obstetrics - Ward 208	TUBELIGHT NOT WORKING IN PATIENTS RESTROOM	Rajan. R.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Jerina. M. - Medical Records	19/12/2022
Comp. Dt. : 23/12/2022								
Status : Completed								
2295	22121099	Medical Records	TUBELIGHT NOT WORKING - 2 NOS	Vengadessaperumal. K.	36W TUBE LIGHT 2NO'S CHANG & 40W STARTER 1NO CHANG & 36W CHOKE 1NO CHANGED		Martin Prabu.V. - Medical Records	26/12/2022
Comp. Dt. : 31/12/2022								
Status : Completed								
2296	22121382	Male Surgery - Ward 202	PLUG POINT NOT WORKING	Manimaran. P.	MCB trip - Trip ON		Pushparaj. J. - Medical Records	31/12/2022
Comp. Dt. : 13/01/2023								
Status : Completed								
2297	23010549	Medical Records	NEED TO CHANGE TUBELIGHT 2 NOS	Damodharan. V.	36W TUBE LIGHT 3NO'S CHANG & 36W CHOKE 1NO CHANGED		Martin Prabu.V. - Medical Records	18/01/2023
Comp. Dt. : 10/02/2023								
Status : Completed								
2298	23020381	Medical Records	NEED TO CHANGE ONE TUBELIGHT	Vijayaraghavan.B.	starter 1nos changed		Kumaravel. R. - Medical Records	10/02/2023
Comp. Dt. : 15/02/2023								
Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2299	23020582	SUPER SPECILAITY OPD IN 2ND FLOOR	FAN SOUND PROBLEM	Thillaikumar. R.	WALLMOUNTING FAN SERVICE WORK PROBLEM SOLVED		Punitha. P. - Medical Records	20/02/2023
Comp. Dt. : 27/02/2023 Status : Completed								
2300	23021030	Obstetrics - Ward 208	NEED TO CHECK POWER -	Muthu. B.	MCB TRIP ON TO WORK PROBLEM SOLVED		Jerina. M. - Medical Records	28/02/2023
Comp. Dt. : 20/03/2023 Status : Completed								
2301	23030805	Medical Records	NEED TO CHANGE TUBELIGHT	Rajan. R.	36W TUBE LIGHT 1NO CHANGED		Martin Prabu.V. - Medical Records	20/03/2023
2302	23030817	Medical Records	NEED TO CHANGE TUBELIGHT FOR ENTRANCE	Rajan. R.	TUBE LIGHT 40W STARTER 1NO CHANGED		Martin Prabu.V. - Medical Records	20/03/2023
Comp. Dt. : 29/03/2023 Status : Completed								
2303	23031258	Medical Records	FAN NOT WORKING	Lakshmanan.V.	wire problem - solved.		Iswin Joseph.M. - Medical Records	30/03/2023
Comp. Dt. : 30/03/2023 Status : Completed								
2304	23031327	Male Surgery - Ward 204	need to check nurse's cabin fan - slow problem	Bharanidharan. R.	Fan checked - ok.		Praveena. V. - Medical Records	04/04/2023
Comp. Dt. : 03/04/2023 Status : Completed								
2305	23040041	ENT WARD-407	TRIP PROBLEM - NED TO CHECK	Dhakshinamoorthy. J	MCB Trip - Trip ON.		Jeyasudha. V. - Medical Records	03/04/2023
2306	23040078	Obstetrics - Ward 208	NEED TO CHECK POWER - ELECTRICAL ITEMS ARE NOT WORKING	Bharanidharan. R.	MCB trip - trip ON.		Jerina. M. - Medical Records	04/04/2023
Comp. Dt. : 05/04/2023 Status : Completed								
2307	23040143	Medical Records	TUBELIGHT [4NOS] NOT WORKING	Vijayaraghavan.B.	36W tube light 2no's & starter 4no's changed.		Martin Prabu.V. - Medical Records	05/04/2023
Comp. Dt. : 17/04/2023 Status : Completed								
2308	23040523	Medical Records	NEED TO CHANGE TUBELIGHT	Srinivasan. R.	TUBE LIGHT 40W STARTER 1NO CHANGED		Martin Prabu.V. - Medical Records	18/04/2023
Comp. Dt. : 08/05/2023 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2309	23050320	SPECIAL OPD IN 2ND FLOOR	NEED FAN CLEANING WORK	Rajan. R.	WALLMOUNTING FAN 1NO CLEANING WORK PROBLEM SOLVED		Parasuraman. R. - Medical Records	09/05/2023
Comp. Dt. : 15/05/2023 Status : Completed								
2310	23050615	Medical Records	NEED TO CHANGE TUBELIGHT 4 NOS	Srinivasan. R.	36W TUBE LIGHT 2NO'S CHANG & 36W CHOKE 1NO CHANGED		Martin Prabu.V. - Medical Records	16/05/2023
Comp. Dt. : 23/05/2023 Status : Completed								
2311	23050926	COMMON TOILET NEAR OPHTAL OPD	NEED TO CHANGE TUBELIGHT FOR FEMALE RESTROOM [4 NOS]	Muthu. B.	36W TUBE LIGHT 2NO'S CHANG & 40W STARTER 1NO CHANG & 36W CHOKE 1NO CHANGED		Sukanya. S. - Medical Records	24/05/2023
Comp. Dt. : 31/05/2023 Status : Completed								
2312	23051218	Medical Records	NEED TO CHECK FAN	Damodharan. V.	PEDESTAL FAN CHEKING WORK NO COMPLAINT		Martin Prabu.V. - Medical Records	02/06/2023
Comp. Dt. : 09/06/2023 Status : Completed								
2313	23060306	Medical Records	NEED TO CHANGE TUBELIGHT	Srinivasan. R.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Martin Prabu.V. - Medical Records	10/06/2023
Comp. Dt. : 12/06/2023 Status : Completed								
2314	23060381	Medical Records	NEED TO FIX NEW FAN 2 NOS	Vijayaraghavan.B.	NEW CEILING FAN 2NO'S WIRING WORK & FAN FIXING WORK & LINE CONNECTION WOPRK PROBLEM SOLVED		Martin Prabu.V. - Medical Records	12/06/2023
2315	23060402	Medical Records	NEED TO REPLACE EXHAUST FAN [INSIDE TO OUTSIDE]	Vijayaraghavan.B.	EXHAUST FAN 2NO'S REMOVING TO REFIXING WORK PROBLEM SOLVED		Martin Prabu.V. - Medical Records	19/06/2023
Comp. Dt. : 21/06/2023 Status : Completed								
2316	23060739	Medical Records	NEED TO CHANGE TUBELIGHT	Vengadessaperumal. K.	TUBE LIGHT 40W STARTER 1NO CHANGED		Martin Prabu.V. - Medical Records	21/06/2023
Dept Name : MICROBIOLOGY - Electrical Maintenance Comp. Dt. : 16/05/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2317	22050577	MICROBIOLOGY	NEED TO FIX NEW PLUG POINTS FOR FIXING NEW MACHINES	Vijayaraghavan.B.	NEW 8M EXECTION BOX 1NO FIXING WORK & LINE CONNECTION WORK PROBLEM SOLVED		Gopal. R. - MICROBIOLOGY	02/06/2022
Comp. Dt. : 28/05/2022 Status : Completed								
2318	22051037	MICROBIOLOGY	NEED TO CHANGE TUBELIGHT FOR ENTRANCE	Suresh. V.	22W LED LIGHT FITTING 1NO REFIXING WORK PROBLEM SOLVED		Punitha. P. - MICROBIOLOGY	30/05/2022
Comp. Dt. : 09/07/2022 Status : Completed								
2319	22070392	MICROBIOLOGY	NEED TO CHANGE TUBELIGHT FOR ENTRANCE	Rajan. R.	36W TUBE LIGHT 1NO CHANGED		Punitha. P. - MICROBIOLOGY	11/07/2022
Comp. Dt. : 19/07/2022 Status : Completed								
2320	22070703	MICROBIOLOGY	NEED TO CHANGE TUBELIGHT	Srinivasan. R.	36W TUBE LIGHT 1NO CHANGED		Karthik. S. - MICROBIOLOGY	20/07/2022
Comp. Dt. : 10/08/2022 Status : Completed								
2321	22080372	MICROBIOLOGY	NEED A NEW U P S LINE CONNECTION FOR ELISA MACHINE	Muthu. B.	ELISA MACHINE UPS LINE CONNECTION WORK PROBLEM SOLVED		Karthik. S. - MICROBIOLOGY	12/08/2022
Comp. Dt. : 08/09/2022 Status : Completed								
2322	22090311	MICROBIOLOGY	PROBLEM IN U P S - NEED TO CHECK	Vijayaraghavan.B.	NEW BATTERY 12V,7AHU 8NO'S CHANG & UPS CHEKING WORK PROBLEM SOLVED		Karthik. S. - MICROBIOLOGY	14/09/2022
2323	22090318	MICROBIOLOGY	NEED TO CHECK U P S NOT WORKING	Vijayaraghavan.B.	3KVA UPS CHEKING WORK NO BACKUP BATTERY PROBLEM		Gopal. R. - MICROBIOLOGY	10/09/2022
Comp. Dt. : 27/09/2022 Status : Completed								
2324	22091037	MICROBIOLOGY	NEED TO CHANGE TUBELIGHT	Suresh. V.	TUBE LIGHT 1NO CHANGED		Arunachalam. G. - MICROBIOLOGY	28/09/2022
Comp. Dt. : 22/11/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2325	22110945	MICROBIOLOGY	NEED TO FIX NEW PLUG POINT	Muthu. B.	8M SURFACE BOX 1NO, 8M PLATE 1NO, 6A SWITCH 2NO'S,6A SOCKET 3NO'S FIXNG & LINE CONNECTION WORK PROBL		Karthik. S. - MICROBIOLOGY	28/11/2022
Comp. Dt. : 27/12/2022 Status : Completed								
2326	22121234	microbiology opd lab	1 TUBELIGHT NOT WORKING	Muthu. B.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANG & SIDE HOLDER 2NO'S CHANGED		Karthik. S. - MICROBIOLOGY	28/12/2022
Comp. Dt. : 05/01/2023 Status : Completed								
2327	23010212	microbiology opd lab	LED LIGHT NEED TO BE FIX	Muthu. B.	LED LIGHT 1NO FIXING WORK PROBLEM SOLVED		Karthik. S. - MICROBIOLOGY	06/01/2023
Comp. Dt. : 11/01/2023 Status : Completed								
2328	23010489	microbiology opd lab	1 TUBELIGHT NOT WORKING	Srinivasan. R.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Karthik. S. - MICROBIOLOGY	12/01/2023
Comp. Dt. : 07/02/2023 Status : Completed								
2329	23020230	MICROBIOLOGY	NEED TO REFIX ONE PLUG POINT	Muthu. B.	6A SOCKET 2NO'S,6A SWITCH 2NO'S,6M PLATE 1NO,6M SURFACE BOX 1NO,2.5SQMM WIRE 5MTR FIXING & LINE CONN		Karthik. S. - MICROBIOLOGY	07/02/2023
Comp. Dt. : 15/02/2023 Status : Completed								
2330	23020570	MICROBIOLOGY	NEED TO CHANGE TUBELIGHT	Vengadessaperumal. K.	TUBE LIGHT 40W STARTER 1NO CHANGED		Vinothini. V. - MICROBIOLOGY	15/02/2023
Comp. Dt. : 16/02/2023 Status : Completed								
2331	23020654	microbiology opd lab	UPS NOT WORKING	Muthu. B.	3KVA UPS NEW BATTERY 8NO'S CHANG & UPS CHEKING WORK PROBLEM SOLVED		Karthik. S. - MICROBIOLOGY	20/02/2023
Comp. Dt. : 25/02/2023 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2332	23020987	MICROBIOLOGY	NEED TO CHANGE CEILING LIGHT - NOT WORKING	Muthu. B.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Karthik. S. - MICROBIOLOGY	27/02/2023
Comp. Dt. : 09/05/2023 Status : Completed								
2333	23050372	MICROBIOLOGY	NEED TO CHANGE LED LIGHT	Manimaran. P.	22W LED LIGHT 1NO CHANGED		Arunachalam. G. - MICROBIOLOGY	11/05/2023
Comp. Dt. : 20/05/2023 Status : Completed								
2334	23050848	MICROBIOLOGY	EXHAUST FAN NOT WORKING	Srinivasan. R.	CAPACITOR 2.5MFT 1NO CHANG & FAN CHEKING WORK PROBLEM SOLVED		Yuvaraj. P. - MICROBIOLOGY	20/05/2023
Comp. Dt. : 10/06/2023 Status : Completed								
2335	23060346	MICROBIOLOGY	NEED TO CHANGE TUBELIGHT	Rajan. R.	TUBE LIGHT 40W STARTER 1NO CHANGED		Karthik. S. - MICROBIOLOGY	10/06/2023
Comp. Dt. : 21/06/2023 Status : Completed								
2336	23060777	MICROBIOLOGY	NEED TO CHANGE TUBELIGHT	Vijayaraghavan.B.	36W TUBE LIGHT 1NO CHANGED		Karthik. S. - MICROBIOLOGY	22/06/2023
Dept Name : MS Office - Electrical Maintenance Comp. Dt. : 17/05/2022 Status : Completed								
2337	22050598	MS Office	NEED TO CHANGE TUBELIGHT	Dhakshinamoorthy. J	36W TUBE LIGHT 1NO CHANG & 36W CHOKE 1NO CHANGED		Manikandan. A. - MS Office	18/05/2022
Comp. Dt. : 18/06/2022 Status : Completed								
2338	22060669	MS Office	NEED TO CHANGE TUBELIGHT FOR DMS MADAM ROOM	Suresh. V.	36W E.choke 1no changed.		Hemavathi. P. - MS Office	18/06/2022
Comp. Dt. : 24/06/2022 Status : Completed								
2339	22060882	SKILL OP IN 5TH FLOOR	NEED TO CHANGE CEILING LIGHT	Muthu. B.	NEW 50W LED DRIVER 1NO CHANGED		Elumalai. M. - MS Office	29/06/2022
Comp. Dt. : 13/07/2022 Status : Completed								
2340	22070517	SPECIAL WARD---B	NEED TO CHANGE TUBELIGHT FOR COMMON RESTROOM	Rajan. R.	36W TUBE LIGHT 1NO CHANGED		Indarajan. R. - MS Office	14/07/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 22/08/2022 Status : Completed								
2341	22080728	MS Office	NEED TO CHANGE RESTROOM TUBELIGHT - NOT WORKING	Vengadessaperumal. K.	TUBE LIGHT 40W STARTER 1NO CHANGED		Hemavathi. P. - MS Office	23/08/2022
Comp. Dt. : 28/09/2022 Status : Completed								
2342	22091115	MS Office	NEED TO CHANGE TUBELIGHT FOR MS SIR ROOM ENTRANCE	Lakshmanan.V.	TUBE LIGHT 40W STARTER 1NO CHANGED		Manikandan. A. - MS Office	29/09/2022
Comp. Dt. : 01/10/2022 Status : Completed								
2343	22100003	MS Office	NEED FAN CLEANING WORK	Manimaran. P.	ALL CEILING FAN CLEANING WORK PROBLEM SOLVED		Manikandan. A. - MS Office	05/10/2022
Comp. Dt. : 15/10/2022 Status : Completed								
2344	22100486	MS Office	NEED TO CHECK POWER - SYSTEM NOT WORKING	Sathishkumar. R.	MCB TRIP ON TO WORK PEOBLEM SOLVED		Manikandan. A. - MS Office	17/10/2022
Comp. Dt. : 31/10/2022 Status : Completed								
2345	22101027	Reception	ALL FANS CLEANING WORK	Srinivasan. R.	ALL CEILING FAN CLEANING WORK PROBLEM SOLVED		Sundarrajan. R. - MS Office	02/11/2022
Comp. Dt. : 16/11/2022 Status : Completed								
2346	22110647	MS Office	1 TUBELIGHT NOT WORKING-1220	Manikandan. M.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Nageswari. N. - MS Office	17/11/2022
Comp. Dt. : 02/12/2022 Status : Completed								
2347	22120070	MS Office	FAN SLOW PROBLEM AT DINNING ROOM NEED URGENT SERVICE	Vijayaraghavan.B.	CEILING FAN CAPACITOR 2.5MFT 1NO CHANGED		Manikandan. A. - MS Office	03/12/2022
Comp. Dt. : 18/01/2023 Status : Completed								
2348	23010609	MS Office	NEED TO CHANGE TUBELIGHT - M S SIR ROOM ENTRANCE	Damodharan. V.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Manikandan. A. - MS Office	18/01/2023
Comp. Dt. : 28/03/2023								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
2349	23031181	Reception	NEED TO CHECK WALL FAN - SOUND PROBLEM AT PATIENT WAITING AREA	Vengadessaperumal. K.,Thillaikumar. R.,Dhakshinamoorth y. J	wallmounting fan serviced & Fixed.		Sundarrajan. R. - MS Office	08/04/2023
Comp. Dt. : 13/04/2023								
Status : Completed								
2350	23040400	General Medicine - OPD	NEED TO CHECK PLUG POINT FOR OPD ENTRANCE	Manimaran. P.	6A Socket changed.		Sundarrajan. R. - MS Office	13/04/2023
Comp. Dt. : 22/06/2023								
Status : Completed								
2351	23060818	MS Office	NEED TO CHANGE TUBELIGHT - NOT WORKING AT M S SIR ROOM	Babu. D.	TUBE LIGHT 40W STARTER 1NO CHANGED		Manikandan. A. - MS Office	23/06/2023
Dept Name : Nephrology - Electrical Maintenance								
Comp. Dt. : 02/05/2022								
Status : Completed								
2352	22050060	DIALYSIS NEW UNIT IN 1ST FLOOR	NEED TO CHECK RO MOTOR - SOUND PROBLEM	Dhakshinamoorthy. J	1HP MOTOR SOUND CHEKING WORK NO PROBLEM SOLVED		Aathimoolam. R. - Nephrology	05/05/2022
Comp. Dt. : 15/07/2022								
Status : Completed								
2353	22070597	DIALYSIS NEW UNIT IN 1ST FLOOR	T V & T V REMOTE NOT WORKING	Muthu. B.	1.5V BATTERY 2NO'S CHANGED		Neelavathi. T. - Nephrology	16/07/2022
Comp. Dt. : 19/08/2022								
Status : Completed								
2354	22080619	DIALYSIS IN 2ND FLOOR	TV SIGNAL PROBLEM	Vengadessaperumal. K.	TV SETUPBOX SETTING PROBLEM SOLVED		Suganya. B. - Nephrology	22/08/2022
2355	22080620	DIALYSIS IN 2ND FLOOR	TUBE LIGHT NOT WORKING	Dhakshinamoorthy. J	9W LED LIGHT 2NO'S CHANG & BABY HOLDER 2NO'S CHANGED		Suganya. B. - Nephrology	23/08/2022
Comp. Dt. : 26/08/2022								
Status : Completed								
2356	22080864	DIALYSIS NEW UNIT IN 1ST FLOOR	NEED TO CHANGE & CHECK PLUG POINT , SWITCH , SWITCH BOARD - PROBLEM	Lakshmanan.V.	16A SWITCH 1NO CHANGED		Suriya. A. - Nephrology	27/08/2022
Comp. Dt. : 12/09/2022								
Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2357	22090445	DIALYSIS NEW UNIT IN 1ST FLOOR	PROBLEM IN ACID MACHINE	Dhakshinamoorthy. J	MOTOR BEARING 2NO'S CHANG & PUSH CHANG CAPACITOR CHANG & MOTOR REFIXING WORK PROBLEM SOLVED		Aathimoolam. R. - Nephrology	22/09/2022
Comp. Dt. : 11/10/2022 Status : Completed								
2358	22100291	DIALYSIS NEW UNIT IN 1ST FLOOR	NEED TO CHECK VOLTAGE	Lakshmanan.V.	SWITCH BOARD VOLTAGE CHECKING WORK NO PROBLEM SOLVED		Kamal. B. - Nephrology	12/10/2022
Comp. Dt. : 12/10/2022 Status : Completed								
2359	22100330	DIALYSIS IN 2ND FLOOR	SHOCK COMING	Dhakshinamoorthy. J	SWITCH BOARD EARTH CHECKING WORK NO PROBLEM SOLVED		Kamal. B. - Nephrology	12/10/2022
Comp. Dt. : 28/10/2022 Status : Completed								
2360	22100901	DIALYSIS NEW UNIT IN 1ST FLOOR	FAN NOT WORKING	Dhakshinamoorthy. J	PEDESTAL FAN 3NO'S SERVICE & CHECKING WORK PROBLEM SOLVED		Kamal. B. - Nephrology	31/10/2022
Comp. Dt. : 08/11/2022 Status : Completed								
2361	22110312	DIALYSIS IN 2ND FLOOR	AURO WATER MACHINE SMOKE COMING	Manimaran. M.	15MFT CAPACITOR 1NO CHANGED		Suganya. B. - Nephrology	09/11/2022
Comp. Dt. : 18/11/2022 Status : Completed								
2362	22110742	DIALYSIS IN 2ND FLOOR	NEED TO CHECK POWER - TRIP PROBLEM	Rajan. R.	MCB TRIP ON TO WORK PROBLEM SOLVED		Suganya. B. - Nephrology	22/11/2022
Comp. Dt. : 06/12/2022 Status : Completed								
2363	22120227	DIALYSIS NEW UNIT IN 1ST FLOOR	3 PIN CHARGING PLUG POINT BURNT	Rajan. R.	16A SOCKET 1NO CHANG & 16A SWITCH 1NO CHANGED		Neelavathi. T. - Nephrology	07/12/2022
Comp. Dt. : 07/12/2022 Status : Completed								
2364	22120334	DIALYSIS IN 2ND FLOOR	R O WATER MOTOR NOT WORKING - NEED URGENT SERVICE	Lakshmanan.V.	RO WATER MOTOR SERVICE WORK PROBLEM SOLVED		Suganya. B. - Nephrology	08/12/2022
Comp. Dt. : 10/12/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2365	22120450	DIALYSIS NEW UNIT IN 1ST FLOOR	NEED TO CHANGE CEILING LIGHT - NOT WORKING	Lakshmanan.V.	6A SWITCH 1NO CHANGED		Kamal. B. - Nephrology	28/12/2022
	Comp. Dt. : 14/12/2022 Status : Completed							
2366	22120644	DIALYSIS NEW UNIT IN 1ST FLOOR	TV NOT WORKING TV NO 2	Manimaran. P.	TV SETUP BOX RESET WORK PROBLEM SOLVED		Aathimoolam. R. - Nephrology	15/12/2022
	Comp. Dt. : 26/12/2022 Status : Completed							
2367	22121154	DIALYSIS NEW UNIT IN 1ST FLOOR	TV CABLE NOT WORKING	Vengadessaperumal. K.	SETUP BOX ADAPTER 5V,2A 1NO CHANG & CHEKING WORK PROBLEM SOLVED		Kamal. B. - Nephrology	18/01/2023
	Comp. Dt. : 05/01/2023 Status : Completed							
2368	23010234	DIALYSIS NEW UNIT IN 1ST FLOOR	SPARK FROM PLUG POINT CONNECTION	Dhakshinamoorthy. J	16A SOCKET WIRE LOOSE SCREW REFIXING WORK PROBLEM SOLVED		Neelavathi. T. - Nephrology	06/01/2023
	Comp. Dt. : 20/01/2023 Status : Completed							
2369	23010702	DIALYSIS IN 2ND FLOOR	Motor not working.	Muthu. B.	MOTOR CHEKING WORK PROBLEM SOLVED		Suganya. B. - Nephrology	21/01/2023
	Comp. Dt. : 02/02/2023 Status : Completed							
2370	23020059	DIALYSIS IN 2ND FLOOR	T V NOT WORKING	Vengadessaperumal. K.	TV CHEKING NO COMPLAINT PROBLEM SOLVED		Suganya. D. - Nephrology	02/02/2023
	Comp. Dt. : 10/02/2023 Status : Completed							
2371	23020380	DIALYSIS IN 2ND FLOOR	RO BOOSTER MOTOR PROBLEM	Lakshmanan.V.	plumbing work incomplete		Aathimoolam. R. - Nephrology	11/02/2023
	Comp. Dt. : 14/02/2023 Status : Completed							
2372	23020558	DIALYSIS NEW UNIT IN 1ST FLOOR	EXHAUST FAN NOT WORKING	Vijayaraghavan.B.	EXHAUST FAN 1NO REMOVING TO ELECTRICAL ROOM		Kamal. B. - Nephrology	16/02/2023
	Comp. Dt. : 16/02/2023 Status : Completed							
2373	23020646	DIALYSIS IN 2ND FLOOR	(1260) PLUG POINT SOCKET PROBLEM	Lakshmanan.V.	MCB TRIP ON TO WORK PROBLEM SOLVED		Aathimoolam. R. - Nephrology	17/02/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 25/02/2023 Status : Completed								
2374	23020980	DIALYSIS IN 2ND FLOOR	TRIP PROBLEM	Manikandan. M.,Rajan. R.,Vengadessaperumal.K.	UPS TRIP ON TO WORK PROBLEM SOLVED		Suganya. B. - Nephrology	28/02/2023
Comp. Dt. : 28/02/2023 Status : Completed								
2375	23021088	DIALYSIS IN 2ND FLOOR	R O ROOM ONE TUBELIGHT NOT WORKING	Srinivasan. R.	TUBE LIGHT 40W STARTER 1NO CHANGED		Santhiya. S. - Nephrology	01/03/2023
Comp. Dt. : 16/03/2023 Status : Completed								
2376	23030626	DIALYSIS NEW UNIT IN 1ST FLOOR	MOTOR LEAKAGE	Rajan. R.	MOTOR WATER LEAK PROBLEM.		Kamal. B. - Nephrology	06/04/2023
2377	23030657	DIALYSIS IN 2ND FLOOR	NEED TO CHANGE TUBELIGHT	Muthu. B.	Motor scrap. Tube light starter 1no changed.		Preetha. E. - Nephrology	18/03/2023
Comp. Dt. : 11/04/2023 Status : Completed								
2378	23040290	DIALYSIS IN 2ND FLOOR	NEED TO CHECK PLUG POINT & SWITCH BOARD - R O WATER BOARD NOT WORKING NEED URGENT SERVICE	Srinivasan. R.,Manikandan. M.,Manimaran. P.	25A socket problem. new 25A Socket changed.		Padmarajarajan. M - Nephrology	12/04/2023
Comp. Dt. : 12/04/2023 Status : Completed								
2379	23040363	DIALYSIS IN 2ND FLOOR	R O RAW WATER MOTOR NOT WORKING	Manikandan. M.	Motor coil problem. Spare motor fixed and tested ok.		Suganya. B. - Nephrology	12/04/2023
2380	23040364	DIALYSIS IN 2ND FLOOR	NEED TO CHANGE TUBELIGHT FOR REUSE AREA	Manimaran. M.	Wire problem - solved.		Suganya. B. - Nephrology	13/04/2023
Comp. Dt. : 17/04/2023 Status : Completed								
2381	23040511	DIALYSIS NEW UNIT IN 1ST FLOOR	FAN NOT WORKING	Muthu. B.	6A SWITCH 2NO'S CHANGED		Kamal. B. - Nephrology	18/04/2023
2382	23040512	DIALYSIS NEW UNIT IN 1ST FLOOR	BOOSTER PUMP NOT WORKING	Srinivasan. R.	BOOSTER PUMP CHEKING WORK PROBLEM SOLVED		Kamal. B. - Nephrology	18/04/2023
Comp. Dt. : 19/04/2023 Status : Completed								
2383	23040580	DIALYSIS NEW UNIT IN 1ST FLOOR	NEED TO CHANGE CEILING LIGHT	Manikandan. M.	9W LED LIGHT 1NO CHANGED		Sivakumar. S. - Nephrology	20/04/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 20/04/2023 Status : Completed								
2384	23040646	DIALYSIS IN 2ND FLOOR	ALL LIGHT DIM - NEED TO CHANGE ALL LIGHTS	Vijayaraghavan.B.	36W CFL 4PIN LIGHT 5NO'S CHANG & 40W STARTRE 4NO'S CHANGED		Suganya. B. - Nephrology	20/04/2023
Comp. Dt. : 02/05/2023 Status : Completed								
2385	23050055	DIALYSIS IN 2ND FLOOR	NEED TO CHECK R O BOOSTER MOTOR	Dhakshinamoorthy. J	OLR SETTING CHANG & MOTOR CHEKING WORK PROBLEM SOLVED		Suganya. B. - Nephrology	02/05/2023
Comp. Dt. : 15/05/2023 Status : Completed								
2386	23050597	DIALYSIS NEW UNIT IN 1ST FLOOR	NEED TO CHANGE FAN BOTTOM	Muthu. B.	PEDESTAL FAN WORSHOP DEPT COMPLAINT PROBLEM SOLVED		Kamal. B. - Nephrology	25/05/2023
Comp. Dt. : 30/05/2023 Status : Completed								
2387	23051183	DIALYSIS IN 2ND FLOOR	NEED TO CHANGE TUBELIGHT [DAUM] FOR POSITIVE ROOM	Suresh. V.	4pin 36W CFL 1no changed.		Suganya. B. - Nephrology	31/05/2023
Comp. Dt. : 01/06/2023 Status : Completed								
2388	23060044	DIALYSIS NEW UNIT IN 1ST FLOOR	NEED TO CHANGE SWITCH - NOT WORKING	Manikandan. M.	16A SWITCH 1NO CHANGED		Kamal. B. - Nephrology	02/06/2023
Comp. Dt. : 15/06/2023 Status : Completed								
2389	23060534	DIALYSIS IN 2ND FLOOR	TV NOT WORKING	Srinivasan. R.	TV SETUP BOX 1NO RESET WORK PROBLEM SOLVED		Suganya. D. - Nephrology	16/06/2023
Comp. Dt. : 30/06/2023 Status : Completed								
2390	23061119	DIALYSIS IN 2ND FLOOR	PROBLEM IN R O BOOSTER MOTOR	Lakshmanan.V.	16A SOCKET 1NO CHANGED		Suganya. B. - Nephrology	01/07/2023
Dept Name : NEUROLOGY - Electrical Maintenance Comp. Dt. : 11/04/2023 Status : Completed								
2391	23040332	EEG	NEED TO CHECK POWER - SUPPLY PROBLEM	Muthu. B.	MCB trip - Trip ON.		Vasuki. P. - NEUROLOGY	11/04/2023
Dept Name : Nursing Office - Electrical Maintenance								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 09/05/2022								
Status : Completed								
2392	22050246	Nursing Office	NEED TO CHANGE TUBELIGHT FOR N S MADAM ROOM	Manikandan. M.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Muthazhagi. A. - Nursing Office	09/05/2022
Comp. Dt. : 10/05/2022								
Status : Completed								
2393	22050366	DNS DRESS CHANGING ROOM	FAN NOT WORKING - NEED URGENT SERVICE	Srinivasan. R.	CEILING FAN WIRE CUT RECONNECTION WORK PROBLEM SOLVED		Prabavathi. K. - Nursing Office	12/05/2022
Comp. Dt. : 13/05/2022								
Status : Completed								
2394	22050477	Female Ortho - Ward 401	STERLIZER PLUG POINT AND SWITCH BOARD PROBLEM	Muthu. B.	16A 3PIN TOP 2NO'S CHANGED		Leena Grace. B. - Nursing Office	14/05/2022
Comp. Dt. : 24/05/2022								
Status : Completed								
2395	22050916	SPECIAL WARD - A1	NEED TO FIX 3 PIN PLUG POINTS EACH BOARD 3 SETS [MULTI] FOR ALL ROOMS	Lakshmanan.V.	ALL ROOM SOCKET FIXING POINT CHEKING WORK		Tamilarasi.C. - Nursing Office	25/05/2022
Comp. Dt. : 27/05/2022								
Status : Completed								
2396	22051020	Paediatrics - Ward 309	NEED TO CHANGE TUBELIGHT FOR PANTRY ROOM	Muthu. B.	TUBE LIGHT 40W STARTER 1NO CHANGED		Sivaranjani. S. - Male Medical Ward	28/05/2022
Comp. Dt. : 08/06/2022								
Status : Completed								
2397	22060293	Male Surgery	NEED FAN CLEANING WORK FOR ALL SURGERY WARDS FROM 201 TO 209	Lakshmanan.V.,Vijay araghavan.B.,Senthil Murugan. A.	ALL 201 TO 209 CEILING FAN CLEANING WORK PROBLEM SOLVED		Padma. A. - Nursing Office	09/06/2022
2398	22060294	Male Surgery - Ward 201	NEED TO REARRANGE CABLE FOR SWITCH BOX - SWITCH BOX REFIX	Dhakshinamoorthy. J	SWITCH BOARD REFIXING WORK PROBLEM SOLVED		Padma. A. - Nursing Office	09/06/2022
Comp. Dt. : 09/06/2022								
Status : Completed								
2399	22060358	SICU	EARTH PROBLEM IN SEPTIC ROOM - NEED URGENT SERVICE	Srinivasan. R.	REST ROOM SWITCH BOARD WIRE CUT RECONNECTION WORK PROBLEM SOLVED		Padma. A. - Nursing Office	10/06/2022
Comp. Dt. : 10/06/2022								
Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2400	22060367	TB AND CHEST WARD-405	BATHROOM LIGHT NOT WORKING	Dhakshinamoorthy. J	Tube light starter 1no & side holder 2no's changed.		Leena Grace. B. - Nursing Office	11/06/2022
Comp. Dt. : 06/07/2022 Status : Completed								
2401	22070189	General Medicine - OPD	NEED TO FIX NEW TUBELIGHT SET FOR ECG ROOM	Rajan. R.	36W TUBE LIGHT 1NO CHANGED		Prabavathi. K. - Nursing Office	12/07/2022
2402	22070227	FEMALE DRESS CHANGING ROOM (NEAR POW-3RD FLOOR)	FLASH LIGHT NOT WORKING	Manimaran. P.	Wire problem - 3Pin top 1no & Wire 4m chnaged.		Ilambharat.K. - Nursing Office	08/07/2022
Comp. Dt. : 08/07/2022 Status : Completed								
2403	22070325	SPECIAL WARD---B	NEED FAN CLEANING WORK FOR ALL ROOMS	Dhakshinamoorthy. J	ALL CEILING FAN CLEANING WORK PROBLEM SOLVED		Tamilarasi.C. - Nursing Office	11/07/2022
Comp. Dt. : 18/07/2022 Status : Completed								
2404	22070656	Male Medical - Ward 301	NEED TO CHANGE TUBELIGHT 2 NOS	Dhakshinamoorthy. J	6A SWITCH 1NO CHANG & 36W TUBE LIGHT 1NO CHANGED		Kalaiaarasi. D. - Nursing Office	19/07/2022
Comp. Dt. : 04/08/2022 Status : Completed								
2405	22080146	MS Office	NEED TO CHANGE TUBELIGHT FOR DNS MADAM ROOM	Dhakshinamoorthy. J	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Muthazhagi. A. - Nursing Office	04/08/2022
Comp. Dt. : 05/08/2022 Status : Completed								
2406	22080198	Labour Room	NEED TO CHECK CRASH CART LIGHT CONNECTION - PROBLEM	Vijayaraghavan.B.	36W TUBE LIGHT 2NO'S CHANG & 40W STARTER 2NO'S CHANGED		Ilambharat.K. - Nursing Office	06/08/2022
Comp. Dt. : 08/08/2022 Status : Completed								
2407	22080275	Female Medical - Ward 305	NEED TO CHANGE TUBELIGHT	Vijayaraghavan.B.	36W TUBE LIGHT 2NO'S CHANG & 40W STARTER 2NO'S CHANGED		Leena Grace. B. - Nursing Office	09/08/2022
Comp. Dt. : 11/08/2022 Status : Completed								
2408	22080393	Labour Room	NEED TO CHECK POWER FOR PLUG POINT - NOT WORKING	Muthu. B.	MCB TRIP ON TO WORK PROBLEM SOLVED		Powlin.P. - Nursing Office	11/08/2022

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 17/08/2022 Status : Completed								
2409	22080493	RICU	TUBELIGHT NOT WORKING	Vengadessaperumal. K.	Tube light starter 1no changed.		Powlin.P. - Nursing Office	17/08/2022
Comp. Dt. : 24/08/2022 Status : Completed								
2410	22080783	ICU	NEED TO CHANGE TUBELIGHT FOR ICU CARITOR	Lakshmanan.V.	22W ROUNT LED LIGHT 1NO CHANG & 36W 4PIN CFL LIGHT 3NO'S CHANGED		Powlin.P. - Nursing Office	24/08/2022
Comp. Dt. : 25/08/2022 Status : Completed								
2411	22080837	RICU	NEED TO CHANGE TUBELIGHT	Muthu. B.	TUBE LIGHT 40W STARTER 1NO CHANGED		Powlin.P. - Nursing Office	26/08/2022
Comp. Dt. : 26/08/2022 Status : Completed								
2412	22080883	POW & SICU	NEED TO FIX NEW SWITCH BOX [TEMPARARY ARRANGEMENT]	Sathishkumar. R.	SWITCH BOARD ARRANGEMENT WORK PROBLEM SOLVED		Padma. A. - Nursing Office	06/09/2022
Comp. Dt. : 30/08/2022 Status : Completed								
2413	22081043	Male Surgery - Ward 201	NEED TO CHANGE TUBELIGHT FOR RESTROOM	Manikandan. M.	36W TUBE LIGHT 1NO CHANGED		Padma. A. - Nursing Office	01/09/2022
Comp. Dt. : 08/09/2022 Status : Completed								
2414	22090340	SPECIAL WARD - A1	NEED TO CHECK SWITCH BOX - NOT WORKING IN ROOM NO 1	Muthu. B.	PLUG POIN WIRE LOOSE RECONNECTION WORK PROBLEM SOLVED		Tamilarasi.C. - Nursing Office	09/09/2022
Comp. Dt. : 16/09/2022 Status : Completed								
2415	22090637	Ophthalmology - OPD	NEED TO CHANGE TUBELIGHT FOR ROOM NO 84	Muthu. B.	36W TUBE LIGHT 1NO CHANGED		Kalaierasi. D. - Nursing Office	17/09/2022
Comp. Dt. : 06/10/2022 Status : Completed								
2416	22100107	Male Surgery	NEED FAN CLEANING WORK FOR WARD NO 201 TO 208	Vijayaraghavan.B.	203 WARD CEILING FAN CLEANING WORK PROBLEM SOLVED		Padma. A. - Nursing Office	08/10/2022
Comp. Dt. : 10/10/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2417	22100205	Male Medical - Ward 303	FAN NOT WORKING	Muthu. B.	6A SWITCH WIRE LOOSE RECONNECTION WORK PROBLEM SOLVED		Leena Grace. B. - Nursing Office	10/10/2022
2418	22100245	Casualty	NEED TO CHECK STERILIZER - SHOCK PROBLEM	Muthu. B.	STERILIZER COIL CHEKING WORK NO PROBLEM SOLVED		Sudha.L. - Nursing Office	11/10/2022
Comp. Dt. : 12/10/2022 Status : Completed								
2419	22100351	Nursing Office	NEED TO CHANGE TUBELIGHT	Lakshmanan.V.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Muthazhagi. A. - Nursing Office	13/10/2022
Comp. Dt. : 02/11/2022 Status : Completed								
2420	22110003	Male Surgery - Ward 201	HEATER NOT WORKING	Srinivasan. R.	WATER HEATER CHEKING HOUSE PROBLEM		Devika.R - Nursing Office	04/11/2022
Comp. Dt. : 07/11/2022 Status : Completed								
2421	22110238	ANS DRESS CHANGING ROOM	1 TUBELIGHT NOT WORKING PROPERLY	Vijayaraghavan.B.	36W tube light 1no & starter 1no changed.		Powlin.P. - Nursing Office	07/11/2022
Comp. Dt. : 09/11/2022 Status : Completed								
2422	22110341	New OT	IN PATIENT WAITING ROOM-1 TUBELIGHT NOT WORKING	Vijayaraghavan.B.	36W TUBE LIGHT 3NO'S CHANG & 40W STARTER 1NO CHANGED		Devika.R - Nursing Office	10/11/2022
2423	22110342	New OT	IN DOCTOR'S ROOM AND PATIENT BATHROOM-2 NO'S TUBELIGHT NEED TO BE CHANGE	Vijayaraghavan.B.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANG & 36W CHOKE 1NO CHANGED		Devika.R - Nursing Office	10/11/2022
Comp. Dt. : 16/11/2022 Status : Completed								
2424	22110644	Male Surgery - Ward 204	REQUESTTO CHECK WHETHER ALL LIGHTS AND FAN'S ARE IN WORKING CONDITION FOR UNIVERSITY EXAM PURPOSE(MS)	Dhakshinamoorthy. J	36W TUBE LIGHT 2NO'S CHANGED		Padma. A. - Nursing Office	19/11/2022
2425	22110645	Male Medical - Ward 303	REQUESTTO CHECK WHETHER ALL LIGHTS AND FAN'S ARE IN WORKING CONDITION FOR UNIVERSITY EXAM PURPOSE(MM)	Dhakshinamoorthy. J	36W TUBE LIGHT 3NO'S CHANG & 40W STARTER 1NO CHANGED		Padma. A. - Nursing Office	18/11/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2426	22110646	Obstetrics - Ward 207	REQUEST TO CHECK WHETHER ALL LIGHTS AND FAN'S ARE IN WORKING CONDITION FOR UNIVERSITY EXAM PURPOSE(OB	Dhakshinamoorthy. J	CEILING FAN 1NO BEARING CHANG & FAN REFIXING WORK PROBLEM SOLVED		Padma. A. - Nursing Office	19/11/2022
Comp. Dt. : 18/11/2022 Status : Completed								
2427	22110746	SPECIAL WARD - A1	NEED TO CHANGE ALL LIGHTS FOR CARITOR - DIM - CHANGE BRIGHT LIGHTS	Rajan. R.	22W LED LIGHT 6NO'S CHANG & LINE CONNECTION WORK PROBLEM SOLVED		Tamilarasi.C. - Nursing Office	19/11/2022
2428	22110783	Female Surgery - Ward 205	NEED TO CHANGE TUBELIGHT FOR REST ROOM	Suresh. V.	TUBE LIGHT 40W STARTER 2NO'S CHANGED		Padma. A. - Nursing Office	21/11/2022
Comp. Dt. : 25/11/2022 Status : Completed								
2429	22111089	Male Surgery - Ward 201	WATER HEATER NOT WORKING IN PATIENT REST ROOM	Muthu. B.	15LTR WATER HEATER 1NO SERVICE WORK & HEATER REFIXING WORK PROBLEM SOLVED		Padma. A. - Nursing Office	29/11/2022
Comp. Dt. : 01/12/2022 Status : Completed								
2430	22120017	Special Ward - A	NEED TO CHANGE LED LIGHT FOR TREATMENT ROOM	Muthu. B.	9W LED LIGHT 1NO CHANGED		Tamilarasi.C. - Nursing Office	02/12/2022
Comp. Dt. : 10/12/2022 Status : Completed								
2431	22120451	Male Medical - Ward 303	NEED TO CHECK POWER - LEFT SIDE ALL ELECTRICAL ITEMS NOT WORKING	Rajan. R.	MCB TRIP ON TO WORK PROBLEM SOLVED		Leena Grace. B. - Nursing Office	10/12/2022
Comp. Dt. : 24/12/2022 Status : Completed								
2432	22121130	Male Surgery - Ward 201	WATER HEATER RNV MATERIAL NEED TO FIX	Dhakshinamoorthy. J	NEW WATER HEATER 15LTR FIXING & LINE CONNECTION WORK PROBLEM SOLVED		Padma. A. - Nursing Office	26/12/2022
Comp. Dt. : 07/01/2023 Status : Completed								
2433	23010300	ICU	WARD FUMICATION WORK-FAN DUST NEED TO BE CLEAN	Muthu. B.	WALLMOUNTING FAN CLEANING WORK PROBLEM SOLVED		Powlin.P. - Nursing Office	07/01/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 20/01/2023 Status : Completed								
2434	23010745	Paediatrics Ward	NEED ALL FAN CLEANING WORK FOR WARD NO 309 & 310	Vijayaraghavan.B.	ALL CEILING FAN CLEANING WORK PROBLEM SOLVED		Rajalakshmi. N. - Nursing Office	23/01/2023
Comp. Dt. : 23/01/2023 Status : Completed								
2435	23010794	Male Surgery	NEED FAN CLEANING WORK [ALL FANS] AT MALE SURGERY WARD 201 TO 204	Srinivasan. R.,Lakshmanan.V.,Manikandan. M.	201 TO 204 ALL CEILING FAN CLEANING WORK PROBLEM SOLVED		Velangannie.N. - Nursing Office	24/01/2023
Comp. Dt. : 04/02/2023 Status : Completed								
2436	23020131	PICU	NEED TO REFIX EXHAUSTER FOR DOCTOR'S RESTROOM	Lakshmanan.V.	DOCTOR RESET ROOM NO COMPLAINT PROBLEM SOLVED		Powlin.P. - Nursing Office	06/02/2023
Comp. Dt. : 04/03/2023 Status : Completed								
2437	23030173	SPECIAL WARD---B	HEATER NOT WORKING - ROOM NO 1	Muthu. B.	WATER HEATER 1NO RESET WORK PROBLEM SOLVED		Tamilarasi.C. - Nursing Office	07/03/2023
Comp. Dt. : 10/03/2023 Status : Completed								
2438	23030433	Special Ward - A	NEED TO CHANGE ALL LIGHTS [LED & CEILING] FOR ROOM NO 2 [VIP ROOM] DIM	Muthu. B.	36W 4PIN CFL LIGH FITTING 1NO CHANG & LINE CONNECTION WORK PROBLEM SOLVED		Tamilarasi.C. - Nursing Office	11/03/2023
Comp. Dt. : 14/03/2023 Status : Completed								
2439	23030548	Main OT	FAN NOT WORKING	Lakshmanan.V.	ALL CEILING FAN CHEKING WORK NO COMPLAINT PROBLEM SOLVED		Devika.R - Nursing Office	20/03/2023
Comp. Dt. : 15/03/2023 Status : Completed								
2440	23030601	New OT	NEED FAN CLEANING WORK	Muthu. B.	All fans - cleaned.		Devika.R - Nursing Office	18/03/2023
Comp. Dt. : 17/03/2023 Status : Completed								
2441	23030678	ORTHO OT	NEED FAN CLEANING WORK AT DOCTOR'S ROOM [ALL FANS]	Lakshmanan.V.	ALL FAN CLEANING WORK PROBLEM SOLVED		Devika.R - Nursing Office	21/03/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 28/03/2023 Status : Completed								
2442	23031154	Main OT	NEED FAN CLEANING WORK	Vijayaraghavan.B.	Fan cleaned.		Devika.R - Nursing Office	29/03/2023
Comp. Dt. : 16/04/2023 Status : Completed								
2443	23040474	Nursing Office	NEED TO CHANGE TUBELIGHT	Vijayaraghavan.B.	36W TUBE LIGHT 1NO CHANGED		Muthazhagi. A. - Nursing Office	17/04/2023
Comp. Dt. : 25/04/2023 Status : Completed								
2444	23040788	Paediatrics - Ward 308	STERILIZER NOT WORKING	Rajan. R.	6A 3PIN TOP 1NO CHANGED		Powlin.P. - Nursing Office	28/04/2023
Comp. Dt. : 27/04/2023 Status : Completed								
2445	23040907	Male Surgery - Ward 201	NEED TO CHANGE TUBELIGHT 2 NOS	Vijayaraghavan.B.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Kowsalya. G. - Male Surgery	28/04/2023
Comp. Dt. : 28/04/2023 Status : Completed								
2446	23040948	NICU	NEED SWITCH BOARD CLEANING WORK	Rajan. R.	ALL SWITCH BOARD CLEANING WORK PROBLEM SOLVED		Powlin.P. - Nursing Office	29/04/2023
Comp. Dt. : 06/05/2023 Status : Completed								
2447	23050224	SPECIALITY OT	EXHAUST FAN NOT WORKING	Babu. D.	EXHAUST FAN CHEKING WORK NO COMPLAINT		Devika.R - Nursing Office	11/05/2023
Comp. Dt. : 08/05/2023 Status : Completed								
2448	23050300	Male Medical - Ward 301	HEATER SWITCH NOT WORKING	Lakshmanan.V.	HEATER SWITCH WIRE LOOSE RECONNECTION WORK PROBLEM SOLVED		Sudha.L. - Nursing Office	09/05/2023
2449	23050301	Male Medical - Ward 302	NEED TO CHANGE TUBELIGHT	Lakshmanan.V.	TUBE LIGHT 40W STARTER 1NO CHANGED		Sudha.L. - Nursing Office	09/05/2023
2450	23050304	Male Psychiatry - Ward 405	FAN NOT WORKING	Lakshmanan.V.	CEILING FAN CAPACITOR 2.5MFT 1NO CHANGED		Rajalakshmi. N. - Nursing Office	09/05/2023
Comp. Dt. : 12/05/2023 Status : Completed								
2451	23050493	Female Medical - Ward 306	X RAY LOBBY NOT WORKING	Manimaran. M.	Wire problem - solved.		Sudha.L. - Nursing Office	15/05/2023
Comp. Dt. : 16/05/2023								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
2452	23050626	ANS DRESS CHANGING ROOM	NEED TO CHANGE TUBELIGHT 2 NOS FOR ANS ROOM AT III FLOOR	Muthu. B.	TUBE LIGHT 40W STARTER 3NO'S CHANGED		Padma. A. - Nursing Office	17/05/2023
Comp. Dt. : 25/05/2023								
Status : Completed								
2453	23051004	DNS DRESS CHANGING ROOM	NEED TO FIX NEW TUBELIGHT SET INADDITION FOR DNS DRESS CHANGING ROOM	Vijayaraghavan.B.	20W LED fitting 1no fixed.		Rajalakshmi. N. - Nursing Office	26/05/2023
Comp. Dt. : 31/05/2023								
Status : Completed								
2454	23051213	Nursing Office	NEED TO CHANGE TUBELIGHT [2NOS] FOR DNS ROOM	Suresh. V.	36W tube light 1no changed.		Rajalakshmi. N. - Nursing Office	31/05/2023
2455	23051244	Male Surgery - Ward 202	FAN NOT WORKING	Thillaikumar. R.	fan mcb triped . on work		Naveen Raj. P. - POW & SICU	01/06/2023
Comp. Dt. : 03/06/2023								
Status : Completed								
2456	23060099	SEPTIC ROOM(NEW) -IN 3RD FLOOR	HEATER NOT WORKING [INTERCOM NO 1322]	Sathishkumar. R.	WATER HEATER LINE CHEKING WORK		Mythili. B. - POW & SICU	05/06/2023
Comp. Dt. : 06/06/2023								
Status : Completed								
2457	23060210	Male Surgery - Ward 201	NEED TO CHECK PLUG POINT NOT WORKING	Vijayaraghavan.B.	6A SOCKET 1NO CHANGED		Kowsalya. G. - Male Surgery	07/06/2023
Comp. Dt. : 13/06/2023								
Status : Completed								
2458	23060439	Special Ward - C	NEED FAN CLEANING WORK	Lakshmanan.V.	ALL CEILING FAN CLEANING WORK PROBLEM SOLVED		Tamilarasi.C. - Nursing Office	14/06/2023
Comp. Dt. : 21/06/2023								
Status : Completed								
2459	23060775	Male Surgery - Ward 201	FAN NOT WORKING	Vengadessaperumal. K.	CEILING FAN BEARING 2NO'S CHANG & FAN REFIXING WORK PROBLEM SOLVED		Kowsalya. G. - Male Surgery	07/07/2023
Comp. Dt. : 22/06/2023								
Status : Completed								
2460	23060797	Nursing Office	NEED TO CHANGE TUBELIGHT FOR N.S ROOM	Vengadessaperumal. K.	TUBE LIGHT 40W STARETR 1NO CHANGED		luthazhagi. A. - Nursing Office	23/06/2023

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 23/06/2023 Status : Completed								
2461	23060845	Male Surgery - Ward 202	NEED TO CHECK PLUG POINT - CHARGER STUCK & NOT WORKING	Vengadessaperumal. K.	6A SOCKET 1NO CHANGED		Pavithiran. V. - TB & Chest / Psychiatry	24/06/2023
Comp. Dt. : 27/06/2023 Status : Completed								
2462	23060992	ORTHO OT	NEED TO CHANGE CEILING LIGHT FOR RECOVERY ROOM	Muthu. B.	18w round fitting 1 nos changed . drive 1 nos changed		Devika.R - Nursing Office	28/06/2023
Dept Name : Nutrition & Dietetics - Electrical Maintenance Comp. Dt. : 10/05/2022 Status : Completed								
2463	22050315	DIET DEPARMENT	NEED TO CHANGE GRINDER BELT	Dhakshinamoorthy. J	GRINDER BELT A 39 1NOCHANG & B 32 1NO CHANGED		Shanmugapriya. J. - Nutrition & Dietetics	12/05/2022
Comp. Dt. : 13/05/2022 Status : Completed								
2464	22050482	Nutrition & Dietetics(inner side of pulmonary medicine-no.99)	NEED TO CHECK GRINDER WORKING CONDITION	Vijayaraghavan.B.	3PHASE GRINDER MOTOR CHEKING WORK RUNNING CONDUCTION PROBLEM SOLVED		Shanmugapriya. J. - Nutrition & Dietetics	14/05/2022
Comp. Dt. : 04/06/2022 Status : Completed								
2465	22060171	DIET DEPARMENT	NEED TO CHECK GRINDER - NOT WORKING	Muthu. B.	GRINDER NEW OIL FULLING WORK & GRINDER CHEKING WORK PROBLEM SOLVED		Shanmugapriya. J. - Nutrition & Dietetics	07/06/2022
Comp. Dt. : 13/07/2022 Status : Completed								
2466	22070513	DIET DEPARMENT	NEED TO CHANGE TUBELIGHT FOR STOREROOM	Rajan. R.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Shanmugapriya. J. - Nutrition & Dietetics	14/07/2022
Comp. Dt. : 16/07/2022 Status : Completed								
2467	22070625	DIET DEPARMENT	NEED CLEANING WORK FOR FAN , TUBELIGHT & EXHAUST FAN	Srinivasan. R.	TUBE LIGHT COVER & CEILING FAN CLEANING WORK PROBLEM SOLVED		Shanmugapriya. J. - Nutrition & Dietetics	18/07/2022
Comp. Dt. : 06/08/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2468	22080235	DIET DEPARMENT	NEED FLOUR MACHINE INSTALLATION WORK	Muthu. B.	FOLUR MACHINE LINE CONNECTION WORK PROBLEM SOLVED		Shanmugapriya. J. - Nutrition & Dietetics	11/08/2022
Comp. Dt. : 20/08/2022 Status : Completed								
2469	22080670	DIET DEPARMENT	NEED TO CHECK STERLIZER SWITCH BOARD - BURNED	Muthu. B.	16A SINGLE POLE MCB 1NO CHANGED		Shanmugapriya. J. - Nutrition & Dietetics	22/08/2022
Comp. Dt. : 09/09/2022 Status : Completed								
2470	22090353	DIET DEPARMENT	NEED TO CHECK GRINDER [2NOS]	Lakshmanan.V.	GRINDER 2NO'S CHEKING WORK GEAR BOX & MOTOR PROBLEM		Shanmugapriya. J. - Nutrition & Dietetics	10/09/2022
Comp. Dt. : 13/09/2022 Status : Completed								
2471	22090479	DIET DEPARMENT	NEED TO REFIX BELT FOR NEW GRINDER	Rajan. R.	GRINDER BELT 2NO'S CHANG & CHEKING WORK PROBLEM SOLVED		Shanmugapriya. J. - Nutrition & Dietetics	14/09/2022
Comp. Dt. : 15/09/2022 Status : Completed								
2472	22090608	LIFT 5	LIFT NOT WORKING - NO 5	Sathishkumar. R.	MCB TRIP ON TO WORK PROBLEM SOLVED		Shanmugapriya. J. - Nutrition & Dietetics	16/09/2022
Comp. Dt. : 19/09/2022 Status : Completed								
2473	22090702	DIET DEPARMENT	NEED TO CHECK MIXIE PLUR POINT & TUBELIGHT 2 NOS - NOT WORKING	Dhakshinamoorthy. J	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANG & 36W CHOKE 3NO'S CHANG & 6A 3PIN TOP 1NO CHANGED		Shanmugapriya. J. - Nutrition & Dietetics	20/09/2022
Comp. Dt. : 26/10/2022 Status : Completed								
2474	22100815	DIET DEPARMENT	MIXER JAR TOP PROBLEM	Dhakshinamoorthy. J	PUSH & BLATE CHANG & CHEKING WORK PROBLEM SOLVED		Shanmugapriya. J. - Nutrition & Dietetics	23/11/2022
Comp. Dt. : 29/10/2022 Status : Completed								
2475	22100942	DIET DEPARMENT	NEED TO FIX ROTI MAKING MACHINE BELT	Manikandan. M.	ROTI MAKING MACHINE BELT EFIXING WORK PROBLEM SOLVED		Shanmugapriya. J. - Nutrition & Dietetics	31/10/2022
Comp. Dt. : 29/11/2022								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
2476	22111204	DIET DEPARMENT	NEED TO CHECK GRINDER - NOT WORKING - NEED URGENT SERVICE	Lakshmanan.V.	GRINDER GREE BOX PROBLEM		Gunapriya. M. - Nutrition & Dietetics	01/12/2022
Comp. Dt. : 08/12/2022								
Status : Completed								
2477	22120394	DIET DEPARMENT	IN KITCHEN-GRINDER INDUCE ELECTRIC SHOCK	Thillaikumar. R.	GRINDER EARTH WIRE CONNECTION WORK PROBLEM SOLVED		Shanmugapriya. J. - Nutrition & Dietetics	09/12/2022
Comp. Dt. : 13/12/2022								
Status : Completed								
2478	22120611	DIET DEPARMENT	NEED TO FIX CABLE FOR GRINDER	Vijayaraghavan.B.	GRINDER MOTOR LINE CONNECTION WORK PROBLEM SOLVED		Shanmugapriya. J. - Nutrition & Dietetics	14/12/2022
Comp. Dt. : 31/12/2022								
Status : Completed								
2479	22121388	DIET DEPARMENT	GRINDER FIXING PLUG POINT NEED TO BE CHANGE	Rajan. R.	Top 3pin 16A 1no changed.		Shanmugapriya. J. - Nutrition & Dietetics	31/12/2022
Comp. Dt. : 04/01/2023								
Status : Completed								
2480	23010122	DIET DEPARMENT	TUBELIGHT NOT WORKING	Thillaikumar. R.	36W TUBE LGIHT 1NO CHANG & 36W CHOKE 1NO CHANGED		Krishna Priya. E. - Nutrition & Dietetics	05/01/2023
Comp. Dt. : 11/02/2023								
Status : Completed								
2481	23020419	DIET DEPARMENT	NEED TO CHECK KITCHEN EXHAUST FAN [FAN NO 2] - NOT WORKING	Muthu. B.	EXHAUST FAN 4MFT 1NO CHANGED		Shanmugapriya. J. - Nutrition & Dietetics	15/02/2023
2482	23020420	GAS GODOWN	NEED TO CHANGE TUBELIGHT 2 NOS BACK SIDE OF GAS GODOWN	Manimaran. P.	36W TUBE LIGHT 1NO CHANG & 36W CHOKE 1NO CHANGED		Shanmugapriya. J. - Nutrition & Dietetics	15/02/2023
2483	23020421	DIET DEPARMENT	NEED CLEANING WORK FOR KITCHEN TUBELIGHT SET, COVER & EXHAUST FAN - TODAY [11.02.2023] ATERNOO	Muthu. B.	CEILING FAN CLEANING WORK & TUBE LIGHT COVER CLEANING WORK PROBLEM SOLVED		Shanmugapriya. J. - Nutrition & Dietetics	15/02/2023
Comp. Dt. : 16/02/2023								
Status : Completed								
2484	23020617	DIET DEPARMENT	(1441) FIRE EXTINGUISHER--SHIFT TO ANOTHER PLACE	Lakshmanan.V.	FIRE EXTINGUISHER SHIFTING TO REFIXNG WORK PROBLEM SOLVED		Shanmugapriya. J. - Nutrition & Dietetics	20/02/2023
Comp. Dt. : 21/02/2023								

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
2485	23020781	DIET DEPARMENT	MIXIE & STERLIZER NOT WORKING	Vengadessaperumal. K.	MCB TRIP ON TO WORK & MIXIE BEARING 2NO'S CHANG & CHEKING WORK PROBLEM SOLVED		Shanmugapriya. J. - Nutrition & Dietetics	22/02/2023
Comp. Dt. : 16/03/2023								
Status : Completed								
2486	23030672	DIET DEPARMENT	TRIP PROBLEM IN V FLOOR	Manikandan. M.	MCB TRIP ON TO WORK PROBLEM SOLVED		Shanmugapriya. J. - Nutrition & Dietetics	16/03/2023
Comp. Dt. : 04/04/2023								
Status : Completed								
2487	23040085	DIET DEPARMENT	NEED TO CHECK GRINDER - SHOCK PROBLEM - NEED URGENT SERVICE	Dhakshinamoorthy. J	Wire problem. 3core wire 2.5sqmm - 3mtr changed.		Vidhyashree. S. - Nutrition & Dietetics	04/04/2023
Comp. Dt. : 13/04/2023								
Status : Completed								
2488	23040421	DIET DEPARMENT	NEED TO CHECK GRINDER BELT - CUT - NEED TO REFIX	Srinivasan. R.	New belt changed.		Shanmugapriya. J. - Nutrition & Dietetics	13/04/2023
Comp. Dt. : 27/04/2023								
Status : Completed								
2489	23040884	DIET DEPARMENT	NEED SERVICE FOR CHAPATI FLOUR MIXER MACHINE - GREASE LEAKAGE AT V FLOOR KITCHEN	Rajan. R.	MIXER MACHINE CHEKING WORK COMPANY SERVICE		Shanmugapriya. J. - Nutrition & Dietetics	28/04/2023
Comp. Dt. : 08/05/2023								
Status : Completed								
2490	23050315	DIET DEPARMENT	"2 L" GRINDER SLOW PROBLEM	Muthu. B.	NEW A 39 A BELT 1NO CHANG & GRINDER CHEKING WORK PROBLEM SOLVED		Shanmugapriya. J. - Nutrition & Dietetics	13/05/2023
Comp. Dt. : 18/05/2023								
Status : Completed								
2491	23050772	DIET DEPARMENT	NEED TO CHANGE TUBELIGHT [2 NOS] FOR KITCHEN	Muthu. B.	36W TUBE LIGHT 1NO CHANG & SIDE HOLDER 1NO CHANGED		Shanmugapriya. J. - Nutrition & Dietetics	19/05/2023
2492	23050773	LIFT 5	NEED REPAIRING WORK FOR LIFT NO 5 NOT WORKING	Vaithianathan.M	LIFT NO:5 BOARD SERVICE WORK LIFT CHEKING WORK PROBLEM SOLVED		Shanmugapriya. J. - Nutrition & Dietetics	20/05/2023
Comp. Dt. : 22/05/2023								
Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2493	23050885	DIET DEPARMENT	PROBLEM IN MIXIE JAR	Manimaran. M.	Bush, coupler and shaft changed. Service done.		Shanmugapriya. J. - Nutrition & Dietetics	26/05/2023
Comp. Dt. : 26/05/2023 Status : Completed								
2494	23051066	DIET DEPARMENT	NEED SERVICE FOR FLOUR MIXTURE MACHINE	Muthu. B.	Bearing problem		Shanmugapriya. J. - Nutrition & Dietetics	07/06/2023
Comp. Dt. : 31/05/2023 Status : Completed								
2495	23051251	MEDICINE	NEED TO CHANGE TUBELIGHT FOR ROOM NO 26 A - MEDICINE WING	Manimaran. M.	LED 22W TUBE LIGHT 1NO CHANGED		Shanmugapriya. J. - Nutrition & Dietetics	02/06/2023
Comp. Dt. : 13/06/2023 Status : Completed								
2496	23060434	DIET DEPARMENT	NEED TO CHECK FIRE EXTINGUISHER - DISPLAYED EXPIRY DATE	Duraikannu. D.	FIRE EXTINGUISHER CHANGED		Shanmugapriya. J. - Nutrition & Dietetics	14/06/2023
Comp. Dt. : 20/06/2023 Status : Completed								
2497	23060696	DIET DEPARMENT	NEED TO CHANGE BEARING FOR FLOUR MACHINE	Ilavarasan. T.	Machine problem solved.		Shanmugapriya. J. - Nutrition & Dietetics	10/07/2023
Comp. Dt. : 22/06/2023 Status : Completed								
2498	23060811	DIET DEPARMENT	NEED TO CHECK PEST KILLER MACHINE - NOT WORKING	Manimaran. P.	20W TUBE LIGHT 1NO CHANGED		Krishna Priya. E. - Nutrition & Dietetics	26/06/2023
Dept Name : Obstetrics & Gynaecology - Electrical Maintenance Comp. Dt. : 22/08/2022 Status : Completed								
2499	22080703	A.P Quateres	NEED TO CHECK POWER - WASHING MACHINE SWITCH & TUBELIGHT NOT WORKING IN QUARTERS NO 15	Dhakshinamoorthy. J	WASHING MACHINE PROBLEM & TUBE LIGHT CHEKING WORK PROBLEM SOLVED		Priyadharshini. D. - Obstetrics & Gynaecology	23/08/2022
Dept Name : OPD - Electrical Maintenance Comp. Dt. : 02/05/2022 Status : Completed								
2500	22050002	Injection Room - OPD	NEED TO CHANGE TUBELIGHT	Lakshmanan.V.	36W TUBE LIGHT 1NO CHANGED		Jaculine Mary. A. - ENT & Ophthal Ward	05/05/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2501	22050039	Dental Special Clinic	NEED TO REPALCE FAN FROM ENTRANCE TO INSIDE ROOM	Muthu. B.	3M SURFACE BOX 1NO, 3M PLATE 1NO, 6A SWITCH 1NO, FIXING WOR & LINE CONNECTION WORK PROBLEM SOLVED		Vanitha. P. - Male Ortho Ward	13/05/2022
Comp. Dt. : 06/05/2022 Status : Completed								
2502	22050193	ENT OPD	NEED TO CHANGE TUBELIGHT - ROOM NO 30	Manikandan. M.	NO COMPLEINT ALL LIGHT CHEKING WORK PROBLEM SOLVED		Ezhilarasi. M. - OPD	09/05/2022
2503	22050210	Ophthalmology - OPD	NEED TO CHANGE TUBELIGHT - OPD NO 81	Manikandan. M.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Seetha. R. - OPD	09/05/2022
Comp. Dt. : 07/05/2022 Status : Completed								
2504	22050222	General Medicine - OPD	NEED TO CHANGE TUBELIGHT ROOM NO 19	Manikandan. M.	36W TUBE LIGHT 1NO CHANGED		Sivaranjani. P. - OPD	09/05/2022
Comp. Dt. : 21/05/2022 Status : Completed								
2505	22050802	General Medicine - OPD	X RAY LOBBY NOT WORKING - ROOM NO 19	Manimaran. P.	WIRE CUT RECONNECTION WORK PROBLEM SOLVED		Sivaranjani. P. - OPD	25/05/2022
Comp. Dt. : 24/05/2022 Status : Completed								
2506	22050855	Surgery OPD	FAN SLOW PROBLEM - ROOM NO 57	Vijayaraghavan.B.	CEILING FAN CAPACITOR 2.5MFT 1NO CHANGED		Indhira. M. - OPD	25/05/2022
Comp. Dt. : 25/05/2022 Status : Completed								
2507	22050923	Injection Room - OPD	NEED TO CHANGE TUBELIGHT FOR ROOM NO 51	Lakshmanan.V.	Tube light starter 1no changed.		Jaculine Mary. A. - ENT & Ophthal Ward	26/05/2022
Comp. Dt. : 27/05/2022 Status : Completed								
2508	22051031	ENT OPD	NEED TO CHECK POWER -	Manimaran. P.	MCB TRIP ON TO WORK PROBLEM SOLVED		Ezhilarasi. M. - OPD	28/05/2022
Comp. Dt. : 30/05/2022 Status : Completed								
2509	22051091	ENT OPD	NEED TO CHANGE TUBELIGHT FOR ROOM NO 24	Srinivasan. R.	22W LED LIGHT 2NO'S CHANGED		Ezhilarasi. M. - OPD	31/05/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 01/06/2022								
Status : Completed								
2510	22060003	CARDIOLOGY OPD	NEED TO CHANGE TUBELIGHT [SMALL SIZE]	Srinivasan. R.	36W TUBE LIGHT CHOKE 1NO CHANGED		Radhika. R. - OPD	02/06/2022
2511	22060018	Surgery OPD	NEED TO CHANGE TUBELIGHT & LED LIGHT FOR RESTROOM	Srinivasan. R.	9W LED LIGHT 1NO CHANG & 40W STARTER 1NO CHANG & 36W TUBE LIGHT 1NO CHANGED		Indhira. M. - OPD	02/06/2022
Comp. Dt. : 02/06/2022								
Status : Completed								
2512	22060081	IVF ART CLINIC-INSIDE OF OG OPD(NO.68)	NEED TO CHECK PLUG POINT - X LOBBY PLUG POINT NOT WORKING & BROKENED	Sathishkumar. R.	6A 3PIN TOP 1NO CHANGED		Rajasekari. R. - OPD	02/06/2022
Comp. Dt. : 06/06/2022								
Status : Completed								
2513	22060208	Paediatrics - OPD	NEED TO CHANGE TUBELIGHT	Vijayaraghavan.B.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Subashree. R. - OPD	07/06/2022
Comp. Dt. : 07/06/2022								
Status : Completed								
2514	22060244	Surgery OPD	NEED TO CHANGE TUBELIGHT FOR ROOM NO 56	Rajan. R.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Indhira. M. - OPD	07/06/2022
2515	22060279	IVF ART CLINIC-INSIDE OF OG OPD(NO.68)	NEED TO CLEAN BATTERY NEAR LAPCARE ROOM	Vijayaraghavan.B.	ALL UPS BATTERY CLEANING WORK PROBLEM SOLVED		Rajasekari. R. - OPD	09/06/2022
Comp. Dt. : 11/06/2022								
Status : Completed								
2516	22060412	PSYCHIATRY OPD	NEED TO CHANGE TUBELIGHT FOR NURSE'S CABIN	Vijayaraghavan.B.	Tube light starter 1no changed.		Bhuvaneswari. G. - P.H.C. - Tiruvonnainallur	11/06/2022
2517	22060431	Surgery OPD	DIGITAL CLOCK NOT WORKING	Vijayaraghavan.B.	MCB trip - Trip On.		Indhira. M. - OPD	11/06/2022
Comp. Dt. : 13/06/2022								
Status : Completed								
2518	22060443	DERMATOLOGY OPD	NEED TO CHANGE TUBELIGHT FOR ROOM NO 72	Dhakshinamoorthy. J	Switch problem - solved.		Jothiammal. S. - OPD	14/06/2022
2519	22060467	Orthopaedics - OPD	NEED TO CHECK POWER - AC STABILIZER , AC NOT WORKING AT DEMO ROOM	Dhakshinamoorthy. J	Power checked - Ok		Durgadevi. J - OPD	14/06/2022
Comp. Dt. : 23/06/2022								
Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2520	22060832	Orthopaedics - OPD	NEED TO CHECK X RAY LOBBY - NOT WORKING	Srinivasan. R.	6A 3PIN TOP 1NO CHANGED		Durgadevi. J - OPD	24/06/2022
	Comp. Dt. : 28/06/2022							
	Status : Completed							
2521	22061020	Ophthalmology - OPD	NEED TO CHANGE TUBELIGHT FOR ROOM NO 81	Manikandan. M.	36w tube light 1no changed		Seetha. R. - OPD	29/06/2022
	Comp. Dt. : 02/07/2022							
	Status : Completed							
2522	22070049	PSYCHIATRY OPD	NEED TO CHANGE TUBELIGHT FOR CABIN	Suresh. V.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Bhuvaneswari. G. - P.H.C. - Tiruvonnainallur	02/07/2022
2523	22070068	Nephrology OPD	NEED TO CHECK FAN - NOT WORKING - NEED URGENT SERVICE	Vijayaraghavan.B.	T5 14W LIGHT 1NO CHANGED		Suvitha. R. - OPD	04/07/2022
	Comp. Dt. : 04/07/2022							
	Status : Completed							
2524	22070071	PLASTIC SURGERY OPD-223	NEED TO CHANGE TUBELIGHT 2 NOS NOT WORKING	Vijayaraghavan.B.	36W 4PIN CFL LIGHT 2NO'S CHANGED		Lakshmidevi. A - OPD	04/07/2022
	Comp. Dt. : 07/07/2022							
	Status : Completed							
2525	22070239	PSYCHIATRY OPD	NEED TO CHANGE TUBELIGHT - ROOM NO 77	Vijayaraghavan.B.	Tube light starter 1no changed.		Bhuvaneswari. G. - P.H.C. - Tiruvonnainallur	08/07/2022
	Comp. Dt. : 08/07/2022							
	Status : Completed							
2526	22070332	IVF ART CLINIC-INSIDE OF OG OPD(NO.68)	NEED POWER CONNECTION WORK FOR FAN & LIGHT FOR SEMON COLLECTION ROOM	Rajan. R.	CEILING FAN 1NO REFIXING WORK & 18W LED LIGHT 4NO'S REFIXING WORK & LINE CONNECTION WORK PROBLEM SOL		Rajasekari. R. - OPD	11/07/2022
	Comp. Dt. : 09/07/2022							
	Status : Completed							
2527	22070354	Paediatrics - OPD	NEED TO CHANGE TUBELIGHT	Vijayaraghavan.B.	Tube light starter 1no changed.		Subashree. R. - OPD	09/07/2022
2528	22070361	ENT OPD	NEED TO FIX NEW EXTN BOX	Rajan. R.	SWITCH BOARD CHEKING WORK NO COMPLENT		Ezhilarasi. M. - OPD	19/07/2022
	Comp. Dt. : 11/07/2022							
	Status : Completed							


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2529	22070413	General Medicine - OPD	FAN SOUND PROBLEM - ROOM NO 17	Suresh. V.	CEILING FAN CUP LOOSE REFIXING WORK PROBLEM SOLVED		Bharathi.D. - OPD	11/07/2022
Comp. Dt. : 14/07/2022 Status : Completed								
2530	22070542	DENTAL OPD -2ND FLOOR	NEED TO CHANGE TUBELIGHT FOR X RAY LOBBY	Vengadessaperumal. K.	20W TUBE LIGHT 1NO CHANGED		Lakshmi Devi. R. - OPD	14/07/2022
2531	22070564	COMMON MALE TOILET NEAR ORTHO OPD	NEED TO CHANGE TUBELIGHT	Lakshmanan.V.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Durgadevi. J - OPD	16/07/2022
Comp. Dt. : 15/07/2022 Status : Completed								
2532	22070579	PLASTIC SURGERY OPD-223	NEED TO CHANGE TUBELIGHT 2 NOS	Muthu. B.	36W 4PIN CFL LIGHT 2NO'S CHANGED		Lakshmidevi. A - OPD	18/07/2022
Comp. Dt. : 19/07/2022 Status : Completed								
2533	22070691	Ophthalmology - OPD	NEED TO CHANGE TUBELIGHT - ROOM NO 83	Rajan. R.	TUBE LIGHT 40W STARTER 1NO CHANGED		Kamala.D. - OPD	19/07/2022
Comp. Dt. : 25/07/2022 Status : Completed								
2534	22070929	DENTAL OPD -2ND FLOOR	NEED TO CHECK X RAY LOBBY LIGHT - NOT WORKING	Rajan. R.	9W LED LIGHT 1NO CHANG & BABY HOLDER 1NO CHANGED		Kanakarani. R. - OPD	27/07/2022
Comp. Dt. : 26/07/2022 Status : Completed								
2535	22070934	Ophthalmology - OPD	NEED TO CHANGE TUBELIGHT - ROOM NO 81	Manimaran. P.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Seetha. R. - OPD	26/07/2022
Comp. Dt. : 30/07/2022 Status : Completed								
2536	22071089	TB & Chest OPD	NEED TO CHANGE TUBELIGHT	Vijayaraghavan.B.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Jothi.R. - OPD	30/07/2022
Comp. Dt. : 04/08/2022 Status : Completed								
2537	22080147	Orthopaedics - OPD	NEED TO CHANGE TUBELIGHT FOR ROOM NO 66	Lakshmanan.V.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Durgadevi. J - OPD	04/08/2022
Comp. Dt. : 06/08/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2538	22080243	TB & Chest OPD	NEED TO CHANGE SWITCH BOX - PLUG POINTS NOT WORKING AT HOD ROOM	Muthu. B.	6A SOCKET 1NO CHANGED		Jothi.R. - OPD	08/08/2022
Comp. Dt. : 10/08/2022 Status : Completed								
2539	22080348	Ophthalmology - OPD	NEED TO CHANGE TUBELIGHT FOR ROOM NO 81	Rajan. R.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Seetha. R. - OPD	10/08/2022
Comp. Dt. : 13/08/2022 Status : Completed								
2540	22080470	Ophthalmology - OPD	NEED TO CHANGE TUBELIGHT FOR ROOM NO 80	Vijayaraghavan.B.	36W Tube light 1no & starter 1no changed.		Seetha. R. - OPD	17/08/2022
Comp. Dt. : 18/08/2022 Status : Completed								
2541	22080594	UROLOGY--OPD	FALSE CEILING LIGHT NOT WORKING	Dhakshinamoorthy. J	9W LED LIGHT 2NO'S CHANG & BABY HOLDER 2NO'S CHANGED		Lavanya. M. - OPD	23/08/2022
Comp. Dt. : 23/08/2022 Status : Completed								
2542	22080738	DENTAL OPD -2ND FLOOR	NEED TO CHANGE TUBELIGHT	Dhakshinamoorthy. J	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Kanakarani. R. - OPD	23/08/2022
2543	22080743	Paediatrics - OPD	NEED TO CHANGE TUBELIGHT	Vengadessaperumal. K.	TUBE LIGHT 40W STARTER 1NO CHANGED		Subashree. R. - OPD	23/08/2022
2544	22080749	General Medicine - OPD	NEED REPAIRING WORK FOR CALLING BELL	Sathishkumar. R.	CALLING BELL CHEKING NO COMPLAINT PROBLEM SOLVED		Bharathi.D. - OPD	23/08/2022
Comp. Dt. : 26/08/2022 Status : Completed								
2545	22080861	Orthopaedics - OPD	NEED TO CHANGE TUBELIGHT FOR OPD ENTRANCE	Lakshmanan.V.	36W TUBE LIGHT 1NO CHANGED		Durgadevi. J - OPD	27/08/2022
2546	22080923	Paediatrics - OPD	NEED TO CHANGE TUBELIGHT FOR REST ROOM	Dhakshinamoorthy. J	20W TUBE LIGHT 1NO CHANGED		Subashree. R. - OPD	27/08/2022
Comp. Dt. : 02/09/2022 Status : Completed								
2547	22090075	General Medicine - OPD	TORCH LIGHT NOT WORKING	Sridharan. R	TORCH LIGHT 1NO BOARD PROBLEM		Bharathi.D. - OPD	10/09/2022
Comp. Dt. : 03/09/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2548	22090142	OG-OPD	NEED TO CHANGE TUBELIGHT FOR HOD ROOM	Manikandan. M.	36W 4PIN CFL LIGHT 1NO CHANGED		Velangkanni. K. - OPD	05/09/2022
		Comp. Dt. : 05/09/2022 Status : Completed						
2549	22090155	Orthopaedics - OPD	NEED TO CHANGE TUBELIGHT FOR ROOM NO 62	Vijayaraghavan.B.	TUBE LIGHT 36W CHOKE 1NO CHANGED		Durgadevi. J - OPD	06/09/2022
		Comp. Dt. : 09/09/2022 Status : Completed						
2550	22090351	PLASTIC SURGERY OPD-223	NEED TO CHANGE TUBELIGHT	Vengadessaperumal. K.	22W LED LIGHT 1NO REFIXING WORK PROBLEM SOLVED		Lakshmid devi. A - OPD	10/09/2022
2551	22090352	TB & Chest OPD	NEED TO CHANGE TUBELIGHT FOR DEMO ROOM	Vijayaraghavan.B.	36W TUBE LIGHT 1NO CHANG & 36W CHOKE 1NO CHANGED		Jothi.R. - OPD	10/09/2022
		Comp. Dt. : 10/09/2022 Status : Completed						
2552	22090388	DENTAL OPD -2ND FLOOR	NEED TO CHANGE TUBELIGHT	Vijayaraghavan.B.	36W TUBE LIGHT 1NO CHANGED		Kanakarani. R. - OPD	10/09/2022
		Comp. Dt. : 13/09/2022 Status : Completed						
2553	22090480	DEMO ROOM IN MEDICINE OPD	NEED TO CHANGE TUBE LIGHT NOT WORKING	Rajan. R.	36W TUBE LIGHT 1NO CHANGED		Indhira. M. - OPD	14/09/2022
		Comp. Dt. : 16/09/2022 Status : Completed						
2554	22090626	ENT	ENT DEMO ROOM TUBELIGHT NOT WORKING	Muthu. B.	22W LED TUBE LIGHT 1NO REFIXING WORK PROBLEM SOLVED		Ezhilarasi. M. - OPD	16/09/2022
		Comp. Dt. : 20/09/2022 Status : Completed						
2555	22090768	Ophthalmology - OPD	DUE TO POWER PROBLEM NEED TO FIX ADDITIONAL PLUG POINT	Muthu. B.	20W TUBE LIGHT NEW FITTING 1NO FIXING WORK PROBLEM SOLVED		Seetha. R. - OPD	22/09/2022
		Comp. Dt. : 21/09/2022 Status : Completed						
2556	22090851	IVF ART CLINIC-INSIDE OF OG OPD(NO.68)	NEED TO CHANGE TUBELIGHT FOR LAB CART ROOM & ALSO NEED FAN & BATTERY ROOM CLEANING WORK	Muthu. B.	ALL CEILING FAN CLEANING WORK & UPS AND BATTERY CLEANING WORK PROBLEM SOLVED		Rajasekari. R. - OPD	23/09/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 22/09/2022								
Status : Completed								
2557	22090858	General Medicine - OPD	CALLING BELL NOT WORKING	Rajan. R.	CALLING BEL CHEKING WORK NO COMPLAINT		Bharathi.D. - OPD	22/09/2022
Comp. Dt. : 24/09/2022								
Status : Completed								
2558	22090962	TB & Chest OPD	NEED TO CHANGE TUBELIGHT 3 NOS	Manikandan. M.	MCB Trip - trip ON.		Jothi.R. - OPD	26/09/2022
2559	22090963	DERMATOLOGY OPD	NEED TO CHANGE TUBELIGHT - OPP TO CABIN	Manikandan. M.	Tube light starter 1no changed.		Indumathi. T. - OPD	26/09/2022
Comp. Dt. : 26/09/2022								
Status : Completed								
2560	22091000	Orthopaedics - OPD	NEED TO CHANGE TUBELIGHT FOR ROOM NO 65	Vijayaraghavan.B.	36W TUBE LIGHT 1NO CHANG & 36W CHOKE 1NO CHANGED		Durgadevi. J - OPD	28/09/2022
Comp. Dt. : 27/09/2022								
Status : Completed								
2561	22091048	Ophthalmology - OPD	ELECTRICAL PROBLEM IN X RAY LOBBY	Rajan. R.	6A SWITCH 1NO CHANGED		Seetha. R. - OPD	29/09/2022
Comp. Dt. : 29/09/2022								
Status : Completed								
2562	22091146	DENTAL OPD -2ND FLOOR	NEED TO CHANGE TUBELIGHT FOR PROCEDURE ROOM	Thillaikumar. R.	36W TUBE LIGHT 1NO CHANG & 36W CHOKE 1NO CHANGED		Lakshmi Devi. R. - OPD	30/09/2022
Comp. Dt. : 30/09/2022								
Status : Completed								
2563	22091197	Ophthalmology - OPD	NEED TO FIX NEW SWITCH BOX	Srinivasan. R.	SWITCH BOARD LINE CHEKING WORK PROBLEM SOLVED		Seetha. R. - OPD	08/10/2022
Comp. Dt. : 03/10/2022								
Status : Completed								
2564	22100016	ENT OPD	NEED TO CHECK POWER	Lakshmanan.V.	MCB TRIP ON TO WORK PROBLEM SOLVED		Ezhilarasi. M. - OPD	06/10/2022
Comp. Dt. : 07/10/2022								
Status : Completed								
2565	22100157	ENT OPD	NEED TO CHANGE TUBELIG FOR ROOM NO 24	Dhakshinamoorthy. J	22W LED TUBE LIGHT 1NO CHANGED		Ezhilarasi. M. - OPD	08/10/2022
Comp. Dt. : 10/10/2022								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
2566	22100248	NEUROLOGY OPD-2ND FLOOR	NEED TO CHECK AC POWER - AC NOT WORKING - OPD NO 222	Dhakshinamoorthy. J	MCB TRIP ON TO WORK PROBLEM SOLVED		Lavanya. M. - OPD	11/10/2022
2567	22100254	ENT OPD	NEED TO CHECK POWER	Muthu. B.	MCB TRIP ON TO WORK PROBLEM SOLVED		Ezhilarasi. M. - OPD	11/10/2022
Comp. Dt. : 11/10/2022								
Status : Completed								
2568	22100296	General Medicine - OPD	NEED TO CHECK POWER	Manimaran. M.	MCB TRIP ON TO WORK PROBLEM SOLVED		Kamala.D. - OPD	12/10/2022
2569	22100305	HOSPITAL II FLOOR	NEED TO CHANGE TUBELIGHT FOR WAY OF DERMATOLOGY PUVA THERAPY ROOM ENTRANCE	Dhakshinamoorthy. J	9W LED LIGHT 2NO'S CHANGED		Indumathi. T. - OPD	12/10/2022
Comp. Dt. : 12/10/2022								
Status : Completed								
2570	22100362	DENTAL OPD -2ND FLOOR	NEED TO REPALCE CEILING FAN [TO BE CHANGE AT ANOTHER PLACE]	Muthu. B.	POINT CHEKING WORK NO ANOTHER PLACE		Kanakarani. R. - OPD	14/11/2022
Comp. Dt. : 13/10/2022								
Status : Completed								
2571	22100414	ENT OPD	TORCH LIGHT NOT WORKING	Sridharan. R	TORCH LIGHT BOARD PROBLEM		Ezhilarasi. M. - OPD	14/10/2022
Comp. Dt. : 20/10/2022								
Status : Completed								
2572	22100658	Ophthalmology - OPD	X-RAY LOBBY NOT WORKING	Vijayaraghavan.B.	9W LED LIGHT 1NO CHANG & BABY HOLDER 1NO CHANGED		Seetha. R. - OPD	21/10/2022
2573	22100659	OPTICAL SHOP NEAR OPHTHAL OPD	NO ELECTRICITY POWER AT OPTICALS	Rajan. R.	MCB TRIP ON TO WORK PROBLEM SOLVED		Seetha. R. - OPD	21/10/2022
Comp. Dt. : 21/10/2022								
Status : Completed								
2574	22100708	Orthopaedics - OPD	TUBELIGHT 2NOS NOT WORKING IN DEMO ROOM	Muthu. B.	36W TUBE LIGHT 2NO'S CHANG & 40W STARTER 1NO CHANGED		Durgadevi. J - OPD	22/10/2022
Comp. Dt. : 27/10/2022								
Status : Completed								
2575	22100858	IVF ART CLINIC-INSIDE OF OG OPD(NO.68)	PATIENTS REST ROOM-2 NO'S TUBELIGHT NOT WORKING	Dhakshinamoorthy. J	36W TUBE LIGHT 1NO CHANG & 36W CHOKE 1NO CHANGED		Rajasekari. R. - OPD	29/10/2022
Comp. Dt. : 28/10/2022								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
2576	22100914	ENT OPD	IN ROOM NO.24 TUBELIGHT SET NEED TO BE REFIX	Muthu. B.	LED fitting refixed.		Ezhilarasi. M. - OPD	31/10/2022
Comp. Dt. : 03/11/2022								
Status : Completed								
2577	22110048	PAIN CLINIC NEAR INJECTION OPD	TUBELIGHT NOT WORKING IN ROOM NO.54	Vengadessaperumal. K.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Badmasri. P. - OPD	03/11/2022
2578	22110085	Paediatrics - OPD	IN REST ROOM-1 TUBELIGHT NOT WORKING	Manimaran. P.	20W TUBE LIGHT 1NO CHANG & 40W STARTER 2NO'S CHANGED		Subashree. R. - OPD	03/11/2022
2579	22110086	Paediatrics - OPD	IN HOD ROOM-PLUG POINT BROKEN,NEED TO BE REFIX	Manimaran. P.	6A 3PIN TOP 1NO CHANGED		Subashree. R. - OPD	03/11/2022
Comp. Dt. : 07/11/2022								
Status : Completed								
2580	22110257	Surgery OPD	IN ROOM NO.59 1 TUBELIGHT NOT WORKING	Manimaran. M.	36W TUBE LIGHT 1NO CHANGED		Indhira. M. - OPD	08/11/2022
Comp. Dt. : 08/11/2022								
Status : Completed								
2581	22110299	Orthopaedics - OPD	2NO'S X-RAY LOBBY NOT WORKING	Manimaran. P.	20W TUBE LIGHT 1NO CHANG & 6A 3PIN TOP 1NO CHANGED		Durgadevi. J - OPD	10/11/2022
2582	22110317	General Medicine - OPD	FAN, LIGHT, AND WALL CLOCK NOT WORKING IN ROOM NO. 17 (MEDICINE OPD)	Dhakshinamoorthy. J	CEILING FAN 1NO REWINDING WORK & BEARING CHANG & FAN REFIXING WORK PROBLEM SOLVED		Bharathi.D. - OPD	14/11/2022
Comp. Dt. : 09/11/2022								
Status : Completed								
2583	22110322	Injection OPD - Female	TUBELIGHT NOT WORKING	Rajan. R.	TUBE LIGHT 40W STARTER 1NO CHANGED		Badmasri. P. - OPD	09/11/2022
2584	22110376	General Medicine - OPD	IN DEMO ROOM-1 TUBELIGHT NOT WORKING	Manimaran. P.	36W TUBE LIGHT FITTING 1NO FIXING WORK PROBLEM SOLVED		Sivaranjani. P. - OPD	10/11/2022
Comp. Dt. : 11/11/2022								
Status : Completed								
2585	22110450	Nephrology OPD	1 TUBELIGHT NOT WORKING IN REST ROOM	Muthu. B.	20W TUBE LIGHT 1NO CHANGED		Jenifer. K. - OPD	15/11/2022
2586	22110476	Surgery OPD	TUBELIGHT NOT WORKING	Muthu. B.	36W TUBE LIGHT 1NO CHANGED		Indhira. M. - OPD	15/11/2022
2587	22110485	General Medicine - OPD	IN ROOM NO.21-2 NO'S TUBELIGHT NOT WORKING	Muthu. B.	36W TUBE LIGHT 2NO'S CHANG & 40W STARTER 1NO CHANGED		Bharathi.D. - OPD	15/11/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 14/11/2022								
Status : Completed								
2588	22110551	Orthopaedics - OPD	IN ROOM NO.67-NO POWER SUPPLY IN SWITCH BOARD	Manikandan. M.	SWITCH BOARD WIRE CUT RECONNECTION WORK PROBLEM SOLVED		Durgadevi. J - OPD	16/11/2022
Comp. Dt. : 15/11/2022								
Status : Completed								
2589	22110564	GENERAL SURGERY OPD-55	IN ROOM NO.56-1 TUBELIGHT NOT WORKING	Manikandan. M.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Indhira. M. - OPD	15/11/2022
2590	22110570	General Medicine - OPD	IN ROOM NO.17-1 TUBELIGHT NOT WORKING	Suresh. V.	MCB TRIP ON TO WORK PROBLEM SOLVED		Kamala.D. - OPD	16/11/2022
Comp. Dt. : 22/11/2022								
Status : Completed								
2591	22110901	General Medicine - OPD	NEED TO CHANGE TUBELIGHT FOR OPD ENTRANCE	Thillaikumar. R.	36W TUBE LIGHT 1NO CHANGED		Bharathi.D. - OPD	23/11/2022
Comp. Dt. : 26/11/2022								
Status : Completed								
2592	22111136	General Medicine - OPD	IN ROOM NO.17-1 TUBELIGHT NOT WORKING	Dhakshinamoorthy. J	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Kamala.D. - OPD	28/11/2022
Comp. Dt. : 29/11/2022								
Status : Completed								
2593	22111238	OG-OPD	IN DOCTOR'S ROOM-3 NO'S LED LIGHT NOT WORKING	Manimaran. P.	36W CFL 4PIN LIGHT 6NO'S CHANGED		Velangkanni. K. - OPD	03/12/2022
Comp. Dt. : 03/12/2022								
Status : Completed								
2594	22120143	TB & Chest OPD	SWITCH BOARD BROKEN IN HOD ROOM	Lakshmanan.V.	8M PLATE 1NO CHANGED		Jothi.R. - OPD	06/12/2022
Comp. Dt. : 05/12/2022								
Status : Completed								
2595	22120168	Orthopaedics - OPD	NEED FAN SERVICE	Lakshmanan.V.	ALL CEILING FAN CLEANING WORK PROBLEM SOLVED		Durgadevi. J - OPD	06/12/2022
Comp. Dt. : 07/12/2022								
Status : Completed								
2596	22120293	DENTAL OPD -2ND FLOOR	FAN DUST NEED TO BE CLEAN	Lakshmanan.V.	ALL CEILING FAN CLEANING WORK PROBLEM SOLVED		Lakshmi Devi. R. - OPD	08/12/2022

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 08/12/2022								
Status : Completed								
2597	22120370	TB & Chest OPD	REQUEST TO FIX NEW TUBELIGHT CONNECTION SET	Rajan. R.	36W TUBE LIGHT SET FIXING & LINE CONNECTION WORK PROBLEM SOLVED		Jothi.R. - OPD	13/12/2022
2598	22120371	Orthopaedics - OPD	NEED TO CHANGE 1 TUBELIGHT IN ROOM NO.66	Manimaran. P.	TUBE LIGHT 40W STARTER 1NO CHANGED		Durgadevi. J - OPD	10/12/2022
Comp. Dt. : 09/12/2022								
Status : Completed								
2599	22120440	TB & Chest OPD	NEED TO FIX NEW TUBELIGHT SET	Thillaikumar. R.	36W TUBE LIGHT SET 1NO FIXING & LINE CONNECTION WORK PROBLEM SOLVED		Jothi.R. - OPD	13/12/2022
Comp. Dt. : 10/12/2022								
Status : Completed								
2600	22120455	Paediatrics - OPD	NEED TO CHANGE TUBELIGHT FOR HOD ROOM	Rajan. R.	TUBE LIGHT 40W STARTER 1NO CHANGED		Subashree. R. - OPD	10/12/2022
2601	22120492	TB & Chest OPD	FAN NOT WORKING	Dhakshinamoorthy. J	FAN REGULATOR 1NO CHANGED		Jothi.R. - OPD	15/12/2022
Comp. Dt. : 12/12/2022								
Status : Completed								
2602	22120503	New OT	IN FEMALE DESSING CHANGING ROOM TUBELIGHT NOT WORKING	Muthu. B.	36W TUBE LIGHT 2NO'S CHANG & 40W STARTER 40W STARTER 2NO'S CHANGED		Banupriya. M. - Operation Theatre	13/12/2022
Comp. Dt. : 13/12/2022								
Status : Completed								
2603	22120576	PSYCHIATRY OPD	NEED TO CHANGE TUBELIGHT FOR ROOM NO 76	Dhakshinamoorthy. J	36W TUBE LIGHT 1NO CHANGED		Bhuvaneswari. G. - P.H.C. - Tiruvonnainallur	15/12/2022
Comp. Dt. : 15/12/2022								
Status : Completed								
2604	22120685	CTVS-ROOM NO.225 -2ND FLOOR	NEED TO CHANGE CEILING LIGHT	Manimaran. P.	36W CFL LIGHT 1NO CHANGED		Suvitha. R. - OPD	17/12/2022
2605	22120688	IVF ART CLINIC-INSIDE OF OG OPD(NO.68)	NEED TO CHANGE LED LIGHT FOR LAB	Vengadessaperumal. K.	NEW 30W LED LIGHT 1NO CHANG & LINE CONNECTION WORK PROBLEM SOLVED		Rajasekari. R. - OPD	28/12/2022
Comp. Dt. : 19/12/2022								
Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2606	22120832	OG-OPD	TUBELIGHT NOT WORKING	Suresh. V.	36W TUBE LIGHT 2NO'S CHANG & 40W STARTER 1NO CHANG & 36W CHOKE 1NO CHANG & SIDE HOLDER 1NO CHANGED		Velangkanni. K. - OPD	20/12/2022
		Comp. Dt. : 24/12/2022 Status : Completed						
2607	22121103	TB & Chest OPD	TUBELIGHT NOT WORKING	Manimaran. M.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Jothi.R. - OPD	26/12/2022
2608	22121121	OG-OPD	STERLIZER SWITCH NOT WORKING	Vengadessaperumal. K.	16A SWITCH 1NO CHANGED		Velangkanni. K. - OPD	26/12/2022
		Comp. Dt. : 26/12/2022 Status : Completed						
2609	22121143	Orthopaedics - OPD	NEED TO FIX PLUG POINT FOR X-LOBBY	Vengadessaperumal. K.	6A 3PIN TOP 1NO CHANGED		Durgadevi. J - OPD	26/12/2022
		Comp. Dt. : 27/12/2022 Status : Completed						
2610	22121248	Ophthalmology - OPD	IN OCT ROOM-SUDDENLY POWER GOT SHUTDOWN	Muthu. B.	10KVA UPS TRIP WIRE CUT RESOLDRING WORK & UPS CHEKING WORK PROBLEM SOLVED		Seetha. R. - OPD	28/12/2022
		Comp. Dt. : 28/12/2022 Status : Completed						
2611	22121272	GASTROENTROLOGY OPD-2ND FLOOR	LIGHT NOT WORKING IN DOCTOR'S ROOM	Lakshmanan.V.	36W CFL 4PIN LIGHT 4NO'S CHANGED		Suvitha. R. - OPD	28/12/2022
2612	22121289	ENT OPD	NO POWER SUPPLY IN ROOM NO.23	Lakshmanan.V.	MCB TRIP ON TO WORK PROBLEM SOLVED		Ezhilarasi. M. - OPD	28/12/2022
		Comp. Dt. : 30/12/2022 Status : Completed						
2613	22121347	GENERAL SURGERY OPD-55	1 TUBELIGHT NOT WORKING	Lakshmanan.V.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Indhira. M. - OPD	30/12/2022
		Comp. Dt. : 02/01/2023 Status : Completed						
2614	23010016	Ophthalmology - OPD	IN ROOM NO.84-TUBELIGHT NOT WORKING	Muthu. B.	36W tube light 1no changed.		Seetha. R. - OPD	02/01/2023
		Comp. Dt. : 03/01/2023 Status : Completed						


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2615	23010065	OG-OPD	2NOS TUBELIGHT NOT WORKING	Muthu. B.	36W 4PIN CFL LIGHT 3NO'S CHANG & 9W LED LIGHT 2NO'S CHANG & LINE CONNECTION WORK PROBLEM SOLVED		Velangkanni. K. - OPD	03/01/2023
Comp. Dt. : 05/01/2023 Status : Completed								
2616	23010194	Orthopaedics - OPD	NEED TO CHANGE TUBELIGHT -ROOM NO.64	Muthu. B.	36W TUBE LIGHT 2NO'S CHANG & 40W STARTER 3NO'S CHANGED		Durgadevi. J - OPD	06/01/2023
2617	23010200	Surgery OPD	NEED TO CHANGE TUBELIGHT	Muthu. B.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Indhira. M. - OPD	06/01/2023
Comp. Dt. : 06/01/2023 Status : Completed								
2618	23010270	General Medicine - OPD	NEED TO CHECK A/C-PLUG POINT.POWER PROBLEM	Muthu. B.	MCB TRIP ON TO WORK PROBLEM SOLVED		Bharathi.D. - OPD	06/01/2023
Comp. Dt. : 07/01/2023 Status : Completed								
2619	23010312	GENERAL SURGERY OPD-55	X-RAY LOBY NO WORKING PROPERLY	Muthu. B.	X-RAY LABY CHEKING WORK PROBLEM SOLVED		Indhira. M. - OPD	09/01/2023
Comp. Dt. : 10/01/2023 Status : Completed								
2620	23010392	Paediatrics - OPD	NEED WIRE EXTENSION	Srinivasan. R.	3M SWITCH BOARD FIXING & LINE CONNECTION WORK PROBLEM SOLVED		Subashree. R. - OPD	12/01/2023
2621	23010393	DERMATOLOGY OPD	STERLIZER NOT WORKING	Muthu. B.	STERLIZER 2KW COIL 1NO CHANGED		Indumathi. T. - OPD	11/01/2023
2622	23010424	General Medicine - OPD	IN ROOM NO.15 NO POWER SUPPLY IN SWITCH BOARD	Manimaran. M.	MCB TRIP ON TO WORK PROBLEM SOLVED		Bharathi.D. - OPD	13/01/2023
Comp. Dt. : 11/01/2023 Status : Completed								
2623	23010467	GENERAL SURGERY OPD-55	TUBELIGHT BLINKING PROBLEM	Vijayaraghavan.B.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Indhira. M. - OPD	12/01/2023
Comp. Dt. : 13/01/2023 Status : Completed								
2624	23010574	Surgery OPD	NEED TO CHANGE TUBELIGHT	Babu. D.	TUBE LIGHT 40W STARTER 1NO CHANGED		Indhira. M. - OPD	14/01/2023
Comp. Dt. : 18/01/2023 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2625	23010640	TB & Chest OPD	NEED TO REFIX SWITCH BOARD	Srinivasan. R.	CEILING FAN REGULATOR TOP 1NO CHANGED		Jothi.R. - OPD	19/01/2023
	Comp. Dt. : 19/01/2023							
	Status : Completed							
2626	23010653	Orthopaedics - OPD	NEED TO CHANGE TUBELIGHT 2 NOS FOR DEMO ROOM	Suresh. V.	36W TUBE LIGHT 1NO CHANGED		Durgadevi. J - OPD	20/01/2023
	Comp. Dt. : 23/01/2023							
	Status : Completed							
2627	23010798	ENT OPD	NEED TO CHANGE TUBELIGHT	Manikandan. M.	36W TUBE LIGHT 1NO CHANG & 36W CHOKE 1NO CHANGED		Kamala.D. - OPD	24/01/2023
2628	23010840	TB & Chest OPD	NEED TO CHANGE TUBELIGHT - HOD ROOM	Muthu. B.	36W TUBE LIGHT 1NO CHANGED		Jothi.R. - OPD	24/01/2023
	Comp. Dt. : 24/01/2023							
	Status : Completed							
2629	23010879	General Medicine - OPD	NEED TO CHANGE TUBELIGHT - ROOM NO 18	Lakshmanan.V.	TUBE LIGHT 40W STARTER 1NO CHANGED		Bharathi.D. - OPD	25/01/2023
	Comp. Dt. : 31/01/2023							
	Status : Completed							
2630	23011119	OG-OPD	X RAY LOBBY 3NOS NOT WORKING	Damodharan. V.	X-RAY LABY 1NO WIRE CUT REJOINT WORK & 2NO'S 6A 3PIN TOP CHANGED		Velangkanni. K. - OPD	01/02/2023
	Comp. Dt. : 07/02/2023							
	Status : Completed							
2631	23020227	OG-OPD	FAN NOT WORKING AT STORE ROOM	Muthu. B.	FAN CHEKING WORK NO COMPLAINT PROBLEM SOLVED		Velangkanni. K. - OPD	07/02/2023
	Comp. Dt. : 08/02/2023							
	Status : Completed							
2632	23020306	TB & Chest OPD	NEED TO FIX NEW REGULATOR	Muthu. B.	ceiling fan regulator cheking no complaint problem solved		Jothi.R. - OPD	09/02/2023
	Comp. Dt. : 10/02/2023							
	Status : Completed							
2633	23020374	CLINICAL DEPARTMENT IN 4th FLOOR	TUBELIGHT NOT WORKING IN PROCEDURE ROOM	Manimaran. P.	36W TUBE LIGHT 1NO CHANGED		Lakshmi Devi. R. - OPD	15/02/2023
	Comp. Dt. : 13/02/2023							
	Status : Completed							


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2634	23020454	OG-OPD	NEED TO CHANGE TUBELIGHT 2 NOS	Rajan. R.	22W LED TUBE LIGHT 2NO'S CHANG & LINE CONNECTION WORK PROBLEM SOLVED		Velangkanni. K. - OPD	14/02/2023
2635	23020486	Paediatrics - OPD	NEED TO CHANGE TUBELIGHT	Vengadessaperumal. K.	TUBE LIGHT 40W STARTER 1NO CHANGED		Subashree. R. - OPD	14/02/2023
Comp. Dt. : 14/02/2023 Status : Completed								
2636	23020508	OG-OPD	need to change tubelight 2 nos	Rajan. R.	36W TUBE LIGHT FITTING 3NO'S CHANG & 9W LED LIGHT 1NO CHANGED		Velangkanni. K. - OPD	16/02/2023
2637	23020515	General Medicine - OPD	NEED TO CHANGE TUBELIGHT FOR ROOM NO 15	Rajan. R.	36w tube light 1no changed		Bharathi.D. - OPD	14/02/2023
2638	23020550	Orthopaedics - OPD	NEED TO CORRECT - TIME FOR DIGITAL CLOCK	Manimaran. P.	CLOCK TIME CORRECT WORK PROBLEM SOLVED		Durgadevi. J - OPD	15/02/2023
Comp. Dt. : 17/02/2023 Status : Completed								
2639	23020665	Paediatrics - OPD	NEED TO CHANGE TUBELIGHT FOR HOD ROOM	Muthu. B.	TUBE LIGHT SIDE HOLDER 1NO CHANGED		Subashree. R. - OPD	18/02/2023
Comp. Dt. : 18/02/2023 Status : Completed								
2640	23020712	Nephrology OPD	NEED TO CHANGE LED LIGHT - OPD NO 215	Muthu. B.	36W 4PIN CFL LIGHT 2NO'S CHANGED		Jenifer. K. - OPD	18/02/2023
2641	23020713	Ophthalmology - OPD	NEED TO CHECK POWER - UPS NOT WORKING - ROOM NO 81	Manimaran. P.	UPS MCB TRIP ON TO WORK PROBLEM SOLVED		Seetha. R. - OPD	18/02/2023
Comp. Dt. : 20/02/2023 Status : Completed								
2642	23020741	Surgery OPD	NEED TO CHANGE TUBELIGHT FOR ROOM NO 55 & NEED CLEANING WORK FOR FAN	Vijayaraghavan.B.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Indhira. M. - OPD	21/02/2023
2643	23020758	Ophthalmology - OPD	NEED TO CHECK POWER SUPPLY - ROOM NO 82	Srinivasan. R.	MCB TRIP ON TO WORK PROBLEM SOLVED		Seetha. R. - OPD	21/02/2023
Comp. Dt. : 21/02/2023 Status : Completed								
2644	23020787	Paediatrics - OPD	NEED TO CHANGE TUBELIGHT	Manikandan. M.	6A SWITCH 1NO CHANG & CEILING FAN CAPACITOR 2.5MFT 1NO CHANG & 36W CHOKE 1NO CHANG & 40W STARTER 1NO		Subashree. R. - OPD	22/02/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2645	23020802	DERMATOLOGY OPD	NEED ADJUSTMENT WORK FOR FIRE PIPELINE AND FAN ROD - FAN PROBLEM TO WORK - ROOM NO 73	Manikandan. M.	CEILING FAN ROD CHANG & LINE CONNECTION WORK PROBLEM SOLVED		Indumathi. T. - OPD	22/02/2023
		Comp. Dt. : 22/02/2023 Status : Completed						
2646	23020835	Ophthalmology - OPD	ROOM NO-83,TUBELIGHT NOT WORKING	Vengadessaperumal. K.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Seetha. R. - OPD	23/02/2023
2647	23020856	Paediatrics - OPD	OPD TUBELIGHT NOT WORKING	Vengadessaperumal. K.	TUBE LIGHT 40W STARTER 1NO CHANGED		Subashree. R. - OPD	23/02/2023
		Comp. Dt. : 23/02/2023 Status : Completed						
2648	23020884	OG-OPD	NEED TO CHANGE TUBELIGHT 2 NOS FOR DEMO ROOM	Vengadessaperumal. K.	36W CFL 4PIN LIGHT 4NO'S CHANG & 40W STARTER 6NO'S CHANGED		Velangkanni. K. - OPD	23/02/2023
		Comp. Dt. : 28/02/2023 Status : Completed						
2649	23021078	PSYCHIATRY OPD	ONE TUBELIGHT NOT WORKING	Sathishkumar. R.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Kamala.D. - OPD	01/03/2023
		Comp. Dt. : 02/03/2023 Status : Completed						
2650	23030058	PSYCHIATRY OPD	NEED TO CHANGE TUBELIGHT	Srinivasan. R.	TUBE LIGHT 40W STARTER 1NO CHANGED		Kamala.D. - OPD	03/03/2023
2651	23030076	OG-OPD	NEED TO CHANGE RESTROOM LED LIGHT FOR HOD MADAM ROOM	Srinivasan. R.	9W LED LIGHT 1NO CHANGED		Velangkanni. K. - OPD	04/03/2023
		Comp. Dt. : 03/03/2023 Status : Completed						
2652	23030119	IVF ART CLINIC-INSIDE OF OG OPD(NO.68)	KETTLE NOT WORKING	Manimaran. P.	NO/OFF SWITCH PROBLEM		Rajasekari. R. - OPD	03/05/2023
		Comp. Dt. : 06/03/2023 Status : Completed						
2653	23030208	General Medicine - OPD	NEED TO CHECK FAN & TUBELIGHT - NOT WORKING	Damodharan. V.	TUBE LIGHT 40W STARTER 1NO CHANG & CEILING FAN CAPACITOR 2.5MFT 1NO CHANGED		Bharathi.D. - OPD	07/03/2023
		Comp. Dt. : 07/03/2023 Status : Completed						


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2654	23030252	Orthopaedics - OPD	DUE TO TOUCH OF FAN - NEED TO CHECK FIRE PIPELINE CONNECTION	Muthu. B.	CEILING FAN ROD 1NO CHANGED		Durgadevi. J - OPD	08/03/2023
Comp. Dt. : 11/03/2023 Status : Completed								
2655	23030441	Paediatrics - OPD	NEED TO CHECK POWER AT HOD ROOM	Muthu. B.	MCB TRIP ON TO WORK PROBLEM SOLVED		Subashree. R. - OPD	14/03/2023
Comp. Dt. : 18/03/2023 Status : Completed								
2656	23030740	TB & Chest OPD	NEED TO CHANGE TUBELIGHT FOR DOCTOR'S ROOM	Thillaikumar. R.	Tube light starter 1no changed.		Jothi.R. - OPD	18/03/2023
2657	23030741	TB & Chest OPD	X RAY LOBBY NOT WORKING	Rajan. R.	9W LED lamp 1no changed.		Jothi.R. - OPD	18/03/2023
2658	23030742	Orthopaedics - OPD	NEED TO CHANGE TUBELIGHT FOR ROOM NO 64	Thillaikumar. R.	Tube light starter 1no changed.		Durgadevi. J - OPD	18/03/2023
Comp. Dt. : 20/03/2023 Status : Completed								
2659	23030758	Injection Room - OPD	NEED TO CHANGE TUBELIGHT FOR ROOM NO 53	Rajan. R.	36W TUBE LIGHT 1NO CAHNG & 40W STARTRE 1NO CHANGED		Badmasri. P. - OPD	20/03/2023
2660	23030775	PSYCHIATRY OPD	NEED TO CHECK FIR PIPELINE - WATERLEAKAGE AT ROOM NO75	Duraikannu. D.	FIRE PIPE LINE WATER LEAKAGE CHEKING WORK PROBLEM SOLVED		Indumathi. T. - OPD	20/03/2023
Comp. Dt. : 23/03/2023 Status : Completed								
2661	23030941	Orthopaedics - OPD	NEED TO CHECK FIRE PIPE LINE - WATER LEAKAGE IN ROOM NO 54	Manimaran. M.	Water leakage problem - solved.		Durgadevi. J - OPD	23/03/2023
Comp. Dt. : 24/03/2023 Status : Completed								
2662	23030990	Surgery OPD	NEED TO CHANGE TUBELIGHT FOR ROOM NO 57	Thillaikumar. R.	36W tube light 1no changed.		Indhira. M. - OPD	24/03/2023
Comp. Dt. : 25/03/2023 Status : Completed								
2663	23031036	DENTAL OPD -2ND FLOOR	NEED TO CHANGE TUBELIGHT FOR PROCEDURE ROOM	Azhagappan. J.	36W E.choke 1no changed.		Lakshmi Devi. R. - OPD	25/03/2023
Comp. Dt. : 27/03/2023 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2664	23031100	TB & Chest OPD	NEED TO CHANGE TUBELIGHT FOR HOD ROOM	Vengadessaperumal. K.	36W TUBE LIGHT CHOKE 1NO CHANGED		Jothi.R. - OPD	28/03/2023
2665	23031107	ENT OPD	FAN NOT WORKING - ROOM NO 26	Thillaikumar. R.	Fan capacitor 2.5mfd 1no changed.		Ezhilarasi. M. - OPD	29/03/2023
Comp. Dt. : 28/03/2023								
Status : Completed								
2666	23031183	ENT OPD	NEED TO CHECK FIRE PIPE LINE - WATER LEAKAGE ROOM NO 26	Thillaikumar. R.	Water leak problem solved.		Ezhilarasi. M. - OPD	31/03/2023
Comp. Dt. : 29/03/2023								
Status : Completed								
2667	23031229	General Medicine - OPD	NEED TO CHANGE TUBELIGHT - ROOM NO 21	Thillaikumar. R.	36W tube light 1no & starter 1no changed.		Bharathi.D. - OPD	29/03/2023
2668	23031243	IVF ART CLINIC-INSIDE OF OG OPD(NO.68)	NEED TO CHECK - ELECTRICAL ITEM BURNT SOUND - NEED URGENT SERVICE AT DR JAYASREE MADAM CABIN	Thillaikumar. R.	Switch problem - solved.		Rajasekari. R. - OPD	29/03/2023
Comp. Dt. : 11/04/2023								
Status : Completed								
2669	23040338	Orthopaedics - OPD	NEED TO CHECK X RAY LOBBY - CONNECTION PROBLEM	Manikandan. M.	X - Ray lobby wire problem - solved.		Durgadevi. J - OPD	12/04/2023
Comp. Dt. : 15/04/2023								
Status : Completed								
2670	23040448	Orthopaedics - OPD	NEED TO CHANGE POWER - PLUG POINT NOT WORKING	Manimaran. M.	6A COCKET 2NO'S CHANG & 6A SWITCH 2NO'S CHANGED		Durgadevi. J - OPD	17/04/2023
Comp. Dt. : 16/04/2023								
Status : Completed								
2671	23040462	Orthopaedics - OPD	NEED TO CHECK FIRE PIPE LINE - WATER LEAKAGE - ORTHO OPD NO 68	Bharanidharan. R.	FIRE PIPE WATER CHEKING WORK NO COMPLAINT		Durgadevi. J - OPD	19/04/2023
2672	23040467	General Medicine - OPD	NEED TO CHANGE TUBELIGHT FOR DEMO ROOM [ROOM NO 22]	Vijayaraghavan.B.	NEW 22W LED LIGHT 1NO CHANGED		Bharathi.D. - OPD	17/04/2023
2673	23040469	ENT OPD	TUBELIGHT NOT WORKING - ROOM NO 25	Vijayaraghavan.B.	36W TUBE LIGHT 1NO CHANGED		Ezhilarasi. M. - OPD	17/04/2023
2674	23040470	ENT OPD	FAN NOT WORKING - ROOM NO 30	Vijayaraghavan.B.	CEILING FAN CAPACIOTR 2.5MFT 1NO CHANG & FAN 2NO'S CLEANING WORK PROBLEM SOLVED		Ezhilarasi. M. - OPD	17/04/2023
Comp. Dt. : 20/04/2023								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
2675	23040627	Orthopaedics - OPD	FAN SLOW PROBLEM - ROOM NO 64	Vijayaraghavan.B.	CEILING FAN CAPACITOR 2.5MFT 1NO CHANGED		Durgadevi. J - OPD	20/04/2023
Comp. Dt. : 22/04/2023								
Status : Completed								
2676	23040698	OG-OPD	FAN NOT WORKING IN STORE ROOM	Muthu. B.	CEILING FAN CAPACITOR 2.5MFT 1NO CHANGED		Velangkanni. K. - OPD	22/04/2023
Comp. Dt. : 24/04/2023								
Status : Completed								
2677	23040776	General Medicine - OPD	NEED TO CHECK POWER - SUPPLY PROBLEM	Manimaran. M.	MCB TRIP ON TO WORK PROBLEM SOLVED		Bharathi.D. - OPD	25/04/2023
Comp. Dt. : 25/04/2023								
Status : Completed								
2678	23040785	General Medicine - OPD	NED TO CHANGE TUBELIGHT - ROOM NO 19	Srinivasan. R.	36W TUBE LIGHT 1NO CHANGED		Sivaranjani. P. - OPD	26/04/2023
2679	23040786	General Medicine - OPD	FAN NOT WORKING - SLOW PROBLEM IN DEMO ROOM	Vijayaraghavan.B.	CEILING FAN CAPACITOR 2.5MFT 1NO CHANGED		Sivaranjani. P. - OPD	26/04/2023
Comp. Dt. : 26/04/2023								
Status : Completed								
2680	23040840	Ophthalmology - OPD	NEED TO CHANGE TUBELIGHT - ROOM NO 80	Rajan. R.	36W TUBE LIGHT 1NO CHANGED		Kamala.D. - OPD	27/04/2023
Comp. Dt. : 28/04/2023								
Status : Completed								
2681	23040949	Surgery OPD	FAN NOT WORKING	Rajan. R.	CEILING FAN CAPACITOR 2.5MFT 1NO CHANGED		Indhira. M. - OPD	28/04/2023
Comp. Dt. : 02/05/2023								
Status : Completed								
2682	23050026	OG-OPD	NEED TO CHECK TUBELIGHT - BURNT AT ENTRANCE NEED URGENT SERVICE	Sathishkumar. R.,Babu. D.,Manimaran. M.	MCB TRIP ON TO WORK PROBLEM SOLVED		Velangkanni. K. - OPD	02/05/2023
2683	23050028	V I P DENTAL CLINIC II FLOOR	TUBELIGHT NOT WORKING - UPS LINE LIGHT ALSO NOT WORKING	Sathishkumar. R.,Babu. D.,Manimaran. M.	36W TUBE LIGHT 1NO CHANG & 36W CHOKE 1NO CHANGED		Lakshmi Devi. R. - OPD	03/05/2023
2684	23050074	Male Surgery - Ward 202	FAN SLOW PROBLEM	Vijayaraghavan.B.	CEILING FAN CAPACIOTR 2.5MFT 1NO CHANGED		Priyadharshini. S. - OPD	03/05/2023
Comp. Dt. : 04/05/2023								
Status : Completed								
2685	23050173	Minor O.T. - Surgical OP	FOCUS LIGHT NOT WORKING	Rajan. R.	BIOMEDICAL DPET COMPLAINT		Durgadevi. J - OPD	06/05/2023

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHAKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 09/05/2023								
Status : Completed								
2686	23050341	Orthopaedics - OPD	NEED TO CHANGE TUBELIGHT FOR OPD ENTRANCE & ROOM NO 65	Muthu. B.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Durgadevi. J - OPD	09/05/2023
Comp. Dt. : 15/05/2023								
Status : Completed								
2687	23050607	Ophthalmology - OPD	NEED TO CHECK FAN & LIGHT - NOT WORKING AT OPHTHAL OPD ONE SIDE	Manimaran. M.	CEILING FAN CAPACITOR 2.5MFT 1NO CHANG & TUBE LIGHT 1NO CHANGED		Seetha. R. - OPD	17/05/2023
Comp. Dt. : 16/05/2023								
Status : Completed								
2688	23050621	Ophthalmology - OPD	NEED TO CHANGE TUBELIGHT - ROOM NO 80	Manimaran. M.	36W TUBE LIGHT 1NO CHANGED		Seetha. R. - OPD	17/05/2023
Comp. Dt. : 17/05/2023								
Status : Completed								
2689	23050712	Paediatrics - OPD	NEED TO CHANGE TUBELIGHT FOR HOD ROOM	Srinivasan. R.	36W TUBE LIGHT 1NO CHANGED		Subashree. R. - OPD	18/05/2023
Comp. Dt. : 18/05/2023								
Status : Completed								
2690	23050768	Surgery OPD	FAN SLOW PROBLEM AT DOCTOR'S ROOM	Thillaikumar. R.	CEILING FAN CAPACITOR 2.5MFT 1NO CHANGED		Indhira. M. - OPD	19/05/2023
2691	23050769	COMMON MALE TOILET NEAR ORTHO OPD	NEED TO CHANGE TUBELIGJT NOT WORKING	Thillaikumar. R.	TUBE LIGHT 40W STARTER 1NO CHANGED		Indhira. M. - OPD	19/05/2023
Comp. Dt. : 03/06/2023								
Status : Completed								
2692	23060082	PSYCHIATRY OPD	NEED TO CHANGE TUBELIGHT	Suresh. V.	TUBE LIGHT 40W STARTER 1NO CHANGED		Indumathi. T. - OPD	05/06/2023
Comp. Dt. : 06/06/2023								
Status : Completed								
2693	23060177	DENTAL VIP CLINIC-SPECIAL OPD-2ND FLOOR	NEED TO REFIX FIRE ALARM - TILL YET NOT CLOSED	Vijayaraghavan.B.	LED FITTING 1NO REFIXING WORK PROBLEM SOLVED		Jayasree. S. - TB & Chest / Psychiatry	07/06/2023
Comp. Dt. : 09/06/2023								
Status : Completed								
2694	23060339	COMMON FEMALE RESTROOM NEAR ORTHO OPD	NEED TO CHANGE TUBELIGHT 2 NOS	Dhakshinamoorthy. J	TUBE LIGHT 40W STARTER 2NO'S CHANGED		Durgadevi. J - OPD	10/06/2023
Comp. Dt. : 12/06/2023								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
2695	23060404	TB & Chest OPD	NEED TO CHECK FAN - SLOW PROBLEM	Damodharan. V.	CEILING FAN CHEKING WORK NO COMPLAINT PROBLEM SOLVED		Jothi.R. - OPD	12/06/2023
Comp. Dt. : 13/06/2023								
Status : Completed								
2696	23060459	PSYCHIATRY OPD	FAN NOT WORKING - ROOM NO 78	Manimaran. M.	CEILING FAN CAPACITOR 2.5MFT 1NO CHANGED		Indumathi. T. - OPD	15/06/2023
Comp. Dt. : 14/06/2023								
Status : Completed								
2697	23060503	PSYCHIATRY OPD	FAN NOT WORKING	Manimaran. M.	CEILING FAN CAPACITOR 2.5MFT 1NO CHANGED		Indumathi. T. - OPD	15/06/2023
Comp. Dt. : 21/06/2023								
Status : Completed								
2698	23060743	TB & Chest OPD	NEED TO CHANGE TUBELIGHT	Vengadessaperumal. K.	TUBE LIGHT 36W CHOKE 1NO CHANGED		Jothi.R. - OPD	22/06/2023
Comp. Dt. : 22/06/2023								
Status : Completed								
2699	23060838	Nephrology OPD	NEED TO CHANGE CEILING LIGHT - OPD NO 215	Vengadessaperumal. K.	NEW LED LIGHT 1NO FIXING WORK PROBLEM SOLVED		Jenifer. K. - OPD	24/06/2023
Comp. Dt. : 23/06/2023								
Status : Completed								
2700	23060872	Paediatrics - OPD	FAN NOT WORKING	Thillaikumar. R.	CEILING FAN CAPACITOR 2.5MFT 1NO CHANGED		Subashree. R. - OPD	24/06/2023
Comp. Dt. : 24/06/2023								
Status : Completed								
2701	23060925	Paediatrics - OPD	FAN SLOW PROBLEM [AGAIN & AGAIN]	Vengadessaperumal. K.	CEILING FAN 1NO REWINDING WORK & BEARING 2NO'S CHANG & FAN REFIXING WORK PROBLEM SOLVED		Subashree. R. - OPD	06/07/2023
Comp. Dt. : 26/06/2023								
Status : Completed								
2702	23060940	DENTAL OPD -2ND FLOOR	NEED TO CHECK X RAY LOBBY CABLE - PROBLEM	Vijayaraghavan.B.	BABY HOLDER 1NO CHANGED		Sarala. V. - OPD	27/06/2023
Comp. Dt. : 28/06/2023								
Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2703	23061062	ENT OPD	NEED TO CHANGE TUBELIGHT FOR ROOM NO 24	Srinivasan. R.	6A SWITCH 1NO CHANG & 6A SOCKET 1NO CHANG & TUBE LIGHT 1NO CHANGED		Ezhilarasi. M. - OPD	30/06/2023
2704	23061063	ENT OPD	SWITCH NOT WORKING AT ROOM NO 28 & 30	Manimaran. P.	6A SWITCH 2NO'S CHANG & 9W LED LIGHT 1NO CHANGED		Ezhilarasi. M. - OPD	30/06/2023
Comp. Dt. : 30/06/2023 Status : Completed								
2705	23061133	General Medicine - OPD	NEED TO CHANGE TUBELIGHT FOR ROOM NO 17	Lakshmanan.V.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Bharathi.D. - OPD	01/07/2023
Dept Name : Operation Theatre - Electrical Maintenance Comp. Dt. : 04/05/2022 Status : Completed								
2706	22050065	OG OT	NEED TO CHANGE TUBELIGHT	Muthu. B.	36W TUBE LIGHT 1NO & 40W STARTER 1NO CHANGED		Vinotha. G. - Operation Theatre	05/05/2022
Comp. Dt. : 10/05/2022 Status : Completed								
2707	22050331	Main OT	NEED TO CHANGE KUNDU LIGHT FOR WASHING AREA	Manikandan. M.	18W 4PIN CFL LIGHT 2NO'S CHANG & 9W LED LIGHT 1NO CHANGED		Mahalakshmi. G. - Operation Theatre	13/05/2022
Comp. Dt. : 11/05/2022 Status : Completed								
2708	22050374	OG OT	NEED TO FIX SWITCH BOARD PANEL COVER	Lakshmanan.V.	SWITCH BOARD PANEL REFIXING WORK PROBLEM SOLVED		Sathia. R. - Operation Theatre	12/05/2022
2709	22050375	New OT	FAN NOT WORKING	Lakshmanan.V.	CEILING FAN CAPACITOR 2.5MFT 1NO CHANGED		Vignesh Kumar. A. - Operation Theatre	12/05/2022
Comp. Dt. : 12/05/2022 Status : Completed								
2710	22050430	OG OT	PEDESTAL FAN NOT WORKING	Sathishkumar. R.	3PIN TOP WIRE CUT RECONNECTION WORK PROBLEM SOLVED		Amudha. V. - Operation Theatre	14/05/2022
Comp. Dt. : 13/05/2022 Status : Completed								
2711	22050448	New OT	NEEDTO CHANGE ONE TUBELIGHT --ENTRANCE	Vijayaraghavan.B.	36W TUBE LIGHT 1NO CHANGED		Jayapratha. S. - Operation Theatre	13/05/2022
Comp. Dt. : 18/05/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2712	22050654	OG OT	NEED TO CHANGE TUBELIGHT	Lakshmanan.V.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Sathia. R. - Operation Theatre	20/05/2022
Comp. Dt. : 19/05/2022 Status : Completed								
2713	22050712	OG OT	FAN NOT WORKING IN FEMALE DRESS CHANGING ROOM	Lakshmanan.V.	CEILING FAN CAPACITOR 2.5MFT 1NO CHANGED		Sathia. R. - Operation Theatre	20/05/2022
Comp. Dt. : 21/05/2022 Status : Completed								
2714	22050797	ORTHO OT	NEED TO CHANGE TUBELIGHT 2 NOS	Muthu. B.	36W TUBE LIGHT 2NO'S CHANG & 36W CHOKE 2NO'S CHANGED		Shankari. G. - Operation Theatre	24/05/2022
Comp. Dt. : 27/05/2022 Status : Completed								
2715	22051017	SURGERY OT	NEED TO CHANGE TUBELIGHT	Muthu. B.	36W TUBE LIGHT 1NO CHANGED		Jagatheeswaran. G. - Operation Theatre	28/05/2022
2716	22051029	New OT	NEED TO FIX 2 PIN TOP FOR FUMIGATION MACHINE	Manimaran. P.	6A 3PIN TOP 1NO CHANGED		Palaniraja. G. - Operation Theatre	28/05/2022
Comp. Dt. : 03/06/2022 Status : Completed								
2717	22060101	Main OT	NEED TO CHANGE TUBELIGHT FOR STORE ROOM	Lakshmanan.V.	TUBE LIGHT 40W STARTRE 1NO CHANGED		Ayisha Bee. M. A. - Operation Theatre	04/06/2022
Comp. Dt. : 06/06/2022 Status : Completed								
2718	22060197	New OT	NEED TO CHANGE PLUGPOINT FOR STERILIZER - BURNT	Muthu. B.	16A 3PIN TOP 1NO CHANGED		Jagatheeswaran. G. - Operation Theatre	09/06/2022
Comp. Dt. : 08/06/2022 Status : Completed								
2719	22060295	ORTHO OT	NEED TO CHANGE TUBELIGHT FOR FEMALE DRESS CHANGING ROOM - NEED URGENT SERVICE	Lakshmanan.V.	16A 3PIN TOP 1NO CHANGED		Mahalakshmi. G. - Operation Theatre	09/06/2022
Comp. Dt. : 10/06/2022 Status : Completed								
2720	22060361	OG OT	ONE TUBE LIGHT NOT WORKING	Muthu. B.	Tube light starter 1no changed.		Ramamoorthy.T.K - Operation Theatre	11/06/2022
Comp. Dt. : 13/06/2022								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
2721	22060454	OG OT	NEED TO CHANGE TUBELIGHT	Dhakshinamoorthy. J	Starter base problem - solved.		Hemalatha.G. - Operation Theatre	14/06/2022
2722	22060477	OG OT	NEED TO CHANGE TUBELIGHT	Srinivasan. R.	Starter base problem - solved.		Amudha. V. - Operation Theatre	14/06/2022
Comp. Dt. : 14/06/2022								
Status : Completed								
2723	22060487	OG OT	NEED TO CHANGE TUBELIGHT	Manikandan. M.	36W E.choke 1no & tube light 1no changed.		Amudha. V. - Operation Theatre	14/06/2022
Comp. Dt. : 18/06/2022								
Status : Completed								
2724	22060672	Main OT	NEED TO CHANGE TUBELIGHT 4 NOS - NOT WORKING	Manikandan. M.	36W tube light 2no's & Starter 2no's changed.		Ayisha Bee. M. A. - Operation Theatre	18/06/2022
Comp. Dt. : 21/06/2022								
Status : Completed								
2725	22060762	New OT	NEED TO CHECK EXTENTION BOARD - NOT WORKING	Dhakshinamoorthy. J	16A 3PIN TOP 1NO CHANGED		Ramachandiran. M. - Operation Theatre	23/06/2022
Comp. Dt. : 23/06/2022								
Status : Completed								
2726	22060828	OG OT	NEED TO CHANGE TUBELIGHT	Lakshmanan.V.	36W TUBE LIGHT 1NO CHANGED		Ramamoorthy.T.K - Operation Theatre	24/06/2022
Comp. Dt. : 24/06/2022								
Status : Completed								
2727	22060886	OG OT	NEED TO CHECK FAN 2 NOS - NOT WORKING	Muthu. B.	PEDESTAL FAN 2NO'S SERVICE WORK & CHEKING WORK PROBLEM SOLVED		Amudha. V. - Operation Theatre	27/06/2022
Comp. Dt. : 29/06/2022								
Status : Completed								
2728	22061062	ORTHO OT	NEED TO CHANGE TUBELIGHT [4 NOS] FOR SURGERY NO 2	Lakshmanan.V.	36W TUBE LIGHT 4NO'S CHANG & 40W STARTER 4NO'S CHANGED		Shankari. G. - Operation Theatre	30/06/2022
Comp. Dt. : 05/07/2022								
Status : Completed								
2729	22070151	EMERGENCY OT NEAR CASUALTY	STERILIZER NOT WORKING	Manikandan. M.	MCB TRIP ON TO WORK PROBLEM SOLVED		Hemalatha.G. - Operation Theatre	11/07/2022
Comp. Dt. : 09/07/2022								
Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2730	22070384	New OT	NEED TO CHANGE TUBELIGHT FOR HOD ROOM	Vijayaraghavan.B.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Perarasan. J. - Operation Theatre	11/07/2022
Comp. Dt. : 19/07/2022 Status : Completed								
2731	22070687	UROLOGY	NEED TO CHANGE TUBELIGHT FOR URO - OT [INTERCOM NO 1149]	Srinivasan. R.	9W LED LIGHT 6NO'S CHANG & BABY HOLDER 6NO'S CHANGED		Punitha. A. - Operation Theatre	30/07/2022
Comp. Dt. : 01/08/2022 Status : Completed								
2732	22080003	OG OT	FAN NOT WORKING AT DRESS CHANGING ROOM	Vijayaraghavan.B.	CEILING FAN WIRE LOOSE RECONNECTION WORK PROBLEM SOLVED		Avina. A. - Operation Theatre	02/08/2022
Comp. Dt. : 02/08/2022 Status : Completed								
2733	22080077	New OT	NEED TO CHECK PLUG POINT - NOT WORKING AT URO OT	Lakshmanan.V.	This complaint forward to Biomedical dept.		Punitha. A. - Operation Theatre	03/08/2022
Comp. Dt. : 08/08/2022 Status : Completed								
2734	22080290	SPECIALITY OT	NEED FAN SERVICE	Dhakshinamoorthy. J	WALLMOUNTING FAN CLEANING WORK PROBLEM SOLVED		Hemalatha.G. - Operation Theatre	09/08/2022
Comp. Dt. : 12/08/2022 Status : Completed								
2735	22080425	New OT	NEED TO CHANGE TUBELIGHT	Lakshmanan.V.	36W tube light 1no and starter 1no changed.		Udhaya Kumar. C. - Operation Theatre	17/08/2022
Comp. Dt. : 17/08/2022 Status : Completed								
2736	22080491	SURGERY OT	TUBELIGHT NOT WORKING (2 NOS)	Lakshmanan.V.	Tube light starter 1no changed.		Jagatheeswaran. G. - Operation Theatre	18/08/2022
Comp. Dt. : 18/08/2022 Status : Completed								
2737	22080556	New OT	TUBE LIGHT NOT WORKING - 3 NOS	Lakshmanan.V.	36W TUBE LIGHT 7NO'S CHANG & 40W STARTER 6NO'S CHANGED		Jagatheeswaran. G. - Operation Theatre	20/08/2022
Comp. Dt. : 19/08/2022 Status : Completed								
2738	22080607	New OT	TUBELIGHT NOT WORKING - 5 NOS	Lakshmanan.V.	36W TUBE LIGHT 5NO'S CHANGED		Udhaya Kumar. C. - Operation Theatre	20/08/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 20/08/2022 Status : Completed								
2739	22080666	ORTHO OT	NEED TO REARRANGE PLUG POINTS - CABLES & SWITCHES ARE DAMAGE	Muthu. B.	6A SOCKET & 6A SWITCH 1NO CHANGED		Mahalakshmi. G. - Operation Theatre	23/08/2022
Comp. Dt. : 22/08/2022 Status : Completed								
2740	22080734	SURGERY OT	HEATER WATER LEAKAGE	Dhakshinamoorthy. J	STERLIZER NEW 2KW COIL 1NO CHANG & CHEKING WORK PROBLEM SOLVED		Ramachandiran. M. - Operation Theatre	23/08/2022
Comp. Dt. : 23/08/2022 Status : Completed								
2741	22080770	EMERGENCY OT NEAR CASUALTY	NEED TO CHECK C P U - POWER PROBLEM	Lakshmanan.V.	SWITCH CHEKING WORK NO COMPLINT PROBLEM SOLVED		Hemalatha.G. - Operation Theatre	24/08/2022
Comp. Dt. : 27/08/2022 Status : Completed								
2742	22080927	Main OT	NEED TO CHANGE CEILING LIGHT - NOT WORKING	Dhakshinamoorthy. J	22W ROUNT LED LIGHT 2NO'S CHANGED		Ayisha Bee. M. A. - Operation Theatre	29/08/2022
Comp. Dt. : 01/09/2022 Status : Completed								
2743	22090003	OG OT	NEED TO CHANGE TUBELIGHT	Vengadessaperumal. K.	36W TUBE LIGHT 1NO CHANGED		Amudha. V. - Operation Theatre	02/09/2022
Comp. Dt. : 06/09/2022 Status : Completed								
2744	22090252	ORTHO OT	NEED TO CHANGE TUBELIGHT 2NOS FOR STORE ROOM & OT NO 3	Vijayaraghavan.B.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Mahalakshmi. G. - Operation Theatre	08/09/2022
Comp. Dt. : 08/09/2022 Status : Completed								
2745	22090300	SPECIALITY OT	NEED TO CHECK AC MACHINE SWITCH - SHOCK PROBLEM	Vijayaraghavan.B.	MACHINE EARTH CHEKING WORK PROBLEM SOLVED		Sobiya. N. - Operation Theatre	09/09/2022
Comp. Dt. : 09/09/2022 Status : Completed								
2746	22090345	OG OT	NEED TO CHANGE TUBELIGHT	Lakshmanan.V.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Amudha. V. - Operation Theatre	10/09/2022
Comp. Dt. : 10/09/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2747	22090390	ORTHO OT	NEED TO CHECK TOP LIGHT - NOT WORKING	Dhakshinamoorthy. J	36W CFL 4PIN LIGHT NO'S CHANGED		Perarasan. J. - Operation Theatre	13/09/2022
	Comp. Dt. : 15/09/2022							
	Status : Completed							
2748	22090572	SPECIALITY OT	UPS LINE NOT WORKING	Manimaran. P.	UPS MCB TRIP ON TO WORK PROBLEM SOLVED		Narayanan.R. - Operation Theatre	15/09/2022
	Comp. Dt. : 17/09/2022							
	Status : Completed							
2749	22090684	SPECIALITY OT	NEED TO CHANGE LED LIGHT FOR STAFF DRESS CHANGING ROOM	Vijayaraghavan.B.	MCB TRIP ON TO WORK PROBLEM SOLVED		Daiseyrani. A. - Operation Theatre	19/09/2022
	Comp. Dt. : 26/09/2022							
	Status : Completed							
2750	22091003	CSSD	NEED TO CHANGE TUBELIGHT	Vijayaraghavan.B.	36W TUBE LIGHT 1NO CHANGED		Ramamoorthy.T.K - Operation Theatre	28/09/2022
	Comp. Dt. : 29/09/2022							
	Status : Completed							
2751	22091158	CSSD	NEED TO CHECK SEALING MACHINE - NOT WORKING	Sridharan. R	SEALING MACHINE SERVICE WORK PROBLEM SOLVED		Ramamoorthy.T.K - Operation Theatre	01/10/2022
	Comp. Dt. : 05/10/2022							
	Status : Completed							
2752	22100018	OG OT	NEED TO CHANGE TUBELIGHT FOR WASHING AREA	Dhakshinamoorthy. J	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Ranjani. V. - Operation Theatre	06/10/2022
	Comp. Dt. : 10/10/2022							
	Status : Completed							
2753	22100200	OG OT	NEED TO CHECK POWER - NO POWER IN INSIDE OT	Muthu. B.	MCB TRIP ON TO WORK PROBLEM SOLVED		Amudha. V. - Operation Theatre	10/10/2022
	Comp. Dt. : 12/10/2022							
	Status : Completed							
2754	22100315	Casualty	FRIDGE NOT WORKING	Suresh. V.	A/C DEPT COMPLAINT		Hemalatha.G. - Operation Theatre	12/10/2022
	Comp. Dt. : 13/10/2022							
	Status : Completed							
2755	22100371	OG OT	NEED TO CHANGE TUBELIGHT	Muthu. B.	36W TUBE LIGHT 1NO CHANGED		Amudha. V. - Operation Theatre	13/10/2022
	Comp. Dt. : 14/10/2022							

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
2756	22100445	Main OT	NEED TO CHANGE TUBELIGHT 4 NOS	Senthil Murugan. A.	36W TUBE LIGHT 4NO'S CHANG & 40W STARTER 2NO'S CHANG & SIDE HOLDER 4NO'S CHANG & 20W TUBE LIGHT 1NO		Shankari. G. - Operation Theatre	17/10/2022
Comp. Dt. : 20/10/2022								
Status : Completed								
2757	22100685	ORTHO OT	STERLIZATION PLUG POINT AND CABLE PROBLEM	Srinivasan. R.	16A 3PIN TOP 1NO CHANGED		Shankari. G. - Operation Theatre	21/10/2022
Comp. Dt. : 27/10/2022								
Status : Completed								
2758	22100855	SPECIALITY OT	STERLIZER POWER PROBLEM	Dhakshinamoorthy. J	16A 3PIN TOP 1NO CHANGED		Deepa. I. - Operation Theatre	28/10/2022
Comp. Dt. : 05/11/2022								
Status : Completed								
2759	22110164	OG OT	TUBELIGHT NOT WORKING	Muthu. B.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Amudha. V. - Operation Theatre	08/11/2022
Comp. Dt. : 11/11/2022								
Status : Completed								
2760	22110445	ORTHO OT	1 TUBELIGHT NOT WORKING	Rajan. R.	36W TUBE LIGHT 1NO CHANGED		Mahalakshmi. G. - Operation Theatre	15/11/2022
Comp. Dt. : 14/11/2022								
Status : Completed								
2761	22110534	ORTHO OT	2 NO'S LED BULB NOT WORKING	Suresh. V.	9W LED LIGHT 1NO CHANGED		Shankari. G. - Operation Theatre	17/11/2022
Comp. Dt. : 16/11/2022								
Status : Completed								
2762	22110638	New OT	IN UROLOGY OT-2 NO'S TUBELIGHT NOT WORKING AND IN RECOVERY ROOM-3 NO'S TUBELIGHT NOT WORKING	Manikandan. M.	36W TUBE LIGHT 4NO'S CHANG & 40W STARTER 4NO'S CHANGED		Shankari. G. - Operation Theatre	18/11/2022
2763	22110686	New OT	IN SURGEON ROOM-1 TUBELIGHT NOT WORKING	Manikandan. M.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Shankari. G. - Operation Theatre	18/11/2022
Comp. Dt. : 17/11/2022								
Status : Completed								
2764	22110705	OG OT	1 TUBELIGHT NOT WORKING IN DOCTOR'S ROOM	Lakshmanan.V.	36W TUBE LIGHT 1NO CHANGED		Ranjani. V. - Operation Theatre	18/11/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 21/11/2022 Status : Completed								
2765	22110863	New OT	X-RAY LOBE NOT WORKING	Sathishkumar. R.	X-RAY LABY CHEKING WORK PROBLEM SOLVED		Kousalya. S. - Operation Theatre	21/11/2022
Comp. Dt. : 22/11/2022 Status : Completed								
2766	22110950	OG OT	TUBELIGHT NOT WORKING IN DOCTORS RESTROOM	Muthu. B.	TUBE LIGHT 40W STARTER 1NO CHANGED		Vinotha. G. - Operation Theatre	23/11/2022
2767	22110958	OG OT	NEED TO CHANGE TUBELIGHT [2 NOS]	Suresh. V.	36W TUBE LIGHT 2NO'S CHANG & 40W STARTER 1NO CHANGED		Srivalli. G. - Operation Theatre	24/11/2022
Comp. Dt. : 28/11/2022 Status : Completed								
2768	22111161	CSSD	1 TUBELIGHT NOT WORKING	Lakshmanan.V.	36W TUBE LIGHT 1NO CHANGED		Ramamoorthy.T.K - Operation Theatre	29/11/2022
Comp. Dt. : 05/12/2022 Status : Completed								
2769	22120159	New OT	NEED TO CHANGE PLUG POINT FOR MALE WAITING ROOM	Lakshmanan.V.	12M PLUG POINT SCREW LOOSE REFIXING WORK & 36W TUBE LIGHT 1NO CHANGED		Jayapratha. S. - Operation Theatre	06/12/2022
Comp. Dt. : 14/12/2022 Status : Completed								
2770	22120638	Main OT	NEED TO CHANGE TUBELIGHT 2NOS FOR WAITING AREA	Lakshmanan.V.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Shankari. G. - Operation Theatre	15/12/2022
2771	22120662	New OT	NEED TO CHANGE TUBELIGHT FOR OT NO 7	Lakshmanan.V.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Punitha. A. - Operation Theatre	15/12/2022
Comp. Dt. : 16/12/2022 Status : Completed								
2772	22120771	OG OT	NEED TO CHANGE TUBELIGHT 2 NOS	Lakshmanan.V.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Srivalli. G. - Operation Theatre	17/12/2022
Comp. Dt. : 19/12/2022 Status : Completed								
2773	22120874	Main OT	NEED TO CHANGE TUBELIGHT - 2 NOS	Lakshmanan.V.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Shankari. G. - Operation Theatre	20/12/2022
Comp. Dt. : 23/12/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2774	22121060	OG OT	TUBELIGHT NOT WORKING	Babu. D.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Sathia. R. - Operation Theatre	24/12/2022
2775	22121061	New OT	TUBELIGHT NOT WORKING FOR STORE ROOM	Muthu. B.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Kousalya. S. - Operation Theatre	24/12/2022
Comp. Dt. : 04/01/2023 Status : Completed								
2776	23010123	Main OT	2NOS (SMALL) TUBELIGHT NOT WORKING IN OT CORRIDOR	Lakshmanan.V.	18W 2PIN CFL LIGHT 2NO'S CHANGED		Shankari. G. - Operation Theatre	05/01/2023
2777	23010129	New OT	X-RAY LOBBY CABLE PROBLEM (UROLOGY OT)	Thillaikumar. R.	6A 3PIN TOP 1NO CHANGED		Gowtham. E. - Operation Theatre	06/01/2023
2778	23010130	New OT	X-RAY LOBBY CABLE PROBLEM	Suresh. V.	2CORE CABLE 4MTR CHANGED		Gowtham. E. - Operation Theatre	05/01/2023
Comp. Dt. : 11/01/2023 Status : Completed								
2779	23010436	SURGERY OT	OLD SURGERY OT-1 TUBELIGHT NOT WORKING IN 1ST FLOOR	Damodharan. V.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Ramachandiran. M. - Operation Theatre	12/01/2023
2780	23010463	New OT	5 NO'S TUBELIGHT NOT WORKING AND FAN REGULATOR PROBLEM	Damodharan. V.	36W TUBE LIGHT 3NO'S CHANG & 40W STARTER 4NO'S CHANGED		Ramachandiran. M. - Operation Theatre	12/01/2023
2781	23010464	New OT	X-RAY LOBBY PLUG POINT PROBLEM	Damodharan. V.	6A 3PIN TOP 1NO CHANGED		Ramachandiran. M. - Operation Theatre	12/01/2023
Comp. Dt. : 20/01/2023 Status : Completed								
2782	23010710	OG OT	NEED TO CHANGE TUBELIGHT FOR DRESS CHANGING ROOM	Dhakshinamoorthy. J	20W TUBE LIGHT 1NO CHANGED		Srivalli. G. - Operation Theatre	21/01/2023
Comp. Dt. : 24/01/2023 Status : Completed								
2783	23010865	OG OT	STERILIZER NOT WORKING	Manimaran. M.	STERILIZER COIL WATER SEL 2NO'S CHANG & LEAK CHEKING WORK PROBLEM SOLVED		Sathia. R. - Operation Theatre	24/01/2023
Comp. Dt. : 28/01/2023 Status : Completed								
2784	23011005	New OT	NEED TO CHECK POWER - 7TH OT , RESTROOM & WASHING AREA LIGHTS NOT WORKING - NEED URGENT SERVICE	Lakshmanan.V.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Punitha. A. - Operation Theatre	30/01/2023
Comp. Dt. : 11/02/2023								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
2785	23020415	OG OT	A/C FIXED NEWLY-REQUEST FOR ELECTRICAL CONNECTION	Rajan. R.	new a/c 2no's 25a switch 2no's,25a socket 2no's,2m plate 2no's,2m surface box 2no's,25a top 2no's,25		Manibharathi. S. - Operation Theatre	13/02/2023
Comp. Dt. : 20/02/2023								
Status : Completed								
2786	23020778	OG OT	NEED FAN CLEANING WORK	Muthu. B.	ALL CEILING FAN CLEANING WORK PROBLEM SOLVED		Manibharathi. S. - Operation Theatre	22/02/2023
Comp. Dt. : 23/02/2023								
Status : Completed								
2787	23020886	UROLOGY	NEED TO CHANGE TUBELIGHT FOR PATIENT WAITING HALL -[URO OT]	Vengadessaperumal. K.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Banupriya. M. - Operation Theatre	23/02/2023
Comp. Dt. : 02/03/2023								
Status : Completed								
2788	23030106	OG OT	NEED TO CHANGE TUBELIGHT FOR FEMALE DOCTOR'S ROOM	Vijayaraghavan.B.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Ranjani. V. - Operation Theatre	03/03/2023
Comp. Dt. : 11/03/2023								
Status : Completed								
2789	23030465	ORTHO OT	NEED TO CHANGE TUBELIGHT FOR SURGEN ROOM	Muthu. B.	36W TUBE LIGHT 1NO CHANGED		Mahalakshmi. G. - Operation Theatre	14/03/2023
Comp. Dt. : 13/03/2023								
Status : Completed								
2790	23030501	ORTHO OT	NEED TO CHANGE TUBELIGHT	Muthu. B.	36W TUBE LIGHT 1NO CHANGED		Sathia. R. - Operation Theatre	14/03/2023
Comp. Dt. : 15/03/2023								
Status : Completed								
2791	23030574	ORTHO OT	NEED TO CHANGE TUBELIGHT FOR STOREROOM	Dhakshinamoorthy. J	36W TUBE LIGHT 1NO CHANGED		Mahalakshmi. G. - Operation Theatre	16/03/2023
Comp. Dt. : 17/03/2023								
Status : Completed								
2792	23030722	CSSD	NEED TO CHANGE TUBELIGHT & NEED FAN CLEANING WORK	Thillaikumar. R.	36W TUBE LIGHT 1NO CHANG & ALL CEILING FAN CLEANIG WORK PROBLEM SOLVED		Ramamoorthy.T.K - Operation Theatre	20/03/2023

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 20/03/2023								
Status : Completed								
2793	23030801	SURGERY OT	NEED TO CHANGE TUBELIGHT FOR OLD SURGERY OT [INTERCOM NO 1159]	Rajan. R.	TUBE LIGHT 40W STARTER 1NO CHANGED		Ramachandiran. M. - Operation Theatre	20/03/2023
Comp. Dt. : 27/03/2023								
Status : Completed								
2794	23031140	OG OT	NEED TO CHECK WARMER - SHOCK PROBLEM	Vengadessaperumal. K.	WARMER CHEKING WORK ELECTRICAL NO COMPLAINT TO BIOMEDICAL DEPT COMPLAINT		Manibharathi. S. - Operation Theatre	27/03/2023
Comp. Dt. : 28/03/2023								
Status : Completed								
2795	23031173	ORTHO OT	NEED TO CHANGE TUBELIGHT	Vijayaraghavan.B.	36W tube light 2no's & starter 3no's changed.		Jamunarani. G. - Operation Theatre	30/03/2023
Comp. Dt. : 06/04/2023								
Status : Completed								
2796	23040175	OG OT	NEED TO CHANGE TUBELIGHT	Muthu. B.	Tube light starter 2no's changed.		Sathia. R. - Operation Theatre	08/04/2023
Comp. Dt. : 17/04/2023								
Status : Completed								
2797	23040525	New OT	NEED TO CHANGE CEILING LIGHT	Manikandan. M.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 3NO'S CHANG & SIDE HOLDR 1NO CHANGED		Logesh. D. - Operation Theatre	18/04/2023
Comp. Dt. : 19/04/2023								
Status : Completed								
2798	23040574	OG OT	NEED TO CHANGE TUBELIGHT FOR MAIN ENTRANCE	Dhakshinamoorthy. J	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Sathia. R. - Operation Theatre	19/04/2023
2799	23040599	ORTHO OT	NEED TO CHANGE TUBELIGHT FOR WASHING AREA [OT NO 3]	Vijayaraghavan.B.	9W LED LIGHT 1NO CHANGED		Mahalakshmi. G. - Operation Theatre	20/04/2023
Comp. Dt. : 20/04/2023								
Status : Completed								
2800	23040644	ORTHO OT	NEED TO CHANGE CEILING LIGHT 2 NOS	Muthu. B.	ORTHO OT DOOR LOCK		Mahalakshmi. G. - Operation Theatre	22/04/2023
Comp. Dt. : 08/05/2023								
Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2801	23050268	New OT	NEED TO CHANGE TUBELIGHT - UROLOGY OT - 109 [INTERCOM NO 1159]	Lakshmanan.V.	36W TUBE LIGHT 1NO CHANG & 36W CHOKE 1NO CHANGED		Udhaya Kumar. C. - Operation Theatre	09/05/2023
2802	23050273	SPECIALITY OT	EXHAUST FAN NOT WORKING	Muthu. B.	EXHAUST FAN CHEKING WORK NO COMPLAINT PROBLEM SOLVED		Sobiya. N. - Operation Theatre	11/05/2023
Comp. Dt. : 11/05/2023 Status : Completed								
2803	23050453	New OT	NEED TO CHANGE TUBELIGHT FOR FEMALE DOCTORS DRESS CHANGING ROOM - AT UROLOGY OT	Babu. D.	TUBE LIGHT 40W STARTER 1NO CHANGED		Punitha. A. - Operation Theatre	11/05/2023
Comp. Dt. : 17/05/2023 Status : Completed								
2804	23050689	New OT	NEED TO REFIX CABLE FOR MONITOR TO PLUGPOINT - DAMAGE	Dhakshinamoorthy. J	SWITCH BOARD WIRE LOOSE CONNECT WIRE RECONNECTION WORK PROBLEM SOLCED		Punitha. A. - Operation Theatre	19/05/2023
2805	23050708	New OT	TOP LIGHT NOT WORKING	Dhakshinamoorthy. J	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Logesh. D. - Operation Theatre	19/05/2023
Comp. Dt. : 27/05/2023 Status : Completed								
2806	23051085	New OT	NEED TO CHANGE TUBELIGHT 2NOS FOR HOD ROOM & MALE DRESS CHANGING ROOM	Lakshmanan.V.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Punitha. A. - Operation Theatre	29/05/2023
Comp. Dt. : 01/06/2023 Status : Completed								
2807	23060026	New OT	NEED TO CHANGE TUBELIGHT FOR RIGHT SIDE AC ROOM	Manikandan. M.	36W TUBE LIGHT 3NO'S CHANG & 36W CHOKE 2NO'S CHANG & 40W STARTER 3NO'S CHANGED		Kuppan.E. - Operation Theatre	02/06/2023
Comp. Dt. : 02/06/2023 Status : Completed								
2808	23060057	SURGERY OT	FUMICATION CABLE PROBLEM	Thillaikumar. R.	6A 3PIN TOP 1NO CHANGED		Abarna. M. - Operation Theatre	02/06/2023
Comp. Dt. : 14/06/2023 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2809	23060501	ORTHO OT	NEED TO CHECK FAN - SOUND PROBLEM AT STORE ROOM	Srinivasan. R.	WALLMOUNTING FAN 1NO SERVICE WORK & FAN REFIXING WORK PROBLEM SOLVED		Parthiban. R. - Operation Theatre	24/07/2023
Comp. Dt. : 17/06/2023 Status : Completed								
2810	23060637	SPECIALITY OT	NEED FAN CLEANING WORK AT ENTRANCE	Muthu. B.	WALLMOUNTING FAN 1NO CLEANING WORK PROBLEM SOLVED		Devi. V. - Operation Theatre	19/06/2023
Comp. Dt. : 20/06/2023 Status : Completed								
2811	23060690	SURGERY OT	NEED TO CHANGE TUBELIGHT FOR ENTRANCE [OLD SURGERY OT]	Vengadessaperumal. K.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Ramachandiran. M. - Operation Theatre	20/06/2023
Comp. Dt. : 23/06/2023 Status : Completed								
2812	23060877	SURGERY OT	NEED ADJUSTMENT WORK FOR STANDING FAN -	Thillaikumar. R.	PEDESTAL FAN 1NO SERVICE WORK PROBLEM SOLVED		Kuppan.E. - Operation Theatre	26/06/2023
2813	23060883	EMERGENCY OT NEAR CASUALTY	NEED TO CHANGE CEILING LIGHT FOR ENTRANCE	Manimaran. P.	LED LIGHT CHOKE WIRE LOOSE CONNECTION & WIRE RECONNECTION WORK PROBLEM SOLVED		Harine. S. - Operation Theatre	26/06/2023
Comp. Dt. : 26/06/2023 Status : Completed								
2814	23060939	Main OT	FAN NOT WORKING	Muthu. B.	PEDESTAL FAN 1NO SERVICE WORK PROBLEM SOLVED		Malathi. M. - Operation Theatre	30/06/2023
Dept Name : Ophthalmology - Electrical Maintenance Comp. Dt. : 16/05/2022 Status : Completed								
2815	22050532	Ophthalmology - OPD	NEED TO CHECK SWITCH BOARD - NOT WORKING	Muthu. B.	6A SOCKET 1NO CHANGED		Rajeswari.V. - Ophthalmology	17/05/2022
Comp. Dt. : 16/06/2022 Status : Completed								
2816	22060612	Ophthalmology - OPD	NEED TO CHANGE TUBELIGHT	Lakshmanan.V.	Tube light starter 1no changed.		Rajeswari.V. - Ophthalmology	17/06/2022
Comp. Dt. : 13/09/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2817	22090511	Ophthalmology - OPD	NEED TO CHANGE TUBELIGHT - ROOM NO 81	Lakshmanan.V.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Rajeswari.V. - Ophthalmology	14/09/2022
Dept Name : ORTHOPAEDICS - Electrical Maintenance Comp. Dt. : 28/06/2022 Status : Completed								
2818	22061000	Orthopaedics - OPD	NEED TO CHANGE TUBELIHT FOR ROOM NO 64	Vijayaraghavan.B.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Manjula. P. - ORTHOPAEDICS	28/06/2022
Comp. Dt. : 21/09/2022 Status : Completed								
2819	22090828	COMMON FEMALE RESTROOM NEAR ORTHO OPD	NEED TO CHANGE TUBELIGHT	Rajan. R.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Manjula. P. - ORTHOPAEDICS	23/09/2022
Comp. Dt. : 06/12/2022 Status : Completed								
2820	22120220	Orthopaedics - OPD	NEED TO CHANGE RESTROOM TUBELIGHT FOR ROOM NO 62	Srinivasan. R.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Manjula. P. - ORTHOPAEDICS	08/12/2022
Comp. Dt. : 21/01/2023 Status : Completed								
2821	23010773	COMMON FEMALE RESTROOM NEAR ORTHO OPD	NEED TO CHANGE TUBELIGHT	Manikandan. M.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 2NO'S CHANGED		Manjula. P. - ORTHOPAEDICS	23/01/2023
Comp. Dt. : 24/03/2023 Status : Completed								
2822	23031031	Orthopaedics - OPD	NEED TO CHANGE TUBELIGHT - ROOM NO 67	Manimaran. M.	Tube light starter 1no changed.		Manjula. P. - ORTHOPAEDICS	25/03/2023
Comp. Dt. : 25/04/2023 Status : Completed								
2823	23040831	COMMON MALE TOILET NEAR ORTHO OPD	NEED TO CHANGE TUBELIGHT 2 NOS	Muthu. B.	36W TUBE LIGHT 2NO'S CHANG & 40W STARTER 2NO'S CHANGED		Manjula. P. - ORTHOPAEDICS	26/04/2023
Dept Name : P.H.C. - Tiruvennainallur - Electrical Maintenance Comp. Dt. : 30/09/2022 Status : Completed								
2824	22091234	Thiruvannainallur	NEED TO CHECK U P S - PROBLEM IN BACKUP	Vaithianathan.M	NEW BATTERY ORDER GIVEN NEXT WEEK WORK COMPLETE		Kanagasabai. D. - P.H.C. - Tiruvannainallur	11/10/2022
Dept Name : PAEDIATRICS - Electrical Maintenance								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 30/05/2022								
Status : Completed								
2825	22051075	ENT OPD	NEED TO CHECK POWER - SYSTEM NOT WORKING [ELECTRICAL FAULT] AT AUDIOMETRY ROOM	Srinivasan. R.	MCB TRIP ON TO WORK PROBLEM SOLVED		Manju @ Brinda. V. - PAEDIATRICS	31/05/2022
Comp. Dt. : 30/01/2023								
Status : Completed								
2826	23011037	Paediatrics - OPD	NEED TO CHANGE TUBELIGHT FOR HOD ROOM	Manimaran. M.	TUBE LIGHT 40W STARTER 1NO CHANGED		Manju @ Brinda. V. - PAEDIATRICS	30/01/2023
Comp. Dt. : 03/03/2023								
Status : Completed								
2827	23030126	ENT OPD	NEED TO CHANGE TUBELIGHT FOR ROOOM NO 24	Manikandan. M.	TUBE LIGHT 40W STARTER 1NO CHANGED		Manju @ Brinda. V. - PAEDIATRICS	04/03/2023
Comp. Dt. : 04/03/2023								
Status : Completed								
2828	23030159	Paediatrics - OPD	NEED TO CHECK POWER - LIGHT & FAN NOT WORKING	Manikandan. M.	MCB TRIP ON TO WORK PROBLEM SOLVED		Manju @ Brinda. V. - PAEDIATRICS	04/03/2023
Comp. Dt. : 05/04/2023								
Status : Completed								
2829	23040167	Audiometry & Speech Therapy	NEED TO REFIX CEILING LIGHT & CABLES	Manimaran. M.	18W CFL fitting refixed.		Manju @ Brinda. V. - PAEDIATRICS	05/04/2023
Comp. Dt. : 08/05/2023								
Status : Completed								
2830	23050285	ENT OPD	NEED TO CHANGE TUBELIGHT FOR ENDOSCOPY ROOM	Rajan. R.	TUBE LIGHT 40W STARTER 1NO CHANGED		Manju @ Brinda. V. - PAEDIATRICS	09/05/2023
Comp. Dt. : 29/05/2023								
Status : Completed								
2831	23051116	Paediatrics - OPD	NEED TO CHANGE TUBELIGHT FOR NEBULIZER ROOM	Muthu. B.	TUBE LIGHT 40W STARTER 2NO'S CHANGED		Gayathri. D. - PAEDIATRICS	30/05/2023
Comp. Dt. : 10/06/2023								
Status : Completed								
2832	23060347	Audiometry & Speech Therapy	NEED TO CHANGE CEILING LIGHT FOR INSIDE AUDIOMETRY	Vijayaraghavan.B.	18W CFL 2no's changed.		Manju @ Brinda. V. - PAEDIATRICS	12/06/2023

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

Dept Name : Paediatrics Ward - Electrical Maintenance

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 17/05/2022								
Status : Completed								
2833	22050613	Paediatrics - Ward 309	HEATER NOT WORKING - PATIENT RESTROOM	Srinivasan. R.	WATER HEATER 1NO RESET WORK PROBLEM SOLVED		Maniyarasi. D. - Paediatrics Ward	18/05/2022
Comp. Dt. : 05/07/2022								
Status : Completed								
2834	22070162	Paediatrics Ward	NEED FAN CLEANING WORK - WARD NO 309 & 310	Dhakshinamoorthy. J	All fans are cleaned & 36W E.choke 1no changed.		Chitra. P. - Paediatrics Ward	07/07/2022
Comp. Dt. : 14/07/2022								
Status : Completed								
2835	22070532	Paediatrics Ward	NEED TO CHANGE TUBELIGHT FOR WARD NO 309 & 310 CARITOR	Vijayaraghavan.B.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Chitra. P. - Paediatrics Ward	14/07/2022
Comp. Dt. : 21/07/2022								
Status : Completed								
2836	22070803	Paediatrics - Ward 309	FAN NOT WORKING	Manikandan. M.	CEILING FAN COIL REWINDING & BEARING 2NO'S CHANG & FAN 1NO REFIXING WORK PROBLEM SOLVED		Naveena. N. - Paediatrics Ward	03/09/2022
Comp. Dt. : 29/08/2022								
Status : Completed								
2837	22080982	Paediatrics - Ward 310	NEED TO CHANGE TUBELIGHT FOR DEMO ROOM	Muthu. B.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Chitra. P. - Paediatrics Ward	30/08/2022
Comp. Dt. : 23/09/2022								
Status : Completed								
2838	22090935	Paediatrics - Ward 310	NEED TO CHECK FAN - NOT WORKING [3NOS]	Manikandan. M.	Y-PHASE SINGLE POLE MCB TRIP ON TO WORK PROBLEM SOLVED		Chitra. P. - Paediatrics Ward	24/09/2022
Comp. Dt. : 28/09/2022								
Status : Completed								
2839	22091108	Paediatrics - Ward 310	NEED TO CHANGE TUBELIGHT FOR PANTRY ROOM	Dhakshinamoorthy. J	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Chitra. P. - Paediatrics Ward	29/09/2022
Comp. Dt. : 14/10/2022								
Status : Completed								
2840	22100444	Paediatrics - Ward 310	NEED REPAIRING WORK FOR X RAY LOBBY	Muthu. B.	6A 3PIN TOP 1NO CHANGED		Chitra. P. - Paediatrics Ward	15/10/2022

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHAL KUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 28/10/2022 Status : Completed								
2841	22100882	Paediatrics - Ward 309	SYSTEM POWER SUPPLY PROBLEM	Sathishkumar. R.	MCB TRIP ON TO WORK PROBLEM SOLVED		Chitra. P. - Paediatrics Ward	29/10/2022
Comp. Dt. : 18/11/2022 Status : Completed								
2842	22110751	Paediatrics Ward	C P U NOT WORKING - WARD NO 307 [ELECTRICAL FAULT]	Rajan. R.	SWITCH BOARD CHEKING WORK PROBLEM SOLVED		Chitra. P. - Paediatrics Ward	19/11/2022
Comp. Dt. : 19/11/2022 Status : Completed								
2843	22110833	Paediatrics - Ward 308	IN ATTENDER ROOM- 1 TUBELIGHT NOT WORKING	Dhakshinamoorthy. J	36W TUBE LIGHT 1NO CHANGED		Chitra. P. - Paediatrics Ward	21/11/2022
Comp. Dt. : 22/11/2022 Status : Completed								
2844	22110899	Female Medical - Ward 307	NEED TO CHANGE TUBELIGHT FOR DUTY DOCTOR'S ROOM - REST ROOM [PAEDIATRICS WARD 307]	Vijayaraghavan.B.	20W TUBE LIGHT 1NO CHANGED		Chitra. P. - Paediatrics Ward	24/11/2022
Comp. Dt. : 24/11/2022 Status : Completed								
2845	22111053	Paediatrics - Ward 308	1 FAN NOT WORKING	Lakshmanan.V.	CEILING FAN CAPACITOR 2.5MFT 1NO CHANGED		Chitra. P. - Paediatrics Ward	25/11/2022
Comp. Dt. : 28/11/2022 Status : Completed								
2846	22111169	Paediatrics - Ward 308	ELECTRIC KETTLE NOT WORKING	Manimaran. P.	KETTLE ON/OFF SWITCH CHANG & CHEKING WORK PROBLEM SOLVED		Chitra. P. - Paediatrics Ward	31/01/2023
Comp. Dt. : 04/01/2023 Status : Completed								
2847	23010191	Paediatrics - Ward 308	REQUEST TO CHECK WHETHER ALL THE LIGHTS ARE WORKING PROPERLY	Lakshmanan.V.	SWITCH BOARD SCREW REFIXING WORK PROBLEM SOLVED		Chitra. P. - Paediatrics Ward	06/01/2023
2848	23010192	Paediatrics - Ward 308	1 TUBELIGHT NOT WORKING	Lakshmanan.V.	TUBE LIGHT 1NO CHANG & 36W CHOKE 1NO CHANGED		Chitra. P. - Paediatrics Ward	05/01/2023
Comp. Dt. : 10/01/2023 Status : Completed								
2849	23010421	Paediatrics - Ward 310	NEED NEW EXTENSION BOX FOR SYSTEM UPS CONNECTION	Manimaran. M.	MCB TRIP ON TO WORK PROBLEM SOLVED		Chitra. P. - Paediatrics Ward	11/01/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 20/01/2023		Status : Completed						
2850	23010695	Paediatrics - Ward 308	POWER PROBLEM - SYSTEM NOT WORKING NEED TO CHECK	Muthu. B.	MCB TRIP ON TO WORK PROBLEM SOLVED		Chitra. P. - Paediatrics Ward	21/01/2023
Comp. Dt. : 27/01/2023		Status : Completed						
2851	23010944	Paediatrics - Ward 308	NEED TO CHANGE TUBELIGHT FOR RESTROOM 1NOS & TREATMENT ROOM 2 NOS	Muthu. B.	36W TUBE LIGHT 3NO'S CHANG & 40W STARTER 1NO CHANG & 36W CHOKE 1NO CHANGED		Chitra. P. - Paediatrics Ward	27/01/2023
2852	23010960	Paediatrics - Ward 308	NEED TO FIX NEW TUBELIGHT SET FOR NURSE'S CABIN	Muthu. B.	36W TUBE LIGHT FITTING 1NO FIXING & LINE CONNECTION WORK PROBLEM SOLVED		Naveena. N. - Paediatrics Ward	27/01/2023
Comp. Dt. : 09/02/2023		Status : Completed						
2853	23020314	Paediatrics Ward	FAN SLOW	Srinivasan. R.	fan 1nos refixed		Chitra. P. - Paediatrics Ward	10/02/2023
Comp. Dt. : 10/02/2023		Status : Completed						
2854	23020373	DIALYSIS IN 2ND FLOOR	MOTOR SOUND PROBLEM	Lakshmanan.V.	DOL STARETR OFF SWITCH PROBLEM SERVICE WORK PROBLEM SOLVED		Parameswari. S. - Paediatrics Ward	15/02/2023
2855	23020396	Paediatrics - Ward 308	FAN NOT WORKING IN DUTY DOCTORS ROOM	Muthu. B.	capacitor 2.5mfd 1 nos changed		Chitra. P. - Paediatrics Ward	11/02/2023
2856	23020397	Paediatrics - Ward 308	FAN NOT WORKING IN DUTY DOCTORS ROOM	Muthu. B.	capacitor 2.5 mfd 1nos changed		Chitra. P. - Paediatrics Ward	11/02/2023
Comp. Dt. : 14/02/2023		Status : Completed						
2857	23020556	Paediatrics - Ward 308	NEED TO REFIX SWITCH FOR SWITCH BOARD	Vengadessaperumal. K.	A/C 25A SWITCH 1NO CHANGED		Naveena. N. - Paediatrics Ward	16/02/2023
Comp. Dt. : 07/03/2023		Status : Completed						
2858	23030255	Female Surgery - Ward 206	NEED TO CHANGE TUBELIGHT	Vijayaraghavan.B.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Rajeswari. P. - Paediatrics Ward	08/03/2023
2859	23030281	Paediatrics Ward	NEED FAN CLEANING WORK FOR WARD NO 308 & 309	Manikandan. M.	ALL CEILING FAN CLEANING WORK PROBLEM SOLVED		Chitra. P. - Paediatrics Ward	08/03/2023
2860	23030289	Paediatrics Ward	NEED TO REFIX SWITCH BOX - WARD NO 307	Manikandan. M.	SWITCH BOARD SCREW REFIXING WORK PROBLEM SOLVED		Chitra. P. - Paediatrics Ward	08/03/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 08/03/2023								
Status : Completed								
2861	23030336	Paediatrics - Ward 308	KETTLE NOT WORKING	Rajan. R.	Wire problem - solved.		Chitra. P. - Paediatrics Ward	10/03/2023
Comp. Dt. : 21/03/2023								
Status : Completed								
2862	23030875	Female Medical - Ward 307	NEED TO CHANGE RESTROOM TUBELIGHT - PAEDIATRICS WARD 307	Lakshmanan.V.	TUBE LIGHT 40W STARTER 1NO CHANGED		Sivaranjani. S. - Male Medical Ward	22/03/2023
Comp. Dt. : 04/04/2023								
Status : Completed								
2863	23040091	Paediatrics Ward	NEED TO CHANGE TUBELIGHT [4NOS] FOR WARD & FOR CARITOR 1 NO	Ganesan. S.,Manikandan. M.,Manimaran. P.	36W tube light 2no's & starter 4no's changed.		Chitra. P. - Paediatrics Ward	05/04/2023
Comp. Dt. : 19/04/2023								
Status : Completed								
2864	23040576	Paediatrics - Ward 308	NEED TO CHECK TUBELIGHT & SWITCH BOX - NOT WORKING	Manikandan. M.	36W TUBE LIGHT 1NO CHANG & SWITCH BOARD MCB TRIP ON TO WORK PROBLEM SOLVED		Kayalvizhi. G. - Paediatrics Ward	20/04/2023
Comp. Dt. : 25/04/2023								
Status : Completed								
2865	23040800	DIALYSIS IN 2ND FLOOR	T.V REMOTE NOT WORKING ROOM NO 1	Manikandan. M.	TV REMOTE 1.5V BATTERY 2NO'S CHANGED		Parameswari. S. - Paediatrics Ward	26/04/2023
2866	23040807	Paediatrics - Ward 308	SWITCH BOARD NOT WORKING	Lakshmanan.V.	6A SOCKET 1NO CHANG & 6A SWITCH 1NO CHANGED		Sangeetha. E. - Paediatrics Ward	26/04/2023
Comp. Dt. : 12/05/2023								
Status : Completed								
2867	23050484	Paediatrics - Ward 308	DUE TO CHILDREN PLAYING AND TOUCH THE SWITCH BOARD SO THAT NEED TO CLOSING PLUG POINTS	Dhakshinamoorthy. J	SWITCH BOARD SCREW REFIXNG WORK & MCB TRIP ON TO WORK PROBLEM SOLVED		Maniyarasi. D. - Paediatrics Ward	13/05/2023
Comp. Dt. : 20/05/2023								
Status : Completed								
2868	23050834	Paediatrics Ward	NEED TO CHANGE TUBELIGHT 6 NOS FOR WARD NO 307 & 308 + RESTROOM TUBELIGHT SMALL SIZE [2 NOS] FOR	Manikandan. M.	36W TUBE LIGHT 2NO'S CHANG & 36W CHOKE 2NO'S CHANG & 40W STARTER 1NO CHANGED		Kayalvizhi. G. - Paediatrics Ward	22/05/2023

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2869	23050835	Paediatrics Ward	NEED TO CHECK EMERGENCY LIGHT - NOT WORKING AT WARD NO 307 & 308	Manikandan. M.	36W TUBE LIGHT 2NO'S CHANG & 36W CHOKE 3NO'S CHANG & 40W STARTER 1NO CHANGED		Kayalvizhi. G. - Paediatrics Ward	22/05/2023
Comp. Dt. : 02/06/2023 Status : Completed								
2870	23060070	Paediatrics - Ward 308	KETTLE NOT WORKING	Rajan. R.	KETTLE WIRE CUT RECONNECTION WORK PROBLEM SOLVED		Chitra. P. - Paediatrics Ward	09/06/2023
Comp. Dt. : 03/06/2023 Status : Completed								
2871	23060087	Paediatrics - Ward 308	FAN - PROBLEM	Muthu. B.	CEILING FAN 1NO REWINDING WORK & BEARING 2NO'S CHANG & FAN REFIXING WORK PROBLEM SOLVED		Chitra. P. - Paediatrics Ward	09/06/2023
Comp. Dt. : 22/06/2023 Status : Completed								
2872	23060808	Female Medical - Ward 307	NEED TO PROVIDE A NEW TUBELIGHT SET FOR TREATMENT ROOM [PAEDIATRIC WARD 307]	Muthu. B.	NEW TUBE LIGHT FITTING 1NO FIXING WORK PROBLEM SOLVED		Maniyarasi. D. - Paediatrics Ward	27/06/2023
Dept Name : PATHOLOGY - Electrical Maintenance Comp. Dt. : 04/07/2022 Status : Completed								
2873	22070073	FNAC ROOM	NEED TO CHANGE TUBELIGHT - NOT WORKING	Vijayaraghavan.B.	36W TUBE LIGHT SET 1NO REFIXING WORK PROBLEM SOLVED		Muthamil.K. - PATHOLOGY	04/07/2022
Comp. Dt. : 22/09/2022 Status : Completed								
2874	22090862	FNAC ROOM	NEED CONNECTION WORK FOR UPS & EXHAUST FAN - ROOM NO 46	Rajan. R.	12" EXHAUST FAN 1NO REFIXING WORK PROBLEM SOLVED		Vijayalakshmi. R. - PATHOLOGY	23/09/2022
Comp. Dt. : 01/02/2023 Status : Completed								
2875	23020001	FNAC ROOM	NEED TO CHANGE TUBELIGHT ROOM NO 46	Lakshmanan.V.	TUBE LIGHT 40W STARTER 1NO CHANGED		Muthamil.K. - PATHOLOGY	02/02/2023
Comp. Dt. : 19/05/2023 Status : Completed								
2876	23050795	Clinical Pathology	NEED TO CHANGE TUBELIGHT	Dhakshinamoorthy. J	36W TUBE LIGHT 1NO CHANG & 36W CHOKE 1NO CHANGED		Muthamil.K. - PATHOLOGY	20/05/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Dept Name : Pharmacy - Electrical Maintenance Comp. Dt. : 04/07/2022 Status : Completed								
2877	22070110	Free Pharmacy	NEED TO CHANGE TUBELIGHT	Suresh. V.	TUBE LIGHT 40W STARTER 1NO CHANGED		Thilagavathi. T. - Pharmacy	05/07/2022
Comp. Dt. : 14/09/2022 Status : Completed								
2878	22090531	Pay Pharmacy	NEED TO CHANGE SWITCH FOR MIKE - NOT WORKING	Manikandan. M.	MIKE CHEKING WORK NO PROBLEM		Silambuselvan. P. - Pharmacy	15/09/2022
Comp. Dt. : 27/09/2022 Status : Completed								
2879	22091061	Free Pharmacy	FAN SLOW PROBLEM & DUE TO DUST NEED SERVICE	Manikandan. M.	CEILING FAN CAPACITOR 2.5MFT 1NO CHANGED		Thilagavathi. T. - Pharmacy	28/09/2022
Comp. Dt. : 17/11/2022 Status : Completed								
2880	22110741	COMMON TOILET NEAR OPHTAL OPD	FEMALE TAFF TOILET-2ND ROOM-1 TUBELIGHT NOT WORKING	Dhakshinamoorthy. J	36W TUBE LIGHT 2NO'S CHANG & 40W STARTER 1NO CHANG & 36W CHOKET 1NO CHANGED		Thilagavathi. T. - Pharmacy	18/11/2022
Comp. Dt. : 09/12/2022 Status : Completed								
2881	22120438	Free Pharmacy	TUBELIGHT NOT WORKING	Manimaran. P.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Jhansirani. T. - Pharmacy	10/12/2022
Comp. Dt. : 19/12/2022 Status : Completed								
2882	22120877	Pay Pharmacy	POWER SUPPLY PROBLEM	Vengadessaperumal. K.	30KVA UPS TRIP ON TO WORK PROBLEM SOLVED		Rameshkumar. R. - Pharmacy	20/12/2022
Comp. Dt. : 05/01/2023 Status : Completed								
2883	23010197	MEDICAL STORE IN BASEMENT	NEED TO CHANGE TUBELIGHT NO.1	Muthu. B.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Deepa. K. - Pharmacy	06/01/2023
Comp. Dt. : 10/01/2023 Status : Completed								
2884	23010377	Pay Pharmacy	6 NO'S LED LIGHT NEED TO CHANGE	Rajan. R.	9W LED LIGHT 6NO'S CHANG & 36W CFL 4PIN LIGHT 3NO'S CHANG & 36W CHOKE 2NO'S CHANGED		Sivabalan. S. - Pharmacy	11/01/2023

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 03/02/2023 Status : Completed								
2885	23020085	Pay Pharmacy	NEED TO CHECK FRIDGE BURN SMELL - NEED URGENT SERVICE	Rajan. R.	Socket problem - solved.		Silambuselvan. P. - Pharmacy	03/02/2023
2886	23020093	Pay Pharmacy	NEED TO CHANGE 3 PIN TOP 2NOS FOR FRIDGE SWITCH BOARD - NEED URGENT SERVICE	Rajan. R.	Socket 16A 1no & Switch 6A 1no changed.		Silambuselvan. P. - Pharmacy	03/02/2023
Comp. Dt. : 18/02/2023 Status : Completed								
2887	23020721	Pay Pharmacy	TRIP PROBLEM	Muthu. B.	SWITCH BOARD WIRE CUT RECONNECTION WORK PROBLEM SOLVED		Silambuselvan. P. - Pharmacy	18/02/2023
Comp. Dt. : 06/03/2023 Status : Completed								
2888	23030199	Pay Pharmacy	NEED TO CHANGE TUBELIGHT 6 NOS & LED LIGHT 1 NO	Damodharan. V.	36W TUBE LIGHT 3NO'S CHANG & 36W CHOKE 1NO CHANG & 40W STARTER 1NO CHANG & 9W LED LIGHT 2NO'S CHANGE		Silambuselvan. P. - Pharmacy	07/03/2023
Comp. Dt. : 16/03/2023 Status : Completed								
2889	23030640	Pay Pharmacy	MIKE SOUND PROBLEM	Rajan. R.	MIKE CHEKING WORK NO PROBLEM SOLVED		Silambuselvan. P. - Pharmacy	21/03/2023
Comp. Dt. : 21/03/2023 Status : Completed								
2890	23030888	Pay Pharmacy	LED BULB NOT WORKING	Rajan. R.,Senthil Murugan. A.,Manimaran. P.	36W CFL 2no's, 36W tube light 2no's, 9W LED lamp 1no changed.		Rameshkumar. R. - Pharmacy	23/03/2023
Comp. Dt. : 03/04/2023 Status : Completed								
2891	23040064	Pay Pharmacy	TRIP PROBLEM	Dhakshinamoorthy. J	Power checked - ok.		Silambuselvan. P. - Pharmacy	03/04/2023
Comp. Dt. : 05/04/2023 Status : Completed								
2892	23040168	Free Pharmacy	NEED TO CHANGE TUBELIGHT	Vijayaraghavan.B.	Tube light starter 1no changed.		Thilagavathi. T. - Pharmacy	05/04/2023
Comp. Dt. : 20/04/2023 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2893	23040623	Pay Pharmacy	NEED TO CHANGE LED LIGHT FOR INSIDE PHARMACY	Vijayaraghavan.B.	9W LED LIGHT 1NO CHANGED		Silambuselvan. P. - Pharmacy	20/04/2023
Comp. Dt. : 03/05/2023 Status : Completed								
2894	23050076	Free Pharmacy	NEED TO PROVIDE EXTN BOX	Azhagappan. J.	EXECTION BOX LINE CHEKING WORK & METERIL'S PURCHASE WORK		Thilagavathi. T. - Pharmacy	11/05/2023
Comp. Dt. : 03/06/2023 Status : Completed								
2895	23060092	Free Pharmacy	FAN SLOW PROBLEM	Muthu. B.	CEILING FAN CAPACITOR 2.5MFT 1NO CHANGED		Thilagavathi. T. - Pharmacy	05/06/2023
Comp. Dt. : 10/06/2023 Status : Completed								
2896	23060350	MEDICAL STORE IN BASEMENT	NEED TO CHANGE CEILING LIGHT FOR CARITOR	Rajan. R.	11W CFL LIGHT 1NO CHANGED		Sujatha.S. - Pharmacy	10/06/2023
Comp. Dt. : 14/06/2023 Status : Completed								
2897	23060496	Free Pharmacy	NEED TO CHANGE TUBELIGHT	Manimaran. M.	36W TUBE LIGHT 1NO CHANGED		Thilagavathi. T. - Pharmacy	16/06/2023
Comp. Dt. : 30/06/2023 Status : Completed								
2898	23061109	Pay Pharmacy	NEED TO CHANGE TUBELIGHT FOR PHARMACY ENTRANCE	Thillaikumar. R.	36W TUBE LIGHT 2NO'S CHANG & 40W STARTER 1NO CHANG & 36W CHOKE 1NO CHANGED		Silambuselvan. P. - Pharmacy	01/07/2023
Dept Name : Physical Education - Electrical Maintenance Comp. Dt. : 07/06/2022 Status : Completed								
2899	22060276	BASKET BALL GROUND	FOCUS LIGHT NOT WORKING	Muthu. B.	INCOMMING WIRE CUT RECONNECTION WORK PROBLEM SOLVED		Rajaguru. S. - Physical Education	08/06/2022
Comp. Dt. : 01/03/2023 Status : Completed								
2900	23030049	Boys hostel	NEED TO CHANGE RESTROOM LED LIGHT & TUBELIGHT FOR PHYSICAL DIRECTOR ROOM	Dhakshinamoorthy. J	9W LED LGITH 1NO CHANGED		Vijayakumar. M. - Physical Education	02/03/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2901	23030050	PLAY GROUND COURT NEAR BOYS HOSTEL	NEED TO CHECK FOCUS LIGHT - NOT WORKING AT 3 COURTS [BADMITTON , BASKET BALL COURT,	Vijayaraghavan.B.	100W LED FOCUS LIGHT CHOKE 50W 5NO'S CHANGED		Vijayakumar. M. - Physical Education	28/03/2023
Dept Name : Physiotherapy - Electrical Maintenance Comp. Dt. : 09/05/2022 Status : Completed								
2902	22050278	Physiotherapy	NEED TO CHANGE TUBELIGHT FOR PHYSIO CARITOR	Srinivasan. R.	36W TUBE LIGHT 1NO CHANGED		Ezhilan.K. - Physiotherapy	12/05/2022
Comp. Dt. : 06/06/2022 Status : Completed								
2903	22060213	Physiotherapy	WATER BLOCK - MOTOR NOT WORKING	Lakshmanan.V.	MOTOR CHEKING WORK RUNNING CONDUCTION PROBLEM SOLVED		Shyamala.P. - Physiotherapy	07/06/2022
Comp. Dt. : 04/07/2022 Status : Completed								
2904	22070076	Physiotherapy	NEED TO CHANGE TUBELIGHT FOR CARITOR	Vijayaraghavan.B.	36W TUBE LIGHT SET 1NO REFIXING WORK PROBLEM SOLVED		Ezhilan.K. - Physiotherapy	04/07/2022
Comp. Dt. : 24/08/2022 Status : Completed								
2905	22080797	Physiotherapy	NEED TO REMOVE & REFIX EXHAUST FAN	Lakshmanan.V.	12" EXHAUST FAN 1NO REMOVING WORK & FAN REFIXING WORK PROBLEM SOLVED		Ezhilan.K. - Physiotherapy	24/08/2022
2906	22080808	Physiotherapy	NEED TO FIX FAN REGULATOR	Lakshmanan.V.	CEILING FAN REGULATOR 1NO CHANGED		Shyamala.P. - Physiotherapy	29/08/2022
Comp. Dt. : 19/09/2022 Status : Completed								
2907	22090745	Physiotherapy	NEED TO CHANGE TUBELIGHT FOR CARITOR	Muthu. B.	22W LED TUBE LIGHT 1NO CHANGED		Ezhilan.K. - Physiotherapy	20/09/2022
Comp. Dt. : 22/09/2022 Status : Completed								
2908	22090878	Physiotherapy	NEED TO CHANGE TUBELIGHT [2NOS] FOR CARITOR	Rajan. R.	36W TUBE LIGHT 1NO CHANG & 36W CHOKE 1NO CHANGED		Shyamala.P. - Physiotherapy	23/09/2022
Comp. Dt. : 26/09/2022 Status : Completed								
2909	22091031	Physiotherapy	EXHAUST FAN NOT WORKING	Lakshmanan.V.	EXHAUST FAN CHEKING WORK PROBLEM SOLVED		Ezhilan.K. - Physiotherapy	29/09/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 30/09/2022								
Status : Completed								
2910	22091187	Physiotherapy	EXHAUST FAN NOT WORKING	Rajan. R.	EXHAUST FAN WIRE LOOSE RECONNECTION WORK PROBLEM SOLVED		Ezhilan.K. - Physiotherapy	06/10/2022
Comp. Dt. : 19/10/2022								
Status : Completed								
2911	22100629	Physiotherapy	ONE TUBELIGHT NOT WORKING	Manimaran. M.	36W TUBE LIGHT 1NO CHANGED		Shyamala.P. - Physiotherapy	21/10/2022
2912	22100630	Physiotherapy	MACHINE CIRCUIT PROBLEM	Manimaran. M.	SWITCH BOARD WIRE LOOSE SCREW REFIXING WORK PROBLEM SOLVED		Shyamala.P. - Physiotherapy	21/10/2022
Comp. Dt. : 24/11/2022								
Status : Completed								
2913	22111032	Physiotherapy	EXHAUST FAN NOT WORKING.	Muthu. B.	EXHAUST FAN 1NO SERVICE WORK PROBLEM SOLVED		Ezhilan.K. - Physiotherapy	25/11/2022
Comp. Dt. : 19/01/2023								
Status : Completed								
2914	23010648	Physiotherapy	NEED TO CHANGE TUBELIGHT	Damodharan. V.	36W TUBE LIGHT 1NO CHANGED		Ezhilan.K. - Physiotherapy	19/01/2023
Comp. Dt. : 27/03/2023								
Status : Completed								
2915	23031141	Physiotherapy	NEED TO CHECK FAN - NOT WORKING	Babu. D.	Fan capaciotor 2.5mfd 1no changed.		Ezhilan.K. - Physiotherapy	29/03/2023
Comp. Dt. : 17/04/2023								
Status : Completed								
2916	23040487	Physiotherapy	NEED TO CHANGE PLUGPOINT [NOT WORKING] FOR INSTRUMENT	Muthu. B.	16A 3PIN TOP 1NO CHANG & 16A SOCKET 1NO CHANGED		Ezhilan.K. - Physiotherapy	17/04/2023
Dept Name : PICU & NICU - Electrical Maintenance								
Comp. Dt. : 04/05/2022								
Status : Completed								
2917	22050064	NICU	NEED TO CHANGE TUBELIGHT	Dhakshinamoorthy. J	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Sameetha. S. - PICU & NICU	05/05/2022
Comp. Dt. : 11/05/2022								
Status : Completed								
2918	22050396	PICU	TUBE LIGHT NOT WORKING	Dhakshinamoorthy. J	36W CHOKE 1NO CHANG & 36W TUBE LIGHT 1NO CHANGED		Revathy. I. - PICU & NICU	13/05/2022

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 16/05/2022 Status : Completed								
2919	22050558	NICU	NEED TO CHANGE TUBELIGHT [2NOS]	Manimaran. P.	36W TUBE LIGHT 2NO'S CHANG & 40W STARTER 2NO'S CHANGED		Arya. K. - PICU & NICU	17/05/2022
Comp. Dt. : 19/05/2022 Status : Completed								
2920	22050692	NICU	NEED TO CHANGE TUBELIGHT	Srinivasan. R.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Parameswari. P. - PICU & NICU	20/05/2022
2921	22050699	PICU	NEED FAN SERVICE	Srinivasan. R.	WALLMOUNTING 1NO CLEANING WORK PROBLEM SOLVED		Revathy. I. - PICU & NICU	20/05/2022
Comp. Dt. : 15/06/2022 Status : Completed								
2922	22060536	PICU	NEED TO CHANGE TUBELIGHT	Lakshmanan.V.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Revathy. I. - PICU & NICU	16/06/2022
Comp. Dt. : 16/06/2022 Status : Completed								
2923	22060600	PICU	NEED TO CHANGE TUBELIGHT	Lakshmanan.V.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Vijayalakshmi. C. - PICU & NICU	16/06/2022
Comp. Dt. : 05/07/2022 Status : Completed								
2924	22070170	NICU	SWITCH BOARD NOT WORKING	Lakshmanan.V.	MCB Trip - Trip ON.		Gobiya. G. - PICU & NICU	07/07/2022
Comp. Dt. : 06/07/2022 Status : Completed								
2925	22070182	PICU	NEED TO CHANGE TUBELIGHT FOR ENTRANCE	Manimaran. P.	Tube light starter 1no changed.		Vijayalakshmi. C. - PICU & NICU	07/07/2022
Comp. Dt. : 12/07/2022 Status : Completed								
2926	22070480	PICU	NEED TO CHANGE TUBE LIGHT	Muthu. B.	36W TUBE LIGHT 1NO CHANGED		Poovathal. K. - PICU & NICU	13/07/2022
Comp. Dt. : 13/08/2022 Status : Completed								
2927	22080468	PICU	NEED FAN GENERAL SERVICE & CLEANING WORK	Vijayaraghavan.B.	Fan serviced and cleaned.		Poovathal. K. - PICU & NICU	17/08/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 18/08/2022 Status : Completed								
2928	22080575	NICU	REQUEST TO CLEAN FAN DUST	Lakshmanan.V.	CEILING FAN WALLMOUNTING FAN CLEANING WORK PROBLEM SOLVED		Sasina. K. - PICU & NICU	20/08/2022
Comp. Dt. : 02/09/2022 Status : Completed								
2929	22090067	PICU	FRIDGE NOT WORKING	Muthu. B.	MCB TRIP ON TO WORK PROBLEM SOLVED		Thirushayeni. A. - PICU & NICU	03/09/2022
Comp. Dt. : 09/09/2022 Status : Completed								
2930	22090347	NICU	NEED TO CHANGE TUBELIGHT	Lakshmanan.V.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Sasina. K. - PICU & NICU	10/09/2022
Comp. Dt. : 15/09/2022 Status : Completed								
2931	22090591	NICU	TUBELIGHT NOT WORKING	Manimaran. P.	TUBE LIGHT WIRE LOOSE RECONNECTION WORK PROBLEM SOLVED		Gobiya. G. - PICU & NICU	16/09/2022
Comp. Dt. : 21/09/2022 Status : Completed								
2932	22090853	NICU	NEED TO CHECK PLUG POINT NOT WORKING	Manikandan. M.	6A SWITCH 1NO CHANGED		Parameswari. P. - PICU & NICU	22/09/2022
Comp. Dt. : 11/10/2022 Status : Completed								
2933	22100283	PICU	NEED TO CHANGE TUBELIGHT	Lakshmanan.V.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Revathy. I. - PICU & NICU	12/10/2022
Comp. Dt. : 19/10/2022 Status : Completed								
2934	22100637	PICU	TUBE LIGHT NOT WORKING	Lakshmanan.V.	TUBE LIGHT 40W STARTER 1NO CHANGED		Poovathal. K. - PICU & NICU	20/10/2022
Comp. Dt. : 25/10/2022 Status : Completed								
2935	22100784	NICU	TUBELIGHT NOT WORKING	Lakshmanan.V.	TUBE LIGHT 40W STARTER 1NO CHANGED		Parameswari. P. - PICU & NICU	26/10/2022
Comp. Dt. : 04/11/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2936	22110139	NEW NICU & PICU-2ND FLOOR	1 NO.TUBELIGHT AND 1 NO.EXHAUST FAN NOT WORKING	Lakshmanan.V.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Poovathal. K. - PICU & NICU	05/11/2022
	Comp. Dt. : 08/11/2022							
	Status : Completed							
2937	22110292	PICU	SWITCH BOX POWER NOT SUPPLY	Manimaran. P.	MCB TRIP ON TO WORK PROBLEM SOLVED		Poovathal. K. - PICU & NICU	10/11/2022
	Comp. Dt. : 01/12/2022							
	Status : Completed							
2938	22120007	NICU	NEED TO CHANGE TUBELIGHT [6NOS]	Dhakshinamoorthy. J	MCB TRIP ON TO WORK PROBLEM SOLVED		Parameswari. P. - PICU & NICU	02/12/2022
	Comp. Dt. : 03/01/2023							
	Status : Completed							
2939	23010074	NICU	HAND DRYER MACHINE NOT WORKING IN REST ROOM	Muthu. B.	2PIN TOP WIRE LOOSE CHEKING WORK PREOBLEM SOLVED		Parameswari. P. - PICU & NICU	03/01/2023
2940	23010082	NEW NICU & PICU-2ND FLOOR	WATER HEATER NOT WORKING IN PATINET REST ROOM	Thillaikumar. R.,Manikandan. M.,Muthu. B.	WATER HEATER RESET WORK PROBLEM SOLVED		Poovathal. K. - PICU & NICU	03/01/2023
	Comp. Dt. : 11/01/2023							
	Status : Completed							
2941	23010449	NEW NICU & PICU-2ND FLOOR	IN NICU-NO POWER SUPPLY IN SWITCH BOARD	Vijayaraghavan.B.	MCB TRIP ON TO WORK PROBLEM SOLVED		Parameswari. P. - PICU & NICU	12/01/2023
	Comp. Dt. : 23/02/2023							
	Status : Completed							
2942	23020913	PICU	KETTLE NOT WORKING	Vengadessaperumal. K.	Need To Wier And Kittle Top Service Problem OK		Umamaheswari. P. - PICU & NICU	24/02/2023
	Comp. Dt. : 27/02/2023							
	Status : Completed							
2943	23021032	DENTAL OPD -2ND FLOOR	NEED TO CHECK POWER	Muthu. B.	MCB TRIP ON TO WORK PROBLEM SOLVED		Ushamala. I. - PICU & NICU	28/02/2023
	Comp. Dt. : 25/03/2023							
	Status : Completed							
2944	23031065	LADIES HOSTEL MESS	NEED TO CHECK MIXIE - NOT WORKING	Dhakshinamoorthy. J	CORBEN PUSH PROBLEM. New carbon brush changed.		Revathy. I. - PICU & NICU	05/04/2023
	Comp. Dt. : 24/04/2023							
	Status : Completed							
2945	23040732	PICU	NEED TO CHECK PLUG POINT - NOT WORKING	Rajan. R.	MCB TRIP ON TO WORK PROBLEM SOLVED		Umamaheswari. P. - PICU & NICU	24/04/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2946	23040764	NICU	NEED TO CHECK SWITCH BOX - SUPPLY PROBLEM NOT WORKING	Muthu. B.	SWITCH BOARD SCREW REFIXING WORK PROBLEM SOLVED		Parameswari. P. - PICU & NICU	25/04/2023
Comp. Dt. : 08/05/2023 Status : Completed								
2947	23050275	Ladies hostel Phase-I	HEATER NOT WORKING AT IV FLOOR	Manimaran. P.	WATER HEATER 1NO THERACUT 1NO CHANG & HEATER CHEKING WORK PROBLEM SOLVED		Revathy. I. - PICU & NICU	12/05/2023
Comp. Dt. : 13/05/2023 Status : Completed								
2948	23050525	NICU	DUE TO FUMIGATION PURPOSE NEED CLEANING WORK	Damodharan. V.	Cleaning work done.		Sarumathi. A. - PICU & NICU	15/05/2023
Comp. Dt. : 16/05/2023 Status : Completed								
2949	23050654	Ladies hostel Phase-II	NEED TO CHANGE TUBELIGHT FOR ROOM NO 4	Dhakshinamoorthy. J	36WTUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Revathy. I. - PICU & NICU	18/05/2023
Comp. Dt. : 29/05/2023 Status : Completed								
2950	23051162	PICU	FAN NOT WORKING AT DOCTOR'S ROOM	Thillaikumar. R.	6A SWITCH 1NO CHANGED		Divya. M. - PICU & NICU	30/05/2023
Comp. Dt. : 16/06/2023 Status : Completed								
2951	23060577	PICU	HAND DRYER CLEANING WORK	Muthu. B.	HAND DRYER CLEANING WORK PROBLEM SOLVED		Sarumathi. A. - PICU & NICU	17/06/2023
Comp. Dt. : 23/06/2023 Status : Completed								
2952	23060871	PICU	U P S POWER PROBLEM - NEED TO CHECK	Vengadessaperumal. K.	MCB TRIP ON TO WORK PROBLEM SOLVED		Umamaheswari. P. - PICU & NICU	24/06/2023
Dept Name : POW & SICU - Electrical Maintenance Comp. Dt. : 02/06/2022 Status : Completed								
2953	22060089	SICU	NEED TO CHANGE TUBELIGHT FOR NUUSR'S DRESS CHANGING ROOM	Srinivasan. R.	TUBE LIGHT 40W STARTER 1NO CHANGED		Gunavathi. G. - POW & SICU	02/06/2022
Comp. Dt. : 07/06/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2954	22060253	POW & SICU	NEED TO CHECK FIRE EXTINGUISHER - DISPLAY EXPIRY DATE	Babu. D.	FIRE EXTINGUISHER REPLASE NEW CYLENDER		Jamuna. K - POW & SICU	07/06/2022
		Comp. Dt. : 13/06/2022 Status : Completed						
2955	22060450	POW & SICU	NEED TO CHECK CALLING BELL - NOT WORKING	Manimaran. P.	2M SURFACE SCREW REFIXING WORK PROBLEM SOLVED		Jamuna. K - POW & SICU	05/07/2022
		Comp. Dt. : 20/06/2022 Status : Completed						
2956	22060716	POW & SICU	STERILIZER NOT WORKING & CHANGE TUBELIGHT FOR DOCTOR'S ROOM	Muthu. B.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Jamuna. K - POW & SICU	21/06/2022
2957	22060732	POW & SICU	EARTH PROBLEM IN REST ROOM - NEED URGENT SERVICE	Vengadessaperumal. K.	WATER HEATER 1NO CHEKING WORK NO COMPLAINT		Pragadeesh. V. - POW & SICU	21/06/2022
		Comp. Dt. : 28/06/2022 Status : Completed						
2958	22060996	SICU	NEED TO CHECK CALLING BELL 2NOS & TUBELIGHT NOT WORKING	Vijayaraghavan.B.	36W TUBE LIGHT 1NO CHANG & 36W CHOKE 1NO CHANG & 40W STARTER 1NO CHANGED		Sathish Kumar. R. - POW & SICU	28/06/2022
		Comp. Dt. : 08/07/2022 Status : Completed						
2959	22070331	SEPTIC ROOM(NEW) -IN 3RD FLOOR	NEED FAN CLENING WORK - ALL FANS	Vijayaraghavan.B.	ALL CEILING FAN CLEANING WORK PROBLEM SOLVED		Kausalya. V. - POW & SICU	11/07/2022
2960	22070351	POW & SICU	NEED FAN CLEANING - ALL ROOM FANS	Dhakshinamoorthy. J	ALL CEILING FAN CLEANING WORK PROBLEM SOLVED		Jamuna. K - POW & SICU	11/07/2022
		Comp. Dt. : 14/07/2022 Status : Completed						
2961	22070554	POW & SICU	CALLING BELL BROKEN	Vengadessaperumal. K.	2M PLATE 1NO,2M SURFACE BOX 1NO CHANGED		Valarmathy. K. - POW & SICU	14/07/2022
		Comp. Dt. : 19/07/2022 Status : Completed						
2962	22070702	SICU	NEED TO REFIX PLUG POINT FOR OPHTHAL ROOM	Srinivasan. R.	SWITCH BOARD SCREW REFIXING WORK PROBLEM SOLVED		Lakshmi. R. - POW & SICU	21/07/2022
		Comp. Dt. : 20/07/2022 Status : Completed						


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2963	22070751	POW & SICU	NEED TO CHANGE CEILING LIGHT	Muthu. B.	9W LED LIGHT 3NO'S CHANGED		Valarmathy. K. - POW & SICU	21/07/2022
	Comp. Dt. : 21/07/2022							
	Status : Completed							
2964	22070778	POW & SICU	NEED TO REFIX CEILING LIGHT & COLOUR [KUNDU] BULB	Muthu. B.	9W LED LIGHT 2NO'S CHANGED		Jamuna. K - POW & SICU	21/07/2022
	Comp. Dt. : 23/07/2022							
	Status : Completed							
2965	22070856	POW & SICU	HEATER NOT WORKING	Muthu. B.	16A SWITCH 1NO CHANG & ALL HEATER CHEKING WORK PROBLEM SOLVED		Dhivagar. K. - POW & SICU	25/07/2022
	Comp. Dt. : 01/08/2022							
	Status : Completed							
2966	22080035	POW & SICU	NEED TO CHANGE REST ROOM TUBELIGHT	Dhakshinamoorthy. J	36W TUBE LIGHT 1NO CHANGED		Gayathri. K. - POW & SICU	02/08/2022
	Comp. Dt. : 23/08/2022							
	Status : Completed							
2967	22080774	POW & SICU	NEED TO CHANGE TUBELIGHT 2NOS	Muthu. B.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 2NO'S CHANGED		Jamuna. K - POW & SICU	24/08/2022
	Comp. Dt. : 29/08/2022							
	Status : Completed							
2968	22080959	POW & SICU	PROBLEM IN BEDSIDE CALLING BELL SYSTEM - NEED TO CHECK	Muthu. B.	SWITCH BOARD SCREW REFIXING WORK & TUBE LIGHT 40W STARTER 1NO CHANGED		Jamuna. K - POW & SICU	29/08/2022
	Comp. Dt. : 30/08/2022							
	Status : Completed							
2969	22081032	POW & SICU	NEED TO CHANGE FAN CONDENSOR	Manikandan. M.	CEILING FAN CAPACITOR 2.5MFT 1NO CHANGED		Valarmathy. K. - POW & SICU	01/09/2022
	Comp. Dt. : 08/09/2022							
	Status : Completed							
2970	22090308	POW & SICU	NEED TO CHANGE TUBELIGHT FOR SEPTIC ROOM	Vijayaraghavan.B.	36W TUBE LIGHT 1NO CHANGED		Jamuna. K - POW & SICU	09/09/2022
	Comp. Dt. : 12/09/2022							
	Status : Completed							
2971	22090439	POW & SICU	NEED TO CHANGE TUBELIGHT 2NOS & CEILING LIGHT 1 NO	Rajan. R.	9W LED LIGHT 2NO'S CHANGED		Jamuna. K - POW & SICU	13/09/2022

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 16/09/2022								
Status : Completed								
2972	22090646	POW & SICU	NEED TO CHANGE TUBELIGHT	Muthu. B.	TUBE LIGHT 40W STARTER 1NO CHANGED		Kausalya. V. - POW & SICU	17/09/2022
Comp. Dt. : 17/09/2022								
Status : Completed								
2973	22090685	POW & SICU	STERILIZER POWER CART NOT WORKING	Muthu. B.	16A 3PIN TOP 1NO CHANGED		Jamuna. K - POW & SICU	19/09/2022
Comp. Dt. : 20/09/2022								
Status : Completed								
2974	22090777	POW & SICU	HEATER NOT WORKING	Lakshmanan.V.	ALL HEATER CHEKING WORK 16A SWITCH 1NO CHANGED		Jamuna. K - POW & SICU	21/09/2022
Comp. Dt. : 27/09/2022								
Status : Completed								
2975	22091044	POW & SICU	NEED TO CHECK POWER FOR U P S - VENTILATION POWER PROBLEM NEED URGENT SERVICE	Dhakshinamoorthy. J	UPS LINE CHEKING WORK PROBLEM SOLVED		Lakshmi. R. - POW & SICU	07/10/2022
Comp. Dt. : 29/09/2022								
Status : Completed								
2976	22091164	POW & SICU	NEED TO CHANGE TUBELIGHT 2NOS	Suresh. V.	36W TUBE LIGHT 2NO'S CHANG & 40W STARTER 1NO CHANGED		Valarmathy. K. - POW & SICU	30/09/2022
Comp. Dt. : 11/10/2022								
Status : Completed								
2977	22100288	POW & SICU	NEED ALL FAN CLEANING WORK	Suresh. V.	ALL CEILING FAN CLEANING WORK PROBLEM SOLVED		Jamuna. K - POW & SICU	12/10/2022
Comp. Dt. : 13/10/2022								
Status : Completed								
2978	22100383	POW & SICU	NEED TO CHANGE TUBELIGHT & CEILING LIGHT	Lakshmanan.V.	9W LED LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Silambarasi. A. - POW & SICU	14/10/2022
Comp. Dt. : 18/10/2022								
Status : Completed								
2979	22100584	POW & SICU	NEED FAN CLEANING WORK	Muthu. B.	ALL CEILING FAN CLEANING WORK PROBLEM SOLVED		Valarmathy. K. - POW & SICU	19/10/2022

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 09/12/2022								
Status : Completed								
2980	22120405	POW & SICU	NEED TO CHANGE TUBELIGHT	Rajan. R.	36W TUBE LIGHT 2NO'S CHANGED		Jamuna. K - POW & SICU	10/12/2022
Comp. Dt. : 10/12/2022								
Status : Completed								
2981	22120475	POW & SICU	IN DOCTOR'S ROOM-1 TUBELIGHT NOT WORKING	Muthu. B.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Jamuna. K - POW & SICU	13/12/2022
Comp. Dt. : 28/12/2022								
Status : Completed								
2982	22121263	POW & SICU	TUBELIGHT NOT WORKING - 1 NOS	Dhakshinamoorthy. J	36W TUBE LIGHT 1NO CHANGED		Jamuna. K - POW & SICU	29/12/2022
2983	22121267	POW & SICU	CEILING LIGHT NOT WORKING - 3 NOS	Dhakshinamoorthy. J	9W LED LIGHT 1NO CHANG & 18W CFL 2PIN 2NO'S CHANG & 36W TUBE LIGHT 1NO CHANGED		Jamuna. K - POW & SICU	29/12/2022
2984	22121306	POW & SICU	1 TUBELIGHT NOT WORKING	Dhakshinamoorthy. J	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Jamuna. K - POW & SICU	29/12/2022
Comp. Dt. : 29/12/2022								
Status : Completed								
2985	22121313	POW & SICU	EXTENSION BOX NOT WORKING	Damodharan. V.	6A 3PIN TOP WIRE CUT RECONNECTION WORK PROBLEM SOLVED		Jamuna. K - POW & SICU	29/12/2022
Comp. Dt. : 03/01/2023								
Status : Completed								
2986	23010090	SICU	PATIENT SIDE CALLING BELL NEED TO BE REFIX PROPERLY	Muthu. B.	2M SURFACE BOX SET 1NO FIXING & LINE CONNECTION WORK PROBLEM SOLVED		Jamuna. K - POW & SICU	03/01/2023
Comp. Dt. : 05/01/2023								
Status : Completed								
2987	23010206	SICU	WATER HEATER SWITCH NOT POWER OFF	Dhakshinamoorthy. J	WATER HEATER 1NO RESET WORK PROBLEM SOLVED		Renugadevi. J. - POW & SICU	06/01/2023
Comp. Dt. : 13/01/2023								
Status : Completed								
2988	23010544	POW & SICU	NEED TO CHECK FAN & SWITCH BOARD POWER PROBLEM & NEED SERVICE	Manimaran. P.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 2NO'S CHANGED		Jamuna. K - POW & SICU	14/01/2023

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
2989	23010550	POW & SICU	TUBELIGHT NOT WORKING	Lakshmanan.V.	MCB TRIP ON TO WORK PROBLEM SOLVED		Subhasini. S. - POW & SICU	14/01/2023
	Comp. Dt. : 14/01/2023							
	Status : Completed							
2990	23010589	POW & SICU	NEED TO CHANGE TUBELIGHT	Muthu. B.	TUBE LIGHT 40W STARTER 1NO CHANGED		Valarmathy. K. - POW & SICU	18/01/2023
	Comp. Dt. : 20/01/2023							
	Status : Completed							
2991	23010696	POW & SICU	NEED FAN CLEANING WORK	Dhakshinamoorthy. J	ALL CEILING FAN CLEANING WORK PROBLEM SOLVED		Jamuna. K - POW & SICU	21/01/2023
	Comp. Dt. : 27/01/2023							
	Status : Completed							
2992	23010942	POW & SICU	NEED TO CHANGE CEILING LIGHT FOR NURSE'S CABIN	Muthu. B.	T5 14W CFL LIGHT 2NO'S CHANGED		Lakshmi. R. - POW & SICU	27/01/2023
	Comp. Dt. : 03/02/2023							
	Status : Completed							
2993	23020112	POW & SICU	NEED TO CHANGE TUBELIGHT	Lakshmanan.V.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Valarmathy. K. - POW & SICU	04/02/2023
	Comp. Dt. : 15/02/2023							
	Status : Completed							
2994	23020608	SICU	NEED TO CHECK POWER - PLUG POINT NOT WORKING	Lakshmanan.V.	6A SOCKET 1NO CHANG & 6A SWITCH 1NO CHANGED		Jayapradha. J. - POW & SICU	17/02/2023
	Comp. Dt. : 22/02/2023							
	Status : Completed							
2995	23020845	POW & SICU	ONE FAN AND ONE TUBELIGHT NOT WORKING	Vijayaraghavan.B.	CEILING FAN 1NO RESOLDING WORK & BEARING 2NO'S CHANG & FAN REFIXING WORK 36W TUBE LIGHT 1NO CHANGED		Jamuna. K - POW & SICU	27/02/2023
2996	23020846	POW & SICU	ONE HEATER NOT WORKING	Vijayaraghavan.B.	OLD WATER HEATER 1NO REFIXING WORK & HEATER CHEKING WORK PROBLEM SOLVED		Jamuna. K - POW & SICU	09/03/2023
	Comp. Dt. : 03/03/2023							
	Status : Completed							
2997	23030121	POW & SICU	NEED TO CHANGE TUBELIGHT	Dhakshinamoorthy. J	36W TUBE LIGHT 1NO CHANGED		Jamuna. K - POW & SICU	04/03/2023

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 04/03/2023								
Status : Completed								
2998	23030161	POW & SICU	NEED TO CHECK POWER - SHOCK PROBLEM - HEATER PIPELINE NEED URGENT SERVICE	Manikandan. M.	WATER HEATERE NEW COIL 2KW 1NO CHANG & HEATER CHEKING WORK PROBLEM SOLVED		Pragadeesh. V. - POW & SICU	08/03/2023
Comp. Dt. : 06/03/2023								
Status : Completed								
2999	23030211	POW & SICU	NEED TO CHANGE CEILING LIGHT	Srinivasan. R.	TUBE LIGHT 40W STARTER 1NO CHANGED		Silambarasi. A. - POW & SICU	07/03/2023
Comp. Dt. : 16/03/2023								
Status : Completed								
3000	23030673	POW & SICU	HEATER [2NOS] NOT WORKING	Lakshmanan.V.	WATER HEATER RESET WORK PROBLEM SOLVED		Jamuna. K - POW & SICU	20/03/2023
Comp. Dt. : 20/03/2023								
Status : Completed								
3001	23030770	SICU	FAN AND TUBELIGHT NOT WORKING - 1 NOS	Rajan. R.	FAN & TUBE LIGHT CHEKING WORK NO COMPLAINT PROBLEM SOLVED		Jamuna. K - POW & SICU	20/03/2023
Comp. Dt. : 27/03/2023								
Status : Completed								
3002	23031102	POW & SICU	NEED FAN CLEANING WORK FOR SEPTIC WARD	Rajan. R.	CEILING FAN CLEANING WORK PROBLEM SOLVED		Jamuna. K - POW & SICU	28/03/2023
Comp. Dt. : 28/03/2023								
Status : Completed								
3003	23031208	POW & SICU	NEED TO CHECK UPS LINE - POWER PROBLEM - NOT WORKING NEED URGENT SERVICE	Dhakshinamoorthy. J,Srinivasan. R.,Manikandan. M.	Wire problem. New wire layed and line connected.		Pragadeesh. V. - POW & SICU	08/04/2023
Comp. Dt. : 06/04/2023								
Status : Completed								
3004	23040202	POW & SICU	NEED CLEANNING WORK FOR TUBELIGHT SETS	Srinivasan. R.	Tube light fitting cleaned.		Silambarasi. A. - POW & SICU	12/04/2023
Comp. Dt. : 12/04/2023								
Status : Completed								
3005	23040382	SICU	NEED TO CHANGE TUBELIGHT 2NOS FOR DOCTOR'S ROOM	Lakshmanan.V.	36W tube light 2no's, E.choke 1no & starter 1no changed.		Arulmozhi. D. - POW & SICU	13/04/2023
Comp. Dt. : 13/04/2023								
Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
3006	23040419	POW & SICU	NEED TO CHANGE TUBELIGHT 2 NOS	Muthu. B.	Switch 6A problem - Switch 6A changed.		Jamuna. K - POW & SICU	15/04/2023
		Comp. Dt. : 24/04/2023 Status : Completed						
3007	23040718	POW & SICU	NEED TO CHANGE CEILING LIGHT & TUBELIGHT	Manimaran. P.	36W CFL LIGHT 4PIN 1NO CHANG & 40W STARTER 1NO CHANGED		Jamuna. K - POW & SICU	25/04/2023
		Comp. Dt. : 05/06/2023 Status : Completed						
3008	23060144	POW & SICU	NEED TO CHANGE FIRE EXTINGUISHER - DISPLAY EXPIRY	Babu. D.	NEW FIRE EXTINGUISHER CYLINDER 1NO CHANGED		Jamuna. K - POW & SICU	07/06/2023
		Comp. Dt. : 21/06/2023 Status : Completed						
3009	23060742	POW & SICU	NEED TO CHANGE TUBELIGHT	Vengadessaperumal. K.	20W TUBE LIGHT 1NO CHANGED		Jamuna. K - POW & SICU	22/06/2023
		Comp. Dt. : 24/06/2023 Status : Completed						
3010	23060921	POW & SICU	HEATER DAMAGE - NEED TO CHECK	Manimaran. P.	WATER HEATER NET LOOSE SCREW REFIXING WORK PROBLEM SOLVED		Jamuna. K - POW & SICU	26/06/2023
		Comp. Dt. : 26/06/2023 Status : Completed						
3011	23060959	POW & SICU	NEED FAN CLEANING WORK	Muthu. B.	all fan cleaning work		Pragadeesh. V. - POW & SICU	28/06/2023
		Dept Name : Power Laundry - Electrical Maintenance Comp. Dt. : 26/05/2022 Status : Completed						
3012	22051003	LAUNDRY	NEED TO REPLACE FAN 3NOS FROM LAUNDRY I FLOOR TO GROUND FLOOR	Dhakshinamoorthy. J	CEILING FAN 3NO'S SHIFTING TO FAN REFIXING WORK PROBLEM SOLVED		Manikandan.M - Power Laundry	31/05/2022
		Comp. Dt. : 04/07/2022 Status : Completed						
3013	22070124	LAUNDRY	NEED TO CHECK POWER - WASHING MACHINE NOT WORKING	Dhakshinamoorthy. J	CONTACT CONTROL WIRE LOOSE SREW REFIXING WORK & WASHING MACHINE CHEKING WORK PROBLEM SOLVED		Punniamurthy. R - Power Laundry	05/07/2022
		Comp. Dt. : 22/07/2022						


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
3014	22070823	LAUNDRY	NEED TO CHECK NEW DRIYER - NOT WORKING - [ELECTRICAL FAULT]	Vijayaraghavan.B.	MCB TRPE ON TO WORK PROLEM SOLVED		Manikandan.M - Power Laundry	22/07/2022
Comp. Dt. : 26/07/2022								
Status : Completed								
3015	22070932	LAUNDRY	HYDRO EXTRACTOR MACHINE - ELECTRICAL FAULT	Dhakshinamoorthy. J	MCB TRIP ON TO WORK PROBLEM SOLVED		Manikandan.M - Power Laundry	27/07/2022
Comp. Dt. : 09/08/2022								
Status : Completed								
3016	22080342	Power Laundry	NEED TO CHANGE TUBELIGHT	Lakshmanan.V.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Manikandan.M - Power Laundry	10/08/2022
Comp. Dt. : 17/08/2022								
Status : Completed								
3017	22080512	Power Laundry	DRYER NO.2 MOTOR SOUND PROBLEM	Dhakshinamoorthy. J	Dryer sound problem solved.		Manikandan.M - Power Laundry	18/08/2022
Comp. Dt. : 27/09/2022								
Status : Completed								
3018	22091057	LAUNDRY	NEED SERVICE FOR OLD IRON BOX	Dhakshinamoorthy. J	IRON BOX CABLE CHANGED		Manikandan.M - Power Laundry	28/09/2022
Comp. Dt. : 09/11/2022								
Status : Completed								
3019	22110367	Power Laundry	DRYER NO.3 -DRYER NOT HEATING	Manimaran. P.	DRYER HEATING COIL SINGLE PHASE LINE CONNECTION WORK PROBLEM SOLVED		Manikandan.M - Power Laundry	11/11/2022
3020	22110368	Power Laundry	DRYER NO.2-HEATER MOTOR SOUND PROBLEM	Sathishkumar. R.	DRYER MOTOR BEARING CHANG & MOTOR REFIXING WORK PROBLEM SOLVED		Manikandan.M - Power Laundry	02/12/2022
Comp. Dt. : 28/11/2022								
Status : Completed								
3021	22111175	Power Laundry	REQUEST TO TEMINATE POWER LINE	Babu. D.	TUBE LIGHT FITTING REMOVING WORK PROBLEM SOLVED		Punniamurthy. R - Power Laundry	02/12/2022
Comp. Dt. : 12/12/2022								
Status : Completed								
3022	22120509	Power Laundry	TUBELIGHT NOT WORKING	Muthu. B.	36W TUBE LIGHT 1NO & 40W STARTER 1NO CHANG & SIDE HOLDER 1NO CHANGED		Manikandan.M - Power Laundry	13/12/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
3023	22120510	Power Laundry	DRYER 3 NOT WORKING	Dhakshinamoorthy. J	DRYER TIMER & 25A CONTCT CHANG & LINE CONNECTION WORK & DRYER CHEKING WORK PROBLEME SOLVED		Manikandan.M - Power Laundry	01/02/2023
Comp. Dt. : 21/12/2022 Status : Completed								
3024	22120965	LAUNDRY	TUBELIGHT NOT WORKING - 1 NOS	Srinivasan. R.	36W TUBE LIGHT 1NO CHANG & 36W CHOKE 1NO CHANGED		Manikandan.M - Power Laundry	22/12/2022
Comp. Dt. : 03/01/2023 Status : Completed								
3025	23010119	LAUNDRY	2NOS TUBELIGHT NOT WORKING	Lakshmanan.V.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 2NO'S CHANGED		Manikandan.M - Power Laundry	04/01/2023
Comp. Dt. : 12/01/2023 Status : Completed								
3026	23010533	LAUNDRY	POWER SUPPLY PROBLEM	Dhakshinamoorthy. J	63A 3POLE MCB 1NO CHANGED		Punnamurthy. R - Power Laundry	14/01/2023
Comp. Dt. : 23/02/2023 Status : Completed								
3027	23020901	LAUNDRY	NEED TO CHANGE TUBELIGHT 2 NOS	Lakshmanan.V.	Neet Tube Light 1 NO, Starter 1 NO Changed		Manikandan.M - Power Laundry	24/02/2023
Comp. Dt. : 16/04/2023 Status : Completed								
3028	23040468	LAUNDRY	NEED TO CHANGE FAN	Srinivasan. R.	CEILING FAN CAPACITOR 2.5MFT 1NO CHANG & FAN ROD 3FEET 1NO CHANGED		Punnamurthy. R - Power Laundry	17/04/2023
Comp. Dt. : 04/05/2023 Status : Completed								
3029	23050158	Power Laundry	HEATER MACHINE NOT WORKING	Manimaran. P.	HEATER MACHINE WIRE CUT RECONNECTION WORK PROBLEM SOLVED		Punnamurthy. R - Power Laundry	06/05/2023
Comp. Dt. : 05/05/2023 Status : Completed								
3030	23050214	LAUNDRY	IRON BOX NOT WORKING	Lakshmanan.V.	16A 3PIN TOP 1NO CHANGED		Manikandan.M - Power Laundry	06/05/2023
Comp. Dt. : 09/05/2023 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
3031	23050356	LAUNDRY	NEED TO CHANGE DRIYER CABLE FOR DRIER NO 1 - CABLE BURNT	Damodharan. V.	DRIYER IN COMMING WIRE CUT RECONNECTION WORK PROBLEM SOLVED		Manikandan.M - Power Laundry	10/05/2023
Comp. Dt. : 11/05/2023 Status : Completed								
3032	23050454	LAUNDRY	DRIYER - II NOT WORKING	Manikandan. M.	MCB TRIP ON TO WORK PROBLEM SOLVED		Manikandan.M - Power Laundry	12/05/2023
Comp. Dt. : 12/05/2023 Status : Completed								
3033	23050521	LAUNDRY	IRON BOX NOT WORKING	Lakshmanan.V.	Wire problem - solved.		Manikandan.M - Power Laundry	15/05/2023
Comp. Dt. : 21/06/2023 Status : Completed								
3034	23060771	LAUNDRY	TRIP PROBLEM - [PROBLEM IN OVEN]	Thillaikumar. R.	MCB WIRE CUT RECONNECTION WORK PROBLEM SOLVED		Punniamurthy. R - Power Laundry	24/06/2023
Dept Name : Printing Press - Electrical Maintenance Comp. Dt. : 30/05/2022 Status : Completed								
3035	22051100	PRESS	NEED TO CHANGE TUBELIGHT	Dhakshinamoorthy. J	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Vijayasekar. K. - Printing Press	31/05/2022
Comp. Dt. : 06/06/2022 Status : Completed								
3036	22060180	Printing Press	NEED TO CHANGE TUBELIGHT	Vijayaraghavan.B.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Vijayasekar. K. - Printing Press	07/06/2022
Comp. Dt. : 15/06/2022 Status : Completed								
3037	22060540	Printing Press	ELECTRICAL FAULT IN U P S - NEED TO CHECK	Srinivasan. R.	16A MCB SINGLE POLE 1NO CHANGED		Thirunavukarassu. K. - Printing Press	16/06/2022
Comp. Dt. : 07/07/2022 Status : Completed								
3038	22070235	Printing Press	NEED TO CHANGE TUBELIGHT	Dhakshinamoorthy. J	Tube light starter 1no changed.		Thirunavukarassu. K. - Printing Press	08/07/2022
Comp. Dt. : 08/07/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
3039	22070326	Printing Press	NEED TO CHANGE TUBELIGHT	Dhakshinamoorthy. J	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Thirunavukarassu. K. - Printing Press	11/07/2022
Comp. Dt. :		26/08/2022						
Status :		Completed						
3040	22080895	PRESS	NEED FAN SERVICE FOR , NEAR PRINTING MACHINE	Dhakshinamoorthy. J	PEDESTAL FAN 1NO SERVICE WORK PROBLEM SOLVED		Vijayasekar. K. - Printing Press	27/08/2022
Comp. Dt. :		19/09/2022						
Status :		Completed						
3041	22090709	Printing Press	NEED TP CHANGE TUBELIGHT [NEAR MACHINE]	Dhakshinamoorthy. J	TUBE LIGHT SIDE HOLDER 1NO CHANGED		Vijayasekar. K. - Printing Press	20/09/2022
Comp. Dt. :		26/09/2022						
Status :		Completed						
3042	22091033	Printing Press	NEED TO CHANGE TUBELIGHT	Manikandan. M.	36W TUBE LIGHT 1NO CHANGED		Vijayasekar. K. - Printing Press	29/09/2022
Comp. Dt. :		27/09/2022						
Status :		Completed						
3043	22091094	Printing Press	NEED TO CHANGE TUBELIGHT NEAR PRINTING MACHINE	Manikandan. M.	36W TUBE LIGHT 1NO CHANG & 540W STARTER 1NO CHANGED		Vijayasekar. K. - Printing Press	28/09/2022
Comp. Dt. :		11/11/2022						
Status :		Completed						
3044	22110449	Printing Press	1 TUBELIGHT NOT WORKING	Muthu. B.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Vijayasekar. K. - Printing Press	15/11/2022
Comp. Dt. :		01/02/2023						
Status :		Completed						
3045	23020021	Printing Press	U P S NOT WORKING	Dhakshinamoorthy. J	UPS CHEKING WORK MCB TRIP ON TO WORK PROBLEM SOLVED		Thirunavukarassu. K. - Printing Press	02/02/2023
Comp. Dt. :		15/02/2023						
Status :		Completed						
3046	23020594	Printing Press	FAN SWITCH NOT WORKING	Manikandan. M.	6A SWITCH 1NO CHANGED		Jayachandran. G. - Printing Press	15/02/2023
Comp. Dt. :		25/02/2023						
Status :		Completed						
3047	23020960	PRESS	NEED TO CHANGE SWITCH	Sathishkumar. R.	6A SWITCH 1NO CHANGED		Thirumugam. R. - Printing Press	25/02/2023

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 02/03/2023 Status : Completed								
3048	23030100	Printing Press	NEED TO CHANGE TUBELIGHT 2 NOS	Srinivasan. R.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Vijayasekar. K. - Printing Press	03/03/2023
Comp. Dt. : 08/03/2023 Status : Completed								
3049	23030303	Printing Press	TUBELIGHT NOT WORKING	Rajan. R.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Thirunavukarassu. K. - Printing Press	08/03/2023
Comp. Dt. : 30/03/2023 Status : Completed								
3050	23031317	Printing Press	NEED TO CHANGE TUBELIGHT NEAR PRINTING MACHINE	Rajan. R.	36W tube light 1no & starter 1no changed.		Vijayasekar. K. - Printing Press	31/03/2023
Comp. Dt. : 06/06/2023 Status : Completed								
3051	23060209	Printing Press	NEED TO CHECK FAN - PROBLEM	Rajan. R.	PEDESTAL FAN 1NO CLEANING WORK PROBLEM SOLVED		Vijayasekar. K. - Printing Press	07/06/2023
Comp. Dt. : 07/06/2023 Status : Completed								
3052	23060223	Printing Press	NEED TO CHANGE TUBELIGHT	Rajan. R.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Thirunavukarassu. K. - Printing Press	07/06/2023
Comp. Dt. : 19/06/2023 Status : Completed								
3053	23060659	COW SHED	NEED TO CHECK TUBELIGHT - NOT WORKING	Damodharan. V.	MCB TRIP ON TO WORK PROBLEM SOLVED		Shanmugam. R. - Printing Press	19/06/2023
Comp. Dt. : 30/06/2023 Status : Completed								
3054	23061107	Printing Press	NEED TO CHANGE REST ROOM TUBELIGHT [SMALL SIZE]	Lakshmanan.V.	36W TUBE LIGHT 1NO CHANGED		Vijayasekar. K. - Printing Press	01/07/2023
Dept Name : Quality Department - Electrical Maintenance Comp. Dt. : 19/05/2022 Status : Completed								
3055	22050700	NAC OFFICE 4TH FLOOR	NEED TO CHANGE TUBELIGHT	Muthu. B.	18W 4PIN CFL LIGHT 2NO'S CHANG & 20W CHOKE 2NO'S CHANGED	 Dr. KAGNE. R.N DEAN SRI MANAKULA VINAYAGAR MEDICAL COLLEGE & HOSPITAL KALITHEERTHALKUPPAM, PUDUCHERRY-605107.	Suganthi. M. - Quality Department	25/05/2022

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 15/06/2022 Status : Completed								
3056	22060592	NAC OFFICE 4TH FLOOR	NEED ELECTRICIAN HELP FOR OFFICE ROOM ARRANGEMENT [DEAN SIR OFFICE]	Manikandan. M.	SWITCH BOX REMOVING TO REARRANGEMENT WORK PROBLEM SOLVED		Suganthi. M. - Quality Department	16/06/2022
Comp. Dt. : 02/08/2022 Status : Completed								
3057	22080052	MS Office	NEED TO CHANGE TUBELIGHT FOR NABH OFFICE	Suresh. V.	TUBE LIGHT 40W STARTER 1NO CHANGED		Pradeep Kumar. S. - Quality Department	02/08/2022
Comp. Dt. : 17/08/2022 Status : Completed								
3058	22080485	MS Office	TUBELIGHT NOT WORKING	Vengadessaperumal. K.	36W tube light 1no changed.		Pradeep Kumar. S. - Quality Department	17/08/2022
Comp. Dt. : 06/02/2023 Status : Completed								
3059	23020181	NABH OFFICE	POWER SUPPLY PROBLEM	Srinivasan. R.	MCB TRIP ON TO WORK PROBLEM SOLVED		Suganthi. M. - Quality Department	06/02/2023
Comp. Dt. : 01/04/2023 Status : Completed								
3060	23040005	MS Office	NEED TO CHANGE TUBELIGHT [NABH ROOM]	Vengadessaperumal. K.	Tube light starter 1no changed.		Harish. K. - Quality Department	03/04/2023
Comp. Dt. : 05/04/2023 Status : Completed								
3061	23040141	NABH OFFICE	NEED TO CHANGE TUBELIGHT - [M.S OFFICE INSIDE NABH]	Vijayaraghavan.B.	Tube light starter 1no changed.		Pradeep Kumar. S. - Quality Department	05/04/2023
Dept Name : Radio Diagnosis - Electrical Maintenance Comp. Dt. : 07/05/2022 Status : Completed								
3062	22050240	RADIOLOGY	NEED TO CHANGE TUBELIGHT	Manikandan. M.	18W 4PIN CFL LIGHT 1NO CHANGED		Manikandan.V. - Radio Diagnosis	09/05/2022
Comp. Dt. : 10/05/2022 Status : Completed								
3063	22050321	XRay	NEED TO CHECK FAN REGULATOR - NOT WORKING ROOM NO 8	Manikandan. M.	FAN REGULATOR 1NO CHANGED		Guru. A. - Radio Diagnosis	12/05/2022
Comp. Dt. : 11/05/2022								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
3064	22050387	RADIOLOGY	IN LAST ROOM-FAN REGULATOE NOT WOKRING	Lakshmanan.V.	FAN REGULATOR TOP COVER 1NO CHANGED		Balabaskaran. A. - Radio Diagnosis	12/05/2022
Comp. Dt. : 14/05/2022								
Status : Completed								
3065	22050491	Ultra Sound	GROUND FLOOR USG ROOM TUBELIGHT NOT WORKING	Muthu. B.	36W TUBE LIGHT 2NO'S CHANG & 40W STARTER 1NO CHANGED		Sangeetha. S. - Radio Diagnosis	17/05/2022
Comp. Dt. : 16/05/2022								
Status : Completed								
3066	22050514	SCAN - GROUND FLOOR - BLOOD BANK OPP	NEED TO CHANGE TUBELIGHT	Muthu. B.	36W TUBE LIGHT 2NO'S CHANG & 40W STARTER 2NO'S CHANGED		Sangeetha. S. - Radio Diagnosis	17/05/2022
Comp. Dt. : 16/06/2022								
Status : Completed								
3067	22060613	MRI	NEED TO FIX SWITCH BOARD - BASEMENT MRI	Lakshmanan.V.	Power point arranged.		Sivabalan. P. - Radio Diagnosis	17/06/2022
Comp. Dt. : 11/07/2022								
Status : Completed								
3068	22070416	BASEMENT SCAN	NEED TO CHANGE"0" WATT LIGHT [YELLOW COLOUR] FOR ULTRA SOUND	Dhakshinamoorthy. J	0.5W LED NIGHT LAMP 1NO CHANGED		Abirami. P. - Radio Diagnosis	11/07/2022
Comp. Dt. : 22/07/2022								
Status : Completed								
3069	22070815	CT Scan	NEED TO CHECK POWER - SWITCH & PLUG POINT NOT WORKING	Muthu. B.	MCB TRIP ON TO WORK PROBLEM SOLVED		Mahendran.V. - Radio Diagnosis	22/07/2022
Comp. Dt. : 27/07/2022								
Status : Completed								
3070	22070997	CT Scan	FANCY LIGHT NOT WORKING	Suresh. V.	9W LED LIGHT 2NO'S CHANGED		Mahendran.V. - Radio Diagnosis	03/08/2022
Comp. Dt. : 09/08/2022								
Status : Completed								
3071	22080339	SCAN - GROUND FLOOR - BLOOD BANK OPP	NEED TO CHECK SWITCH - NOT WORKING	Suresh. V.	6A SWITCH 1NO CHANGED		Sangeetha. S. - Radio Diagnosis	10/08/2022
Comp. Dt. : 18/08/2022								
Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
3072	22080555	SCAN - GROUND FLOOR - BLOOD BANK OPP	TUBE LIGHT NOT WORKING	Muthu. B.	36W CHOKE 1NO CHANG & 40W STARTER 1NO CHANGED		Kanimozhi. D. - Radio Diagnosis	20/08/2022
Comp. Dt. :		26/08/2022						
Status :		Completed						
3073	22080877	CT Scan	NEED TO CHANGE "BULB" - NOT WORKING AT CONSOLE ROOM	Dhakshinamoorthy. J	9W LED LIGHT 1NO CHANGED		Mahendran.V. - Radio Diagnosis	27/08/2022
Comp. Dt. :		30/08/2022						
Status :		Completed						
3074	22081018	XRay	NEED TO CHANGE TUBELIGHT FOR RESTROOM	Dhakshinamoorthy. J	36W TUBE LIGHT 1NO CHANGED		Abirami. P. - Radio Diagnosis	01/09/2022
Comp. Dt. :		07/09/2022						
Status :		Completed						
3075	22090261	XRay	NEED TO CHANGE TUBELIGHT FOR CARITOR	Lakshmanan.V.	36W TUBE LIGHT 1NO CHANGED		Manikandan.V. - Radio Diagnosis	08/09/2022
Comp. Dt. :		08/09/2022						
Status :		Completed						
3076	22090312	CT Scan	NEED TO CHANGE BULB - FUSE	Vijayaraghavan.B.	9W LED LIGHT 1NO CHANGED		Mahendran.V. - Radio Diagnosis	09/09/2022
Comp. Dt. :		14/09/2022						
Status :		Completed						
3077	22090527	RADIOLOGY	NEED TO CHANGE TUBELIGHT 2NOS FOR LIBRARY ROOM	Suresh. V.	9W LED LIGHT 2NO'S CHANG & BABY HOLDER 2NO'S CHANGED		Abirami. P. - Radio Diagnosis	24/09/2022
Comp. Dt. :		17/09/2022						
Status :		Completed						
3078	22090664	Reception	NEED TO CHANGE X RAY LOBBY LIGHT IN RECEPTION	Manimaran. P.	20W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Manikandan.V. - Radio Diagnosis	19/09/2022
Comp. Dt. :		20/09/2022						
Status :		Completed						
3079	22090762	RADIOLOGY	NEED TO CHANGE TUBELIGHT FOR FAX ROOM	Rajan. R.	9W LED LIGHT 2NO'S CHANGED		Jayalakshmi. D. - Radio Diagnosis	24/09/2022
Comp. Dt. :		14/10/2022						
Status :		Completed						
3080	22100465	Male Surgery - Ward 204	FAN NOT WORKING - SLOW PROBLEM AT NURSE'S CABIN	Manikandan. M.	CEILING FAN CAPACITOR 2.5MFT 1NO CHANGED		Praveen Kumar. M. - Radio Diagnosis	15/10/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 20/10/2022 Status : Completed								
3081	22100660	MRI	FANCY LIGHT NOT WORKING IN MRI ROOM	Dhakshinamoorthy. J	18W 4PIN CFL LIGHT 2NO'S CHANGED		Sushmitha. K. - Radio Diagnosis	26/10/2022
Comp. Dt. : 26/10/2022 Status : Completed								
3082	22100787	SCAN - GROUND FLOOR - BLOOD BANK OPP	TUBE LIGHT NOT WORKING	Srinivasan. R.	TUBE LIGHT 40W STARTER 1NO CHANGED		Sudha. D. - Radio Diagnosis	27/10/2022
Comp. Dt. : 29/11/2022 Status : Completed								
3083	22111246	RADIOLOGY	IN DARK ROOM-1 TUBELIGHT NOT WORKING	Lakshmanan.V.	TUBE LIGHT 1NO & 40W STARTER 1NO CHANGED		Manikandan.V. - Radio Diagnosis	30/11/2022
Comp. Dt. : 07/12/2022 Status : Completed								
3084	22120278	XRy	IN DARK ROOM-1 TUBELIGHT NOT WORKING	Srinivasan. R.	36W TUBE LIGHT 1NO CHANGED		Manikandan. G. - Radio Diagnosis	08/12/2022
Comp. Dt. : 10/12/2022 Status : Completed								
3085	22120463	RADIOLOGY	NEED TO CHANGE TUBELIGHT FOR RESTROOM	Manikandan. M.	36W TUBE LIGHT 1NO CHANGED		Abirami. P. - Radio Diagnosis	13/12/2022
Comp. Dt. : 26/12/2022 Status : Completed								
3086	22121152	XRy	BULB NOT WORKING IN DARK ROOM	Vengadessaperumal. K.	0.5W NIGHT LAMP 1NO CHANGED		Thamizhpandiyan. G - Radio Diagnosis	26/12/2022
Comp. Dt. : 27/12/2022 Status : Completed								
3087	22121227	RADIOLOGY	2NOS TUBELIGHT NOT WORKING IN REST ROOM (BASEMENT SCAN)	Vengadessaperumal. K.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 2NO'S CHANGED		Abirami. P. - Radio Diagnosis	28/12/2022
Comp. Dt. : 03/02/2023 Status : Completed								
3088	23020092	XRy	NEED TO CHANGE TUBELIGHT FOR 600 ROOM	Vengadessaperumal. K.	Tube light fitting 36W 1no replaced.		Manikandan.V. - Radio Diagnosis	03/02/2023
Comp. Dt. : 13/02/2023 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
3089	23020472	MRI	NEED TO CHANGE TUBELIGHT FOR MRI ROOM	Rajan. R.,Sathishkumar. R.,Vengadessaperumal.K.	22W LED TUBE LIGHT 2NO'S CHANGED		Mahendran.V. - Radio Diagnosis	14/02/2023
Comp. Dt. : 15/02/2023 Status : Completed								
3090	23020585	XRay	XRAY ROOM NO-21,POWER PROBLEM(1516)	Srinivasan. R.	MCB TRIP ON TO WORK PROBLEM SOLVED		Manikandan.V. - Radio Diagnosis	17/02/2023
Comp. Dt. : 25/03/2023 Status : Completed								
3091	23031075	SCAN - GROUND FLOOR - BLOOD BANK OPP	NEED TO CHANGE TUBELIGHT	Srinivasan. R.	0.5W LED LIGHT 1NO CHANGED		Kanimozhi. D. - Radio Diagnosis	27/03/2023
Comp. Dt. : 27/03/2023 Status : Completed								
3092	23031126	SCAN - GROUND FLOOR - BLOOD BANK OPP	NEED TO CHANGE TUBELIGHT 2 NOS	Srinivasan. R.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Sankari. D. - Radio Diagnosis	27/03/2023
Comp. Dt. : 03/04/2023 Status : Completed								
3093	23040050	MRI	NEED TO CHANGE CEILING LIGHT	Muthu. B.	4pin 18W CFL 2no's changed.		Sushmitha. K. - Radio Diagnosis	03/04/2023
Comp. Dt. : 24/04/2023 Status : Completed								
3094	23040717	XRay	NEED TO CHANGE TUBELIGHT FOR DARK ROOM	Rajan. R.	36W TUBE LIGHT 1NO CHANH & 40W STARTER 1NO CHANGED		Manikandan.V. - Radio Diagnosis	24/04/2023
Comp. Dt. : 06/05/2023 Status : Completed								
3095	23050221	XRay	NEED TO CHANGE TUBELIGHT FOR D R ROOM	Manikandan. M.	TUBE LIGHT 36W CHOKE 1NO CHANGED		Malathi. N. - Radio Diagnosis	08/05/2023
Comp. Dt. : 11/05/2023 Status : Completed								
3096	23050417	XRay	NEED TO CHANGE TUBELIGHT FOR D R ROOM	Damodharan. V.	9W LED LIGHT 1NO CHANGED		Chandrasekar. S. - Radio Diagnosis	11/05/2023
Comp. Dt. : 19/06/2023 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
3097	23060685	SCAN - GROUND FLOOR - BLOOD BANK OPP	NEED TO CHANGE TUBELIGHT	Lakshmanan.V.	TUBE LIGHT 40W STARTER 1NO CHANGED		Sudha. D. - Radio Diagnosis	20/06/2023
Comp. Dt. :		20/06/2023						
Status :		Completed						
3098	23060704	XRay	NEED TO CHANGE TUBELIGHT	Vengadessaperumal. K.	MCB TRIP ON TO WORK PROBLEM SOLVED		Malathi. N. - Radio Diagnosis	20/06/2023
Dept Name :		Reception - Electrical Maintenance						
Comp. Dt. :		29/06/2022						
Status :		Completed						
3099	22061082	Reception	NEED TO CHANGE CEILING LIGHT - NOT WORKING	Dhakshinamoorthy. J	ROUNT LED LIGHT (WW) 3NO'S 18W CHOKE CHANGED		Jayakumar. R. - Reception	04/07/2022
Comp. Dt. :		10/08/2022						
Status :		Completed						
3100	22080366	Reception	NEED TO CLEAN & GENERAL SERVICE FOR ALL FANS	Dhakshinamoorthy. J	CEILING FAN & WALLMOUNTING FAN CLEANING WORK PROBLEM SOLVED		Sankari. K. - Reception	11/08/2022
Comp. Dt. :		02/11/2022						
Status :		Completed						
3101	22110005	Reception	CEILING FAN GOT DOWN IN COUNTER NO.10	Srinivasan. R.	CEILING FAN 1NO NEW ROD FIXING & FAN LINE CONNECTION WORK PROBLEM SOLVED		Sankari. K. - Reception	17/11/2022
Comp. Dt. :		18/01/2023						
Status :		Completed						
3102	23010610	Reception	NEED FANS [ALL FANS] CLEANING & SERVICE	Dhakshinamoorthy. J	ALL FAN CLEANING WORK PROBLEM SOLVED		Sankari. K. - Reception	19/01/2023
Comp. Dt. :		21/01/2023						
Status :		Completed						
3103	23010750	Reception	NEED TO CHANGE LIGHT FOR COUNTER NO 9	Muthu. B.	COUNTER NO 9 LIGHT CHEKING WORK NO COMPLAINT		Ranjithkumar. P. - Reception	23/01/2023
Comp. Dt. :		22/02/2023						
Status :		Completed						
3104	23020870	Reception	COUNTER NO-11-FAN ROD SHAKING PROBLEM	Manikandan. M.	FAN ROD SHAKING SCREW REFIXING WORK PROBLEM SOLVED		Sankari. K. - Reception	23/02/2023
Comp. Dt. :		27/03/2023						
Status :		Completed						


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
3105	23031099	Reception	NEED FAN CLEANING WORK FOR COUNTER NO 10	Manikandan. M.	ALL CEILING FAN CLEANING WORK PROBLEM SOLVED		Sankari. K. - Reception	28/03/2023
Dept Name : RICU - Electrical Maintenance Comp. Dt. : 26/05/2022 Status : Completed								
3106	22050966	RICU	NEED TO CHANGE TUBELIGHT 2 NOS	Manimaran. P.	36W Tube light 1no & Starter 2no's changed.		Deva @ Devanathan. P. - RICU	26/05/2022
Comp. Dt. : 02/06/2022 Status : Completed								
3107	22060080	RICU	NEED TO CHANGE TUBELIGHT	Srinivasan. R.	TUBE LIGHT 40W STARTER 1NO CHANGED		Prasanna. S.U. - RICU	02/06/2022
Comp. Dt. : 07/07/2022 Status : Completed								
3108	22070275	RICU	NEED TO CHECK POWER -NEED URGENT SERVICE	Manimaran. P.	UPS Trip - Trip ON.		Tamililakkiya. K. - RICU	07/07/2022
Comp. Dt. : 20/07/2022 Status : Completed								
3109	22070750	RICU	NEED TO CHECK POWER	Vengadessaperumal. K.	15KVA UPS TRIP ON TO WORK PROBLEM SOLVED		Anitha. A. - RICU	21/07/2022
Comp. Dt. : 23/09/2022 Status : Completed								
3110	22090951	RICU	NEED URGENT SERVICE - POWER PROBLEM - VENTILATION GOING ON	Vijayaraghavan.B.	30KWA UPS TRIP ON TO WORK PROBLEM SOLVED		Nanthini. M. - RICU	24/09/2022
Comp. Dt. : 22/10/2022 Status : Completed								
3111	22100749	RICU	PEST KILLER NOT WORKING	Dhakshinamoorthy. J	MCB TRIP ON TO WORK PROBLEM SOLVED		Tamililakkiya. K. - RICU	25/10/2022
Comp. Dt. : 14/11/2022 Status : Completed								
3112	22110545	RICU	SWITCH BOARD NOT WORKING	Dhakshinamoorthy. J	MCB TRIP ON TO WORK PROBLEM SOLVED		Tamililakkiya. K. - RICU	15/11/2022
Comp. Dt. : 26/12/2022 Status : Completed								
3113	22121146	RICU	TUBELIGHT NOT WORKING	Vengadessaperumal. K.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 3NO'S CHANGED		Anitha. A. - RICU	26/12/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
3114	22121166	RICU	TUBELIGHT NOT WORKING IN 2NOS	Vengadessaperumal. K.	TUBE LIGHT 40W STARTER 2NO'S CHANGED		Tamililakkiya. K. - RICU	26/12/2022
Comp. Dt. : 06/01/2023 Status : Completed								
3115	23010254	RICU	ALL FANS CLEANING WORK	Rajan. R.	6M PLATE 1NO CHNAG & WALLMOUNTING FAN 1NO CLEANING WORK PROBLEMSOLVED		Tamililakkiya. K. - RICU	06/01/2023
Comp. Dt. : 09/01/2023 Status : Completed								
3116	23010341	RICU	FAN NEED TO BE REFIX	Srinivasan. R.	WALLMOUNTING FAN 1N REFIXING WORK PROBLEM SOLVED		Tamililakkiya. K. - RICU	10/01/2023
Comp. Dt. : 14/01/2023 Status : Completed								
3117	23010591	RICU	NEED TO CHECK SWITH BOARD 2 NO'S - NOT WORKING	Lakshmanan.V.	MCB TRIP ON TO WORK PROBLEM SOLVED		Tamililakkiya. K. - RICU	18/01/2023
Comp. Dt. : 06/02/2023 Status : Completed								
3118	23020188	RICU	NEED TO CHANGE TUBELIGHT	Srinivasan. R.	36W TUBE LIGHT 1NO CHANGED		Tamililakkiya. K. - RICU	06/02/2023
Comp. Dt. : 12/05/2023 Status : Completed								
3119	23050485	RICU	NEED TO CHANGE TUBELIGHT 3 NOS	Manimaran. P.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Tamililakkiya. K. - RICU	13/05/2023
Comp. Dt. : 15/05/2023 Status : Completed								
3120	23050596	RICU	NEED FAN CLEANING WORK	Muthu. B.	WALLMOUNTING FAN CLEANING WORK PROBLEM SOLVED		Tamililakkiya. K. - RICU	17/05/2023
Comp. Dt. : 18/05/2023 Status : Completed								
3121	23050727	RICU	NEED TO CHANGE TUBELIGHT	Dhakshinamoorthy. J	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Silambarasan. S. - RICU	19/05/2023
Comp. Dt. : 31/05/2022 Status : Completed								
Dept Name : Security - SIS - Electrical Maintenance								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
3122	22051120	Casualty	NEED TO CHANGE TUBELIGHT FOR RESTROOM	Srinivasan. R.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Murugan. S. - Security - SIS	01/06/2022
Comp. Dt. : 02/03/2023 Status : Completed								
3123	23030064	B.ED COLLEGE	NEED TO CHECK COLLEGE BELL - NOT WORKING NEED URGENT SERVICE	Damodharan. V.	SINGLE POLE MCB WIRE CUT RECONNECTION WORK PROBLEM SOLVED		Lakshmi. P. - Security - SIS	03/03/2023
Dept Name : Security - Stalwalt Security Servies - Electrical Maintenance Comp. Dt. : 19/01/2023 Status : Completed								
3124	23010672	HOSPITAL I FLOOR OPP TO LIFT 1	NEED TO REFIX SWITCH BOARD - DAMAGE & BROKEN [LABOUR ROOM CARITOR]	Dhakshinamoorthy. J	SWITCH BOARD SCREW REFIXING WORK PROBLEM SOLVED		Devi. K. - Security - Stalwalt Security Servies	20/01/2023
Dept Name : Skill Lab - Electrical Maintenance Comp. Dt. : 11/03/2023 Status : Completed								
3125	23030444	ICU	NEED FAN CLEANING WORK	Muthu. B.	ALL WALLMOUNTING FAN CLEANING WORK PROBLEM SOLVED		Santhiya. P. - Skill Lab	13/03/2023
Dept Name : Special Clinic - Electrical Maintenance Comp. Dt. : 02/05/2022 Status : Completed								
3126	22050011	DIALYSIS NEW UNIT IN 1ST FLOOR	FAN SLOW PROBLEM - NEED TO CHECK	Dhakshinamoorthy. J	PEDESTAL FAN SERVICE WORK & 2MFT CAPACITOR 1NO CHANGED		Nandhini.M. - Special Clinic - Reception	18/05/2022
Comp. Dt. : 21/05/2022 Status : Completed								
3127	22050799	Reception	EARTH PROBLEM , -DUE TO CABLE DAMAGE - NEED TO PASTE CABLE LINE FOR COUNTER NO 1 - NEED URGENT SERV	Lakshmanan.V.	6A SOCKET 1NO REFIXING WORK PROBLEM SOLVED		Baskar. G. - Special Clinic - Reception	23/05/2022
Comp. Dt. : 24/05/2022 Status : Completed								
3128	22050887	Reception	NEED TO CHECK POWER - COUNTER NO 1 SYSTEM NOT WORKING [ELECTRICAL FAULT]	Vijayaraghavan.B.	MCB TRIP ON TO WORK PROBLEM SOLVED		Baskar. G. - Special Clinic - Reception	25/05/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 15/06/2022 Status : Completed								
3129	22060538	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	FAN NOT WORKING - NEED URGENT SERVICE	Manikandan. M.	MCB TRIP ON TO WORK PROBLEM SOLVED		Saranya. S. - Clinical Department	15/06/2022
Comp. Dt. : 18/07/2022 Status : Completed								
3130	22070663	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	NEED TO CHANGE TUBELIGHT	Srinivasan. R.	9W LED LIGHT 2NO'S CHANG & BABY HOLDER 2NO'S CHANGED		Christy. S. - Special OPD	05/08/2022
Comp. Dt. : 19/06/2023 Status : Completed								
3131	23060661	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	NEED TO CHANGE CEILING LIGHT - NEED URGENT SERVICE	Vengadessaperumal. K.	LED LIGHT WIRE CUT RECONNECTION WORK PROBLEM SOLVED		Ramya. A. V. - Special Clinic	20/06/2023
Dept Name : Special Clinic - Dialysis - Electrical Maintenance Comp. Dt. : 31/12/2022 Status : Completed								
3132	22121408	DIALYSIS NEW UNIT IN 1ST FLOOR	PEDESTAL FAN PLUG POIN BROKEN,T NEED TO BE CHANGE	Manimaran. P.	6A 3PIN TOP 1NO CHANGED		Swathika. K. - Special Clinic - Dialysis	02/01/2023
Dept Name : Special Clinic - Office - Electrical Maintenance Comp. Dt. : 10/03/2023 Status : Completed								
3133	23030408	SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	NEED TO FIX EXTENSION BOX -WITH 3 PIN HOLDER 3 NOS	Rajan. R.	TUBE LIGHT 40W STARTER 2NO'S CHANGED		Thamizhselvi. S. - Administration	15/03/2023
Comp. Dt. : 29/04/2023 Status : Completed								
3134	23041011	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	FAN NOT WORKING	Manimaran. M.	MCB TRIP ON TO WORK PROBLEM SOLVED		Krithika. J. - Special Clinic - Office	02/05/2023
Comp. Dt. : 06/05/2023 Status : Completed								
3135	23050220	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	FAN NOT WORKING	Manimaran. M.	MCB TRIP ON TO WORK PROBLEM SOLVED		Krithika. J. - Special Clinic - Office	08/05/2023
Comp. Dt. : 26/05/2023 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
3136	23051032	SPECIAL CLINIC-1st FLOOR(above Room no. 100)	NEED TO CHECK POWER	Dhakshinamoorthy. J	AC problem - informed to AC Dept.		Monica Sales. D. - Special Clinic - Office	26/05/2023
Dept Name : Special Clinic - Reception - Electrical Maintenance Comp. Dt. : 07/12/2022 Status : Completed								
3137	22120291	Reception	IN COUNTER 2-SWITCH FIXING WORK NEED TO DO	Rajan. R.	6A SOCKET 2NO'S REFIXING WORK PROBLEM SOLVED		Geetha. J. - Special Clinic - Reception	08/12/2022
Comp. Dt. : 31/01/2023 Status : Completed								
3138	23011104	Reception	NEED REPAIRING WORK FOR FAN - NOT ROTATED & SOUND PROBLEM AT CC COUNTER	Lakshmanan.V.	WALLMOUNTING FAN SERVICE WORK PROBLEM SOLVED		Baskar. G. - Special Clinic - Reception	01/02/2023
Comp. Dt. : 30/05/2023 Status : Completed								
3139	23051203	DIALYSIS NEW UNIT IN 1ST FLOOR	FAN NOT WORKING	Manimaran. M.	PEDESTAL FAN 1NO WIRE CUT RECONNECTION WORK PROBLEM SOLVED		Baskar. G. - Special Clinic - Reception	31/05/2023
Dept Name : Special Ward - Electrical Maintenance Comp. Dt. : 02/05/2022 Status : Completed								
3140	22050044	Special Ward - A	NEED TO CHANGE TUBELIGHT FOR RESTROOM ROOM NO 4	Srinivasan. R.	9W LED LIGHT 1NO CHANGED		Arulperunjothi. M. - Special Ward	05/05/2022
Comp. Dt. : 12/05/2022 Status : Completed								
3141	22050428	SPECIAL WARD A THIRD FLOOR	IN ROOMNO.9 CEILING LIGHT NOT WORKING	Lakshmanan.V.	9W LED LIGHT 2NO'S CHANGED		Kowsalya. A. - Special Ward	14/05/2022
Comp. Dt. : 17/05/2022 Status : Completed								
3142	22050593	SPECIAL WARD---B	NEED TO CHANGE TUBELIGHT	Srinivasan. R.	TUBE LIGHT 40W STARTER 1NO CHANGED		Reena. N. - Special Ward	18/05/2022
Comp. Dt. : 20/05/2022 Status : Completed								
3143	22050740	SPECIAL WARD---B	HEATER NOT WORKING ROOM NO 22 & 23	Manikandan. M.	16A SWITCH 1NO CHANG & 1M PLATE 1NO CHANGED		Reena. N. - Special Ward	21/05/2022
3144	22050769	SPECIAL WARD - A1	TV NOT WORKING - ROOM NO 1	Manikandan. M.	SETUP BOX 1NO CHANGED		Gayathiri. V. - Special Ward	21/05/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
3145	22050772	Special Ward B	HEATER NOT WORKING	Manikandan. M.	16A SWITCH 1NO CHANG & 1M PLATE 1NO CHANGED		Reena. N. - Special Ward	21/05/2022
Comp. Dt. : 24/05/2022 Status : Completed								
3146	22050853	SPECIAL WARD---B	NEED TO REFIX SWITCH BOARD FOR ROOM NO B4-B5	Lakshmanan.V.	12x6 mica sheet fixed.		Reena. N. - Special Ward	26/05/2022
3147	22050874	SPECIAL WARD---B	TORCH LIGHT NOT WORKING	Sathishkumar. R.	TORCH LIGHT 1.5V AA BATTER 3NO'S CHANGED		Reena. N. - Special Ward	31/05/2022
3148	22050908	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	FAN NOT WORKING	Manimaran. P.	CEILING FAN CHEKING GOOD RUNNING CONDUCTION PROBLEM SOLVED		Elakkiya. S. - Special Ward	25/05/2022
3149	22050920	SPECIAL WARD - A1	NEED TO CHANGE LED LIGHT FOR ROOM NO 10	Lakshmanan.V.	2x2 fitting refixed.		Manjula. R. - Special Ward	26/05/2022
Comp. Dt. : 27/05/2022 Status : Completed								
3150	22051009	Special Ward - A	FAN SLOW PROBLEM ROOM NO 7	Muthu. B.	CEILING FAN CAPACIOTR 2.5MFT 1NO CHANGED		Arulperunjothi. M. - Special Ward	28/05/2022
3151	22051010	SPECIAL WARD - A1	NEED TO CHANGE RESTROOM TUBELIGHT FOR ROOM NO 3	Muthu. B.	18W 2PIN CFL LIGHT 2NO'S CHANGED		Sivasankari. M. - Special Ward	28/05/2022
Comp. Dt. : 31/05/2022 Status : Completed								
3152	22051135	Special Ward - A	NEED TO CHANGE TUBELIGHT	Dhakshinamoorthy. J	T5 14W LIGHT 1NO CHANGED		Revathi. S. - Special Ward	01/06/2022
Comp. Dt. : 01/06/2022 Status : Completed								
3153	22060031	Special Ward - C	NEED REFIX PLUG POINT CABLES AT FEMALE SIDE -	Lakshmanan.V.	SWITCH BOARD SCREW REFIXING WORK PROBLEM SOLVED		Abirami. G. - Special Ward	02/06/2022
3154	22060033	SPECIAL WARD---B	NEED TO REFIX SWITCH BOARD [10 NOS] DAMAGE & CABLES ARE UNFIXED	Lakshmanan.V.	MICA SHEET 2NO'S REFIXING WORK PROBLEM SOLVED		Reena. N. - Special Ward	03/06/2022
Comp. Dt. : 03/06/2022 Status : Completed								
3155	22060123	Special Ward - A	NEED TO CHANGE LED LIGHT FOR CARITOR	Lakshmanan.V.	9W LED LIGHT 1NO CHANGED		Gayathiri. V. - Special Ward	04/06/2022
3156	22060128	Special Ward - A	T V NOT WORKING - ROOM NO 3	Dhakshinamoorthy. J	SETUP BOX SETTING CHANG & TV CHEKING WORK PROBLEM SOLVED		Gayathiri. V. - Special Ward	04/06/2022
Comp. Dt. : 06/06/2022								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
3157	22060177	SPECIAL WARD---B	NEED TO CHECK ALL ELECTRICAL ITEMS FOR ALL ROOMS	Vijayaraghavan.B.	ALL ELECTRICAL ITEMS CHEKING WORK PROBLEM SOLVED		Reena. N. - Special Ward	07/06/2022
3158	22060179	SPECIAL WARD---B	NEED TO CHANGE TUBELIGHT	Vijayaraghavan.B.	NEW CEILING LED LIGTH 3NO'S CHANGED		Reena. N. - Special Ward	07/06/2022
3159	22060215	SPECIAL WARD---B	NEED FAN CLEANING WORK FOR ALL ROOMS	Dhakshinamoorthy. J	ALL CEILING FAN CLEANING WORK PROBLEM SOLVED		Jayanthi. A. - Special Ward	07/06/2022
Comp. Dt. : 11/06/2022								
Status : Completed								
3160	22060409	SPECIAL WARD - A1	NEED TO CHANGE TUBELIGHT FOR ROOM NO 3	Muthu. B.	T5 14W Tube light 2no's changed.		Prithika. V. - Special Ward	11/06/2022
Comp. Dt. : 16/06/2022								
Status : Completed								
3161	22060631	Special Ward - A	T V NOT WORKING - ROOM NO 8	Dhakshinamoorthy. J	Mode changed - Tested ok.		Bharathi. R. - Special Ward	17/06/2022
Comp. Dt. : 18/06/2022								
Status : Completed								
3162	22060674	Special Ward - C	NEED TO CHECK POWER - SYSTEM NOT WORKING [ELECTRICAL FAULT]	Vengadessaperumal. K.	MCB Trip - Trip On.		Pushpa. U. - Special Ward	18/06/2022
Comp. Dt. : 22/06/2022								
Status : Completed								
3163	22060780	Special Ward - A	NEED TO CHANGE RESTROOM LED LIGHT FOR ROOM NO 6 & CEILING LIGHT [2NOS] FOR CARITOR	Vengadessaperumal. K.	9W LED LIGHT 2NO'S CHANGED		Bharathi. R. - Special Ward	23/06/2022
Comp. Dt. : 23/06/2022								
Status : Completed								
3164	22060855	SPECIAL WARD---B	NEED TO CHANGE TUBELIGHT FOR ROOM NO 24	Lakshmanan.V.	TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Jayanthi. A. - Special Ward	24/06/2022
Comp. Dt. : 24/06/2022								
Status : Completed								
3165	22060888	SPECIAL WARD - A1	FAN PROBLEM [3NOS] - NOT WORKING IN TREATMENT ROOM , ROOM NO 9 &11	Muthu. B.	CEILING FAN CAPACITOR 2.5MFT 3NO'S CHANGED		Manjula. R. - Special Ward	25/06/2022
Comp. Dt. : 30/06/2022								
Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
3166	22061091	Special Ward - A	NEED TO CHECK ALL ELECTRICAL ITEMS FOR ALL ROOMS	Manimaran. P.	9W LED LIGHT 1NO CHANG & ALL SWITCH BOARD CHEKING WORK PROBLEM SOLVED		Bharathi. R. - Special Ward	01/07/2022
3167	22061107	SPECIAL WARD---B	TUBELIGHT & FAN NOT WORKING AT B2 & HEATER NOT WORKING AT B1	Lakshmanan.V.	WATER HEATER RESET WORK PROBLEM SOLVED		Jayanthi. A. - Special Ward	02/07/2022
3168	22061136	SPECIAL WARD---B	NEED TO CHECK FAN [FEMALE SIDE] NOT WORKING & REARRANGE SWITCH BOARD [2NOS]	Lakshmanan.V.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Abirami. G. - Special Ward	01/07/2022
Comp. Dt. : 04/07/2022 Status : Completed								
3169	22070094	SPECIAL WARD - A1	NEED TO CHECK ALL ELECTRICAL ITEMS FOR ALL ROOMS	Muthu. B.	ALL ROOM'S ELECTRICAL ITEM'S CHEKING WORK PROBLEM SOLVED		Manjula. R. - Special Ward	05/07/2022
Comp. Dt. : 07/07/2022 Status : Completed								
3170	22070284	SPECIAL WARD---B	NEED TO FIX CEILING LED LIGHT DOOR	Vijayaraghavan.B.	9W LED LIGHT 1NO CHANGED		Reena. N. - Special Ward	12/07/2022
Comp. Dt. : 08/07/2022 Status : Completed								
3171	22070328	Special Ward - C	NEED FAN CLEANING WORK FOR ALL ROOMS	Lakshmanan.V.	ALL CEILING FAN CLEANING WORK PROBLEM SOLVED		Sangeetha. S. - Special Ward	11/07/2022
3172	22070339	SPECIAL WARD---B	NEED TO CHECK ALL ROOM SWITCH BOARDS	Muthu. B.	ALL SWITCH BOARD CHEKING WORK PROBLEM SOLVED		Reena. N. - Special Ward	11/07/2022
Comp. Dt. : 11/07/2022 Status : Completed								
3173	22070406	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	NEED TO CHANGE TUBELIGHT FOR ECG ROOM	Suresh. V.	36W TUBE LIGHT 1NO CHANGED		Elakkiya. S. - Special Ward	11/07/2022
Comp. Dt. : 12/07/2022 Status : Completed								
3174	22070454	Special Ward - A	NEED TO REFIX CEILING SQUARE LIGHT - HANGING AT ROOM NO 9	Rajan. R.	18W CFL LIGHT 2NO'S CHANGED		Gayathiri. V. - Special Ward	12/07/2022
3175	22070458	Special Ward - A	T V NOT WORKING - ROOM NO 6	Rajan. R.	SETUP BOX SETTING PROBLEM SOLVED		Gayathiri. V. - Special Ward	12/07/2022
Comp. Dt. : 21/07/2022 Status : Completed								
3176	22070794	Special Ward - A	T V NOT WORKING - ROOM NO 9	Manikandan. M.	TV CHEKING WORK NO COMPLAINT		Revathi. S. - Special Ward	22/07/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 27/07/2022 Status : Completed								
3177	22071005	Special Ward - A	NEED TO CHANGE CEILING LIGHT FOR NURSE'S CABIN	Srinivasan. R.	18W CFL 2PIN LIGHT 2NO'S CHANGED		Bharathi. R. - Special Ward	29/07/2022
Comp. Dt. : 03/08/2022 Status : Completed								
3178	22080121	Special Ward - C	NEED TO CHANGE RESTROOM CFL LIGHT FOR FEMALE RESTROOM	Lakshmanan.V.	36W TUBE LIGHT 3NO'S CHANG & 40W STARTER 2NO'S CHANG & 36W CHOKE 1NO CHANGED		Abirami. G. - Special Ward	03/08/2022
Comp. Dt. : 04/08/2022 Status : Completed								
3179	22080172	SPECIAL WARD A THIRD FLOOR	REQUEST TO FIX 15 AMPS SOCKET ON ROOM SIDE	Dhakshinamoorthy. J	6A SOCKET CHEKING WORK NO COMPLAINT		Bharathi. R. - Special Ward	06/08/2022
Comp. Dt. : 09/08/2022 Status : Completed								
3180	22080315	Special Ward - A	NEED ALL ELECTRICAL ITEMS GENERAL SERVICE FOR ALL ROOMS	Dhakshinamoorthy. J	ALL ELECTRICAL ITEM'S CHEKING WORK & 9W LED LIGHT 4NO'S CHANGED		Ezhilarasi. P. - Special Ward	10/08/2022
Comp. Dt. : 11/08/2022 Status : Completed								
3181	22080409	Special Ward - A	NEED TO FIX 15 "A " SOCKET	Dhakshinamoorthy. J	16A SOCKET 1NO CHANGED		Bharathi. R. - Special Ward	12/08/2022
Comp. Dt. : 12/08/2022 Status : Completed								
3182	22080450	Special Ward - A	NEED TO CHANGE RESTROOM TUBELIGHT FOR ROOM NO 9	Vijayaraghavan.B.	9W LED Lamp 1no changed.		Bharathi. R. - Special Ward	17/08/2022
Comp. Dt. : 13/08/2022 Status : Completed								
3183	22080484	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	FAN NOT WORKING	Vengadessaperumal. K.	MCB trip - trip on.		Elakkiya. S. - Special Ward	17/08/2022
Comp. Dt. : 17/08/2022 Status : Completed								
3184	22080522	SPECIAL WARD A1-FOURTH FLOOR	IN ROOM NO.4-BATHROOM LIGHT NOT WORKING	Lakshmanan.V.	9W LED lamp 1no changed.		Muthulakshmi. A. - Special Ward	18/08/2022
Comp. Dt. : 22/08/2022								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
3185	22080732	SPECIAL WARD - A1	TV NOT WORKING - ROOM NO 3	Vengadessaperumal. K.	TV AV MODE CHANG & CHEKING WORK PROBLEM SOLVED		Manjula. R. - Special Ward	23/08/2022
3186	22080735	SPECIAL WARD - A1	HEATER NOT WORKING ROOM NO 7	Vijayaraghavan.B.	WATER HEATER 1NO RESET WORK PROBLEM SOLVED		Ahilandeswari. B. - Special Ward	23/08/2022
Comp. Dt. : 24/08/2022								
Status : Completed								
3187	22080786	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	FAN NOT WORKING	Lakshmanan.V.	MCB TRIP ON TO WORK PROBLEM SOLVED		Elakkiya. S. - Special Ward	24/08/2022
Comp. Dt. : 25/08/2022								
Status : Completed								
3188	22080831	Special Ward - A	T V NOT WORKING IN ROOM NO 2	Vengadessaperumal. K.	LED TV POWER BOARD CHANG & TV CHEKING WORK PROBLEM SOLVED		Kowsalya. A. - Special Ward	25/08/2022
Comp. Dt. : 29/08/2022								
Status : Completed								
3189	22080980	SPECIAL WARD---B	HEATER NOT WORKING ROOM NO B21	Muthu. B.	WATER HEATER 1NO RESET WORK PROBLEM SOLVED		Reena. N. - Special Ward	30/08/2022
Comp. Dt. : 02/09/2022								
Status : Completed								
3190	22090077	SPECIAL WARD - A1	FAN CLEANING WORK	Vijayaraghavan.B.	ALL CEILING FAN CLEANING WORK PROBLEM SOLVED		Manjula. R. - Special Ward	03/09/2022
Comp. Dt. : 05/09/2022								
Status : Completed								
3191	22090160	Special Ward - A	NEED TO CHECK ALL ELECTRICAL ITEMS FOR ALL ROOMS	Muthu. B.	ALL CEILING FAN CLEANING WORK PROBLEM SOLVED		Bharathi. R. - Special Ward	06/09/2022
3192	22090184	Special Ward - C	FRIDGE CABLE NOT WORKING	Vijayaraghavan.B.	MCB TRIP ON TO WORK PROBLEM SOLVED		Dhatchayani.N. - Special Ward	06/09/2022
Comp. Dt. : 13/09/2022								
Status : Completed								
3193	22090484	Special Ward - A	NEED TO CHANGE CEILING LIGHT FOR ROOM NO 3	Babu. D.	9W LED LIGHT 2NO'S CHANG & BABY HOLDER 2NO'S CHANGED		Manjula. R. - Special Ward	13/09/2022
Comp. Dt. : 17/09/2022								
Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
3194	22090661	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	FAN NOT WORKING	Rajan. R.	FAN REGULATOR WIRE CUT RECONNECTION WORK PROBLEM SOLVED		Elakkiya. S. - Special Ward	19/09/2022
Comp. Dt. :		21/09/2022						
Status :		Completed						
3195	22090844	Special Ward - A	NEED TO CHANGE NIGHT LAMP FOR ROOM NO 1	Manikandan. M.	0.5W LED NIGHT LAMP 1NO CHANGED		Bharathi. R. - Special Ward	22/09/2022
Comp. Dt. :		23/09/2022						
Status :		Completed						
3196	22090949	Special Ward - A	T V NOT WORKING - ROOM NO 9	Manikandan. M.	MCB TRIP ON TO WORK PROBLEM SOLVED		Kowsalya. A. - Special Ward	24/09/2022
Comp. Dt. :		24/09/2022						
Status :		Completed						
3197	22090961	Special Ward - A	NEED TO CHANGE RESTROOM TUBELIGHT FOR ROOM NO 3	Vijayaraghavan.B.	9W LED lamp 1no changed.		Revathi. S. - Special Ward	26/09/2022
Comp. Dt. :		26/09/2022						
Status :		Completed						
3198	22091030	SPECIAL WARD---B	NEED TO CHANGE GUNDU BULB 2 NOS FOR STRIGHT ROOM	Lakshmanan.V.	9W LED LIGHT 1NO CHANGED		Reena. N. - Special Ward	30/09/2022
Comp. Dt. :		27/09/2022						
Status :		Completed						
3199	22091093	SPECIAL WARD---B	NEED TO CHANGE NIGHT LAMP FOR STRIGHT ROOMS [2NOS]	Lakshmanan.V.	ANGLE HOLDER 2NO'S CHANG & 0.5W LED NIGHT LAMP 2NO'S CHANG & LINE CONNECTION WORK PROBLEM SOLVED		Reena. N. - Special Ward	06/10/2022
Comp. Dt. :		28/09/2022						
Status :		Completed						
3200	22091120	SPECIAL WARD - A1	TV NOT WORKING ROOM NO 7	Lakshmanan.V.	MCB TRIP ON TO WORK PROBLEM SOLVED		Revathi. S. - Special Ward	29/09/2022
Comp. Dt. :		10/10/2022						
Status :		Completed						
3201	22100206	SPECIAL WARD---B	NEED TO REARRANGE SWITCH BOX - DAMAGE	Muthu. B.	4M MICA SHEET 1NO REFIXING WORK PROBLEM SOLVED		Kaviya. M. - Special Ward	11/10/2022
Comp. Dt. :		11/10/2022						
Status :		Completed						


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
3202	22100295	Special Ward - A	NEED TO CHANGE TUBELIGHT FOR ROOM NO 9	Dhakshinamoorthy. J	30W LED LIGHT 1NO REFIXNG WORK PROBLEM SOLVED		Bharathi. R. - Special Ward	12/10/2022
Comp. Dt. :		12/10/2022						
Status :		Completed						
3203	22100327	Special Ward - A	CORRIDOR TUBELIGHT NOT WORKING	Dhakshinamoorthy. J	9W LED LIGHT 1NO CHANGED		Bharathi. R. - Special Ward	12/10/2022
Comp. Dt. :		13/10/2022						
Status :		Completed						
3204	22100421	SPECIAL WARD---B	NEED TO CHANGE TUBELIGHT	Muthu. B.	9W LED LIGHT 2NO'S CHANG & 0.5W LED LIGHT 1NO CHANGED		Reena. N. - Special Ward	13/10/2022
Comp. Dt. :		29/10/2022						
Status :		Completed						
3205	22100941	SPECIAL WARD - A1	TUBELIGHT NOT WORKING IN ROOM NO.2	Dhakshinamoorthy. J	9W TUBE LIGHT 1NO CHANGED		Ragavi. P. - Special Ward	31/10/2022
Comp. Dt. :		31/10/2022						
Status :		Completed						
3206	22100999	SPECIAL WARD - A1	ALL FANS CLEANING WORK	Lakshmanan.V.	ALL CEILING FAN CLEANING WORK PROBLEM SOLVED		Ragavi. P. - Special Ward	04/11/2022
3207	22101011	SPECIAL WARD---B	BED NO-20,HEATER NOT WORKING	Muthu. B.	WATER HEATER THERMO CUT 1NO CHANG & HEATER CHEKING WORK PROBLEM SOLVED		Ahilandeswari. B. - Special Ward	02/11/2022
Comp. Dt. :		07/11/2022						
Status :		Completed						
3208	22110233	SPECIAL WARD - A1	NEED TV RECHARGE	Vaithianathan.M	TV SETUP BOX RESET WORK PROBLEM SOLVED		Sivapriya. P. - Special Ward	08/11/2022
3209	22110252	SPECIAL WARD -B IN FOURTH FLOOR	IN ROOM NO.20 WATER HEATER NOT WORKING	Lakshmanan.V.	WATER HEATER TRIP ON TO WORK PROBLEM SOLVED		Reena. N. - Special Ward	09/11/2022
3210	22110254	SPECIAL WARD A1-FOURTH FLOOR	IN ROOMNO.11 FAN WORKING SLOWLY	Lakshmanan.V.	CEILING FAN CAPACITOR 2.5MFT 1NO CHANGED		Manjula. R. - Special Ward	08/11/2022
Comp. Dt. :		11/11/2022						
Status :		Completed						
3211	22110464	SPECIAL WARD A THIRD FLOOR	IN ROOM NO.6-TV NOT WORKING	Dhakshinamoorthy. J	TV SETUP BOX CHEKING WORK PROBLEM SOLVED		Bharathi. R. - Special Ward	14/11/2022
Comp. Dt. :		15/11/2022						
Status :		Completed						
3212	22110596	SPECIAL WARD A THIRD FLOOR	IN ROOM NO.7-1 NIGHT LAMP NOT WORKING	Dhakshinamoorthy. J	9W LED LIGHT 1NO CHANGED		Bharathi. D. - Special Ward	17/11/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 17/11/2022 Status : Completed								
3213	22110697	SPECIAL WARD A1-FOURTH FLOOR	IN ROOM NO.5 AND 2 WATER HEATER NOT WORKING	Lakshmanan.V.	WATER HEATER CHEKING RESET WORK PROBLEM SOLVED		Manjula. R. - Special Ward	18/11/2022
Comp. Dt. : 21/11/2022 Status : Completed								
3214	22110849	SPECIAL WARD -C IN FOURTH FLOOR	WATER HEATER NOT WORKING IN REST ROOM ON BOTH SIDES	Muthu. B.	WATER HEATER NEW 2KW COIL 1NO CHANG & LINE CONNECTION WORK PROBLEM SOLVED		Archanadevi. A. - Special Ward	22/11/2022
Comp. Dt. : 29/11/2022 Status : Completed								
3215	22111254	SPECIAL WARD -C IN FOURTH FLOOR	IN FEMALE SIDE-1 TUBELIGHT NOT WORKING	Muthu. B.	TUBE LIGHT 40W STARTER 1NO CHANGED		Hemachandra. P. - Special Ward	30/11/2022
Comp. Dt. : 05/12/2022 Status : Completed								
3216	22120189	SPECIAL WARD -C IN FOURTH FLOOR	1 TUBELIGHT NOT WORKING	Muthu. B.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANG & 40W CHOKE 1NO CHANGED		Hemachandra. P. - Special Ward	06/12/2022
3217	22120204	SPECIAL WARD A1-FOURTH FLOOR	IN ROOM NO.3-TV NOT WORKING	Muthu. B.	TV SETUP BOX WIRE LOOSE RECONNECTION WORK PROBLEM SOLVED		Sivapriya. P. - Special Ward	06/12/2022
Comp. Dt. : 09/12/2022 Status : Completed								
3218	22120424	Obstetrics - Ward 208	NEED TO CHECK CARITOR SWITCH - SPARK	Thillaikumar. R.	MCB TRIP ON TO WORK PROBLEM SOLVED		Bharathi. R. - Special Ward	10/12/2022
Comp. Dt. : 12/12/2022 Status : Completed								
3219	22120496	Special Ward - C	(2 NOS)TUBELIGHT NOT WORKING FOR DOCTORS ROOM	Muthu. B.	20W tube light 2feet 1no changed.		Kavipriya. P. - Special Ward	12/12/2022
Comp. Dt. : 13/12/2022 Status : Completed								
3220	22120605	Special Ward - C	HEATER NOT WORKING - FEMALE SIDE	Vijayaraghavan.B.	WATER HEATER COIL SET SERVICE WORK & HEATER REFIXING WORK & LINE CONNECTION WORK PROBLEM SOLVED		Divya. M. - Special Ward	19/12/2022
Comp. Dt. : 14/12/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
3221	22120620	ENT Ward - 410	HEATER NOT WORKING - WARD NO 410	Vijayaraghavan.B.	WATER HEATER COIL SET SERVICE WORK & HEATER REFIXING & LINE CONNECTION WORK PROBLEM SOLVED		Hemachandra. P. - Special Ward	19/12/2022
3222	22120628	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	NEED TO CHECK CEILING LIGHT - RAIN WATER LEAKAGE [DR. RAMYA MADAM ROOM]	Dhakshinamoorthy. J	18W LED LIGHT 1NO REMOVING WORK & A/C CHLLER WATER LEAKE		Elakkiya. S. - Special Ward	15/12/2022
Comp. Dt. :		15/12/2022						
Status :		Completed						
3223	22120682	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	NEED TO CHECK AC NEAR ELECTRICAL CABLE HOLE - WATER LEAKAGE AT DR. RAMYA MADAM ROOM	Manimaran. P.	A/C CHILLER WATER LEAKE		Dhatchayani.N. - Special Ward	17/12/2022
3224	22120694	SPECIAL WARD---B	NEED TO CHECK WATER HEATER SWITCH - SHOCK PROBLEM - ROOM NO 22,23 & 24	Lakshmanan.V.	WATER HEATER NEW 2KW COIL 1NO CHANG & HEATER LINE CONNECTION WORK PROBLEM SOLVED		Kavipriya. P. - Special Ward	19/12/2022
Comp. Dt. :		26/12/2022						
Status :		Completed						
3225	22121135	Special Ward - C	TUBELIGHT NOT WORKING IN ROOM NO 409	Vengadessaperumal. K.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1 NO CHANGED		Pushpa. U. - Special Ward	26/12/2022
Comp. Dt. :		27/12/2022						
Status :		Completed						
3226	22121218	SPECIAL WARD A1-FOURTH FLOOR	IN ROOM NO.7-WATER HEATER NOT WORKING	Dhakshinamoorthy. J	WATER HEATER RESET WORK PROBLEM SOLVED		Ragavi. P. - Special Ward	28/12/2022
Comp. Dt. :		02/01/2023						
Status :		Completed						
3227	23010011	SPECIAL WARD A1-FOURTH FLOOR	IN ROOM NO.9 AND 10-WATER HEATER NOT WORKING	Muthu. B.	Heater reset - OK.		Prithika. V. - Special Ward	02/01/2023
3228	23010020	SPECIAL WARD A1-FOURTH FLOOR	IN ROOM NO.3-SHOW LIGHT NOT WORKING	Muthu. B.	9W LED lamp 1no changed & Water heater reset.		Manjula. R. - Special Ward	02/01/2023
Comp. Dt. :		03/01/2023						
Status :		Completed						
3229	23010059	SPECIAL WARD---B	HEATER NOT WORKING IN ROOM NO B3	Lakshmanan.V.	WATER HEATER RESET WORK PROBLEM SOLVED		Sangeetha. S. - Special Ward	03/01/2023
3230	23010063	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	FAN CLEANING WORK	Lakshmanan.V.	CEILING FAN CLEANING WORK PROBLEM SOLVED		Elakkiya. S. - Special Ward	03/01/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
3231	23010118	SPECIAL CLINIC-1st FLOOR(above Room no. 100)	FAN CLEANING WORK	Lakshmanan.V.	ALL CEILING FAN CLEANING WORK PROBLEM SOLVED		Elakkiya. S. - Special Ward	04/01/2023
		Comp. Dt. : 04/01/2023 Status : Completed						
3232	23010170	SPECIAL WARD A1-FOURTH FLOOR	in room no.5 ceiling led light not working	Lakshmanan.V.	T5 14W CFL LIGHT 2NO'S CHANGED		Manjula. R. - Special Ward	05/01/2023
3233	23010171	SPECIAL WARD A1-FOURTH FLOOR	IN ROOM NO.5-SWITCH BOARD PLUG POINT UNPLUGED	Lakshmanan.V.	T5 14W CFL LIGHT 2NO'S CHANGED		Manjula. R. - Special Ward	05/01/2023
		Comp. Dt. : 06/01/2023 Status : Completed						
3234	23010250	SPECIAL WARD---B	ROOM NOS-B1, B2 AND CT POST OPP WARD-HEATER NOT WORKING	Rajan. R.,Thillaikumar. R.,Sathishkumar. R.	WATER HEATER 3NO'S RESET WORK & HEATER CHEKING WORK PROBLEM SOLVED		Jayanthi. A. - Special Ward	06/01/2023
		Comp. Dt. : 07/01/2023 Status : Completed						
3235	23010321	SPECIAL WARD A1-FOURTH FLOOR	IN ROOM NO.7 AND 9-BATHROOM LIGHT NEED TO BE FIX	Dhakshinamoorthy. J	LIGHT FITTING WIRE CUT RECONNECTION WORK PROBLEM SOLVED		Bharathi. R. - Special Ward	07/01/2023
		Comp. Dt. : 09/01/2023 Status : Completed						
3236	23010334	SPECIAL WARD A1-FOURTH FLOOR	IN ROOM NO.1-1 TUBELIGHT NOT WORKING	Rajan. R.	9W LED LIGHT 1NO CHANGED		Sivapriya. P. - Special Ward	09/01/2023
		Comp. Dt. : 10/01/2023 Status : Completed						
3237	23010386	SPECIAL WARD -B IN FOURTH FLOOR	IN ROOM B5.1 TUBELIGHT NOT WORKING AND FAN REGULATOR NOT WORKING	Muthu. B.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Sangeetha. S. - Special Ward	11/01/2023
		Comp. Dt. : 14/01/2023 Status : Completed						
3238	23010598	Special Ward - A	TV NOT WORKING - ROOM NO.9	Vijayaraghavan.B.	6A 2PIN TOP WIRE LOOSE RECONNECTION WORK PROBLEM SOLVED		Gayathri. P. - Special Ward	18/01/2023
		Comp. Dt. : 20/01/2023 Status : Completed						
3239	23010713	Special Ward - A	T V NOT WORKING - ROOM NO 6	Damodharan. V.	32" LED TV 1NO REMOVING TO ELECTRICAL ROOM		Ezhilarasi. P. - Special Ward	21/01/2023

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 23/01/2023 Status : Completed								
3240	23010806	SPECIAL WARD---B	HEATER NOT WORKING - ROOM B1-B2-B3	Dhakshinamoorthy. J	WATER HEATER 1NO RESET WORK PROBLEM SOLVED		Ahilandeswari. B. - Special Ward	24/01/2023
Comp. Dt. : 27/01/2023 Status : Completed								
3241	23010957	SPECIAL WARD A1-FOURTH FLOOR	IN ROOM NO.8-TV NOT WORKING	Lakshmanan.V.	SETUP BOX SETTING PROBLEM SOLVED		Ragavi. P. - Special Ward	30/01/2023
Comp. Dt. : 28/01/2023 Status : Completed								
3242	23010999	SPECIAL WARD---B	HEATER NOT WORKING ROOM NO 2	Lakshmanan.V.	WATER HEATER 1NO RESET WORK PROBLEM SOLVED		Sangeetha. S. - Special Ward	30/01/2023
3243	23011017	Special Ward - A	TV REMOTE NOT WORKING & TV NOT WORKING IN ROOM NO 8	Lakshmanan.V.	SETUP BOX SETTING RESET WORK PROBLEM SOLVED SOLVED		Revathi. S. - Special Ward	30/01/2023
Comp. Dt. : 30/01/2023 Status : Completed								
3244	23011045	Special Ward - A	TV NOT WORKING ROOM NO 1	Manimaran. M.	LED TV CHEKING WORK NO PROBLEM SOLVED		Bharathi. R. - Special Ward	31/01/2023
3245	23011071	SPECIAL WARD---B	NEED TO CHANGE TUBELIGHT FOR DOCTOR'S ROOM	Muthu. B.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Sangeetha. S. - Special Ward	31/01/2023
Comp. Dt. : 03/02/2023 Status : Completed								
3246	23020090	SPECIAL WARD---B	RESTROOM HEATER NOT WORKING	Lakshmanan.V.	WATER HEATER RESET WORK PROBLEM SOLVED		Sangeetha. S. - Special Ward	04/02/2023
Comp. Dt. : 06/02/2023 Status : Completed								
3247	23020159	SPECIAL WARD---B	HEATER NOT WORKING	Srinivasan. R.	WATER HEATER 2NO'S RESET WORK PROBLE SOLVED		Sangeetha. S. - Special Ward	06/02/2023
Comp. Dt. : 08/02/2023 Status : Completed								
3248	23020295	SPECIAL WARD - A1	WATER HEATER NOT WORKING IN ROOM NO. 2, 3	Srinivasan. R.	water heater 2no's reset work problem solved		Sivapriya. P. - Special Ward	09/02/2023
Comp. Dt. : 09/02/2023 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
3249	23020335	SPECIAL WARD---B	NEED TO FIX SWITCH BOX	Sathishkumar. R.	ALL ROOM SWITCH BOARD CHEKING WORK PROBLEM SOLVED		Sangeetha. S. - Special Ward	09/02/2023
Comp. Dt. : 15/02/2023 Status : Completed								
3250	23020592	SPECIAL WARD - A1	TV NOT WORKING ROOM NO 3	Srinivasan. R.	TV SETUP BOX RESET WORK PROBLEM SOLVED		Manjula. R. - Special Ward	16/02/2023
3251	23020593	SPECIAL WARD - A1	HEATER NOT WORKING	Dhakshinamoorthy. J	WATER HEATER RESET WORK PROBLEM SOLVED		Manjula. R. - Special Ward	16/02/2023
Comp. Dt. : 16/02/2023 Status : Completed								
3252	23020644	Special Ward - A	NURSES STATION POWER SUPPLY PROBLEM	Manikandan. M.	MCB TRIP ON TO WORK PROBLEM SOLVED		Gayathri. P. - Special Ward	17/02/2023
Comp. Dt. : 20/02/2023 Status : Completed								
3253	23020749	Paediatrics - Ward 309	NEED TO REFIX SWITCH BOX FOR DEMO ROOM	Vijayaraghavan.B.	DEMO ROOM SWITCH BOARD SCREW REFIXING WORK PROBLEM SOLVED		Hemachandra. P. - Special Ward	21/02/2023
3254	23020752	SPECIAL WARD---B	HEATER NOT WORKING ROOM NO B-1	Srinivasan. R.	WATER HEATER THERMO CUT 1NO CHANG & HEATER 1NO CHEKING WORK PROBLEM SOLVED		Sangeetha. S. - Special Ward	22/02/2023
Comp. Dt. : 21/02/2023 Status : Completed								
3255	23020784	SPECIAL WARD---B	NEED TO CHANGE TUBELIGHT FOR ROOM NO B4- B5	Manikandan. M.	WATER HEATER THREMO CUT 1NO CHANG & HEATER CHEKING WORK PROBLEM SOLVED		Sangeetha. S. - Special Ward	22/02/2023
Comp. Dt. : 22/02/2023 Status : Completed								
3256	23020837	Special Ward - A	ROOM NO-5,ONE CEILING TUBELIGHT SCREW FIXING WORK	Damodharan. V.	CEILING LIGHT LOVER REFIXING WORK PREOBLEM SOLVED		Bharathi. R. - Special Ward	23/02/2023
Comp. Dt. : 23/02/2023 Status : Completed								
3257	23020881	Special Ward - C	HEATER [BOTH SIDE] NOT WORKING	Muthu. B.	WATER HEATER NEW COIL SET 1NO CHANG & 2KW COIL 1NO CHANG & LINE CONNECTION WORK PROBLEM SOLVED		Pushpa. U. - Special Ward	16/03/2023
3258	23020897	SPECIAL WARD---B	X RAY LOBBY NOT WORKING	Vengadessaperumal. K.	11W CFL LIGHT 1NO CHANGED		Sangeetha. S. - Special Ward	23/02/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
3259	23020912	Special Ward - C	HEATER NOT WORKING	Manimaran. P.	WATER HEATER 1NO SERVICE WORK & HEATER REFIXING WORK PROBLEM SOLVED		Hemachandra. P. - Special Ward	02/03/2023
Comp. Dt. : 27/02/2023 Status : Completed								
3260	23020999	Special Ward - A	NEED TO CHANGE CEILING LIGHT FOR ROOM NO 1	Dhakshinamoorthy. J	18W CFL LIGHT 2PIN 2NO'S CHANGED		Ragavi. P. - Special Ward	28/02/2023
3261	23021017	SPECIAL WARD - A1	NEED TO REFIXPLUG POINT FOR ROOM NO 1,5 & 10	Vijayaraghavan.B.	6A SOCKET 1NO REFIXING WORK & SWITCH BOARD SCREW REFIXING WORK PROBLEM SOLVED		Manjula. R. - Special Ward	28/02/2023
3262	23021041	Special Ward - A	TV NOT WORKING - ROOM NO 9	Muthu. B.	TV CHEKING WORK NO COMPLAINT PROBLEM SOLVED		Gayathri. P. - Special Ward	28/02/2023
Comp. Dt. : 01/03/2023 Status : Completed								
3263	23030051	SPECIAL WARD - A1	TV NOT WORKING ROOM NO 3 & 10	Manimaran. M.	R.NO10 TV SETUP BOX 1NO SERVICE WORK REFIXING WORK PROBLEM SOLVED		Sivapriya. P. - Special Ward	09/03/2023
Comp. Dt. : 02/03/2023 Status : Completed								
3264	23030067	Special Ward - C	HEATER AND TUBELIGHT NOT WORKING AT FEMALE SIDE RESTROOM	Srinivasan. R.	WATER HEATER 1NO SERVICE WORK & REFIXING WORK & 36W CHOKE 1NO CHANGED		Keerthana. N. - Special Ward	04/03/2023
Comp. Dt. : 04/03/2023 Status : Completed								
3265	23030179	SPECIAL WARD - A1	NEED TO CLOSE CEILING LIGHT AT NURSE'S STATION	Rajan. R.	WORKSHOP DEPT COPLAINT		Manjula. R. - Special Ward	06/03/2023
3266	23030181	SPECIAL WARD - A1	NEED TO CHECK ALL ELECTRICAL ITEMS AT ALL ROOMS	Rajan. R.	ALL ELECTRICAL ITEMS CHEKING WORK PROBLEM SOLVED		Manjula. R. - Special Ward	06/03/2023
Comp. Dt. : 07/03/2023 Status : Completed								
3267	23030271	SPECIAL WARD - A1	NEED TO CHANGE AC CABLE	Muthu. B.	16A 3PIN TOP 1NO CHANGED		Manjula. R. - Special Ward	08/03/2023
Comp. Dt. : 11/03/2023 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
3268	23030442	SPECIAL WARD---B	NEED TO CHANGE TUBELIGHT FOR ROOM NO B3-B4	Srinivasan. R.	TUBE LIGHT 40W STARTER 2NO'S CHANG & SIDE HOLDER 1NO CHANGED		Sangeetha. S. - Special Ward	13/03/2023
Comp. Dt. : 13/03/2023 Status : Completed								
3269	23030499	Special Ward - A	NEED TO CHANGE REST ROOM CFL LIGHT FOR ROOM NO 8	Srinivasan. R.	9W LED LIGHT 1NO CHANGED		Bharathi. R. - Special Ward	14/03/2023
Comp. Dt. : 15/03/2023 Status : Completed								
3270	23030599	SPECIAL WARD---B	NEED TO CHECK CALLING BELL BOARD - NOT WORKING	Manikandan. M.	CALLING CHEKING WORK NO COMPLAINT PROBLEM SOLVED		Sangeetha. S. - Special Ward	25/05/2023
3271	23030624	SPECIAL WARD---B	HEATER NOT WORKING - ROOM NO B1-B2	Dhakshinamoorthy. J	WATER HEATER 1NO RESET WORK PROBLEM SOLVED		Sangeetha. S. - Special Ward	16/03/2023
Comp. Dt. : 16/03/2023 Status : Completed								
3272	23030636	SPECIAL WARD - A1	FAN NOT WORKING ROOM NO 2	Muthu. B.	wire problem - solved.		Manjula. R. - Special Ward	18/03/2023
Comp. Dt. : 20/03/2023 Status : Completed								
3273	23030766	SPECIAL WARD---B	HEATER NOT WORKING - ROOM NO B20 TO B 24	Rajan. R.	WATER HEATER 2NO'S RESET WORK PROBLEM SOLVED		Ahilandeswari. B. - Special Ward	20/03/2023
3274	23030767	SPECIAL WARD---B	NEED TO CHANGE TUBELIGHT FOR ENTRANCE	Rajan. R.	36W CFL 4PIN LIGHT 3NO'S CHANG & LINE CONNECTION WORK PROBLEM SOLVED		Ahilandeswari. B. - Special Ward	20/03/2023
Comp. Dt. : 21/03/2023 Status : Completed								
3275	23030840	SPECIAL WARD - A1	NEED TO CHANGE RESTROOM TUBELIGHT FOR ROOM NO 9	Lakshmanan.V.	18W 2PIN CFL LIGTHT 1NO CHANGED		Prithika. V. - Special Ward	22/03/2023
3276	23030877	SPECIAL WARD - A1	NEED TO CHANGE CENTRE LIGHT FOR ROOM NO 1	Rajan. R.	9W LED LIGHT 1NO CHANGED		Prithika. V. - Special Ward	22/03/2023
Comp. Dt. : 23/03/2023 Status : Completed								
3277	23030937	Paediatrics - Ward 310	FAN NOT WORKING IN TREATMENT ROOM	Muthu. B.	Fan capacitor 2.5mfd 1no changed.		Hemachandra. P. - Special Ward	23/03/2023
Comp. Dt. : 24/03/2023 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
3278	23030991	SPECIAL WARD---B	NEED TO CHANGE "0 WATT" LIGHT FOR ROOM NO B19-B20	Thillaikumar. R.	Night lamp 1no changed.		Sangeetha. S. - Special Ward	24/03/2023
Comp. Dt. : 25/03/2023 Status : Completed								
3279	23031062	Special Ward - C	NEED FAN CLEANING WORK	Dhakshinamoorthy. J	Fan cleaned.		Kavipriya. P. - Special Ward	30/03/2023
Comp. Dt. : 29/03/2023 Status : Completed								
3280	23031235	Special Ward - C	NEED TO CHANGE TUBELIGHT FOR PANTRY ROOM	Vijayaraghavan.B.	Tube light starter 1no changed.		Muthulakshmi. A. - Special Ward	30/03/2023
Comp. Dt. : 30/03/2023 Status : Completed								
3281	23031312	SPECIAL WARD - A1	NEED TO CHANGE CEILING LIGHT - ROOM NO 5	Muthu. B.	3x36W 2x2 fitting problem - spare 2x2 fitting changed.		Manjula. R. - Special Ward	01/04/2023
3282	23031325	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	NEED TO CHANGE CEILING LIGHT	Muthu. B.	Light point Wire problem - solved.		Elakkiya. S. - Special Ward	31/03/2023
Comp. Dt. : 04/04/2023 Status : Completed								
3283	23040106	Special Ward - C	FAN NOT WORKING - ROOM NO 410	Manikandan. M.	Fan capacitor 2.5mfd 1no changed.		Divya. M. - Special Ward	05/04/2023
Comp. Dt. : 06/04/2023 Status : Completed								
3284	23040210	SPECIAL WARD - A1	T V NOT WORKING - ROOM NO 3	Manikandan. M.	Setup box adapter problem - solved.		Manjula. R. - Special Ward	08/04/2023
Comp. Dt. : 08/04/2023 Status : Completed								
3285	23040246	SPECIAL WARD - A1	T V NOT WORKING - ROOM NO 3	Manimaran. M.	Set top box connector problem. Spare set top fixed.		Manjula. R. - Special Ward	11/04/2023
Comp. Dt. : 10/04/2023 Status : Completed								
3286	23040273	SPECIAL WARD - A1	TOWARDS FALSE CEILING REPAIRING WORK - NEED TO REMOVE [AFTER COMPLETION OF WORK] & REFIX ALL RE	Muthu. B.	2Feet LED fitting 11no's fixed.		Manjula. R. - Special Ward	10/04/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 11/04/2023 Status : Completed								
3287	23040342	SPECIAL WARD - A1	NEED TO CHECK FAN - SOUND PROBLEM - ROOM NO 1	Muthu. B.	Fan checked - ok.		Prithika. V. - Special Ward	12/04/2023
Comp. Dt. : 13/04/2023 Status : Completed								
3288	23040397	SPECIAL WARD - A1	T V NOT WORKING ROOM NO 3	Vijayaraghavan.B.	TV SETUP BOX RESET WORK PROBLEM SOLVED		Manjula. R. - Special Ward	17/04/2023
Comp. Dt. : 17/04/2023 Status : Completed								
3289	23040500	Special Ward - A	NEED TO FIXING LIGHT FOR ROOM NO 7	Vijayaraghavan.B.	CFL LIGHT FITTING 1NO REFIXING WORK PROBLEM SOLVED		Revathi. S. - Special Ward	17/04/2023
3290	23040502	SPECIAL WARD---B	NEED TO CHANGE RESTROOM TUBELIGHT FOR B1 - B2	Vijayaraghavan.B.	20W TUBE LIGHT 1NO CHNGED		Sangeetha. S. - Special Ward	17/04/2023
Comp. Dt. : 20/04/2023 Status : Completed								
3291	23040625	Special Ward - A	WATER HEATER NOT WORKING - ROOM NO 3	Vijayaraghavan.B.	WATER HEATER 1NO RESET WORK PROBLEM SOLVED		Bharathi. R. - Special Ward	20/04/2023
3292	23040633	Special Ward - A	CEILING LIGHT NOT WORKING - ROOM NO 7	Muthu. B.	T5 14W CFL LIGHT 2NO'S CHANGED		Bharathi. R. - Special Ward	20/04/2023
Comp. Dt. : 24/04/2023 Status : Completed								
3293	23040755	Special Ward - C	NEED TO CHECK WATER HEATER - LEAKAGE AT ROOM NO 409	Muthu. B.	WATER HEATER 1NO RESET WORK PROBLEM SOLVED		Muthulakshmi. A. - Special Ward	26/04/2023
Comp. Dt. : 27/04/2023 Status : Completed								
3294	23040895	SPECIAL WARD - A1	TV NOT WORKING - ROOM NO 3	Vijayaraghavan.B.	TV CHEKING WORK PROBLEM SOLVED		Shalini. S. - Special Ward	28/04/2023
Comp. Dt. : 28/04/2023 Status : Completed								
3295	23040979	SPECIAL WARD - A1	PLUG POINT NOT WORKING ROOM NO 1	Muthu. B.	SWITCH BOARD REFIXNING WORK PROBLEM SOLVED		Manjula. R. - Special Ward	29/04/2023
3296	23040980	SPECIAL WARD - A1	NEED TO REFIX CEILING LIGHT - ROOM NO 2	Muthu. B.	6A SWITCH 1NO CHANGED		Manjula. R. - Special Ward	29/04/2023
Comp. Dt. : 02/05/2023 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
3297	23050022	Paediatrics - Ward 310	FAN NOT WORKING - FEMALE MEDICAL WARD]	Vijayaraghavan.B.	CEILING FAN CAPACITOR 2.5MFT 1NO CHANGED		Hemachandra. P. - Special Ward	03/05/2023
3298	23050073	Paediatrics - Ward 310	NEED TO CHANGE TUBELIGHT [FEMALE MEDICAL WARD 310]	Lakshmanan.V.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Pushpa. U. - Special Ward	04/05/2023
Comp. Dt. : 03/05/2023 Status : Completed								
3299	23050098	SPECIAL WARD---B	HEATER NOT WORKING B4 - B5	Dhakshinamoorthy. J	WATER HEATER 1NO RSET WORK PROBLEM SOLVED		Sangeetha. S. - Special Ward	04/05/2023
3300	23050106	SPECIAL WARD - A1	TV NOT WORKING ROOM NO 10	Sathishkumar. R.	TV SWITCH ON THE WORK PROBLEM SOLVED		Manjula. R. - Special Ward	04/05/2023
3301	23050112	CTVS - MALE PRE-OP ROOM INSIDE SPECIAL WARD B	HEATER NOT WORKING	Lakshmanan.V.	WATER HEATER NEW COIL 2KW 1NO CHANGED		Sangeetha. S. - Special Ward	04/05/2023
Comp. Dt. : 04/05/2023 Status : Completed								
3302	23050133	Special Ward - A	NEED TO CHECK ALL ROOM ENTRANCE EMERGENCY LIGHT - NOT WORKING	Rajan. R.	MCB TRIP ON TO WORK PROBLEM SOLVED		Ragavi. P. - Special Ward	06/05/2023
Comp. Dt. : 05/05/2023 Status : Completed								
3303	23050217	Special Ward - A	NEED TO CHANGE RESTROOM LIGHT FOR ROOM NO 2	Rajan. R.	9W LED LIGHT 1NO CHANGED		Gayathri. P. - Special Ward	06/05/2023
Comp. Dt. : 08/05/2023 Status : Completed								
3304	23050329	SPECIAL WARD - A1	T V NOT WORKING - ROOM NO 3	Lakshmanan.V.	LED TV SWITCH ON THE WORK PROBLEM SOLVED		Manjula. R. - Special Ward	09/05/2023
3305	23050330	SPECIAL WARD - A1	HEATER NOT WORKING - ROOM NO 5	Lakshmanan.V.	WATER HEATER 1NO RESET WORK PROBLEM SOLVED		Manjula. R. - Special Ward	09/05/2023
3306	23050332	SPECIAL WARD---B	WATER HEATER NOT WORKING ROOM NO B1-B2-B3	Muthu. B.	WATER HEATER 1NO RESET WORK PROBLEM SOLVED		Ahilandeswari. B. - Special Ward	10/05/2023
Comp. Dt. : 12/05/2023 Status : Completed								
3307	23050502	SPECIAL WARD---B	NEED TO FIX TUBELIGHT FOR CTVS ROOM	Manimaran. P.	36W TUBE LIGHT 1NO CHANGED		Sangeetha. S. - Special Ward	13/05/2023
3308	23050522	SPECIAL WARD - A1	NEED TO CHANGE CEILING LIGHT - ROOM NO 1	Damodharan. V.	9W LED lamp 1no changed.		Manjula. R. - Special Ward	15/05/2023
Comp. Dt. : 15/05/2023 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
3309	23050572	SPECIAL WARD - A1	HEATER NOT WORKING - ROOM NO 7	Muthu. B.	WATER HEATER 1NO REMOVING TO ELECTRICAL ROOM. Alternative Water heater fixed.		Manjula. R. - Special Ward	27/05/2023
3310	23050594	Female Ortho - Ward 402	FAN SLOW PROBLEM	Dhakshinamoorthy. J	TUBE LIGHT 40W STARTER 1NO CHANG & FAN CAPACITOR 2.5MFT 1NO CHANGED		Suganya. D. - Special Ward	16/05/2023
Comp. Dt. : 16/05/2023 Status : Completed								
3311	23050670	Paediatrics - Ward 310	NEED TO CHANGE TUBELIGHT FOR NURSE'S STATION	Muthu. B.	36W TUBE LIGHT 1NO CHANG & 36W TUBE LIGHT 2NO'S CHANG & 40W STARTER 1NO CHANGED		Hemachandra. P. - Special Ward	17/05/2023
Comp. Dt. : 17/05/2023 Status : Completed								
3312	23050676	Paediatrics - Ward 308	NEED TO RE ARRANGE CABLES INSIDE SWITCH BOARD	Srinivasan. R.	SWITCH BOARD 1NO SCREW REFIXING WORK PROBLEM SOLVED		Suganya. D. - Special Ward	17/05/2023
Comp. Dt. : 25/05/2023 Status : Completed								
3313	23051000	SPECIAL WARD - A1	HEATER NOT WORKING - ROOM NO 7	Vijayaraghavan.B.	Heater reset - ok.		Shalini. S. - Special Ward	26/05/2023
Comp. Dt. : 29/05/2023 Status : Completed								
3314	23051123	Special Ward - A	FAN NOT WORKING	Thillaikumar. R.	CEILING FAN 1NO REFIXING WORK PROBLEM SOLVED		Gayathri. P. - Special Ward	30/05/2023
Comp. Dt. : 30/05/2023 Status : Completed								
3315	23051178	Special Ward - A	TV NOT WORKING ROOM NO 9	Manimaran. M.	TV SETUP BOX RESET WORK PROBLEM SOLVED		Revathi. S. - Special Ward	31/05/2023
3316	23051200	Special Ward - A	IN ROOM NO-1,TV NOT WORKING	Manimaran. M.	TV SETUP BOX RESET WORK PROBLEM SOLVED		Keerthana. N. - Special Ward	31/05/2023
Comp. Dt. : 01/06/2023 Status : Completed								
3317	23060038	CTVS - MALE PRE-OP ROOM INSIDE SPECIAL WARD B	HEATER NOT WORKING	Manikandan. M.	WATER HEATER 1NO RESET WORK PROBLEM SOLVED		Sangeetha. S. - Special Ward	02/06/2023
Comp. Dt. : 06/06/2023 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
3318	23060182	Special Ward - C	NEED TO CHANGE TUBELIGHT 3 NOS	Muthu. B.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 2NO'S CHANGED		Muthulakshmi. A. - Special Ward	07/06/2023
Comp. Dt. : 10/06/2023 Status : Completed								
3319	23060355	SPECIAL WARD - A1	NEED TO CHECK & REFIX PLUG POINT - NOT WORKING	Vijayaraghavan.B.	6A SWITCH 1NO CHANG & 6A SOCKET 1NO CHANGED		Manjula. R. - Special Ward	10/06/2023
Comp. Dt. : 13/06/2023 Status : Completed								
3320	23060448	SPECIAL WARD---B	NEED TO CHANGE TUBELIGHT FOR ROOM NO B4- B5-B6	Muthu. B.	36W TUBE LIGHT 2NO'S CHANG & 40W STARTER 1NO CHANGED		Ahilandeswari. B. - Special Ward	14/06/2023
3321	23060471	SPECIAL WARD - A1	tv not working - room no 5	Muthu. B.	TV FAULT REMOVING TO ELECTRICAL ROOM serviced and refixed		Nivetha. R. - Special Ward	28/06/2023
3322	23060472	SPECIAL WARD - A1	NEED TO CHANGE RESTROOM LIGHT - NOT WORKING - ROOM NO 5	Muthu. B.	9W LED LIGHT 1NO CHANGED		Nivetha. R. - Special Ward	14/06/2023
3323	23060473	Special Ward - C	FAN SOUND PEOBLEM [WARD INSIDE MALE SIDE]	Lakshmanan.V.	CEILING FAN CLAMP 1NO CHANGED		Divya. M. - Special Ward	15/06/2023
Comp. Dt. : 14/06/2023 Status : Completed								
3324	23060506	Female Medical - Ward 307	NEED TO CHECK X RAY LOBBY PLUG POINT BROKEN NOT WORKING [PAEDIATRIC WARD 307]	Srinivasan. R.	TOP WIRE CUT RECONNECTION WORK PROBLEM SOLVED		Suganya. D. - Special Ward	15/06/2023
Comp. Dt. : 16/06/2023 Status : Completed								
3325	23060604	Special Ward - C	FAN LEEF TOUCHING FIRE PIPE (NOISE PROBLEM)	Vaithianathan.M	CEILING FAN CHEKING WORK NO COMPLAINT		Muthulakshmi. A. - Special Ward	19/06/2023
Comp. Dt. : 17/06/2023 Status : Completed								
3326	23060617	SPECIAL WARD---B	HEATER NOT WORKING - B9 - B 12 & B4 - B6	Vijayaraghavan.B.	WATER HEATER 1NO RESET WORK PROBLEM SOLVED		Jayabarathi. P. - Special Ward	19/06/2023
3327	23060618	SPECIAL WARD---B	NEED TO CHANGE TUBELIGHT FOR ROOM NO B7 -B9	Vijayaraghavan.B.	36W TUBE LIGHT 2NO'S CHANG & 40W STARTER 1NO CHANGED		Jayabarathi. P. - Special Ward	19/06/2023
3328	23060630	SPECIAL WARD - A1	T V NOT WORKING ROOM NO 1	Muthu. B.	TV SETUP BOX 1NO RESET WORK PROBLEM SOLVED		Sivapriya. P. - Special Ward	19/06/2023
3329	23060633	SPECIAL WARD---B	HEATER NOT WORKING - B 19 -B21	Lakshmanan.V.	WATER HEATER 1NO RESET WORK PROBLEM SOLVED		Jayabarathi. P. - Special Ward	19/06/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 20/06/2023 Status : Completed								
3330	23060717	Paediatrics - Ward 309	SYSTEM NOT WORKING - POWER PROBLEM [FEMALE MEDICAL WARD 309]	Lakshmanan.V.	MCB TRIP ON TO WORK PROBLEM SOLVED		Hemachandra. P. - Special Ward	21/06/2023
3331	23060735	Female Medical	NEED TO CHANGE TUBELIGHT FOR DOCTOR'S RESTROOM [WARD NO 309 & 310]	Vengadessaperumal. K.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANG & MCB TRIP ON TO WORK PROBLEM SOLVED		Hemachandra. P. - Special Ward	21/06/2023
Comp. Dt. : 21/06/2023 Status : Completed								
3332	23060768	SPECIAL WARD---B	NEED FAN CLEANING WORK	Lakshmanan.V.	ALL CEILING FAN CLEANING WORK PROBLEM SOLVED		Sangeetha. S. - Special Ward	06/07/2023
Comp. Dt. : 26/06/2023 Status : Completed								
3333	23060965	SPECIAL WARD - A1	HEATER NOT WORKING ROOM NO 11	Vijayaraghavan.B.	WATER HEATER 1NO RESET WORK PROBLEM SOLVED		Manjula. R. - Special Ward	27/06/2023
3334	23060966	SPECIAL WARD - A1	NEED TO REFIX PLUG POINT - DAMAGE - ROOM NO 1	Vijayaraghavan.B.	SWITCH BOARD SCREW REFIXING WORK PROBLEM SOLVED		Manjula. R. - Special Ward	27/06/2023
Dept Name : Surgical Oncology - Electrical Maintenance Comp. Dt. : 18/07/2022 Status : Completed								
3335	22070640	Oncology	NEED TO CHECK CEILING LIGHT - NOT WORKING	Srinivasan. R.	9W LED LIGHT 4NO'S CHANG & BABY HOLDER 4NO'S CHANGED		Dhivya Bharathi. P. - Surgical Oncology	30/07/2022
Comp. Dt. : 15/03/2023 Status : Completed								
3336	23030607	Oncology	NEED TO CHECK FOCUS LIGHT NOT WORKING	Rajan. R.	FOCUS LIGHT CHEKING WORK BIOMEDICAL DEPT COMPLAINT		Dhivya Bharathi. P. - Surgical Oncology	16/03/2023
Comp. Dt. : 23/06/2023 Status : Completed								
3337	23060893	ONCOLOGY DEPT-2ND FLOOR-SPECIAL OPD	CEILING LIGHT FRAME - FELL DOWN - NEED TO REARRANGE - OPD NO 212	Vijayaraghavan.B.	CFL LIGHT FITTING COVER REFIXING WORK PROBLEM SOLVED		Dhivya Bharathi. P. - Surgical Oncology	27/06/2023
Dept Name : Tailoring Department - Electrical Maintenance Comp. Dt. : 27/07/2022								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
3338	22071019	Tailoring Department	NEED A NEW PLUG POINT CONNECTION FOR FIXING NEW MACHINE	Vengadessaperumal. K.	16A SOCKET 1NO CHANG & 16A SWITCH 2NO'S CHANG & 6A SWITCH 1NO CHANGED		Ilayaraja.S. - Tailoring Department	30/07/2022
Comp. Dt. : 30/09/2022								
Status : Completed								
3339	22091190	Tailoring Department	NEED TO BE CHANGED SWITCH POINT ANOTHER PLACE	Manikandan. M.	3MTR 3CORE 1.5SQ MM WIRE CHANGED		Ilayaraja.S. - Tailoring Department	01/10/2022
Comp. Dt. : 14/11/2022								
Status : Completed								
3340	22110558	Tailoring Department	CEILING FAN NOT WORKING-BARRING NEED TO CHANGE	Thillaikumar. R.	CEILING FAN 1NO BEARING 2NO'S CHANGED		Ilayaraja.S. - Tailoring Department	17/11/2022
Comp. Dt. : 13/01/2023								
Status : Completed								
3341	23010566	Tailoring Department	NEED TO CHECK TAILORING MACHINE MOTOR - BURNT SMELL	Rajan. R.	TAILORING MOTOR CHEKING WORK NO PROBLEM SOLVED		Ilayaraja.S. - Tailoring Department	14/01/2023
Dept Name : TB & CHEST - Electrical Maintenance								
Comp. Dt. : 16/05/2023								
Status : Completed								
3342	23050671	TB & Chest OPD	FAN NOT WORKING	Manimaran. M.	CEILING FAN ROD 1NO CHANGED		Kirubasankar. E. - TB & CHEST	17/05/2023
Dept Name : TB & Chest / Psychiatry - Electrical Maintenance								
Comp. Dt. : 08/06/2022								
Status : Completed								
3343	22060309	PSYCHIATRY WARD	FAN NOT WORKING WARD NO 405	Dhakshinamoorthy. J	6A SWITCH 1NO CHANGED		Pasupathi. M. - Derm,Pulmo,Psych Ward	09/06/2022
Dept Name : Tele Exchange - Electrical Maintenance								
Comp. Dt. : 04/07/2022								
Status : Completed								
3344	22070082	EDP IN UNDERGROUND	NEW POWER CONNECTION FOR RACK 17 U	Rajan. R.	POWER LINE CHEKING WORK PROBLEM SOLVED		Vivek. A. - Tele Exchange	02/08/2022
Comp. Dt. : 09/08/2022								
Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
3345	22080303	EDP IN UNDERGROUND	NEED TO CHANGE TUBELIGHT FOR SERVER ROOM & NEED A UPS LINE CONNECTION FOR TUBELIGHT	Suresh. V.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Vivek. A. - Tele Exchange	10/08/2022
Comp. Dt. : 19/10/2022 Status : Completed								
3346	22100626	RADIOLOGY	TELEPHONE CABLE LAYING CHANGING WORK	Vaithianathan.M	TELEPHONE CABLE LAYING WORK PROBLEM SOLVED		Vivek. A. - Tele Exchange	28/10/2022
Comp. Dt. : 25/10/2022 Status : Completed								
3347	22100778	A.P Quateres	CCTV NVR NEW POWER SPPLY	Manikandan. M.	8M SWITCH BOARD SET 1NO FIXING WORK & LINE CONNECTION WORK PROBLEM SOLVED		Vivek. A. - Tele Exchange	02/11/2022
Comp. Dt. : 30/12/2022 Status : Completed								
3348	22121357	EDP IN UNDERGROUND	IN SERVER ROOM-ELECTRICAL POWER BOX NEED TO BE CHANGE	Suresh. V.	Power point removed.		Padmanaban. G. - Tele Exchange	02/01/2023
Comp. Dt. : 03/01/2023 Status : Completed								
3349	23010064	Tele Exchange	TELEPHONE CABLE LAYING IN COMMERCIAL BLOCK TO WORK SHOP	Manikandan. M.	TELEPHONE CABLE LAYING WORK PROBLEM SOLVED		Vivek. A. - Tele Exchange	03/01/2023
Comp. Dt. : 11/04/2023 Status : Completed								
3350	23040298	CASUALTY RECEPTION	NEED TO CHANGE CAMERA CABLE	Vijayaraghavan.B.	CAMERA CABLE LAYING WORK PROBLEM SOLVED		Padmanaban. G. - Tele Exchange	19/04/2023
Comp. Dt. : 27/04/2023 Status : Completed								
3351	23040886	EDP IN UNDERGROUND	POWER ISSUE AT C C TV MONITOR IN EDP SERVER ROOM	Vijayaraghavan.B.	POWER LINE CHEKING WORK NO COMPLAINT PROBLEM SOLVED		Padmanaban. G. - Tele Exchange	03/05/2023
Comp. Dt. : 02/05/2023 Status : Completed								
3352	23050054	ENT OPD	NEED TELEPHONE CABLE LAYING WORK FROM ENT OPD TO ENT ENTRANCE	Dhakshinamoorthy. J	TELEPHONE CABLE LAYING WORK PROBLEM SOLVED		Padmanaban. G. - Tele Exchange	04/05/2023

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 25/05/2023 Status : Completed								
3353	23051009	AO Office	NEED NEW CABLE LAYING WORK	Damodharan. V.	Data cable and telephone cable layed.		Padmanaban. G. - Tele Exchange	29/05/2023
Comp. Dt. : 05/06/2023 Status : Completed								
3354	23060142	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	NEED TELEPHONE CABLE LAYING WORK FOR DR. RAMYA MADAM ROOM	Rajan. R.	NEW TELEPHONE CABLE LAYING WORK PROBLEM SOLVED		Padmanaban. G. - Tele Exchange	10/06/2023
Dept Name : Transport - Electrical Maintenance Comp. Dt. : 29/08/2022 Status : Completed								
3355	22080968	CAR PARKING AREA	NEED A NEW TUBELIGHT & FAN CONNECTION FOR MECHANIC SHED NEAR CAR PARKING AREA	Vijayaraghavan.B.	36W TUBE LIGHT FITTING 1NO REFIXING WORK PROBLEM SOLVED		Sasikumar. P. - Transport	03/09/2022
Comp. Dt. : 02/09/2022 Status : Completed								
3356	22090078	Casualty	FAN FITTING WORK IN AMBULANCE	Muthu. B.	WALLMOUNTING FAN 1NO REFIXING WORK PROBLEM SOLVED		Ramalingam. J. - Transport	03/09/2022
Comp. Dt. : 24/11/2022 Status : Completed								
3357	22111058	Work Shop	FOCUS LIGHT NOT WORKING IN OUTER AREA NEAR WORKSHOP	Dhakshinamoorthy. J	100W FOCUS LIGHT 2NO'S FIXING & LINE CONNECTION WORK PROBLEM SOLVED		Sasikumar. P. - Transport	29/11/2022
Comp. Dt. : 24/03/2023 Status : Completed								
3358	23031001	Transport	NEED TO CHANGE TUBELIGHT	Thillaikumar. R.	36W tube light 1no changed.		Ashok Kumar. K. - Transport	24/03/2023
Comp. Dt. : 06/05/2023 Status : Completed								
3359	23050254	Work Shop	NEED TO CHANGE TUBELIGHT 2 NOS FOR 1ST MECHANIC ROOM NEAR WORKSHOP	Muthu. B.	NEW 22W LED TUBE LIGHT 2NO'S FIXING & LINE CONNECTION WORK PROBLEM SOLVED		Velu. K. - Transport	09/05/2023
Comp. Dt. : 27/06/2023 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
3360	23061016	Transport	WATER WASH MOTOR NOT WORKING	Lakshmanan.V.	MOTOR REWINDING & BEARING 2NO'S CHANG & MOTOR LINE CONNECTION WORK PROBLEM SOLVED		Mohan.T. - Transport	03/07/2023
Dept Name : UHC Villupuram - Electrical Maintenance Comp. Dt. : 19/09/2022 Status : Completed								
3361	22090706	UHC Villupuram	NEED TO CHECK U P S & REFILL DISTILLED WATER FOR BATTERY	Vaithianathan.M	12V BATTERY CHANG & UPS CHEKING WORK PROBLEM SOLVED		Sankari. J. - UHC Villupuram	06/10/2022
Comp. Dt. : 18/05/2023 Status : Completed								
3362	23050770	UHC Villupuram	NEED TO CHANGE TUBELIGHT [2NOS] FOR DOCTOR'S ROOM	Manikandan. M.	36W TUBE LIGHT 1NO CHANG & 36W CHOKE 1NO CHANG & 40W STARTER 1NO CHANG & SIDE HOLDER 5NO'S CHANGED		Sankari. J. - UHC Villupuram	23/05/2023
3363	23050771	UHC Villupuram	3 PIN SWITCH NOT WORKING & FAN SLOW PROBLEM	Manikandan. M.	CEILING FAN CAPACITOR 2.5MFT 3NO'S CHANGED		Sankari. J. - UHC Villupuram	23/05/2023
Dept Name : Veterinary Science - Electrical Maintenance Comp. Dt. : 23/03/2023 Status : Completed								
3364	23030950	Animal House	NEED TO CHECK FAN 2NOS & EXHAUST FAN 2 NOS - NOT WORKING	Rajan. R.	Exhaust fan 2no's cleaned & Fan capacitor 2.5mfd 1no changed.		Rajaram. P. - Veterinary Science	23/03/2023
Dept Name : Ward - Electrical Maintenance Comp. Dt. : 09/08/2022 Status : Completed								
3365	22080337	SCAN - GROUND FLOOR - BLOOD BANK OPP	NEED TO CHANGE TUBELIGHT	Rajan. R.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Jerina Begum. P. - Ward	10/08/2022
Comp. Dt. : 11/08/2022 Status : Completed								
3366	22080413	DENTAL OPD -2ND FLOOR	NEED TO CHECK X RAY LOBBY INSIDE LIGHT - NOT WORKING	Muthu. B.	9W LED LIGHT 1NO CHANGED		Patchaiyammal.K - Ward	12/08/2022
Comp. Dt. : 28/09/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
3367	22091107	Paediatrics - Ward 309	NEED TO CHANGE TUBELIGHT FOR CABIN	Dhakshinamoorthy. J	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		Chitra. P. - Ward	29/09/2022
Comp. Dt. : 10/06/2023 Status : Completed								
3368	23060354	BASEMENT SCAN	NEED TO CHANGE TUBELIGHT 2 NOS FOR BASEMENT RESTROOM	Muthu. B.	20W TUBE LIGHT 2NO'S CHANGED		Jerina Begum. P. - Ward	12/06/2023
Dept Name : Work Shop - Electrical Maintenance Comp. Dt. : 25/05/2022 Status : Completed								
3369	22050964	Work Shop	WELDING MACHINE NOT WORKING	Manikandan. M.	MCB trip - Trip ON		Ganesan. A. - Work Shop	26/05/2022
Comp. Dt. : 27/06/2022 Status : Completed								
3370	22060971	Work Shop	WELDING MACHINE NOT WORKING	Lakshmanan.V.	WIRE CUT RECONNECTION WORK PROBLEM SOLVED		Ganesan. A. - Work Shop	28/06/2022
Comp. Dt. : 11/07/2022 Status : Completed								
3371	22070403	Work Shop	NEED TO CHECK CUTTING MACHINE - NOT WORKING	Dhakshinamoorthy. J	CUTTING MACHINE SWITCH SERVICE WORK PROBLEM SOLVED		Murugavel - Civil - Maintenance	12/07/2022
Comp. Dt. : 07/09/2022 Status : Completed								
3372	22090262	Work Shop	DRILLING MACHINE NOT WORKING	Sridharan. R	DRILLING MACHINE WIRE CUT RECONNECTION WORK PROBLEM SOLVED		Pachaimuthusamy. D. - Work Shop	07/09/2022
Comp. Dt. : 21/09/2022 Status : Completed								
3373	22090818	Work Shop	NEED TO CHANGE CABLE FOR WELDING MACHINE - CABLE DAMAGE & NOT WORKING	Sridharan. R	WELDING MACHINE WIRE CUT RECONNECTION WORK PROBLEM SOLVED		Ganesan. A. - Work Shop	22/09/2022
Comp. Dt. : 29/09/2022 Status : Completed								
3374	22091151	Work Shop	NEED TO CHECK PLUG POINT - NOT WORKING	Vijayaraghavan.B.	NEW 50W LED LIGHT 1NO FIXING WORK PROBLEM SOLVED		Ganesan. A. - Work Shop	05/10/2022
Comp. Dt. : 28/10/2022								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
3375	22100939	Work Shop	EXTENSION BOX WIRE GOT DAMAGED,CHANGE IT	Srinivasan. R.	6A SOCKET 1NO CHANGED		Ganesan. A. - Work Shop	31/10/2022
Comp. Dt. : 04/11/2022								
Status : Completed								
3376	22110158	Work Shop	DRILLING MACHINE NOT WORKING	Lakshmanan.V.	DRILLING MACHINE SERVICE WORK PROBLEM SOLVED		Ganesan. A. - Work Shop	05/11/2022
Comp. Dt. : 11/11/2022								
Status : Completed								
3377	22110479	Work Shop	HAND CUTTING MACHINE REPAIR WORK	Lakshmanan.V.	CUTTING MACHINE WIRE CUT RECONNECTION WOK PROBLEM SOLVED		Ganesan. A. - Work Shop	14/11/2022
3378	22110483	Work Shop	EXTENSION BOX AND WELDING MACHINE CABLE NEED TO BE CHANGE	Vaithianathan.M	THREE CORE 2.5SQ MM WIRE EXECTION BOX 20MTR & WELDING MACHINE 2NO'S 30MTER & DRILLING MACHINE & CUTT		Ganesan. A. - Work Shop	29/11/2022
Comp. Dt. : 25/11/2022								
Status : Completed								
3379	22111096	Work Shop	WELDING MACHINE NOT WORKING	Muthu. B.	WELDING MACHINE SERVICE WORK PROBLEM SOLVED		Ganesan. A. - Work Shop	29/11/2022
Comp. Dt. : 10/12/2022								
Status : Completed								
3380	22120474	Work Shop	FORTUNE CUTTING MACHINE REPAIR WORK	Dhakshinamoorthy. J	6A 3PIN TOP 1NO CHANGED		Ganesan. A. - Work Shop	15/12/2022
Comp. Dt. : 14/12/2022								
Status : Completed								
3381	22120621	Work Shop	NEED TO CHECK HAND CUTTING MACHINE - NOT WORKING	Manimaran. P.	CUTTING MACHINE SERVICE WORK PROBLEM SOLVED		Murugavel - Civil - Maintenance	15/12/2022
Comp. Dt. : 13/01/2023								
Status : Completed								
3382	23010554	Work Shop	NEED TO CHANGE SOCKET	Vijayaraghavan.B.	16A SOCKET 1NO CHANG & 16A 3PIN TOP 1NO CHANGED		Ganesan. A. - Work Shop	14/01/2023
Comp. Dt. : 11/03/2023								
Status : Completed								
3383	23030461	Work Shop	NEED TO PROVIDE EXTENTION BOX 2 NOS	Vaithianathan.M	Already extension box provided.		Ganesan. A. - Work Shop	10/04/2023

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 17/03/2023 Status : Completed								
3384	23030731	Work Shop	NEED TO CHECK HAND CUTTING MACHINE - NOT WORKING	Rajan. R.	carbon bresh problem. New carbon brush changed.		Ganesan. A. - Work Shop	03/04/2023
Comp. Dt. : 30/03/2023 Status : Completed								
3385	23031304	Work Shop	NEED TO CHECK HAND CUTTING MACHINE - NOT WORKING	Sathishkumar. R.	CARBON BRESH PROBLEM. New, Carbon brush changed.		Ganesan. A. - Work Shop	03/04/2023
Comp. Dt. : 02/05/2023 Status : Completed								
3386	23050025	Work Shop	NEED REPAIRING WORK FOR CUTTING MACHINE {14" }	Dhakshinamoorthy. J	14" CUTTING MACHINE CHEKING WORK ROTOR SIDE PROBLEM SHIFTING TO WORKSHOP SERVICE WORK		Ganesan. A. - Work Shop	03/05/2023
Comp. Dt. : 10/06/2023 Status : Completed								
3387	23060364	Work Shop	HAND DRILLING MACHINE NOT WORKING	Muthu. B.	Wire problem - solved.		Ganesan. A. - Work Shop	12/06/2023
Comp. Dt. : 12/06/2023 Status : Completed								
3388	23060408	Work Shop	WELDING MACHINE NOT WORKING	Manimaran. M.	WELDING MACHINE SERVICE WORK PROBLEM SOLVED		Ganesan. A. - Work Shop	14/06/2023
Work Type : Work Dept Name : Civil - Maintenance - Electrical Maintenance Comp. Dt. : 21/05/2022 Status : Completed								
3389	22050808	Hospital	Hospital near and Ladies hostel Phase-I backside - Tubelight not working, to be change new light	Vijayaraghavan.B.	36W TUBE LIGHT 1NO CHANGED		Gurunathan. V. - Civil - Maintenance	25/05/2022
Comp. Dt. : 17/06/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
3390	22060668	Hospital	Hospital sump (ortho OPD side) and Boys Hostel near pump house - tubelight not working, to be change	Muthu. B.	36W TUBE LIGHT 1NO CHANGED		Gurunathan. V. - Civil - Maintenance	21/06/2022
Comp. Dt. : 06/12/2022 Status : Completed								
3391	22120231	D-WING	D Wing Motor starter problem, need to urgent service	Rajan. R.	36MFT CAPACITOR 1NO CHANGED		Gurunathan. V. - Civil - Maintenance	07/12/2022
Comp. Dt. : 08/12/2022 Status : Completed								
3392	22120378	Free Pharmacy	Free Pharmacy opposite Male and Female common toilet - 2Nos of Exhaust fan need to be fix	Manimaran. P.	EXHAUST FAN POINT CHEKING WORK PROBLEM SOLVED		Gurunathan. V. - Civil - Maintenance	10/12/2022
Dept Name : Computer Department - Electrical Maintenance Comp. Dt. : 07/09/2022 Status : Completed								
3393	22090279	Guest House - Indian Bank	NEED CAMERA CABLE LAYING WORK	Dhakshinamoorthy. J	CAMERA CABLE LAYING WORK PROBLEM SOLVED		Selvam. D. - Computer Department	12/10/2022
Comp. Dt. : 14/03/2023 Status : Completed								
3394	23030550	RADIOLOGY	NEED NETWORK CABLE LAYING WORK AT RADIOLOGY ENTRANCE	Damodharan. V.	CAMERA CABLE LAYING WORK PROBLEM SOLVED		Murugavel.R - Computer Department	16/03/2023
Comp. Dt. : 11/04/2023 Status : Completed								
3395	23040341	Hospital	NEED TO PUT HOLES FOR FIXING CAMERA IN HOSPITAL [15 PLACES]	Manikandan. M.	Holes work - done.		Prakash. P. - Computer Department	12/04/2023
Comp. Dt. : 15/05/2023 Status : Completed								
3396	23050620	JR Quarters	NEED CAMERA CABLE LAYING WORK	Srinivasan. R.	NEW CAMERA 4NO'S WIREING WORK & CAMERA FIXING WORK PROBLEM SOLVED		Prakash. P. - Computer Department	25/05/2023
Comp. Dt. : 26/05/2023 Status : Completed								

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
3397	23051056	Ladies hostel Phase-I	NEED CAMERA CABLE LAYING WORK	Srinivasan. R.	OLD CAMERA CABLE LINE CUT NEW CAMERA WIRE LAYING WORK PROBLEM SOLVED		Prakash. P. - Computer Department	30/05/2023
Dept Name : PICU & NICU - Electrical Maintenance Comp. Dt. : 10/11/2022 Status : Completed								
3398	22110439	NEW NICU & PICU-2ND FLOOR	REQUEST TO GIVE NEW ELECTRICAL CONNECTION FOR HOT AND COLD WATER DISPENSER	Manikandan. M.	ELECTRICAL POINT CHELING WORK PROBLEM SOLVED		Poovathal. K. - PICU & NICU	18/11/2022
Dept Name : Special Ward - Electrical Maintenance Comp. Dt. : 03/01/2023 Status : Completed								
3399	23010088	SPECIAL WARD A THIRD FLOOR	REQUEST FOR NEW EMERGENCY LIGHT	Vaithianathan.M	UPS LINE CHEKING WORK PROBLEM SOLVED		Bharathi. R. - Special Ward	19/01/2023
Dept Name : Tele Exchange - Electrical Maintenance Comp. Dt. : 10/06/2022 Status : Completed								
3400	22060377	Medical Records	REQUEST TO LAY CCTV CABLE FROM MRD TO EDP SERVER ROOM	Vijayaraghavan.B.,M animaran. P.,Srinivasan. R.	CCTV CABLE LAYING WORK PROBLEM SOLVED		Padmanaban. G. - Tele Exchange	24/06/2022
Comp. Dt. : 17/06/2022 Status : Completed								
3401	22060658	MEDICAL COLLEGE LIFT	NEED TO PROVIDE CABLE LINE FOR FIXING CAMERA	Vaithianathan.M	NEW CAMERA FIXING WORK PROBLEM SOLVED		Padmanaban. G. - Tele Exchange	02/07/2022
Comp. Dt. : 10/10/2022 Status : Completed								
3402	22100209	Work Shop	NEED CAMERA CABLE LAYING WORK AT WORKSHOP	Rajan. R.	CAMERA CABLE WIRE LAYING WORK PROBLEM SOLVED		Padmanaban. G. - Tele Exchange	12/10/2022
3403	22100238	SUPER SPECILAITY OPD IN 2ND FLOOR	NEED TELEPHONE CABLE LAYING WORK	Manikandan. M.	TELEPHONE CABLE LAYINH WORK PROBLEM SOLVED		Padmanaban. G. - Tele Exchange	12/10/2022
Comp. Dt. : 09/12/2022 Status : Completed								
3404	22120414	Paediatrics - OPD	NEED TO REFIXING C C TV CAMERA AT HOSPITAL GROUND FLOOR PAEDIATRIC OPD CARITOR NEED ELECTRICAL	Rajan. R.	CCTV CAMERA WIRING WORK & 2NO'S CAMERA FIXING WORK PROBLEM SOLVED		Vivek. A. - Tele Exchange	23/12/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
College Name :		SMVNC						
Work Type :		Complaint						
Dept Name :		Electrical Maintenance - Electrical Maintenance						
Comp. Dt. :		09/05/2022						
Status :		Completed						
3405	22050281	Nursing College	NEED TO CHANGE LED LIGHT FOR STAFF RESTROOM - GROUND FLOOR	Manikandan. M.	9W LED LIGHT 1NO CHANGED		DHANDAPANI - SMVNC	12/05/2022
Comp. Dt. :		16/05/2022						
Status :		Completed						
3406	22050569	Nursing College	NEED TO CHECK POWER - EARTH PROBLEM IN GROUND FLOOR CLASS ROOM	Lakshmanan.V.	SWITCH BOARD CHEKING WORK NO PROBLEM SOLVED		RAJARAJESWARI - SMVNC	20/05/2022
Comp. Dt. :		25/05/2022						
Status :		Completed						
3407	22050942	Nursing College	NEED TO PROVIDE NEW ELECTRICAL LINE CONNECTION FOR COOLER AT II & III FLOOR	Srinivasan. R.,Babu. D.,Vijayaraghavan.B.	3M PLATE 2NO'S, 2M SURFACE BOX 2NO'S, 16A SWITCH 2NO'S, 16A SOCKET 2NO'S, 1.5SQ MM WIRE 60MTR & LINE		TAMILPULAVENDRAN - SMVNC	30/05/2022
3408	22050943	Nursing College	NEED TO CHANGE TUBELIGHT [8 NOS]	Srinivasan. R.	36W TUBE LIGHT 9NO'S CHANG & 36W CHOKE 2NO'S CHANG & 40W STARTER 1NO CHANGED		TAMILPULAVENDIRAN - SMVNC	27/05/2022
Comp. Dt. :		20/06/2022						
Status :		Completed						
3409	22060696	Nursing College	NEED TO CHANGE TUBELIGHT FOR PRINCIPAL OFFICE	Dhakshinamoorthy. J	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		RAJARAJESWARI - SMVNC	21/06/2022
Comp. Dt. :		30/06/2022						
Status :		Completed						
3410	22061102	Nursing College	NEED TO CHANGE TUBELIGHT FOR PRINCIPAL OFFICE - NEED URGENT	Muthu. B.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 2NO'S CHANGED		JAYASEELAN - SMVNC	01/07/2022
Comp. Dt. :		09/09/2022						
Status :		Completed						
3411	22090369	Nursing College	NEED TO CHANGE TUBELIGHT 10 NOS	Manimaran. P.	36W TUBE LIGHT 8NO'S CHANG & 40W STARTER 4NO'S CHANGED		JAYASEELAN - SMVNC	14/09/2022
Comp. Dt. :		19/09/2022						


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
3412	22090733	Nursing College	NEED TO CHANGE TUBELIGHT FOR PRINCIPAL OFFICE	Dhakshinamoorthy. J	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		DHANDAPANI - SMVNC	20/09/2022
Comp. Dt. : 11/10/2022								
Status : Completed								
3413	22100270	Nursing College	NEED TO CHANGE TUBELIGHT FOR ENTRANCE	Suresh. V.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		JAYASEELAN - SMVNC	12/10/2022
Comp. Dt. : 09/11/2022								
Status : Completed								
3414	22110359	Nursing College	IN ENTRANCE STEPS-1 TUBELIGHT NOT WORKING	Dhakshinamoorthy. J	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		VENKATESAN - SMVNC	10/11/2022
Comp. Dt. : 10/11/2022								
Status : Completed								
3415	22110383	Nursing College	IN PRINCIPAL ROOM-1 TUBELIGHT NOT WORKING	Lakshmanan.V.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		DHANDAPANI - SMVNC	15/11/2022
Comp. Dt. : 14/12/2022								
Status : Completed								
3416	22120627	Nursing College	NEED TO CHECK TUBELIGHT 2NOS & FAN 2 NOS - NOT WORKING AT II FLOOR CLASS ROOM	Manikandan. M.	36W TUBE LIGHT 7NO'S CHANG & 36W CHOKE 4NO'S CHANG & 40W STARTER 10NO'S CHANG & CEILING FAN CAPACITO		DHANDAPANI - SMVNC	17/12/2022
Comp. Dt. : 03/01/2023								
Status : Completed								
3417	23010073	Nursing College	NEED TO CUT SHORTER WIRE	Muthu. B.	2HP MOTOR STARTER WIRE CUT RECONNECTION WORK PROBLEM SOLVED		RAJA - SMVNC	03/01/2023
Comp. Dt. : 12/01/2023								
Status : Completed								
3418	23010516	Nursing College	MIC NOT WORKING	Sathishkumar. R.	MIC WIRE CUT RESOLDRING WORK & MIC CHEKING WORK PROBLEM SOLVED		DHANDAPANI - SMVNC	13/01/2023
Comp. Dt. : 21/01/2023								
Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
3419	23010785	Nursing College	TOTALLY 6 NO'S TUBELIGHT NOT WORKING IN LADIES AND GENTS TOILET	Rajan. R.	36W TUBE LIGHT 4NO'S CHANG & 36W CHOKE 3NO'S CHANG & 40W STARTER 1NO CHANGED		DHANDAPANI - SMVNC	24/01/2023
Comp. Dt. : 23/01/2023 Status : Completed								
3420	23010836	Nursing College	TUBELIGHT NOT WORKING IN PRINCIPAL ROOM	Rajan. R.	36W TUBE LIGHT 1NO CHANGED		RAJARAJESHWARI - SMVNC	24/01/2023
Comp. Dt. : 25/01/2023 Status : Completed								
3421	23010905	Nursing College	NEED TO CHANGE TUBELIGHT FOR LIBRARY	Thillaikumar. R.	TUBE LIGHT CHEKING WORK NO COMPLAINT PROBLEM SOLVED		KIRUBHA - SMVNC	27/01/2023
Comp. Dt. : 02/02/2023 Status : Completed								
3422	23020075	Nursing College	NEED TO CHANGE TUBELIGHT FOR PAEDIATRIC LAB	Suresh. V.	36W TUBE LIGHT 1NO CHANGED		RAJARAJESWARI - SMVNC	04/02/2023
Comp. Dt. : 06/02/2023 Status : Completed								
3423	23020167	Nursing College	NEED ELECTRICIAN HELP FOR FIXIING LIGHTS FOR INSTRUMENT	Muthu. B.	9W LED LIGHT 1NO FIXING WORK PROBLEM SOLVED		RAJARAJESWARI - SMVNC	20/02/2023
Comp. Dt. : 08/02/2023 Status : Completed								
3424	23020268	Nursing College	MIKE NOT WORKING IN GROUND FLOOR CLASS ROOM NO. 1	Srinivasan. R.	mike wire cut reconnection work problem solved		DHANDAPANI - SMVNC	09/02/2023
Comp. Dt. : 24/02/2023 Status : Completed								
3425	23020935	Nursing College	NEED TO CHECK ELECTICAL PIPELINE AT I FLOOR - WATER COMING - TRIP PROBLEM	Dhakshinamoorthy. J	SWITCH BOARD WATER LEAKE CHEKING WORK PLUMBING COMPLAINT		DHANDAPANI - SMVNC	25/02/2023
Comp. Dt. : 16/03/2023 Status : Completed								
3426	23030639	Nursing College	SPEAKER NOT WORKING AT I FLOOR	Rajan. R.	SPEAKER CHEKING WORK AMBLIFE RPROBLEM SOLVED		DHANDAPANI - SMVNC	16/03/2023
Comp. Dt. : 17/03/2023 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
3427	23030695	Nursing College	NEED TO CHANGE TUBELIGHT FOR PRINCIPAL OFFICE	Rajan. R.	Tube light starter 1no changed.		DHANDAPANI - SMVNC	18/03/2023
Comp. Dt. : 25/03/2023 Status : Completed								
3428	23031040	Nursing College	FAN NOT WORKING - GROUND FLOOR CLASS ROOM	Dhakshinamoorthy. J,Babu.	Fan removed to power room.		DHANDAPANI - SMVNC	03/04/2023
3429	23031063	Nursing College	NEED TO PROVIDE A NEW TUBELIGHT SET FOR RECEPTION	D.,Srinivasan. R. Dhakshinamoorthy. J,Babu. D.,Srinivasan. R.	Spare ceiling fan fixed. Tube light fitting 2no's fixed.		JAYASEELAN - SMVNC	06/04/2023
Comp. Dt. : 20/04/2023 Status : Completed								
3430	23040650	Nursing College	NEED TO CHANGE FAN CONDENSER 2NOS FOR LIBRARY	Muthu. B.	CEILING FAN CAPACIOTR 2.5MFT 1NO CHANGED		KIRUBHA - SMVNC	22/04/2023
Comp. Dt. : 24/04/2023 Status : Completed								
3431	23040762	Nursing College	NEED TO CHANGE TUBELIGHT FOR LIBRARY	Vijayaraghavan.B.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		KIRUBHA - SMVNC	26/04/2023
Comp. Dt. : 31/05/2023 Status : Completed								
3432	23051246	Nursing College	POWER ISSUE - I FLOOR VP ROOM	Thillaikumar. R.	SWITCH BOARD WIRE CUT RECONNECTION WORK PROBLEM SOLVED		DHANDAPANI - SMVNC	02/06/2023
Comp. Dt. : 30/06/2023 Status : Completed								
3433	23061115	Nursing College	STANDING FAN NOT WORKING	Dhakshinamoorthy. J	PEDESTAL FAN WIRE CUT RECONNECTION WORK PROBLEM SOLVED		JAYASEELAN - SMVNC	05/07/2023

College Name : SMVPT

Work Type : Complaint

Dept Name : Electrical Maintenance - Electrical Maintenance

Comp. Dt. : 02/09/2022

Status : Completed

3434 22090096 Polytechnic college TUBE LIGHT SERVICE WORK (NEED TO CHANGE) - 25 NOS

Srinivasan. R.

36W TUBE LIGHT 4NO'S CHANG & 3NO'S CHANGED

Comp. Dt. : 04/11/2022

Status : Completed

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

KATHIRESAN - SMVPT

15/09/2022

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
3435	22110155	Polytechnic college	IN ROOM NO.115-SWITCH BOARD SWITHES PROBLEM	Rajan. R.	SWITCH BOARD 8M SET 2NO'S & 12M SET 2NO'S FIXING & LINE CONNECTION WORK PROBLEM SOLVED		SANTHANAM - SMVPT	11/11/2022
Comp. Dt. : 16/11/2022 Status : Completed								
3436	22110683	Polytechnic college	IN DRAWING HALL-SWITCH BOARD SWITCHES GOT DAMAGED	Muthu. B.	24W LED LIGHT 6NO'S CHANG & 36W TUBE LIGHT 3NO'S CHANG & 40W STARTER 5NO'S CHANGED		SANTHANAM - SMVPT	21/11/2022
Comp. Dt. : 12/12/2022 Status : Completed								
3437	22120562	Polytechnic college	NEAR EXAM CELL-1 TUBELIGHT NOT WORKING	Manikandan. M.	36W TUBE LIGHT 2NO'S CHANG & 40W CHOKE 2NO'S CHANG & 22W LED LIGHT 2NO'S FIXING WORK PROBLEM SOLVED		SANTHANAM - SMVPT	15/12/2022
Comp. Dt. : 14/12/2022 Status : Completed								
3438	22120637	Polytechnic college	NEED TO CHECK SUMP MOTOR - SOUND PROBLEM	Dhakshinamoorthy. J	SUMP MOTOR CHEKING WORK BEARING SOUND		SANTHANAM - SMVPT	17/12/2022
Comp. Dt. : 20/01/2023 Status : Completed								
3439	23010729	Polytechnic college	NEED TO CHANGE LED LIGHT & SWITCH BOX - DAMAGE & NOT WORKING	Manikandan. M.	12M SWITCH BOARD 2NO'S REFIXNIG WORK & LED TUBE LIGHT 2NO'S REFIXING WORK PROBLEM SOLVED		SANTHANAM - SMVPT	24/01/2023
Comp. Dt. : 23/01/2023 Status : Completed								
3440	23010830	Polytechnic college	NEED TO CHANGE TUBELIGHT FOR ELECTRICAL ROOM	Manikandan. M.	36W TUBE LIGHT 2NO'S CHANG & 40W STARTER 2NO'S CHANGED		SANTHANAM - SMVPT	24/01/2023
Comp. Dt. : 30/01/2023 Status : Completed								
3441	23011078	WORKSHOP-POLYTECH NIC COLL	NEED TO CHECK POWER - SUPPLY PROBLEM - CLASSES GOING ON	Lakshmanan.V.	INCOMING WIRE CUT WIRE RECONNECTION WORK PROBLEM SOLVED		SANTHANAM - SMVPT	31/01/2023
Comp. Dt. : 01/02/2023 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
3442	23020031	Polytechnic college	NEED TO CHANGE TUBELIGHT 2NOS FOR GROUND FLOOR LUNCH ROOM & I FLOOR LAB	Vengadessaperumal. K.	36W TUBE LIGHT 3NO'S CHANG & 40W STARTER 2NO'S CHANGED		SANTHANAM - SMVPT	02/02/2023
Comp. Dt. : 28/02/2023 Status : Completed								
3443	23021064	Polytechnic college	PHYSICS LAB FAN AND SWITCH BOARDS CLEANING WORK	Dhakshinamoorthy. J	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		SANTHANAM - SMVPT	02/03/2023
3444	23021065	Polytechnic college	2ND FLOOR POWER SUPPLY PROBLEM AND ONE TUBELIGHT NOT WORKING	Dhakshinamoorthy. J	36W TUBE LIGHT 2NO'S CHANG & 40W STARTER 1NO CHANGED		SANTHANAM - SMVPT	02/03/2023
Comp. Dt. : 02/03/2023 Status : Completed								
3445	23030074	Polytechnic college	NEED REPAIRING WORK FOR RO WATER MOTOR	Damodharan. V.	RO WATER MOTOR CHEKING NO COMPLAINT PROBLEM SOLVED		SANTHANAM - SMVPT	09/03/2023
Comp. Dt. : 31/03/2023 Status : Completed								
3446	23031366	Polytechnic college	NEED TO CHECK POWER & PLUG POINT - NOT WORKING AT I FLOOR -	Muthu. B.	Power checked & Tube light starter 6no's changed.		SANTHANAM - SMVPT	03/04/2023
Comp. Dt. : 27/04/2023 Status : Completed								
3447	23040932	Polytechnic college	NEED TO CHECK AC POWER LINE - AC NOT WORKING NEED URGENT SERVICE - EXAMS GOING ON AT CENTRE I	Vijayaraghavan.B.	A/C INCOMING MCB TRIP ON TO WORK PROBLEM SOLVED		MANJU - SMVPT	03/05/2023
Comp. Dt. : 11/05/2023 Status : Completed								
3448	23050458	Polytechnic college	AS REMOVED CABLE TOWARDS PAINTING WORK NEED TO REARRANGE AT PHYSICS LAB	Lakshmanan.V.	PHYSICS LAB TABLE NEW WIRING WORK & LINE CONNECTON WORK PROBLEM SOLVED		SANTHANAM - SMVPT	16/05/2023
Comp. Dt. : 14/06/2023 Status : Completed								
3449	23060486	Polytechnic college	NEED TO CHECK POWER - WHOLE COLLEGE NO POWER	Sathishkumar. R.	MCB TRIP ON TO WORK PROBLEM SOLVED		SANTHANAM - SMVPT	14/06/2023
Comp. Dt. : 27/06/2023								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
3450	23061033	Polytechnic college	NEED TO FIX FAN FOR II FLOOR CSE STAFF ROOM	Vijayaraghavan.B.	mcb trip on work. fan working good condition		SANTHANAM - SMVPT	28/06/2023
Comp. Dt. : 30/06/2023								
Status : Completed								
3451	23061135	Polytechnic college	NEED ELECTRICAL TECHINCIAN FOR ELECTRICAL FAULTS	Dhakshinamoorthy. J	36W TUBE LIGHT 4NO'S CHANG & 40W STARTER 12NO'S CHANG & ALL SWITCH BOARD REFIXNG WORK PROBLEM SOLVED		SANTHANAM - SMVPT	03/07/2023

College Name : VCE

Work Type : Complaint

Dept Name : Electrical Maintenance - Electrical Maintenance

Comp. Dt. : 27/06/2022

Status : Completed

3452	22060959	B.ED COLLEGE	NEED TO CHECK POWER - NEED URGENT SERVICE	Muthu. B.	SWITCH BOARD INCOMMING WIRE CUT RECONNECTION WORK PROBLEM SOLVED		SRIMAN - VCE	28/06/2022

Comp. Dt. : 27/07/2022

Status : Completed

3453	22071021	B.ED COLLEGE	NEED TO CHECK POWER - ELECTRICAL ITEMS NOT WORKING	Vijayaraghavan.B.	MCB TRIP ON TO WORK PROBLEM SOLVED		SRIMAN - VCE	29/07/2022

Comp. Dt. : 05/10/2022

Status : Completed

3454	22100070	B.ED COLLEGE	NEED TO CHECK POWER & U P S - PROBLEM	Srinivasan. R.	board problem non availabiliby of materials next week work complete		SRIMAN - VCE	12/10/2022

Comp. Dt. : 06/10/2022

Status : Completed

3455	22100085	B.ED COLLEGE	NEED TO CHECK POWER - ELECTRICAL ITEMS NOT WORKING	Muthu. B.	36W TUBE LIGHT 5NO'S CHANG & 40W STARTER 4NO'S CHANG & 36W CHOKE 9NO'S CHANGED		SRIMAN - VCE	08/10/2022

Comp. Dt. : 18/01/2023

Status : Completed

3456	23010629	B.ED COLLEGE	NEED TO CHANGE TUBELIGHT FOR ENTRANCE STREET LIGHT	Srinivasan. R.	TUBE LIGHT WIRE CUT RECONNECTION WORK PROBLEM SOLVED		SRIMAN - VCE	19/01/2023

Comp. Dt. : 19/01/2023

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
3457	23010676	B.ED COLLEGE	NEED TO CHANGE TUBELIGHT 7 NOS FOR LIBRARY	Rajan. R.	36W TUBE LIGHT 4NO'S CHANG & 36W CHOKE 3NO'S CHANG & 40W STARTER 3NO'S CHANGED		SRIMAN - VCE	24/01/2023
Comp. Dt. : 17/02/2023								
Status : Completed								
3458	23020708	B.ED COLLEGE	NEED TO CHANGE TUBELIGHT	Lakshmanan.V.	36W TUBE LIGHT 2NO'S CHANG & 36W CHOKE 1NO CHANG & 40W STARTER 1NO CHANGED		SRIMAN - VCE	20/02/2023
Comp. Dt. : 03/03/2023								
Status : Completed								
3459	23030155	B.ED COLLEGE	NEED TO REFIX TUBELIGHT CABLE LINE AT I FLOOR - NEED URGENT SERVICE -	Rajan. R.	36W TUBE LIGHT FITTING 1NO REMOVING TO ELECTRICAL ROOM		SRIMAN - VCE	04/03/2023
Comp. Dt. : 10/03/2023								
Status : Completed								
3460	23030434	B.ED COLLEGE	NEED TO CHANGE TUBELIGHT 2 NOS [PRINCIPAL OFFICE & I FLOOR STAFF ROOM]	Rajan. R.	36W TUBE LIGHT 1NO CHANG & 36W CHOKE 1NO CHANGED		SRIMAN - VCE	15/03/2023
Comp. Dt. : 08/04/2023								
Status : Completed								
3461	23040242	Mit ladies hostel	NEED TO CHANGE STREET LIGHT 5NOS FROM MIT LADIES HOSTEL TO B.ED STREET WAY [TUBELIGHT TIED IN TR	Lakshmanan.V.	36W tube light 2no's & E.choke 1no changed.		RAMESH - VCE	10/04/2023
Comp. Dt. : 27/04/2023								
Status : Completed								
3462	23040942	B.ED COLLEGE	NEED TO CHANGE TUBELIGHT FOR OFFICE	Manimaran. M.	36W TUBE LIGHT 1NO CHANG & 40W STARTER 1NO CHANGED		VENKATESAN - VCE	03/05/2023
Comp. Dt. : 12/05/2023								
Status : Completed								
3463	23050489	B.ED COLLEGE	NEED TO CHANGE TUBELIGHT [2 NOS] FOR OFFICE & GROUND FLOOR RESTROOM	Muthu. B.	36W tube light 1no & starter 2no's changed.		VENKATESAN - VCE	15/05/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.



Sri Manakula Vinayagar Medical College and Hospital

Complaint Status Report From 01-05-2022 To 30-06-2023

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
College Name : SMVMCH								
Work Type : Complaint								
Dept Name : Civil - Execution - Housekeeping								
Comp. Dt. : 27/07/2022								
Status : Completed								
1	22071026	PICU & NICU	2nd floor G wing - 209 & 210 common toilet cleaning work.	Naresh. R	Toilet cleaning work completed with SPG labours		Praveen Kumar. K. - Civil - Execution	03/09/2022
Comp. Dt. : 13/10/2022								
Status : Completed								
2	22100433	professor quarters	Need to clean all toilets in room no.6,9 and 10	Naresh. R	Cleaning work completed with PKD housekeeping labours		Murugan.N. - Civil - Execution	04/02/2023
Comp. Dt. : 23/12/2022								
Status : Completed								
3	22121093	Orthopaedics - OPD	HOUSEKEEPING MACHINE WORK IN ORTHO OPD DEMO CLASS	Naresh. R	Demo class room Cleaned with machine, work completed		Sivamurugan. M - Civil - Execution	10/01/2023
College Name : SMVMCH-COL								
Work Type : Complaint								
Dept Name : Computer Department - Housekeeping								
Comp. Dt. : 15/06/2022								
Status : Completed								
4	22060581	DIGITAL LAB	DUE TO DEATH OF RAT AT FALSE CEILING , BAD SMELL IN DIGITAL LAB - TOWARDS CLEANING WORK NEED HOUSE	Naresh. R	Cleaning work completed with labours		Jayaraj. J. - Computer Department	30/06/2022
College Name : SMVMCH-HOS								
Work Type : Complaint								
Dept Name : Administration - Housekeeping								
Comp. Dt. : 21/10/2022								
Status : Completed								
5	22100713	AO Office	WAY TO REST ROOM -BAD SMELL COMING-REQUEST TO CHECK IT	Naresh. R	Rest room cleaned with SPG labours		Karthik. K. - Administration	26/10/2022

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 20/12/2022 Status : Completed								
6	22120917	GENERAL STORE	RACK CLEANING WORK NEED LABOURS	Naresh. R	Rack cleaning work completed with SPG labours		Arulkumaran. S. - Administration	23/12/2022
Comp. Dt. : 18/01/2023 Status : Completed								
7	23010633	General Stores[Linen]	NEED CLEANING WORK AT STORE ENTRANCE - NEED URGENT SERVICE	Naresh. R	Cleaning work completed		Motheeswarar. R.S. - Administration	20/01/2023
Comp. Dt. : 28/02/2023 Status : Completed								
8	23021051	Chairman Office	RECEPTION --BAD SMELL COMING	Naresh. R	Checking, no complaints		Sadhasivam. K. - Administration	15/03/2023
Dept Name : Air Condition Department - Housekeeping Comp. Dt. : 17/10/2022 Status : Completed								
9	22100544	MIT AUDITORIUM BACKSIDE	NEED UNWANTED TREES GRASS CUTING & CLEANING WORK OUT & AROUND THE AUDITORIUM	Naresh. R	Cleaning work completed with city garden labours		Saravanan. C. - Air Condition Department	26/10/2022
Comp. Dt. : 01/03/2023 Status : Completed								
10	23030038	HOSPITAL TERROUS	NEED AC DEPT ROOM CLEANING WORK	Elangchezhiyan. R.	Cleaning work completed with SPG labours		Panneer Selvam. P. - Air Condition Department	15/03/2023
Dept Name : Canteen - Boys Hostel - Housekeeping Comp. Dt. : 06/05/2022 Status : Completed								
11	22050181	Mit boys hostel	NEED CLEANING & CUTTING [UNWANTED TREES AND GRASS] BACK SIDE OF MIT BOYS HOSTEL	Naresh. R	Cleaning work completed with vivek labours		Sambasivam. K. - Canteen - Boys Hostel	30/07/2022
Comp. Dt. : 19/07/2022 Status : Completed								
12	22070726	PG-QUATERS	NEED CLEANING WORK AT PG HOSTEL BACK SIDE [GRASS & UNWANTED TREES CUTTING]	Naresh. R	cleaning work completed with vivek labours		Sambasivam. K. - Canteen - Boys Hostel	30/07/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 26/09/2022 Status : Completed								
13	22091018	Mit boys hostel	NEED UNWANTED TREES & GRASS CUTTING AND CLEANING WORK IN AND AROUND MIT BOYS HOSTEL	Naresh. R	Cleaning work completed with vivek labours		Sambasivam. K. - Canteen - Boys Hostel	10/10/2022
Comp. Dt. : 13/05/2023 Status : Completed								
14	23050553	Mit boys hostel	NEED GRASS & UNWANTED TREES CUTTING & CLEANING WORK AT MIT BOYS HOSTEL IN AND AROUND	Naresh. R	Cleaning work completed with city garden labours		Sambasivam. K. - Canteen - Boys Hostel	14/06/2023
Dept Name : Canteen-Girls Hostel - Housekeeping Comp. Dt. : 02/05/2022 Status : Completed								
15	22050061	Ladies hostel Phase-II	NEED GRASS & UNWANTED TREES CUTTING & CLEANING WORK AT IN & AROUND	Naresh. R	Cleaning work completed by city garden and vivek labours		Malliga. K. - Canteen-Girls Hostel	06/05/2022
Comp. Dt. : 29/06/2022 Status : Completed								
16	22061052	JR Quarters	NEED CLEANING WORK FOR UNWANTED GRASS & TREES AT MAIN ENTRANCE	Naresh. R	Garden cleaning work completed		Virgin Mary - Canteen-Girls Hostel	20/07/2022
Comp. Dt. : 13/07/2022 Status : Completed								
17	22070491	JR Quarters	NEED GARDEN CLEINING WORK	Naresh. R	Garden cleaning work completed with city garden labours and vivek labours		Virgin Mary - Canteen-Girls Hostel	20/07/2022
Comp. Dt. : 23/09/2022 Status : Completed								
18	22090950	JR Quarters	NEED GARDEN CLEANING WORK	Naresh. R	Cleaning work completed with vivek labours		Virgin Mary - Canteen-Girls Hostel	10/10/2022
Comp. Dt. : 17/10/2022 Status : Completed								
19	22100515	Ladies hostel Phase-I	NEED TO CUT & CLEAN UNWANTED TREES & GRASS AT II FLOOR BALCONY	Naresh. R	Trees cut and cleaning work completed with plumber		Revathy. N. - Canteen-Girls Hostel	04/11/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Dept Name : Clinical Department - Housekeeping Comp. Dt. : 08/12/2022 Status : Completed								
20	22120375	CLINICAL DEPARTMENT IN 3RD FLOOR	REQUEST TO CHANGE NEW BASKET,DUSTBIN AND DOOR MATS	Naresh. R	New basket, dustbin and door mats given		Selvi. A. - Clinical Department	24/12/2022
Dept Name : ENT & Ophthal Ward - Housekeeping Comp. Dt. : 28/01/2023 Status : Completed								
21	23011022	Male Ortho - Ward 403	NEED WARD & WINDOW , DOOR CLEANING WORK	Elangchezhiyan. R.	Cleaning work completed with SPG labours		Vijayakumar. G. - ENT & Ophthal Ward	30/01/2023
Dept Name : Gas Power Plant - Housekeeping Comp. Dt. : 07/07/2022 Status : Completed								
22	22070251	Gas Power Plant	NEED CLANING WORK AT GASPLANT OUTER PLACES - NEED URGENT SERVICE	Naresh. R	Clening work completed with vivek labours and city garden labours		Mahi Mohan Ram.S. - Gas Power Plant	12/07/2022
Dept Name : Medical Records - Housekeeping Comp. Dt. : 23/08/2022 Status : Completed								
23	22080737	COMMON TOILET NEAR OPHTAL OPD	NEED TO PROVIDE NEW MUGS FOR RESTROOM - DAMAGE & BROKEN	Naresh. R	New 4Nos of mug given.		Sukanya. S. - Medical Records	29/08/2022
Comp. Dt. : 12/09/2022 Status : Completed								
24	22090433	GENERAL STORE	DUE TO DEATH OF CAT - BAD SMELL & NOT CLEANED - NEED URGENT SERVICE - AT OPPOSITE TO BASEMENT GEN	Naresh. R	Cat removed and cleaned that place with scavengers		Iswin Joseph.M. - Medical Records	12/09/2022
Comp. Dt. : 24/09/2022 Status : Completed								
25	22090974	Medical Records	Ventilation glass cleaning work	Naresh. R	Ventilation glass cleaning work completed with SPG labours		Martin Prabu.V. - Medical Records	12/10/2022
Comp. Dt. : 31/05/2023 Status : Completed								
26	23051216	COMMON TOILET NEAR OPHTAL OPD	NEED TO PROVIDE NEAT & CLEAN BUCKET & MUG FOR ALL FEMALE ROOMS - BROKEN & DAMAGE & WASTE	Naresh. R	Bucket and mug given		Sukanya. S. - Medical Records	14/06/2023

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Dept Name : Nursing Office - Housekeeping Comp. Dt. : 08/07/2022 Status : Completed								
27	22070303	Labour Room	NEED HOUSE KEEPING ATTENDERS FOR CLEANING WORK AT LOBOUR WING	Naresh. R	Cleaning work completed with SPG labours		Rajalakshmi. N. - Nursing Office	12/07/2022
Comp. Dt. : 27/08/2022 Status : Completed								
28	22080931	ORTHO OT	NEED CLEANING WORK FOR BACK SIDE OF ORTHO OT	Naresh. R	Cleaning work completed with SPG labours		Rajalakshmi. N. - Nursing Office	10/10/2022
Comp. Dt. : 20/01/2023 Status : Completed								
29	23010746	Paediatrics Ward	NEED WARD CLEANING WORK FOR WARD NO 309 & 310	Ayyappan. K.	Cleaning work completed with SPG labours		Rajalakshmi. N. - Nursing Office	30/01/2023
Comp. Dt. : 21/02/2023 Status : Completed								
30	23020810	SPECIAL WARD---B	NEED TO SPRAY INSECT AND CLEANING WORK FOR ALL RESTROOMS	Ayyappan. K.	Insect chemical sprayed, All toilet cleaning work completed with SPG labours		Tamilarasi.C. - Nursing Office	15/03/2023
Comp. Dt. : 03/03/2023 Status : Completed								
31	23030125	SPECIAL WARD---B	NEED TO CHECK & CLEANING FOR ALL RESTROOMS - BAD SMELL	Ayyappan. K.	All rest room cleaning work completed with SPG labours		Tamilarasi.C. - Nursing Office	15/03/2023
Dept Name : Nutrition & Dietetics - Housekeeping Comp. Dt. : 18/03/2023 Status : Completed								
32	23030756	DIET DEPARMENT	NEED CLEANING WORK FOR BACKSIDE STORAGE ROOM	Ayyappan. K.	Cleaning work completed		Shanmugapriya. J. - Nutrition & Dietetics	06/04/2023
Dept Name : OPD - Housekeeping Comp. Dt. : 10/09/2022 Status : Completed								
33	22090416	IVF ART CLINIC-INSIDE OF OG OPD(NO.68)	DUE TO RAT PROBLEM - NEED CLEANING WORK AT FALSE CEILING	Naresh. R	Rat cleaned and destroyed with maintenance scavengers, and Rat pad given	 Dr. KAGNE. R.N DEAN SRI MANAKULA VINAYAGAR MEDICAL COLLEGE & HOSPITAL KALITHEERTHALKUPPAM, PUDUCHERRY-605107.	Rajasekari. R. - OPD	10/10/2022

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Dept Name : Operation Theatre - Housekeeping Comp. Dt. : 03/06/2022 Status : Completed								
34	22060124	SURGERY OT	NEED CLEANING WORK AT SURGERY OT - RAT PROBLEM	Naresh. R	Cleaning work completed		Sobiya. N. - Operation Theatre	30/06/2022
Comp. Dt. : 05/10/2022 Status : Completed								
35	22100073	EMERGENCY OT NEAR CASUALTY	DUE TO RAT PROBLEM NEED CLEANING WORK	Naresh. R	Rat pad given		Sobiya. N. - Operation Theatre	10/10/2022
Dept Name : Pharmacy - Housekeeping Comp. Dt. : 03/03/2023 Status : Completed								
36	23030134	Pay Pharmacy	NEED CLEANING WORK	Ayyappan. K.	Cleaning work completed with SPG labours		Silambuselvan. P. - Pharmacy	15/03/2023
Dept Name : Physical Education - Housekeeping Comp. Dt. : 15/04/2023 Status : Completed								
37	23040457	BASKET BALL GROUND	NEED GRASS CLEANING AND TREES CUTTING WORK.	Naresh. R	Cleaning work completed with vivek labours		Vijayakumar. M. - Physical Education	14/06/2023
Comp. Dt. : 19/04/2023 Status : Completed								
38	23040579	PLAY GROUND BETWEEN JR QUARTERS AND LADIES HOSTEL PH -II	NEED UNWANTED GRASS CUTTING & CLENING WORK	Naresh. R	Cleaning work completed by Vivek labours		Vijayakumar. M. - Physical Education	24/06/2023
Dept Name : POW & SICU - Housekeeping Comp. Dt. : 16/02/2023 Status : Completed								
39	23020648	SICU	ALL COTS CLEANING WORK	Naresh. R	Cleaning work completed with SPG labours		Jamuna. K - POW & SICU	15/03/2023
Dept Name : Reception - Housekeeping Comp. Dt. : 21/01/2023 Status : Completed								
40	23010758	Reception	NEED CLEANING WORK FOR RECEPTION TV [BIG SIZE] - DUST FORM BACK & SIDE WALLS	Ayyappan. K.	Cleaning work completed		Sankari. K. - Reception	30/01/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Dept Name : UHC Villupuram - Housekeeping Comp. Dt. : 11/05/2023 Status : Completed								
41	23050461	UHC Villupuram	NEED GARDEN CLEANING WORK	Naresh. R	Cleaning work completed with city garden labours		Gomathi. M. - UHC Villupuram	11/07/2023
Comp. Dt. : 27/05/2023 Status : Completed								
42	23051098	UHC Villupuram	NEED GARDEN CLEANING WORK	Naresh. R	Cleaning work completed with city garden labours		Sankari. J. - UHC Villupuram	11/07/2023
Comp. Dt. : 20/06/2023 Status : Completed								
43	23060699	VILLUPURAM PHC	DUE TO RAIN TREE FALL DOWN NEED TO CLEAR	Naresh. R	Cleaning work completed with city garden labours		Sankari. J. - UHC Villupuram	11/07/2023
Work Type : Work Dept Name : Administration - Housekeeping Comp. Dt. : 16/06/2022 Status : Completed								
44	22060621	General Stores[Linen]	NEED MALE SCAVENGERS [5 NOS] FOR RACK CLEANING WORK	Naresh. R	Cleaning work completed with vivek labours		Motheeswarar. R.S. - Administration	30/06/2022
Dept Name : Canteen-Girls Hostel - Housekeeping Comp. Dt. : 16/05/2023 Status : Completed								
45	23050644	Ladies hostel Phase-II	NEED GARDEN CLEANING WORK - JR SIDE	Naresh. R	Cleaning work completed by Vivek labours		Malliga. K. - Canteen-Girls Hostel	24/06/2023
Dept Name : Civil - Execution - Housekeeping Comp. Dt. : 27/05/2022 Status : Completed								
46	22051018	Casualty	Casualty corridor need to be clean - very urgent	Naresh. R	Cleaning work completed with SPG labours		Murugan.N. - Civil - Execution	11/06/2022
Dept Name : Electrical Maintenance - Housekeeping Comp. Dt. : 29/05/2023 Status : Completed								
47	23051129	TRANSFORMER YARD	NEED CLEANING WORK	Naresh. R	Cleaning work completed by Vivek labours		Vaithianathan.M - Electrical Maintenance	24/06/2023
Dept Name : Guest House - Indian Bank - Housekeeping Comp. Dt. : 23/09/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
48	22090929	Guest House - Indian Bank	Need garden labours for sand levelling work from Guest house front side (Mr.Murugan - Project Manage	Naresh. R	sand levelling work completed		John. H. - Guest House - Indian Bank	10/10/2022
Dept Name : Work Shop - Housekeeping Comp. Dt. : 14/06/2023 Status : Completed								
49	23060493	Work Shop	NEED MANPOWER 2 NOS [MALE] FOR CLEANNING WORK	Naresh. R	Cleaning work completed with city garden labours		Ganesan. A. - Work Shop	14/06/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

Minutes

Maintenance Committee Meeting

DATE

September 30th 2023

TIME

11:00 AM

The Maintenance Committee meeting took place at the M.S. office. The following members attended the meeting.

IN ATTENDANCE

Dr. M. Pragash, Medical Superintendent, Dr. S. Girja, DMS (Med), Mr. Murugan, Project Engineer, Mr. Raja. B, Manager -IT, Mrs. Tessy, DNS, Mr. Vaithyanathan, Electrical In charge, Mr. Saravanan, AC In charge, Mr. Ganesh, Workshop In charge, Mr. Sridar, Biomedical In charge, Mr. R. Naresh, Housekeeping In charge

DISCUSSIONS

The secretary welcomed the gathering and reviewed the minutes of previous meeting.

The members were required about the duties, deficiencies, and the reason from noncompliance.

- ✓ Air conditioning department installed new air conditions in CT scan, Boys and Girls hostels.
- ✓ Workshop department replaced name boards on hospitals and done painting work on Junior resident quarters.
- ✓ Electrical department associated with Fire safety project and completed on basement, ground and first floors.
- ✓ Biomedical department associated with Philips to install a new CT scan machine in the Radiology department.
- ✓ Civil maintenance department renovate the CT scan department.
- ✓ Information Technology department installed optic fiber cables between hospital, medical college, quarters, and hostels.


Chairperson
Maintenance Committee


Secretary
Maintenance Committee

Dr. KAGNE. R.M.
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM
PUDUCHERRY-605 010

Minutes

Maintenance Committee Meeting

DATE March 30th 2023

TIME 02:30 PM

The Maintenance Committee meeting took place at the Clinical Department, 2nd Floor. The following members attended the meeting.

IN ATTENDANCE

Dr. M. Pragash, Medical Superintendent, Dr. S. Girja, DMS (Med), Mr. Murugan, Project Engineer, Mr. Raja. B, Manager -IT, Mrs. Tessy, DNS, Mr. Vaithyanathan, Electrical In charge, Mr. Saravanan, AC In charge, Mr. Ganesh, Workshop In charge, Mr. Sridar, Biomedical In charge, Mr. R. Naresh, Housekeeping In charge

DISCUSSIONS

The secretary welcomed the gathering and reviewed the minutes of previous meeting.

The members were required about the duties, deficiencies, and the reason from noncompliance.

- ✓ Air conditioning department installed new air conditions in OBG-OT, Xray and NICU.
- ✓ Workshop department made 5 numbers of nurses station for new hospital block. Repaired window shutters.
- ✓ Electrical department associated with Fire safety project and completed on second, thirds and fourth floors.
- ✓ Biomedical department associated with Ge-Wipro to install a new multi para monitor in the new hospital block.
- ✓ Civil maintenance department repaint on corridors. Repair the roofing sheets on terrace.
- ✓ Information Technology department installed new WiFi access points at hospital.

ANNOUNCEMENTS / NEXT MEETING

May 23rd 2023


Chairperson
Maintenance Committee


Secretary
Maintenance Committee


Dr. KAGNE. R.M
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM
PUDUCHERRY-605106

Minutes

Maintenance Committee Meeting

DATE May 23rd 2023

TIME 11:00 AM

The Maintenance Committee meeting took place at the Clinical Department, 2nd Floor. The following members attended the meeting.

IN ATTENDANCE

Dr. M. Pragash, Medical Superintendent, Dr. S. Girja, DMS (Med), Mr. Murugan, Project Engineer, Mr. Raja. B, Manager -IT, Mrs. Rajalakshmi DNS, Mr. Vaithyanathan, Electrical Incharge, Mr. Saravanan, AC In charge, Mr. Ganesh, Workshop In charge, Mr. Sridar, Biomedical In charge, Mr. R. Naresh, Housekeeping In charge.

ADVISORY COMMITTEE

New members may include from Gas plant, Housekeeping, Laundry, Tailoring, Dietician and Telephone departments.

Informed to all department in charges to use our ERP-Complaints / Instrument assets.

DISCUSSIONS

The secretary welcomed the gathering and reviewed the minutes of previous meeting.

The members were required about the duties, deficiencies, and the reason from noncompliance.

- ✓ Air conditioning department
 - AHU – Shifting work – may complete within 3 months.
 - Chiller – Ducting and chill water piping work – New hospital block
- ✓ Workshop department
 - Changing the wheels / safety belts for carts – Dialysis department – work in progress.
- ✓ Electrical department
 - Changing CFT lights to LED lights – Hospital
 - Lift No.3 – Service is under progress.
- ✓ Biomedical department
 - Associated with Skan ray to install a new multi para monitor in the new hospital block.
- ✓ Civil maintenance department
 - Ward 401 – Toilet alteration work
 - Main Portico – arresting the leakage
 - TV Nallur – water tank leakage – work in progress

Dr. KAGNE. R.M.
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHAKUPPAM
PUDUCHERRY-605106

- ✓ DMS
 - Informed housekeeping in charge - insects' disturbance on ICU's.
- ✓ DNS
 - Raise a request for a separate rack to keep hazardous items for all wards.
 - RO – water – filters are not changed in regular basis – Project manger requested a list from DNS.
- ✓ Project Engineer
 - Waste garbage (needles, gauze, and food) thrown from windows – C/ D wing (North / South)
 - A laptop found on new hospital block – hand over to NS.

ANNOUNCEMENTS / NEXT MEETING

September 30th 2023


Chairperson
Maintenance Committee


Secretary
Maintenance Committee

SRI MANAKULA VINAYAGAR MEDICAL COLLEGE AND HOSPITAL



Minutes of the Meeting – Maintenance Committee Meeting

SMVMCH/
COM/-MCM

Version No: 1.0

Date	07 - Dec - 2022	Venue	Civil Execution Office	Time	02.30 PM to 03.30 PM
Committee Members Present				Members Absent	
Mr. Murugan – Project Manager cum Civil Maintenance Head				Frequency : 3 months	
Mr. Vaithiyanathan – Incharge - Electrical Dept			(Member)		
Mr. Saravanan – Incharge - Air Condition Department			(Member)		
Mr. Sridhar – Incharge - Biomedical Engineering			(Member)		
Mr. Ganesan - Incharge – Workshop			(Member)		
				MOM No :	
Er. Murugan – Project Manager - initiated the meeting by welcoming all the team members.					

Page 1 of 6

Dr. KAGNE. R.M.
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHAKUPPAM
PUDUCHERRY-605106

SRI MANAKULA VINAYAGAR MEDICAL COLLEGE AND HOSPITAL



Minutes of the Meeting – Maintenance Committee Meeting

SMVMCH/
COM/-MCM

Version No: 1.0

I. Agenda – Review of the minutes of the previous meeting :

I. Review of Electrical Department :

S.No	Item	Action Plan	Responsibility	Target Date	Comments
1	I. Fire safety certificate (NOC approval) to be obtained from the Government of Puducherry is still pending	Fire safety equipment purchase and install the work completed may be December 2022. Hence in mean time NOC requested in Fire Department.	Mr. Vaithiyanathan Electrical Incharge	Work completion on March 2023	Mr. Vaithiyanathan should personal attention in this regard and give top priority

II. Review of Civil – Maintenance Department :

S.No	Item	Action Plan	Responsibility	Target Date	Comments
2	I. Dialysis – I Floor step – Pediatric backside – water leakage problem	Project Manager E.Murugan and Plumbers – The rain water leakage complaint rectified.	Er. N.Murugan Project Manager & V.Gurunathan Plumber – Civil – Maintenance Dept	Work completion on September 2022	Work completed

Page 2 of 6

Dr. KAGNE. R.M.
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM
PUDUCHERRY-605102

SRI MANAKULA VINAYAGAR MEDICAL COLLEGE AND HOSPITAL



Minutes of the Meeting – Maintenance Committee Meeting

SMVMCH/
COM/-MCM

Version No: 1.0

II. New RO Plant – In terrace – Rain water coming inside of Plant	Project Manger E.Murugan & Mr.V.Gurunathan – Plumber, may be taken necessary action to fix the door.	Er. N.Murugan Project Manager, V.Gurunathan Plumber – Civil – Maintenance Dept & Mr. Ganesan – Workshop Incahrge	Before the 30th September 2022	Work completed
III. Special Clinic Room No:100 – I Floor – DMO Room – Rain water coming inside – ceiling damage problem	Project Manger E.Murugan & Mr.V.Gurunathan – Plumber, may be taken necessary action to fix the door.	Er. N.Murugan Project Manager, V.Gurunathan Plumber – Civil – Maintenance Dept & Mr. Ganesan – Workshop Incahrge	Before the 30th September 2022	Work completed
IV. New assignment & Requirements in Hospital : Antiskid flooring required in Ortho ward and special ward restroom steps.	Project Manger E.Murugan & Mr.V.Vengadesan – Plumbing Supervisor, may be taken necessary action to fix the Anti skid floor tile.	Er. N.Murugan Project Manager, Mr.V.Vengadesan – Plumbing Supervisor – Civil – Maintenance Dept & Mr. Ganesan – Workshop Incahrge	Before the 30th June 2023	Work should be done within the stipulated period

SRI MANAKULA VINAYAGAR MEDICAL COLLEGE AND HOSPITAL



Minutes of the Meeting – Maintenance Committee Meeting

SMVMCH/
COM/-MCM

Version No: 1.0

III. Review of Bio Medical Engineering Department :					
S.No	Item	Action Plan	Responsibility	Target Date	Comments
3	I. Pending work review pointed out in the previous meeting	Checklist prepared for all the complaints from various department and maintained	Er. Sridhar – Bio-Medical Department Incharge	--	--
	II. New assignment & Requirements in Hospital : ECG Machines, Scan machines Installation work	Er. Sridhar – Bio-Medical Department Incharge, may be taken necessary action to install the machines.	Er. Sridhar – Bio-Medical Department Incharge	Before the 30 th June 2023	Work should be done within the stipulated period

Dr. KAGNE. R.M.
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM
PUDUCHERRY-605106

SRI MANAKULA VINAYAGAR MEDICAL COLLEGE AND HOSPITAL



Minutes of the Meeting – Maintenance Committee Meeting

SMVMCH/
COM/-MCM

Version No: 1.0

IV. Review of Air Condition Department :

S.No	Item	Action Plan	Responsibility	Target Date	Comments
4	I. G wing - OG OT, Recovery room – CFM and Tonnage is very low at all AHU.	Mr.Saravanan – Incharge of A/C Dept, may be taken necessary action to install the machines.	Mr.Saravanan – Incharge of A/C Dept	--	--
	II. Hospital roof chiller and all AHU running beyond life time. (to be replaced)	Chiller unit and all AHU to be replaced with management approval.	Mr.Saravanan – Incharge of A/C Dept	Waiting for Management approval.	New Split A/C fixed Reports approval to be given by the management.
	III. New split AC installation work pending.	New split AC installation work completed in all demo rooms of the hospital, except 3 rd floor demo room (2 nos of demo room) pending.	Mr.Saravanan – Incharge of A/C Dept		All demo rooms – Split A/C installed, work completed
	IV. New assignment & Requirements in Hospital	There are no new assignment and requirements in the hospital. We work with daily complaints only	Mr.Saravanan – Incharge of A/C Dept	--	--

Page 5 of 6

Dr. KAGNE. R.M.
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM
PUDUCHERRY-605102

SRI MANAKULA VINAYAGAR MEDICAL COLLEGE AND HOSPITAL



Minutes of the Meeting – Maintenance Committee Meeting

SMVMCH/
COM/-MCM

Version No: 1.0

V. Review of Workshop Department :

S.No	Item	Action Plan	Responsibility	Target Date	Comments
5	Review of pending pointed out in the previous meeting - work related to workshop division	1. Casualty partition sliding door & painting work 2. Cot stretcher wheel to be changed – Waiting for material 3. Male Medical Ward – 303 – New duct door fix 4. EDP department server room partition rearrange 5. New ramp fix at Dietary Department.	Mr. Murugan – Project Manager Mr. Ganesan – Incharge of workshop	All pending Work's are completed	--
S.No	Item	Action Plan	Responsibility	Target Date	Comments
6	Next Meeting Date		07.03.2023	Secretary	

Date: 07.12.2022

Co. Secretary
7.12.2022

Page 6 of 6

Dr. KAGNE. R.M.
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM
PUDUCHERRY-605106

SRI MANAKULA VINAYAGAR MEDICAL COLLEGE AND HOSPITAL



Minutes of the Meeting – Maintenance Committee Meeting

SMVMCH/
COM/-MCM

Version No: 1.0

Date	07 - Sep - 2022	Venue	Civil Execution Office	Time	02.30 PM to 03.30 PM
Committee Members Present				Members Absent	
Mr. Murugan – Project Manager cum Civil Maintenance Head				Frequency : 3 months	
Mr. Vaithyanathan – Incharge - Electrical Dept (Member)					
Mr. Saravanan – Incharge - Air Condition Department (Member)					
Mr. Sridhar – Incharge - Biomedical Engineering (Member)					
Mr. Ganesan – Incharge – Workshop (Member)					
Mr. Murugavel – System Engineer – Computer Department (Member)				MOM No :	
Er. Murugan – Project Manager - initiated the meeting by welcoming all the team members.					

Page 1 of 7

Dr. KAGNE. R.M.
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM
PUDUCHERRY-605106

SRI MANAKULA VINAYAGAR MEDICAL COLLEGE AND HOSPITAL



Minutes of the Meeting – Maintenance Committee Meeting

SMVMCH/
COM/-MCM

Version No: 1.0

I. Agenda – Review of the minutes of the previous meeting :

I. Review of Electrical Department :

S.No	Item	Action Plan	Responsibility	Target Date	Comments
1	I. Fire safety certificate (NOC approval) to be obtained from the Government of Puducherry is still pending	BOQ done, Fire safety equipments supplier call for tender in August, again September 2022 work may be started and completed November 2022. Hence in mean time NOC requested in Fire Department. (Final supplier may be finalist this week. Work may be start third week of September 2022).	Mr. Vaithiyanathan Electrical Incharge should obtain the same within the stipulated period	Work completion November 2022	Mr. Vaithiyanathan should bestow his personal attention in this regard and give top priority
	II. Patient call system in Special Ward - B	Sample PCB system board purchased, trial run in progress. Permanent calling system to be installed and tested.	Mr. Vaithiyanathan Electrical Incharge & Mr. Karthikeyan – Manager (Purchase), SMVMCH	Before end of 30 th of September 2022	--

Page 2 of 7

Dr. KAGNE. R.M.
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHAKUPPAM
PUDUCHERRY-605101

SRI MANAKULA VINAYAGAR MEDICAL COLLEGE AND HOSPITAL



Minutes of the Meeting – Maintenance Committee Meeting

SMVMCH/
COM/-MCM

Version No: 1.0

II. Review of Civil – Maintenance Department :

S.No	Item	Action Plan	Responsibility	Target Date	Comments
2	I. Dialysis – I Floor step – Pediatric backside – water leakage problem	Project Manger E.Murugan, Er. Sasikala may be contracted to take necessary action to arrest water leakage problem.	Er. N.Murugan Project Manager, Er. Sasikala – Site Engineer – Civil Executin	Before the 30 th September 2022	Pending works should be done within the stipulated period
	II. New RO Plant – In terrace – Rain water coming inside of Plant	Project Manger E.Murugan & Mr.V.Gurunathan – Plumber, may be taken necessary action to fix the door.	Er. N.Murugan Project Manager, V.Gurunathan Plumber – Civil – Maintenance Dept & Mr. Ganesan – Workshop Incahrge	Before the 30 th September 2022	
	III. Special Clinic Room No:100 – I Floor – DMO Room – Rain water coming inside – ceiling damage problem	Project Manger E.Murugan & Mr.V.Gurunathan – Plumber, may be taken necessary action to fix the door.	Er. N.Murugan Project Manager, V.Gurunathan Plumber – Civil – Maintenance Dept & Mr. Ganesan – Workshop Incahrge	Before the 30 th September 2022	

SRI MANAKULA VINAYAGAR MEDICAL COLLEGE AND HOSPITAL



Minutes of the Meeting – Maintenance Committee Meeting

SMVMCH/
COM/-MCM

Version No: 1.0

III. Review of Bio Medical Engineering Department :

S.No	Item	Action Plan	Responsibility	Target Date	Comments
3	I. Pending work review pointed out in the previous meeting II. 25 complaints are Pending. Major complaints are pending with materials problem.	Checklist prepared for all the complaints from various department and maintained Out of 801 complaints are received during this year so far in which 25 only pending to be rectified. Most of the complaints have minor problem for want of spares that also would be completed within a month. Time down may be reduced by taking immediate steps in all the complaints.	Er. Sridhar – Bio-Medical Department Incharge & Mrs. Shymala – Manager (Purchase), SMVMCH	Time given 30th September 2022	To be follow up

Dr. KAGNE. R.M.
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM
PUDUCHERRY-605106

SRI MANAKULA VINAYAGAR MEDICAL COLLEGE AND HOSPITAL



Minutes of the Meeting – Maintenance Committee Meeting

SMVMCH/
COM/-MCM

Version No: 1.0

IV. Review of Air Condition Department :

S.No	Item	Action Plan	Responsibility	Target Date	Comments
4	I. G wing - OG OT, Recovery room – CFM and Tonnage is very low at all AHU.	Genies Aircon Pvt. Ltd. Mr. Palaniyappan (MD) and Mr. N.G Venkatesh (Service Manager) visited our G wing (OG OT, all AHU and chiller unit) on 07.09.2022	Mr.Saravanan – Incharge of A/C Dept	Report to be submitted by them within 3 to 4 days.	Reports approval to be given by the management.
	II. Hospital roof chiller and all AHU running beyond life time. (to be replaced)	Chiller unit and all AHU to be replaced with management approval.	Mr.Saravanan – Incharge of A/C Dept	Waiting for Management approval.	Reports approval to be given by the management.
	III. New split AC installation work pending.	New split AC installation work completed in all demo rooms of the hospital, except 3 rd floor demo room (2 nos of demo room) pending.	Mr.Saravanan – Incharge of A/C Dept	3 rd floor demo room installation work will be completed by next week.	Reports approval to be given by the management.


Dr. KAGNE. R.M.
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAKUPPAM
 PUDUCHERRY-605102

SRI MANAKULA VINAYAGAR MEDICAL COLLEGE AND HOSPITAL



Minutes of the Meeting – Maintenance Committee Meeting

SMVMCH/
COM/-MCM

Version No: 1.0

V. Review of Workshop Department :

S.No	Item	Action Plan	Responsibility	Target Date	Comments
5	Review of pending pointed out in the previous meeting - work related to workshop division	1. Casualty partition sliding door & painting work 2. Cot stretcher wheel to be changed – Waiting for material 3. Male Medical Ward – 303 – New duct door fix 4. EDP department server room partition rearrange 5. New ramp fix at Dietary Department	Mr. Murugan – Project Manager Mr. Ganesan – Incharge of workshop & Mr. Karthikeyan – Manager (Purchase)	1 st , 3 rd , 4 th and 5 th point's are Work completed 2. Waiting material (material expected on or before 9 th September 2022)	Pending works should be done within the stipulated period

Dr. KAGNE. R.M
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM
 PUDUCHERRY-605105

SRI MANAKULA VINAYAGAR MEDICAL COLLEGE AND HOSPITAL



Minutes of the Meeting – Maintenance Committee Meeting

SMVMCH/
COM/-MCM

Version No: 1.0

S.No	Item	Action Plan	Responsibility	Target Date	Comments
6	Next Meeting Date		07.12.2022	Secretary	

Date: 07.09.2022

C. Srinivasan
8/9/2022

Dr. KAGNE. R.M.
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM
PUDUCHERRY-605102



Sri Manakula Vinayagar Medical College and Hospital

Complaint Status Report From 01-05-2022 To 30-06-2023

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
College Name :		MIT						
Work Type :		Complaint						
Dept Name :		Tele Exchange - Tele Exchange						
Comp. Dt. :		07/05/2022						
Status :		Completed						
1	22050243	MIT College	INTERCOM NO 2235 NOT WORKING - [IT LAB]	Vivek. A.	two pair cable line disconnected rejoin		ANANTHAN - MIT	07/05/2022
Comp. Dt. :		10/05/2022						
Status :		Completed						
2	22050352	Mit ladies hostel	NEED TO CHECK ENTRANCE CAMERA NOT WORKING	Vivek. A.	camera power wire disconnected wire rejoin probelm solved		AROKIAMARY - MIT	10/05/2022
Comp. Dt. :		14/06/2022						
Status :		Completed						
3	22060495	MIT College	INTERCOM NO 2221 [MBA HOD NUMBER] NOT WORKING	Vivek. A.	keepad probelm keepda changed		GUBERAN - MIT	16/06/2022
Comp. Dt. :		04/07/2022						
Status :		Completed						
4	22070098	Mit ladies hostel	COCONUT LEAF FALL DOWN MAIN ENTRANCE CAMERA BROKENED	Vivek. A.	mit main entrance camera refixed probelm solved		AROKIAMARY - MIT	06/07/2022
Comp. Dt. :		11/07/2022						
Status :		Completed						
5	22070443	MIT College	INTERCOM NO 2218 [CASHIER] NOT WORKING	Padmanaban. G.	flc card issue flc card reboot probelm solved		GUBERAN - MIT	12/07/2022
Comp. Dt. :		02/08/2022						
Status :		Completed						
6	22080099	MIT MESS	INTERCOM NO 2212 NOT WORKING	Vivek. A.	two pair cable changed probelm soled		GUBERAN - MIT	03/08/2022
Comp. Dt. :		08/08/2022						
Status :		Completed						
7	22080258	MIT College	INTERCOM NO 2209 NOT WORKING	Vivek. A.	instrument keepad changed probelm solved		GUBERAN - MIT	09/08/2022
Comp. Dt. :		12/08/2022						

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
8	22080451	MIT College	INTERCOM NO 3008 NOT WORKING	Vivek. A.	line cord changed probelm solved		GUBERAN - MIT	13/08/2022
Comp. Dt. : 18/08/2022								
Status : Completed								
9	22080603	MIT MESS	INTERCOM 2212 NOT WORKING	Vivek. A.	cable issue		GUBERAN - MIT	23/08/2022
Comp. Dt. : 20/08/2022								
Status : Completed								
10	22080661	MIT MESS	INTERCOM NO 2212 NOT WORKING	Vivek. A.	two pair cable issue		GUBERAN - MIT	05/09/2022
Comp. Dt. : 19/09/2022								
Status : Completed								
11	22090746	MIT College	INTERCOM NO 2218 NOT WORKING	Vivek. A.	port issue changed port number probelm solved		GUBERAN - MIT	19/09/2022
Comp. Dt. : 28/09/2022								
Status : Completed								
12	22091114	MIT College	INTERCOM NO 2221 [MBA HOD ROOM] & 2212 [MESS] NOT WORKING	Vivek. A.	port issue reboot port probelm solved		GUBERAN - MIT	28/09/2022
Comp. Dt. : 07/10/2022								
Status : Completed								
13	22100126	Mit ladies hostel	INTERCOM NO 3047 NOT WORKING	Vivek. A.	cable issue		AROKIAMARY - MIT	08/10/2022
Comp. Dt. : 10/10/2022								
Status : Completed								
14	22100217	MIT College	INTERCOM NO 2209 NOT WORKING	Vivek. A.	line cord changed probelm solved		GUBERAN - MIT	11/10/2022
Comp. Dt. : 17/10/2022								
Status : Completed								
15	22100517	Mit ladies hostel	INTERCOM NO 3047 NOT WORKING	Vivek. A.	instrument keepad changed probelm solved		AROKIAMARY - MIT	17/10/2022
Comp. Dt. : 19/10/2022								
Status : Completed								
16	22100635	MIT College	INTERCOM NO-2232-NOT WORKING	Vivek. A.	coil cord changed probelm solved		KAVITHA - MIT	19/10/2022
Comp. Dt. : 05/11/2022								
Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
17	22110185	MIT MESS	INTERCOM 2212 INTERCOM NOT WORKING FOR A WHILE	Vivek. A.	two pair cable changed probelm solved		GUBERAN - MIT	22/11/2022
	Comp. Dt. : 09/11/2022							
	Status : Completed							
18	22110366	MIT College	IN 1ST FLOOR MBA DEPT-INTERCOM NOT WORKING(2221)	Vivek. A.	port issue reboot port probelm solved		KAVITHA - MIT	10/11/2022
	Comp. Dt. : 02/12/2022							
	Status : Completed							
19	22120061	MIT College	INTECOM NO 2218 NOT WORKING	Vivek. A.	line cord changed probelm solved		GUBERAN - MIT	02/12/2022
	Comp. Dt. : 22/12/2022							
	Status : Completed							
20	22121033	MIT College	INTERCOM NO. 2203 NOT WORKING	Vivek. A.	puls\ton button adjesment		KAVITHA - MIT	28/12/2022
	Comp. Dt. : 07/01/2023							
	Status : Completed							
21	23010320	MIT College	IN EC DEPT HOD ROOM-INTERCOM 2203 NOT WORKING	Padmanaban. G.	port problem		SIVASUBRAMANIYAN - MIT	11/01/2023
	Comp. Dt. : 23/01/2023							
	Status : Completed							
22	23010834	MIT College	INTERCOM NO 2202 NOT WORKING	Vivek. A.	line cord changed		KAVITHA - MIT	24/01/2023
	Comp. Dt. : 13/02/2023							
	Status : Completed							
23	23020502	Mit ladies hostel	INTERCOM NO 3047 NOT WORKING	Vivek. A.	coil cord changed		RAVI - MIT	14/02/2023
	Comp. Dt. : 04/03/2023							
	Status : Completed							
24	23030165	MIT College	INTERCOM NO 2210 [IV FLOOR] NOT WORKING	Vivek. A.	two pair cable joint refixed		KAVITHA - MIT	06/03/2023
	Comp. Dt. : 13/04/2023							
	Status : Completed							
25	23040417	MIT College	INTERCOM NO 2209 NOT WORKING	Vivek. A.	line cord changed problem solved		GUBERAN 9443384689 -	15/04/2023
	Comp. Dt. : 26/04/2023							


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
26	23040864	MIT College	INTERCOM NO 2221 & 2218 NOT WORKING [INTERCOM NO 2218 LINE PROBLEM]	Vivek. A.	line cord and two pair cable changed		KAVITHA - MIT	28/04/2023
Comp. Dt. : 08/05/2023								
Status : Completed								
27	23050270	MIT College	INTERCOM NO 2201 [AO SIR'S] NOT WORKING	Vivek. A.	two pair cable rejoin problem solved		KAVITHA - MIT	08/05/2023
Comp. Dt. : 17/05/2023								
Status : Completed								
28	23050696	MIT MESS	INTERCOM NO 2212 NOT WORKING	Vivek. A.	two pair cable changed problem solved		GUBERAN - MIT	18/05/2023
Comp. Dt. : 22/06/2023								
Status : Completed								
29	23060817	Mit ladies hostel	INTERCOM NO 3047 NOT WORKING	Vivek. A.	two pair cable changed problem solved		AROKIAMARY - MIT	22/06/2023
Comp. Dt. : 26/06/2023								
Status : Completed								
30	23060974	Mit ladies hostel	INTERCOM NO 3047 NOT WORKING	Vivek. A.	two pair cable changed problem solved		AROKIAMARY - MIT	27/06/2023

College Name : Others

Work Type : Complaint

Dept Name : Tele Exchange - Tele Exchange

Comp. Dt. : 25/11/2022

Status : Completed

31	22111098	Mit ladies hostel	IN ENTRANCE-CAMERA NOT WORKING	Vivek. A.	camera power adapter changed probelm solved		AROKIYAMARY - Others	25/11/2022

College Name : SMVMCH

Work Type : Complaint

Dept Name : BIOCHEMISTRY - Tele Exchange

Comp. Dt. : 07/03/2023

Status : Completed

32	23030284	BIOCHEMISTRY--COLLEGE	INTERCOM NO. 2077 NOT WORKING	Vivek. A.	hospital-to- medical college telephone cable pair changed problem solved		Suganthi. P. - BIOCHEMISTRY	24/03/2023

Dept Name : Canteen - Boys Hostel - Tele Exchange

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 14/11/2022 Status : Completed								
33	22110508	Mit boys hostel	INTERCOM 2122 NOT WORKING	Vivek. A.	port nember issue		Sambasivam. K. - Canteen - Boys Hostel	24/11/2022
Comp. Dt. : 26/12/2022 Status : Completed								
34	22121179	Boys hostel	RECEPTION CAMERA NO.2 NOT WORKING	Vivek. A.	cat 5 cable jack refixed camera working probelm solved		Sambasivam. K. - Canteen - Boys Hostel	31/12/2022
Comp. Dt. : 07/02/2023 Status : Completed								
35	23020254	Boys hostel	INTERCOM NO 1029 NOT WORKING IN STAFF CANTEEN	Vivek. A.	puls/ton button adjustment		Elumalai. M. - Canteen - Boys Hostel	08/02/2023
Comp. Dt. : 29/04/2023 Status : Completed								
36	23041006	Boys hostel	INTERCOM NO 2812 NOT WORKING	Vivek. A.	line cord changed problem solved		Anand. G. - Transport	02/05/2023
Dept Name : Canteen-Girls Hostel - Tele Exchange Comp. Dt. : 10/11/2022 Status : Completed								
37	22110408	Ladies hostel Phase-I	INTERCOM 3045 NOT WORKING	Vivek. A.	two pair cable changed probelm solved		Malliga. K. - Canteen-Girls Hostel	21/11/2022
Comp. Dt. : 04/01/2023 Status : Completed								
38	23010133	JR Quarters	INTERCOM NO 3042 NOT WORKING	Vivek. A.	intercom handset speaker wire rejoin problem solved		Virgin Mary - Canteen-Girls Hostel	05/01/2023
Comp. Dt. : 23/01/2023 Status : Completed								
39	23010813	Ladies hostel Phase-I	INTERCOM NO 3045NOT WORKING	Vivek. A.	two pair cable changed probelm solved		Revathy. N. - Canteen-Girls Hostel	25/01/2023
Comp. Dt. : 16/02/2023 Status : Completed								
40	23020621	Ladies hostel Phase-I	MESS CAMERA --CHANGE THE POSITION	Vivek. A.	kitchen camera position changed		Malliga. K. - Canteen-Girls Hostel	20/02/2023
Comp. Dt. : 22/02/2023 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
41	23020861	Ladies hostel Phase-II	CAMERA NO-7,FOCUS CHANGE	Vivek. A.	kitchen camera position adjusment		Malliga. K. - Canteen-Girls Hostel	23/02/2023
Dept Name : Civil - Maintenance - Tele Exchange Comp. Dt. : 08/11/2022 Status : Completed								
42	22110306	NEW STP	INTERCOM NO. 2811 NOT WORKING	Vivek. A.	two pair cable changed probelm solved		Ranganathan. K. - Civil - Maintenance	09/11/2022
Dept Name : Computer Department - Tele Exchange Comp. Dt. : 03/01/2023 Status : Completed								
43	23010076	Ladies hostel Phase-II	IN KITCHEN-CAMERA NOT WORKING	Padmanaban. G.	kitchen camera lens cleaned up		Balachandar. A. - Computer Department	24/01/2023
44	23010078	Boys hostel	HARD DISC NOT WORKING	Vivek. A.	Change new Hadr disk problem complited		Selvam. D. - Computer Department	23/01/2023
Comp. Dt. : 11/01/2023 Status : Completed								
45	23010480	Polytechnic college	CAMERA NOT WORKING	Vivek. A.	main entrance camera changed probelm solved		Raja.B - Computer Department	08/02/2023
46	23010481	Nursing College	CAMERA NOT WORKING	Vivek. A.	1st floor right side camera refixed probelm solved		Raja.B - Computer Department	21/01/2023
Comp. Dt. : 18/01/2023 Status : Completed								
47	23010638	Lecture Hall 2	4 NO'S CAMERA NAME NOT GIVEN	Vivek. A.	ch-name changed		Valamburi. R. - Computer Department	18/01/2023
Comp. Dt. : 21/01/2023 Status : Completed								
48	23010760	Boys hostel	Reception camera not workingin bos hostel	Vivek. A.	camera changed probelm solved		Selvam. D. - Computer Department	30/01/2023
Comp. Dt. : 07/02/2023 Status : Completed								
49	23020219	MEDICAL COLLEGE	library harddisk move to lect 2	Vivek. A.	library hard disk 8 tb removed for lecture hall nvr 6 tb hard disk fixed		Valamburi. R. - Computer Department	08/02/2023
Comp. Dt. : 09/02/2023 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
50	23020326	DIRECTOR OFFICE-1ST FLOOR IN COLLEGE	DINING STEP CAMERA NOT WORKING	Vivek. A.	camera cable refixed probelm solved		Valamburi. R. - Computer Department	10/02/2023
51	23020327	MEDICAL COLLEGE	SECURITY CAMERA POSITION CHANGE	Padmanaban. G.	security camera refixed probelm solved		Valamburi. R. - Computer Department	10/02/2023
Comp. Dt. : 10/02/2023 Status : Completed								
52	23020403	DIGITAL LAB	11th channel camera name given	Vivek. A.	11 camera name changed		Valamburi. R. - Computer Department	20/02/2023
Comp. Dt. : 20/04/2023 Status : Completed								
53	23040628	Lecture Hall 2	TWO CAMERA NOT WORKING	Vivek. A.	poe swiche power on problem solved		Valamburi. R. - Computer Department	20/04/2023
Comp. Dt. : 05/05/2023 Status : Completed								
54	23050202	SKILL LAB - MEDICAL COLLEGE	NVR not working	Padmanaban. G.	Network problem complite		Selvam. D. - Computer Department	11/05/2023
Comp. Dt. : 17/05/2023 Status : Completed								
55	23050679	SMVPT	ONE CAMERA NOT WORKING	Vivek. A.	all camera working		Valamburi. R. - Computer Department	12/06/2023
56	23050681	Nursing College	8TH CHANNEL CAMERA POSITION CHANGE	Vivek. A.	camera position changed problem solved		Valamburi. R. - Computer Department	22/05/2023
Comp. Dt. : 31/05/2023 Status : Completed								
57	23051236	TELEPHONE DEPARTMENT IN EDP(UNDERGROUND)	2 camera not in college side	Vivek. A.	poe swiche cat 5 wire jack refixed		Selvam. D. - Computer Department	02/06/2023
Comp. Dt. : 14/06/2023 Status : Completed								
58	23060514	A.P Quateres	channel no:14 camera not working(anatomy back side)	Vivek. A.	camera ip changed problem solved		Shafiullah. R. - Computer Department	19/06/2023
Comp. Dt. : 30/06/2023 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
59	23061123	Lecture Hall1	Lecture hall 1 NVR all camera devices offline	Vivek. A.	poe swiche port changed		Selvam. D. - Computer Department	12/07/2023
Dept Name : Dermatology & Vener. - Tele Exchange Comp. Dt. : 02/09/2022 Status : Completed								
60	22090059	DERMATOLOGY OPD	intercome no 1073 problem	Vivek. A.	phone handset changed probelm solved		Jayachandran. M. - Dermatology & Vener.	02/09/2022
Dept Name : Director Office - Tele Exchange Comp. Dt. : 26/11/2022 Status : Completed								
61	22111131	A.P Quateres	IN OFFICE-INTERCOM 2679 NOT WORKING	Vivek. A.	coil cord changed probelm solved		Mani. A. - Director Office	26/11/2022
Dept Name : ENT & Ophthal Ward - Tele Exchange Comp. Dt. : 31/05/2023 Status : Completed								
62	23051234	Female Medical - Ward 305	INTERCOM DIAL NUMBER BUTTON NOT WORKING - NO 1316	Vivek. A.	puls/ton button adjesment		Bhuvaneswari. M. - ENT & Ophthal Ward	31/05/2023
Dept Name : ICU - Tele Exchange Comp. Dt. : 08/06/2022 Status : Completed								
63	22060285	ICU	INTERCOM NO 1115 NOT WORKING	Vivek. A.	line cord probelm new line cord changed		Latha. K. - ICU	10/06/2022
Dept Name : Male Surgery - Tele Exchange Comp. Dt. : 09/08/2022 Status : Completed								
64	22080344	Male Surgery - Ward 201	INTERCOM NO 1216 NOT WORKING	Vivek. A.	line cord + instrument changed probelm solved		Sivasankari. T. - Male Surgery	11/08/2022
Dept Name : Nursing Office - Tele Exchange Comp. Dt. : 16/07/2022 Status : Completed								
65	22070628	Male Ortho - Ward 404	INTERCOM NO 1409 NOT WORKING	Vivek. A.	instrument damage new instrument fixed probelm solved		Jenit Jerlin. D. - Male Ortho Ward	18/07/2022
Dept Name : OPD - Tele Exchange Comp. Dt. : 18/04/2023 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
66	23040565	TB & Chest OPD	INTER COM NOT WORKING	Vivek. A.	coil cord chnaged		Jothi.R. - OPD	19/04/2023
Dept Name : Physical Education - Tele Exchange Comp. Dt. : 31/12/2022 Status : Completed								
67	22121394	Boys hostel	INTERCOM 2048 NOT WORKING	Vivek. A.	line cord + instrument changed probelm solved		Vijayakumar. M. - Physical Education	02/01/2023
Dept Name : PHYSIOLOGY - Tele Exchange Comp. Dt. : 18/10/2022 Status : Completed								
68	22100600	PHYSIOLOGY-- -COLLEGE	INTERCOM NO:2035 NOT WORKING	Vivek. A.	instrument damage new instrument fixed		Shanthini. M. - BIOCHEMISTRY	19/10/2022
Comp. Dt. : 21/12/2022 Status : Completed								
69	22120977	PHYSIOLOGY-- -COLLEGE	INTERCOM NO. 2006, 2038 NOT WORKING - 2 NOS	Vivek. A.	two pair cable disconnected cable rejoin probelm solved		Shanthini. M. - BIOCHEMISTRY	22/12/2022
Comp. Dt. : 22/12/2022 Status : Completed								
70	22120999	PHYSIOLOGY-- -COLLEGE	INTERCOM NO. 2035 NOT WORKING	Vivek. A.	two pair cable disconnected cable rejoin probelm solved		Shanthini. M. - BIOCHEMISTRY	22/12/2022
Dept Name : POW & SICU - Tele Exchange Comp. Dt. : 14/02/2023 Status : Completed								
71	23020548	SICU	INTERCOM NO 1320 NOT WORKING [AUDIO PROBLEM]	Vivek. A.	coil cord changed		Gunavathi. G. - POW & SICU	15/02/2023
Dept Name : Security - SIS - Tele Exchange Comp. Dt. : 24/11/2022 Status : Completed								
72	22111047	Mit boys hostel	INTERCOM 2122 NOT WORKING	Vivek. A.	two pair cable changed probelm solved		Ganesan. R. - Security - SIS	12/12/2022
Dept Name : SMV Allied Health Sciences - Tele Exchange Comp. Dt. : 08/02/2023 Status : Completed								
73	23020312	MICROBIOLOGY IN COLLEGE	CAMERA DIRECTION ADJUSTING WORK IN 3RD FLOOR LECTURE HALL - 5	Vivek. A.	camera position changed probelm solved		Affik Moideen. M. - Allied Health Sciences	10/02/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Dept Name : Special Clinic - Office - Tele Exchange Comp. Dt. : 09/06/2023 Status : Completed								
74	23060309	SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	INTERCOM NO 1456 NOT WORKING	Vivek. A.	coil cord changed problem solved		Thamizhselvi. S. - Administration	10/06/2023
Dept Name : Special Ward - Tele Exchange Comp. Dt. : 02/09/2022 Status : Completed								
75	22090103	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	INTER COM 1098 NOT WORKING	Vivek. A.	two pair cable disconnected rejoin problem solved		Elakkiya. S. - Special Ward	05/09/2022
Comp. Dt. : 10/05/2023 Status : Completed								
76	23050404	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	INTER COM NOT WORKING	Vivek. A.	cable issue		Pushpa. K. - Special Ward	20/05/2023
College Name : SMVMCH-COL Work Type : Complaint Dept Name : ANATOMY - Tele Exchange Comp. Dt. : 14/07/2022 Status : Completed								
77	22070529	ANATOMY	INTERCOM NO 2025 NOT WORKING	Vivek. A.	puls/ton button refixed problem solved		Mathivanan.B. - ANATOMY	18/07/2022
Comp. Dt. : 16/09/2022 Status : Completed								
78	22090652	ANATOMY	INTERCOM NO 2025 NOT WORKING	Vivek. A.	line cord changed problem solved		Mathivanan.B. - ANATOMY	19/09/2022
Dept Name : BIOCHEMISTRY - Tele Exchange Comp. Dt. : 10/05/2022 Status : Completed								
79	22050347	BIOCHEMISTRY--COLLEGE	INTERCOM NO 2055 NOT WORKING - C R L LAB	Vivek. A.	puls\ton button changed		Suganthi. P. - BIOCHEMISTRY	10/05/2022
Comp. Dt. : 18/05/2022 Status : Completed								
80	22050649	Central Research Lab	INTERCOM NO 2055 NOT WORKING	Vivek. A.	port issue port number changed problem solved		Anusuya. J. - BIOCHEMISTRY	18/05/2022
Comp. Dt. : 07/09/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
81	22090270	BIOCHEMISTRY-- -COLLEGE	INTERCOM NO 2077 NOT WORKING	Vivek. A.	two pair cable disconnected rejoin probelm solved		Suganthi. P. - BIOCHEMISTRY	08/09/2022
Comp. Dt. : 28/11/2022 Status : Completed								
82	22111179	BIOCHEMISTRY-- -COLLEGE	INTERCOM 2008 NOT WORKING	Vivek. A.	instrument handset changed probelm solved		Suganthi. P. - BIOCHEMISTRY	29/11/2022
Comp. Dt. : 13/03/2023 Status : Completed								
83	23030502	BIOCHEMISTRY-- -COLLEGE	INTERCOM NO 2077 NOT WORKING	Vivek. A.	hospital-to- medical college telephone cable pair changed problem solved		Suganthi. P. - BIOCHEMISTRY	24/03/2023
Comp. Dt. : 15/03/2023 Status : Completed								
84	23030623	BIOCHEMISTRY-- -COLLEGE	NEED TO EXTEND INTERCOM CABLE [NO 2051]	Vivek. A.	line cord changed probelm solved		Suganthi. P. - BIOCHEMISTRY	24/03/2023
Dept Name : COMMUNITY MEDICINE - Tele Exchange Comp. Dt. : 27/07/2022 Status : Completed								
85	22070988	COMMUNITY MEDICINE DEPT IN MEDICAL COLLEGE	PROBLEMS IN INCOMING CALLS - NEED TO CHECK INTERCOM NO 2073 - NEED URGENT SERVICE	Vivek. A.	2073 call forward probelm solved		Sunitha. P. - COMMUNITY MEDICINE	27/07/2022
Comp. Dt. : 03/08/2022 Status : Completed								
86	22080140	COMMUNITY MEDICINE DEPT IN MEDICAL COLLEGE	INTERCOM NO 2074 NOT WORKING	Vivek. A.	line cord problem .change new line cord		Rajalakshmi. M. - COMMUNITY MEDICINE	04/08/2022
Comp. Dt. : 10/09/2022 Status : Completed								
87	22090399	COMMUNITY MEDICINE DEPT IN MEDICAL COLLEGE	INTERCOM NO 2396 [PARALLEL LINE] IN NAC OFFICE NOT WORKING	Vivek. A.	line cord changed probelm solved		Rajesh. D. - COMMUNITY MEDICINE	12/09/2022
Comp. Dt. : 03/11/2022 Status : Completed								
88	22110068	COMMUNITY MEDICINE DEPT IN MEDICAL COLLEGE	INTERCOM 2073 NOT WORKING	Vivek. A.	telephone cable changed probelm solved		uthuvel. A. - COMMUNITY MEDICINE	07/11/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 06/03/2023 Status : Completed								
89	23030233	COMMUNITY MEDICINE DEPT IN MEDICAL COLLEGE	NEED TO CHANGE INTERCOM LINE NO 2396 TO NEW CHANGED PLACE	Vivek. A.	line shifting 2396 problem solved		Vijai. A. - COMMUNITY MEDICINE	11/03/2023
Comp. Dt. : 08/03/2023 Status : Completed								
90	23030306	MEDICAL COLLEGE III FLOOR	NEED TO CHANGE INTERCOM LINE CONNECTION [NAC OFFICE]	Vivek. A.	line shifting 2396 problem solved		Rajesh. D. - COMMUNITY MEDICINE	11/03/2023
Comp. Dt. : 04/04/2023 Status : Completed								
91	23040097	COMMUNITY MEDICINE DEPT IN MEDICAL COLLEGE	INTERCOM NO 2096 NOT WORKING [DR. PREM ANAND - PROF ROOM]	Vivek. A.	two pair cable changed problem solved		Sunitha. P. - COMMUNITY MEDICINE	06/04/2023
Dept Name : Computer Department - Tele Exchange Comp. Dt. : 14/11/2022 Status : Completed								
92	22110504	DIGITAL LAB	INTERCOM 2003 NOT WORKING	Vivek. A.	port number changed probelm solved		Madhubalan. S. - Computer Department	14/11/2022
Comp. Dt. : 30/01/2023 Status : Completed								
93	23011048	Hospital	HOSPITAL ALL FLOOR - CCTV CAMERA - NO NAME	Vivek. A.	camera-ch-name changed		Murugavel.R - Computer Department	31/01/2023
Comp. Dt. : 19/05/2023 Status : Completed								
94	23050803	Director Office	CAMERA NOT WORKING AT DIRECTOR OFFICE CANTEEN SIDE	Vivek. A.	camera side jack refixed problem solved		Selvam. D. - Computer Department	22/05/2023
Dept Name : Director Office - Tele Exchange Comp. Dt. : 26/10/2022 Status : Pending								
95	22100816	Electrical Maintanance College	TELEPHONE WIRE ARRANGEMENT WORK	Padmanaban. G.			Bala Murugan.K. - Director Office	
Comp. Dt. : 07/01/2023 Status : Completed								
96	23010323	Director Office	INTERCOM 2080 NOT WORKING	Vivek. A.	coil cord chaged probelm solved		Vijayalakshmi. G. D. - Director Office	09/01/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 15/02/2023 Status : Completed								
97	23020575	Director Office	INTERCOM NO 2089 NOT WORKING - CABLE PROBLEM	Vivek. A.	line cord jack changed		Vijayalakshmi. G. D. - Director Office	20/02/2023
Dept Name : FORENSIC MEDICINE - Tele Exchange Comp. Dt. : 14/06/2022 Status : Completed								
98	22060523	FORENSIC MEDICINE (3RD FLOOR) IN COLLEGE	INTERCOM NO 2098 & 2100 NOT WORKING	Vivek. A.	hanset speaker refixed probelm solved		Mathavi. B. - FORENSIC MEDICINE	04/07/2022
Comp. Dt. : 21/09/2022 Status : Completed								
99	22090819	FORENSIC MEDICINE (3RD FLOOR) IN COLLEGE	INTERCOM NO 2413 [DEAN SIR OFFICE] NOT WORKING - AUDIO & CABLE PROBLEM	Vivek. A.	puls/ton button adujesment		Mathavi. B. - FORENSIC MEDICINE	21/09/2022
Dept Name : MICROBIOLOGY - Tele Exchange Comp. Dt. : 02/05/2022 Status : Completed								
100	22050016	MICROBIOLOGY IN COLLEGE	INTERCOM NO 2052 & 2053 NOT WORKING	Vivek. A.	line cord changed probbelm solved		Buvana. C. - MICROBIOLOGY	02/05/2022
Comp. Dt. : 26/07/2022 Status : Completed								
101	22070937	MICROBIOLOGY IN COLLEGE	INTERCOM NO 2375 NOT WORKING	Vivek. A.	puls/ton button changed		Praveenkumar. S. - MICROBIOLOGY	26/07/2022
Comp. Dt. : 02/09/2022 Status : Completed								
102	22090108	MICROBIOLOGY IN COLLEGE	INTERCOM NO. 2054 NOT WORKING (MICROBIOLOGY 2ND FLOOR)	Vivek. A.	two pair line disconnected rejoin probelm solved		Buvana. C. - MICROBIOLOGY	05/09/2022
Comp. Dt. : 16/11/2022 Status : Completed								
103	22110685	MICROBIOLOGY IN COLLEGE	IN PROFESSOR ROOM-INTERCOM 2092 NOT WORKING	Vivek. A.	keepad changed probelm solved		Buvana. C. - MICROBIOLOGY	21/11/2022
Comp. Dt. : 12/01/2023 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
104	23010503	MICROBIOLOGY IN COLLEGE	INTERCOM NO. 2085 NOT WORKING	Vivek. A.	puls/ton button changed		Mageswari. R. - MICROBIOLOGY	12/01/2023
Comp. Dt. : 24/01/2023 Status : Completed								
105	23010880	MICROBIOLOGY IN COLLEGE	INTERCOM NO 2085 NOT WORKING - OUT GOING PROBLEM	Vivek. A.	instrument mother bord issue new instrument fixed probelm solved		Gopal. R. - MICROBIOLOGY	25/01/2023
Dept Name : MS Office - Tele Exchange Comp. Dt. : 30/07/2022 Status : Completed								
106	22071101	NEW SKILL LAB - MEDICAL COLLEGE	INTERCOM NO 2001 NOT WORKING [SOUND PROBLEM]	Vivek. A.	port issue		Elumalai. M. - MS Office	09/08/2022
Dept Name : PATHOLOGY - Tele Exchange Comp. Dt. : 03/11/2022 Status : Completed								
107	22110102	PATHOLOGY IN COLLEGE	INTERCOM 2010 NOT WORKING	Vivek. A.	coil cord changed probelm solved		Kalaichelvi.M. - PATHOLOGY	04/11/2022
Comp. Dt. : 06/04/2023 Status : Completed								
108	23040209	PATHOLOGY IN COLLEGE	INTERCOM NO 2010 NOT WORKING	Vivek. A.	coil cord changed problem solved		Kalaichelvi.M. - PATHOLOGY	06/04/2023
Dept Name : PHARMACOLOGY - Tele Exchange Comp. Dt. : 12/07/2022 Status : Completed								
109	22070471	PHARMACOLOGY	INTERCOM NO 2081 NOT WORKING	Vivek. A.	line cord jack changed		Panchali. P. - PHARMACOLOGY	18/07/2022
Comp. Dt. : 17/08/2022 Status : Completed								
110	22080530	Animal House	INTERCOM 2045 NOT WORKING	Vivek. A.	port number issue port changed probelm solved		Panchali. P. - PHARMACOLOGY	26/08/2022
Comp. Dt. : 24/08/2022 Status : Completed								
111	22080795	PHARMACOLOGY	INTERCOM NO 2081 NOT WORKING	Vivek. A.	instrument motherbord changed probelm solved		Devanathan. S. - PHARMACOLOGY	26/08/2022
Comp. Dt. : 16/02/2023 Status : Completed								
112	23020659	Animal House	INTERCOM NO-2045,NOT WORKING	Vivek. A.	two pair cable changed probelm solved		Panchali. P. - PHARMACOLOGY	01/03/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 28/02/2023 Status : Completed								
113	23021072	Animal House	INTERCOM NOT WORKING	Vivek. A.	two pair cable changed		Panchali. P. - PHARMACOLOGY	01/03/2023
Comp. Dt. : 24/03/2023 Status : Completed								
114	23031017	PHARMACOLOGY	INTERCOM NO 2081 NOT WORKING	Vivek. A.	hanset speaker refixed		Nageswari. S. - PHARMACOLOGY	24/03/2023
Comp. Dt. : 30/03/2023 Status : Completed								
115	23031309	PHARMACOLOGY	NEED TO CHECK INTERCOM LINE CONNECTION [NO 2081] LINE CROSS	Vivek. A.	line connection check problem solved		Nageswari. S. - PHARMACOLOGY	01/04/2023
Comp. Dt. : 01/06/2023 Status : Completed								
116	23060032	PHARMACOLOGY	INTERCOM NO 2081 - NOT WORKING	Vivek. A.	instrument changed		Nageswari. S. - PHARMACOLOGY	05/06/2023
Dept Name : PHYSIOLOGY - Tele Exchange Comp. Dt. : 27/09/2022 Status : Completed								
117	22091039	PHYSIOLOGY-- -COLLEGE	INTERCOM NO 2033 NOT WORKING	Vivek. A.	port issue		Shanthini. M. - BIOCHEMISTRY	11/10/2022
Comp. Dt. : 29/09/2022 Status : Completed								
118	22091172	PHYSIOLOGY-- -COLLEGE	INTERCOM NO 2006 NOT WORKING	Vivek. A.	line cord changed probelm solved		Balasankar. P. - PHYSIOLOGY	01/10/2022
Comp. Dt. : 31/10/2022 Status : Completed								
119	22101039	PHYSIOLOGY	INTERCOM N-2033,-INTERCOM PIN PLUGPOINT LOOSE POSITION	Vivek. A.	cable issue		Jayanthi.A. - PHYSIOLOGY	03/11/2022
Comp. Dt. : 22/11/2022 Status : Completed								
120	22110942	MEDICAL COLLEGE	INTERCOM MODEM BROKEN NO:2035	Vivek. A.	100 pair cable issue		Balasankar. P. - PHYSIOLOGY	12/12/2022
Comp. Dt. : 05/01/2023 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
121	23010235	PHYSIOLOGY-- -COLLEGE	INTERCOM 2035 NOT WORKING	Padmanaban. G.	two pair cable changed problem solved		Deepika. V. - PHYSIOLOGY	13/03/2023
Comp. Dt. : 25/03/2023 Status : Completed								
122	23031042	PHYSIOLOGY-- -COLLEGE	NEED TO REARRANGE TELEPHONE CABLE	Vivek. A.	telephone box wire colsed problem solved		Shanthini. M. - BIOCHEMISTRY	01/04/2023
Dept Name : Security - SIS - Tele Exchange Comp. Dt. : 06/02/2023 Status : Completed								
123	23020173	MEDICAL COLLEGE GROUND FLOOR	INTERCOM NO 2002 NOT WORKING	Vivek. A.	line cord changed probelm solved		Prabakaran. P. - Security - SIS	06/02/2023
Dept Name : SMV Allied Health Sciences - Tele Exchange Comp. Dt. : 20/01/2023 Status : Completed								
124	23010714	MICROBIOLOGY IN COLLEGE	INTERCOM NO 2085 NOT WORKING	Vivek. A.	instrument mother bord issue new instrument fixed probelm solved		Raffik Moideen. M. - SMV Allied Health Sciences	25/01/2023
Comp. Dt. : 13/03/2023 Status : Completed								
125	23030514	MICROBIOLOGY IN COLLEGE	NEED TO REFIX CC TV CAMERA - LECTURE HALL IV	Vivek. A.	camera refixed		Raffik Moideen. M. - SMV Allied Health Sciences	16/03/2023
Comp. Dt. : 26/05/2023 Status : Completed								
126	23051029	LECTURE HALL V	NEED TO REFIX CAMERA	Vivek. A.	camera side new box fixed		Raffik Moideen. M. - SMV Allied Health Sciences	02/06/2023

College Name : SMVMCH-HOS

Work Type : Complaint

Dept Name : Administration - Tele Exchange

Comp. Dt. : 06/07/2022

Status : Completed

127	22070203	AO Office	INTERCOM NO 1137 NOT WORKING	Vivek. A.	coil cord changed		Elumalai.K.A. - Administration	06/07/2022

Comp. Dt. : 08/10/2022

Status : Completed

128	22100177	AO Office	INTERCOM NO. 1177 NOT WORKING	Vivek. A.	FLC card port issue reboot FLC card probelm solved		Shanthini Devi. R. K. - Administration	10/10/2022

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 03/06/2023 Status : Completed								
129	23060104	AO Office	INTERCOM NO 3018 NOT WORKING	Vivek. A.	caller id instrument changed		Shyamala. R. - Administration	03/06/2023
Dept Name : Air Condition Department - Tele Exchange Comp. Dt. : 16/05/2023 Status : Completed								
130	23050656	AC DEPT	INTERCOM NO 1119 NOT WORKING	Vivek. A.	new insturment changed problem solved		Panneer Selvam. P. - Air Condition Department	17/05/2023
Dept Name : Audit Wing - Tele Exchange Comp. Dt. : 16/05/2022 Status : Completed								
131	22050570	Audit Wing	INTERCOM NO 3066 CABLE PROBLEM	Vivek. A.	coil cord probelm new coil cord changed		Hari Ram Singh. B. - Audit Wing	17/05/2022
Dept Name : BIOCHEMISTRY - Tele Exchange Comp. Dt. : 08/08/2022 Status : Completed								
132	22080254	BIOCHEMISTRY	INTERCOM NO 1011 NOT WORKING	Vivek. A.	instrument keepad button changed probelm solved		Durga Devi. I. - BIOCHEMISTRY	09/08/2022
Comp. Dt. : 25/08/2022 Status : Completed								
133	22080846	Biochemistry Lab-Hospital	INTERCOM NO 1011 - NOISE PROBLEM	Vivek. A.	coil cord probelm solved		Srinivasamurugan. V. - BIOCHEMISTRY	26/08/2022
Comp. Dt. : 23/09/2022 Status : Completed								
134	22090957	Blood Collection Centre	INTERCOM NO 1008 - INCOMING PROBLEM	Vivek. A.	puls/ton button adjesment		Srinivasamurugan. V. - BIOCHEMISTRY	24/09/2022
Comp. Dt. : 02/12/2022 Status : Completed								
135	22120067	Reception	INTERCOM NO. 1021 NOT WORKING COUNTER NO. 8-9	Vivek. A.	two pair wire changed probelm solved		Srinivasamurugan. V. - BIOCHEMISTRY	02/12/2022
Comp. Dt. : 03/12/2022 Status : Completed								
136	22120103	Reception	INTERCOM NO. 1008 NOT WORKING	Vivek. A.	two pair cable changed probelm solved		Srinivasamurugan. V. - BIOCHEMISTRY	06/12/2022

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 12/01/2023 Status : Completed								
137	23010507	BIOCHEMISTRY-- -COLLEGE	INTERCOM NO. 2051 NOT WORKING	Vivek. A.	two pair wire changed probelm solved		Suganthi. P. - BIOCHEMISTRY	12/01/2023
Comp. Dt. : 09/03/2023 Status : Completed								
138	23030373	Reception	INTERCOM NO 1021 NOT WORKING	Vivek. A.	coil cord changed probelm solved		Srinivasamurugan. V. - BIOCHEMISTRY	09/03/2023
Comp. Dt. : 24/04/2023 Status : Completed								
139	23040738	Reception	NEED TO CHECK INTERCOM [AUDIO PROBLEM] NO 1021 - COUNTER NO 9	Vivek. A.	coil cord changed problem solved		Srinivasamurugan. V. - BIOCHEMISTRY	25/04/2023
Comp. Dt. : 02/05/2023 Status : Completed								
140	23050036	BIOCHEMISTRY	INTERCOM NO 1011 NOT WORKING - [KEYPAD , INCOMING]	Vivek. A.	instrument keypad chamged problem solved		Srinivasamurugan. V. - BIOCHEMISTRY	02/05/2023
Comp. Dt. : 05/06/2023 Status : Completed								
141	23060149	BIOCHEMISTRY	INTERCOM NO 1011 NOT WORKING	Vivek. A.	new instrument changed problem solved		Parameswari. G. - BIOCHEMISTRY	05/06/2023
Dept Name : BLOOD BANK - Tele Exchange Comp. Dt. : 29/05/2023 Status : Completed								
142	23051153	Blood Bank	INTERCOM NO 1001 NOT WORKING	Vivek. A.	line card changed		Haripriya. R. - BLOOD BANK	29/05/2023
Dept Name : Blood Collection Centre - Tele Exchange Comp. Dt. : 25/10/2022 Status : Completed								
143	22100764	Reception	INTERCOM NO:1021 NOT WORKING IN COUNTER NO:8	Vivek. A.	two pair cable changed probelm solved		Kasthuribai. J. - Blood Collection Centre	25/10/2022
Comp. Dt. : 28/11/2022 Status : Completed								
144	22111157	lab report issuing counter 8 in reception	intercom 1021 not working	Vivek. A.	two pair cable disconnected cable rejoint		Kasthuribai. J. - Blood Collection Centre	28/11/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Dept Name : Canteen - Boys Hostel - Tele Exchange Comp. Dt. : 13/06/2022 Status : Completed								
145	22060439	CANTEEN-COMMERCI L COMPLEX	INTERCOM NO 1029 NOT WORKING	Vivek. A.	line cord probelm new line cord changed		Anand. G. - Transport	14/06/2022
Comp. Dt. : 21/06/2022 Status : Completed								
146	22060754	STAFF'S CANTEEN	INTERCOM NO 1029 NOT WORKING	Vivek. A.	instrument damage new instrument fixed probelm solved		Anand. G. - Transport	22/06/2022
Comp. Dt. : 27/06/2022 Status : Completed								
147	22060957	STAFF'S CANTEEN	INTERCOM NO 1029 NOT WORKING	Vivek. A.	instrument keepad probelm keepad changed probelm solved		Anand. G. - Transport	27/06/2022
Comp. Dt. : 28/06/2022 Status : Completed								
148	22061003	Canteen - Boys Hostel	INTERCOM NO 2813 NOT WORKING - [AUDIO PROBLEM]	Vivek. A.	cable issue		Kesavaraj. P. - Canteen - Boys Hostel	18/07/2022
Comp. Dt. : 27/07/2022 Status : Completed								
149	22071033	Boys hostel	INTERCOM NO 2813 NOT WORKING	Vivek. A.	two pair cable changed probelm solved		Anand. G. - Transport	04/08/2022
Comp. Dt. : 29/07/2022 Status : Completed								
150	22071070	Boys hostel	INTERCOM NO 2813 NOT WORKING	Vivek. A.	two pair cable issue		Kesavaraj. P. - Canteen - Boys Hostel	01/08/2022
Comp. Dt. : 13/09/2022 Status : Completed								
151	22090476	STAFF'S CANTEEN IN COMMERCIAL BLOCK	INTERCOM NO 1029 NOT WORKING - AUDIO & SOUND PROBLEM	Vivek. A.	instrument damage instrument changed probelm solved		Anand. G. - Transport	13/09/2022
Comp. Dt. : 19/09/2022 Status : Completed								
152	22090694	Boys hostel	NEED TO CHECK & CHANGE INTERCOM CABLE FOR NO 2813	Vivek. A.	line cord changed probelm solved		Kesavaraj. P. - Canteen - Boys Hostel	19/09/2022
Comp. Dt. : 05/10/2022								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
153	22100055	Boys hostel Phase-II	CC TV CAMERA NOT WORKING AT II FLOOR	Vivek. A.	camera cable rejoin camera working probelm solved		Sambasivam. K. - Canteen - Boys Hostel	10/10/2022
Comp. Dt. : 02/12/2022								
Status : Completed								
154	22120100	Boys hostel PH-I	INTERCOM NO. 2048 NOT WORKING IN ROOM NO 2 IN PHYSICAL EDUCATION ROOM	Vivek. A.	line cord wire changed probelm solved		Sambasivam. K. - Canteen - Boys Hostel	06/12/2022
Comp. Dt. : 06/12/2022								
Status : Completed								
155	22120254	Boys hostel	IN WARDEN ROOM-INTERCOM 2812 NOT WORKING	Vivek. A.	two pair wire changed probelm solved		Anand. G. - Transport	06/12/2022
Comp. Dt. : 10/12/2022								
Status : Completed								
156	22120459	Mit boys hostel	INTERCOM NO 2122 NOT WORKING	Vivek. A.	two pair cable changed probelm solved		Sambasivam. K. - Canteen - Boys Hostel	12/12/2022
Comp. Dt. : 24/12/2022								
Status : Completed								
157	22121116	COMMERCIAL BLOCK	IN STAFF CANTEEN -INTERCOM 1029 AND 2812 NOT WORKING	Vivek. A.	instrument changed + coil cord changed probelm solved		Anand. G. - Transport	28/12/2022
Comp. Dt. : 03/02/2023								
Status : Completed								
158	23020077	STAFF'S CANTEEN IN COMMERCIAL BLOCK	INTERCOM NO 1029 NOT WORKING	Vivek. A.	instrument ringer changed pobelm solved		Anand. G. - Transport	06/02/2023
Comp. Dt. : 01/04/2023								
Status : Completed								
159	23040013	STAFF'S CANTEEN IN COMMERCIAL BLOCK	INTERCOM NO 1029 NOT WORKING	Vivek. A.	instrument motherbord changed problem solved		Anand. G. - Transport	03/04/2023
Comp. Dt. : 03/04/2023								
Status : Completed								
160	23040040	CANTEEN-COMMERCI L COMPLEX	INTERCOM NO 1029 NOT WORKING	Vivek. A.	instrument motherbord changed problem solved		Anand. G. - Transport	03/04/2023
Dept Name : Canteen - Hospital - Tele Exchange								
Comp. Dt. : 07/11/2022								
Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
161	22110203	DIET DEPARMENT	TELEPHONE WIRE LOOSE CONNECTION IN INTERCOM NO.1440	Vivek. A.	instrument keepad changed		Sankar. M. - Canteen - Hospital	10/11/2022
Comp. Dt. : 13/12/2022 Status : Completed								
162	22120581	DIET DEPARMENT	INTERCOM NO 1440 NOT WORKING	Vivek. A.	line cord changed probelm solved		Sankar. M. - Canteen - Hospital	13/12/2022
Dept Name : Canteen-Girls Hostel - Tele Exchange Comp. Dt. : 06/07/2022 Status : Completed								
163	22070193	Ladies hostel Phase-I	ENTRANCE CC TV CAMERA NOT WORKING	Vivek. A.	phase 1 enternce camera refixed probelm solved		Malliga. K. - Canteen-Girls Hostel	11/07/2022
Comp. Dt. : 11/07/2022 Status : Completed								
164	22070417	Ladies hostel Phase-II	PROBLEM IN C C TV CAMERA [PHASE I SIDE]	Vivek. A.	camera night vision probelm new camera refixed probelm solved		Malliga. K. - Canteen-Girls Hostel	21/07/2022
Comp. Dt. : 19/07/2022 Status : Completed								
165	22070710	Ladies hostel Phase-II	C C TV CAMERA NIGHT VISION PROBLEM AT PHASE I SIDE	Vivek. A.	camera night vision probelm new camera refixed probelm solved		Malliga. K. - Canteen-Girls Hostel	21/07/2022
Comp. Dt. : 26/07/2022 Status : Completed								
166	22070960	Ladies hostel Phase-II	INTERCOM NO 3044 - DIAL PAD DAMAGE	Vivek. A.	instrument keepad changed probelm solved		Malliga. K. - Canteen-Girls Hostel	27/07/2022
Comp. Dt. : 08/08/2022 Status : Completed								
167	22080249	Ladies hostel Phase-I	INTERCOM NO 3045 NOT WORKING	Vivek. A.	two pair wire disconnected wire rejoin probelm solved		Revathy. N. - Canteen-Girls Hostel	09/08/2022
Comp. Dt. : 27/08/2022 Status : Completed								
168	22080934	Ladies hostel Phase-II	INTER COM NO 3044 SOUND PROBLEM	Vivek. A.	ringer agesment probelm solved		Malliga. K. - Canteen-Girls Hostel	30/08/2022
Comp. Dt. : 29/08/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
169	22080977	Ladies hostel Phase-II	INTERCOM NO 3044 NOT WORKING	Vivek. A.	two pair cable changed probelm solved		Virgin Mary - Canteen-Girls Hostel	30/08/2022
	Comp. Dt. : 21/11/2022							
	Status : Completed							
170	22110840	J.R Quateres	INTERCOM 3042 NOT WORKING	Vivek. A.	two pair cable changed probelm solved		Virgin Mary - Canteen-Girls Hostel	22/11/2022
	Comp. Dt. : 13/12/2022							
	Status : Completed							
171	22120583	Ladies hostel Phase-II	INTERCOM NO 3044 NOT WORKING	Vivek. A.	puls/ton button adjesment		Malliga. K. - Canteen-Girls Hostel	13/12/2022
	Comp. Dt. : 14/12/2022							
	Status : Completed							
172	22120664	JR Quarters	INTERCOM NO 3042 NOT WORKING	Vivek. A.	two pair line changed probelm solved		Virgin Mary - Canteen-Girls Hostel	17/12/2022
	Comp. Dt. : 17/12/2022							
	Status : Completed							
173	22120808	JR Quarters	CC TV CAMERA [JR OPPOSITE] NOT WORKING	Vivek. A.	camera ip changed probelm solved		Virgin Mary - Canteen-Girls Hostel	22/12/2022
174	22120811	Ladies hostel Phase-II	CC TV CAMERA [MESS OPPOSITE] NOT WORKING	Vivek. A.	camera ip changed probelm solved		Malliga. K. - Canteen-Girls Hostel	22/12/2022
	Comp. Dt. : 14/02/2023							
	Status : Completed							
175	23020511	JR Quarters	INTERCOM NO 3042 NOT WORKING	Vivek. A.	instrument changed		Virgin Mary - Canteen-Girls Hostel	14/02/2023
	Comp. Dt. : 07/03/2023							
	Status : Completed							
176	23030261	JR Quarters	INTERCOM NO 3042 NOT WORKING	Vivek. A.	puls/ton button adjustment		Virgin Mary - Canteen-Girls Hostel	07/03/2023
	Comp. Dt. : 09/03/2023							
	Status : Completed							
177	23030357	JR Quarters	INTERCOM NO 3042 NOT WORKING	Vivek. A.	two pair cable changed problem solved		Virgin Mary - Canteen-Girls Hostel	11/03/2023
	Comp. Dt. : 11/03/2023							
	Status : Completed							
178	23030454	JR Quarters	NEED TO CHECK ENTRANCE CC TV CAMERA - NOT WORKING	Vivek. A.	stp cat 6 cable rejoin probelm solved		Virgin Mary - Canteen-Girls Hostel	15/03/2023
	Comp. Dt. : 17/03/2023							
	Status : Completed							


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
179	23030690	JR Quarters	PROBLEM IN ENTRANCE CAMERA	Vivek. A.	camera cat 6 cable rejoin problem solved		Virgin Mary - Canteen-Girls Hostel	28/03/2023
Comp. Dt. : 21/03/2023 Status : Completed								
180	23030853	Ladies hostel Phase-II	NEED TO CHECK CAMERA NO 4 & 8 - NOT WORKING	Vivek. A.	cat 5 cable issue		Malliga. K. - Canteen-Girls Hostel	22/05/2023
Comp. Dt. : 23/03/2023 Status : Completed								
181	23030958	JR Quarters	C C TV CAMERA NOT WORKING AT ENTRANCE	Vivek. A.	camera cat 6 cable rejoin		Virgin Mary - Canteen-Girls Hostel	28/03/2023
Comp. Dt. : 27/03/2023 Status : Completed								
182	23031124	Ladies hostel Phase-I	INTERCOM NO 3045 NOT WORKING	Vivek. A.	port issue port reboot problem solved		Revathy. N. - Canteen-Girls Hostel	28/03/2023
Comp. Dt. : 25/04/2023 Status : Completed								
183	23040784	JR Quarters	CAMERA NOT WORKING AT ENTRANCE	Vivek. A.	camera removed		Virgin Mary - Canteen-Girls Hostel	08/05/2023
Comp. Dt. : 28/04/2023 Status : Completed								
184	23040964	Ladies hostel Phase-II	CAMERA 2 NOS NOT WORKING	Vivek. A.	poe switch issue		Malliga. K. - Canteen-Girls Hostel	02/05/2023
Comp. Dt. : 08/05/2023 Status : Completed								
185	23050288	Ladies hostel Phase-II	CC TV CAMERA NOT WORKING - AT ENTRANCE	Vivek. A.	camera position changed		Malliga. K. - Canteen-Girls Hostel	09/05/2023
Comp. Dt. : 05/06/2023 Status : Completed								
186	23060126	JR Quarters	NEED TO CHECK CAMERA - DISPLAYED GREEN COLOUR	Vivek. A.	monitor VGA cable changed problem solved		Virgin Mary - Canteen-Girls Hostel	07/06/2023
Comp. Dt. : 12/06/2023 Status : Completed								
187	23060394	JR Quarters	CAMERA NOT WORKING	Vivek. A.	power switch refixed problem solved		Virgin Mary - Canteen-Girls Hostel	12/06/2023
Comp. Dt. : 12/06/2023 Status : Completed								
Dept Name : CARDIOLOGY - Tele Exchange Comp. Dt. : 02/06/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
188	22060058	ECHO CARDIO GRAM	INTERCOM NO 1038 NOT WORKING	Vivek. A.	line cord jack probelm new line cord jack refixed		Ramani Palanivel.P. - CARDIOLOGY	02/06/2022
Comp. Dt. : 20/07/2022 Status : Completed								
189	22070756	ECHO CARDIO GRAM	INTERCOM NO 1090 NOT WORKING	Vivek. A.	instrument keepad probelm new keepad fixed		Ramani Palanivel.P. - CARDIOLOGY	20/07/2022
Comp. Dt. : 20/04/2023 Status : Completed								
190	23040661	ECHO CARDIO GRAM	INTERCOM NO 1038 NOT WORKING	Vivek. A.	line cord changed		Ramani Palanivel.P. - CARDIOLOGY	22/04/2023
Comp. Dt. : 01/06/2023 Status : Completed								
191	23060014	ECHO CARDIO GRAM	INTERCOM NO 1038 NOT WORKING	Vivek. A.	line card jack changed problem solved		Ramani Palanivel.P. - CARDIOLOGY	01/06/2023
Dept Name : Cardiothoracic ICU - Tele Exchange Comp. Dt. : 27/06/2022 Status : Completed								
192	22060951	SPECIAL WARD---B	INTERCOM NO 1459 NOT WORKING	Vivek. A.	line cord jack probelm new line jack crimping		Nilavu. K. - Cardiothoracic POW	27/06/2022
Comp. Dt. : 18/07/2022 Status : Completed								
193	22070675	CT-ICU ROOM-NEAR ORTHO OT RECOVERY ROOM	INTERCOM NO 1112 NOT WORKING	Vivek. A.	line cord changed probelm solved		Aswani. J. - Cardiothoracic ICU	19/07/2022
Comp. Dt. : 03/05/2023 Status : Completed								
194	23050095	CT-ICU ROOM-NEAR ORTHO OT RECOVERY ROOM	INTERCOM NO 1112 NOT WORKING	Vivek. A.	line cord jack and coil cord changed problem solved		Sadham Husain. S. - Cardiothoracic ICU	03/05/2023
Comp. Dt. : 09/05/2023 Status : Completed								
195	23050342	CT-ICU ROOM-NEAR ORTHO OT RECOVERY ROOM	INTERCOM NO 1112 NOT WORKING	Vivek. A.	coil cord changed problem solved		Sadham Husain. S. - Cardiothoracic ICU	10/05/2023
Comp. Dt. : 11/05/2023 Status : Request Cancel								
196	23050434	CT-ICU ROOM-NEAR ORTHO OT RECOVERY ROOM	INTERCOM NO 1112 NOT WORKING	Vivek. A.	coil cord and line jack changed		Sadham Husain. S. - Cardiothoracic ICU	


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 15/06/2023 Status : Completed								
197	23060520	CTVS INSIDE ORTHO OT	INTERCOM NOT WORKING PROPERLY(1112)	Vivek. A.	new instrument changed problem solved		Isaivani. R. - Cardiothoracic ICU	15/06/2023
Dept Name : Cardiothoracic POW - Tele Exchange Comp. Dt. : 15/05/2023 Status : Completed								
198	23050577	CT-POST OPERATIVE WARD IN 4TH FLOOR	INTERCOM NO 1459 NOT WORKING	Vivek. A.	line cord changed problem solved		Srimathi. V. - Cardiothoracic POW	15/05/2023
Dept Name : Cardiothoracic Surgery - Tele Exchange Comp. Dt. : 07/05/2022 Status : Completed								
199	22050224	ORTHO OT	INTERCOM NO 1117 - NOT WORKING [DIAL BUTTON NO " 7 " NOT WORKING]	Vivek. A.	instrument keypad button changed		Haripriya. T. - Cardiothoracic Surgery	07/05/2022
Comp. Dt. : 17/11/2022 Status : Completed								
200	22110718	CTVS-ROOM NO.225 -2ND FLOOR	INTERCOM 1255 NOT WORKING	Vivek. A.	two pair cable changed probelm solved		Rajasekar. M. - Cardiothoracic Surgery	21/11/2022
Dept Name : Civil - Maintenance - Tele Exchange Comp. Dt. : 02/07/2022 Status : Completed								
201	22070057	Civil - Maintenance	NEED TO CHANGE INTERCOM CABLE - DAMAGE FOR NO 1661	Vivek. A.	coil cord probelm coil cord changed		Gurunathan. V. - Civil - Maintenance	02/07/2022
Comp. Dt. : 25/07/2022 Status : Completed								
202	22070898	Civil - Maintenance	NEED TO CHECK INTERCOM DIAL KEY PAD - NOT WORKING	Vivek. A.	instrument damage new instrument fixed		Gurunathan. V. - Civil - Maintenance	25/07/2022
Comp. Dt. : 11/10/2022 Status : Completed								
203	22100300	NEW STP	INTERCOM NO 2811 NOT WORKING	Vivek. A.	two pair cable changed probelm solved		Ranganathan. K. - Civil - Maintenance	09/11/2022
Comp. Dt. : 03/06/2023 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
204	23060088	OLD STP PLANT	INTERCOM NO 2810 & 2811 NOT WORKING [OLD STP & NEW STP]	Vivek. A.	cable stock no		Ranganathan. K. - Civil - Maintenance	26/06/2023
Dept Name : Clinical Department - Tele Exchange Comp. Dt. : 17/08/2022 Status : Completed								
205	22080514	CLINICAL DEPARTMENT IN 2ND FLOOR	IN ROOMNO.3 INTERCOM 1248 NOT WORKING	Vivek. A.	instrument receiver changede probelm solved		Kheerthikaa. V. - Clinical Department	17/08/2022
Comp. Dt. : 14/09/2022 Status : Completed								
206	22090553	CLINICAL DEPARTMENT IN 4th FLOOR	INTERCOM NO 1410 NOT WORKING	Vivek. A.	coil cord changed probelm solved		Vimal. P. - Clinical Department	15/09/2022
Comp. Dt. : 16/09/2022 Status : Completed								
207	22090643	CLINICAL DEPARTMENT IN 2ND FLOOR	PROBLEM IN INTERCOM NO 1238 - LINE CROSSING & NOT WORKING	Vivek. A.	port issue reboot port probelm solved		Kheerthikaa. V. - Clinical Department	17/09/2022
Comp. Dt. : 06/12/2022 Status : Completed								
208	22120221	CLINICAL DEPARTMENT IN 4th FLOOR	INTERCOM NO 1410 NOT WORKING	Vivek. A.	puls/ton button changed probelm solved		Patchammal. K. - Clinical Department	06/12/2022
Comp. Dt. : 08/02/2023 Status : Completed								
209	23020269	CLINICAL DEPARTMENT IN 2ND FLOOR	INTERCOM NO. 1242 NOT WORKING	Vivek. A.	coil cord changed probelm solved		Vidhyavathi. S. - Clinical Department	08/02/2023
210	23020284	CLINICAL DEPARTMENT IN 3RD FLOOR	INTERCOM NO. 1347 PROBLEM	Vivek. A.	coil cord changed		Priya. S. - Clinical Department	08/02/2023
Comp. Dt. : 05/05/2023 Status : Completed								
211	23050198	CLINICAL DEPARTMENT IN 3RD FLOOR	INTERCOM NO 1347 NOT WORKING	Vivek. A.	coil cord changed problem solved		Bhuvana.M. - Clinical Department	05/05/2023
Comp. Dt. : 22/05/2023 Status : Completed								
212	23050863	CLINICAL DEPARTMENT IN 4th FLOOR	INTERCOM NO 1410 NOT WORKING	Vivek. A.	coil cord changed		Patchammal. K. - Clinical Department	29/05/2023
Comp. Dt. : 09/06/2023 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
213	23060344	CLINICAL DEPARTMENT IN 4th FLOOR	NEED TO PROVIDE A NEW INTERCOM LINE CONNECTION FOR LEAFT SIDE ROOM NO 2	Vivek. A.	cable issue		Vijayalakshmi.N - Clinical Department	08/07/2023
Comp. Dt. : 12/06/2023 Status : Completed								
214	23060423	CLINICAL DEPARTMENT IN 4th FLOOR	INTERCOM NO 1410 NOT WORKING [SOUND PROBLEM]	Vivek. A.	coil cord changed		Vimal. P. - Clinical Department	13/06/2023
Comp. Dt. : 16/06/2023 Status : Completed								
215	23060582	CLINICAL DEPARTMENT IN 4th FLOOR	INTERCOM NO.1410 NOT WORKING	Vivek. A.	coil cord changed problem solved		Vimal. P. - Clinical Department	16/06/2023
Dept Name : CLINICAL PATHOLOGY - Tele Exchange Comp. Dt. : 04/05/2022 Status : Completed								
216	22050067	Clinical Pathology	NEED TO REFIX INTERCOM CABLE - PROBLEM	Vivek. A.	coi cord changed		Sivasakthi. D. - CLINICAL PATHOLOGY	05/05/2022
Comp. Dt. : 11/08/2022 Status : Completed								
217	22080407	Clinical Pathology	INTERCOM NO 1007 NOT WORKING - [OUT GOING PROBLEM]	Vivek. A.	instrument probelm new instrument xed		Vinothini. R. - CLINICAL PATHOLOGY	11/08/2022
Comp. Dt. : 21/01/2023 Status : Completed								
218	23010763	Clinical Pathology	INTERCOM NO 1007 NOT WORKING	Vivek. A.	hanset speaker refixed probelm solved		Vinod Gnana Kumar. D. - CLINICAL PATHOLOGY	21/01/2023
Comp. Dt. : 20/03/2023 Status : Completed								
219	23030759	Clinical Pathology	INTERCOM NO 1007 NOT WORKING	Vivek. A.	hanset speaker wire rejoint proble solved		Malathi. M. - CLINICAL PATHOLOGY	20/03/2023
Dept Name : COMMUNITY MEDICINE - Tele Exchange Comp. Dt. : 01/09/2022 Status : Completed								
220	22090012	COMMUNITY MEDICINE DEPT IN MEDICAL COLLEGE	NEED TO REPLACE [ANOTHER TABLE] INTERCOM - NO 2090	Vivek. A.	line cord changed probelm solved		Sunitha. P. - COMMUNITY MEDICINE	05/09/2022

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 07/12/2022 Status : Completed								
221	22120325	Dean Office	NEED TO CHECK AND CHANGE INTERCOM NO 2073 CABLES & SOUND PROBLEM	Vivek. A.	line cord + coil cord changed probelm solved		Sunitha. P. - COMMUNITY MEDICINE	07/12/2022
Dept Name : Computer Department - Tele Exchange Comp. Dt. : 23/11/2022 Status : Completed								
222	22110989	DIGITAL LAB	INTERCOM 2003 NOT WORKING	Vivek. A.	port issue port number changed		Balachandar. A. - Computer Department	24/11/2022
Comp. Dt. : 02/01/2023 Status : Completed								
223	23010045	Hospital	IN ALL FLOOR NVR,CH-6 AND CH-13 POSITION TIME AND NO NAME	Vivek. A.	ch-6 camera position adijesment 13-camera time changed		Raja.B - Computer Department	06/01/2023
224	23010047	BASEMENT AUDITORIUM	AUDITORIUM NVR NO NAME	Vivek. A.	AUDITORIUM NVR CH-NAME CHANGED		Raja.B - Computer Department	05/01/2023
225	23010048	Hospital	CMD AND AO NVR CHANNEL-27 POSITION CHANGE	Vivek. A.	AO NVR CHANNEL-27 POSITION changed probelm solved		Raja.B - Computer Department	06/01/2023
226	23010049	SPECIALITY OT	OT NVR NO NAME	Vivek. A.	OT NVR CH-NAME CHANGED		Raja.B - Computer Department	05/01/2023
227	23010050	Reception	RECEPTION NVR CH-7,CH-13,CH-31 POSITION CHANGE	Padmanaban. G.	position change complitad		Raja.B - Computer Department	11/01/2023
Comp. Dt. : 03/01/2023 Status : Completed								
228	23010075	Ladies hostel Phase-II	HARD DISC NOT DETECTING	Vivek. A.	Change new hard disk . problem complited		Balachandar. A. - Computer Department	23/01/2023
Comp. Dt. : 06/01/2023 Status : Completed								
229	23010253	JR Quarters	ONE CAMERA NOT WORKING	Padmanaban. G.	camera side jack refixed probelm solved		Balachandar. A. - Computer Department	21/01/2023
Comp. Dt. : 21/01/2023 Status : Completed								
230	23010788	HOSPITAL CAMPUS	IN ALL FLOORS CAMERA CHANNEL 3 COLUR ISSUE	Vivek. A.	camera issue		Raja.B - Computer Department	15/03/2023
231	23010789	HOSPITAL CAMPUS	IN ALL FLOORS CAMERA CHANNEL 5-POSITION NEED TO BE CHANGE	Vivek. A.	camera position ok		Raja.B - Computer Department	24/01/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
232	23010790	HOSPITAL CAMPUS	CAMERA NMC NVR TIME NEED TO CHANGE	Vivek. A.	NMC NVR TIME CHNGED PROBELM SOLVED		Raja.B - Computer Department	24/01/2023
233	23010791	HOSPITAL CAMPUS	IN RECEPTION AREA-CAMERA NVR RENAME FOR ALL CAMERA'S	Vivek. A.	Recptrion all camera nvr name changed		Raja.B - Computer Department	24/01/2023
Comp. Dt. : 31/01/2023 Status : Completed								
234	23011083	JR Quarters	NEED TO CHECK ALL CAMERA POSITION	Vivek. A.	camera position changed		Balachandar. A. - Computer Department	01/02/2023
Comp. Dt. : 09/02/2023 Status : Completed								
235	23020319	Polytechnic college	CAMERA DIRECTION ADJUSTMENT WORK - 3 NOS	Vivek. A.	camera position changed probelm solved		Prakash. P. - Computer Department	10/02/2023
Comp. Dt. : 24/02/2023 Status : Completed								
236	23020952	Polytechnic college	NEED TO CHECK CCTV CAMERA NO 12 - POSITION CHANGE	Vivek. A.	camera position adjustment problem solved		Prakash. P. - Computer Department	06/03/2023
Comp. Dt. : 28/02/2023 Status : Completed								
237	23021079	Reception	RECEPTION NVR 4TH CHANNEL CAMERA NOT WORKING	Vivek. A.	instrument mother bord issue new instrument changed		Raja.B - Computer Department	01/03/2023
Comp. Dt. : 06/03/2023 Status : Completed								
238	23030223	Hospital	ALL FLOOR CC TV CAMERA V NOT RECORDED	Vivek. A.	camera refixed probelm solved		Murugavel.R - Computer Department	08/03/2023
Comp. Dt. : 08/03/2023 Status : Completed								
239	23030300	Polytechnic college	PROBLEM IN N V R HARDDISK	Vivek. A.	hard disk rebooting probelm solved		Prakash. P. - Computer Department	09/03/2023
Comp. Dt. : 25/03/2023 Status : Completed								
240	23031066	Nursing College	CC TV CAMERA NOT WORKING	Vivek. A.	poe side cat 5 jack refixed probelm solved		Prakash. P. - Computer Department	28/03/2023

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 28/03/2023								
Status : Completed								
241	23031147	Nursing College	CC TV CAMERA NOT WORKING	Vivek. A.	poe side cat 5 jack refixed probelm solved		Prakash. P. - Computer Department	28/03/2023
Comp. Dt. : 25/04/2023								
Status : Completed								
242	23040799	STAFF NURSE QUARTERS	CAMERA DOWN POSITION	Vivek. A.	camera position changed		Murugavel.R - Computer Department	26/04/2023
Comp. Dt. : 03/05/2023								
Status : Completed								
243	23050089	EDP IN UNDERGROUND	N S G CAMERA 2NOS NOT WORKING CHANNEL NO 19 & 20	Vivek. A.	power on problem solved		Shafiullah. R. - Computer Department	05/05/2023
244	23050090	EDP IN UNDERGROUND	CAMPUS CAMERA 1 NOT WORKING CHANNEL NO 10	Vivek. A.	camera wire damage wire refixed		Shafiullah. R. - Computer Department	08/05/2023
245	23050100	Boys hostel	CAMERA NOT CLEAR IN BOYS HOSTEL KITCHEN	Vivek. A.	camera lens cleaning		Balachandar. A. - Computer Department	15/05/2023
Comp. Dt. : 05/05/2023								
Status : Completed								
246	23050199	JR Quarters	PROBLEM IN CC TV CAMERA [1 NO]	Vivek. A.	cat 5 cable changed		Prakash. P. - Computer Department	31/05/2023
247	23050200	Ladies hostel Phase-I	PROBLEM IN CC TV CAMERA [2 NO]	Vivek. A.	cat 5 cable changed problem solved		Prakash. P. - Computer Department	31/05/2023
Comp. Dt. : 16/05/2023								
Status : Completed								
248	23050629	Boys hostel	CAMERA HARD DISK NOT CONNECTED	Vivek. A.	hard disk checking storage fine		Balachandar. A. - Computer Department	17/05/2023
Comp. Dt. : 31/05/2023								
Status : Completed								
249	23051227	Reception	N V R CHANNEL NO 17 C C CAMERA NOT WORKING	Vivek. A.	camera side jack refixed problem solved		Murugavel.R - Computer Department	03/06/2023
Comp. Dt. : 27/06/2023								
Status : Completed								
250	23061005	Polytechnic college	NEED TO CHECK - CHANNEL NO 2 , NOT WORKING	Vivek. A.	camera side cable changed		Balachandar. A. - Computer Department	01/07/2023

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 28/06/2023 Status : Completed								
251	23061049	EDP IN UNDERGROUND	NEED TO PROVIDE PARALLEL INTERCOM LINE FOR INTERCOM NO 1528	Vivek. A.	1528 parallel line fixed problem solved		Prakash. P. - Computer Department	28/06/2023
252	23061058	Nursing College	CC TV CAMERA AT III FLOOR NOT WORKING	Vivek. A.	cat 5 jack changed probelm solved		Shafiullah. R. - Computer Department	01/07/2023
Dept Name : COVID Ward - Tele Exchange Comp. Dt. : 12/05/2022 Status : Completed								
253	22050441	ENT WARD-408	INTERCOM 1430 NOT WORKING	Vivek. A.	instrument bazzar changed probelm solved		Agila. V. - ENT & Ophthal Ward	12/05/2022
Comp. Dt. : 04/06/2022 Status : Completed								
254	22060162	ENT WARD-407	INTERCOM NO 1430 NOT WORKING	Vivek. A.	line cord probelm new line cord changed		Jayalakshmi. J. - ENT & Ophthal Ward	04/06/2022
Dept Name : CSSD - Tele Exchange Comp. Dt. : 02/09/2022 Status : Completed								
255	22090111	CSSD	INTERCOM NO 1504 TELEPHONE PROBLEM	Vivek. A.	coil cord changed probelm solved		Vinnarasi. R - CSSD	05/09/2022
Comp. Dt. : 16/11/2022 Status : Completed								
256	22110682	CSSD	INTERCOM 1504 NOT WORKING	Vivek. A.	instrument damage new instrument fixed		Pazhanivel.S. - CSSD	17/11/2022
Comp. Dt. : 03/01/2023 Status : Completed								
257	23010114	CSSD	INTERCOM 1502 NOT WORKING	Vivek. A.	intercom keypad adjesment probelm solved		Vinnarasi. R - CSSD	04/01/2023
Dept Name : Derm,Pulmo,Psych Ward - Tele Exchange Comp. Dt. : 04/05/2022 Status : Completed								
258	22050070	TB AND CHEST WARD-405	INTERCOM NO 1411 - CABLE PROBLEM	Vivek. A.	coil cord wire probelm new coil cord wire changed		Sarathkumar. R. - Derm,Pulmo,Psych Ward	05/05/2022
Comp. Dt. : 04/07/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
259	22070101	Male Ortho - Ward 404	INTERCOM NO 1409 NOT WORKING	Vivek. A.	hanset speaker disconnected speaker refixed		Manjula. P. - Male Ortho Ward	06/07/2022
Comp. Dt. : 23/01/2023 Status : Completed								
260	23010838	Male Psychiatry - Ward 405	INTERCOM NO 1411 NOT WORKING	Vivek. A.	puls/ton button changed probelm solved		Kavitha. S. - Derm,Pulmo,Psych Ward	24/01/2023
Comp. Dt. : 09/05/2023 Status : Completed								
261	23050378	Male Psychiatry - Ward 405	INTERCOM NO 1411 NOT WORKING	Vivek. A.	line cord changed problem solved		Sarathkumar. R. - Derm,Pulmo,Psych Ward	10/05/2023
Dept Name : Dermatology & Vener. - Tele Exchange Comp. Dt. : 01/09/2022 Status : Completed								
262	22090053	DERMATOLOGY OPD	INTERCOM NO 1073 NOT WORKING	Vivek. A.	phone hanset changed probelm solved		Jayachandran. M. - Dermatology & Vener.	02/09/2022
Comp. Dt. : 21/06/2023 Status : Completed								
263	23060756	DERMATOLOGY OPD	INTERCOM NO 1043 NOT WORKING - ROOM NO 73 - NEED URGENT SERVICE	Vivek. A.	line cord changed problem solved		Jayachandran. M. - Dermatology & Vener.	21/06/2023
Dept Name : Dialysis - Tele Exchange Comp. Dt. : 11/06/2022 Status : Completed								
264	22060413	DIALYSIS IN 2ND FLOOR	INTERCOM NO 1280 NOT WORKING - INCOMING PROBLEM	Vivek. A.	puls/ton button adjustment proelm solved		Arthy. T. - Dialysis	14/06/2022
Comp. Dt. : 01/08/2022 Status : Completed								
265	22080043	DIALYSIS NEW UNIT IN 1ST FLOOR	INTERCOM NO 1160 NOT WORKING	Vivek. A.	line cord changed probelm solved		Vikneswari. K. - Dialysis	01/08/2022
Comp. Dt. : 10/10/2022 Status : Completed								
266	22100216	DIALYSIS NEW UNIT IN 1ST FLOOR	INTERCOM NO 1161 NOT WORKING & DIEL BUTTON PROBLEM	Vivek. A.	instrurment damage new instrurment fixed		Sumathira. C - Dialysis	10/10/2022
Comp. Dt. : 28/10/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
267	22100903	DIALYSIS NEW UNIT IN 1ST FLOOR	INTERCOM 1160 NOT WORKING	Vivek. A.	puls/ton button changed probelm solved		Sarathambal. R. - Dialysis	29/10/2022
Comp. Dt. : 30/11/2022 Status : Completed								
268	22111281	Female Ortho Ward	INTERCOM NO 1417 NOT WORKING - AUDIO PROBLEM	Vivek. A.	coil cord wire changed probelm solved		Jeeva. S. - Dialysis	01/12/2022
Comp. Dt. : 10/06/2023 Status : Completed								
269	23060357	DIALYSIS NEW UNIT IN 1ST FLOOR	INTERCOM NO 1161 NOT WORKING	Vivek. A.	line cord and coil cord changed		Piravinkumar. A. - Dialysis	10/06/2023
Comp. Dt. : 13/06/2023 Status : Completed								
270	23060465	DIALYSIS NEW UNIT IN 1ST FLOOR	INTERCOM NO 1161 NOT WORKING [CABLE PROBLEM]	Vivek. A.	new instrument changed problem		Sumathira. C - Dialysis	14/06/2023
Dept Name : Director Office - Tele Exchange Comp. Dt. : 15/12/2022 Status : Completed								
271	22120698	A.P Quateres	INTERCOM NO 2680 NOT WORKING	Vivek. A.	port issue port number changed probelm solved		Mani. A. - Director Office	17/12/2022
Dept Name : Dressing - Tele Exchange Comp. Dt. : 07/09/2022 Status : Completed								
272	22090286	Male Surgery - Ward 201	INTERCOM NO 1216 NOT WORKING	Vivek. A.	line cord jack cahnged probelm solved		Dhachinamoorthy.R. - Dressing	07/09/2022
Comp. Dt. : 16/04/2023 Status : Completed								
273	23040476	Male Surgery - Ward 201	INTERCOM NO 1216 NOT WORKING	Vivek. A.	line cord jack changed problem solved		Dhachinamoorthy.R. - Dressing	17/04/2023
Dept Name : Electrical Maintenance - Tele Exchange Comp. Dt. : 15/06/2022 Status : Completed								
274	22060575	LIFT 5	INTERCOM NO 1560 NOT WORKING	Vivek. A.	two pair line cable disconnected cable rejoin probelm solved		Senthil Murugan. A. - Electrical Maintenance	20/06/2022
Comp. Dt. : 17/06/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
275	22060644	LIFT 2	INTERCOM NO 1428 NOT WORKING	Vivek. A.	hanset speaker disconnected speaker refixed		Senthil Murugan. A. - Electrical Maintenance	18/06/2022
276	22060663	LIFT 5	INTERCOM NO 1560 NOT WORKING	Vivek. A.	two pair line cable disconnected cable rejoin probelm solved		Azhagappan. J. - Electrical Maintenance	20/06/2022
Comp. Dt. : 28/10/2022 Status : Completed								
277	22100876	LIFT 2	PHONE NOT WORKING	Vivek. A.	insrument motherbord issue instrument changed probelm solved		Angappan. A. - Electrical Maintenance	31/10/2022
Comp. Dt. : 10/01/2023 Status : Completed								
278	23010408	LIFT 3 -PATIENT LIFT	INTERCOM 1234 NOT WORKING	Vivek. A.	puls/ton button changed probelm solved		Vaithianathan.M - Electrical Maintenance	11/01/2023
Comp. Dt. : 07/02/2023 Status : Completed								
279	23020260	Electrical Maintenance	INTERCOM NO 3065 WIRE LOOSE CONNECTION	Vivek. A.	line cord jack refixed probelm solved		Manimaran. M. - Electrical Maintenance	08/02/2023
Comp. Dt. : 30/03/2023 Status : Completed								
280	23031277	LIFT 5	INTERCOM NO 1560 NOT WORKING	Vivek. A.	hanset speaker wire refixed problem solved		Angappan. A. - Electrical Maintenance	03/04/2023
Comp. Dt. : 26/04/2023 Status : Completed								
281	23040871	LIFT 5	INTERCOM NO 1560 NOT WORKING	Vivek. A.	two pair cable rejoin		Senthil Murugan. A. - Electrical Maintenance	27/04/2023
Comp. Dt. : 23/05/2023 Status : Completed								
282	23050914	LIFT 2	INTERCOM NO 1428 NOT WORKING	Vivek. A.	new instrument changed problem solved		Kumaran.R. - Electrical Maintenance	23/05/2023
Comp. Dt. : 08/06/2023 Status : Completed								
283	23060298	LIFT 4	NEED TO PROVIDE MODEM FOR LIFT NO 4	Vivek. A.	new instrument changed		Duraikannu. D. - Electrical Maintenance	12/06/2023
Dept Name : EMERGENCY MEDICINE - Tele Exchange Comp. Dt. : 18/05/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
284	22050655	Casualty	INTERCOM NO 1014 NOT WORKING	Vivek. A.	coil cord wire probelm new coil cord wire changed		Sasirekha. K. - EMERGENCY MEDICINE	18/05/2022
Comp. Dt. : 07/07/2022 Status : Completed								
285	22070243	Casualty	INTERCOM NO 1015 NOT WORKING	Vivek. A.	coil cord changed		Sasirekha. K. - EMERGENCY MEDICINE	07/07/2022
Comp. Dt. : 26/07/2022 Status : Completed								
286	22070962	Casualty	INTERCOM NO 1014 & 1015 NOT WORKING	Vivek. A.	1041 instrument damage new instrument fixed 1015 coli cord changed probelm solved		Kanimozhi. E. - EMERGENCY MEDICINE	26/07/2022
Comp. Dt. : 04/08/2022 Status : Completed								
287	22080169	Female Casulaty	INTERCOM 1016 NOT WORKING	Vivek. A.	line cord changed probelm solved		Sasirekha. K. - EMERGENCY MEDICINE	05/08/2022
Comp. Dt. : 05/08/2022 Status : Completed								
288	22080187	Female Casulaty	INTERCOM NO 1016 NOT WORKING	Vivek. A.	line cord jack changed		Seethalakshmi. R. - EMERGENCY MEDICINE	05/08/2022
Comp. Dt. : 10/08/2022 Status : Completed								
289	22080359	Casualty	INTERCOM NO 1015 NOT WORKING	Vivek. A.	coil cord changed probelm solved		Kanimozhi. E. - EMERGENCY MEDICINE	11/08/2022
Comp. Dt. : 25/08/2022 Status : Completed								
290	22080824	Female Casulaty	INTERCOM NO 1016 NOT WORKING [AUDIO PROBLEM]	Vivek. A.	coil cord changed probelm solved		Rajipriya. K. - EMERGENCY MEDICINE	26/08/2022
Comp. Dt. : 13/09/2022 Status : Completed								
291	22090504	Casualty	INTERCOM NO 1014 NOT WORKING - AUDIO & CABLE PROBLEM	Vivek. A.	coil cord changed probelm solved		Kanimozhi. E. - EMERGENCY MEDICINE	14/09/2022
Comp. Dt. : 14/09/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
292	22090532	Casualty	INTERCOM NO 1015 NOT WORKING AUDIO PROBLEM	Vivek. A.	coil cord changed probelm solved		Rajipriya. K. - EMERGENCY MEDICINE	14/09/2022
Comp. Dt. : 31/10/2022 Status : Completed								
293	22101007	Casualty	INTERCOM NO-1015,NOT WORKING PROPERLY	Vivek. A.	coil cord changed probelm solved		Kanimozhi. E. - EMERGENCY MEDICINE	31/10/2022
Comp. Dt. : 17/11/2022 Status : Completed								
294	22110720	FEVER CLINIC	INTERCOM 1671 NOT WORKING	Vivek. A.	instrument keepad changed		Yuvaraj. G - EMERGENCY MEDICINE	21/11/2022
Comp. Dt. : 18/11/2022 Status : Completed								
295	22110758	FEVER CLINIC	INTERCOM NO 1070 NOT WORKING	Vivek. A.	instrument changed probelm solved		Kanimozhi. E. - EMERGENCY MEDICINE	22/11/2022
Comp. Dt. : 12/12/2022 Status : Completed								
296	22120498	Casualty	INTERCOM NO:1015 NOT WORKING	Vivek. A.	coil cord changed probelm solved		Dhanalakshmi. M. - EMERGENCY MEDICINE	12/12/2022
Comp. Dt. : 26/12/2022 Status : Completed								
297	22121175	Casualty	INTERCOM NO. 1015 NOT WORKING	Vivek. A.	hanset changed proobelm solved		Devi. S - EMERGENCY MEDICINE	29/12/2022
298	22121182	Casualty	INTERCOM NO 1012 NOT WORKING	Vivek. A.	coil cord changed		Kanimozhi. E. - EMERGENCY MEDICINE	28/12/2022
Comp. Dt. : 08/03/2023 Status : Completed								
299	23030338	Casualty	INTERCOM NO 1014 NOT WORKING	Vivek. A.	line cord changed probelm solved		Balamurugan. M. - EMERGENCY MEDICINE	09/03/2023
Comp. Dt. : 30/03/2023 Status : Completed								
300	23031310	Female Casulaty	INTERCOM NO 1016 NOT WORKING	Vivek. A.	coil cord changed probelm solved		Dhanalakshmi. M. - EMERGENCY MEDICINE	30/03/2023
Comp. Dt. : 13/04/2023								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
301	23040416	Casualty	INTERCOM NO 1015 NOT WORKING	Vivek. A.	coil cord changed problem solved		Kanimozhi. E. - EMERGENCY MEDICINE	15/04/2023
Comp. Dt. : 15/04/2023								
Status : Completed								
302	23040439	Casualty	INTERCOM NO 1014 NOT WORKING	Vivek. A.	line cord changed problem solved		Kanimozhi. E. - EMERGENCY MEDICINE	15/04/2023
Comp. Dt. : 20/04/2023								
Status : Completed								
303	23040624	Casualty	INTERCOM NO 1015 NOT WORKING [AUDIO PROBLEM]	Vivek. A.	phone handset changed		Kanimozhi. E. - EMERGENCY MEDICINE	20/04/2023
Comp. Dt. : 12/05/2023								
Status : Completed								
304	23050475	Casualty	INTERCOM NO 1014 NOT WORKING	Vivek. A.	coil cord prblem solved		Kanimozhi. E. - EMERGENCY MEDICINE	12/05/2023
Comp. Dt. : 22/05/2023								
Status : Completed								
305	23050868	Casualty	INTERCOM NO 1015 NOT WORKING	Vivek. A.	phone handset changed		Kanimozhi. E. - EMERGENCY MEDICINE	22/05/2023
Comp. Dt. : 24/05/2023								
Status : Completed								
306	23050955	Casualty	INTERCOM NO 1015 NOT WORKING [REPEAT]	Vivek. A.	new instrument changed		Sasirekha. K. - EMERGENCY MEDICINE	24/05/2023
Comp. Dt. : 19/06/2023								
Status : Completed								
307	23060655	Casualty	INTERCOM NO 1014 NOT WORKING	Vivek. A.	coil cord changed probelm solved		Sasirekha. K. - EMERGENCY MEDICINE	19/06/2023
Comp. Dt. : 21/06/2023								
Status : Completed								
308	23060770	Casualty	NEED TO CHANGE INTERCOM ANOTHER PLACE OR ROOM	Vivek. A.	intercom line changed		Sasirekha. K. - EMERGENCY MEDICINE	22/07/2023
Dept Name : ENT & Ophthal Ward - Tele Exchange								
Comp. Dt. : 19/07/2022								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
309	22070723	ENT WARD-407	INTERCOM NO 1429 [AUDIO PROBLEM] - NOT WORKING	Vivek. A.	ringer button changed probelm solved		Madhiveni. M. - ENT & Ophthal Ward	20/07/2022
Comp. Dt. : 12/08/2022								
Status : Completed								
310	22080442	ENT WARD-407	INTERCOM NO 1430 NOT WORKING	Vivek. A.	line cord janck changed probelm solved		Jaculine Mary. A. - ENT & Ophthal Ward	12/08/2022
Comp. Dt. : 23/08/2022								
Status : Completed								
311	22080761	ENT WARD-407	INTERCOM NO 1430 NOT WORKING	Vivek. A.	instrument keepad cahanged probelm solved		Agila. V. - ENT & Ophthal Ward	23/08/2022
Comp. Dt. : 06/10/2022								
Status : Completed								
312	22100100	Female Medical - Ward 306	INTERCOM NO 1316 NOT WORKING	Vivek. A.	coil cord changed probelm solved		Bhuvaneswari. M. - ENT & Ophthal Ward	07/10/2022
Comp. Dt. : 10/10/2022								
Status : Completed								
313	22100252	Female Medical - Ward 306	INTERCOM NO 1313 NOT WORKING	Vivek. A.	line cord changed probelm solved		Bhuvaneswari. M. - ENT & Ophthal Ward	10/10/2022
Comp. Dt. : 17/10/2022								
Status : Completed								
314	22100514	ENT WARD-408	INTERCOM NO 1429 NOT WORKING - AUDIO & INCOMING PROBLEM	Vivek. A.	instrument puls/ton button changed probelm solved		Jayalakshmi. J. - ENT & Ophthal Ward	18/10/2022
Comp. Dt. : 25/11/2022								
Status : Completed								
315	22111100	Female Medical - Ward 305	INTERCOM 1316 NOT WORKING	Vivek. A.	coil cord changed probelm solved		Bhuvaneswari. M. - ENT & Ophthal Ward	26/11/2022
Comp. Dt. : 20/12/2022								
Status : Completed								
316	22120905	Female Medical - Ward 305	INTERCOM NO 1316 NOT WORKING	Vivek. A.	coil cord changed probelm solved		Bhuvaneswari. M. - ENT & Ophthal Ward	20/12/2022
Comp. Dt. : 21/12/2022								
Status : Completed								
317	22120991	ENT WARD-407	INTERCOM NO. 1430 NOT WORKING	Vivek. A.	line cord jack refixed probelm solved		Jayalakshmi. J. - ENT & Ophthal Ward	22/12/2022
Comp. Dt. : 05/01/2023								
Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
318	23010217	ENT WARD-407	INTERCOM 1430 NOT WORKING	Vivek. A.	puls/ton button adjesment		Samundeeswari. E. - ENT & Ophthal Ward	05/01/2023
	Comp. Dt. : 07/01/2023							
	Status : Completed							
319	23010307	Female Medical - Ward 306	INTERCOM 1316 NOT WORKING	Vivek. A.	keepad button changed probelm solved		Bhuvaneswari. M. - ENT & Ophthal Ward	07/01/2023
	Comp. Dt. : 11/01/2023							
	Status : Completed							
320	23010484	ENT WARD-407	INTERCOM 1430 KEYPAD NOT WORKING	Vivek. A.	keypad button changed probelm solved		Jayalakshmi. J. - ENT & Ophthal Ward	11/01/2023
	Comp. Dt. : 15/02/2023							
	Status : Completed							
321	23020572	Female Medical - Ward 306	INTERCOM NO 1313 NOT WORKING	Vivek. A.	pus/ton button changed		Bhuvaneswari. M. - ENT & Ophthal Ward	17/02/2023
	Comp. Dt. : 17/02/2023							
	Status : Completed							
322	23020670	ENT WARD-407	INTERCOM NO 1430 NOT WORKING	Vivek. A.	hanset refixed probelm solved		Jayalakshmi. J. - ENT & Ophthal Ward	17/02/2023
	Comp. Dt. : 21/02/2023							
	Status : Completed							
323	23020817	ENT WARD-407	INTERCOM NO 1430 NOT WORKING	Vivek. A.	hanset speaker refixed		Jayalakshmi. J. - ENT & Ophthal Ward	21/02/2023
	Comp. Dt. : 23/02/2023							
	Status : Completed							
324	23020888	ENT WARD-407	INTERCOM NO 1430 NOT WORKING	Vivek. A.	instrument hanset speaker refixed probelm soilved		Jayalakshmi. J. - ENT & Ophthal Ward	23/02/2023
	Comp. Dt. : 08/03/2023							
	Status : Completed							
325	23030337	ENT WARD-407	INTERCOM NO 1430 NOT WORKING	Vivek. A.	puls/ton button adjusment		Jayalakshmi. J. - ENT & Ophthal Ward	09/03/2023
	Comp. Dt. : 24/03/2023							
	Status : Completed							
326	23030996	ENT WARD-407	INTERCOM NO 1430 - DIAL BUTTON PROBLEM	Vivek. A.	keepad button adjusment		Jayalakshmi. J. - ENT & Ophthal Ward	24/03/2023
	Comp. Dt. : 27/03/2023							
	Status : Completed							
327	23031093	Female Medical - Ward 305	INTERCOM NO 1316 NOT WORKING	Vivek. A.	coil cor changed probelm solved		Bhuvaneswari. M. - ENT & Ophthal Ward	27/03/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 20/04/2023 Status : Completed								
328	23040681	ENT WARD-407	INTERCOM NO 1430 DIAL BUTTON NOT WORKING	Vivek. A.	puls/ton button adjesment		Agila. V. - ENT & Ophthal Ward	22/04/2023
Comp. Dt. : 28/04/2023 Status : Completed								
329	23040974	Female Medical - Ward 305	INTERCOM NO 1516 NOT WORKING	Vivek. A.	coil cord changed intercom number 1316		Bhuvaneswari. M. - ENT & Ophthal Ward	29/04/2023
Comp. Dt. : 02/06/2023 Status : Completed								
330	23060067	ENT WARD-407	INTERCOM NO 1430 NOT WORKING	Vivek. A.	new instrument changed problem solved		Ranjitha. A. - Female Medical Ward	02/06/2023
Comp. Dt. : 05/06/2023 Status : Completed								
331	23060117	Female Medical - Ward 305	INTERCOM NO 1316 NOT WORKING	Vivek. A.	new instrument changed probelm solved		Bhuvaneswari. M. - ENT & Ophthal Ward	05/06/2023
Dept Name : Female Medical Ward - Tele Exchange Comp. Dt. : 15/07/2022 Status : Completed								
332	22070586	Female Medical - Ward 306	INTERCOM NO 1313 NOT WORKING	Vivek. A.	puls/ton button changed		Vaitheeswari. A. - Female Medical Ward	16/07/2022
Comp. Dt. : 21/07/2022 Status : Completed								
333	22070781	Female Medical - Ward 306	INTERCOM NO 1313 - RING TONE PROBLEM	Vivek. A.	instrument damage new instrumen fixed probelm solved		Vaitheeswari. A. - Female Medical Ward	22/07/2022
Comp. Dt. : 31/12/2022 Status : Completed								
334	22121396	Female Medical - Ward 305	INTERCOM 1316-KEYPAD NOT WORKING	Vivek. A.	puls/ton button adjesment		Gnanasoundari. G - Female Medical Ward	31/12/2022
Comp. Dt. : 09/02/2023 Status : Completed								
335	23020361	Female Medical - Ward 305	INTERCOM NO. 1316 NOT WORKING	Vivek. A.	coil cord changed probelm solved		Maniarasy. K. - Female Medical Ward	10/02/2023
Comp. Dt. : 11/04/2023 Status : Completed								
336	23040323	Female Medical - Ward 306	INTERCOM NO 1312 NOT WORKING	Vivek. A.	line card jack changed problem solved		Anto Valani. A. - Female Medical Ward	12/04/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 29/04/2023 Status : Completed								
337	23041008	Male Medical - Ward 302	INTERCOM NO 1318 NOT WORKING	Vivek. A.	coil cord changed problem solved		Vaitheeswari. A. - Female Medical Ward	29/04/2023
Dept Name : Female Ortho Ward - Tele Exchange Comp. Dt. : 09/06/2022 Status : Completed								
338	22060340	Male Ortho - Ward 404	INTERCOM NO 1409 NOT WORKING	Vivek. A.	coil cord probelm new coil cord changed		Gayathri. S. - Male Ortho Ward	10/06/2022
Comp. Dt. : 06/09/2022 Status : Completed								
339	22090209	Female Ortho - Ward 402	TELEPHONE NOT WORKING INTERCOM NO (1414)	Vivek. A.	line cord changed probelm solved		Girija. G. - Female Ortho Ward	07/09/2022
Comp. Dt. : 10/02/2023 Status : Completed								
340	23020392	Female Ortho - Ward 401	INTERCOM NO.1417 NOT WORKING	Vivek. A.	coil cord changed probelm solved		Dhansulakshmi. K. - Female Ortho Ward	10/02/2023
Comp. Dt. : 25/03/2023 Status : Completed								
341	23031046	Female Ortho - Ward 402	INTERCOM NO 1417 NOT WORKING	Vivek. A.	hanset speaker wire refixed		Anbuselvi. P. - Female Ortho Ward	25/03/2023
Dept Name : Female Surgery - Tele Exchange Comp. Dt. : 06/07/2022 Status : Completed								
342	22070216	Male Surgery - Ward 203	INTERCOM NO 1218 NOT WORKING	Vivek. A.	coil cor changed probelm solved		Ezhilarasi. E. - Male Surgery	07/07/2022
Comp. Dt. : 16/09/2022 Status : Completed								
343	22090650	Male Surgery - Ward 203	INTERCOM NO 1218 NOT WORKING	Vivek. A.	instrument keepad changed probelm solved		Vinodhini. K. - Female Surgery	17/09/2022
Comp. Dt. : 06/12/2022 Status : Completed								
344	22120275	Female Surgery - Ward 205	INTERCOM 1215 NOT WORKING	Vivek. A.	line cord jack changed		Vaidegi. S. - Female Surgery	06/12/2022
Comp. Dt. : 07/12/2022 Status : Completed								
345	22120303	Female Surgery - Ward 205	INTERCOM 1217 NOT WORKING	Vivek. A.	line cord wire changed probelm solved		Vaidegi. S. - Female Surgery	07/12/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 06/01/2023 Status : Completed								
346	23010276	Female Surgery - Ward 206	INTERCOM NO-1214,NOT WORKING PROPERLY	Vivek. A.	line cord jack refixed probelm solved		Suseela. R. - ICU	07/01/2023
Comp. Dt. : 19/01/2023 Status : Completed								
347	23010682	Male Surgery - Ward 203	INTERCOM NO 1213 NOT WORKING	Vivek. A.	puls/ton button adjesment		Saranya. V. - Female Surgery	20/01/2023
Comp. Dt. : 20/03/2023 Status : Completed								
348	23030784	Male Surgery - Ward 203	INTERCOM NO 1213 NOT WORKING	Vivek. A.	puls/ton button adjusment probelm solved		Priyanka. V. - Female Surgery	20/03/2023
Comp. Dt. : 23/03/2023 Status : Completed								
349	23030975	DENTAL OPD -2ND FLOOR	INTERCOM NO 1230 NOT WORKING	Vivek. A.	new instrument changed probelm solved		Jayasree. S. - TB & Chest / Psychiatry	24/03/2023
Comp. Dt. : 12/04/2023 Status : Completed								
350	23040349	Male Surgery - Ward 203	INTERCOM NO 1213 NOT WORKING	Vivek. A.	line cord jack changed		Saranya. V. - Female Surgery	12/04/2023
Dept Name : FORENSIC MEDICINE - Tele Exchange Comp. Dt. : 25/04/2023 Status : Completed								
351	23040821	FORENSIC MEDICINE (3RD FLOOR) IN COLLEGE	INTERCOM NO 2098 NOT WORKING	Vivek. A.	coil cord changed problem solved		Mathavi. B. - FORENSIC MEDICINE	10/05/2023
Dept Name : Gas Power Plant - Tele Exchange Comp. Dt. : 08/06/2022 Status : Completed								
352	22060300	Printing Press	INTERCOM NO 3077 NOT WORKING	Vivek. A.	two pair cable disconnected cable rejoin probelm solved		Mahi Mohan Ram.S. - Gas Power Plant	14/06/2022
Comp. Dt. : 17/10/2022 Status : Completed								
353	22100521	Gas Power Plant	INTERCOM NO 3077 NOT WORKING	Vivek. A.	cable issue		Mahi Mohan Ram.S. - Gas Power Plant	27/10/2022
Comp. Dt. : 08/03/2023								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
354	23030332	Gas Power Plant	INTERCOM NO 3077, 1521, 1056 NOT WORKING	Vivek. A.	20 pair cable rejoin probelm solved		Mahi Mohan Ram.S. - Gas Power Plant	10/03/2023
Comp. Dt. : 12/04/2023								
Status : Completed								
355	23040361	Printing Press	NEED TO CHECK CAMERA - PROBLEM	Vivek. A.	camera play back check problem solved		Mahi Mohan Ram.S. - Gas Power Plant	13/04/2023
Dept Name : GENERAL MEDICINE - Tele Exchange								
Comp. Dt. : 02/12/2022								
Status : Completed								
356	22120062	ECG ROOM NEAR MEDICINE OPD	INTERCOM NO 1094 NOT WORKING	Vivek. A.	instrument motherbord issue new instrument fixed		Rohini. B. - General Medicine	02/12/2022
Dept Name : Guest House - Indian Bank - Tele Exchange								
Comp. Dt. : 06/08/2022								
Status : Completed								
357	22080242	Guest House - Indian Bank	C C TV CAMERA NOT WORKING	Vivek. A.	new cable laying 3 camera working probelm solved		John. H. - Guest House - Indian Bank	07/11/2022
Dept Name : Gynac Ward - Tele Exchange								
Comp. Dt. : 25/06/2022								
Status : Completed								
358	22060930	Male Surgery - Ward 203	INTERCOM NO 1218 NOT WORKING	Vivek. A.	line cord jack changed		Aravindhan. A. - Male Surgery	25/06/2022
Comp. Dt. : 29/06/2022								
Status : Completed								
359	22061038	Obstetrics - Ward 208	INTERCOM NO 1224 NOT WORKING	Vivek. A.	line cord changed		Suriya. S. - Hospital Infection Control	29/06/2022
Comp. Dt. : 16/07/2022								
Status : Completed								
360	22070621	Obstetrics - Ward 207	INTERCOM NO 1223 NOT WORKING	Vivek. A.	line cord changed		Ashwini. V. - Gynac Ward	16/07/2022
Comp. Dt. : 29/08/2022								
Status : Completed								
361	22080957	Obstetrics - Ward 208	INTERCOM NO 1224 NOT WORKING	Vivek. A.	line cord jack changed probelm solved		Ashwini. V. - Gynac Ward	29/08/2022
Comp. Dt. : 21/09/2022								
Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
362	22090814	Obstetrics - Ward 207	INTERCOM NO 1224 NOT WORKING	Vivek. A.	line cord changed probelm solved		Sangeetha. J. - Gynac Ward	21/09/2022
	Comp. Dt. : 26/06/2023 Status : Completed							
363	23060984	Obstetrics - Ward 208	INTERCOM NO 1223 SOUND PROBLEM	Vivek. A.	coil cord changed problem solved		Sangeetha. J. - Gynac Ward	26/06/2023
	Dept Name : Hospital Infection Control - Tele Exchange Comp. Dt. : 12/10/2022 Status : Completed							
364	22100348	Male Ortho - Ward 403	NEED TO PROVIDE A NEW INTERCOM CONNECTION	Vivek. A.	new intercom line fixed number-1433		Mohana. M. - Hospital Infection Control	03/11/2022
	Dept Name : ICCU - Tele Exchange Comp. Dt. : 06/07/2022 Status : Completed							
365	22070218	ICU	INTERCOM NO 1130 NOT WORKING [SECURITY]	Vivek. A.	wall mounted phone damage new phone fixed		Elakiya. P. - ICCU	07/07/2022
	Comp. Dt. : 01/08/2022 Status : Completed							
366	22080005	ICCU	INTERCOM NO 1110 NOT WORKING	Vivek. A.	two pair cable changed probelm solved		Suriyakala. A. - ICCU	01/08/2022
	Comp. Dt. : 09/09/2022 Status : Completed							
367	22090354	ICCU	INTERCOM NO 1110 NOT WORKING	Vivek. A.	instrument damage new instrument fixed probelm solved		Ammu. R. - ICCU	09/09/2022
	Comp. Dt. : 29/03/2023 Status : Completed							
368	23031239	ICCU	INTERCOM NO 1141 NOT WORKING [PROBLEM IN OUTGOING]	Vivek. A.	new instrument changed		Saradha. G. - ICCU	29/03/2023
	Comp. Dt. : 15/04/2023 Status : Completed							
369	23040456	ICCU	INTERCOM NO 1130 NOT WORKING	Vivek. A.	hanset speaker refixed		Ammu. R. - ICCU	17/04/2023
	Comp. Dt. : 24/04/2023 Status : Completed							
370	23040724	ICCU	INTERCOM NO 1141 NOT WORKING	Vivek. A.	instrument keepad changed problem solved		Suriyakala. A. - ICCU	24/04/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 08/05/2023 Status : Completed								
371	23050308	ICCU	INTERCOM NO 1130 NOT WORKING	Vivek. A.	instrument change problem solved		Ammu. R. - ICCU	08/05/2023
Dept Name : ICU - Tele Exchange Comp. Dt. : 08/07/2022 Status : Completed								
372	22070334	RICU	INTERCOM NO 1114 NOT WORKING	Vivek. A.	coil cord changed		Vimala. S. P. - ICU	08/07/2022
Comp. Dt. : 27/01/2023 Status : Completed								
373	23010962	ICU	INTERCOM NO 1141 NOT WORKING	Vivek. A.	coil cord changed probelm solved		Latha. K. - ICU	28/01/2023
Comp. Dt. : 17/02/2023 Status : Completed								
374	23020664	ICU	INTERCOM NO 1141 NOT WORKING	Vivek. A.	line cord changed		Latha. K. - ICU	17/02/2023
Comp. Dt. : 22/04/2023 Status : Completed								
375	23040697	POW & SICU	INTERCOM NO 1320 NOT WORKING	Vivek. A.	line cord changed problem solved		Gogul. M. - ICU	22/04/2023
Comp. Dt. : 17/05/2023 Status : Completed								
376	23050678	ICU	INTERCOM NO 1130 NOT WORKING	Vivek. A.	new instrument changed problem solved		Latha. K. - ICU	17/05/2023
377	23050722	ICU	INTERCOM NO 1115 NOT WORKING	Vivek. A.	line cord changed		Jayabharathi. R. - ICU	18/05/2023
Comp. Dt. : 26/06/2023 Status : Completed								
378	23060936	ICU	INTERCOM NO 1110 NOT WORKING - ICU -11	Vivek. A.	line cord jack changed problem solved		Latha. K. - ICU	26/06/2023
Dept Name : Labour Ward - Tele Exchange Comp. Dt. : 13/05/2022 Status : Completed								
379	22050450	labour room -pow	INTERCOM NO-1126 NOT WORKING	Vivek. A.	instrument damage new instrument refixed		Usharani. A. - Labour Ward	14/05/2022
Comp. Dt. : 22/11/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
380	22110900	Labour Room	INTERCOM NO 1207 NOT WORKING	Vivek. A.	coil cord changed probelm solved		Sathiyavathi. S. - Labour Ward	22/11/2022
Comp. Dt. : 07/01/2023 Status : Completed								
381	23010304	Labour Room	INTERCOM 1207 NOT WORKING	Vivek. A.	coil cord changed probelm solved		Sathiyavathi. S. - Labour Ward	07/01/2023
Comp. Dt. : 25/01/2023 Status : Completed								
382	23010922	Labour Room	INTERCOM NO 1207 NOT WORKING	Vivek. A.	coil cord changed probelm solved		Kodhai. T. - Labour Ward	25/01/2023
Comp. Dt. : 13/02/2023 Status : Completed								
383	23020449	Labour Room	INTERCOM NO. 1207 NOT WORKING	Vivek. A.	coil cord changed probelm solved		Sathiyavathi. S. - Labour Ward	14/02/2023
Comp. Dt. : 01/03/2023 Status : Completed								
384	23030027	Labour Room	INTERCOM NO 1207 NOT WORKING	Vivek. A.	instrument mother bord issue new instrument changed		Usharani. A. - Labour Ward	01/03/2023
Comp. Dt. : 30/03/2023 Status : Completed								
385	23031313	Labour Room	INTERCOM NO 1207 NOT WORKING	Vivek. A.	coil cord changed problem solved		Kanimozhi. S. - Labour Ward	30/03/2023
Comp. Dt. : 08/05/2023 Status : Completed								
386	23050294	Labour Room	INTERCOM NO 1207 NOT WORKING	Vivek. A.	coil cord changed problem solved		Kodhai. T. - Labour Ward	08/05/2023
Dept Name : Library - Tele Exchange Comp. Dt. : 25/04/2023 Status : Completed								
387	23040827	medical college library 2nd floor	INTERCOM NO 2004 NOT WORKING [IN COMING]	Vivek. A.	port number changed problem solved		Elangovan.N. - Library	26/04/2023
Dept Name : Male Medical Ward - Tele Exchange Comp. Dt. : 02/06/2022 Status : Completed								
388	22060057	Male Medical - Ward 301	INTERCOM NO 1314 NOT WORKING	Vivek. A.	coil cord changed		Kanmani. R. - Male Medical Ward	02/06/2022
Comp. Dt. : 13/06/2022								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
389	22060466	Male Medical - Ward 301	INTERCOM NO 1314 NOT WORKING	Vivek. A.	instrument damage new instrument fixed		Ramya. D. - Male Medical Ward	18/06/2022
Comp. Dt. : 15/06/2022								
Status : Completed								
390	22060585	Male Medical - Ward 301	INTERCOM NO 1314 NOT WORKING	Vivek. A.	coil cord changed		Soniya Gandhi. A. - Male Medical Ward	16/06/2022
Comp. Dt. : 02/08/2022								
Status : Completed								
391	22080089	Male Medical - Ward 301	INTERCOM NO 1314 NOT WORKING [AUDIO RING TONE PROBLEM]	Vivek. A.	puls/ton button changed		Soniya Gandhi. A. - Male Medical Ward	03/08/2022
Comp. Dt. : 18/08/2022								
Status : Completed								
392	22080560	Male Medical - Ward 301	INTERCOM NO. 1314 NOT WORKING	Vivek. A.	instrument keypad +line cord changed probelm solved		Soniya Gandhi. A. - Male Medical Ward	18/08/2022
Comp. Dt. : 13/12/2022								
Status : Completed								
393	22120579	Male Medical - Ward 304	INTERCOM NO 1317 NOT WORKING	Vivek. A.	line cord jack refixed probelm solved		Soniya Gandhi. A. - Male Medical Ward	13/12/2022
Comp. Dt. : 30/03/2023								
Status : Completed								
394	23031323	Male Medical - Ward 302	INTERCOM NO 1318 NOT WORKING	Vivek. A.	line cord changed problem solved		Karthikeyan. I. - Male Medical Ward	31/03/2023
Comp. Dt. : 31/03/2023								
Status : Completed								
395	23031333	Male Medical - Ward 301	INTERCOM NO 1318 NOT WORKING	Vivek. A.	line cord changed problem solved		Daniel Joseph - POW & SICU	31/03/2023
Comp. Dt. : 08/05/2023								
Status : Completed								
396	23050279	Male Medical - Ward 303	INTEROM NO 1315 NOT WORKING	Vivek. A.	line cord changed problem solved		Vijayalakshmi. S. - Male Medical Ward	08/05/2023
Comp. Dt. : 01/06/2023								
Status : Completed								
397	23060043	Male Medical - Ward 303	INTERCOM NO 1315 NOT WORKING	Vivek. A.	line cord changed		Ananthi. P. - Male Medical Ward	01/06/2023
Comp. Dt. : 27/06/2023								
Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
398	23061029	Male Medical - Ward 303	INTERCOM NO 1315 NOT WORKING	Vivek. A.	coil cord changed problem solved		Vijayalakshmi. S. - Male Medical Ward	28/06/2023
	Comp. Dt. : 28/06/2023 Status : Completed							
399	23061068	Male Medical - Ward 302	INTERCOM NO 1318 NOT WORKING	Vivek. A.	coil cord changed problem solved		Kanmani. R. - Male Medical Ward	28/06/2023
	Dept Name : Male Ortho Ward - Tele Exchange Comp. Dt. : 07/05/2022 Status : Completed							
400	22050238	TB AND CHEST WARD-405	INTER COM NO 1411 NOT WORKING	Vivek. A.	instrument old damage new instrument changed		Rajasree. R. - Male Ortho Ward	07/05/2022
	Comp. Dt. : 15/09/2022 Status : Completed							
401	22090610	Male Ortho Ward	INTERCOM NO 1402 NOT WORKING	Vivek. A.	coil cord changed probelm solved		Rajasree. R. - Male Ortho Ward	16/09/2022
	Comp. Dt. : 17/09/2022 Status : Completed							
402	22090680	Male Ortho - Ward 404	INTERCOM NO 1417 NOT WORKING	Vivek. A.	phone keepad changed probelm solved		Rajasree. R. - Male Ortho Ward	19/09/2022
	Comp. Dt. : 29/10/2022 Status : Completed							
403	22100949	Male Surgery - Ward 204	INTERCOM NO. 1213 PHONE NOT WORKING	Vivek. A.	liline cord jack changed probelm solved		Vanitha. P. - Male Ortho Ward	29/10/2022
	Comp. Dt. : 08/11/2022 Status : Completed							
404	22110279	Male Ortho - Ward 403	INTERCOM NO.1402 NOT WORKING	Vivek. A.	coil cord + line cord jack changed		Maheswari. J. - Male Ortho Ward	09/11/2022
	Comp. Dt. : 20/01/2023 Status : Completed							
405	23010748	Male Ortho - Ward 404	INTERCOM NO 1409 NOT WORKING	Vivek. A.	coil cord changed probelm solved		Maheswari. J. - Male Ortho Ward	21/01/2023
	Comp. Dt. : 11/02/2023 Status : Completed							
406	23020427	Male Ortho - Ward 404	INTERCOM NO 1409 - RING TONE PROBLEM	Vivek. A.	puls/ton button adjiesment		Sandhiya. L. - Male Ortho Ward	13/02/2023
	Comp. Dt. : 27/02/2023 Status : Completed							


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
407	23021033	Male Ortho - Ward 404	INTERCOM NO 1409 NOT WORKING - AUDIO & RING TONE PROBLEM	Vivek. A.	puls/ton button adjesment probelm solved		Sandhiya. L. - Male Ortho Ward	27/02/2023
Comp. Dt. : 21/03/2023 Status : Completed								
408	23030862	Male Ortho - Ward 404	INTERCOM NO 1409 NOT WORKING	Vivek. A.	intercom hanset changed proplem solved		Gayathri. S. - Male Ortho Ward	21/03/2023
Comp. Dt. : 24/04/2023 Status : Completed								
409	23040753	Male Ortho - Ward 404	INTERCOM NO 1409 NOT WORKING	Vivek. A.	line cord jack changed		Maheswari. J. - Male Ortho Ward	24/04/2023
Comp. Dt. : 06/05/2023 Status : Completed								
410	23050258	Male Medical - Ward 303	INTERCOM NO 1315 NOT WORKING	Vivek. A.	line cord changed problem solved		Monisha Dheetchith. C. - Labour Ward	08/05/2023
Comp. Dt. : 18/05/2023 Status : Completed								
411	23050748	Male Ortho - Ward 404	INTERCOM NO 1409 NOT WORKING	Vivek. A.	coil cord and line jack changed problem solved		Maheswari. J. - Male Ortho Ward	20/05/2023
Comp. Dt. : 26/05/2023 Status : Completed								
412	23051050	Male Ortho - Ward 403	INTERCOM NO 1402 NOT WORKING	Vivek. A.	line card jack changed		Maheswari. J. - Male Ortho Ward	26/05/2023
Dept Name : Male Surgery - Tele Exchange Comp. Dt. : 10/06/2022 Status : Completed								
413	22060385	Male Surgery - Ward 201	INTERCOM 1216 VOICE NOT AUDIBLE	Vivek. A.	puls\ton button adjustment to coil cord wire changed		Sarmila. M. - Female Surgery	10/06/2022
Comp. Dt. : 29/06/2022 Status : Completed								
414	22061085	Female Surgery - Ward 205	INTERCOM NO 1217 NOT WORKING	Vivek. A.	phone hanset changed		Suseela. R. - ICU	30/06/2022
Comp. Dt. : 30/06/2022 Status : Completed								
415	22061135	Female Surgery - Ward 205	INTERCOM NO 1217 NOT WORKING	Vivek. A.	instrument damage new instrument fixed probelm solved		Subashini. D. - Gynac Ward	01/07/2022
Comp. Dt. : 19/07/2022								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
416	22070713	Obstetrics - Ward 207	INTERCOM NO 1224 NOT WORKING [AUDIO PROBLEM]	Vivek. A.	phone ringer changed		Ramajayam. S. - Gynac Ward	20/07/2022
Comp. Dt. : 09/08/2022								
Status : Completed								
417	22080320	Male Surgery - Ward 201	INTERCOM NO 1216 NOT WORKING	Vivek. A.	line cord changed probelm solved		Sugumari. M. - Male Surgery	11/08/2022
Comp. Dt. : 10/08/2022								
Status : Completed								
418	22080352	Male Surgery - Ward 201	INTERCOM NO 1216 NOT WORKING	Vivek. A.	instrument keepad changed probelm solved		Sarmila. M. - Female Surgery	11/08/2022
Comp. Dt. : 21/09/2022								
Status : Completed								
419	22090837	Male Surgery - Ward 201	INTERCOM NO 1216 NOT WORKING	Vivek. A.	line cord changed probelm solved		Kanimozhi. N - Male Surgery	21/09/2022
Comp. Dt. : 30/09/2022								
Status : Completed								
420	22091185	Male Surgery - Ward 201	INTERCOM NO 1216 AUDIO PROBLEM	Vivek. A.	phone handset changed probelm solved		Kanimozhi. N - Male Surgery	01/10/2022
Comp. Dt. : 06/10/2022								
Status : Completed								
421	22100114	Male Surgery - Ward 201	INTERCOM NO 1216 NOT WORKING [AUDIO PROBLEM]	Vivek. A.	handset refixed probelm solved		Sugumari. M. - Male Surgery	07/10/2022
Comp. Dt. : 19/10/2022								
Status : Completed								
422	22100644	Male Surgery - Ward 201	TELEPHONE NOT WORKING(1216)	Vivek. A.	phone handset refixed probelm solved		Kanimozhi. N - Male Surgery	20/10/2022
Comp. Dt. : 15/02/2023								
Status : Completed								
423	23020565	Male Surgery - Ward 201	INTERCOM NO 1216 NOT WORKING	Vivek. A.	line cord jack refixed		Sarmila. M. - Female Surgery	15/02/2023
Comp. Dt. : 20/03/2023								
Status : Completed								
424	23030821	Male Surgery - Ward 201	INTERCOM NO 1216 NOT WORKING	Vivek. A.	line cord jack changed problem solved		Malathy. S - Male Surgery	20/03/2023
Comp. Dt. : 29/03/2023								
Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
425	23031259	Male Surgery - Ward 201	INTERCOM NO 1216 NOT WORKING	Vivek. A.	line cord jack changed problem solved		Malathy. S - Male Surgery	30/03/2023
Comp. Dt. : 26/04/2023 Status : Completed								
426	23040882	Male Surgery - Ward 201	INTERCOM NO 1216 NOT WORKING	Vivek. A.	line cord jack changed problem solved		Kanimozhi. N - Male Surgery	27/04/2023
Comp. Dt. : 31/05/2023 Status : Completed								
427	23051240	Male Surgery - Ward 202	INTERCOM NO 1215 NOT WORKING	Vivek. A.	coil cord changed		Kanimozhi. N - Male Surgery	31/05/2023
Comp. Dt. : 08/06/2023 Status : Completed								
428	23060258	Male Surgery - Ward 202	INTERCOM NO 1215 NOT WORKING	Vivek. A.	coil cord changed probelm solved		Sasikala. A. - Male Surgery	08/06/2023
Dept Name : Marketing Team - Tele Exchange Comp. Dt. : 06/06/2022 Status : Completed								
429	22060174	FEVER CLINIC	INTERCOM NO 1671 NOT WORKING	Vivek. A.	phone keypad probelm keepad changed probelm solved		Amirtharaj. A. - Marketing Team	06/06/2022
Comp. Dt. : 19/09/2022 Status : Completed								
430	22090695	Reception	NEED TO CHECK & CHANGE INTERCOM CABLE FOR NO 2111	Vivek. A.	line cord changed probelm solved		Gokulraj. K. - Marketing Team	19/09/2022
Comp. Dt. : 08/12/2022 Status : Completed								
431	22120382	SPECIAL WARD -B IN FOURTH FLOOR	INTERCOM 1420 NOT WORKING	Vivek. A.	coil cord changed probelm solved		Shameena Begum. A. - Marketing Team	09/12/2022
Comp. Dt. : 16/12/2022 Status : Completed								
432	22120746	CUSTOMER CARE EXECUTIVE-RECEPTIO N	INTERCOM 3111 NOT WORKING	Vivek. A.	potr problem		Sathiya Priya. J. - Marketing Team	16/12/2022
Comp. Dt. : 25/04/2023 Status : Completed								
433	23040820	IVF ART CLINIC-INSIDE OF OG OPD(NO.68)	INTERCOM NO 3060 NOT WORKING	Vivek. A.	port number changed problem solved		Sathiya. M. - Marketing Team	26/04/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 13/05/2023 Status : Completed								
434	23050536	Chairman Office	FAX NOT WORKING - NEED URGENT SERVICE	Vivek. A.	two pair cable changed problem solved		Priya. A. - Marketing Team	04/08/2023
Comp. Dt. : 23/05/2023 Status : Completed								
435	23050911	Reception	INTERCOM NO 3111 NOT WORKING AT CC COUNTER	Vivek. A.	coil cord changed		Ramya. C. - Marketing Team	23/05/2023
Comp. Dt. : 01/06/2023 Status : Completed								
436	23060029	Reception	INTERCOM NO 3111 - CABLE PROBLEM AT C C COUNTER	Vivek. A.	two pair cable changed		Amirtharaj. A. - Marketing Team	01/06/2023
Dept Name : Medical Records - Tele Exchange Comp. Dt. : 02/05/2022 Status : Completed								
437	22050030	Medical Records	INTERCOM NO 1527 NOT WORKING	Vivek. A.	two pair cable probelm new cable changed		Martin Prabu.V. - Medical Records	02/05/2022
Comp. Dt. : 07/06/2022 Status : Completed								
438	22060250	Medical Records	NEED TO CHECK INTERCOM NO 2525 - AUDIO PROBLEM	Vivek. A.	hanset spaker probelm spaker refixed		Martin Prabu.V. - Medical Records	07/06/2022
Comp. Dt. : 08/06/2022 Status : Completed								
439	22060298	Medical Records	INTERCOM NO 2323 NOT WORKING	Vivek. A.	coil cord probelm new coil cord changed		Martin Prabu.V. - Medical Records	10/06/2022
Comp. Dt. : 14/06/2022 Status : Completed								
440	22060494	Medical Records	INTERCOM NO 2323 NOT WORKING	Vivek. A.	hanset damage new hanset fixed probelm solved		Martin Prabu.V. - Medical Records	16/06/2022
Comp. Dt. : 29/07/2022 Status : Completed								
441	22071053	Medical Records	NEED TO CHANGE INTERCOM PHONE 2525 - AUDIO PROBLEM - NEED URGENT SERVICE	Vivek. A.	hanset speaker changed		Martin Prabu.V. - Medical Records	30/07/2022
Comp. Dt. : 09/08/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
442	22080340	DIRECTOR QUATERS	INTERCOM NO 2075 [SMVEC DIRECTOR] NOT WORKING - NEED URGENT SERVICE	Vivek. A.	port number issue port changed probelm solved		Sukanya. S. - Medical Records	17/08/2022
Comp. Dt. : 16/12/2022 Status : Completed								
443	22120745	Male Medical - Ward 303	INTERCOM 1315 NOT WORKING	Vivek. A.	line cord changed probelm solved		Mohanapriya. A. - Medical Records	17/12/2022
444	22120776	Medical Records	INTERCOM NO 2323 - MODOM BROKEN	Vivek. A.	coil cord problem		Martin Prabu.V. - Medical Records	16/12/2022
Comp. Dt. : 11/01/2023 Status : Completed								
445	23010500	Paediatrics - Ward 310	INTERCOM 1312 CONNECTION NEED TO GIVE	Vivek. A.	line cord changed probelm solved		Deepa. S. - Medical Records	11/01/2023
Comp. Dt. : 21/01/2023 Status : Completed								
446	23010765	Medical Records	INTERCOM NO 1530 NOT WORKING	Vivek. A.	line cord wire changed probelm solved		Martin Prabu.V. - Medical Records	21/01/2023
Comp. Dt. : 31/01/2023 Status : Completed								
447	23011101	Medical Records	INTERCOM NO 2525 PROBLEM	Vivek. A.	line cord wire changed		Martin Prabu.V. - Medical Records	01/02/2023
Comp. Dt. : 03/02/2023 Status : Completed								
448	23020115	Medical Records	INTERCOM NO 2525 AUDIO PROBLEM - NEED URGENT SERVICE	Vivek. A.	instrument mother bord issue instrument changed		Martin Prabu.V. - Medical Records	06/02/2023
Comp. Dt. : 21/02/2023 Status : Completed								
449	23020823	Male Medical - Ward 304	INTERCOM 1317 NOT WORKING	Vivek. A.	instrument keypad changed		Mohanapriya. A. - Medical Records	21/02/2023
Comp. Dt. : 02/03/2023 Status : Completed								
450	23030099	Medical Records	INTERCOM NO 2525 NOT WORKING	Vivek. A.	caller id phone stock no.		Sukanya. S. - Medical Records	28/03/2023
Comp. Dt. : 15/03/2023 Status : Completed								
451	23030603	Medical Records	INTERCOM NO 3131 NOT WORKING	Vivek. A.	line cord + coil cord changed probelm solved		iswin Joseph.M. - Medical Records	15/03/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
452	23030604	Female Surgery - Ward 206	INTERCOM NO 1214 - CABLE PROBLEM	Vivek. A.	line cord jack refixed problem solved		Pushparaj. J. - Medical Records	15/03/2023
Comp. Dt. : 28/03/2023 Status : Completed								
453	23031196	Medical Records	INTERCOM NO 2323 NOT WORKING - SOUND PROBLEM	Vivek. A.	coil cord changed probelm solved		Avanthia. R. - Medical Records	28/03/2023
Comp. Dt. : 04/04/2023 Status : Completed								
454	23040104	Medical Records	NEED TO CHECK INTERCOM NO 2525 - NOT WORKING	Vivek. A.	instrument changed problem solved		Martin Prabu.V. - Medical Records	06/04/2023
Comp. Dt. : 25/04/2023 Status : Completed								
455	23040813	Medical Records	NEED TO CHANGE CABLE - PROBLEM - INTERCOM NO 2323	Vivek. A.	coil cord changed		Avanthia. R. - Medical Records	26/04/2023
Comp. Dt. : 29/04/2023 Status : Completed								
456	23040995	Male Medical - Ward 303	INTERCOM NO 1317 NOT WORKING	Vivek. A.	instrument handset changed		Vijayakumari. P. - Medical Records	29/04/2023
Comp. Dt. : 15/05/2023 Status : Completed								
457	23050573	Medical Records	INTERCOM NO 2525 NOT WORKING [AUDIO PROBLEM] 3	Vivek. A.	line cord changed		Martin Prabu.V. - Medical Records	15/05/2023
Comp. Dt. : 01/06/2023 Status : Completed								
458	23060047	Medical Records	PROBLEM IN INTERCOM NO 2323	Vivek. A.	coil cord changed problem solved		Avanthia. R. - Medical Records	01/06/2023
Comp. Dt. : 30/06/2023 Status : Completed								
459	23061127	Medical Records	INTERCOM NO 2323 NOT WORKING	Vivek. A.	coil cord changed problem sloved		Avanthia. R. - Medical Records	01/07/2023
Dept Name : MICROBIOLOGY - Tele Exchange Comp. Dt. : 12/10/2022 Status : Completed								
460	22100310	microbiology opd lab	INTERCOM NO:1009 NOT WORKING	Vivek. A.	line cord jack changed probelm solved		Julia. S. - MICROBIOLOGY	13/10/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 06/02/2023 Status : Completed								
461	23020154	MICROBIOLOGY	DIAL PAD NO 1 NOT WORKING [INTERCOM NO 1009]	Vivek. A.	instrument changed		Arunachalam. G. - MICROBIOLOGY	07/02/2023
Comp. Dt. : 11/03/2023 Status : Completed								
462	23030457	MICROBIOLOGY IN COLLEGE	INTERCOM NO 2085 NOT WORKING	Vivek. A.	port number changed		Praveenkumar. S. - MICROBIOLOGY	13/03/2023
Comp. Dt. : 31/05/2023 Status : Completed								
463	23051231	MICROBIOLOGY	INTERCOM NO 1009 NOT WORKING	Vivek. A.	line card changed		Kohila. S. - MICROBIOLOGY	01/06/2023
Dept Name : MS Office - Tele Exchange Comp. Dt. : 09/11/2022 Status : Completed								
464	22110332	SKILL LAB - MEDICAL COLLEGE	NEED TO FIX NEW INTERCOM	Vivek. A.	new intercom line fixed number 2001		Prabhakaran. S. - Medical Records	14/11/2022
Comp. Dt. : 27/01/2023 Status : Completed								
465	23010994	MS Office	INTERCOM 1221 AND 1240 NOT WORKING	Vivek. A.	coil cord + line cord changed probelm solved		Rajalakshmi. G. - MS Office	28/01/2023
Comp. Dt. : 28/01/2023 Status : Completed								
466	23011003	MS Office	INTERCOM NO1221 & 1240 NOT WORKING - NEED URGENT SERVICE	Vivek. A.	coil cord + line cord changed probelm solved		Rajalakshmi. G. - MS Office	28/01/2023
Dept Name : Nephrology - Tele Exchange Comp. Dt. : 29/09/2022 Status : Completed								
467	22091162	DIALYSIS NEW UNIT IN 1ST FLOOR	DIAL BATTON PROBLEM - INTERCOM NO 1161	Vivek. A.	puls/ton button adujesment		Kamal. B. - Nephrology	30/09/2022
Comp. Dt. : 09/12/2022 Status : Completed								
468	22120400	DIALYSIS NEW UNIT IN 1ST FLOOR	INTERCOM NO 1161 NOT WORKING	Vivek. A.	line cord jack changed probelm solved		Kamal. B. - Nephrology	09/12/2022
Comp. Dt. : 04/05/2023 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
469	23050174	DIALYSIS NEW UNIT IN 1ST FLOOR	NEED TO CHANGE INTERCOM CABLE - DAMAGE - NO 1161	Vivek. A.	coil cord changed problem solved		Kamal. B. - Nephrology	05/05/2023
Dept Name : Nursing Office - Tele Exchange Comp. Dt. : 06/07/2022 Status : Completed								
470	22070220	Female Ortho - Ward 401	INTERCOM NO 1417 NOT WORKING	Vivek. A.	line cord +coil cord changed probelm solved		Vani. M. - Female Ortho Ward	07/07/2022
Comp. Dt. : 19/07/2022 Status : Completed								
471	22070696	ICU	INTERCOM NO 1115 NOT WORKING	Vivek. A.	puls/ton button changed		Leena Grace. B. - Nursing Office	19/07/2022
Comp. Dt. : 23/07/2022 Status : Completed								
472	22070850	ENT WARD-407	NEED TO CHECK INTERCOM - NOT WORKNG -NO 1429 & 1430	Vivek. A.	hanset +puls/ton button changed		Chandralekha. S. - Nursing Office	23/07/2022
Comp. Dt. : 10/08/2022 Status : Completed								
473	22080364	Male Surgery - Ward 201	INTERCOM NO 1216 NOT WORKING - REPEAT	Vivek. A.	line cord + instrument changed probelm solved		Kalaiaarasi. D. - Nursing Office	11/08/2022
Comp. Dt. : 06/10/2022 Status : Completed								
474	22100116	OG-OPD	INTERCOM NO 1083 NOT WORKING	Vivek. A.	instrument damage new instrument fixed		Kalaiaarasi. D. - Nursing Office	07/10/2022
Comp. Dt. : 08/11/2022 Status : Completed								
475	22110275	SKILL OP IN 5TH FLOOR	INTERCOM NO.1446 NOT WORKING	Vivek. A.	two cable issue number changed 1447		Ilambharat.K. - Nursing Office	08/11/2022
Comp. Dt. : 14/02/2023 Status : Completed								
476	23020554	Nursing Office	NEED A PARALLEL INTERCOM LINE CONNECTION FOR DNS OFFICE	Vivek. A.	parallel lineno passepap port issue		Rajalakshmi. N. - Nursing Office	21/03/2023
Comp. Dt. : 13/03/2023 Status : Completed								
477	23030475	ICU	INTERCOM NO 1130 NOT WORKING	Vivek. A.	instrument hanset refixe		Kalaiaarasi. D. - Nursing Office	13/03/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 30/03/2023								
Status : Completed								
478	23031290	Male Surgery - Ward 201	INTERCOM NO 1216 NOT WORKING	Vivek. A.	line cord jack changed problem solved		Kowsalya. G. - Male Surgery	30/03/2023
Comp. Dt. : 22/04/2023								
Status : Completed								
479	23040703	ICU	INTERCOM NO 1130 NOT WORKING	Vivek. A.	line cord changed problem solved		Kalaiaarasi. D. - Nursing Office	24/04/2023
Comp. Dt. : 27/04/2023								
Status : Completed								
480	23040913	SPECIAL WARD---B	INTERCOM NO 1420 NOT WORKING	Vivek. A.	coil cord changed		Tamilarasi.C. - Nursing Office	28/04/2023
Comp. Dt. : 16/05/2023								
Status : Completed								
481	23050659	ANS DRESS CHANGING ROOM	INTERCOM NO 1322 NOT WORKING III FLOOR ANS ROOM	Vivek. A.	new instrument changed		Chandralekha. S. - Nursing Office	18/05/2023
Dept Name : Nutrition & Dietetics - Tele Exchange								
Comp. Dt. : 25/06/2022								
Status : Completed								
482	22060926	DIET DEPARMENT	INTERCOM NO 1440 NOT WORKING	Vivek. A.	instrument probelm new instrument fixed		Krishna Priya. E. - Nutrition & Dietetics	28/06/2022
Comp. Dt. : 06/01/2023								
Status : Completed								
483	23010291	DIET DEPARMENT	INTERCOME NO-1441-NOT WORKING	Vivek. A.	line cord changed probelm solved		Krishna Priya. E. - Nutrition & Dietetics	07/01/2023
Comp. Dt. : 02/03/2023								
Status : Completed								
484	23030060	DIET DEPARMENT	INTERCOM NO 1441 NOT WORKING	Vivek. A.	line cord changed probelm solved		Shanmugapriya. J. - Nutrition & Dietetics	02/03/2023
Dept Name : OPD - Tele Exchange								
Comp. Dt. : 05/05/2022								
Status : Completed								
485	22050131	ENT OPD	INTERCOM NO 1031 NOT WORKING	Vivek. A.	keepad changed		Ezhilarasi. M. - OPD	05/05/2022
Comp. Dt. : 09/05/2022								
Status : Completed								
486	22050280	ONCOLOGY DEPT-2ND FLOOR-SPECIAL OPD	INTERCOM NO 1292 NOT WORKING	Vivek. A.	line cord wire changed		Lakshmidevi. A - OPD	09/05/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 16/05/2022 Status : Completed								
487	22050576	DENTAL OPD -2ND FLOOR	INTERCOM NO 1210 NOT WORKING [AUDIO PROBLEM]	Vivek. A.	hanset spaker refixed probelm solved		Lakshmi Devi. R. - OPD	17/05/2022
Comp. Dt. : 17/05/2022 Status : Completed								
488	22050606	ENT OPD	INTERCOM NO 1031 NOT WORKING	Vivek. A.	instrument probelm new instrument changed		Ezhilarasi. M. - OPD	18/05/2022
Comp. Dt. : 03/06/2022 Status : Completed								
489	22060095	ENT WARD-407	INTERCOM NO 1430 NOT WORKING	Vivek. A.	line cord probelm new line cord changed		Jaculine Mary. A. - ENT & Ophthal Ward	04/06/2022
Comp. Dt. : 09/06/2022 Status : Completed								
490	22060346	Surgery OPD	INTERCOM NO 1062 NOT WORKING [SOUND PROBLEM]	Vivek. A.	phone hanset probelm new hanset changed		Indhira. M. - OPD	10/06/2022
Comp. Dt. : 10/06/2022 Status : Completed								
491	22060376	DENTAL OPD -2ND FLOOR	INTERCOM 1210 ,WHILE SPEAKING VOICE NOT AUDIBLE TO THE RECEIVER	Vivek. A.	speaker probelm new speaker changed		Lakshmi Devi. R. - OPD	10/06/2022
Comp. Dt. : 08/07/2022 Status : Completed								
492	22070333	Surgery OPD	INTERCOM NO 1062 NOT WORKING	Vivek. A.	instrument borken new instrument fixed		Indhira. M. - OPD	08/07/2022
Comp. Dt. : 15/07/2022 Status : Completed								
493	22070573	NEUROLOGY OPD-2ND FLOOR	INTERCOM CABLE PROBLEM - NEED TO REFIX [INTERCOM NO 1265] - IN OPD NO 222	Vivek. A.	two pair cable issue		Lavanya. M. - OPD	01/08/2022
494	22070588	Surgery OPD	INTERCOM NO 1062 NOT WORKING	Vivek. A.	instrument damage new instrument fixed probelm solved		Indhira. M. - OPD	18/07/2022
Comp. Dt. : 02/08/2022 Status : Completed								
495	22080063	Paediatrics - OPD	INTERCOM NO 1050 NOT WORKING	Vivek. A.	line cord changed probelm solved		Indumathi. T. - OPD	03/08/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 22/08/2022 Status : Completed								
496	22080692	Paediatrics - OPD	NEED TO REPLACE INTERCOM [REFIX ANOTHER PLACE]	Vivek. A.	cable issue		Subashree. R. - OPD	30/08/2022
Comp. Dt. : 26/08/2022 Status : Completed								
497	22080919	ENT OPD	INTERCOM NO 1036 NOT WORKING	Vivek. A.	coil cord cahnged probelm solved		Ezhilarasi. M. - OPD	29/08/2022
Comp. Dt. : 12/09/2022 Status : Completed								
498	22090421	Paediatrics - OPD	NEED TO REPLACE [OTHER PLACE] INTERCOM NO 1050	Vivek. A.	other place cable laying		Subashree. R. - OPD	19/09/2022
Comp. Dt. : 20/09/2022 Status : Completed								
499	22090775	TB & Chest OPD	INTERCOM NO 1095 NOT WORKING	Vivek. A.	coil cord + line cord changed probelm solved		Jothi.R. - OPD	21/09/2022
Comp. Dt. : 14/10/2022 Status : Completed								
500	22100437	OG-OPD	NEED TO CHECK TELEPHONE LINE - ALL INTERCOMS NOT WORKING	Vivek. A.	flc card port issue flc cord reboot probelm sooved		Velangkanni. K. - OPD	15/10/2022
Comp. Dt. : 18/11/2022 Status : Completed								
501	22110789	CTVS-ROOM NO.225 -2ND FLOOR	NEED A NEW INTERCOM LINE CONNECTION FOR HOD ROOM	Vivek. A.	line cord wire changed probelm solved		Suvitha. R. - OPD	07/12/2022
Comp. Dt. : 19/11/2022 Status : Completed								
502	22110815	Nephrology OPD	NEED TO CHANGE INTERCOM CABLE - DAMAGED (1261)	Vivek. A.	two pair cable changed probelm solved		Jenifer. K. - OPD	21/11/2022
Comp. Dt. : 03/12/2022 Status : Completed								
503	22120140	General Medicine - OPD	INTERCOM NO. 1033 BROKEN IN MEDICINE OPD - ROOM NO20	Vivek. A.	instrument handset changed		Sivaranjani. P. - OPD	06/12/2022
Comp. Dt. : 08/12/2022								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
504	22120376	Surgery OPD	INTERCOM 1062 VOICE NOT CLEAR WHILE SPEAKING	Vivek. A.	coil cord changed probelm solved		Indhira. M. - OPD	08/12/2022
505	22120391	Ophthalmology - OPD	INTERCOM 1080 NOT WORKING	Vivek. A.	puls/ton button adjesment		Seetha. R. - OPD	09/12/2022
Comp. Dt. : 09/12/2022								
Status : Completed								
506	22120441	TB & Chest OPD	INTERCOM NO 1095 NOT WORKING - AUDIO PROBLEM	Vivek. A.	port issue reboot port probelm solved		Jothi.R. - OPD	09/12/2022
Comp. Dt. : 10/12/2022								
Status : Completed								
507	22120489	ENT OPD	INTERCOM 1036 NOT WORKING	Vivek. A.	instrument changed probelm solved		Ezhilarasi. M. - OPD	12/12/2022
Comp. Dt. : 13/12/2022								
Status : Completed								
508	22120593	OG-OPD	INTERCOM NO 1087 NOT WORKING	Vivek. A.	two pair cable changed probelm solved		Velangkanni. K. - OPD	13/12/2022
509	22120599	TB & Chest OPD	INTERCOM NO 1095 NOT WORKING	Vivek. A.	two pair wire + line cord changed probelm solved		Jothi.R. - OPD	13/12/2022
Comp. Dt. : 29/12/2022								
Status : Completed								
510	22121315	TB & Chest OPD	INTERCOM NO 1095 NOT WORKING	Vivek. A.	line cord changed probelm solved		Jothi.R. - OPD	30/12/2022
511	22121333	TB & Chest OPD	INTERCOM 1095 NOT WORKING	Vivek. A.	line cord changed probelm solved		Jothi.R. - OPD	30/12/2022
Comp. Dt. : 09/01/2023								
Status : Completed								
512	23010366	OG-OPD	IN HOD ROOM-INTERCOM 1061 NOT WORKING	Vivek. A.	instrument changed probelm solved		Velangkanni. K. - OPD	10/01/2023
Comp. Dt. : 01/02/2023								
Status : Completed								
513	23020008	CTVS-ROOM NO.225 -2ND FLOOR	INTERCOM NO 1255 NOT WORKING	Vivek. A.	line cord jack refixed probelm solved		Kamala.D. - OPD	03/02/2023
Comp. Dt. : 04/02/2023								
Status : Completed								
514	23020139	OG-OPD	INTERCOM NO 1067 NOT WORKING	Vivek. A.	instrument keepad changed		Velangkanni. K. - OPD	10/02/2023
Comp. Dt. : 07/02/2023								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
515	23020217	PSYCHIATRY OPD	INTERCOM NO 1075 NOT WORKING	Vivek. A.	instrument changed		Kamala.D. - OPD	09/02/2023
Comp. Dt. : 10/02/2023								
Status : Completed								
516	23020384	OG-OPD	INTERCOM NO.1087 NOT WORKING	Vivek. A.	line cord changed probelm solved		Velangkanni. K. - OPD	10/02/2023
Comp. Dt. : 13/02/2023								
Status : Completed								
517	23020471	NEUROLOGY OPD-2ND FLOOR	INTERCOM NO 1264 NOT WORKING	Vivek. A.	two pair cable rejoin probelm solved		Lavanya. M. - OPD	13/02/2023
518	23020479	DENTAL OPD -2ND FLOOR	INTERCOM NO 1210 NOT WORKING	Vivek. A.	instrument changed		Lakshmi Devi. R. - OPD	17/02/2023
Comp. Dt. : 28/02/2023								
Status : Completed								
519	23021063	GENERAL SURGERY OPD-55	TELEPHONE PIN PROBLEM	Vivek. A.	coil cord changed probelm solved		Indhira. M. - OPD	01/03/2023
520	23021085	TB & Chest OPD	HOD SIR ROOM INTERCOM NOT WORKING	Vivek. A.	line cord cord changed		Jothi.R. - OPD	01/03/2023
Comp. Dt. : 07/03/2023								
Status : Completed								
521	23030257	Nephrology OPD	INTERCOM NO 1285 NOT WORKING	Vivek. A.	line cord changed probelm solved		Jenifer. K. - OPD	07/03/2023
522	23030260	TB & Chest OPD	INTERCOM NO 1095 NOT WORKING	Vivek. A.	coil cord changed prrobelm solved		Jothi.R. - OPD	07/03/2023
Comp. Dt. : 10/03/2023								
Status : Completed								
523	23030413	ENT OPD	INTERCOM NO 1023 NOT WORKING	Vivek. A.	line cord changed		Ezhilarasi. M. - OPD	24/03/2023
Comp. Dt. : 14/03/2023								
Status : Completed								
524	23030549	ENT OPD	INTERCOM NO 1023 NOT WORKING	Vivek. A.	cable issue		Ezhilarasi. M. - OPD	02/05/2023
Comp. Dt. : 17/03/2023								
Status : Completed								
525	23030691	General Medicine - OPD	INTERCOM NO 1096 NOT WORKING ROOM NO 19	Vivek. A.	line cord changed problem solved		Sivaranjani. P. - OPD	18/03/2023
Comp. Dt. : 21/03/2023								
Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
526	23030845	Ophthalmology - OPD	INTERCOM NO 1075 NOT WORKING	Vivek. A.	puls/ton button adjusment		Seetha. R. - OPD	21/03/2023
	Comp. Dt. : 29/03/2023							
	Status : Completed							
527	23031234	ENT OPD	INTERCOM NO 1023 NOT WORKING	Vivek. A.	two pair cable changed problem solved		Ezhilarasi. M. - OPD	17/05/2023
	Comp. Dt. : 03/04/2023							
	Status : Completed							
528	23040045	Orthopaedics - OPD	INTERCOM NO 1064 & 1044 NOT WORKING [ROOM NO 63 & 64]	Vivek. A.	instrument changed		Durgadevi. J - OPD	04/04/2023
	Comp. Dt. : 05/04/2023							
	Status : Completed							
529	23040159	ENT OPD	INTERCOM NUMBERS 1023 , 1032 , 1034 & 1036 NOT WORKING	Vivek. A.	puls/ton button adjusment		Ezhilarasi. M. - OPD	08/04/2023
	Comp. Dt. : 08/04/2023							
	Status : Completed							
530	23040224	NEUROLOGY OPD-2ND FLOOR	INTERCOM NO 1250 NOT WORKING	Vivek. A.	new instrument changed problem solved		Radhika. R. - OPD	08/04/2023
	Comp. Dt. : 11/04/2023							
	Status : Completed							
531	23040330	Ophthalmology - OPD	INTERCOM NO 1080 NOT WORKING	Vivek. A.	port number changed		Seetha. R. - OPD	12/04/2023
	Comp. Dt. : 17/04/2023							
	Status : Completed							
532	23040503	Plastic Surgery	INTERCOM NO 1258 NOTWORKING	Vivek. A.	line cord changed problem solved		Lakshmid devi. A - OPD	17/04/2023
	Comp. Dt. : 20/04/2023							
	Status : Completed							
533	23040684	DENTAL OPD -2ND FLOOR	INTERCOM NO 1210 NOT WORKING	Vivek. A.	button keypad cahged problemm solved		Kamala.D. - OPD	22/04/2023
	Comp. Dt. : 24/04/2023							
	Status : Completed							
534	23040726	Orthopaedics - OPD	NEED CONNECTION WORK FOR INTERCOM - NO 1049 - ROOM NO 64	Vivek. A.	cable issue		Durgadevi. J - OPD	20/07/2023
	Comp. Dt. : 29/04/2023							
	Status : Completed							


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
535	23040998	OG-OPD	INTERCOM NO 1061 NOT WORKING	Vivek. A.	coil cord changed problem solved		Velangkanni. K. - OPD	02/05/2023
Comp. Dt. : 04/05/2023 Status : Completed								
536	23050161	ENT OPD	INTERCOM NO 1023 NOT WORKING	Vivek. A.	two pair cable changed problem solved		Kamala.D. - OPD	17/05/2023
537	23050172	CTVS-ROOM NO.225 -2ND FLOOR	INTERCOM NO 1255 NOT WORKING	Vivek. A.	line cord changed problem solved		Jenifer. K. - OPD	05/05/2023
Comp. Dt. : 05/05/2023 Status : Completed								
538	23050212	Nephrology OPD	INTERCOM NO 1250 NOT WORKING	Vivek. A.	puls/ton button adjesment		Radhika. R. - OPD	06/05/2023
Comp. Dt. : 12/05/2023 Status : Completed								
539	23050514	NEUROLOGY OPD-2ND FLOOR	INTERCOM NO 1265 NOT WORKING [AUDIO PROBLEM] OPD NO 222	Vivek. A.	coil cord changed problem solved		Lavanya. M. - OPD	13/05/2023
Comp. Dt. : 15/05/2023 Status : Completed								
540	23050574	Orthopaedics - OPD	INTERCOM NO 1048 NOT WORKING - ROOM NO 64	Vivek. A.	cable issue		Durgadevi. J - OPD	01/08/2023
541	23050575	Orthopaedics - OPD	NEED TO PROVIDE INTERCOM CONNECTION FOR NO 1044 ROOM NO 64 - REMINDER NO II	Vivek. A.	cable issue		Durgadevi. J - OPD	03/08/2023
Comp. Dt. : 29/05/2023 Status : Completed								
542	23051131	Ophthalmology - OPD	INTERCOM NO 1085 NOT WORKING	Vivek. A.	new instrument changed		Kamala.D. - OPD	31/05/2023
Comp. Dt. : 01/06/2023 Status : Completed								
543	23060019	Surgery OPD	INTERCOM NO 1062 - CABLE PROBLEM	Vivek. A.	coil cord changed		Indhira. M. - OPD	01/06/2023
Comp. Dt. : 14/06/2023 Status : Completed								
544	23060479	DENTAL VIP CLINIC-SPECIAL OPD-2ND FLOOR	INTERCOM NO 1230 NOT WORKING	Vivek. A.	coil cord and line cord jack changed		Jayasree. S. - TB & Chest / Psychiatry	14/06/2023
545	23060491	Nephrology OPD	INTERCOM NO 1261 NOT WORKING - OPD NO 226	Vivek. A.	2 instrument parallel line fixed		Jenifer. N. - OPD	14/06/2023
Comp. Dt. : 16/06/2023								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
546	23060595	Nephrology OPD	1261-INTERCOM NOT WORKING	Vivek. A.	new instrument changed problem solved		Jenifer. K. - OPD	16/06/2023
Comp. Dt. : 19/06/2023								
Status : Completed								
547	23060680	Paediatrics - OPD	NEED CABLE EXTEND & CHANGE ANOTHER PLACE - INTERCOM NO 1058	Vivek. A.	line cord cable exted problem solved		Subashree. R. - OPD	23/06/2023
Comp. Dt. : 22/06/2023								
Status : Completed								
548	23060820	TB & Chest OPD	INTERCOM NO 1095 NOT WORKING [HOD ROOM]	Vivek. A.	line cord changed		Jothi.R. - OPD	22/06/2023
Dept Name : Operation Theatre - Tele Exchange								
Comp. Dt. : 10/05/2022								
Status : Completed								
549	22050346	ORTHO OT	INTERCOM NO 1117 NOT WORKING	Vivek. A.	coil cord changed probelm solved		Sendhil Kumar. C. - Operation Theatre	10/05/2022
Comp. Dt. : 20/05/2022								
Status : Completed								
550	22050754	OG OT	INTERCOM NO 1125 NOT WORKING [AUDIO PROBLEM]	Vivek. A.	coil cord probelm new coil cord changed		Amudha. V. - Operation Theatre	21/05/2022
Comp. Dt. : 09/06/2022								
Status : Completed								
551	22060341	ORTHO OT	INTERCOM NO 1117 [PARALLEL LINE] NOT WORKING	Vivek. A.	two pair cable disconnected cable rejoin probelm solved		Mahalakshmi. G. - Operation Theatre	10/06/2022
Comp. Dt. : 24/06/2022								
Status : Completed								
552	22060885	ORTHO OT	INTERCOM NO 1117 [PARALLEL LINE] NOT WORKING	Vivek. A.	instrument probelm new instrument changed		Mahalakshmi. G. - Operation Theatre	24/06/2022
Comp. Dt. : 05/08/2022								
Status : Completed								
553	22080216	EMERGENCY OT NEAR CASUALTY	INTERCOM NO 1018 BUTTON , AUDIO & SOUND PROBLEM - NOT WORKING	Vivek. A.	instrument keepa button changed probelm solved		Hari Hara Sudhan. K. - Operation Theatre	12/08/2022
Comp. Dt. : 08/08/2022								
Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
554	22080257	New OT	INTERCOM NO 1159 AT RECOVERY ROOM - NOT WORKING	Vivek. A.	two pair wire damage new wire fixed probelm solved		Kousalya. S. - Operation Theatre	09/08/2022
	Comp. Dt. : 11/08/2022							
	Status : Completed							
555	22080415	ORTHO OT	INTERCOM NO 1117 NOT WORKING	Vivek. A.	line cord changed probelm solved		Shankari. G. - Operation Theatre	12/08/2022
	Comp. Dt. : 17/08/2022							
	Status : Completed							
556	22080486	New OT	INTERCOM NO - 1159 NOT WORKING	Vivek. A.	puls/ton button changed probelm solved		Udhaya Kumar. C. - Operation Theatre	17/08/2022
557	22080492	SURGERY OT	INTERCOM(1159) BUTTON NOT WORKING	Vivek. A.	instrument keypad button changed probelm solved		Jagatheeswaran. G. - Operation Theatre	18/08/2022
	Comp. Dt. : 18/08/2022							
	Status : Completed							
558	22080597	SURGERY OT	INTERCOM 1159 NOT WORKING	Vivek. A.	instrument keypad changed probelm solved		Ramachandiran. M. - Operation Theatre	19/08/2022
	Comp. Dt. : 19/08/2022							
	Status : Completed							
559	22080636	New OT	INTERCOM DIAL PAD NOT WORKING	Vivek. A.	instrument keypad changed probelm solved		Udhaya Kumar. C. - Operation Theatre	19/08/2022
	Comp. Dt. : 02/09/2022							
	Status : Completed							
560	22090107	Main OT	NEED TO CHANGE PHONE WIRE	Vivek. A.	line cord changed probelm solved		Shankari. G. - Operation Theatre	05/09/2022
	Comp. Dt. : 07/09/2022							
	Status : Completed							
561	22090291	ORTHO OT	PROBLEM ININTERCOM CABE - NO 1170	Vivek. A.	coil cord wire changed probelm soved		Mahalakshmi. G. - Operation Theatre	07/09/2022
	Comp. Dt. : 05/11/2022							
	Status : Completed							
562	22110172	Main OT	INTERCOM 1170 NOT WORKING	Vivek. A.	line cord jack chganged probelm solved		Ayisha Bee. M. A. - Operation Theatre	05/11/2022
	Comp. Dt. : 05/12/2022							
	Status : Completed							
563	22120206	OG OT	INTERCOM 1125 SOUND NOT AUDIBLE	Vivek. A.	phone handset changed		Subashini. E. - Operation Theatre	06/12/2022
	Comp. Dt. : 02/01/2023							
	Status : Completed							

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
564	23010024	New OT	INTERCOM 1125 CABLE PROBLEM(IN ENTRANCE)	Vivek. A.	coil cord changed probelm solved		Kousalya. S. - Operation Theatre	03/01/2023
Comp. Dt. : 11/01/2023 Status : Completed								
565	23010470	New OT	INTERCOM 1149 NOT WORKING IN ENTRANCE	Vivek. A.	coil cord changed probelm solved		Ramachandiran. M. - Operation Theatre	11/01/2023
Comp. Dt. : 10/03/2023 Status : Completed								
566	23030424	OG OT	INTERCOM NO 1125 NOT WORKING	Vivek. A.	coil cord changed probelm solved		Sathia. R. - Operation Theatre	10/03/2023
Comp. Dt. : 11/03/2023 Status : Completed								
567	23030464	ORTHO OT	INTERCOM NO 1170 NOT WORKING	Vivek. A.	coil cord changed probelm solved		Mahalakshmi. G. - Operation Theatre	13/03/2023
Comp. Dt. : 29/05/2023 Status : Completed								
568	23051122	OG OT	INTERCOM NO 1125 NOT WORKING	Vivek. A.	two pair cable refixed problem solved		Sathia. R. - Operation Theatre	29/05/2023
Comp. Dt. : 16/06/2023 Status : Completed								
569	23060581	Main OT	(1159) INTERCOM BUTTON PROBLEM	Vivek. A.	coil cord and line cord changed		Udhaya Kumar. C. - Operation Theatre	16/06/2023
Comp. Dt. : 23/06/2023 Status : Completed								
570	23060855	ORTHO OT	INTERCOM NO 1170 NOT WORKING [RECOVERY ROOM]	Vivek. A.	coil cord changed problem solved		Mahalakshmi. G. - Operation Theatre	23/06/2023
Dept Name : Ophthalmology - Tele Exchange Comp. Dt. : 13/02/2023 Status : Completed								
571	23020478	EYE Bank	INTERCOM NO 3101 NOT WORKING	Vivek. A.	instrument changed		Rajeswari.V. - Ophthalmology	14/02/2023
Dept Name : PAEDIATRICS - Tele Exchange Comp. Dt. : 23/05/2023 Status : Completed								
572	23050935	Paediatrics - OPD	NEED TO CHANGE INTERCOM INSTRUMENT - BROKEN -	Vivek. A.	hanset changesd		Gayathri. D. - PAEDIATRICS	23/05/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Dept Name : Paediatrics Ward - Tele Exchange Comp. Dt. : 25/02/2023 Status : Completed								
573	23020991	Paediatrics - Ward 308	INTERCOM NO 1346 NOT WORKING	Vivek. A.	coil cord changed probelm solved		Naveena. N. - Paediatrics Ward	27/02/2023
Comp. Dt. : 27/03/2023 Status : Completed								
574	23031131	Paediatrics - Ward 308	INTERCOM NO 1346 NOT WORKING	Vivek. A.	instrument handset changed		Kayalvizhi. G. - Paediatrics Ward	28/03/2023
Comp. Dt. : 15/05/2023 Status : Completed								
575	23050576	Paediatrics - Ward 308	INTEROM NO 1346 NOT WORKING	Vivek. A.	puls/ton button changed		Maniyarasi. D. - Paediatrics Ward	15/05/2023
Comp. Dt. : 20/06/2023 Status : Completed								
576	23060736	Paediatrics - Ward 308	INTERCOM NO 1345 NOT WORKING	Vivek. A.	puls/ton button changed		Chitra. P. - Paediatrics Ward	21/06/2023
Dept Name : PHARMACOLOGY - Tele Exchange Comp. Dt. : 16/09/2022 Status : Completed								
577	22090645	Animal House	INTERCOM NO 2045 NOT WORKING	Vivek. A.	cable issue		Panchali. P. - PHARMACOLOGY	06/10/2022
Dept Name : Pharmacy - Tele Exchange Comp. Dt. : 21/02/2023 Status : Completed								
578	23020800	Pay Pharmacy	INTERCOM NO 1089 NOT WORKING - AUDIO PROBLEM	Vivek. A.	new instrument changed		Silambuselman. P. - Pharmacy	21/02/2023
Comp. Dt. : 04/05/2023 Status : Completed								
579	23050145	Free Pharmacy	INTERCOM NO 1037 NOT WORKING	Vivek. A.	two pair cable changed problem solved		Thilagavathi. T. - Pharmacy	05/05/2023
Comp. Dt. : 26/05/2023 Status : Completed								
580	23051071	Free Pharmacy	INTERCOM NO 1037 NOTWORKING	Vivek. A.	instrument changed		Sivabalan. S. - Pharmacy	31/05/2023
Comp. Dt. : 31/05/2023 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
581	23051225	Free Pharmacy	INTERCOM DIAL BUTTON NOT WORKING [NO 3 , 7, 6 & 5]	Vivek. A.	instrument changed problem solved		Thilagavathi. T. - Pharmacy	31/05/2023
Dept Name : Physical Education - Tele Exchange Comp. Dt. : 15/03/2023 Status : Completed								
582	23030621	Boys hostel	INTERCOM NO 2048 NOT WORKING	Vivek. A.	line cord changed problem solved		Vijayakumar. M. - Physical Education	16/03/2023
Comp. Dt. : 08/05/2023 Status : Completed								
583	23050325	Boys hostel	INTERCOM NO 2048 NOT WORKING [ROOM NO 2]	Vivek. A.	two pair cable changed		Vijayakumar. M. - Physical Education	15/05/2023
Comp. Dt. : 23/05/2023 Status : Completed								
584	23050930	Boys hostel	INTERCOM NO 2048 NOT WORKING	Vivek. A.	two pair cable changed problem solved		Vijayakumar. M. - Physical Education	17/07/2023
Dept Name : PHYSIOLOGY - Tele Exchange Comp. Dt. : 10/09/2022 Status : Completed								
585	22090413	College - Physiology	TELEPHONE NOT WORKING (INTERCOM NO 2006)	Vivek. A.	instrument keypad changed problem solved		Shanthini. M. - BIOCHEMISTRY	13/09/2022
Comp. Dt. : 27/01/2023 Status : Completed								
586	23010976	PHYSIOLOGY--COLLEGE	INTERCOM NO 2035 NOT WORKING	Vivek. A.	cable issue		Deepika. V. - PHYSIOLOGY	01/03/2023
Dept Name : PICU & NICU - Tele Exchange Comp. Dt. : 23/05/2022 Status : Completed								
587	22050832	PICU	INTERCOM NO 1141 NOT WORKING	Vivek. A.	puls \ton button adjustment		Kalaivani. N. - EMERGENCY MEDICINE	23/05/2022
Comp. Dt. : 11/06/2022 Status : Completed								
588	22060406	PICU	INTERCOM NO 1141 NOT WORKING	Vivek. A.	line cord problem new line cord changed		Vijayalakshmi. C. - PICU & NICU	14/06/2022
Comp. Dt. : 01/10/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
589	22100005	PICU	INTERCOM NO 1141 NOT WORKING	Vivek. A.	coil cord changed probelm solved		Vijayalakshmi. C. - PICU & NICU	01/10/2022
Comp. Dt. : 26/10/2022 Status : Completed								
590	22100833	PICU	INTERCOM 1141 WIRE NEED TO BE CHANGE	Vivek. A.	coil cord changed probelm solved		Poovathal. K. - PICU & NICU	26/10/2022
Dept Name : POW & SICU - Tele Exchange Comp. Dt. : 24/01/2023 Status : Completed								
591	23010883	POW & SICU	INTERCOM NO 1322 CALLER TONE PROBLEM	Vivek. A.	phone bazzar changed probelm solved		Pragadeesh. V. - POW & SICU	25/01/2023
Comp. Dt. : 03/02/2023 Status : Completed								
592	23020111	POW & SICU	INTERCOM NO 1320 NOT WORKING	Vivek. A.	coil cord changed probelm solved		Valarmathy. K. - POW & SICU	06/02/2023
Comp. Dt. : 16/02/2023 Status : Completed								
593	23020639	SICU	INTERCOM NO-1320,NOT WORKING	Vivek. A.	new instrument changed		Jamuna. K - POW & SICU	17/02/2023
Comp. Dt. : 20/05/2023 Status : Completed								
594	23050836	POW & SICU	INTERCOM NO 1320 NOT WORKING	Vivek. A.	instrument changed problem solved		Jamuna. K - POW & SICU	20/05/2023
Comp. Dt. : 01/06/2023 Status : Completed								
595	23060002	SICU	INTERCOM NO 1320 NOT WORKING	Vivek. A.	line card changed problem solved		Praveena. E. - POW & SICU	01/06/2023
Comp. Dt. : 07/06/2023 Status : Completed								
596	23060220	SICU	INTERCOM NO 1320 AUDIO PROBLEM	Vivek. A.	puls/ton problem solved		Gunavathi. G. - POW & SICU	07/06/2023
Dept Name : Power Laundry - Tele Exchange Comp. Dt. : 09/05/2022 Status : Completed								
597	22050265	LAUNDRY	INTERCOM NO 1056 NOT WORKING	Vivek. A.	port issue port number changed		Manikandan.M - Power Laundry	09/05/2022
Comp. Dt. : 12/12/2022 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
598	22120511	Power Laundry	TELEPHONE NO:1056 NOT WORKING	Vivek. A.	cable issue		Manikandan.M - Power Laundry	17/12/2022
Comp. Dt. : 14/12/2022 Status : Completed								
599	22120639	LAUNDRY	INTERCOM NO 1056 NOT WORKING	Vivek. A.	commercial block to workshope tele phone cable changed		Manikandan.M - Power Laundry	03/01/2023
Comp. Dt. : 21/12/2022 Status : Completed								
600	22120966	LAUNDRY	INTERCOM NO. 1056 NOT WORKING	Vivek. A.	commercial block to workshope telephone cable changed		Manikandan.M - Power Laundry	03/01/2023
Comp. Dt. : 08/03/2023 Status : Completed								
601	23030325	LAUNDRY	INTERCOM NO 1056 NOT WORKING	Vivek. A.	20 pair cable rejoin probelm solved		Manikandan.M - Power Laundry	10/03/2023
Comp. Dt. : 28/03/2023 Status : Completed								
602	23031224	LAUNDRY	INTERCOM NO 1056 NOT WORKING	Vivek. A.	cat 6 cable changed probelm solved		Manikandan.M - Power Laundry	30/03/2023
Dept Name : Quality Department - Tele Exchange Comp. Dt. : 14/06/2022 Status : Completed								
603	22060532	NAC OFFICE 4TH FLOOR	NEED TO CHECK INTERCOM NO 1491 - NOT WORKING NEED URGENT SERVICE	Vivek. A.	port issue port number changed probelm solved		Suganthi. M. - Quality Department	15/06/2022
Dept Name : Radio Diagnosis - Tele Exchange Comp. Dt. : 06/01/2023 Status : Completed								
604	23010258	RADIOLOGY	INTERCOM NO-1545,NOT WORKING PROPERLY(SOUND PROBLEM)	Vivek. A.	line cord changed probelm solved		Jayalakshmi. D. - Radio Diagnosis	06/01/2023
Comp. Dt. : 02/03/2023 Status : Completed								
605	23030098	SCAN - GROUND FLOOR - BLOOD BANK OPP	INTERCOM NO 1092 NOT WORKING	Vivek. A.	line cord jack changed probelm solved		Kanimozhi. D. - Radio Diagnosis	03/03/2023
Comp. Dt. : 02/05/2023								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
606	23050004	RADIOLOGY	INTERCOM NO 1545 NOT WORKING	Vivek. A.	two pair cable changed problem solved		Jayalakshmi. D. - Radio Diagnosis	05/05/2023
Comp. Dt. : 26/06/2023								
Status : Completed								
607	23060983	SCAN - GROUND FLOOR - BLOOD BANK OPP	INTERCOM - RECEIVER BROKEN - NEED TO CHECK OPP	Vivek. A.	hanset and line cord changed		Sudha. D. - Radio Diagnosis	27/06/2023
Dept Name : Reception - Tele Exchange								
Comp. Dt. : 30/06/2022								
Status : Completed								
608	22061122	TB & Chest OPD	INTERCOM NO 1095 NOT WORKING	Vivek. A.	line cord probelm new line cord fixed		Sankari. K. - Reception	30/06/2022
Comp. Dt. : 30/08/2022								
Status : Completed								
609	22081009	Reception	INTERCOM NO 6 [PARALLEL LINE 1079] NOT WORKING	Vivek. A.	line cord problem		Sankari. K. - Reception	30/08/2022
Comp. Dt. : 25/10/2022								
Status : Completed								
610	22100769	Reception	INTERCOM NO:1027 NOT WORKING IN COUNTER NO:10	Vivek. A.	two pair cable changed probelm solved		Sankari. K. - Reception	25/10/2022
Comp. Dt. : 31/10/2022								
Status : Completed								
611	22101034	Reception	INTERCOM NO-1079,NOT WORKING PROPERLY	Vivek. A.	coil cord changed probelm solved		Jayakumar. R. - Reception	31/10/2022
Comp. Dt. : 19/12/2022								
Status : Completed								
612	22120831	CASUALTY RECEPTION	INTERCOM NO. 1079, 1021, 1000, 1041, 1079 NOT WORKING - 5 NOS	Vivek. A.	two pair cable damage new two pair cable laying probelm solved		Karthik. V. - Reception	19/12/2022
Comp. Dt. : 30/12/2022								
Status : Completed								
613	22121349	Reception	INTERCOM 1079 NOT WORKING	Vivek. A.	instrument changed probelm solved		Sankari. K. - Reception	31/12/2022
Comp. Dt. : 29/03/2023								
Status : Completed								
614	23031265	Reception	INTERCOM NO 6 NOT WORKING	Vivek. A.	coil cord changed probelm solved		Jayakumar. R. - Reception	29/03/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 04/05/2023 Status : Completed								
615	23050179	Reception	need to change intercom cable - counter no 9	Vivek. A.	coil cord changed problem solved		Ranjithkumar. P. - Reception	05/05/2023
Comp. Dt. : 23/05/2023 Status : Completed								
616	23050927	CASHCOUNTER IN RECEPTION	INTERCOM NO 1041 NOT WORKING	Vivek. A.	line card and coil card changed		Ranjithkumar. P. - Reception	23/05/2023
Comp. Dt. : 26/05/2023 Status : Completed								
617	23051030	CASHCOUNTER IN RECEPTION	INTERCOM NO 1041 NOT WORKING [SOUND PROBLEM]	Vivek. A.	port number changed probelm solved		Murugan. S. - Reception	26/05/2023
Comp. Dt. : 03/06/2023 Status : Completed								
618	23060096	Reception	EMERGENCY CODE LINE NOT WORKING - NEED URGENT SERVICE	Vivek. A.	two pair cable changed problem solved		Sankari. K. - Reception	03/06/2023
Dept Name : RICU - Tele Exchange Comp. Dt. : 19/07/2022 Status : Completed								
619	22070725	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	INTERCOM NO 1040 - CABLE PROBLEM - NOT WORKING	Vivek. A.	coil cord wire jack changed		Tamililakkiya. K. - RICU	20/07/2022
Comp. Dt. : 05/08/2022 Status : Completed								
620	22080219	RICU	PROBLEM IN INTERCOM CABLE - NEED TO REFIX - INTERCOM NO 1114 -	Vivek. A.	instrument mother bord probelm new instrument fixed		Tamililakkiya. K. - RICU	05/08/2022
Comp. Dt. : 11/01/2023 Status : Completed								
621	23010461	RICU	INTERCOM 1114 WIRE NEED TO BE CHANGE	Vivek. A.	line cord jack refixed		Nanthini. M. - RICU	11/01/2023
Comp. Dt. : 18/01/2023 Status : Completed								
622	23010625	RICU	NEED TO CHANGE INTERCOM CABLE - DAMAGE - NO 1114	Vivek. A.	two pair cable changed probelm solved		Nanthini. M. - RICU	18/01/2023
Comp. Dt. : 18/02/2023								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
623	23020728	RICU	INTERCOM NO 1114 NOT WORKING	Vivek. A.	line cord jack changed		Tamililakkiya. K. - RICU	20/02/2023
Comp. Dt. : 02/05/2023								
Status : Completed								
624	23050066	POW & SICU	INTERCOM CABLE DAMAGE - NEED TO CHANGE - NO 1320	Vivek. A.	line cord changed		Yuvarani. P. - RICU	02/05/2023
Dept Name : Security - SIS - Tele Exchange								
Comp. Dt. : 16/12/2022								
Status : Completed								
625	22120778	Quarters - Staff	INTERCOM NO 2680 NOT WORKING	Vivek. A.	port issue port number changed probelm solved		Murugan. S. - Security - SIS	17/12/2022
Comp. Dt. : 03/05/2023								
Status : Completed								
626	23050117	ICU	INTERCOM NO 1130 NOT WORKING	Padmanaban. G.	instrument changed		Murugesan. M. - Security - SIS	05/05/2023
Dept Name : Skill Lab - Tele Exchange								
Comp. Dt. : 08/06/2023								
Status : Completed								
627	23060293	ICU	INTERCOM NO 1115 NOT WORKING	Vivek. A.	line card jack changed problem solved		Santhiya. P. - Skill Lab	08/06/2023
Dept Name : Special Clinic - Tele Exchange								
Comp. Dt. : 16/05/2022								
Status : Completed								
628	22050539	Reception	INTERCOM NO 1021 NOT WORKING	Vivek. A.	two pair line disconnected pronelm line rejoint probelm solved		Baskar. G. - Special Clinic - Reception	17/05/2022
Comp. Dt. : 13/06/2022								
Status : Completed								
629	22060451	SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	INTERCOM NO 1457 NOT WORKING	Vivek. A.	puls/ton button adjustment probelm solved		Monica Sales. D. - Special Clinic - Office	14/06/2022
630	22060458	Reception	INTERCOM NO 1020 NOT WORKING	Padmanaban. G.	coil cord probelm new coil cord changed		Baskar. G. - Special Clinic - Reception	14/06/2022
Comp. Dt. : 18/06/2022								
Status : Completed								
631	22060688	SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	INTERCOM NO 1456 NOT WORKING	Vivek. A.	line cord + coil cord changed		Divya. K. - Special Clinic - Office	20/06/2022

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 11/07/2022								
Status : Completed								
632	22070438	SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	INTERCOM NO 1457 NOT WORKING	Padmanaban. G.	flc card issue flc card reboot probelm solved		Monica Sales. D. - Special Clinic - Office	12/07/2022
Comp. Dt. : 02/08/2022								
Status : Completed								
633	22080058	SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	INTERCOM NO 1457 NOT WORKING	Vivek. A.	line cord +coil cord changed probelm solved		Kaveri. R. - Special Clinic - Office	03/08/2022
Comp. Dt. : 29/08/2022								
Status : Completed								
634	22080975	SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	INTERCOM NO 1455 - PIN BROKEN	Vivek. A.	line cord jack changed probelm solved		Monica Sales. D. - Special Clinic - Office	29/08/2022
Comp. Dt. : 03/09/2022								
Status : Completed								
635	22090131	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	INTERCOM NO 1098 NOT WORKING - NEED URGENT SERVICE	Vivek. A.	two pair cable disconnected rejoin probelm solved		Ramya. A. V. - Special Clinic	05/09/2022
Comp. Dt. : 15/09/2022								
Status : Completed								
636	22090581	SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	TELEPHONE NO:1456 NOT WORKING	Vivek. A.	line cord changed probelm solved		Divya. K. - Special Clinic - Office	16/09/2022
Comp. Dt. : 03/10/2022								
Status : Completed								
637	22100011	Reception	NEED TO REFIX INTERCOM CABLE FOR NO 3111 - DAMAGE	Vivek. A.	line cord changed probelm solved		Baskar. G. - Special Clinic - Reception	06/10/2022
Comp. Dt. : 08/10/2022								
Status : Completed								
638	22100186	SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	INTERCOM NO. 1457 NOT WORKING	Vivek. A.	FLC card port issue reboot FLC card probelm solved		Kabilan. R. - Special Clinic - Office	10/10/2022
Comp. Dt. : 07/11/2022								
Status : Completed								
639	22110189	CUSTOMER CARE EXECUTIVE-RECEPTION	INTERCOM NO. 3111 NOT WORKING	Vivek. A.	FLC card port issue port chnaged probelm solved		Geetha. J. - Special Clinic - Reception	07/11/2022
Comp. Dt. : 11/11/2022								

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
640	22110452	Reception	INTERCOM 1020 NOT WORKING	Vivek. A.	coil cord changed probelm solved		Geetha. J. - Special Clinic - Reception	11/11/2022
Comp. Dt. : 04/05/2023								
Status : Completed								
641	23050150	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	INTERCOM NO 1098 NOT WORKING [INCOMING , AUDIO PROBLEM]	Vivek. A.	two pair cable changed problem solved		Ramya. A. V. - Special Clinic	10/06/2023
Dept Name : Special Clinic - Dialysis - Tele Exchange								
Comp. Dt. : 05/12/2022								
Status : Completed								
642	22120179	DIALYSIS NEW UNIT IN 1ST FLOOR	INTERCOM 1160 NOT WORKING	Vivek. A.	linee cord changed probelm solved		Swathika. K. - Special Clinic - Dialysis	06/12/2022
Comp. Dt. : 01/02/2023								
Status : Completed								
643	23020002	DIALYSIS NEW UNIT IN 1ST FLOOR	INTERCOM NO 1160 NOT WORKING	Vivek. A.	coil cord changed probelm solved		Swathika. K. - Special Clinic - Dialysis	01/02/2023
Dept Name : Special Clinic - Office - Tele Exchange								
Comp. Dt. : 25/11/2022								
Status : Completed								
644	22111113	SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	INTERCOM 1456 NOT WORKING	Vivek. A.	instrument keypad changed		Divya. K. - Special Clinic - Office	26/11/2022
Comp. Dt. : 20/01/2023								
Status : Completed								
645	23010723	SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	INTERCOM NO 1456 NOT WORKING	Vivek. A.	coil cord changed probelm solved		Divya. K. - Special Clinic - Office	20/01/2023
Comp. Dt. : 17/02/2023								
Status : Completed								
646	23020697	SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	INTERCOM NO 1456 NOT WORKING	Vivek. A.	instrment keypad changed probelm solved		Divya. K. - Special Clinic - Office	17/02/2023
Comp. Dt. : 19/04/2023								
Status : Completed								
647	23040591	SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	INTERCOM NO 1455 NOT WORKING	Vivek. A.	port issue		Monica Sales. D. - Special Clinic - Office	22/04/2023
Comp. Dt. : 18/05/2023								
Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
648	23050745	SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	DIAL BUTTON NO 4 & 7 NOT WORKING	Vivek. A.	new instrument changed		Kalaivani. K. - Special Clinic - Office	18/05/2023
Comp. Dt. : 23/06/2023 Status : Completed								
649	23060858	SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	INTERCOM NO 1457 NOT WORKING	Vivek. A.	line cord changed		Kalaivani. K. - Special Clinic - Office	01/07/2023
Dept Name : Special Clinic - Reception - Tele Exchange Comp. Dt. : 05/12/2022 Status : Completed								
650	22120145	Reception	INTERCOM NO 1008 NOT WORKING	Vivek. A.	two pair cable changed probelm solved		Baskar. G. - Special Clinic - Reception	06/12/2022
Comp. Dt. : 02/03/2023 Status : Completed								
651	23030104	Reception	INTERCOM NO 1020 NOT WORKING	Vivek. A.	line cord changed probelm solved		Baskar. G. - Special Clinic - Reception	03/03/2023
Comp. Dt. : 13/04/2023 Status : Completed								
652	23040420	SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	INTERCOM NO 1456 NOT WORKING	Vivek. A.	coil cord changed problem solved		Savitha. K. - Special Clinic - Reception	15/04/2023
Comp. Dt. : 06/05/2023 Status : Completed								
653	23050227	SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	INTERCOM NO 1456 NOT WORKING	Vivek. A.	coil cord changed problem solved		Savitha. K. - Special Clinic - Reception	06/05/2023
Comp. Dt. : 27/05/2023 Status : Completed								
654	23051074	DIALYSIS NEW UNIT IN 1ST FLOOR	INTERCOM NO 1160 NOT WORKING	Vivek. A.	hanset changed problem solved		Baskar. G. - Special Clinic - Reception	29/05/2023
Dept Name : Special OPD - Tele Exchange Comp. Dt. : 07/12/2022 Status : Completed								
655	22120320	SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	INTERCOM NO 1456 NT WORKING	Vivek. A.	instrument keepad changed probelm solved		Uma Maheswari. D. - Special OPD	08/12/2022
Comp. Dt. : 05/01/2023 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
656	23010223	Reception	INTERCOM 1020 NOT WORKING	Vivek. A.	coil cord changed probelm solved		Uma Maheswari. D. - Special OPD	05/01/2023
Comp. Dt. : 20/04/2023 Status : Completed								
657	23040659	Reception	INTERCOM NO 1020 NOT WORKING [AUDIO PROBLEM]	Vivek. A.	insturemt changed problem solved		Uma Maheswari. D. - Special OPD	22/04/2023
Comp. Dt. : 11/05/2023 Status : Completed								
658	23050438	Reception	INTERCOM NO 3111 NOT WORKING - AUDIO SOUND PROBLEM AT CC COUNTER	Vivek. A.	coil cord changed problem solved		Uma Maheswari. D. - Special OPD	11/05/2023
Comp. Dt. : 17/05/2023 Status : Completed								
659	23050705	Reception	INTERCOM NO 1020NOT WORKING [AUDIO PROBLEM]	Vivek. A.	new instrument changed problem solved		Uma Maheswari. D. - Special OPD	17/05/2023
Dept Name : Special Ward - Tele Exchange Comp. Dt. : 05/05/2022 Status : Completed								
660	22050120	SPECIAL WARD---B	INTERCOM NO 1420 NOT WORKING	Vivek. A.	line cord jack changed		Reena. N. - Special Ward	05/05/2022
Comp. Dt. : 09/05/2022 Status : Completed								
661	22050310	SPECIAL WARD - A1	INTERCOM NO 1400 NOT WORKING	Vivek. A.	line cord jack changed		Manjula. R. - Special Ward	09/05/2022
Comp. Dt. : 12/05/2022 Status : Completed								
662	22050415	Special Ward - A	(1300)PHONE RINING PROBLEM	Vivek. A.	instrument spaker changed probelm solved		Reena. N. - Special Ward	12/05/2022
Comp. Dt. : 17/05/2022 Status : Completed								
663	22050592	SPECIAL WARD - A1	INTERCOM NO 1400 NOT WORKING	Vivek. A.	line cord probelm new line cord fixed		Reena. N. - Special Ward	17/05/2022
Comp. Dt. : 23/05/2022 Status : Completed								
664	22050822	SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	INTERCOM NO 1456 NOT WORKING	Vivek. A.	line cord jack changed coil cord changed probelm solved		hatchayani.N. - Special Ward	23/05/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 15/09/2022								
Status : Completed								
665	22090583	SPECIAL OPD	TELEPHONE NO:1098 NOT WORKING	Vivek. A.	two pair cable changed probelm solved		Elakkiya. S. - Special Ward	16/09/2022
Comp. Dt. : 29/09/2022								
Status : Completed								
666	22091179	Special Ward - C	INTERCOM NO 1424 NOT WORKING	Vivek. A.	phone handset changed probelm solved		Archanadevi. A. - Special Ward	30/09/2022
Comp. Dt. : 30/09/2022								
Status : Completed								
667	22091194	Special Ward - C	INTERCOM NO 1424 NOT WORKING	Vivek. A.	phone handset changed probelm solved		Archanadevi. A. - Special Ward	30/09/2022
Comp. Dt. : 01/10/2022								
Status : Completed								
668	22100002	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	NEED TO REFIX INTERCOM CABLE - NO 1099	Vivek. A.	phone handset changed probelm solved		Sangeetha. C. - Special Ward	01/10/2022
Comp. Dt. : 05/10/2022								
Status : Completed								
669	22100026	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	INTERCOM NO 1098 [DR. RAMYA MADAM ROOM] NOT WORKING	Vivek. A.	line cord changed probelm solved		Elakkiya. S. - Special Ward	07/10/2022
Comp. Dt. : 10/10/2022								
Status : Completed								
670	22100251	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	INTERCOM NO 1040 NOT WORKING - NEED TO CHANGE CABLE	Vivek. A.	line cord changed probelm solved		Elakkiya. S. - Special Ward	10/10/2022
Comp. Dt. : 21/10/2022								
Status : Completed								
671	22100707	Special Ward - C	INTERCOM NO:1424 NOT WORKING	Vivek. A.	two pair cable changed probelm solved		Divya. M. - Special Ward	25/10/2022
Comp. Dt. : 22/11/2022								
Status : Completed								
672	22110897	Special Ward - C	INTERCOM NO 1424 NOT WORKING - AUDIO PROBLEM	Vivek. A.	line cord jack changed probelm solved		Abirami. G. - Special Ward	22/11/2022
673	22110956	Special Ward - C	INTERCOM NO 1424 NOT WORKING - AGAIN AUDIO PROBLEM	Vivek. A.	instrument keypad changed probelm solved		Vijai. M. - Medical Records	23/11/2022
Comp. Dt. : 19/12/2022								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
674	22120841	Special Ward - A	INTERCOM NO. 1366 NOT WORKING IN ROOM NO. 2	Vivek. A.	cable issue		Revathi. S. - Special Ward	30/12/2022
Comp. Dt. : 11/01/2023								
Status : Completed								
675	23010483	SPECIAL WARD -B IN FOURTH FLOOR	INTERCOM 1420 NOT WORKING	Vivek. A.	line cord jack refixed probelm solved		Sangeetha. S. - Special Ward	11/01/2023
Comp. Dt. : 06/02/2023								
Status : Completed								
676	23020195	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	NEED TO REFIX INTER COM CABLE - DAMAGE [INTERCOM NO 1040]	Vivek. A.	line cord changed probelm solved		Elakkiya. S. - Special Ward	06/02/2023
Comp. Dt. : 13/03/2023								
Status : Completed								
677	23030488	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	INTERCOM NO 1040 NOT WORKING	Vivek. A.	port number changed problem solved		Elakkiya. S. - Special Ward	13/03/2023
Comp. Dt. : 14/03/2023								
Status : Completed								
678	23030547	SPECIAL WARD---B	INTERCOM NO 1420 NOT WORKING	Vivek. A.	line cord jack changed problem solved		Suganya. K. - Special Ward	14/03/2023
Comp. Dt. : 04/04/2023								
Status : Completed								
679	23040090	Dialysis	INTERCOM NO 1160 & 1280 [DIALYSIS I & II FLOOR] NOT WORKING	Vivek. A.	coil cord changed		Pushpa. K. - Special Ward	04/04/2023
Comp. Dt. : 11/04/2023								
Status : Completed								
680	23040293	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	DUE TO BITE OF RAT, INTERCOM CABLE DAMAGE NEED TO CHANGE INTERCOM CABLE NO 1040	Vivek. A.	line cord jack changed problem solved		Elakkiya. S. - Special Ward	11/04/2023
Comp. Dt. : 19/04/2023								
Status : Completed								
681	23040589	Paediatrics - Ward 308	INTERCOM NO 1346 NOT WORKING	Vivek. A.	line cord and coil cord changed		Suganya. D. - Special Ward	19/04/2023
Comp. Dt. : 12/05/2023								
Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
682	23050506	SPECIAL CLINIC -100(NEAR FREE PHARMACY)	INTERCOM NO 1098 NOT WORKING	Vivek. A.	two pair cable changed problem solved		Pushpa. K. - Special Ward	10/06/2023
Comp. Dt. : 22/05/2023 Status : Completed								
683	23050869	SPECIAL WARD---B	INTERCOM NO 1420 NOT WORKING	Vivek. A.	line card and coil cord changed problem solved		Sangeetha. S. - Special Ward	22/05/2023
Comp. Dt. : 13/06/2023 Status : Completed								
684	23060467	Special Ward - C	INTERCOM NO 1424 NOT WORKING	Vivek. A.	puls/ton button adjesment problem solved		Divya. M. - Special Ward	14/06/2023
Comp. Dt. : 17/06/2023 Status : Completed								
685	23060622	Paediatrics - Ward 310	INTERCOM NO 1312 NOT WORKING - [FEMALE MEDICAL - 310]	Vivek. A.	coil cord changed probelm solved		Kaviya. M. - Special Ward	19/06/2023
Comp. Dt. : 22/06/2023 Status : Completed								
686	23060816	SPECIAL CLINIC-Ist FLOOR(above Room no. 100)	INTERCOM NO 1455 - CABLE PROBELM - NEED TO CHANGE	Vivek. A.	line cord jack changed		Dhatchayani.N. - Special Ward	22/06/2023
687	23060819	SPECIAL WARD---B	INTERCOM NO 1420 NOT WORKING	Vivek. A.	coil cord changed probelm solved		Sangeetha. S. - Special Ward	24/06/2023
Dept Name : TB & CHEST - Tele Exchange Comp. Dt. : 19/05/2022 Status : Completed								
688	22050706	RMO Office	INTERCOM NO 3188 NOT WORKING	Vivek. A.	100 pair cable disconnected cable rejoin probelm solved		Praveen. R. - TB & CHEST	28/05/2022
Comp. Dt. : 26/12/2022 Status : Completed								
689	22121176	TB & Chest OPD	INTERCOM NO. 1095 NOT WORKING	Vivek. A.	puls/ton button adjesment probelm solved		Kirubasankar. E. - TB & CHEST	28/12/2022
Dept Name : Tele Exchange - Tele Exchange Comp. Dt. : 14/11/2022 Status : Completed								
690	22110530	MEDICAL COLLEGE	INTERCOM 2002 NOT WORKING-SECURITY GAURD	Vivek. A.	two pair cable changed probelm solved		Vivek. A. - Tele Exchange	14/11/2022

Dr. KAGNE. R.N
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 01/12/2022 Status : Completed								
691	22120033	NICU	INTERCOM NO 1277 NOT WORKING	Vivek. A.	puls/8ton channged probelm solved		Vivek. A. - Tele Exchange	01/12/2022
Comp. Dt. : 13/02/2023 Status : Completed								
692	23020492	COMMERCIAL BLOCK	CAMERA NO 11 NOT WORKING	Vivek. A.	poe port changed		Vivek. A. - Tele Exchange	21/02/2023
Comp. Dt. : 05/05/2023 Status : Completed								
693	23050203	Printing Press	cc tv camera 1 no not working	Vivek. A.	poe side jack refixed problem solved		Vivek. A. - Tele Exchange	08/05/2023
Dept Name : Transport - Tele Exchange Comp. Dt. : 26/04/2023 Status : Request Cancel								
694	23040855	Transport	INTERCOM NO 3019 NOT WORKING [AUDIO PROBLEM]	Vivek. A.	port number changed problem solved		Sasikumar. P. - Transport	
Dept Name : Veterinary Science - Tele Exchange Comp. Dt. : 12/05/2023 Status : Completed								
695	23050499	Animal House	INTERCOM NO 2045 NOT WORKING	Vivek. A.	two pair cable changed problem solved		Rajaram. P. - Veterinary Science	15/05/2023
Dept Name : Ward - Tele Exchange Comp. Dt. : 22/05/2023 Status : Completed								
696	23050867	XRay	INTERCOM NO 1516 NOT WORKING AUDIO PROBLEM	Vivek. A.	new instrument fixed		Jerina Begum. P. - Ward	22/05/2023
Dept Name : Work Shop - Tele Exchange Comp. Dt. : 08/06/2022 Status : Completed								
697	22060284	Work Shop	INTERCOM NO 1666 NOT WORKING	Vivek. A.	two pair cable disconnected cable rejoin probelm solved		Pachaimuthusamy. D. - Work Shop	14/06/2022
Comp. Dt. : 26/05/2023 Status : Completed								
698	23051027	Work Shop	INTERCOM NO 1666 NOT WORKING	Vivek. A.	line card changed		Moorthy. L. - Work Shop	27/05/2023


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
College Name : SMVNC Work Type : Complaint Dept Name : Tele Exchange - Tele Exchange Comp. Dt. : 25/06/2022 Status : Completed								
699	22060919	Nursing College	INTERCOM NO 2403 & 2409 NOT WORKING	Vivek. A.	two pair cable changed		JAYASEELAN - SMVNC	01/07/2022
Comp. Dt. : 14/09/2022 Status : Completed								
700	22090565	Nursing College	INTERCOM NO 2400 NOT WORKING	Vivek. A.	line cord changed probelm solved		JAYASEELAN - SMVNC	16/09/2022
Comp. Dt. : 07/11/2022 Status : Completed								
701	22110223	Nursing College	IN THRID FLOOR INTETRCOM NO.2403 AND 2407 NOT WORKING	Vivek. A.	cable issue		RAJARAJESWARI - SMVNC	30/11/2022
Comp. Dt. : 21/12/2022 Status : Completed								
702	22120954	Nursing College	CAMERA NOT WORKING IN 1ST FLOOR	Vivek. A.	cable issue		DHANDAPANI - SMVNC	31/12/2022
Comp. Dt. : 06/01/2023 Status : Completed								
703	23010275	Nursing College	INTERCOM NO-2409 AND 2406 NOT WORKING.AUDIO PROBLEM	Vivek. A.	two pair cable + instrument changed probelm nsolved		RAJARAJESHWARI - SMVNC	30/01/2023
Comp. Dt. : 11/01/2023 Status : Completed								
704	23010459	Nursing College	IN PRINCIPAL ROOM-3071 NOT WORKING	Padmanaban. G.	port number changed probelm solved		DHANDAPANI - SMVNC	12/01/2023
Comp. Dt. : 27/01/2023 Status : Completed								
705	23010949	Nursing College	NEED TO CHECK CC TV CAMERA [NO 10] - NOT WORKING	Vivek. A.	camera jack refixed		RAJARAJESWARI - SMVNC	01/02/2023
706	23010982	Nursing College	INTERCOM NO 2409 NOT WORKING	Vivek. A.	instrument old damage new instrument fixed		RAJARAJESWARI - SMVNC	28/01/2023
Comp. Dt. : 09/02/2023 Status : Completed								


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
707	23020328	Nursing College	INTERCOM NO 2402 NOT WORKING	Vivek. A.	puls/ton button adjiesment probelm solved		KIRUBHA - SMVNC	09/02/2023
Comp. Dt. : 25/04/2023 Status : Completed								
708	23040781	Nursing College	CAMERA NOT WORKING AT PRINCIPAL OFFICE	Vivek. A.	poe side jack refixed problem solved		DHANDAPANI - SMVNC	28/04/2023

College Name : SMVPT
Work Type : Complaint
Dept Name : Tele Exchange - Tele Exchange
Comp. Dt. : 30/09/2022
Status : Completed

709	22091217	Polytechnic college	CCTV CAMERA 2NOS NOT WORKING	Vivek. A.	camera issue		SANTHANAM - SMVPT	31/10/2022


Dr. KAGNE. R.N
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 PUDUCHERRY-605107.