

Sri Manakula Vinayagar Medical College and Hospital

Kalitheerthalkuppam - Pondicherry 605 107.

Maintenance Department - Work Progress Report - 02.01.2017

Date	Name	Designation	Location	In time	Work	Out time	Work Status
02.01.2017	Sundhar Prakash Ramkumar Anandharaj Shankar	Plumber	Special Ward B	8.30 AM	Room No: B17, B18 - fully demolshing and pipe fixing work	4.00 PM	COMPLETED
	Thanushkodi V.Rajendiran	Scavenger	PICU	8.30 AM	Common bathroom block removed	9.30 AM	COMPLETED
			Commercial Complex	10.00 AM	Staff canteen wash basin block removed and canteen chamber block removed	1.00 PM	
			Special Ward B	2.00 PM	Raffees shifting work	4.00 PM	
	Santhosh R.Rajendiran Azhagar Chellaveeran	Plumber	Nursing College	8.30 AM	College back side 4" and 2½" duct fully new line fixing work - Pending	4.00 PM	WIP
	Pandiyaraj Ragul Gandhi Yuvaraj Sharma	Pl. Asst	Nursing College	8.30 AM	College back side 4" and 2½" earth work	1.00 PM	COMPLETED
			Special Ward B	2.00 PM	Cot shifting work from Special ward B to Ward 207	3.00 PM	
			Community Medicine	3.00 PM	Community Medicine dept Baner shifting from Main gate	3.20 PM	
			Microbiology Dept	3.20 PM	Table & water bottle shifting work from General store to Microbiology dept	4.15 PM	

TRUE COPY ATTESTED

DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
MADAGADIPET, PUDUCHERRY-605 107.

Muniyan Durainkannu	Scavenger	New STP	8.30 AM	Waste sludge removed and shifting work	4.00 PM	COMPLETED
		Male Ortho Ward	4.00 PM	Ward 403 - Toilet block removed	4.15 PM	
S.Manikanda n Gopal	Plumber	AP Quarters	2.00 PM	Washbasin sink block removed	2.45 PM	COMPLETED
		Medical College	3.00 PM	Ground floor, 1st floor and 2nd floor - Water cooler filter changed	5.30 PM	
		B Quarters	5.40 PM	Room No:20, Wash basin sink waste coupling changed and Room No:7, Wash basin sink outlet line problem, so new 1½" and 1½" pipe line changed	6.30 PM	
		Polytechnic College	7.00 PM	STP water line block removed	7.50 PM	
Abdhul Azees	Plumber	Hospital B Quarters Boys Hostel Polytechnic College	8.10 AM	RO Plant back wash and operating work	4.00 PM	COMPLETED

Maintenance Department - Work Progress Report - 03.01.2017

Date	Name	Designation	Location	In time	Work	Out time	Work Status
	Prakash Sundhar Ramkumar Anandharaj	Plumber	Boys Hostel	8.30 AM	Hostel terrace water line removed and RO Water line connection line giving work and RO water line new connection fixing work and 1st floor to 4th floor cooler line given work	4.15 PM	COMPLETED
	Azhagar Chellaveeran	Plumber	MIT Ladies Hostel	8.30 AM	1st floor 4" and 2½" pipe line new line fixing work	4.00 PM	COMPLETED

TRUE COPY ATTESTED

DR. S. MANICKAVELU
SRI MANICKAVELU NAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHAKUPPAM,
KADAPADI PET, PUDUCHERRY-605 107.

03.01.2017

Arunagiri Shankar Azees	Plumber	RICU	8.30 AM	Washbasin outlet pipe leakage problem, block removed and leakage arrested, Tap rework	10.00 AM	COMPLETED
		Male Medical Ward	10.15 AM	Ward 301 - Urinal bush cock changed	12.00 PM	
		Casualty	12.00 PM	Common male toilet tap broken, so changed new tap	12.30 PM	
		Biochemistry Lab	12.30 PM	Lab side common male toilet block removed	1.00 PM	
		Ophthal OPD	2.00 PM	Wash basin connection tube leakage problem, so changed new connection tube	2.30 PM	
		Casualty	2.30 PM	Common male toilet -agin tap broken, so changed another new tap 1No and Toilet block removed	3.00 PM	
		Clinical Dept	3.00 PM	Bureau shifting work from Clinical dept to 308	4.15 PM	
Pandiyaraj Sharma V.Rajendiran	Pl. Asst Scavenger	Hospital Outer	8.30 AM	Outer side Telephone dept cable line earth work	4.00 PM	COMPLETED
Dhanushkodi Duraikannu Muniyan	Scavenger	Boys Hostel	8.30 AM	Hostel terrace fungus cleaning work	11.00 AM	COMPLETED
		Animal House	11.10 AM	Waste sludge removed and shifting work	1.00 PM	
		Nursing Hostel	2.00 PM	Hostel back side 6Nos of chamber cleaning work	3.00 PM	
		General Store	3.15 PM	X-Ray paper unloading and shifting work	4.00 PM	
Ragul Thulasi	Pl. Asst	Hospital Outer	8.30 AM	Outer side Telephone dept cable line earth work	1.00 PM	COMPLETED
		OBS Ward	2.00 PM	Ward 207, 208 - Cot shifting ork	3.00 PM	
		Peadiatric Ward	3.00 PM	Bureau shifting work from Clinical dept to 308	4.05 PM	
S.Manikandan	Plumber	Nursing Hostel	2.00 PM	1st floor all toilet 2½" waste water line new connection line making work	4.00 PM	COMPLETED

SRINIVASARAO
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
MADAGADIPET, PUDUCHERRY-605 107.

	Udhaya		VC Sir House	4.30 PM	Went to VC Sir house, for plumbing work	8.00 PM	
	Abdhul Azees	Plumber	Hospital B Quarters Boys Hostel Polytechnic College	8.10 AM	RO Plant back wash and operating work	4.00 PM	COMPLETED

Maintenance Department - Work Progress Report - 04.01.2017

Date	Name	Designation	Location	In time	Work	Out time	Work Status
04.01.2017	Prakash Sundhar Ramkumar	Plumber	D Wing	8.30 AM	Sump motor on and sewage motor removed	10.00 AM	COMPLETED
			TB & Chest Ward	10.15 AM	Ward 405 - Elbow action pillar cock rework	11.00 AM	
			Special Ward A	11.15 AM	3rd floor Room No:7, Wash basin block removed, and bottle trap refixing work	1.00 PM	
			Hospital Terrace	2.00 PM	All door pad lock fixing work - Pending	4.00 PM	WIP
	S.Manikandan Anandharaj	Plumber	VC Sir house	8.30 AM	Went to VC Sir house - for plumbing work	4.00 PM	COMPLETED
	Chellaveeran Santhosh	Plumber	Boys Hostel	8.30 AM	Phase-I, Room No:27, Flush tank not working, so flush tank washer changed and fully rework	9.30 AM	COMPLETED
			Polytechnic College	9.45 AM	Ground floor outer side 1" pipe line changed	1.00 PM	
			A Quarters	2.00 PM	Room No:2, Wash basin pillar cock and angle valve changed and waste outlet line fully rework and wall mixer tap rework	4.00 PM	

TRUE COPY ATTESTED

SEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
MADAGADIPET, PUDUCHERRY-605 107.

Muniasi / Sharma Yuvaraj / Ragul M.Rajendiran	Pl. Asst	Medical College	8.30 AM	150 Nos Table shifting from Medical College to MIT Auditorium	2.00 PM	COMPLETED
	Scavenger	Polytechnic College	2.30 PM	30Nos of Table shifting work	4.00 PM	
Muniyan Duraikannu	Scavenger	Medical College	8.30 AM	150 Nos Table shifting from Medical College to MIT Auditorium	2.00 PM	COMPLETED
		Boys Hostel	2.00 PM	Hostel canteen block removed	3.00 PM	
		Nursing College	3.00 PM	College chamber cleaning work	4.15 PM	
Abdhul Azees	Plumber	Hospital B Quarters Boys Hostel Polytechnic College	8.10 AM	RO Plant back wash and operating work	4.00 PM	COMPLETED

Maintenance Department - Work Progress Report - 07.01.2017							
Date	Name	Designation	Location	In time	Work	Out time	Work Status
	Sundhar Ramkumar Arunagiri Anandharaj V.Rajendiran	Plumber Scavenger	D Wing	8.30 AM	Sump motor on and sewage water removed	10.00 AM	COMPLETED
			Special Ward B	10.00 AM	Room No:B9, B10, B11,B12 - Flush tank rework and water heater refixing work	12.00 PM	
			ICU	12.00 PM	Scrub water leakage problem, waste outlet line rework, leakage arrested	1.00 PM	
			Male Surgery Ward	2.00 PM	Ward 201 - Common bathroom tap leakage problem, so changed tap	3.00 PM	
			OG OT	3.00 PM	Female toilet wash basin block removed and waste outlet line fully rework	4.00 PM	

TRUE COPY ATTESTED

DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
NADAGADIPET, PUDUCHERRY-605 007.

07.01.2017	Prakash Santhosh Azhagar	Plumber	Sunflower Garden	8.30 AM	Water pipe line making new line fixing work	4.00 PM	COMPLETED
	R.Rajendiran Shankar	Plumber	Polytechnic College	8.30 AM	Ground floor toilet fully damaged, so changed new pipe and water line connection given work	4.00 PM	COMPLETED
	Chellaveeran Muniyan	Plumber Scavenger	Medical College - Garden	8.30 AM	2" UPVC waste line warth work and cleaning work	4.00 PM	COMPLETED
	Pandiyaraj Yuvaraj Sharma Kannan	Pl. Asst	Special Ward B	8.30 AM	Cot shifting work from special ward B to Female Ortho ward	10.00 AM	COMPLETED
			Sunflower Garden	10.00 AM	STP waste pipe line earth work	4.00 PM	
	M.Rajendiran Duraikannu	Scavenger	New STP	8.30 AM	Waste sludge removed and shifting work	4.00 PM	COMPLETED
	Abdhul Azees	Plumber	Hospital B Quarters Boys Hostel Polytechnic College	8.10 AM	RO Plant back wash and operating work	4.00 PM	COMPLETED

TRUE COPY ATTESTED

Maintenance Department - Work Progress Report - 09.01.2017

DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHAKUPPAM,
MADAGADIHET, PUDUCHERRY-605 107.

Date	Name	Designation	Location	In time	Work	Out time	Work Status
	Sundhar Ramkumar	Plumber	Villupuram	8.00 AM	Went to MD Sir house for plumbing work	4.00 PM	COMPLETED
			Boys Hostel	8.30 AM	Room No:18, EWC, shower fixing work	12.00 PM	

09.01.2017	S.Manikandan Anandharaj V.Rajendiran	Plumber	Labour Room	12.15 PM	Doctor room flush tank leakage problem, so flush tank washer changed and connection tube changed	1.00 PM	COMPLETED
		Scavenger	TB & Chest OPD	2.00 PM	Towel rod 4No fixing work	3.30 PM	
			Orhto OPD	3.30 PM	Flush tank not working, flush tank fully rework	4.00 PM	
	Chellaveeran Azhagar	Plumber	STP Bond	8.30 AM	Old STP new pipe line fixing and rework the STP Bond	4.00 PM	COMPLETED
	Arunagiri Sivaraja	Plumber	Main Portico	8.30 AM	Portico opposite 4" pipe line removed and grating fixed	1.00 PM	COMPLETED
			F Wing OT's	2.00 PM	6" Rain water line elbow shoe changing work	4.00 PM	
	Thulasi Sharma	Pl. Asst	STP Bond	8.30 AM	Pipe line earth work	4.00 PM	COMPLETED
	Pandiyaraj Yuvaraj Ragul	Pl. Asst	Hospital Outer	8.30 AM	Hospital outer side Telephone cable earth work	4.00 PM	COMPLETED
	M. Rajendiran Duraikannu Dhanushkodi Munivan	Scavenger	Old STP	8.30 AM	Waste sludge removed and sump cleaning work	1.00 PM	COMPLETED
			Animal House	2.00 PM	Waste sludge removed and sump cleaning work	4.00 PM	
	Abdhul Azees	Plumber	Hospital B Quarters Boys Hostel Polytechnic College	8.10 AM	RO Plant back wash and operating work	4.00 PM	COMPLETED

TRUE COPY ATTESTED

DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALTHEERTHALKUPPAM,
MADAGADIPET, PUDUCHERRY-605 107.

Maintenance Department - Work Progress Report - 10.01.2017

Date	Name	Designation	Location	In time	Work	Out time	Work Status
	Sundhar Ramkumar Arunagiri	Plumber	E and F Wing	8.10 AM	E and F wing OT's 1st floor west side 6" rain water line rework	11.45 AM	COMPLETED
			E Wing	11.45 AM	E Wing backside duct 2½" waste pipe line broken, waste pipe line block removed and rework the pipe line - Pending	3.30 PM	WIP
			Special Ward C	3.35 PM	Flush tank leakage problem, so flush tank washer changed and fully rework	4.00 PM	COMPLETED
	Prakash Sivaraja V.Rajendiran	Plumber Scavenger	D Wing	8.30 AM	Sump motor on and sewage water removed	9.30 AM	COMPLETED
			Dialysis Room	9.45 AM	2nd floor Dialysis room - Water cooler filter elbow changed	11.00 AM	
			Casualty	11.10 AM	Casualty common gents toilet urinal waste line 1½" pipe line rework	1.00 PM	
			TB & Chest Ward	2.00 PM	Ward 405 - Toilet block removed, Ward 403 - Floor leakage problem, checking the leakage and A/C dept complaint, so infrom to A/C Incharge	2.45 PM	
			Special Ward B	3.00 PM	3rd floor CT POW Special ward B - Flush tank leakage problem, so changed the flush tank washer and rework	4.00 PM	
	Udhaya Anandharaj Shankar	Plumber	Polytechnic College	8.10 AM	College terrace tank pipe line leakage problem, so changed the pipe line Ground floor and 1st floor - washbasin and urinal pipe line fully rework	4.00 PM	COMPLETED
	Chellaveeran Azhagar	Plumber	Old STP	8.30 AM	Old STP back side garden line work	4.00 PM	COMPLETED
	Ragul		MIT College	8.10 AM	College Principal room bero shifting work	9.30 AM	

TRUE COPY ATTESTED

DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
MADAGADIPET, PUDUCHERRY-605 107.

10.01.2017	Sharma Yuvaraj	Pl. Asst	Old STP	9.45 AM	Telephone cable earth work and Old STP back side garden line earth work	4.00 PM	COMPLETED
	Thulasi Duraikannu	Pl. Asst Scavenger	MIT College	8.10 AM	College Principal room bero shifting work	9.30 AM	COMPLETED
			MRD Dept	9.45 AM	File arrangement work	4.00 PM	
	Dhanushkodi M.Rajendran Munivan	Scavenger	Old STP	8.30 AM	Old STP back side garden line earth work	1.00 PM	COMPLETED
			New STP	2.00 PM	Waste sludge removed and shifting work	4.00 PM	
	Kannan	Pl. Asst	General Store	1.00 PM	Material arrangement work	5.00 PM	COMPLETED
			Campus	5.30 PM	Mosquito machine operating work	7.50 PM	
	S. Manikandan R. Rajendiran	Plumber	Boys Hostel	1.30 PM	Phase-I, Room No:18, Health faucet problem, so changed new health faucet	3.00 PM	COMPLETED
			Medical College	3.10 PM	Ground floor Physiology dept HOD Room toilet - health faucet problem, so changed the new health faucet	4.00 PM	
			Boys Hostel	4.10 PM	Phase-I, Ground floor Dining hall - Water cooler float valve rework and waste line block removed	5.30 PM	
			Free Pharmacy	5.45 PM	Pharmacy opposite Dining area push type Bib cock leakage problem, so changed the 2No Bib cock	6.30 PM	
			A Quarters	6.45 PM	Room No:2, Wash basin leakage problem, so changed the connection tube and extention nipple	7.50 PM	
	Abdhul Azees	Plumber	Hospital B Quarters Boys Hostel Polytechnic College	8.10 AM	RO Plant back wash and operating work	4.00 PM	COMPLETED

TRUE COPY ATTESTED

DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERIMAL KUPPAM,
MADAGABIPET, PUDUCHERRY-605 107.

Maintenance Department - Work Progress Report - 11.01.2017

Date	Name	Designation	Location	In time	Work	Out time	Work Status
	Sundhar	Plumber	E and F Wing	8.30 AM	E and F Wing Center OT's 4th floor pipe line work and 4" sewage pipe line work from scaffolding - Pending	11.00 AM	WIP
			Pondy	11.30 AM	Went to Secretery Sir house for plumbing work - Pending	4.30 PM	WIP
				5.00 PM	Went Pondy City Center - for plumbing work	7.00 PM	COMPLETED
	Arunagiri M.Rajendiran	Plumber Scavenger	E and F Wing	8.30 AM	E and F Wing Center OT's 4th floor pipe line work and 4" sewage pipe line work from scaffolding - Pending	11.00 AM	WIP
				11.15 AM	All wing and all inner staricase padlock fixing and welding removing and old lock demolshing work	1.00 PM	COMPLETED
			Ground floor	2.00 PM	Room No.23, Washbasin elbow action pillar cock handle repairing work	2.40 PM	
			Plastic Surgery OPD	2.45 PM	Ward 223 - 2nd floor EWC flush tank float valve problem, so leakage in flush tank - Pending	4.15 PM	WIP
	Prakash Anandharaj Ramkumar	Plumber	E and F Wing	8.30 AM	E and F Wing Center OT's 4th floor pipe line work and 4" sewage pipe line work from scaffolding - Pending	11.00 AM	WIP
			VC Sir Company	11.10 AM	Went to VC Sir company - RO tank 5000 ltr shifting and tank water line making connection given work -Pending	4.00 PM	COMPLETED
			Old STP	8.30 AM	STP backside garden line ½" pipe line rework	10.00 AM	
			MIT College	10.00 AM	College backside canteen 1¼" pipe line work and 6" waste water line work	11.30 AM	

TRUE COPY ATTESTED

DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHAKUPPAM,
MADAGADIPET, PUDUCHERRY-605 107.

Sri Manakula Vinayagar Medical College and Hospital

Kalitheerthalkuppam -Pondicherry 605 107.

Maintenance Department - Work Progress Report - 02.01.2018

Date	Name	Designation	Location	In time	Work	Out time	Work Status
	Sundhar Prakash Manikandan Ramkumar R.Rajendran	Plumber	B Wing	8.30 AM	Ground floor B Wing Free pharmacy oppposite ladies common toilet 4Nos tap broken, 2Nos dummy fixed and old CP tap 2Nos changed	11.00 AM	COMPLETED
			Special Ward B	11.10 AM	4th floor Special ward B - Room No:4 - Wall mixer tap leakage problem, now rework the tap	11.45 AM	
			Male Surgery Ward	12.00 PM	Ward 204 - EWC Seat cover changed	12.30 PM	
			Dialysis - ICU	12.30 PM	ICU inside dialysis water line filter broken, rework the filter and UPVC materials need so waiting for material	1.00 PM	PENDING - WFM
			E Wing	2.00 PM	E Wing side RO water line broken, so rework the water line	4.00 PM	COMPLETED
	Prakash Ramkumar		Thirubuvanai	2.00 PM	Went to Thirubuvanai Eswari Agencies - Purchase of Taps	4.00 PM	
	Anandharaj Azhagar Shankar	Plumber	Boys Hostel	8.30 AM	Phase-II, 4th floor water cooler filter cleaned and hose rework	10.00 AM	COMPLETED
				10.00 AM	Phase-III, Room No:35 - New Health faucet 1No changed	10.30 AM	
			Old STP	10.30 AM	STP opposite side 2½" water line earth work	12.30 PM	
			MIT Canteen	12.30 PM	Mess inside 1" water line broken, rework the pipe line	1.00 PM	
			Medical College	2.00 PM	Community Medicine dept - exam hall - wash basin elbow rework and block removed	3.30 PM	
			Nursing College	3.30 PM	2HP motor line problem, rework the motor line	4.00 PM	

TRUE COPY ATTESTED

COMPLETED

SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHAL KUPPAM,
MADAGADIPET, PUDUCHERRY-605 107.

02.01.2018

Muniyan Thanushkodi	Scavenger	Special Ward B	8.30 AM	Special Ward B - 4th floor - Wash basin 3Nos block removed	10.00 AM	COMPLETED
		Special Ward C	10.15 AM	Special Ward C - 4rd floor - Male common toilet block rmeoved	11.00 AM	
		D Wing	11.15 AM	D Wing side chamber block removed	12.30 PM	
		Main OT	12.30 PM	Rat dead in OT inside, removed the rat	1.00 PM	
		Special Ward B	2.00 PM	CT POW - Special Ward B - 4th floor - Screen fixing work	3.00 PM	
		Male Medical Ward	3.00 PM	Ward 304 - Toilet block removed	4.00 PM	
Pandiyaraj	Pl. Asst	TV Nallur	8.30 AM	Biomedical waste shifting work from TV Nallur, Villupuram to SMVMCH	1.00 PM	COMPLETED
		Medical College	2.00 PM	Table shifting work from Medical College to MIT Auditorium	4.00 PM	
Yuvaraj Thulasi Kathiresan V.Rajendran	Pl. Asst Scavenger	Medical College	8.00 AM	Table shifting work from Medical College to MIT Auditorium	4.00 PM	COMPLETED
Santhosh Chellaveeran	Plumber	MIT College	8.30 AM	2nd floor waste water removed in toilet	4.00 PM	COMPLETED
		ICU	4.00 PM	ICU inside dialysis water line filter broken, rework the filter, PVC pipe line changed, Filter	8.00 PM	
Valli Poorani Sivagangai	G.Labour	Medical College	8.00 AM	Table shifting work from Medical College to MIT Auditorium	12.00 PM	COMPLETED
		AO Office	12.00 PM	AO Office & MD Office - water can shifting work	1.00 PM	
		Polytechnic College	2.00 PM	Chairs shifting work from Polytechnic College to MIT Auditorium	4.00 PM	

TRUE COPY ATTESTED

DEAN
SRINIVASAN ARULANAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHAKUPPAM,
MADAGADIPET, PUDUCHERRY-605 107.

	Arunagiri	Plumber	Hospital B Quarters Boys Hostel Polytechnic College	8.10 AM	RO Plant back wash and operating work	4.00 PM	COMPLETED
--	-----------	---------	---	---------	---------------------------------------	---------	-----------

Maintenance Department - Work Progress Report - 03.01.2018

Date	Name	Designation	Location	In time	Work	Out time	Work Status
03.01.2018	Sundhar Ramkumar	Plumber	B Wing	8.30 AM	B Wing ground floor east side 1½" pipe line broken, so earth work and pipe line rework	12.00 PM	COMPLETED
			Pondy	12.00 PM	Went to Uruvaiyar company - pipe line broken, earth work and pipe line rework	4.00 PM	
	Arunagiri S.Manikandan Prakash Shankar	Plumber	B Wing	8.30 AM	B Wing ground floor east side 1½" pipe line broken, so earth work and pipe line rework	12.00 PM	COMPLETED
			G Wing	12.00 PM	G Wing south side 2nd floor corridor rain water pipe fixed and wall cutting work	1.00 PM	
			Microbiology Lab	2.00 PM	Wash basin sink swan neck leakage problem, rework the tap and spindle changed	2.30 PM	
			Special Ward A	2.30 PM	3rd floor Special ward A - Room No:4- Wash basin block removed	3.00 PM	
			Free Pharmacy	3.00 PM	Pharmacy opposite side ladies and gents toilet PVC tap 2Nos changed	3.30 PM	
			OBS Ward	3.30 PM	Ward 208 - PVC Tap 2Nos changed and flush tank rework	4.00 PM	
	Pandiaraj Yuvaraj Thulasi Dhanushkodi	Pl. Asst	MIT Auditorium	8.30 AM	Table shifting work from Medical College to MIT Auditorium	4.00 PM	COMPLETED

TRUE COPY ATTESTED

DR. N.
SRIMANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
MADAGADIPET, PUDUCHERRY-605 107.

Muniyan V.Rajendran	Scavenger	Old STP & New STP	8.30 AM	Waste sludge removed and shifting work	2.00 PM	COMPLETED
		MIT College	8.30 AM	College ground floor toilet block removed	4.00 PM	
Sivaraj Chellaveeran	Plumber	AP Quarters	2.00 PM	Room No:33- Water heater fixing work	4.30 PM	COMPLETED
		B Quarters	4.30 PM	Wash basin sink block removed, balcony rain water line fixing work	6.00 PM	
		ICU Dialysis	6.00 PM	ICU dialysis - 1½" water line rework, filter serviced	7.50 PM	
Valli Poorani Sivagangai Renuga Kathiresan	G.Labour Scavenger	SMVEC	8.00 AM	Pavar block loading and unloading work	4.00 PM	COMPLETED
R.Rajendran	Plumber	Hospital B Quarters Boys Hostel Polytechnic College	8.10 AM	RO Plant back wash and operating work	4.00 PM	COMPLETED

Maintenance Department - Work Progress Report - 04.01.2018							
Date	Name	Designation	Location	In time	Work	Out time	Work Status
	Santhosh Azhagar Udhaya Anandharaj	Plumber	MIT College	8.30 AM	College terrace RO Water line work	12.00 PM	COMPLETED
			Old STP	12.00 PM	STP Opposite side 2½" line earth work	1.00 PM	
			Polytechnic College	2.00 PM	Ground floor pipe line rework and lab sink tap rework, 1½" waste line rework	4.00 PM	
			Special Ward B	8.30 AM	Room No:4, 8 - Wall mixer tap changed	12.00 PM	

TRUE COPY ATTESTED

GEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHAL KUPPAM,
MADAGADIPEI, PUDUCHERRY-605 107.

04.01.2018

Sundhar Ramkumar Prakash	Plumber	Guest House	12.00 PM	1st floor Room No:102, 103, 105 - Flush tank full set service and new health faucet 1No changed	1.00 PM	COMPLETED
		Special Ward C	2.00 PM	South side toilet water heater connection tube changed but leakage not arrested, so inform to electrical dept	3.00 PM	
		Female Surgery Ward	3.00 PM	Ward 206 - Treatment room elbow action tap rework	4.00 PM	
	Plumber	CSSD	8.30 AM	Waste water removing motor block removed	10.00 AM	COMPLETED
		SMVEC	10.00 AM	Civil admin dept opposite side motor leakage problem, motor washer changed, leakage arrested	12.00 PM	
		Old STP	12.00 PM	STP Opposite side 2½" line earth work	1.00 PM	
		Hospital - II, III Floor	2.00 PM	2nd and 3rd floor - NABH work	4.00 PM	
	Pl. Asst	Special Ward B	8.30 AM	Scree fixing work	10.45 AM	COMPLETED
		Hospital	11.00 AM	Rolling chair shifting work from ground floor to 4th floor	12.00 PM	
		MIT Auditorium	12.00 PM	Table shifting work from Medical College to MIT Auditorium	4.00 PM	
Muniyan Thanushkodi M.Rajendran	Scavenger	MIT College	8.30 AM	Tank cleaning work	1.00 PM	COMPLETED
		MIT Auditorium	2.00 PM	Table shifting work from Medical College to MIT Auditorium	4.00 PM	
V.Rajendran	Scavenger	MIT College	8.30 AM	Ground floor toilet block removed, 2nd floor gents toilet block removed	1.00 PM	COMPLETED
		MIT Auditorium	2.00 PM	Table shifting work from Medical College to MIT Auditorium	4.00 PM	
Chellaveeran				Room No:3 - Kitchen sink waste house outlet pipe rework, and block removed		

TRUE COPY ATTESTED

DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KARAIKAL, KANNIYAKUMARI
MADAGADIPEL, PUDUCHERRY-605 107.

Unnaveeran Sivaraja	Plumber	AP Quarters	2.00 PM	Room No:46 - Flush tank full set rework and Room No:33 - Wash basin tap rework, spindle changed	8.00 PM	COMPLETED
Valli / Poorani Sivagangai Renuga Kathiresan	G.Labour Scavenger	SMVEC	8.00 AM	Pavar blocks arrangement work	4.00 PM	COMPLETED
Arunagiri	Plumber	Hospital B Quarters Boys Hostel Polytechnic College	8.10 AM	RO Plant back wash and operating work	4.00 PM	COMPLETED

Maintenance Department - Work Progress Report - 05.01.2018

Date	Name	Designation	Location	In time	Work	Out time	Work Status
	Sundhar Shankar	Plumber	Pondy	8.30 AM	Went to Pondy Secretary Sir house for plumbing work	4.00 PM	COMPLETED
	R.Rajendran Manikandan	Plumber	Old STP	8.30 AM	STP near 2½" pipe line broken, so earth work	11.00 AM	WIP - PENDING
			Boys Hostel	11.15 AM	Phase-II, Ground floor water cooler drianage area rework and cooler hose rework	1.00 PM	COMPLETED
			MIT College	2.00 PM	College terrace RO water tank washing work	4.00 PM	WIP - PENDING
			Special Ward A	8.30 AM	Room No:9 - Wash basin block removed, fisher bold broken, so removed the washbasin and fisher bold changed then refixed in wash basin	12.00 PM	

TRUE COPY ATTESTED
 DEAN
 SRINIVASARAO VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 MADRASADIPET, PUDUCHERRY-605 107.

05.01.2018

Prakash Ramkumar	Plumber	Medicine OPD	12.00 PM	Room No:18, 22 - Wall ceiling leaakge problem, go and check the leakage- expansion joint leakage, so inform to civil dept Project Manager	1.00 PM	COMPLETED
		Ortho OT	2.00 PM	Female duty Doctor room toilet health faucet leakage problem, so changed new health faucet	4.00 PM	
Santhosh Azhagar	Plumber	SMVEC	8.30 AM	VC Sir land - 5" pipe line fixed and earth work	4.00 PM	COMPLETED
Anandharaj Udhaya	Plumber	Polytechnic College	8.30 AM	Ground floor IWC removed, 4" pipe line rework then back side in south side earth work	12.30 PM	COMPLETED
		Boys Hostel	12.30 PM	Phase-II, Room No:20 - Helath faucet broken, so changed new helath faucet	1.00 PM	
		Basket Ball Ground	2.00 PM	Garden line 1½" pipe line broken, so dummy fixed	4.00 PM	
Pandiaraj Yuvaraj Thulasi V.Rajendran	Pl. Asst	SMVEC	8.20 AM	Pavar block fixing work and sand shifting work	12.00 PM	WIP - PENDING
		Basement Auditorium	12.00 PM	MS Madam retirement function, so function arrangement work	4.00 PM	COMPLETED
Muniyan M.Rajendran	Scavenger	Male Medical Ward	8.30 AM	Ward 301, 302 - Common toilet block removed	9.30 PM	COMPLETED
		Male Ortho Ward	9.30 AM	Ward 404 - Wash basin block removed	10.00 AM	
		MIT College	10.15 AM	Tank cleaning work and sand, jally and pavar block shifting to college ground floor to terrace	4.00 PM	
						TRUE COPY
Chellaveeran Sivaraja Kannan	Plumber	Nursing College	2.30 PM	2nd floor tap broken, so changed the new PVC Tap	4.30 PM	COMPLETED
		Bio Gas Plant	4.30 PM	Water line fixing work	6.00 PM	
	Pl. Asst	Ladies Hoste 1	6.00 PM	Phase-I, Room No:36 - Tap water leakage problem, so tap spindle changed, leakage arrested, Kannan- Fogging machine operating work	8.00 PM	

SEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
SANTHEERTHALKUPPAM,
MADRAS-605 107.

Valli / Poorani Sivagangai Renuga Kathiresan	G.Labour	Special Ward B	8.30 AM	Screen removing work	12.00 PM	COMPLETED
	Scavenger	AO Office & MD Office	12.00 PM	Water can shifting work	1.00 PM	
		Special Ward C	2.00 PM	Screen fixing work	4.00 PM	
Arunagiri	Plumber	Hospital B Quarters Boys Hostel Polytechnic College	8.10 AM	RO Plant back wash and operating work	4.00 PM	COMPLETED

Maintenance Department - Work Progress Report - 06.01.2018

Date	Name	Designation	Location	In time	Work	Out time	Work Status
06.01.2018	Prakash Ramkumar	Plumber	Paediatric Ward	8.30 AM	Ward 307- Tap broken, so changed new tap, Ward 308 - Flush tank rework	9.30 AM	COMPLETED
			Guest House	9.30 AM	Guest house chamber block removed	11.00 AM	
			VC Sir House	11.00 AM	Went to VC Sir house for all plumbing fittings checking and tank cleaning work	1.00 PM	
			Biochemistry Lab	2.00 PM	Biochemistry lab wash basin sink waste outlet line rework	2.30 PM	
			OG OPD	2.30 PM	OG OPD - wash basin waste outlet line rework	3.00 PM	
			Male Surgery Ward	3.00 PM	Ward 204 - Elbow action tap leakage problem, tap spindle changed	4.00 PM	
	S.Manikanda n R.Rajendran	Plumber	MIT College	8.30 AM	College terrace tank line fixing work	4.00 PM	WIP - PENIDNC
	Santhosh Anandharaj Azhagar	Plumber	Old STP	8.30 AM	STP near 2½" pipe line broken, so earth work	1.00 PM	COMPLETED
			Polytechnic College	2.00 PM	Ground floor EWC removed, 4" pipe line rework then back side in south side earth work	4.00 PM	

TRUE COPY ATTESTED

DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
MADAGADIPET, PUDUCHERRY-605 107.

06.01.2018

V.Rajendran Kathiresan Muniyan	Scavenger	New STP & OLD STP	8.30 AM	Waste sludge removed and shifting work	11.00 AM	COMPLETED
		VC Sir House	11.00 AM	Went to VC Sir house - tank cleaning work	1.00 PM	
		OG OPD	2.00 PM	OG OPD - wash basin block removed	3.00 PM	
		Boys Hostel	3.00 PM	Phase-II, 4th floor toilet block removed	4.00 PM	
M.Rajendran Yuvaraj	Scavenger Pl. Asst	SMVEC	8.30 AM	Pavar block loading and unloading work	4.00 PM	COMPLETED
Valli / Poorani Sivagangai Renuga	G.Labour	SMVEC	8.00 AM	Sand loading and unloading work	4.00 PM	COMPLETED
Arunagiri	Plumber	Hospital B Quarters Boys Hostel Polytechnic College	8.10 AM	RO Plant back wash and operating work	4.00 PM	COMPLETED

Maintenance Department - Work Progress Report - 08.01.2018

Date	Name	Designation	Location	In time	Work	Out time	Work Status
	Sundhar Sivaraja Shankar	Plumber	Pondy	8.30 AM	Went to Pondy Secretary Sir house for plumbing work (1 Floor towel rod and soap dish fixed and all taps cleaning work)	4.00 PM	COMPLETED
	R.Rajendran Manikandan	Plumber	OG OPD	8.30 AM	Wash basin connection tube rework and waste hose rework	9.30 AM	COMPLETED
			AP Quarters & Boys Hostel	9.30 AM	RO Plant back wash and operating work	12.00 PM	

S. R. SIVAGANESH
 DEPUTY CHIEF ENGINEER
 MAINTENANCE DEPARTMENT
 KALITHEERTHAL KUPPAM,
 PUDUCHERRY-605 007.

08.01.2018	Prakash		Male Surgery Ward	12.15 PM	Ward 203 - Aquaguard water filter changed	1.00 PM	
			TB & Chest ward	2.00 PM	Ward 405 - Wash basin clamp checking work	4.00 PM	
	Udhaya Anandharaj	Plumber	Ladies Hostel	8.20 AM	Phase-II, Ground floor float valve changed, 3rd floor toilet wash basin block removed	11.45 AM	COMPLETED
				12.00 PM	Phase-I, Room No:59 - Flush tank full set rework	1.00 PM	
			Boys Hostel	2.00 PM	Phase-II, 3rd floor urinal pipe line fully rework	4.00 PM	
	Dhanushkodi V.Rajendran M.Rajendran Duraikannu	Scavenger	Old STP & New STP	8.30 AM	Waste sludge removed and shifting work	1.00 PM	COMPLETED
			Medical College	2.00 PM	Table shifting work from Medical college to MIT College	4.00 PM	
	Pandiaraj Thulasi	Pl. Asst	TV Nallur	8.30 AM	Biowaste shifting work from TV Nallur and Villupuram to SMVMCH	1.00 PM	COMPLETED
			Medical College	2.00 PM	Table shifting work from Medical college to MIT College	4.00 PM	
	Valli / Poorani Sivagangai Renuga Muniyan	G.Labour	SMVEC	8.30 AM	Sand filling work in Road at SMVEC	4.00 PM	COMPLETED
		Scavenger					
	Arunagiri	Plumber	Hospital B Quarters Boys Hostel Polytechnic College	8.10 AM	RO Plant back wash and operating work	4.00 PM	COMPLETED

TRUE COPY ATTESTED
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 MADHURAI, PUDUCHERRY-605 107.

Maintenance Department - Work Progress Report - 09.01.2018							
Date	Name	Designation	Location	In time	Work	Out time	Work Status

Sri Manakula Vinayagar Medical College and Hospital

Kalitheerthalkuppam -Pondicherry 605 107.

Maintenance Department - Work Progress Report - 02.01.2020

Date	Name	Designation	In time	Out time	Location	Work	Work Status
02.01.2020	Prakash Shankar Abdhul Azees Chellaveeran	Plumber	8.30 AM	4.00 PM	D Wing	D Wing near waste water removed and motor block removed	COMPLETED
					Clinical Dept	4th floor Clinical dept - Room No:5 - Flush tank full set rework	
					Septic Room	3rd floor Septic Room - CP Angle valve broken, rework the angle cock	
					NS Rom	NS Room toilet - block removed, wash basin waste water outlet line rework	
	Arunagiri R.Rajendran	Plumber	8.30 AM	4.00 PM	Polytechnic College	I Floor toilet - floor breaking work, IWC 2Nos new fixing work purpose	WIP - PENDING
	Udhaya Anandharaj	Plumber	8.30 AM	4.00 PM	MIT College	Ground floor, I Floor- Bathroom fittings old removed, new fittings changed	COMPLETED
	Azhagar	Plumber	1.30 PM	8.00 PM	Ladies Hostel	Phase-I, Dining hall water not coming, all tap air lock released and rework the tap	COMPLETED
					Hospital	RO Plant operating work	
	Pandiaraj/ Thulasi Yuvaraj / Senthil / Murali / Prakash	Pl.Asst	8.30 AM	4.00 PM	MIT College	Table shifting work and scaffolding work	COMPLETED
					MIT Auditorium	Exam hall table shifting work	

TRUE COPY ATTESTED

DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
MADAGADIPET, PUDUCHERRY-605 107.

Lakshmanan Sivagangai				JR Quarters	Quarters opposite concrete block broken, removed the raffees and shifted to	
Thanushkodi Nadhamani V.Rajendran	Scavenger	8.30 AM	4.00 PM	Old STP & New STP	Waste sludge removed and shifting work	COMPLETED
				Bio gas plant	Food waste collect in all hostels and canteens and grinding work	
				MIT Ladies Hostel	I floor, 3rd floor - bathroom block removed	
				AP Quarters	Room No:15 - Kitchen sink waste line block removed	
				Ladies Hostel	Phase-I, outer side chamber block removed	
				MIT College	I Floor common toilet block removed	
Santhosh	Plumber	8.30 AM	4.00 PM	Hospital B Quarters Boys Hostel Medical College	RO Plant operating work	COMPLETED

Maintenance Department - Work Progress Report - 03.01.2020

Date	Name	Designation	In time	Out time	Location	Work	Work Status
	Prakash Shankar Abdhul Azees Chellaveeran	Plumber	8.30 AM	4.00 PM	D Wing	D Wing near waste water removed and motor block removed	COMPLETED
					Clinical Dept	4th floor Clinical dept - Room No:5 - Flush tank full set rework	
					Septic Room	3rd floor Septic Room - CP Angle valve broken, rework the angle cock	

TRUE COPY ATTESTED

DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
MADAGADIPET, PUDUCHERRY-605 007.

03.01.2020					NS Rom	NS Room toilet - block removed, wash basin waste water outlet line rework	
	Arunagiri R.Rajendran	Plumber	8.30 AM	4.00 PM	Polytechnic College	I Floor toilet - floor breaking work, IWC 2Nos new fixing work purpose	WIP - PENDING
	Udhaya Anandharaj	Plumber	8.30 AM	4.00 PM	MIT College	Ground floor, I Floor- Bathroom fittings old removed, new fittings changed	COMPLETED
	Azhagar	Plumber	1.30 PM	8.00 PM	Ladies Hostel	Phase-I, Dining hall water not coming, all tap air lock released and rework the tap	COMPLETED
					Hospital	RO Plant operating work	
	Pandiaraj/ Thulasi Yuvaraj / Senthil / Murali / Prakash Lakshmanan Sivagangai	Pl.Asst	8.30 AM	4.00 PM	MIT College	Table shifting work and scaffolding work	COMPLETED
					MIT Auditorium	Exam hall table shifting work	
					JR Quarters	Quarters opposite concrete block broken, removed the raffees and shifted to	
	Thanushkodi Nadhamani V.Rajendran	Scavenger	8.30 AM	4.00 PM	Old STP & New STP	Waste sludge removed and shifting work	COMPLETED
				Bio gas plant	Food waste collect in all hostels and canteens and grinding work		
				MIT Ladies Hostel	I floor, 3rd floor - bathroom block removed		
				AP Quarters	Room No:15 - Kitchen sink waste line block removed		

TRUE COPY ATTESTED

SRINIVASAN VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
MADAGADIPET, PUDUCHERRY-605 107.

					Ladies Hostel	Phase-I, outer side chamber block removed	
					MIT College	I Floor common toilet block removed	
	Santhosh	Plumber	8.30 AM	4.00 PM	Hospital B Quarters Boys Hostel Medical College	RO Plant operating work	COMPLETED

Maintenance Department - Work Progress Report - 04.01.2020

Date	Name	Designation	In time	Out time	Location	Work	Work Status
	Prakash Shankar Abdhul Azees Chellaveeran	Plumber	8.30 AM	4.00 PM	D Wing	D Wing near waste water removed and motor block removed	COMPLETED
					Clinical Dept	4th floor Clinical dept - Room No:5 - Flush tank full set rework	
					Septic Room	3rd floor Septic Room - CP Angle valve broken, reowrk the angle cock	
					NS Rom	NS Room toilet - block removed, wash basin waste water outlet line rework	
	Arunagiri R.Rajendran	Plumber	8.30 AM	4.00 PM	Polytechnic College	I Floor toilet - floor breaking work, IWC 2Nos new fixing work purpose	WIP - PENDING
	Udhaya Anandharaj	Plumber	8.30 AM	4.00 PM	MIT College	Ground floor, I Floor- Bathroom fittings old removed, new fittings changed	COMPLETED

TRUE COPY ATTESTED

DEAN
SRI MANAKULAVINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
MADAGADIPET, PUDUCHERRY-605 107.

04.01.2020							
	Azhagar	Plumber	1.30 PM	8.00 PM	Ladies Hostel	Phase-I, Dining hall water not coming, all tap air lock released and rework the tap	COMPLETED
					Hospital	RO Plant operating work	
	Pandiaraj/ Thulasi Yuvaraj / Senthil / Murali / Prakash Lakshmanan Sivagangai	Pl.Asst	8.30 AM	4.00 PM	MIT College	Table shifting work and scaffolding work	COMPLETED
					MIT Auditorium	Exam hall table shifting work	
					JR Quarters	Quarters opposite concrete block broken, removed the raffees and shifted to workshon side	
	Thanushkodi Nadhamani V.Rajendran	Scavenger	8.30 AM	4.00 PM	Old STP & New STP	Waste sludge removed and shifting work	COMPLETED
					Bio gas plant	Food waste collect in all hostels and canteens and grinding work	
				MIT Ladies Hostel	I floor, 3rd floor - bathroom block removed		
				AP Quarters	Room No:15 - Kitchen sink waste line block removed		
				Ladies Hostel	Phase-I, outer side chamber block removed		
				MIT College	I Floor common toilet block removed		
Santhosh	Plumber	8.30 AM	4.00 PM	Hospital B Quarters Boys Hostel Medical College	RO Plant operating work	COMPLETED	

TRUE COPY ATTESTED

DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
MADAGADIPET, PUDUCHERRY-605 107.

Maintenance Department - Work Progress Report - 06.01.2020

Date	Name	Designation	In time	Out time	Location	Work	Work Status
06.01.2020	Prakash Manikandan Abdhul Azees	Plumber	8.20 AM	4.00 PM	D Wing	Sump waste water removed, motor block removed	COMPLETED
					Special Ward C	4th floor Special ward C - Toilet Tap broken, changed the new tap	
					Paediatric OPD	OPD backside RO plant tap leakage problem, tap rework	
					D Wing	Motor shifting to basement sump	
	Ramkumar	Plumber	8.30 AM	4.00 PM	Thirubuvana i	Went to Thirubuvana i Eswari Agencies for purchase of plumbing materials	COMPLETED
	Azhagar Arunagiri Anandharaj	Plumber	8.30 AM	4.00 PM	Nursing College	College tank line valve leakage changing work	COMPLETED
					Polytechnic College	Tank line fixing work	
					Nursing College	In terrace rain water line wall broken, make hole and pipe fixing work	
	Pandiaraj / Thulasi / Senthil / Murali / Prakash/ yuvaraj Lakshmanan	Pl.Asst	8.30 AM	4.00 PM	Hospital Canteen	Rice bag loading and unloading work	COMPLETED
					Nursing College	College opposite side hollow block bricks removed and sand shifting work	
					Polytechnic College	College 2nd floor toilet floor broken, wastage shifting work	
	Thanushkodi	Scavenger			Old STP & New STP	Waste sludge removed and shifting work	
					Bio gas plant	Food waste collect in all hostels and canteens and grinding work	

TRUE COPY ATTESTED

DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE HOSPITAL
KALITHEER
MADAGADIPET, PUDUCHERRY-605 107.

V.Rajendran Nathamani	Scavenger	8.30 AM	4.00 PM	Pondy	Rajendran went to Pondy Secretary Sir house for chamber block removed	COMPLETED
				Nursing College	College backside chamber block removed, Ground floor gents toilet urinal line block removed	
Santhosh	Plumber	8.30 AM	4.00 PM	Hospital B Quarters Boys Hostel Medical College	RO Plant operating work	COMPLETED

Maintenance Department - Work Progress Report - 07.01.2020							
Date	Name	Designation	In time	Out time	Location	Work	Work Status
	Prakash Ramkumar Shankar	Plumber	8.20 AM	4.00 PM	General Medicine OPD	Room No:47 - Wash basin block removed and waste coupling, bottle trap changed	COMPLETED
					Paediatric Ward	Ward 308 - Water heater tap leakage problem, tap rework, leakage arrested	
					Male Surgery Ward	Ward 203 - Urinal line broken, rework the line and refixed	
					D Wing	Gents common toilet urinal angle valve changed	
					CSSD	Waste water removing motor block removed, 1.1/4" pipe line rework	
					Nursing College	I Floor bathroom - wash basin fixed, 2nd floor - ladies toilet and gents toilet flush tank leakage, rework	

TRUE COPY ATTESTED

DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHAL KUPPAM,
MADAGADI PET, PUDUCHERRY-605 107.

07.01.2020	Arunagiri Chellaveeran	Plumber	8.30 AM	4.00 PM	Boys Hostel	Phase-III, Room No:7 - health faucet set fixed, Phase-II, 3rd floor - Bthroom pipe line rework, new tap changed	COMPLETED
					Ladies Hostel	Phase-II, hostel backside 4" pipe line rework	
					Medical College	Community medicine dept - lecturer hall - wash basin fixing work	
	Anand Udhaya	Plumber	1.30 PM	8.00 PM	Old STP	10HP motor suction line fully rework	COMPLETED
					New STP	STP plant motor bolt and nut refixed	
					D Wing	Waste water removed and motor block removed	
					Hospital	RO Plant operating work	
	Pandiaraj /Thulasi Yuvaraj / Murali Lakshmanan / Senthil / Kannan / Prakash Sivagangai	Pl.Asst	8.30 AM	4.00 PM	AP Quarters	Quarters side sand filling work	COMPLETED
					Printing Press	Paper bundle loading and unloading work, Diary and file shifting work from press to general store	
					Special Ward B	4th floor Special ward B - Screen removing work	
					Paediatric Ward	Bero shifting work from Ward 309 to workshop	
					Paediatric OPD	Table, bero shifting work from another room	
					Medical College	Community medicine dept - lecturer hall - wash basin shifting work	
					Villupuram	Biowaste shifting work from TV Nallur, Villupuram to SMVMCH	
	V.Rajendran	Scavenger			Old STP & New STP	Waste sludge removed and shifting work	
					Bio gas plant	Food waste collect in all hostels and canteens and grinding work	
					Ladies Hostel	Phase-II, 1st, 4th floor -Common toilet block removed	

TRUE COPY ATTESTED

TRUE COPY ATTESTED

TRUE COPY ATTESTED

DR. ANAND V. NAYAGAR
SRINIVASAN V. NAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHAL KUPPAM,
MADAGADIPET, PUDUCHERRY-605 107.

Thanushkodi Nadhamani	Scavenger	8.30 AM	4.00 PM	Medical College	Ground floor gents toilet block removed, Community medicine dept - lecturer hall - wash basin block removed	COMPLETED
				MIT Ladies Hostel	4th floor common toilet block removed	
				B.Ed College	Ground floor gents toilet block removed	
Abdhul Azees	Plumber	8.30 AM	4.00 PM	B Quarters Boys Hostel Medical College Hospital	RO Plant operating work	COMPLETED

Maintenance Department - Work Progress Report - 08.01.2020

Date	Name	Designation	In time	Out time	Location	Work	Work Status
	Prakash Ramkumar	Plumber	8.30 AM	4.00 PM	Villupuram	Went to Villupuram Chairman sir house and villupuram health centre for plumbing work	COMPLETED
	Azhagar Anandharaj	Plumber	8.30 AM	4.00 PM	JR Quarters	Water cooler shifting work and pipe line changing work	COMPLETED
					Ladies hostel	Phase-II, Hostel backside 4" pipe line block, pipe cutting and block removed, rejoint the pipe line	
					Nursing College	College backside 4" drianage line outer elbow broken, rework the pipe line and elbow changed	
					Polytechnic College	College backside 4" drianage line broken, rework the pipe line and rejoint	

TRUE COPY ATTESTED

DEAN
SRI MANAKULAVINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHAKUPPAM,
MADAGADIPET, PUDUCHERRY-605 107.

08.01.2020	Arunagiri Udhaya	Plumber	8.30 AM	4.00 PM	Medical College	Old bore pipe cutting and removing work	COMPLETED
					Nursing College	College backside 4" drianage line outer elbow broken, rework the pipe line and elbow changed	
	Chellaveeran Gopal	Plumber	1.30 PM	8.00 PM	Nursing College	College backside 4" drianage line outer elbow broken, rework the pipe line and elbow changed, 2.1/2" Tee changed	COMPLETED
					D Wing	D Wing side waste water removed, motor block removed and RO plant operating work	
	Pandiaraj/ Thulasi Yuvaraj / Senthil / Murali / Prakash Lakshmanan Sivangamai	Pl.Asst	8.30 AM	4.00 PM	SMVEC	Went to SMVEC - Roller machine loading to lorry	COMPLETED
					Nursing College	All bathroom duct waste materials and broken, bricks sands removing work	
					Polytechnic College	College side sand, brocks removing work	
					MIT College	In terrace Rope shifting to nurisng college terrace	
					Pump House	Box pipes and sand removing work	
	Thanushkodi Nadhamani V.Rajendran	Scavenger	8.30 AM	4.00 PM	Old STP & New STP	Waste sludge removed and shifting work	COMPLETED
					Bio gas plant	Food waste collect in all hostels and canteens and grinding work	
					Nursing College	College side champer cleaning work	
					Polytechnic College	I floor toilet block removed, 4th floor - floor breaking, waste materials shifting work	
					Nursing College	Chamber lid shifting from polytechnic to nursing college	

TRUE COPY ATTESTED

SEEN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHAL KUPPAM,
MADAGADI PET, PUDUCHERRY-605 107.



Sri Manakula Vinayagar Medical College and Hospital

Complaint Status Report From 01-01-2020 To 31-12-2022

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
College Name : SMVMCH-HOS								
Work Type : Complaint								
Dept Name : Administration - Civil - Maintenance								
Comp. Dt. : 20/01/2020								
Status : Completed								
1	20010485	AO Office	TAP BROKEN - WATER LEAKAGE AT WASHING AREA	Rajendran. R.	Wrong complaint, 3rd floor 6" pipe line leakage problem in POW, floor breaking and pipe line rework		Karthik. K. - Administration	21/01/2020
Comp. Dt. : 22/02/2020								
Status : Completed								
2	20020846	AO Office	GENTS REST ROOM GUN NOT WORKING - WATER FLOW	Prakash. V.	Health faucet rework, work completed		Kadhiravan. C. - Administration	22/02/2020
Comp. Dt. : 26/03/2020								
Status : Completed								
3	20030782	Dialysis	TAP BROKEN WATER LEAKAGE - BACKSIDE OF DIALYSIS	Prakash. V.	1.1/2" pipe line broken, door elbow changed, rework the pipe line, problem solved		Gomathy. K. - Administration	26/03/2020
Comp. Dt. : 11/06/2020								
Status : Completed								
4	20060317	AO Office	IN REST ROOM-BAD SMELL PROBLEM	Prakash. V., Arunagiri. V., Ramkumar. R.	Pipe line broken, rework the pipe line, work completed		Karthik. K. - Administration	11/06/2020
Comp. Dt. : 22/06/2020								
Status : Completed								
5	20060620	AO Office	HAND SHOWER NOT WORKING AT FEMALE REST ROOM	Manikandan. S.	Health faucet full set rework, work completed		Kanimozhi. D. - Administration	22/06/2020
Comp. Dt. : 24/06/2020								
Status : Completed								
6	20060672	AO Office	WATER COOLER LEAKAGING PROBLEM	Prakash. V.	A/C dept complaint, Hot & Cold machine new drain line to be fixing work, so msg forward to A/C dept		Gomathy. K. - Administration	24/06/2020

TRUE COPY ATTESTED

DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHAKUPPAM,
MADAGADIPEI, PUDUCHERRY-605 102.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 27/06/2020 Status : Completed								
7	20060760	Dining Hall	WATER LEAKAGE AT GROUND FLOOR RECEPTION BACKSIDE DINING HALL	Prakash. V.,Ramkumar. R.,Manikandan. S.	4" pipe line 1 length changed, leakage arrested, but A/C drain line leakage problem, inform to Mr.Ra		Sathiyamoorthy. D. - Administration	04/07/2020
Comp. Dt. : 04/07/2020 Status : Completed								
8	20070090	AO Office	BACKSIDE WASHING AREA TAP REPAIR - NEED TO CHANGE	Prakash. V.,Abdul Azees. J.,Sellaveeran. M.	Backside water Pipe line refixed in properly, leakage arrested, work completed		Gomathy. K. - Administration	06/07/2020
Comp. Dt. : 17/07/2020 Status : Completed								
9	20070409	AO Office	NEED REPAIRING WORK FOR TAP - BROKEN AT BACKSIDE WASHING AREA	Prakash. V.	Pipe line rework and clamp fixed, work completed		Lester. Rodgers - Civil - Maintenance	20/07/2020
Comp. Dt. : 10/09/2020 Status : Completed								
10	20090183	AO Office	water not coming-1136	Prakash. V.,Rajendran. R.,Ramkumar. R.	POW to be ready in covid ward purpose, 8 nos of bathroom plumbing fittings fixed, so valve closed, a		Karthik. K. - Administration	12/09/2020
Comp. Dt. : 18/09/2020 Status : Completed								
11	20090354	AO Office	WASH BASIN SINK LEAKAGING PROBLEM IN DINING HALL	Abdul Azees. J.,Rajendran. R.,Prakash. V.	Wash basin waste line fully rework, work completed		Gomathy. K. - Administration	19/09/2020
Comp. Dt. : 25/09/2020 Status : Completed								
12	20090523	AO Office	wash basin sink waste line leaking problrm	Ramkumar. R.	1.1/4" Waste line fully rework, work completed, work completed		Gomathy. K. - Administration	26/09/2020
Comp. Dt. : 03/12/2020 Status : Completed								
13	20120117	AO Office	RAINWATER PIPE LINE BROKEN - WATER FLOW - BACK SIDE OF AO OFFICE - NEED URGENT SERVICE	Prakash. V.,Sellaveeran. M.,Sankar. V.	2nd floor Dialysis backside sunshade rain water water stagnation, water removed and cleaned that pla		Kadhiravan. C. - Administration	03/12/2020

TRUE COPY ATTESTED
19/09/2020
CLEAN
SRIMANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
MADAGADIPEI, PUDUCHERRY-605 007.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 07/12/2020 Status : Completed								
14	20120292	AO Office	RAIN WATER LEAKAGE AT BACK SIDE OF WASHING AREA - NEED URGENT SERVICE	Prakash. V.,Manikandan. S.,Rajendran. R.	Due to heavy rain, 6" pipe line rework, leakage arrested, work completed		Gomathy. K. - Administration	10/12/2020
Comp. Dt. : 09/12/2020 Status : Completed								
15	20120386	AO Office	FLUSH WATER NOT COMING AT REGISTRAR RESTROOM - NEED URGENT SERVICE	Prakash. V.	Flush tank full set rework, float washer changed, work completed		Kanimozhi. D. - Administration	09/12/2020
Comp. Dt. : 09/01/2021 Status : Completed								
16	21010335	AO Office	NEED CLEANING WORK FOR RECORD ROOM [RAT DEATH]	Rajendhiran. V.	Dead rat removed, cleaned that place		Elumalai.K.A. - Administration	09/01/2021
Comp. Dt. : 11/01/2021 Status : Completed								
17	21010381	AO Office	NEED CLEANING WORK FOR FALSE CEILING AT RECORD ROOM [RAT DEATH] NEED URGENT SERVICE	Arunagiri. V.,Rajendhiran. V.,Thanuzkodi. E	Our technician check that place, we are not found the rat, msg forward to A/C dept and workshop		Elumalai.K.A. - Administration	11/01/2021
Comp. Dt. : 12/02/2021 Status : Completed								
18	21020469	AO Office	MALE REST ROOM BLOCK	Rajendhiran. V.	Toilet block removed, work completed on that day		Kadhiravan. C. - Administration	13/02/2021
Comp. Dt. : 04/03/2021 Status : Completed								
19	21030203	AO Office	SINK WATER LEAKAGE IN DINNING ROOM	Rajendran. R.,Manikandan. S.,Sellaveeran. M.	Angle valve rework and refixed in properly, problem solved		Kanimozhi. D. - Administration	04/03/2021
Comp. Dt. : 27/03/2021 Status : Completed								
20	21031048	AO Office	SINK BLOCK AT MALE RESTROOM	Rajendhiran. V.	Sink block removed, work completed		Kadhiravan. C. - Administration	27/03/2021
Comp. Dt. : 30/07/2021 Status : Completed								

13/02/2021
TRUE COPY ATTESTED
 DEAN
 SRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 (MCH) KUTHALAKUPPAM,
 MADAGADI PET, PUDUCHERRY-605 107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
21	21070986	COVID CONTROL ROOM	NEED LABOURS FOR SHIFTING WORK	Pandiaraj. V., Yuvaraj. M., Thulasi. V.	Shifting work completed		Kanimozhi. D. - Administration	30/07/2021
	Comp. Dt. : 17/08/2021							
	Status : Completed							
22	21080567	AO Office	WASH BASIN BLOCK	Rajendhiran. V.	Wash basin block removed, work completed		Gomathy. K. - Administration	17/08/2021
	Comp. Dt. : 21/08/2021							
	Status : Completed							
23	21080723	AO Office	RAIN WATER BLOCK - WATER LEAKAGE AT BACK SIDE OF AO OFFICE- [AC GENERATOR SIDE]	Prakash. V., Arunagiri. V., Manikandan. S.	Rain water removed and block removed, work completed		Karthik. K. - Administration	21/08/2021
	Comp. Dt. : 28/08/2021							
	Status : Completed							
24	21080999	AO Office	RAIN WATER BLOCK - BACK SIDE OF AO OFFICE	Prakash. V., Arunagiri. V., Rajendran. R.	2nd floor flooring cement pointing work done, rain water line rework, leakage arrested, block remove		Siva. E. - Administration	28/08/2021
	Comp. Dt. : 29/09/2021							
	Status : Completed							
25	21091081	AO Office	WASHBASIN BLOCK - DINING HALL BACKSIDE	Prakash. V., Manikandan. S., Arunagiri. V.	Wash basin waste water outlet line fully rework, block removed, work completed		Gomathy. K. - Administration	29/09/2021
	Comp. Dt. : 24/12/2021							
	Status : Completed							
26	21120973	AO Office	WASHBASIN WATER LEAKAGE PROBLEM	Prakash. V., Rajendran. R., Ramkumar. R.	Wash basin outlet line fully rework, work completed		Santhosh Raja. K. - Administration	
	Comp. Dt. : 27/01/2022							
	Status : Completed							
27	22010666	AO Office	SINK BLOCK IN MALE RESTROOM	Prakash. V.	Sink block removed, waste water line rework, work completed		Kadhiravan. C. - Administration	27/01/2022
28	22010671	Chairman Office	NEED TO CHANGE RESTROOM TAP - WATER LEAKAGE IN VC SIR OFFICE RESTROOM - NEED URGENT SERVICE	Prakash. V., Manikandan. S., Rajendran. R.	New Jaquar CP health faucet - 1 No changed, work completed		Sadhasivam. K. - Administration	31/01/2022
	Comp. Dt. : 25/02/2022							

TRUE COPY ATTESTED

TRUE COPY ATTESTED

TRUE COPY ATTESTED

DEAN
24/12/2021
VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
MAUDAGADIPET, PUDUCHERRY-605 107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
29	22020822	AO Office	DUE DEAD OF RAT - NEED CLENING WORK AT RECORD ROOM	Rajendhiran. V.,Govindan. R.,Sakthivel. E.	Rat removed and cleaned that place with housekeeping labours		Elumalai.K.A. - Administration	26/02/2022
Comp. Dt. : 01/03/2022								
Status : Completed								
30	22030010	Chairman Office	WATER LEAKAGE IN CHAIRMAN OFFICE CONFERENCE HALL RESTROOM	Prakash. V.,Ramkumar. R.,Arunagiri. V.	Health faucet leakage problem, New CP Health faucet 1No changed, work completed		Sadhasivam. K. - Administration	04/03/2022
Comp. Dt. : 08/03/2022								
Status : Completed								
31	22030249	AO Office	NEED TO CHANGE WASH BASIN TAP - WATER LEAKAGE	Ramkumar. R.	SS Sink tap spindle changed, work completed		Santhosh Raja. K. - Administration	08/03/2022
Comp. Dt. : 24/03/2022								
Status : Completed								
32	22030979	AO Office	NEED TO CHANGE REST ROOM OUTLET WATER FILLTER - BLOCK - AT S A O SIR ROOM	Thanuzkodi. E	SAO Sir room toilet block removed,work completed		Karthik. K. - Administration	24/03/2022
Comp. Dt. : 30/03/2022								
Status : Completed								
33	22031230	AO Office	STAFF REST ROOM BLOCK	Rajendhiran. V.	Toilet block removed, work completed		Santhosh Raja. K. - Administration	31/03/2022
Comp. Dt. : 20/04/2022								
Status : Completed								
34	22040699	AO Office	ICE WATER NOT COMING IN COOLER	Ramkumar. R.	Informed to AC department.		Karthik. K. - Administration	20/04/2022
Comp. Dt. : 22/04/2022								
Status : Completed								
35	22040806	AO Office	FLUSH WATER LEAKAGE & RESTROOM BLOCK AT "S A O" SIR ROOM	Prakash. V.,Thanuzkodi. E.,Rajendhiran. V.	Flush tank fullset cleaned and serviced, Toilet block removed,work completed		Santhosh Raja. K. - Administration	23/04/2022
Comp. Dt. : 30/04/2022								
Status : Completed								
36	22041115	Reception	NEED TO SPRAY " TERMITE SPREY" FOR SWAMY PHOTO BACKSIDE	Kannan. V.	AGM Inform to Project Manager Mrs. Sivapoosanam (Civil admin)		Sathiyamoorthy. D. - Administration	07/07/2022
Comp. Dt. : 04/05/2022								

20/04/2022
TRUE COPY ATTESTED

DEAN
SRIMANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
MADAGADIPET, PUDUCHERRY-605 107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
37	22050082	AO Office	NEED TO CHANGE HAND SHOWER FOR REGISTRAR ROOM [DAMAGE - WATER LEAKAGE]	Prakash. V.	New health faucet changed.		Kanimozhi. D. - Administration	04/05/2022
Comp. Dt. : 18/05/2022								
Status : Completed								
38	22050680	Main Gate	NEED LABOURS 4 NOS FOR UNLOADING PAPER BUNDALS FROM GATE TO BASEMENT STORE	Pandiaraj. V.,Yuvaraj. M.,Thulasi. V.	Paper bundle unloading work completed		Motheeswarar. R.S. - Administration	21/05/2022
Comp. Dt. : 14/06/2022								
Status : Completed								
39	22060500	AO Office	NEED TO REFIX HAND SHOWER FOR FEMALE STAFF REST ROOM	Arunagiri. V.	Health faucet fixed.		Kanimozhi. D. - Administration	23/06/2022
Comp. Dt. : 27/06/2022								
Status : Completed								
40	22060968	AO Office	MALE RESTROOM BLOCK - NEED URGENT SERVICE	Rajendhiran. V.	Block removed.		Santhosh Raja. K. - Administration	28/06/2022
Comp. Dt. : 15/07/2022								
Status : Completed								
41	22070602	General Stores[Linen]	NEED TO CHECK DUCT PIPE LINE - WATER LEAKAGE INSIDETHE STORE	Prakash. V.,Rajendran. R.,Manikandan. S.	Special clinic #100 - duct line block, so floor leakage problem, duct line fully rework, leakage arr		Motheeswarar. R.S. - Administration	16/07/2022
Comp. Dt. : 22/07/2022								
Status : Completed								
42	22070829	AO Office	DUE TO HEAVY RAIN METAL RUBBY SHEET IN BACK SIDE OF AO OFFICE FELL DOWN NEED TO REFIX	Pandiaraj. V.,Thulasi. V.,Prakash. N.	Metal rubby sheet shifted.		Gomathy. K. - Administration	26/07/2022
Comp. Dt. : 03/08/2022								
Status : Completed								
43	22080122	Chairman Office	WATER NOT COMING IN CONFERENCE HALL WASH BASIN TAP - NEED TO CHECK & CHANGE	Prakash. V.,Arunagiri. V.,Ramkumar. R.	Sink Elbow action pillar cock and hot & Cold tap filter cleaned and serviced, rework the tap, proble		Sadhasivam. K. - Administration	04/08/2022
Comp. Dt. : 17/08/2022								

TRUE COPY ATTESTE:

DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUNPAM,
MADAGADIPIET, PUDUCHERRY-605 107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
44	22080539	GENERAL STORE	NEED MANPOWER TO SHIFT EQUIPEMENT FROM MAIN ENTRANCE TO STORE	Pandiaraj. V.,Yuvaraj. M.,Thulasi. V.	shifting work done.		Manikandan. S. - Administration	23/08/2022
Comp. Dt. : 22/08/2022								
Status : Completed								
45	22080710	AO Office	SINK BLOCK - NEED URGENT SERVICE	Rajendhiran. V.,Thanuzkodi. E.,Murugan. S.	Block removed.		Kadhiravan. C. - Administration	23/08/2022
Comp. Dt. : 23/08/2022								
Status : Completed								
46	22080750	Paediatrics - OPD	NEED TO CHANGE R O DRINKING WATER TAP - WATER LEAKAGE	Prakash. V.,Rajendran. R.,Ramkumar. R.	Bush changed.		Arulkumaran. S. - Administration	24/08/2022
Comp. Dt. : 06/09/2022								
Status : Completed								
47	22090233	AO Office	BLOCK IN MALE RESTROOM	Rajendhiran. V.,Murugan. R.,Thanuzkodi. E	block removed.		Karthik. K. - Administration	07/09/2022
Comp. Dt. : 12/10/2022								
Status : Completed								
48	22100339	GENERAL STORE	2 NO'S LABOUR NEED FOR SHIFTING WORK	Pandiaraj. V.	Machine shifting work done.		Manikandan. S. - Administration	13/10/2022
Comp. Dt. : 09/11/2022								
Status : Completed								
49	22110354	GENERAL STORE	WATER LEAKAGING FROM WALL CEILING	Prakash. V.,Rajendran. R.,Ramkumar. R.	Water leakage arrested.		Manikandan. S. - Administration	10/11/2022
Comp. Dt. : 15/11/2022								
Status : Completed								
50	22110599	GENERAL STORE	NEED LABOURS FOR MEDICINE COVER SHIFTING PURPOSE(FROM NEAR FREE PHARMACY)	Pandiaraj. V.,Yuvaraj. M.,Thulasi. V.	Shifting work completed		Manikandan. S. - Administration	16/11/2022
Comp. Dt. : 01/12/2022								
Status : Completed								
51	22120006	Chairman Office	WATER NOT COMING IN WASH BASIN AT V.C SIR OFFICE ROOM	Vengatesan. V.	tap filter rework done.		Sadhasivam. K. - Administration	05/12/2022

TRUE COPY ATTESTED

DEAN
SRI MANJULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
MADAGADI PET, PUDUCHERRY-605 107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 16/12/2022		Status : Completed						
52	22120760	GENERAL STORE	NEED MANPOWER TO SHIFT MATERIALS FROM GASPLANT TO GENERAL STORE	Pandiaraj. V., Yuvaraj. M., Senthil Kumar. R.	Materials shifting work completed		Manikandan. S. - Administration	20/12/2022
Comp. Dt. : 30/12/2022		Status : Completed						
53	22121367	GENERAL STORE	NEED MANPOWER FOR MATERIALS SHIFT FROM MAIN GATE	Pandiaraj. V., Yuvaraj. M., Senthil Kumar. R.	Hospital materials shifting work completed		Manikandan. S. - Administration	31/12/2022
Dept Name : Air Condition Department - Civil - Maintenance								
Comp. Dt. : 11/02/2020		Status : Completed						
54	20020406	Mit ladies hostel	NEED TO FIX WATER COOLER FLOATING VALUE	Udhaya Kumar. R.	Float valve changed, problem solved		Saravanan. C. - Air Condition Department	18/02/2020
Comp. Dt. : 15/02/2021		Status : Completed						
55	21020517	AC DEPT	NEED TO CHANGE TAP - WATER LEAKAGE AT HOSPITAL I FLOOR	Prakash. V.	New PVC tap changed, work completed		Udhaya Shankar. P. - Air Condition Department	18/02/2021
Comp. Dt. : 05/11/2021		Status : Completed						
56	21110093	marchuary	NEED CLEANING & UNWANTED TREES CUTTING WORK FOR MARCHUARY SOUTH SIDE	Kumar. V.	Inform to Housekeeping dept Mr.Naresh		Saravanan. C. - Air Condition Department	15/11/2021
Comp. Dt. : 28/12/2021		Status : Completed						
57	21121067	NEW CHILLER IN TERROUS	PIPE LINE DAMAGE IN ROOF	Prakash. V., Arunagiri. V., Sankar. V.	1" Pipe line rework, work completed on that day		Saravanan. C. - Air Condition Department	30/12/2021
Comp. Dt. : 14/02/2022		Status : Completed						
58	22020478	HOSPITAL TERROUS	NEED A NEW PIPE LINE CONNECTION & A SMALL TANK FOR AC LEAF CLEANING PURPOSE AT HOSPITAL TERROUS "C"	Pandiaraj. V., Yuvaraj. M., Thulasi. V.	Civil work, Inform to Project Managr Mururgan sir - WFM		Babu. D. - Air Condition Department	08/03/2022
Comp. Dt. : 20/05/2022		Status : Completed						

TRUE COPY ATTESTED

DEAN
SRI MANJULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
MADAGADIPET, PUDUCHERRY-605 107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
59	22050778	CHILLER IN HOSPITAL TERROUS	NEED A NEW PIPE LINE CONNECTION	Prakash. V.	1/2" valve changed, problem solved		Babu. D. - Air Condition Department	24/05/2022
	Comp. Dt. : 23/08/2022 Status : Completed							
60	22080765	Casualty	NEED CLEANING & CUTTING UNWANTED TREES AT BACK SIDE OF EMERGENCY CASUALTY	Pandiaraj. V.	Unwanted trees were cut		Panneer Selvam. P. - Air Condition Department	03/09/2022
	Comp. Dt. : 29/08/2022 Status : Completed							
61	22080965	AHU Room-1ST FLOOR	BLOCK - BACK SIDE OF A H U ROOM I FLOOR - NEED TO CLEAR	Govindan. R., Thanuzkodi. E., Rajendran. R.	4" pipe line rework, dummy fixed, work completed		Panneer Selvam. P. - Air Condition Department	05/09/2022
	Comp. Dt. : 22/09/2022 Status : Completed							
62	22090899	General Medicine	DRAINAGE BLOCK - BACK SIDE OF MEDICINE OPD	Rajendhiran. V., Murugan. S., Thanuzkodi. E	block removed.		Thulasi Daran. R. - Air Condition Department	24/09/2022
	Comp. Dt. : 21/10/2022 Status : Completed							
63	22100714	CHILDREN'S PLAY GROUND INSIDE HOSPITAL	WATER LEAKAGING FROM 2ND FLOOR CARDIOLOGY OPD INTO GROUND FLOOR	Prakash. V., Rajendran. R., Ramkumar. R.	A/C complaint. Not a plumbing complaint.		Panneer Selvam. P. - Air Condition Department	22/10/2022
	Dept Name : ANATOMY - Civil - Maintenance Comp. Dt. : 20/01/2020 Status : Completed							
64	20010515	ANATOMY	NEED TO CHECK WASH BASIN TAP CONNECTION - WATER LEAKAGE	Gopal. S.	Wash basin tap rework and refixed in properly, problem solved		Mathivanan.B. - ANATOMY	27/01/2021
	Comp. Dt. : 23/01/2021 Status : Completed							
65	21010765	ANATOMY	NEED TO CHANGE WASH BASIN TAP AT RECEPTION HALL - WATER LEAKAGE	Arunagiri. V.	Wash basin angle valve spindle changed, work completed		Mathivanan.B. - ANATOMY	27/01/2021
	Comp. Dt. : 08/03/2022 Status : Completed							
66	22030270	ANATOMY	WASH BASIN [2 NOS] BROKEN	Sivaraja. M.	New wash basin fixed(2 No.s)		Mathivanan.B. - ANATOMY	21/03/2022
	Comp. Dt. : 14/12/2022 Status : Completed							

TRUE COPY ATTESTED

DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHAL KUPPAM,
MASS/01/2021, PUDUCHERRY-605 107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
67	22120650	ANATOMY	FLUSH NOT WORKING 2 NOS	Anandharaj. M., Azhagar. N., Sellaveeran. M.	Flush tank rework done.		Mathivanan.B. - ANATOMY	17/12/2022
Dept Name : Animal House - Civil - Maintenance Comp. Dt. : 18/03/2021 Status : Completed								
68	21030754	Animal House	RESTROOM BLOCK	Rajendhiran. V.	Toilet block removed, work completed		Prema. A. - Animal House	18/03/2021
Comp. Dt. : 13/07/2021 Status : Completed								
69	21070453	Animal House	WASH BASIN WATER BLOCK	Thanuzkodi. E, Thulasi. V., Prakash. V.	New Wash basin changed, water line connection given, work completed		Prema. A. - Animal House	14/07/2021
Comp. Dt. : 02/09/2021 Status : Completed								
70	21090105	Animal House	BLOCK AT BACK SIDE OF ANIMAL HOUSE - NEED URGENT SERVICE	Rajendhiran. V.	Chamber block removed, work completed		Prema. A. - Animal House	03/09/2021
Comp. Dt. : 22/09/2021 Status : Completed								
71	21090806	Animal House	BLOCK - BACK SIDE OF ANIMAL HOUSE - NEED URGENT SERVICE	Thanuzkodi. E	Chamber block removed, work completed		Prema. A. - Animal House	22/09/2021
Dept Name : Audit Wing - Civil - Maintenance Comp. Dt. : 10/07/2020 Status : Completed								
72	20070229	Casualty	SINK WATER OUT LET LEAKAGE - NEED URGENT SERVICE	Manikandan. S., Sellaveeran. M., Ramkumar. R.	Back side pipe line Elbow, MTA, coupling changed and pipe line rework, work completed		Raji. R. - Audit Wing	11/07/2020
Comp. Dt. : 05/06/2021 Status : Completed								
73	21060139	AO Office	URINAL BLOCK AT MALE REST ROOM	Prakash. V., Rajendhiran. V., Thanuzkodi. E	Urinal line fully block removed, work completed		Raji. R. - Audit Wing	05/06/2021
Dept Name : BIOCHEMISTRY - Civil - Maintenance Comp. Dt. : 07/01/2020 Status : Completed								
74	20010151	Blood Collection Centre	wash basin sink block-1008	Rajendhiran. V.	Sink block removed and door elbow 1No changed, work completed		Srinivasamurugan. V. - BIOCHEMISTRY	07/01/2020

TRUE COPY ATTESTED

DEAN
SRIMANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALUTHEERTHALKUPPAM
MADAGADIPET, PUDUCHERRY-605 107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 24/01/2020 Status : Completed								
75	20010670	Blood Collection Centre	NEED MANPOWER TO SHIT BERO TO COLLEGE SIDE	Pandiaraj. V., Yuvaraj. M., Thulasi. V.	Bero shifting work completed		Srinivasamurugan. V. - BIOCHEMISTRY	28/01/2020
Comp. Dt. : 02/03/2020 Status : Completed								
76	20030013	COMMON MALE TOILET NEAR BIOCHEMISTRY	COMMON TPILET BLOCKED, NEED SCAVENGER	Thanuzkodi. E	Toilet block removed, work completed		Srinivasamurugan. V. - BIOCHEMISTRY	02/03/2020
77	20030041	Biochemistry Lab-Hospital	WASH BASIN SINK TAP LEAKAGING PROBLEM	Manikandan. S.	Wash basin elbow tap spindle changed, problem solved		Preethi. A. - Blood Collection Centre	03/03/2020
Comp. Dt. : 18/03/2020 Status : Completed								
78	20030604	Biochemistry Lab-Hospital	NEED TO CHANGE TAP - WATER LEAKAGE	Prakash. V.	Wash basin JK white cement pointing work completed		Srinivasamurugan. V. - BIOCHEMISTRY	18/03/2020
Comp. Dt. : 26/05/2020 Status : Completed								
79	20050205	Clinical Pathology	NEED TO CHANGE MINERAL WATER CANE	Prakash. V.	Wrong complaint		Srinivasamurugan. V. - BIOCHEMISTRY	01/06/2020
Comp. Dt. : 29/06/2020 Status : Completed								
80	20060776	Blood Collection Centre	SINK BLOCK AT ROOM NO 47	Rajendhiran. V.	Sink block removed, work completed		Srinivasamurugan. V. - BIOCHEMISTRY	29/06/2020
81	20060797	Blood Collection Centre	WASH BASIN WATER LEAKAGE AT WASHING AREA	Prakash. V., Ramkumar. R., Abdul Azees. J.	Waste coupling changed, waste outlet line rework, work completed		Srinivasamurugan. V. - BIOCHEMISTRY	30/06/2020
Comp. Dt. : 23/07/2020 Status : Completed								
82	20070560	Blood Collection Centre	NEED TO CHECK WASH BASIN - BROKEN & WATER LEAKAGE	Ramkumar. R., Prakash. V., Rajendran. R.	Tap rework, work completed		Srinivasamurugan. V. - BIOCHEMISTRY	23/07/2020
Comp. Dt. : 04/08/2020 Status : Completed								
83	20080058	COMMON MALE TOILET NEAR BIOCHEMISTRY	WASH BASIN WATER LEAKAGE	Ramkumar. R., Rajendran. R., Prakash. V.	Wash basin pillar cock rework and flush tank full set rework, work completed		Srinivasamurugan. V. - BIOCHEMISTRY	05/08/2020
Comp. Dt. : 12/08/2020								

TRUE COPY ATTESTED

DEAN
MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
MADAGADIPEI, PUDUCHERRY-605 107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
84	20080247	Blood Collection Centre	WASH BASIN SINK LEAKAGING PROBLEM	Rajendran. R.	Elbow action pillar cock fully rework and refixed, work completed		Srinivasamurugan. V. - BIOCHEMISTRY	12/08/2020
Comp. Dt. : 01/09/2020								
Status : Completed								
85	20090025	BIOCHEMISTRY	NEED TO CHANGE AURO WATER FILTER	Rajendran. R.,Manikandan. S.,Ramkumar. R.	RO Filter 3Nos changed, work completed		Srinivasamurugan. V. - BIOCHEMISTRY	02/09/2020
Comp. Dt. : 11/09/2020								
Status : Completed								
86	20090215	COMMON MALE TOILET NEAR BIOCHEMISTRY	WASH BASIN SINK LEAKAGING PROBLEM	Ramkumar. R.	Wash basin pillar cock and waste line fully rework and refixed in properly, work completed		Srinivasamurugan. V. - BIOCHEMISTRY	12/09/2020
Comp. Dt. : 02/12/2020								
Status : Completed								
87	20120094	BIOCHEMISTRY	NEED TO CHECK MINERAL WATER PIPE LINE - FLOW SLOW	Manikandan. S.	Filter changed, work completed		Srinivasamurugan. V. - BIOCHEMISTRY	09/12/2020
Comp. Dt. : 07/12/2020								
Status : Completed								
88	20120235	BIOCHEMISTRY-- -COLLEGE	NEED LABOURS 4 NOS FOR TABLE SHIFTING AND ARRANGEMENT WORK	Pandiaraj. V.	Table shifting and arrangement work completed		Preethi. A. - Blood Collection Centre	07/12/2020
Comp. Dt. : 12/12/2020								
Status : Completed								
89	20120514	COMMON FEMALE TOILET NEAR LAB SIDE	WATER NOT COMING AT WASHBASIN [2NOS] AT FEMELE COMMON REST ROOM	Prakash. V.,Manikandan. S.,Rajendran. R.	2Nos of Tap rework, tap block removed,work completed		Srinivasamurugan. V. - BIOCHEMISTRY	12/12/2020
Comp. Dt. : 19/01/2021								
Status : Completed								
90	21010578	GENT'S STAFF TOILET NEAR BIOCHEMISTRY	TOILET BLOCK	Thanuzkodi. E	Toilet block removed, work completed		Srinivasamurugan. V. - BIOCHEMISTRY	12/12/2020
Comp. Dt. : 21/01/2021								
Status : Completed								
91	21010670	BIOCHEMISTRY	NEED LABOURS 2 NOS FOR SHIFTING TABLE FROM LAB TO WORKSHOP	Yuvaraj. M.,Thulasi. V.,Senthil Kumar. R.	Table shifting work completed		Srinivasamurugan. V. - BIOCHEMISTRY	22/01/2021
Comp. Dt. : 11/02/2021								

TRUE COPY ATTESTED

DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALOTIEER CHALKUPPAM,
MADAGADIPET, PUDUCHERRY-605 107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
92	21020394	BIOCHEMISTRY	NEED AQUAGUARD FILTER CLEANING WORK	Prakash. V.,Manikandan. S.,Udhaya Kumar. R.	Micron filter 2Nos, carbon filter 1No changed, work completed		Srinivasamurugan. V. - BIOCHEMISTRY	12/02/2021
Comp. Dt. : 08/04/2021								
Status : Completed								
93	21040187	Blood Collection Centre	SINK BLOCK	Rajendhiran. V.	Wash basin sink and D Wing side ladies and gents common toilet block removed, work completed		Srinivasamurugan. V. - BIOCHEMISTRY	08/04/2021
Comp. Dt. : 29/04/2021								
Status : Completed								
94	21040989	BIOCHEMISTRY	NEED TO CHECK WATER PIPE LINE , NOT COMING	Prakash. V.	In terrace water pipe line work going, so valve closed, after finishing the work, valve opened, prob		Srinivasamurugan. V. - BIOCHEMISTRY	30/04/2021
Comp. Dt. : 28/06/2021								
Status : Completed								
95	21060753	COMMON FEMALE TOILET NEAR BIOCHEMISTRY	NEED TO CHANGE WASH BASIN - DAMAGE -	Prakash. V.	New Wash basin changed, water line connection given, work completed		Srinivasamurugan. V. - BIOCHEMISTRY	05/07/2021
Comp. Dt. : 05/07/2021								
Status : Completed								
96	21070173	Blood Collection Centre	NEED TO REFIX WASH BASIN SINK - DAMAGE - - NEED URGENT SERVICE		New fisher bolt fixed, work completed		Srinivasamurugan. V. - BIOCHEMISTRY	09/07/2021
Comp. Dt. : 06/07/2021								
Status : Completed								
97	21070236	Blood Collection Centre	NEED WHITE CEMENT WORK FOR SINK REFIXING	Prakash. V.,Rajendran. R.,Gopal. S.	Fisher bolt fixed, work completed on 08.07.2021		Srinivasamurugan. V. - BIOCHEMISTRY	09/07/2021
Comp. Dt. : 08/07/2021								
Status : Completed								
98	21070314	Blood Collection Centre	NEED TO REFIX SINK - DAMAGE	Prakash. V.,Rajendran. R.,Sellaveeran. M.	New fisher bolt changed, work completed		Srinivasamurugan. V. - BIOCHEMISTRY	09/07/2021
Comp. Dt. : 15/07/2021								
Status : Completed								
99	21070525	COMMON MALE TOILET NEAR BIOCHEMISTRY	REST ROOM BLOCK	Rajendhiran. V.	Toilet block removed, work completed		Srinivasamurugan. V. - BIOCHEMISTRY	15/07/2021

TRUE COPY ATTESTED

DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHAKUPPAM,
MADAGADIPET, PUDUCHERRY-605 006

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 26/07/2021 Status : Completed								
100	21070852	Biochemistry Lab-Hospital	DISTILLED WATER PLANT FILTER NEED TO BE CHNAGE	Manikandan. S.,Sankar. V.,Arunagiri. V.	Micron filter changed, work completed		Srinivasamurugan. V. - BIOCHEMISTRY	26/07/2021
Comp. Dt. : 31/07/2021 Status : Completed								
101	21071030	COMMON MALE TOILET NEAR BIOCHEMISTRY	NEED TO CHECK NEWLY FIXED TAP CONNECTION - WATER NOT COMING	Prakash. V.	Tap and flush tank fullset rework, work completed		Srinivasamurugan. V. - BIOCHEMISTRY	02/08/2021
Comp. Dt. : 07/08/2021 Status : Completed								
102	21080261	COMMON MALE TOILET NEAR BIOCHEMISTRY	NEED TO CHANGE TAP - DAMAGE - WATER FLOW - NEED URGENT SERVICE	Arunagiri. V.	New Tap changed, work completed		Srinivasamurugan. V. - BIOCHEMISTRY	07/08/2021
Comp. Dt. : 01/09/2021 Status : Completed								
103	21090038	COMMON FEMALE TOILET NEAR LAB SIDE	WESTERN TOILET BLOCKED-NEED SCAVENGER	Rajendhiran. V.	Toilet block removed, work completed		Durga Devi. I. - BIOCHEMISTRY	01/09/2021
Comp. Dt. : 22/11/2021 Status : Completed								
104	21110755	COMMON MALE TOILET NEAR BIOCHEMISTRY	BLOCK - NEED URGENT SERVICE	Rajendhiran. V.	Toilet block removed, work completed		Srinivasamurugan. V. - BIOCHEMISTRY	23/11/2021
105	21110762	BIOCHEMISTRY	NEED TO CHANGE FILTER FOR MINERAL WATER TANK	Prakash. V.	3Nos of micron filter changed, work completed		Srinivasamurugan. V. - BIOCHEMISTRY	23/11/2021
Comp. Dt. : 03/01/2022 Status : Completed								
106	22010024	BIOCHEMISTRY	NEED TO CHECK RO WATER & MINARAL WATER CONNECTION - WATER NOT COMING	Prakash. V.,Rajendran. R.,Arunagiri. V.	RO water motor problem, motor serviced, tank filled with water, then opened valve, problem solved		Srinivasamurugan. V. - BIOCHEMISTRY	03/01/2022
Comp. Dt. : 10/01/2022 Status : Completed								
107	22010295	BIOCHEMISTRY--COLLEGE	BLOCK IN SINK	Rajendhiran. V.	Wash basin waste line fully to be change, WFM - Repeated complaint		Suganthi. P. - BIOCHEMISTRY	17/01/2022
Comp. Dt. : 19/01/2022 Status : Completed								

TRUE COPY ATTESTED
03/01/2022
DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
MADAGADIPET, PUDUCHERRY-605 107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
108	22010498	COMMON MALE TOILET NEAR BIOCHEMISTRY	NEED TO CHECK & CHANGE TAP - WATER LEAKAGE	Prakash. V.,Arunagiri. V.,Rajendran. R.	Tap spindle changed, leakage arrested, refixed the tap in properly, problem solved		Srinivasamurugan. V. - BIOCHEMISTRY	19/01/2022
Comp. Dt. : 15/02/2022 Status : Completed								
109	22020485	BIOCHEMISTRY	NEED TO CHANGE DISTILLED WATER FILTER	Prakash. V.,Arunagiri. V.,Ramkumar. R.	Micron filter 2Nos changed, problem solved		Srinivasamurugan. V. - BIOCHEMISTRY	15/02/2022
Comp. Dt. : 17/02/2022 Status : Completed								
110	22020583	COMMON MALE TOILET NEAR BIOCHEMISTRY	NEED TO CHANGE TAP FOR REST ROOM - WATER LEAKAGE	Prakash. V.,Arunagiri. V.,Rajendran. R.	Toilet block removed, sink tap and toilet tap rework, work completed		Parameswari. G. - BIOCHEMISTRY	18/02/2022
Comp. Dt. : 19/02/2022 Status : Completed								
111	22020642	COMMON MALE TOILET NEAR BIOCHEMISTRY	BLOCK IN REST ROOM - NEED URGENT SERVICE	Rajendhiran. V.,Thanuzkodi. E.,Govindan. R.	Toilet block removed, work completed		Srinivasamurugan. V. - BIOCHEMISTRY	19/02/2022
Comp. Dt. : 11/05/2022 Status : Completed								
112	22050384	Biochemistry Lab-Hospital	R O WATER TUBE FIXING WORK	Prakash. V.	New water hose changed.		Srinivasamurugan. V. - BIOCHEMISTRY	12/05/2022
Comp. Dt. : 16/05/2022 Status : Completed								
113	22050519	Blood Collection Centre	WATER LEAKAGE IN WASHING ROOM SINK	Prakash. V.	M seal fixing work done		Srinivasamurugan. V. - BIOCHEMISTRY	16/05/2022
Comp. Dt. : 20/05/2022 Status : Completed								
114	22050750	COMMON FEMALE TOILET NEAR BIOCHEMISTRY	WATER NOT COMING	Prakash. V.,Ramkumar. R.,Rajendran. R.	Tap and helath faucet filter cleaned and serviced, problem solved		Sangeetha. S. - BIOCHEMISTRY	21/05/2022
Comp. Dt. : 25/05/2022 Status : Completed								
115	22050959	COMMON MALE TOILET NEAR BIOCHEMISTRY	NEED TO CHECK WHERE WATER LEAKAGE - NEED URGENT SERVICE - BAD SMELL	Thanuzkodi. E.,Govindan. R.,Sakthivel. E.	Toilet block removed, work completed		Sathyamurugan. E. - BIOCHEMISTRY	25/05/2022
Comp. Dt. : 01/06/2022 Status : Completed								

TRUE COPY ATTESTED
21/05/2022

DEAN
SRI MANJALA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
MADAGADIPET, PUDUCHERRY-605 007
25/05/2022

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
116	22060001	COMMON MALE TOILET NEAR BIOCHEMISTRY	FLUSH NOT WORKING	Arunagiri. V.,Prakash. V.,Rajendran. R.	Flush tank fullset rework and serviced, problem solved		Sathyamurugan. E. - BIOCHEMISTRY	01/06/2022
	Comp. Dt. : 07/06/2022							
	Status : Completed							
117	22060262	BIOCHEMISTRY	NEED TO CHANGE DISTILLED WATER FILTER	Prakash. V.	Micron Filter and Carbon filter changed, problem solved		Srinivasamurugan. V. - BIOCHEMISTRY	08/06/2022
	Comp. Dt. : 24/06/2022							
	Status : Completed							
118	22060868	Blood Collection Centre	NEED TO CHANGE SINK TAP - WATER LEAKAGE & TAP DAMAGE	Ramkumar. R.,Rajendran. R.,Prakash. V.	New sink tap rework.		Srinivasamurugan. V. - BIOCHEMISTRY	28/06/2022
	Comp. Dt. : 30/06/2022							
	Status : Completed							
119	22061130	BIOCHEMISTRY	DISTILLED WATER PLANT LEAKAGE	Prakash. V.,Ramkumar. R.,Rajendran. R.	RO Water hose rework, work completed		Srinivasamurugan. V. - BIOCHEMISTRY	04/07/2022
	Comp. Dt. : 16/07/2022							
	Status : Completed							
120	22070627	COMMON MALE TOILET NEAR BIOCHEMISTRY	BLOCK -	Rajendhiran. V.	Block removed		Srinivasamurugan. V. - BIOCHEMISTRY	18/07/2022
	Comp. Dt. : 18/07/2022							
	Status : Completed							
121	22070681	BIOCHEMISTRY-- -COLLEGE	NEED TO CHANGE TAP - WATER LEAKAGE	Azhagar. N.,Anandharaj. M.,Sellaveeran. M.	1.1/4" Waste coupling, waste hose changed, work completed		Suganthi. P. - BIOCHEMISTRY	20/07/2022
	Comp. Dt. : 02/08/2022							
	Status : Completed							
122	22080060	COMMON MALE TOILET NEAR BIOCHEMISTRY	BLOCK IN MALE RESTROOM	Rajendhiran. V.	Block removed.		Srinivasamurugan. V. - BIOCHEMISTRY	03/08/2022
123	22080072	BIOCHEMISTRY	NEED TO CHANGE SINK TAP - DAMAGE & WATER LEAKAGE AT WASHING ROOM	Prakash. V.	Spindle has been changed in elbow action tap		Srinivasamurugan. V. - BIOCHEMISTRY	03/08/2022
	Comp. Dt. : 22/08/2022							
	Status : Completed							
124	22080708	COMMON MALE TOILET NEAR BIOCHEMISTRY	BLOCK AND BAD SMELL - NEED TO CHECK - NEED URGENT SERVICE	Rajendhiran. V.,Thanuzkodi. E,Murugan. S.	Block removed.		Srinivasamurugan. V. - BIOCHEMISTRY	23/08/2022
	Comp. Dt. : 05/09/2022							

TRUE COPY ATTESTED

03/08/2022
DEAN
SRI MANAKULA VINAYAKAR
MEDICAL COLLEGE & HOSPITAL
KALYANEERTHAKUPPAM,
MADAGADIPEI, PUDUCHERRY-605 107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
125	22090198	BIOCHEMISTRY	NEED TO REPLACE DISTILLED WATER FILTER	Prakash. V.,Rajendran. R.,Ramkumar. R.	Sand filter and carbon filter changed, work completed		Srinivasamurugan. V. - BIOCHEMISTRY	09/09/2022
Comp. Dt. : 08/10/2022								
Status : Completed								
126	22100194	TOILET NEAR CLINICAL PATHOLOGY	REST ROOM BLOCK	Rajendhiran. V.,Thanuzkodi. E,Murugan. S.	Block removed.		Sathyamurugan. E. - BIOCHEMISTRY	11/10/2022
Comp. Dt. : 17/10/2022								
Status : Completed								
127	22100511	COMMON MALE TOILET NEAR BIOCHEMISTRY	NEED TO REFIX FLUSH TANK - DAMAGE & BROKEN AT STAFF REST ROOM	Prakash. V.,Rajendran. R.,Ramkumar. R.	Flush tank refixed in the clamp		Srinivasamurugan. V. - BIOCHEMISTRY	19/10/2022
Comp. Dt. : 28/10/2022								
Status : Completed								
128	22100933	COMMON MALE TOILET NEAR BIOCHEMISTRY	TOILET BLOCKED,NEED SCAVENGER	Rajendhiran. V.,Thanuzkodi. E,Murugan. S.	Block removed.		Sathyamurugan. E. - BIOCHEMISTRY	29/10/2022
Comp. Dt. : 29/10/2022								
Status : Completed								
129	22100957	COMMON TOILET NEAR BLOOD BANK	RESTROOM BLOCK NEAR MICROBIOLOGY LAB	Rajendhiran. V.	Block removed.		Srinivasamurugan. V. - BIOCHEMISTRY	31/10/2022
Comp. Dt. : 03/11/2022								
Status : Completed								
130	22110057	COMMON MALE TOILET NEAR BIOCHEMISTRY	RESTROOM BLOCK	Rajendhiran. V.,Murugan. S.,Thanuzkodi. E	Block removed.		Srinivasamurugan. V. - BIOCHEMISTRY	03/11/2022
131	22110060	Biochemistry Lab-Hospital	IN MALE REST ROOM- WESTERN TOILET FLUSH TANK PIPE DAMAGE	Prakash. V.,Rajendran. R.,Ramkumar. R.	Flush tank leakage arrested. Flush tank and health faucet rework done.		Srinivasamurugan. V. - BIOCHEMISTRY	09/11/2022
Comp. Dt. : 05/11/2022								
Status : Completed								
132	22110179	COMMON MALE TOILET NEAR BIOCHEMISTRY	TOILET BLOCKED,NEED SCAVENGER	Rajendhiran. V.,Thanuzkodi. E,Murugan. S.	block removed.		Srinivasamurugan. V. - BIOCHEMISTRY	08/11/2022
Comp. Dt. : 26/11/2022								
Status : Completed								

TRUE COPY ATTESTED

DEAN
SRI MANANJUNATHAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEENTHAL KUPPAM,
MADAGADI PET, PUDUCHERRY-605 007.
08/11/2022

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
133	22111129	Biochemistry Lab-Hospital	WATER NOT COMING ON LAB SIDE WING	Prakash. V.,Rajendran. R.,Ramkumar. R.	Uniqcore connstruction broken the pipe. New pipe connected.		Srinivasamurugan. V. - BIOCHEMISTRY	28/11/2022
Comp. Dt. : 21/12/2022 Status : Completed								
134	22120951	COMMON FEMALE TOILET NEAR BIOCHEMISTRY	REST ROOM BLOCK	Thanuzkodi. E,Rajendhiran. V.,Murugan. S.	Block removed.		Nirmala.B. - BIOCHEMISTRY	21/12/2022
Dept Name : Biomedical - Civil - Maintenance Comp. Dt. : 18/03/2020 Status : Completed								
135	20030605	Biomedical	NEED 2 NOS OF MAN POWER	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	Shifting work completed		Gurumoorthy. G. - Biomedical	20/03/2020
Comp. Dt. : 02/12/2020 Status : Completed								
136	20120099	SPECIALITY OT	NEED LABOURS 2 NOS FOR SHIFTING OT LIGHT FROM SPECIALITY OT TO POST OPP	Mahesh Babu. N.,Pandiaraj. V.,Yuvaraj. M.	Shifting work completed		Ganesh Kumar. S. - Biomedical	11/12/2020
Dept Name : BLOOD BANK - Civil - Maintenance Comp. Dt. : 28/01/2020 Status : Completed								
137	20010779	Blood Bank	NEED LABOUR 1 NO FOR SCREEN FIXING WORK	Pandiaraj. V.,Yuvaraj. M.,Thulasi. V.	Screen fixing work completed		Ganesh. V. - BLOOD BANK	28/01/2020
Comp. Dt. : 21/02/2020 Status : Completed								
138	20020776	Blood Bank	NEED LABOURS 4 NOS FOR SHIFTING ITEMS FROM BLOOD BANK TO MEDICAL COLLEGE	Pandiaraj. V.,Yuvaraj. M.,Lakshmanan. V.	Shifting work completed		Ganesh. V. - BLOOD BANK	24/02/2020
Comp. Dt. : 11/06/2020 Status : Completed								
139	20060319	Blood Bank	NEED MANPOWER FOR SHIFTING WORK	Pandiaraj. V.,Thulasi. V.,Kannan. V.	Shifting work completed		Ganesh. V. - BLOOD BANK	11/06/2020
Comp. Dt. : 10/07/2020 Status : Completed								
140	20070246	Blood Bank	TAP LEAKAGE	Manikandan. S.	2Nos of CP Elbow pillar cock changed, 1No tap spindle work completed		Ganesh. V. - BLOOD BANK	10/07/2020

TRUE COPY ATTESTED

DEAN
SRIMANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
MADAGADIPET, PUDUCHERRY-605 107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
	Comp. Dt. : 06/08/2020							
	Status : Completed							
141	20080102	TOILET NEAR CLINICAL PATHOLOGY	NEED TO CHANGE TAP - NOT WORKING - WATER NOT COMING	Prakash. V.	Ladies toilet and Gents toilet - New CP Tap 2Nos changed, work completed		Thirumangai. S. - BLOOD BANK	12/08/2020
	Comp. Dt. : 07/09/2020							
	Status : Completed							
142	20090111	LADIES STAFF TOILET NEAR LAB	WATER TAP NEED TO BE REFIX PROPERLY IN WASH BASIN SINK	Manikandan. S.,Rajendran. R.,Prakash. V.	Tap rework and refixed in proeprly, work completed		Thirumangai. S. - BLOOD BANK	12/09/2020
	Comp. Dt. : 18/01/2021							
	Status : Completed							
143	21010518	Blood Bank	NEED LABOURS 4NOS FOR SHIFTING MACHINE FROM BLOOD BANK TO MICROBIOLOGY (COLLEGE SIDE)	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	Machine shifting work completed		Ganesh. V. - BLOOD BANK	18/01/2021
	Comp. Dt. : 22/01/2021							
	Status : Completed							
144	21010757	Blood Bank	NEED TO CHANGE TAP FOR LAB NO 1	Prakash. V.	Health faucet place changed, work completed		Ganesh. V. - BLOOD BANK	30/01/2021
	Comp. Dt. : 28/01/2021							
	Status : Completed							
145	21010885	Blood Bank	2 NO'S WASH BASIN SINK DAMAGED-BROKEN	Prakash. V.,Abdul Azees. J.,Sankar. V.	2Nos of new wash basin changed, work completed		Ganesh. V. - BLOOD BANK	30/01/2021
	Comp. Dt. : 05/02/2021							
	Status : Completed							
146	21020182	Blood Bank	NEED LABOURS 4 NOS FOR SHIFTING WORK FROM MEDICAL COLLEGE TO BLOOD BANK	Pandiaraj. V.,Yuvaraj. M.,Thulasi. V.	Machine 1No shifting work completed		Ganesh. V. - BLOOD BANK	09/02/2021
	Comp. Dt. : 26/02/2021							
	Status : Completed							
147	21021018	Blood Bank	NEED TO CHECK PIPE LINE CONNCETON - WATER NOT COMING	Manikandan. S.	Wash basin waste line fully rework, tap rework and refixed in properly, work completed		Ganesh. V. - BLOOD BANK	27/02/2021
	Comp. Dt. : 27/02/2021							
	Status : Completed							

TRUE COPY ATTESTED

27/02/2021
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
MADAGADIPET, PUDUCHERRY-605 107.

[illegible]

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 28/03/2022 Status : Completed								
3584	22031101	Ophthalmology - OPD	SINK WATER LEAKAGE - ROOM NO 84	Rajendran. R.	CP Elbow action tap spindle changed, leakage arrested, problem solved		Rajeswari.V. - Ophthalmology	07/04/2022
Comp. Dt. : 08/04/2022 Status : Completed								
3585	22040313	Ophthalmology - OPD	REST ROOM FLUSH NOT WORKING	Prakash. V.,Ramkumar. R.,Rajendran. R.	Flush tank fullset rework, washer changed, work completed		Rajeswari.V. - Ophthalmology	09/04/2022
Dept Name : ORTHOPAEDICS - Civil - Maintenance Comp. Dt. : 01/02/2020 Status : Completed								
3586	20020023	Orthopaedics - OPD	in room no.63 bathroom tap leakaging problem	Prakash. V.	Flush tank leakage problem, washer changed, leakage arrested, problem solved		Manjula. P. - ORTHOPAEDICS	01/02/2020
Comp. Dt. : 03/08/2020 Status : Completed								
3587	20080007	Orthopaedics - OPD	NEED LABOURS 2 NOS FOR FIXING BANNER	Pandiaraj. V.,Yuvaraj. M.,Thulasi. V.	Banner fixing work completed		Manjula. P. - ORTHOPAEDICS	06/08/2020
Comp. Dt. : 02/11/2020 Status : Completed								
3588	20110008	COMMON MALE TOILET NEAR ORTHO OPD	NEED TO CHANGE TAP - BROKEN - WATER LEAKAGE	Ramkumar. R.,Prakash. V.,Rajendran. R.	Wrong complaint, Urinal line block removed and refixed in properly, work completed		Manjula. P. - ORTHOPAEDICS	03/11/2020
Comp. Dt. : 18/02/2021 Status : Completed								
3589	21020675	Orthopaedics - OPD	WASH BASIN TAP DAMAGE - WATER NOT COMING	Prakash. V.	New CP Elbow action pillar cock changed, work completed		Manjula. P. - ORTHOPAEDICS	18/02/2021
Comp. Dt. : 02/03/2021 Status : Completed								
3590	21030120	Orthopaedics - OPD	REST ROOM BLOCK AT HOD SIR ROOM - NO 62	Thanuzkodi. E,Rajendhiran. V.,Prakash. V.	OPD backside pipe line broken, rework the pipe line, Toilet block removed, work competed		Manjula. P. - ORTHOPAEDICS	04/03/2021
Comp. Dt. : 07/01/2022 Status : Completed								

TRUE COPY ATTESTED

SRI MANJULA P. NAYAGAR
 MEDICAL OFFICER
 04/03/2021
 ADAGADI PET, PUDUCHERRY-605 107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
3591	22010194	Orthopaedics - OPD	WATER LEAKAGE IN WASHBASIN TAP	Prakash. V.	Sink pillar cock rework, JK white pointing work done, work completed		Manjula. P. - ORTHOPAEDICS	07/01/2022
Comp. Dt. : 08/01/2022 Status : Completed								
3592	22010234	Orthopaedics - OPD	WASH BASIN WATER LEAKAGE - ROOM NO 62 [REPEAT]	Prakash. V.	Wash basin tap elbow action tap rework, work completed		Manjula. P. - ORTHOPAEDICS	17/01/2022
Comp. Dt. : 27/05/2022 Status : Completed								
3593	22051023	COMMON MALE TOILET NEAR ORTHO OPD	BLOCK IN MALE RESTROOM	Thanuzkodi. E	block remover		Manjula. P. - ORTHOPAEDICS	27/05/2022
Comp. Dt. : 04/08/2022 Status : Completed								
3594	22080176	Orthopaedics - OPD	NEED LABOURS FOR THINGS SHIFTING WORK	Pandiaraj. V., Yuvaraj. M., Senthil Kumar. R.	shifting work completed.		Manjula. P. - ORTHOPAEDICS	11/08/2022
Dept Name : P.H.C. - Tiruvonnainallur - Civil - Maintenance Comp. Dt. : 06/10/2020 Status : Completed								
3595	20100106	Thiruvonnainallur	NEED PLUMBING WORK	Prakash. V., Arunagiri. V., Azhagar. N.	All plumbing fittings changed, pipe line fully rework, work completed		Kanagasabai. D. - P.H.C. - Tiruvonnainallur	12/01/2021
Comp. Dt. : 07/03/2022 Status : Completed								
3596	22030210	Thiruvonnainallur	REST ROOM BLOCK IN THIRUVONNAINALLUR P H C	Rajendhiran. V.	All bathroom block removed and drainage line block removed, work completed		Kanagasabai. D. - P.H.C. - Tiruvonnainallur	10/03/2022
Comp. Dt. : 18/04/2022 Status : Completed								
3597	22040597	Thiruvonnainallur	BLOCK IN REST ROOM	Rajendhiran. V.	Block removed		Kanagasabai. D. - P.H.C. - Tiruvonnainallur	19/04/2022
Comp. Dt. : 29/04/2022 Status : Completed								
3598	22041095	Thiruvonnainallur	NEED TO CHECK & CHANGE FLUSH TANK - DAMAGE	Ramkumar. R.	Flush tank changed		Kanagasabai. D. - P.H.C. - Tiruvonnainallur	30/04/2022
Comp. Dt. : 05/05/2022								

TRUE COPY ATTESTED

19/04/2022

SRIMANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
19/04/2022
MADAGADIPET, PUDUCHERRY-605 107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
3599	22050162	Thiruvannainallur	NEED PLUMBER HELP FOR FIXING URINAL & OTHER RAPAIRING WORK	Prakash. V.	Urinal block removed and all rooms were checked.		Kanagasabai. D. - P.H.C. - Tiruvannainallur	09/05/2022
Comp. Dt. : 23/09/2022								
Status : Completed								
3600	22090952	Thiruvannainallur	URINAL BLOCK AND NEED PLUMBER HELP	Prakash. V.	All floor plumbing work completed.		Kanagasabai. D. - P.H.C. - Tiruvannainallur	18/10/2022
Dept Name : PAEDIATRICS - Civil - Maintenance								
Comp. Dt. : 16/03/2020								
Status : Completed								
3601	20030543	NICU	NEED TO REFIX SINK - 1140	Ramkumar. R.,Prakash. V.,Rajendran. R.	New Wash basin sink fixed, water line connection given, work completed		Thambiprabagarane. K. - PAEDIATRICS	17/03/2020
Comp. Dt. : 07/04/2021								
Status : Completed								
3602	21040146	Paediatrics - OPD	NEED LABOURS 3 NOS FOR BANNER FIXING WORK	Pandiaraj. V.,Yuvaraj. M.,Thulasi. V.	Baner fixing work completed at main gate		Manju @ Brinda. V. - PAEDIATRICS	07/04/2021
Comp. Dt. : 06/10/2021								
Status : Completed								
3603	21100131	Paediatrics - OPD	WASHBASIN [3NOS] BLOCK	Rajendhiran. V.	Wash basin block removed, work completed		Manju @ Brinda. V. - PAEDIATRICS	06/10/2021
Dept Name : Paediatrics Ward - Civil - Maintenance								
Comp. Dt. : 02/01/2020								
Status : Completed								
3604	20010030	Paediatrics - Ward 309	NEED LABOURS 2 NOS FOR RE FIXING BERO	Pandiaraj. V.,Yuvaraj. M.,Thulasi. V.	Bero shifting work completed		Chitra. P. - Paediatrics Ward	08/01/2020
Comp. Dt. : 06/01/2020								
Status : Completed								
3605	20010147	Paediatrics - Ward 308	drinking water machine not working	Prakash. V.,Ramkumar. R.,Abdul Azees. J.	heater line problem, msg inform to electrical dept		Chitra. P. - Paediatrics Ward	08/01/2020
Comp. Dt. : 21/01/2020								
Status : Completed								

TRUE COPY ATTESTED

DEAN
SRI MANAKUL VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHAL KUPPAM,
MADAGADIPET, PUDUCHERRY-605 107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
3606	20010545	Male Ortho - Ward 403	REST ROOM BLOCK	Rajendhiran. V., Thanuzkodi. E, Nathamani. M.	Toilet block removed, work completed		Maniyarasi. D. - Paediatrics Ward	21/01/2020
Comp. Dt. : 30/01/2020 Status : Completed								
3607	20010825	Male Ortho - Ward 403	WASH BASIN BLOCK	Rajendhiran. V.	Sink block removed, waste line fully rework, work completed		Maniyarasi. D. - Paediatrics Ward	30/01/2020
Comp. Dt. : 10/02/2020 Status : Completed								
3608	20020325	Paediatrics - Ward 309	REST ROOM BLOCK	Rajendhiran. V., Thanuzkodi. E, Nathamani. M.	Toilet block removed, work completed		Chitra. P. - Paediatrics Ward	15/02/2020
Comp. Dt. : 11/02/2020 Status : Completed								
3609	20020389	Paediatrics - Ward 310	REST ROOM BLOCK	Rajendhiran. V., Thanuzkodi. E, Nathamani. M.	Toilet block removed, work completed		Chitra. P. - Paediatrics Ward	15/02/2020
Comp. Dt. : 11/09/2020 Status : Completed								
3610	20090210	Female Casulaty	BATHROOM TAP PROBLEM	Rajendran. R.	Tap changed, work completed		Tamililakkiya. K. - RICU	12/09/2020
Comp. Dt. : 19/11/2020 Status : Completed								
3611	20110530	RICU	NEED LABOURS 2 NOS FOR COT ARRANGEMENTS	Yuvaraj. M., Prakash. N., Kannan. V.	Cot arrangement work completed		Tamililakkiya. K. - RICU	23/11/2020
Comp. Dt. : 24/11/2020 Status : Completed								
3612	20110684	Female Medical - Ward 306	RESTROOM TAP BROKEN - WATER FLOW - NEED URGENT SERVICE	Rajendran. R., Prakash. V., Arunagiri. V.	Ward 310 -New PVC Tap, pillar cock, flush tank washer and float washer changed, leakage arrested, wo		Kayalvizhi. G. - Paediatrics Ward	24/11/2020
Comp. Dt. : 07/12/2020 Status : Completed								
3613	20120226	Paediatrics - Ward 308	NEED LABOURS 2 NOS FOR EXAM ARRANGEMENTS ON 09.12.2020 FOR COT AND SCREEN	Pandiaraj. V.	Ward 308- arrangement work completed, Bero shifting from Ward 307 to paediatric OPD, work completed		Kayalvizhi. G. - Paediatrics Ward	07/12/2020

TRUE COPY ATTESTED
 24/11/2020
 DEAN
 BRI MANAKULA VINAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPAM,
 MADAGADIPET, PUDUCHERRY-605 107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
3614	20120228	Paediatrics - Ward 308	FLSUH NOT WORKING AT DOCTOR'S RESTROOM	Prakash. V.,Manikandan. S.,Rajendran. R.	Flush tank washer changed and full set rework, work completed		Kayalvizhi. G. - Paediatrics Ward	07/12/2020
Comp. Dt. : 08/12/2020 Status : Completed								
3615	20120302	Paediatrics - Ward 308	NEED LABOURS 3 NOS FOR COT ARRANGEMENT	Pandiaraj. V.,Senthil Kumar. R.,Yuvaraj. M.	Cot arrangement work completed		Kayalvizhi. G. - Paediatrics Ward	09/12/2020
Comp. Dt. : 06/01/2021 Status : Completed								
3616	21010187	Male Medical - Ward 303	NEED LABOURS 2 NOS FOR SHIFTING COT FROM 303 TO RICU	Pandiaraj. V.,Yuvaraj. M.,Thulasi. V.	Cot shifting work completed		Tamililakkiya. K. - RICU	08/01/2021
Comp. Dt. : 23/01/2021 Status : Completed								
3617	21010779	Male Surgery - Ward 201	REST ROOM BLOCK	Rajendhiran. V.	Toilet block removed, work completed		Maniyarasi. D. - Paediatrics Ward	23/01/2021
Comp. Dt. : 04/02/2021 Status : Completed								
3618	21020156	Paediatrics - Ward 308	WATER NOT COMING AT PATIENT REST ROOM	Kannan. J.,Thirisangu. S.,Prakash. V.	RO plant have to be serviced, problem solved on 05.02.2021		Kayalvizhi. G. - Paediatrics Ward	06/02/2021
Comp. Dt. : 06/02/2021 Status : Completed								
3619	21020221	Paediatrics - Ward 308	TAP BROKEN - WATER LEAKAGE - NEED URGENT SERVICE	Prakash. V.,Sellaveeran. M.,Ramkumar. R.	New elbow action pillar cock changed, work completed		Chitra. P. - Paediatrics Ward	10/02/2021
Comp. Dt. : 05/03/2021 Status : Completed								
3620	21030242	Paediatrics - Ward 309	COMMON REST ROOM BLOCK	Rajendhiran. V.	Common toilet block removed, work completed		Chitra. P. - Paediatrics Ward	05/03/2021
Comp. Dt. : 08/07/2021 Status : Completed								
3621	21070311	Female Medical - Ward 306	NEED LABOURS 4 NOS FOR COT SHIFTING WORK FROM III FLOOR TO 303 [NEED URGENT SERVICE]	Pandiaraj. V.,Yuvaraj. M.,Thulasi. V.	Cot shifting work completed		Chitra. P. - Paediatrics Ward	09/07/2021
Comp. Dt. : 10/08/2021 Status : Completed								

TRUE COPY ATTESTED

DEAN
 SRIMANAKULANATHAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALITHEERTHALKUPPA
 MADAGADIPET, PUDUCHERRY-605 007

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
3622	21080354	Female Medical - Ward 307	REST ROOM BLOCK - NEED TO CHANGE OUTLET WATER CLOSET -	Rajendhiran. V.,Thanuzkodi. E,Rajendran. R.	Toilet block removed, sink outlet line rework		Chitra. P. - Paediatrics Ward	10/08/2021
	Comp. Dt. : 07/09/2021							
	Status : Completed							
3623	21090245	Female Medical - Ward 307	NEED TO CHANGE INDIAN TOILET BASIN - DAMAGE & BROKEN	Arunagiri. V.,Prakash. V.,Ramkumar. R.	waiting for material - IWC and floor breaking work pending		Chitra. P. - Paediatrics Ward	17/01/2022
	Comp. Dt. : 11/10/2021							
	Status : Completed							
3624	21100320	Paediatrics - Ward 310	WATER LEAKAGE IN WASHBASIN TAP - NEED TO CHANGE	Prakash. V.	Sink stand broken, Inform to workshop dept, making new stand		Chitra. P. - Paediatrics Ward	10/11/2021
	Comp. Dt. : 15/10/2021							
	Status : Completed							
3625	21100416	RICU	REST ROOM BLOCK - NEED URGENT SERVICE	Rajendhiran. V.	2Nos of Toilet block removed, work completed		Anitha. N. - Hospital Infection Control	15/10/2021
	Comp. Dt. : 16/11/2021							
	Status : Completed							
3626	21110544	Paediatrics - Ward 309	BATHROOM BLOCK	Rajendhiran. V.	Toilet block removed on that day, work completed		Rajeswari. P. - Paediatrics Ward	17/11/2021
	Comp. Dt. : 02/12/2021							
	Status : Completed							
3627	21120074	Paediatrics Ward	SINK BLOCK IN WARD NO 310 & HEATER TAP LEAKAGE IN WARD NO 309	Prakash. V.	Ward 309,310- 3Nos of CP tap spindle and 5Nos of Angle valve spindle changed, all tap serviced and S		Chitra. P. - Paediatrics Ward	02/12/2021
	Comp. Dt. : 29/01/2022							
	Status : Completed							
3628	22010721	Paediatrics - Ward 309	NEED LABOURS 4 NOS FOR COT ARRANGEMENT WORK FOR EXAM PURPOSE	Yuvaraj. M.,Pandiaraj. V.,Prakash. N.	Cot shifting and arrangement work for exam purpose, work completed		Maniyarasi. D. - Paediatrics Ward	31/01/2022
	Comp. Dt. : 18/02/2022							
	Status : Completed							
3629	22020599	Paediatrics - Ward 310	RESTROOM BLOCK	Rajendhiran. V.,Thanuzkodi. E,Govindan. R.	Toilet block removed, work completed		Samina Sowkath. S. - Paediatrics Ward	18/02/2022
	Comp. Dt. : 09/03/2022							

TRUE COPY ATTESTED

DEAN

SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
MADAGADIPEI, PUDUCHERRY-605 107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
3630	22030306	Paediatrics Ward	NEED TO SPRAY MASQUITO SPRAY FOR WARD NO 309 & 310	Kannan. V.	Mosquito chemical sprayed		Chitra. P. - Paediatrics Ward	12/03/2022
Comp. Dt. : 29/03/2022								
Status : Completed								
3631	22031180	Paediatrics - Ward 309	SINK WATER NOT COMING - SINK LEAKAGE IN DOCTOR'S ROOM	Prakash. V.	CP Elbow action pillar cock rework, work completeda		Rajeswari. P. - Paediatrics Ward	05/04/2022
Comp. Dt. : 08/04/2022								
Status : Completed								
3632	22040325	Paediatrics - Ward 309	TAP WATER LEAKAGE IN DUTY DOCTOR ROOM	Arunagiri. V.	New spindle changed		Chitra. P. - Paediatrics Ward	11/04/2022
3633	22040326	Paediatrics - Ward 309	FLUSH NOT WORKING IN DOCTORS RESTROOM IN PAEDIATRIC WARD 309	Arunagiri. V.	Flush tank fullset cleaned and serviced, washer changed, problem solved		Chitra. P. - Paediatrics Ward	09/04/2022
Comp. Dt. : 13/04/2022								
Status : Completed								
3634	22040483	Paediatrics - Ward 309	SINK TAP DAMAGE - WATER FLOW AT DOCTOR'S ROOM - EXAM GOING ON NEED URGENT SERVICE	Prakash. V.,Rajendran. R.,Arunagiri. V.	New CP Elbow action tap changed, problem solved		Chitra. P. - Paediatrics Ward	18/04/2022
Comp. Dt. : 21/04/2022								
Status : Completed								
3635	22040717	Paediatrics Ward	NEED LABOURS 6 NOS FOR WARD ARRANGEMENT WARD NO 307,308,309 & 310	Pandiaraj. V.,Yuvaraj. M.,Thulasi. V.	All ward cot shifting and arrangement work completed		Chitra. P. - Paediatrics Ward	21/04/2022
Comp. Dt. : 23/04/2022								
Status : Completed								
3636	22040846	Paediatrics - Ward 310	SINK OUTLET HOSE DAMAGE & WATER LEAKAGE IN DOCTOR'S ROOM	Ramkumar. R.,Arunagiri. V.,Prakash. V.	Waste hose and waste coupling changed, waste water outlet line fully rework, work completed		Chitra. P. - Paediatrics Ward	27/04/2022
Comp. Dt. : 26/04/2022								
Status : Completed								
3637	22040917	Paediatrics - Ward 310	CEILING WATER LEAKAGE	Arunagiri. V.,Prakash. V.,Ramkumar. R.	Expansion joint leakage, inform to Project manager, WIP		Chitra. P. - Paediatrics Ward	29/04/2022
Comp. Dt. : 28/06/2022								
Status : Completed								

TRUE COPY ATTESTED
27/04/2022

DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
MADAGADIPET, PUDUCHERRY-605 107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
3638	22061032	Female Medical - Ward 305	NEED LABOURS 3 NOS FOR SHIFTING FRIDGE FROM GENERAL STORE TO FEMALE MEDICINE WARD INSIDE H I C C	Pandiaraj. V., Yuvaraj. M., Murali. K.	Fridge shifting work completed		Anitha. N. - Hospital Infection Control	01/07/2022
Comp. Dt. : 13/07/2022 Status : Completed								
3639	22070500	Paediatrics - Ward 309	BLOCK AT PATIENT RESTROOM & WASH BASIN	Thanuzkodi. E	Block removed		Chitra. P. - Paediatrics Ward	14/07/2022
Comp. Dt. : 21/07/2022 Status : Completed								
3640	22070802	Paediatrics - Ward 309	CEILING WATER LEAKAGE AT FAN CONNECTING WALL - NEED TO CHECK	Prakash. V., Rajendran. R., Ramkumar. R.	Expansion joint problem.		Naveena. N. - Paediatrics Ward	26/07/2022
Comp. Dt. : 27/09/2022 Status : Completed								
3641	22091090	Paediatrics - Ward 309	NEED TO REFIX WASH BASIN ELBOW TAP AT DUTY DOCTOR'S ROOM	Rajendran. R., Ramkumar. R., Arunagiri. V.	Connection tube changed and elbow action tap rework.		Chitra. P. - Paediatrics Ward	28/09/2022
Comp. Dt. : 30/09/2022 Status : Completed								
3642	22091211	Paediatrics - Ward 310	BLOCK IN RESTROOM	Rajendhiran. V., Murugan. S., Thanuzkodi. E	Block removed.		Chitra. P. - Paediatrics Ward	01/10/2022
Comp. Dt. : 03/11/2022 Status : Completed								
3643	22110089	Paediatrics - Ward 309	TOILET BLOCKED, NEED SCAVENGER	Murugan. S., Rajendhiran. V., Thanuzkodi. E	Block removed.		Chitra. P. - Paediatrics Ward	03/11/2022
3644	22110090	Paediatrics - Ward 310	WASH BASIN SINK TAP BROKEN	Prakash. V., Rajendran. R., Ramkumar. R.	Wash basin pillar cock rework.		Chitra. P. - Paediatrics Ward	04/11/2022
Comp. Dt. : 09/11/2022 Status : Completed								
3645	22110356	Paediatrics - Ward 310	WASH BASIN SINK TAP WATER LEAKAGING PROBLEM	Prakash. V., Rajendran. R., Ramkumar. R.	Tap rework done.		Naveena. N. - Paediatrics Ward	10/11/2022
3646	22110370	Paediatrics - Ward 309	WASH BASIN SINK HOSE LEAKAGING PROBLEM	Prakash. V., Rajendran. R., Ramkumar. R.	Wash basin waste water outlet line fully rework, work completed		Chitra. P. - Paediatrics Ward	14/11/2022
Comp. Dt. : 10/11/2022								

TRUE COPY ATTESTED

DEAN
SRI MANAKULA VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
MADAGADIPEI, PUDUCHERRY-605 107.
10/11/2022

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Status : Completed								
3647	22110410	Paediatrics - Ward 309	WASH BASIN SINK HOSE WATER LEAKAGING PROBLEM	Rajendran. R.,Manikandan. S.,Sankar. V.	Wash basin waste water outlet line fully rework, work completed		Naveena. N. - Paediatrics Ward	14/11/2022
Comp. Dt. : 18/11/2022								
Status : Completed								
3648	22110792	Paediatrics - Ward 308	NEED TO CHECK FLOOR - WATER LEAKAGE - NEED URGENT SERVICE	Prakash. V.,Rajendran. R.,Ramkumar. R.	Expansion joint water leakage		Chitra. P. - Paediatrics Ward	23/11/2022
Comp. Dt. : 19/11/2022								
Status : Completed								
3649	22110826	Paediatrics - Ward 308	NEED MANPOWER FOR COT ARRANGEMENTS WORK	Pandiaraj. V.,Yuvaraj. M.,Thulasi. V.	Cot arrangement work completed		Chitra. P. - Paediatrics Ward	21/11/2022
Comp. Dt. : 21/11/2022								
Status : Completed								
3650	22110847	Paediatrics - Ward 308	NEED LABOURS 2 NO'S FOR SCREEN FIXING WORK IN 307 AND 308 WARD	Pandiaraj. V.	Screen fixing work completed.		Rajeswari. P. - Paediatrics Ward	22/11/2022
Comp. Dt. : 22/11/2022								
Status : Completed								
3651	22110953	Paediatrics Ward	NEED LABOURS 4 NOS FOR WARD REARRANGEMENT WORK - WARD NO 307 & 308	Pandiaraj. V.,Yuvaraj. M.,Senthil Kumar. R.	Ward rearrangement work done.		Chitra. P. - Paediatrics Ward	25/11/2022
Comp. Dt. : 28/11/2022								
Status : Completed								
3652	22111168	Paediatrics - Ward 308	NEED LABOURS 2 NO'S FOR SCREEN REMOVING WORK	Pandiaraj. V.	Screen removed.		Chitra. P. - Paediatrics Ward	01/12/2022
Comp. Dt. : 30/11/2022								
Status : Completed								
3653	22111257	Female Medical - Ward 307	WATER LEAKAGE IN WASH BASIN DRAINAGE PIPE LINE & WASH BASIN - NEED TO CHECK & CHANGE AT PAEDOATRIC	Rajendran. R.,Manikandan. S.,Sankar. V.	Wash basin drain pipe line connection rework done.		Chitra. P. - Paediatrics Ward	01/12/2022
Comp. Dt. : 10/12/2022								
Status : Completed								

TRUE COPY ATTESTED

DEAN
SRINIVASAKUL VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
KALITHEERTHALKUPPAM,
MADAGADIPET, PUDUCHERRY-605 007.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
3654	22120494	Paediatrics - Ward 308	TOILET BLOCKED,NEED SCAVENGER	Rajendhiran. V.,Thanuzkodi. E,Murugan. S.	block removed.		Rajeswari. P. - Paediatrics Ward	12/12/2022
Comp. Dt. : 30/12/2022 Status : Completed								
3655	22121365	Paediatrics - Ward 308	TOILET BLOCKED,NEED SCAVENGER	Rajendhiran. V.	Block removed.		Rajeswari. P. - Paediatrics Ward	31/12/2022
Dept Name : PATHOLOGY - Civil - Maintenance Comp. Dt. : 04/06/2021 Status : Completed								
3656	21060104	PATHOLOGY IN COLLEGE	NEED TO CHANGE ELBOW TAP [2NPS]	Sivaraja. M.	2Nos of new Elbow action tap changed, work completed		Sathia Rajesh. C. - PATHOLOGY	05/06/2021
Comp. Dt. : 02/12/2021 Status : Completed								
3657	21120082	PATHOLOGY IN COLLEGE	TAP DAMAGE - WATER LEAK IN LAB	Sellaveeran. M.	Tap changed, work completed		Kalaichelvi.M. - PATHOLOGY	04/12/2021
Comp. Dt. : 29/12/2021 Status : Completed								
3658	21121102	FNAC ROOM	WASH BASIN WATER LEAKAGE	Rajendran. R.,Arunagiri. V.,Manikandan. S.	New Wash basin fixed, water line connection given, work completed		Vijayalakshmi. R. - PATHOLOGY	29/12/2021
Comp. Dt. : 30/08/2022 Status : Completed								
3659	22081028	PATHOLOGY IN COLLEGE	NEED PLUMBER FOR PIPELINE ALTER WORK	Udhaya Kumar. R.	3/4" UPVC pipe line and 1.1/2" waste water pipe line fully changed for two nos of machines, work com		Sathia Rajesh. C. - PATHOLOGY	03/09/2022
Dept Name : PHARMACOLOGY - Civil - Maintenance Comp. Dt. : 30/06/2021 Status : Completed								
3660	21060810	PHARMACOLOGY	TAP BROKEN - WATER FLOW - NEED URGENT SERVICE -	Anandharaj. M.	New Tap changed, work completed		Panchali. P. - PHARMACOLOGY	08/07/2021
Comp. Dt. : 24/09/2022 Status : Completed								
3661	22090972	Main Gate	NEED LABOURS 2 NOS FOR BANNER REMOVING WORK AT MAIN GATE ENTRANCE	Pandiaraj. V.	Banner removed.		Panchali. P. - PHARMACOLOGY	26/09/2022

TRUE COPY ATTESTED

DEAN
SRINIVASULU VINAYAGAR
MEDICAL COLLEGE & HOSPITAL
MADAGADIPET, PUDUCHERRY-605 107.

S.No.	Comp. No.	Location	Problem	Assign To	Solution	Remarks	Created User	Close Dt
Comp. Dt. : 27/09/2022 Status : Completed								
3662	22091050	PHARMACOLOGY	NEED LABOUR 1 NO FOR RACK SHIFTING WORK	Pandiaraj. V.	Rack shifting work completed.		Devanathan. S. - PHARMACOLOGY	01/10/2022
Dept Name : Pharmacy - Civil - Maintenance Comp. Dt. : 04/03/2020 Status : Completed								
3663	20030127	COMMON TOILET NEAR FREE PHARMACY	GENTS TOILET BLOCK,NEED SCAVENGER	Rajendhiran. V.,Thanuzkodi. E,Nathamani. M.	Toilet block removed, work completed		Bremavathy.P. - Pharmacy	05/03/2020
Comp. Dt. : 10/06/2020 Status : Completed								
3664	20060306	COMMON TOILET NEAR FREE PHARMACY	TOILET BLOCKED,BAD SMELL PROBLEM,NEED SCAVENGER	Thanuzkodi. E	Toilet block removed, work completed		Bremavathy.P. - Pharmacy	10/06/2020
Comp. Dt. : 10/09/2020 Status : Completed								
3665	20090184	LADIES STAFF TOILET NEAR PSYCHIATRY OPD-H WING	water not coming	Prakash. V.,Ramkumar. R.,Rajendran. R.	POW to be ready in covid ward purpose, 8 nos of bathroom plumbing fittings fixed, so valve closed, a		Bremavathy.P. - Pharmacy	12/09/2020
Comp. Dt. : 09/10/2020 Status : Completed								
3666	20100248	Free Pharmacy	TAP BROKEN WATER FLOW NEED URGENT SERVICE	Prakash. V.	Wrong complaint, flush tank washer changed, leakage arrested, now problem solved		Bremavathy.P. - Pharmacy	10/10/2020
Comp. Dt. : 27/10/2020 Status : Completed								
3667	20100676	COMMON TOILET NEAR FREE PHARMACY	TAP BROKEN - NEED TO CHANGE TAP - NEED URGENT SERVICE	Prakash. V.	New Tap changed, work completed		Bremavathy.P. - Pharmacy	28/10/2020
Comp. Dt. : 03/11/2020 Status : Completed								
3668	20110064	GENT'S STAFF TOILET NEAR SKIN OPD	ALL WATER TAP GOT DAMAGED-REQUEST TO CHANGE IT	Ramkumar. R.	All tap checking, block removed and New PVC pillar cock changed, sink refixed, work completed		Silambuselvan. P. - Pharmacy	04/11/2020
Comp. Dt. : 29/12/2020 Status : Completed								

TRUE COPY ATTESTED

DEAN
 SRIMANAKULANAYAGAR
 MEDICAL COLLEGE & HOSPITAL
 KALYANESWARI, KUPPAM,
 MADAGADIPET, PUDUCHERRY